



Tennessee Valley Authority  
1101 Market Street, LP 3R  
Chattanooga, Tennessee 37402-2801

R. M. Krich  
Vice President  
Nuclear Licensing

April 21, 2010

10 CFR 50.4

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555-0001

Browns Ferry Nuclear Plant, Unit 3  
Facility Operating License No. DPR-68  
NRC Docket No. 50-296

Subject: **Browns Ferry Nuclear Plant, Unit 3, Core Operating Limits Report for  
Cycle 15 Operation**

In accordance with the requirements of Technical Specification 5.6.5.d, the Tennessee Valley Authority is submitting the Unit 3, Cycle 15, Core Operating Limits Report (COLR), Revision 1. Revision 0 of the Unit 3, Cycle 15, COLR was previously issued. It contained the Shutdown Margin criteria in support of fuel loading for Cycle 15 (Mode 5 operation). Revision 1 to the Unit 3, Cycle 15, COLR includes all modes of operation (Modes 1 through 5).

There are no new commitments contained in this letter. If you have any questions, please contact Terry Cribbe at (423) 751-3850.

Respectfully,

R. M. Krich

Enclosure:

Browns Ferry, Unit 3, Cycle 15, Core Operating Limits Report, (105% OLTP),  
TVA-COLR-BF3C15, Revision 1 (Final)

cc: See Page 2

DO30  
NRK

U.S. Nuclear Regulatory Commission  
Page 2  
April 21, 2010

cc: (w/Enclosure):

NRC Regional Administrator - Region II  
NRC Senior Resident Inspector - Browns Ferry Nuclear Plant

**Enclosure  
Tennessee Valley Authority  
Browns Ferry Nuclear Plant  
Unit 3**

**Browns Ferry, Unit 3, Cycle 15, Core Operating Limits Report, (105% OLTP),  
TVA-COLR-BF3C15, Revision 1 (Final)**

---

**(See Attached)**




**Nuclear Fuel Engineering - BWRFE**  
1101 Market Street, Chattanooga, TN 37402


# **Browns Ferry Unit 3 Cycle 15**


## **Core Operating Limits Report, (105% OLTP)**


**TVA-COLR-BF3C15** Revision 1 (Final)  
(Revision Log, Page v)


**March 2010**

Prepared:  Date: March 15, 2010  
T. W. Eichenberg, Sr. Specialist

Verified:  Date: 3/15/10  
B. C. Mitchell, Engineer

Approved:  Date: 3/15/10  
G. C. Storey, Manager, BWR Fuel Engineering

Reviewed:  Date: 3/19/10  
M. J. Keck, Manager, Reactor Engineering

Approved:  Date: 3/19/2010  
Chairman, PORC

## Table of Contents

Total Number of Pages = 34 (including review cover sheet)

List of Tables .....	iii
List of Figures .....	iv
Revision Log .....	v
Nomenclature .....	vi
References .....	viii
1 Introduction .....	1
1.1 Purpose .....	1
1.2 Scope .....	1
1.3 Fuel Loading .....	1
1.4 Acceptability .....	1
2 APLHGR Limits .....	3
2.1 Rated Power and Flow Limit: $APLHGR_{RATED}$ .....	3
2.2 Off-Rated Power Dependent Limit: $APLHGR_P$ .....	3
2.3 Off-Rated Flow Dependent Limit: $APLHGR_F$ .....	3
2.4 Single Loop Operation Limit: $APLHGR_{SLO}$ .....	3
2.5 Equipment Out-Of-Service Corrections .....	5
3 LHGR Limits .....	6
3.1 Rated Power and Flow Limit: $LHGR_{RATED}$ .....	6
3.2 Off-Rated Power Dependent Limit: $LHGR_P$ .....	6
3.3 Off-Rated Flow Dependent Limit: $LHGR_F$ .....	6
3.4 Equipment Out-Of-Service Corrections .....	6
4 OLMCPR Limits .....	10
4.1 Flow Dependent MCPR Limit: $MCPR_F$ .....	10
4.2 Power Dependent MCPR Limit: $MCPR_P$ .....	10
4.2.1 Scram Speed Dependent Limits (TSSS vs. NSS) .....	10
4.2.2 Exposure Dependent Limits .....	12
4.2.3 Equipment Out-Of-Service (EOOS) Options .....	13
4.2.4 Single-Loop-Operation (SLO) Limits .....	13
4.2.5 Below Pypass Limits .....	13
5 APRM Flow Biased Rod Block Trip Settings .....	18
6 Rod Block Monitor (RBM) Trip Setpoints and Operability .....	19
7 Shutdown Margin Limit .....	21
Appendix A: Thermal-Hydraulic Stability .....	22

**List of Tables**

Nuclear Fuel Types ..... 2  
Nominal Scram Time Basis ..... 12  
MCPR<sub>p</sub> Limits for Nominal Scram Time Basis ..... 14  
MCPR<sub>p</sub> Limits for Technical Specification Scram Time Basis ..... 16  
Analytical RBM Trip Setpoints ..... 19  
RBM Setpoint Applicability ..... 19  
Control Rod Withdrawal Error Results ..... 20  
OPRM Setpoints ..... 24



1101 Market Street, Chattanooga, TN 37402

Date: March 15, 2010

EDMS: L32 100315 801

---

## List of Figures

APLHGR <sub>RATED</sub> for ATRIUM-10 Fuel .....	4
LHGR <sub>RATED</sub> for ATRIUM-10 Fuel .....	7
LHGRFAC <sub>P</sub> for ATRIUM-10 Fuel .....	8
LHGRFAC <sub>F</sub> for ATRIUM-10 Fuel .....	9
MCPR <sub>F</sub> for ATRIUM-10 Fuel .....	11

## Revision Log

Number	Page	Description
1-R1	All	Revised to support all modes of operation. Converted format to BWRFE report style.
2-R1	vi	Eliminated unnecessary Nomenclature items.
3-R1	viii-x	Added 5 new references (1-5). Added new methodology references (22-23) in support of Appendix for OPRM setpoints. Added PRNM setpoint references (24-27).
4-R1	1	Updated Section 1.2 scope to support all modes.
5-R1	3-24	Added new material for Sections 2 through 6. The previous Section 2 becomes new Section 7. Added new appendix discussing OPRM setpoints for RPS instrumentation.
1-R0	All	New document, per NFTP-111, Section 3.3, Item Q.



## Nomenclature

APLHGR	Average Planar LHGR
APRM	Average Power Range Monitor
AREVA NP	Vendor (Framatome, Siemens)
BOC	Beginning of Cycle
BSP	Backup Stability Protection
BWR	Boiling Water Reactor
CAVEX	Core Average Exposure
CD	Coast Down
CMSS	Core Monitoring System Software
COLR	Core Operating Limits Report
CPR	Critical Power Ratio
CRWE	Control Rod Withdrawal Error
CSDM	Cold SDM
DIVOM	Delta CPR over Initial CPR vs. Oscillation Magnitude
EOC	End of Cycle
EOOS	Equipment OOS
FFTR	Final Feedwater Temperature Reduction
FFWTR	Final Feedwater Temperature Reduction
FHOOS	Feedwater Heaters OOS
ft	Foot: english unit of measure for length
GWd	Giga Watt Day
HTSP	High TSP
ICA	Interim Corrective Action
ICF	Increased Core Flow (beyond rated)
IS	In-Service
kW	kilo watt: SI unit of measure for power.
LCO	License Condition of Operation
LFWH	Loss of Feedwater Heating
LHGRFAC	LHGR Multiplier (Power or Flow dependent)
LPRM	Low Power Range Monitor
LRNB	Generator Load Reject, No Bypass
MAPFAC	MAPLHGR multiplier (Power or Flow dependent)
MCPR	Minimum CPR



---

MSRV	Moisture Separator Reheater Valve
MSRVOOS	MSRV OOS
MTU	Metric Ton Uranium
MWd/MTU	Mega Watt Day per Metric Ton Uranium
NEOC	Near EOC
NRC	United States Nuclear Regulatory Commission
NSS	Nominal Scram Speed
NTSP	Nominal TSP
OLMCPR	MCPR Operating Limit
OOS	Out-Of-Service
OPRM	Oscillation Power Range Monitor
PBDA	Period Based Detection Algorithm
Pbypass	Power, below which TSV Position and TCV Fast Closure Scrams are Bypassed
PLU	Power Load Unbalance
PLUOOS	PLU OOS
PRNM	Power Range Neutron Monitor
RBM	Rod Block Monitor
RPS	Reactor Protection System
RPT	Recirculation Pump Trip
RPTOOS	RPT OOS
SDM	Shutdown Margin
SLMCPR	MCPR Safety Limit
SLO	Single Loop Operation
TBV	Turbine Bypass Valve
TBVIS	TBV IS
TBVOOS	Turbine Bypass Valves OOS
TIP	Transversing In-core Probe
TIPOOS	TIP OOS
TLO	Two Loop Operation
TSP	Trip Setpoint
TSSS	Technical Specification Scram Speed
TVA	Tennessee Valley Authority

---

## References

1. ANP-2895, Revision 0, **Browns Ferry Unit 3 Cycle 15 Reload Safety Analysis**, AREVA NP, Inc., February 2010.
2. EMF-3213(P) Revision 0, **Mechanical Design Report for Browns Ferry Unit 3 Reload BFE3-13 ATRIUM-10 Fuel Assemblies**, Framatome ANP, Inc., September 2005.
3. ANP-2628(P) Revision 0, **Mechanical Design Report for Browns Ferry Unit 3 Reload BFE3-14 ATRIUM™-10 Fuel Assemblies**, AREVA NP, Inc., May 2007.
4. ANP-2838(P) Revision 0, **Mechanical Design Report for Browns Ferry Unit 3 Reload BFE3-15 ATRIUM™-10 Fuel Assemblies**, AREVA NP, Inc., August 2009.
5. ANP-2806(P) Revision 0, **Browns Ferry Unit 3 Cycle 15 Plant Parameters Document**, AREVA NP, Inc., June 2009.
6. BFE-2904, Revision 1, "*Browns Ferry Unit 3 Reload 14 In-Core Shuffle Verification*," Calculation File, Tennessee Valley Authority, February 2010.

### Methodology References

7. XN-NF-81-58(P)(A) Revision 2 and Supplements 1 and 2, **RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model**, Exxon Nuclear Company, March 1984.
8. XN-NF-85-67(P)(A) Revision 1, **Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel**, Exxon Nuclear Company, September 1986.
9. EMF-85-74(P) Revision 0 Supplement 1(P)(A) and Supplement 2(P)(A), **RODEX2A (BWR) Fuel Rod Thermal-Mechanical Evaluation Model**, Siemens Power Corporation, February 1998.
10. ANF-89-98(P)(A) Revision 1 and Supplement 1, **Generic Mechanical Design Criteria for BWR Fuel Designs**, Advanced Nuclear Fuels Corporation, May 1995.
11. XN-NF-80-19(P)(A) Volume 1 and Supplements 1 and 2, **Exxon Nuclear Methodology for Boiling Water Reactors - Neutronic Methods for Design and Analysis**, Exxon Nuclear Company, March 1983.
12. XN-NF-80-19(P)(A) Volume 4 Revision 1, **Exxon Nuclear Methodology for Boiling Water Reactors: Application of the ENC Methodology to BWR Reloads**, Exxon Nuclear Company, June 1986.

13. EMF-2158(P)(A) Revision 0, **Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2**, Siemens Power Corporation, October 1999.
14. XN-NF-80-19(P)(A) Volume 3 Revision 2, **Exxon Nuclear Methodology for Boiling Water Reactors, THERMEX: Thermal Limits Methodology Summary Description**, Exxon Nuclear Company, January 1987.
15. XN-NF-84-105(P)(A) Volume 1 and Volume 1 Supplements 1 and 2, **XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis**, Exxon Nuclear Company, February 1987.
16. ANF-524(P)(A) Revision 2 and Supplements 1 and 2, **ANF Critical Power Methodology for Boiling Water Reactors**, Advanced Nuclear Fuels Corporation, November 1990.
17. ANF-913(P)(A) Volume 1 Revision 1 and Volume 1 Supplements 2, 3 and 4, **COTRANSA2: A Computer Program for Boiling Water Reactor Transient Analyses**, Advanced Nuclear Fuels Corporation, August 1990.
18. ANF-1358(P)(A) Revision 1, **The Loss of Feedwater Heating Transient in Boiling Water Reactors**, Advanced Nuclear Fuels Corporation, September 1992.
19. EMF-2209(P)(A) Revision 3, **SPCB Critical Power Correlation**, Siemens Power Corporation, September 2009.
20. EMF-2361(P)(A) Revision 0, **EXEM BWR-2000 ECCS Evaluation Model**, Framatome ANP Inc., May 2001.
21. EMF-2292(P)(A) Revision 0, **ATRIUM™-10: Appendix K Spray Heat Transfer Coefficients**, Siemens Power Corporation, September 2000.
22. EMF-CC-074(P)(A), Volume 4, Revision 0, **BWR Stability Analysis: Assessment of STAIF with Input from MICROBURN-B2**, Siemens Power Corporation, August 2000.
23. BAW-10255(P)(A), Revision 2, **Cycle-Specific DIVOM Methodology Using the RAMONA5-FA Code**, Framatome ANP, Inc., May, 2008.

PRNM Setpoint References

24. Filtered Setpoints - EDE-28-0990 Rev. 3 Supplement E, "PRNM (APRM, RBM, and RFM) Setpoint Calculations [ARTS/MELL (NUMAC) - Power-Uprate Condition] for Tennessee Valley Authority Browns Ferry Nuclear Plant", October 1997.
25. Unfiltered Setpoints - EDE-28-0990 Rev. 2 Supplement E, "PRNM (APRM, RBM, and RFM) Setpoint Calculations [ARTS/MELL (NUMAC) - Power-Uprate Condition] for Tennessee Valley Authority Browns Ferry Nuclear Plant", October 1997.



1101 Market Street, Chattanooga, TN 37402

## Nuclear Fuel Engineering - BWRFE

**Date:** March 15, 2010

**EDMS:** L32 100315 801

- 
26. GE Letter LB#: 262-97-133, Browns Ferry Nuclear Plant Rod Block Monitor Setpoint Clarification - GE Proprietary Information, September 12, 1997.
  
  27. NEDC-32433P, **Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Unit 1, 2, and 3**, GE Nuclear Energy, April 1995.

---

## 1 Introduction

In anticipation of cycle startup, it is necessary to describe the expected limits of operation.

### 1.1 Purpose

The primary purpose of this document is to satisfy requirements identified by unit technical specification section 5.6.5. This document may be provided, upon final approval, to the NRC.

### 1.2 Scope

This document will discuss the following areas:

- Average Planar Linear Heat Generation Rate (APLHGR) Limit  
(Technical Specifications 3.2.1 and 3.7.5)
- Linear Heat Generation Rate (LHGR) Limit  
(Technical Specification 3.2.3, 3.3.4.1, and 3.7.5)
- Minimum Critical Power Ratio Operating Limit (OLMCPR)  
(Technical Specifications 3.2.2, 3.3.4.1, and 3.7.5)
- Average Power Range Monitor (APRM) Flow Biased Rod Block Trip Setting  
(Technical Requirements Manual Section 5.3.1 and Table 3.3.4-1)
- Rod Block Monitor (RBM) Trip Setpoints and Operability  
(Technical Specification Table 3.3.2.1-1)
- Shutdown Margin (SDM) Limit  
(Technical Specification 3.1.1)

### 1.3 Fuel Loading

The core will contain all AREVA NP, Inc., ATRIUM-10 fuel. Nuclear fuel types used in the core loading are shown in Table 1.1. The core shuffle and final loading were explicitly evaluated for BOC cold shutdown margin performance as documented in Reference 6.

### 1.4 Acceptability

Limits discussed in this document were generated based on NRC approved methodologies per References 7 through 23.

Table 1.1 Nuclear Fuel Types

Fuel Description	Original Cycle	Number of Assemblies	Nuclear Fuel Type (NFT)	Fuel Names (Range)
ATRIUM-10 A10-4171B-14GV80-FCB	13	43	1	FCB001-FCB064
ATRIUM-10 A10-4163B-16GV80-FCB	13	68	2	FCB065-FCB232
ATRIUM-10 A10-4181B-13GV80-FCB	13	64	3	FCB233-FCB296
ATRIUM-10 A10-4218B-15GV80-FCC	14	215	4	FCC001-FCC216
ATRIUM-10 A10-4218B-13GV80-FCC	14	72	5	FCC219-FCC290
ATRIUM-10 A10-3831B-15GV80-FCD	15	200	6	FCD001-FCD200
ATRIUM-10 A10-3403B-9GV80-FCD	15	20	7	FCD257-FCB276
ATRIUM-10 A10-3392B-10GV80-FCD	15	36	8	FCD221-FCB256
ATRIUM-10 A10-4218B-15GV80-FCC	15	2	9	FCC217-FCC218
ATRIUM-10 A10-4218B-13GV80-FCC	15	4	10	FCC307-FCC310
ATRIUM-10 A10-3757B-10GV80-FCC	15	40	11	FCC335-FCC374

The table identifies the expected fuel type breakdown in anticipation of final core loading. The final composition of the core depends upon uncertainties during the outage such as discovering a failed fuel bundle, or other bundle damage. Minor core loading changes, due to unforeseen events, will conform to the safety and monitoring requirements identified in this document.

## 2 APLHGR Limits

### (Technical Specifications 3.2.1 & 3.7.5)

The APLHGR limit is determined by adjusting the rated power APLHGR limit for off-rated power, off-rated flow, and SLO conditions. The most limiting of these is then used as follows:

$$\text{APLHGR limit} = \text{MIN} ( \text{APLHGR}_P , \text{APLHGR}_F , \text{APLHGR}_{\text{SLO}} )$$

where:

APLHGR <sub>P</sub>	off-rated power APLHGR limit	[APLHGR <sub>RATED</sub> * MAPFAC <sub>P</sub> ]
APLHGR <sub>F</sub>	off-rated flow APLHGR limit	[APLHGR <sub>RATED</sub> * MAPFAC <sub>F</sub> ]
APLHGR <sub>SLO</sub>	SLO APLHGR limit	[APLHGR <sub>RATED</sub> * SLO Multiplier]

### 2.1 Rated Power and Flow Limit: APLHGR<sub>RATED</sub>

The rated conditions APLHGR, for all fuel types, is identified in Reference 1 and shown in Figure 2.1.

### 2.2 Off-Rated Power Dependent Limit: APLHGR<sub>P</sub>

Reference 1, for ATRIUM-10 fuel, does not specify a power dependent APLHGR. Therefore, MAPFAC<sub>P</sub> is set to a value of 1.0.


### 2.3 Off-Rated Flow Dependent Limit: APLHGR<sub>F</sub>

Reference 1, for ATRIUM-10 fuel, does not specify a flow dependent APLHGR. Therefore, MAPFAC<sub>F</sub> is set to a value of 1.0.

### 2.4 Single Loop Operation Limit: APLHGR<sub>SLO</sub>

The single loop operation multiplier for ATRIUM-10 fuel is **0.85**, per Reference 1.





Planar Avg. Exposure (GWd/MTU)	APLHGR Limit (kW/ft)
0.0	12.5
15.0	12.5
67.0	7.3

Figure 2.1 APLHGR<sub>RATED</sub> for ATRIUM-10 Fuel

---

## 2.5 Equipment Out-Of-Service Corrections

The limit shown in Figure 2.1 is applicable for operation with all equipment In-Service as well as the following Equipment Out-Of-Service (EOOS) options; including combinations of the options:

In-Service	All equipment In-Service (includes 1 SRVOOS)
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
PLUOOS	Power Load Unbalance Out-Of-Service
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service or Final Feedwater Temperature Reduction

Single Recirculation Loop Operation (SLO) requires the application of the SLO multipliers to the rated APLHGR limits as described previously.

### 3 LHGR Limits

(Technical Specification 3.2.3, 3.3.4.1, & 3.7.5)

The LHGR limit is determined by adjusting the rated power LHGR limit for off-rated power and off-rated flow conditions. The most limiting of these is then used as follows:

$$\text{LHGR limit} = \text{MIN} (\text{LHGR}_P, \text{LHGR}_F)$$

where:

LHGR <sub>P</sub>	off-rated power LHGR limit	$[\text{LHGR}_{\text{RATED}} * \text{LHGRFAC}_P]$
LHGR <sub>F</sub>	off-rated flow LHGR limit	$[\text{LHGR}_{\text{RATED}} * \text{LHGRFAC}_F]$

#### 3.1 Rated Power and Flow Limit: LHGR<sub>RATED</sub>

The rated conditions LHGR, for all fuel types, is identified in Reference 1 and shown in Figure 3.1. The LHGR limit is consistent with References 2, 3, and 4.

#### 3.2 Off-Rated Power Dependent Limit: LHGR<sub>P</sub>

The ATRIUM-10 fuel, LHGR limits are adjusted for off-rated power conditions using the LHGRFAC<sub>P</sub> multiplier provided in Reference 1. The multiplier is split into two sub cases: turbine bypass valves in and out-of-service. The multipliers are shown in Figure 3.2.

#### 3.3 Off-Rated Flow Dependent Limit: LHGR<sub>F</sub>

The ATRIUM-10 fuel, LHGR limits are adjusted for off-rated flow conditions using the LHGRFAC<sub>F</sub> multiplier provided in Reference 1. The multiplier is shown in Figure 3.3.


#### 3.4 Equipment Out-Of-Service Corrections

The limit shown in Figure 3.1 is applicable for operation with all equipment In-Service as well as the following Equipment Out-Of-Service (EOOS) options; including combinations of the options.

In-Service	All equipment In-Service
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
PLUOOS	Power Load Unbalance Out-Of-Service
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service or Final Feedwater Temperature Reduction
SLO	Single Loop Operation, One Recirculation Pump Out-Of-Service


\* All equipment service conditions assume 1 SRVOOS.

The off-rated power corrections shown in Figure 3.2 are dependent on operation of the Turbine Bypass Valve system. For this reason, separate limits are to be applied for TBVIS or TBVOOS operation. The limits have no dependency on RPTOOS, PLUOOS, FHOOS/FFWTR, or SLO.




Pellet Exposure (GWd/MTU)	LHGR Limit (kW/ft)
0.0	13.4
18.9	13.4
74.4	7.1

Figure 3.1 LHGR<sub>RATED</sub> for ATRIUM-10 Fuel



Turbine Bypass In-Service		Turbine Bypass Out-of-Service	
Core Power	LHGRFAC <sub>p</sub>	Core Power	LHGRFAC <sub>p</sub>
(% Rated)		(% Rated)	
100.0	1.00	100.0	0.90
30.0	0.63	30.0	0.63
<b>Core Flow &gt; 50% Rated</b>		<b>Core Flow &gt; 50% Rated</b>	
30.0	0.54	30.0	0.44
25.0	0.49	25.0	0.40
<b>Core Flow ≤ 50% Rated</b>		<b>Core Flow ≤ 50% Rated</b>	
30.0	0.58	30.0	0.52
25.0	0.54	25.0	0.46

Figure 3.2 LHGRFAC<sub>p</sub> for ATRIUM-10 Fuel  
(Independent of other EOOS conditions)



Core Flow (% Rated)	LHGRFAC <sub>F</sub>
30.0	0.91
47.8	1
107.0	1

Figure 3.3 LHGRFAC<sub>F</sub> for ATRIUM-10 Fuel  
(Values bound all EOOS conditions)

(107.0% maximum core flow line is used to support 105% rated flow operation, ICF)

## 4 OLMCPR Limits

(Technical Specification 3.2.2, 3.3.4.1, & 3.7.5)

OLMCPR is calculated to be the most limiting of the flow or power dependent values

$$\text{OLMCPR limit} = \text{MAX} ( \text{MCPR}_F , \text{MCPR}_P )$$

where:

$\text{MCPR}_F$  core flow-dependent MCPR limit  
 $\text{MCPR}_P$  power-dependent MCPR limit

### 4.1 Flow Dependent MCPR Limit: $\text{MCPR}_F$

$\text{MCPR}_F$  limits are dependent upon core flow (% of Rated), and the max core flow limit, (Rated or Increased Core Flow, ICF).  $\text{MCPR}_F$  limits are shown in Figure 4.1, per Reference 1. Limits are valid for all EOOS combinations. No adjustment is required for SLO conditions.

### 4.2 Power Dependent MCPR Limit: $\text{MCPR}_P$

$\text{MCPR}_P$  limits are dependent upon:

- Core Power Level (% of Rated)
- Technical Specification Scram Speed (TSSS) or Nominal Scram Speed (NSS)
- Cycle Operating Exposure (NEOC, EOC, and CD - as defined in this section)
- Equipment Out-Of-Service Options
- Two or Single recirculation Loop Operation (TLO vs. SLO)


The  $\text{MCPR}_P$  limits are provided in the following tables, where each table contains the limits for all fuel types and EOOS options (for a specified scram speed and exposure range). The CMSS determines  $\text{MCPR}_P$  limits, from these tables, based on linear interpolation between the specified powers.

#### 4.2.1 Scram Speed Dependent Limits (TSSS vs. NSS)

$\text{MCPR}_P$  limits are provided for two different sets of assumed scram speeds. The Technical Specification Scram Speed (TSSS)  $\text{MCPR}_P$  limits are applicable at all times, as long as the scram time surveillance demonstrates the times in Technical Specification Table 3.1.4-1 are met. Nominal Scram Speeds (NSS) may be used, as long as the scram time surveillance demonstrates Table 4.1 times are applicable.<sup>†</sup>

\* Reference 1 analysis results are based on information identified in Reference 5.

† Assumption basis is consistent with method used to perform actual timing measurements, (i.e., including pickup/dropout effects).



Core Flow (% Rated)	MCPR <sub>F</sub>
30.0	1.61
78.0	1.28
107.0	1.28

Figure 4.1 MCPR<sub>F</sub> for ATRIUM-10 Fuel  
(Values bound all EOOS conditions)

(107.0% maximum core flow line is used to support 105% rated flow operation, ICF)



Table 4.1 Nominal Scram Time Basis

<b>Notch Position</b>	<b>Nominal Scram Timing</b>
<b>(index)</b>	<b>(seconds)</b>
46	0.42
36	0.98
26	1.60
6	2.90

In demonstrating compliance with nominal scram time basis, surveillance requirements from Technical Specification 3.1.4 apply; accepting the definition of SLOW rods should conform to scram speeds shown in Table 4.1. If conformance is not demonstrated, TSSS based MCPR<sub>P</sub> limits are applied.

On initial cycle startup, TSSS limits are used until the successful completion of scram timing confirms NSS based limits are applicable.

#### 4.2.2 Exposure Dependent Limits

Exposures are tracked on a Core Average Exposure basis (CAVEX, not Cycle Exposure). Higher exposure MCPR<sub>P</sub> limits are always more limiting and may be used for any Core Average Exposure up to the ending exposure. Per Reference 1, MCPR<sub>P</sub> limits are provided for the following exposure ranges:

BOC to NEOC	NEOC corresponds to	<b>29,395 MWd / MTU</b>
BOC to EOC	EOC corresponds to	<b>32,712 MWd / MTU</b>
BOC to End of Coast	End of Coast	<b>34,082 MWd / MTU</b>

NEOC refers to a Near EOC exposure point.

The EOC exposure point is not the true End-Of-Cycle exposure. Instead it corresponds to a licensing exposure window exceeding expected end-of-full-power-life.

The End of Coast exposure point represents a licensing exposure point exceeding the expected end-of-cycle exposure including cycle extension options.

#### 4.2.3 Equipment Out-Of-Service (EOOS) Options

EOOS options covered by MCPR<sub>p</sub> limits are given by the following:

In-Service	All equipment In-Service
RPTOOS	EOC-Recirculation Pump Trip Out-Of-Service
TBVOOS	Turbine Bypass Valve(s) Out-Of-Service
RPTOOS+TBVOOS	Combined RPTOOS and TBVOOS
PLUOOS	Power Load Unbalance Out-Of-Service
PLUOOS+RPTOOS	Combined PLUOOS and RPTOOS
PLUOOS+TBVOOS	Combined PLUOOS and TBVOOS
PLUOOS+TBVOOS+RPTOOS	Combined PLUOOS, RPTOOS, and TBVOOS
FHOOS (or FFWTR)	Feedwater Heaters Out-Of-Service (or Final Feedwater Temperature Reduction)

For exposure ranges up to NEOC and EOC, additional combinations of MCPR<sub>p</sub> limits are also provided including FHOOS. The CD exposure range assumes application of FFWTR. FHOOS based MCPR<sub>p</sub> limits for the CD exposure are redundant because the temperature setdown assumption is identical with FFWTR.

#### 4.2.4 Single-Loop-Operation (SLO) Limits

MCPR<sub>p</sub> limits are increased by 0.02 to support SLO, per Reference 1.

#### 4.2.5 Below Pbyypass Limits

Below Pbyypass (30% rated power), MCPR<sub>p</sub> limits depend upon core flow. One set of MCPR<sub>p</sub> limits applies for core flow is above 50% of rated; a second set applies if the core flow is less than or equal to 50% rated.

\* All equipment service conditions assume 1 SRVOOS.

**Table 4.2 MCPR<sub>p</sub> Limits for Nominal Scram Time Basis**

Operating Condition	Power (% of rated)	BOC to NEOC	BOC to EOC	BOC to End of Coast
Base Case	100	1.42	1.42	1.44
	75	1.52	1.52	1.55
	65	1.57	1.57	1.62
	50	1.75	1.75	1.81
	50	1.91	1.91	1.91
	40	2.01	2.01	2.03
	30	2.23	2.23	2.33
	30 at > 50%F	2.53	2.53	2.62
	25 at > 50%F	2.77	2.77	2.89
	30 at ≤ 50%F	2.47	2.47	2.55
	25 at ≤ 50%F	2.68	2.68	2.79
TBVOOS	100	1.46	1.46	1.47
	75	1.59	1.59	1.61
	65	1.62	1.62	1.64
	50	1.77	1.77	1.83
	50	1.91	1.91	1.91
	40	2.01	2.01	2.05
	30	2.25	2.25	2.35
	30 at > 50%F	3.11	3.11	3.23
	25 at > 50%F	3.50	3.50	3.62
	30 at ≤ 50%F	2.76	2.76	2.88
	25 at ≤ 50%F	3.15	3.15	3.29
FHOOS	100	1.44	1.44	---
	75	1.55	1.55	---
	65	1.62	1.62	---
	50	1.81	1.81	---
	50	1.91	1.91	---
	40	2.03	2.03	---
	30	2.33	2.33	---
	30 at > 50%F	2.62	2.62	---
	25 at > 50%F	2.89	2.89	---
	30 at ≤ 50%F	2.55	2.55	---
	25 at ≤ 50%F	2.79	2.79	---
PLUOOS	100	1.42	1.43	1.44
	75	1.52	1.52	1.55
	65	1.81	1.81	1.81
	50	---	---	---
	50	1.91	1.91	1.91
	40	2.01	2.01	2.03
	30	2.23	2.23	2.33
	30 at > 50%F	2.53	2.53	2.62
	25 at > 50%F	2.77	2.77	2.89
	30 at ≤ 50%F	2.47	2.47	2.55
	25 at ≤ 50%F	2.68	2.68	2.79

All limits, including "Base Case," support RPTOOS operation; operation is supported for any combination of 1 MSRVOOS, up to 2 TIPOOS (or the equivalent number of TIP channels), and up to 50% of the LPRMs out-of-service. For single-loop operation, MCPR<sub>p</sub> limits will be 0.02 higher.

FFWTR and FHOOS assume the same value of temperature drop. Consequently, FHOOS limits are not provided for BOC to End of COAST due to redundancy. Thermal limits for the "BOC to End of COAST" exposure applicability window are developed to conservatively bound FHOOS limits for earlier exposure applicability windows.

A 50% power step change for PLUOOS limits is not supported. When core power is ≤ 50%, the LRNB event is the same with, or without PLUOOS.

Table 4.2 MCPR<sub>P</sub> Limits for Nominal Scram Time Basis (continued)

Operating Condition	Power (% of-rated)	BOC to NEOC	BOC to EOC	BOC to End of Coast
TBVOOS FHOOS	100	1.47	1.47	---
	75	1.60	1.60	---
	65	1.64	1.64	---
	50	1.83	1.83	---
	50	1.91	1.91	---
	40	2.05	2.05	---
	30	2.35	2.35	---
	30 at > 50°F	3.23	3.23	---
	25 at > 50°F	3.62	3.62	---
	30 at ≤ 50°F	2.88	2.88	---
25 at ≤ 50°F	3.29	3.29	---	
TBVOOS PLUOOS	100	1.46	1.46	1.47
	75	1.59	1.59	1.61
	65	1.81	1.81	1.81
	50	---	---	---
	50	1.91	1.91	1.91
	40	2.01	2.01	2.05
	30	2.25	2.25	2.35
	30 at > 50°F	3.11	3.11	3.23
	25 at > 50°F	3.50	3.50	3.62
	30 at ≤ 50°F	2.76	2.76	2.88
25 at ≤ 50°F	3.15	3.15	3.29	
FHOOS PLUOOS	100	1.44	1.44	---
	75	1.55	1.55	---
	65	1.81	1.81	---
	50	---	---	---
	50	1.91	1.91	---
	40	2.03	2.03	---
	30	2.33	2.33	---
	30 at > 50°F	2.62	2.62	---
	25 at > 50°F	2.89	2.89	---
	30 at ≤ 50°F	2.55	2.55	---
25 at ≤ 50°F	2.79	2.79	---	
TBVOOS FHOOS PLUOOS	100	1.47	1.47	---
	75	1.60	1.60	---
	65	1.81	1.81	---
	50	---	---	---
	50	1.91	1.91	---
	40	2.05	2.05	---
	30	2.35	2.35	---
	30 at > 50°F	3.23	3.23	---
	25 at > 50°F	3.62	3.62	---
	30 at ≤ 50°F	2.88	2.88	---
25 at ≤ 50°F	3.29	3.29	---	

All limits, including "Base Case," support RPTOOS operation; operation is supported for any combination of 1 MSRVOOS, up to 2 TIPOOS (or the equivalent number of TIP channels), and up to 50% of the LPRMs out-of-service. For single-loop operation, MCPR<sub>P</sub> limits will be 0.02 higher.

FFWTR and FHOOS assume the same value of temperature drop. Consequently, FHOOS limits are not provided for BOC to End of COAST due to redundancy. Thermal limits for the "BOC to End of COAST" exposure applicability window are developed to conservatively bound FHOOS limits for earlier exposure applicability windows.

A 50% power step change for PLUOOS limits is not supported. When core power is ≤ 50%, the LRNB event is the same with, or without PLUOOS.

Table 4.3 MCPR<sub>P</sub> Limits for Technical Specification Scram Time Basis\*

Operating Condition	Power (% of rated)	BOC to NEOC	BOC to EOC	BOC to End of Coast
Base Case	100	1.43	1.47	1.52
	75	1.56	1.56	1.58
	65	1.59	1.59	1.64
	50	1.77	1.77	1.83
	50	1.92	1.92	1.92
	40	2.02	2.02	2.05
	30	2.25	2.25	2.35
	30 at > 50°F	2.53	2.53	2.62
	25 at > 50°F	2.77	2.77	2.89
	30 at ≤ 50°F	2.47	2.47	2.55
25 at ≤ 50°F	2.68	2.68	2.79	
TBVOOS	100	1.48	1.52	1.55
	75	1.61	1.61	1.63
	65	1.63	1.63	1.67
	50	1.79	1.79	1.85
	50	1.92	1.92	1.92
	40	2.02	2.02	2.07
	30	2.27	2.27	2.37
	30 at > 50°F	3.11	3.11	3.23
	25 at > 50°F	3.50	3.50	3.62
	30 at ≤ 50°F	2.76	2.76	2.88
25 at ≤ 50°F	3.15	3.15	3.29	
FHOOS	100	1.45	1.47	---
	75	1.58	1.58	---
	65	1.64	1.64	---
	50	1.83	1.83	---
	50	1.92	1.92	---
	40	2.05	2.05	---
	30	2.35	2.35	---
	30 at > 50°F	2.62	2.62	---
	25 at > 50°F	2.89	2.89	---
	30 at ≤ 50°F	2.55	2.55	---
25 at ≤ 50°F	2.79	2.79	---	
PLUOOS	100	1.44	1.48	1.53
	75	1.56	1.56	1.58
	65	1.82	1.82	1.82
	50	---	---	---
	50	1.92	1.92	1.92
	40	2.02	2.02	2.05
	30	2.25	2.25	2.35
	30 at > 50°F	2.53	2.53	2.62
	25 at > 50°F	2.77	2.77	2.89
	30 at ≤ 50°F	2.47	2.47	2.55
25 at ≤ 50°F	2.68	2.68	2.79	

All limits, including "Base Case," support RPTOOS operation; operation is supported for any combination of 1 MSRVOOS, up to 2 TIPOOS (or the equivalent number of TIP channels), and up to 50% of the LPRMs out-of-service. For single-loop operation, MCPR<sub>P</sub> limits will be 0.02 higher.

FFWTR and FHOOS assume the same value of temperature drop. Consequently, FHOOS limits are not provided for BOC to End of COAST due to redundancy. Thermal limits for the "BOC to End of COAST" exposure applicability window are developed to conservatively bound FHOOS limits for earlier exposure applicability windows.

A 50% power step change for PLUOOS limits is not supported. When core power is ≤ 50%, the LRNB event is the same with, or without PLUOOS.

Table 4.3 MCPR<sub>P</sub> Limits for Technical Specification Scram Time Basis (continued)

Operating Condition	Power (% of rated)	BOC to NEOC	BOC to EOC	BOC to End of Coast
TBVOOS FHOOS	100	1.49	1.52	---
	75	1.62	1.62	---
	65	1.67	1.67	---
	50	1.85	1.85	---
	50	1.92	1.92	---
	40	2.07	2.07	---
	30	2.37	2.37	---
	30 at > 50%F	3.23	3.23	---
	25 at > 50%F	3.62	3.62	---
	30 at ≤ 50%F	2.88	2.88	---
	25 at ≤ 50%F	3.29	3.29	---
TBVOOS PLUOOS	100	1.48	1.52	1.55
	75	1.61	1.61	1.63
	65	1.82	1.82	1.82
	50	---	---	---
	50	1.92	1.92	1.92
	40	2.02	2.02	2.07
	30	2.27	2.27	2.37
	30 at > 50%F	3.11	3.11	3.23
	25 at > 50%F	3.50	3.50	3.62
	30 at ≤ 50%F	2.76	2.76	2.88
	25 at ≤ 50%F	3.15	3.15	3.29
FHOOS PLUOOS	100	1.45	1.48	---
	75	1.58	1.58	---
	65	1.82	1.82	---
	50	---	---	---
	50	1.92	1.92	---
	40	2.05	2.05	---
	30	2.35	2.35	---
	30 at > 50%F	2.62	2.62	---
	25 at > 50%F	2.89	2.89	---
	30 at ≤ 50%F	2.55	2.55	---
	25 at ≤ 50%F	2.79	2.79	---
TBVOOS FHOOS PLUOOS	100	1.49	1.52	---
	75	1.62	1.62	---
	65	1.82	1.82	---
	50	---	---	---
	50	1.92	1.92	---
	40	2.07	2.07	---
	30	2.37	2.37	---
	30 at > 50%F	3.23	3.23	---
	25 at > 50%F	3.62	3.62	---
	30 at ≤ 50%F	2.88	2.88	---
	25 at ≤ 50%F	3.29	3.29	---

All limits, including "Base Case," support RPTOOS operation; operation is supported for any combination of 1 MSRVOOS, up to 2 TIPOOS (or the equivalent number of TIP channels), and up to 50% of the LPRMs out-of-service. For single-loop operation, MCPR<sub>P</sub> limits will be 0.02 higher.

FFWTR and FHOOS assume the same value of temperature drop. Consequently, FHOOS limits are not provided for BOC to End of COAST due to redundancy. Thermal limits for the "BOC to End of COAST" exposure applicability window are developed to conservatively bound FHOOS limits for earlier exposure applicability windows.

A 50% power step change for PLUOOS limits is not supported. When core power is ≤ 50%, the LRNB event is the same with, or without PLUOOS.

## 5 APRM Flow Biased Rod Block Trip Settings

(Technical Requirements Manual Section 5.3.1 and Table 3.3.4-1)

The APRM rod block trip setting is based upon References 24 & 25, and is defined by the following:

$$SRB \leq (0.66(W-\Delta W) + 61\%) \quad \text{Allowable Value}$$

$$SRB \leq (0.66(W-\Delta W) + 59\%) \quad \text{Nominal Trip Setpoint (NTSP)}$$

where:

SRB = Rod Block setting in percent of rated thermal power (3458 MW<sub>t</sub>)

W = Loop recirculation flow rate in percent of rated

$\Delta W$  = Difference between two-loop and single-loop effective recirculation flow at the same core flow ( $\Delta W=0.0$  for two-loop operation)

The APRM rod block trip setting is clamped at a maximum allowable value of 115% (corresponding to a NTSP of 113%).

## 6 Rod Block Monitor (RBM) Trip Setpoints and Operability (Technical Specification Table 3.3.2.1-1)

The RBM trip setpoints and applicable power ranges, based on References 24 & 25, are shown in Table 6.1. Setpoints are based on an HTSP, unfiltered analytical limit of 117%. Unfiltered setpoints are consistent with a nominal RBM filter setting of 0.0 seconds; filtered setpoints are consistent with a nominal RBM filter setting less than 0.5 seconds. Cycle specific CRWE analyses of OLMCPR are documented in Reference 1, superceding values reported in References 24, 25, and 27.

Table 6.1 Analytical RBM Trip Setpoints\*

RBM Trip Setpoint	Allowable Value (AV)	Nominal Trip Setpoint (NTSP)
LPSP	27%	25%
IPSP	62%	60%
HPSP	82%	80%
LTSP - unfiltered	124.7%	123.0%
- filtered	123.5%	121.8%
ITSP - unfiltered	119.7%	118.0%
- filtered	118.7%	117.0%
HTSP - unfiltered	114.7%	113.0%
- filtered	113.7%	112.0%
DTSP	90%	92%

As a result of cycle specific CRWE analyses, RBM setpoints in Technical Specification Table 3.3.2.1-1 are applicable as shown in Table 6.2. Cycle specific setpoint analysis results are shown in Table 6.3, per Reference 1.

Table 6.2 RBM Setpoint Applicability

Thermal Power (% Rated)	Applicable MCPR <sup>†</sup>	Notes from Table 3.3.2.1-1	Comment
> 27% and < 90%	< 1.74	(a), (b), (f), (h)	two loop operation
	< 1.77	(a), (b), (f), (h)	single loop operation
≥ 90%	< 1.43	(g)	two loop operation <sup>‡</sup>

\* Values are considered maximums. Using lower values, due to RBM system hardware/software limitations, is conservative, and acceptable.

† MCPR values shown correspond with, (support), SLMPCR values identified in Reference 1.

‡ Greater than 90% rated power is not attainable in single loop operation.



Table 6.3 Control Rod Withdrawal Error Results

<b>RBM Setpoint</b>	<b>CRWE OLM CPR</b>
<b>Unfiltered</b>	
107	1.29
111	1.32
114	1.35
117	1.35

Results, compared against the base case OLM CPR results of Table 4.2, indicate SLM CPR remains protected for RBM inoperable conditions (i.e., unblocked).

## **7 Shutdown Margin Limit**

### **(Technical Specification 3.1.1)**

Assuming the strongest OPERABLE control blade is fully withdrawn, and all other OPERABLE control blades are fully inserted, the core shall be sub-critical and meet the following minimum shutdown margin:

$$\text{SDM} > 0.38\% \text{ dk/k}$$



1101 Market Street, Chattanooga, TN 37402

## Nuclear Fuel Engineering - BWRFE

**Date:** March 15, 2010

**EDMS:** L32 100315 801

---

### Appendix A: Thermal-Hydraulic Stability

---

**RPS Instrumentation****(Technical Specification 3.3.1.1)**

Technical Specification Section 3.3.1.1, LCO 3.3.1.1 states:

*The RPS instrumentation for each Function in Table 3.3.1.1-1 shall be OPERABLE.*

Table 3.3.1.1-1, Function 2f, identifies the OPRM upscale function. This function must be operable in conjunction with the following surveillance requirements:

SR 3.3.1.1.1  
SR 3.3.1.1.7  
SR 3.3.1.1.13  
SR 3.3.1.1.16  
SR 3.3.1.1.17

**Background**

Browns Ferry uses the Option III stability Detect and Suppress solution as part of the PRNM system. The Option III system is based upon combining groups of local LPRM's into cells known as OPRM's. The OPRM's generate a combined LPRM signal that is examined for the characteristics of a reactor instability event, and if detected, a reactor trip is generated.

The PBDA is the licensing basis portion of the Option III system, requiring a cycle-specific calculation to determine the amplitude setpoint to generate a reactor trip in time to protect the fuel from exceeding the SLMCPR.

The OPRM Upscale Trip function is required to be operable when the plant is in a region of power-flow operation where actual thermal-hydraulic oscillations might occur (T.S. enabled region -- greater than 25% rated thermal power and less than 60% recirculation drive flow).

**Setpoints**

Instrument setpoints are established such that the reactor will be tripped before an oscillation can grow to the point where the SLMCPR is exceeded. An Option III stability analysis is performed for each reload core to determine allowable OLMCPR's as a function of OPRM setpoint. Analyses consider both steady state startup operation, and the case of a two recirculation pump trip from rated power.

The resulting stability based OLMCPR's are reported in Reference 1. The OPRM setpoint is selected such that required margin to the SLMCPR is provided without stability being a limiting event. Analyses are based on cycle specific DIVOM analyses performed per Reference 23. The calculated OLMCPR's are shown in Table A.1. Review of results, relative to the base case

operation shown in Table 4.2 indicates that an OPRM setpoint of 1.15 can be supported. Extrapolation beyond a setpoint of 1.15 is not allowed.

Table A.1 OPRM Setpoints

OPRM Setpoint	OLMCPR (SS)	OLMCPR (2PT)
1.05	1.18	1.18
1.06	1.20	1.20
1.07	1.22	1.22
1.08	1.24	1.24
1.09	1.26	1.26
1.10	1.28	1.28
1.11	1.30	1.30
1.12	1.32	1.32
1.13	1.34	1.34
1.14	1.36	1.36
1.15	1.39	1.39

### Backup Stability

Should the Option III system be declared inoperable, alternate methods/procedures (i.e., stability ICA's) are incorporated restricting plant operation in the high power, low core flow region of the power/flow map. ICA's contain specific operator actions, providing clear instructions (depending upon the plant type) for operator response to a reactor inadvertently (or under controlled conditions) entering any of the defined regions. ICA's provide appropriate guidance to reduce the likelihood of hydraulic instability, and enhance early detection in the very unlikely event a stability threshold is exceeded in spite of the ICA guidelines.

In July 2002, GE recommended the original ICAs, established generically in 1994, be re-evaluated to assure adequate conservatism, given the trend to higher energy cores and more aggressive fuel management strategies. The recommended replacement regions and the associated calculational procedure are referred to as BSP, and need to be confirmed on a plant/cycle specific basis. The vendor has performed an ICA/BSP confirmation calculation using the NRC approved method in Reference 22.

Based upon the above discussion, appropriate stability analyses and evaluations have been performed to satisfy licensing requirements.