



**Pacific Gas and  
Electric Company®**

**James R. Becker**  
Site Vice President

Diablo Canyon Power Plant  
Mail Code 104/5/601  
P. O. Box 56  
Avila Beach, CA 93424

805.545.3462  
Internal: 691.3462  
Fax: 805.545.6445

April 23, 2010

PG&E Letter DCL-10-045

10 CFR 50.90

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
Response to NRC Request for Additional Information Regarding License  
Amendment Request 09-06, "Critical Damping Value for Structural Dynamic  
Qualification of the Control Rod Drive Mechanism Pressure Housings" (TAC Nos.  
ME2995 and ME2996)

Reference: 1. PG&E Letter DCL-09-86, "License Amendment Request 09-06,  
"Critical Damping Value for Structural Dynamic Qualification of the  
Control Rod Drive Mechanism Pressure Housings," dated  
December 14, 2009. (ADAMS Accession No. ML093580092)

Dear Commissioners and Staff:

By letter dated December 14, 2009 (Reference 1), Pacific Gas and Electric Company (PG&E) submitted a license amendment request to revise the licensing basis and the Final Safety Analysis Report Update (FSARU) to allow use of a damping value of 5 percent of critical damping for the structural dynamic qualification of the control rod drive mechanism pressure housings on the replacement reactor vessel head for the design earthquake, double design earthquake, Hosgri earthquake, and loss-of-coolant accident (LOCA) loading conditions.

On April 15, 2010 (ADAMS Accession No. ML101050521), the NRC staff requested additional information required to complete the review of LAR 09-06. PG&E's responses to the staff's questions are provided in the enclosure.

This information does not affect the results of the technical evaluation or the no significant hazards consideration determination previously transmitted in Reference 1.

PG&E makes no regulatory commitments (as defined by NEI 99-04) in this letter. This letter includes no revisions to existing regulatory commitments.



If you have any questions, or require additional information, please contact Tom Baldwin at (805) 545-4720.

I state under penalty of perjury that the foregoing is true and correct.

Executed on April 23, 2010.

Sincerely,

James R. Becker  
*Site Vice President*

tcg4231 50304279

Enclosure

cc: Diablo Distribution

cc/enc: Gary W. Butner, Acting Branch Chief, California Department of Public Health

Elmo E. Collins, NRC Region IV

Michael S. Peck, NRC, Senior Resident Inspector

Alan B. Wang, Project Manager, Office of Nuclear Reactor Regulation

**PG&E Response to NRC Request for Additional Information Regarding License Amendment Request (LAR) 09-06, “Critical Damping Value for Structural Dynamic Qualification of the Control Rod Drive Mechanism Pressure Housings”**

NRC Question 1:

*Please provide the following information:*

*(a) Provide a summary of the recent analysis results for the new CRDM pressure housing based on a 5% critical damping value for all load combinations that contain DE, DDE, HE, and LOCA loadings, showing the respective margins.*

*(b) Provide a brief description of the structural dynamic analysis methodology used in the qualification of the CRDM pressure housings on the replacement reactor vessel head.*

*(c) Provide, for comparison, a summary of lower damping values used in the original CRDM analysis and a summary of the design basis analysis results, with the respective margins.*

*(d) Clarify that the higher 5% critical damping value will only be applied to the CRDMs, and will not be applied to the reactor coolant piping or reactor internals analyses.*

PG&E Response:

(a) The following tables summarize the recent analysis results for the new control rod drive mechanism (CRDM) pressure housing based on a 5 percent critical damping value for all load combinations that contain design earthquake (DE), double design earthquake (DDE), Hosgri earthquake (HE), and loss-of-coolant accident (LOCA) loadings. The interaction ratio is the calculated value divided by the allowable value. Interaction ratios below 1.0 represent margin. The values are bounding for both units.

Table 1: Rod Travel Housing Stresses

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (DE Load Combination)	13.06 ksi	24.3 ksi	0.54
Local Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination)	39.74 ksi	48.6 ksi	0.82
Fatigue Usage Factor (DE Load Combination)	.004	1.0	0.004
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	36.91 ksi	58.3 ksi	0.63
Local Primary Membrane + Primary Bending Stress (DDE Load Combination)	17.32 ksi	58.3 ksi	0.30

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (HE Load Combination)	28.77 ksi	58.3 ksi	0.49

Table 2: Latch Housing Stresses

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (DE Load Combination)	22.01 ksi	24.3 ksi	0.91
Local Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination) Note: Secondary Stress Excludes Thermal Bending Stress per ASME Simplified Elastic-Plastic Analysis Rules	18.71 ksi	48.6 ksi	0.38
Fatigue Usage Factor (DE Load Combination)	0.033	1.0	0.033
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	54.74 ksi	58.3 ksi	0.94
Local Primary Membrane + Primary Bending Stress (DDE Load Combination)	39.29 ksi	58.3 ksi	0.67
Local Primary Membrane + Primary Bending Stress (HE Load Combination)	49.23 ksi	58.3 ksi	0.84

Table 3: CRDM Nozzle between Top of Head and Dissimilar Metal Weld

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (DE Load Combination)	26.64 ksi	34.9 ksi	0.76
Local Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination)	66.77 ksi	69.9 ksi	0.96
Fatigue Usage Factor (DE Load Combination)	0.003	1.0	0.003
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	71.43 ksi	83.8 ksi	0.85

Table 4: CRDM Nozzle at J-Groove Weld

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (DE Load Combination)	25.88 ksi	35.0 ksi	0.74
Local Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination)	66.77 ksi	69.9 ksi	0.96
Fatigue Usage Factor (DE Load Combination)	0.282	1.0	0.282
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	67.47 ksi	83.9 ksi	0.80

- (b) The following provides a brief description of the structural dynamic analysis methodology used in the qualification of the CRDM pressure housings on the replacement reactor vessel head:

The DE and DDE horizontal direction seismic loads, acting on the CRDMs, were determined using finite element models and nonlinear seismic time history methods. For Unit 2, a center row of five CRDMs was modeled to include the effects of different CRDM lengths due to the curvature of the reactor head. For Unit 1, a center row of seven CRDMs was modeled. This approach is conceptually consistent with the approach used to determine seismic loads in the original CRDM seismic analysis.

The finite element models included nonlinear spring elements to represent the gaps and contact between the seismic plates (near the tops of the CRDM rod travel housings) and to represent the contact between the outer seismic plates and the seismic stop plates. A linear spring was also included to represent the combined tie-rod and Integrated Head Assembly (IHA) stiffness connection to the wall. The IHA was included in the models as a vertical beam connecting the Reactor Vessel Closure Head (RVCH) to the tie-rod spring. An IHA horizontal beam was included to connect the IHA vertical beam to the seismic stop plates.

Time history input motions for the CRDM DE and DDE horizontal earthquake analyses were developed at the RVCH elevation and at the elevation corresponding to the tie-rod/IHA connection to the wall. The time history input motions at the tie-rod/IHA connection elevation were used to generate acceleration response spectra for comparison to existing response spectra at this same elevation. The generated response spectra enveloped the existing response spectra at all frequencies within the CRDM response frequency range. Time history input motions at the RVCH were developed by Westinghouse for use by AREVA who supplied and qualified the replacement RVCH, IHA, and CRDMs.

The time history inputs and CRDM models were used with the ANSYS structural analysis program to determine seismic forces acting on the CRDMs along their lengths due to DE and DDE horizontal direction earthquakes. The analyses used ANSYS Beta damping corresponding to 5 percent of the critical damping ratio for the CRDMs. Analyses show the CRDM fundamental frequency range is 5 to 8 Hz and the dominant frequencies of response are below 10 Hz. Therefore, a conservative value of 10 Hz was used to determine the CRDM Beta damping value used in the analyses.

The HE horizontal direction seismic forces and the vertical direction seismic forces for DE, DDE, and HE were determined using linear elastic response spectra methods. The response spectra analyses included the center CRDM (the shortest) and a peripheral CRDM (the longest) to envelope the results for all CRDMs. Vertical direction 5 percent damping response spectra at the RVCH elevation were used for

the vertical direction seismic analyses since the CRDMs are supported vertically only at the RVCH elevation. The HE horizontal direction seismic analysis used 5 percent damping response spectra at the RVCH elevation and the elevation of the seismic plates. To account for gaps between the seismic plates, a static analysis was also performed using a forced horizontal direction displacement at the CRDM seismic plate elevation that corresponds to the maximum cumulative gap.

The resulting seismic forces acting on the CRDMs due to both vertical and horizontal DE, DDE, and HE earthquakes were used with CRDM physical properties to determine seismic stresses acting on the CRDM. The seismic stresses were combined with other applicable stresses such as pressure and thermal to determine the total combined stress for each applicable load combination. The combined stresses were determined at each critical location along the length of the CRDM assembly including locations along the rod travel housing, latch housing, and CRDM penetration into the RVCH. These stresses were then evaluated for acceptance per Section NB-3200 of the ASME Boiler and Pressure Vessel Code 2001 Edition through 2003 Addendum. This Code was satisfactorily reconciled to the original CRDM code of record.

- (c) The original CRDM analysis was performed by Westinghouse using the nonlinear time history analysis method with stiffness damping corresponding to 3 percent of the critical damping. DDE loads were determined to be larger than the HE loads and therefore the DDE results bound the HE results. The following table summarizes results from the original CRDM analysis along with allowable values and interaction ratios. The interaction ratio is the calculated value divided by the allowable value. Interaction ratios below 1.0 represent margin.

Table 5: Rod Travel Housing and Latch Housing Loads

Location and Load	Calculated Value	Allowable Value	Interaction Ratio
Rod Travel Housing DDE Moment	64 in-kip	73 in-kip	0.88
CRDM Latch Housing DDE Moment	140 in-kip	670 in-kip	0.21

Table 6: CRDM Nozzle between Top of Head and Dissimilar Metal Weld

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Primary Membrane + Primary Bending Stress (DE Load Combination)	23.67 ksi	23.98 ksi	0.99
Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination)	68.40 ksi	69.9 ksi	0.98
Fatigue Usage Factor (DE Load Combination)	0.002	1.0	0.002
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	55.73 ksi	58.32 ksi	0.96

Table 7: CRDM Nozzle at J-Groove Weld

ASME Classification	Calculated Value	Allowable Value	Interaction Ratio
Local Primary Membrane + Primary Bending Stress (DE Load Combination)	24.35 ksi	34.48 ksi	0.71
Local Primary Membrane + Primary Bending + Secondary Stress (DE Load Combination)	50.21 ksi	69.9 ksi	0.72
Fatigue Usage Factor (DE Load Combination)	0.191	1.0	0.191
Local Primary Membrane + Primary Bending Stress (DDE + LOCA Load Combination)	56.34 ksi	83.88 ksi	0.67

- (d) The higher 5 percent critical damping value per this LAR will only be applied to the CRDMs and will NOT be applied to the reactor coolant piping or reactor internals analyses. The original analysis seismic model included the reactor vessel and internals along with the CRDMs and seismic support platform. As discussed above, the new seismic model includes the CRDMs and the IHA that incorporates a seismic support platform but the model ends at the reactor vessel closure head. Time History and response spectra inputs are developed by Westinghouse at the reactor vessel closure head for use in the new CRDM analysis. Regulatory Guide 1.61 Revision 1 damping is used for the IHA and associated components. As discussed with the NRC staff, a LAR will be submitted to obtain NRC approval to use these damping values. Damping values for the reactor vessel internals and reactor piping are unchanged from the original analyses.

NRC Question 2:

*Pages 3 and 4 along with Figure 1 of the enclosure to PG&E's letter dated December 14, 2010 (DCL-09-086), provide the basis for similarity between the original equipment manufacturer (OEM) CRDM and the new AREVA supplied replacement CRDM from considerations such as the seismic support plate gap, CRDM length, latch housing and rod travel housing materials, CRDM geometrical section properties, operating parameters, appurtenances, and design differences. Provide a similar comparison of the AREVA-supplied replacement CRDMs and the CRDMs tested by Westinghouse, as described in the topical report, WCAP-7921-AR.*

PG&E Response:

The following provides the comparison of the AREVA-supplied replacement CRDMs and the CRDMs tested by Westinghouse, as described in the topical report, WCAP-7921-AR:


1. *Gap at the seismic support plates.* The AREVA-supplied replacement CRDMs provide a 0.070 inch gap (cold) and a 0.100 inch gap (hot) between the CRDM seismic support plates. The Westinghouse CRDM testing determined the damping



values for three different gap values: zero gap, 0.015 inch gap, and 0.060 inch gap. The testing showed larger gaps significantly increased the measured CRDM damping. The seismic support plate gaps for the AREVA-supplied CRDMs exceed the maximum gaps included in the Westinghouse testing to ensure the test results are applicable to the replacement CRDM installation.

2. *CRDM length.* The Westinghouse CRDM damping testing utilized a model L-105B CRDM that is designed for a 10-foot core. Diablo Canyon has 12-foot cores and therefore the AREVA-supplied CRDMs are approximately 17 to 40 inches longer than the tested L-105B CRDM as measured from the top of the reactor vessel closure head to the top of the rod travel housing. See Figure 1. It is expected that the longer latch assembly and rod travel housing of the AREVA-supplied CRDMs will have a positive effect on damping (ie: higher damping when compared to the L-105B tested CRDM).
3. *Latch Housing and Rod Travel Housing (RTH) Materials.* The AREVA-supplied CRDMs and the L-105B tested CRDM both use type 304 stainless steel.
4. *Section Properties.* Figure 1 shows section property differences between the L-105B CRDMs that were tested and the AREVA-supplied CRDMs. The original Diablo Canyon L-106A CRDMs supplied by Westinghouse have essentially the same section properties as the AREVA-supplied CRDMs. Westinghouse has determined these section property differences will have negligible impact on CRDM damping. Other U.S. plants base their current license basis acceptance to use 5 percent damping for their CRDM analysis on the Westinghouse L-105B testing.
5. *Operating Parameters.* The Westinghouse L-105B CRDM damping tests were performed at a pressure of 2,250 psi and a temperature of 400 degrees Fahrenheit. Normal operating conditions included in the AREVA-supplied CRDM design are 2,235 psig and 610 degrees Fahrenheit. The difference in temperature is expected to have negligible effect on damping.
6. *Appurtenances.* The AREVA-supplied CRDMs have the typical appurtenances including coil assemblies, digital rod position indicator coil stack, and an attached control rod. The Westinghouse L-105B testing included an operating coil stack, a nonfunctioning rod position indicator coil stack and a weight at the bottom of the drive shaft to simulate the weight of the control rod.
7. *Specific Design Differences.* The specific design differences provided in DCL-09-086 between the AREVA-supplied CRDMs and the CRDMs originally installed at Diablo Canyon are also applicable between the AREVA-supplied CRDMs and the L-105B CRDMs that were tested. These differences have negligible effect on damping. In addition, there are specific differences in CRDM length and section properties as discussed above.





C:\D:\HW\EDMS\1105614.dgn