

## Masters, Anthony

---

**From:** Lake, Louis *RL*  
**Sent:** Friday, December 04, 2009 12:02 PM  
**To:** Dan naus; Masters, Anthony; Carrion, Robert; Thomas, George  
**Subject:** Clarification on Vertical Tendons  
**Categories:** Perform Review

Yesterday, during our conference call, I mentioned that CR was considering not de-tensioning vertical tendons, thought they were in the area of the delamination but wasn't sure, and that it didn't seem to make sense. I followed up with Garry and got clarification. In order to better stabilize Buttresses #3 and #4 during the de-tensioning sequence, they are considering not de-tensioning tendons located within and just to each side of these buttresses. They have not made a final decision.

Lou

*C-82*