

POWER AUTHORITY OF THE STATE OF NEW YORK  
 INDIAN POINT NO. 3 NUCLEAR POWER PLANT  
 P. O. BOX 215 BUCHANAN, N. Y. 10511  
 TELEPHONE: 914-739-8200



50286

April 24, 1979  
 IP-KEM-4647

Docket No. 59-286  
 License No. DPR-64

Mr. Boyce H. Grier, Director  
 Office of Inspection and Enforcement  
 Region I  
 U. S. Nuclear Regulatory Commission  
 631 Park Avenue  
 King of Prussia, Pennsylvania 19406

Subject: I.E. Bulletin No. 79-03  
 Reference: IP-WDH-4535

Dear Mr. Grier:

In response to I.E. Bulletin No. 79-03, the Power Authority has investigated the status of the Indian Point 3 Nuclear Power Plant with regard to the use of ASME SA-312, Type 304 or other welded (without filler metal) pipe manufactured by Youngstown Welding and Engineering Company. Our initial response was covered in the referenced letter which stated that an additional investigation would be made into piping under four inches in diameter to determine if any had been supplied by Youngstown Welding and Engineering Company.

The additional investigation has concluded that no piping under four inches in diameter was supplied by Youngstown. The results of our complete investigation into the use of pipe manufactured by Youngstown Welding and Engineering Company have indicated that no welded pipe (without filler metal) has been used in safety related systems at Indian Point 3 Nuclear Power Plant.

Very truly yours,

  
 J. P. Bayne  
 Resident Manager

KEM:ms

cc: Office of Inspection and Enforcement  
 U. S. Nuclear Regulatory Commission  
 Division of Reactor Construction Inspection  
 Washington, D. C. 20555

7906140326