

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
)
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.


The proposed change to the Indian Point 3 Technical Specifications seeks to amend Section 3.3 of Appendix A to avert possible Residual Heat Removal Pump damage by precluding the spurious closing of Residual Heat Removal system miniflow valves 1870 and 743 in accordance with the Commission's September 22, 1980 letter.

The proposed change to the Technical Specifications are presented in Attachment I to this Application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE STATE
OF NEW YORK

By 
J. P. Bayne
Senior Vice President
Nuclear Generation

Subscribed and Sworn to before
me this 7 day of November 1980.


Notary Public

RUTH G. ZAPP
Notary Public, State of New York
No. 30-4663428
Qualified in Nassau County
Commission Expires March 30, 1982

~~8011180~~ 442