

BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
POWER AUTHORITY OF THE STATE OF NEW YORK ) Docket No. 50-286  
 )  
Indian Point 3 Nuclear Power Plant )

APPLICATION FOR AMENDMENT TO  
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This proposed change to the Indian Point 3 Technical Specifications seeks to amend Table 3.6-1 to delete four (4) containment isolation valves which have been modified for automatic operation. This modification was performed in accordance with the requirements of NUREG-0737, Item II.E.4.2., which presents a position regarding the isolation of nonessential systems. The proposed change also adds two (2) new containment isolation valves, part of a recently installed demineralized water system, to Table 4.4-1.

The proposed change to the Technical Specifications are presented in Attachment I to this Application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE STATE  
OF NEW YORK

By C. M. Wilberding  
J. P. Bayne  
Senior Vice President  
Nuclear Generation

Subscribed and sworn to before  
me this 20 day of February 1981.

Ruth G. Zapp  
Notary Public  
Notary Public, State of New York  
No. 304683423  
Qualified in Nassau County  
Commission Expires March 30, 1982

8108030560