

NRP

Barber, Scott

From: Barkley, Richard
Sent: Monday, November 23, 2009 10:50 AM
To: Cullingford, Michael
Cc: Gitter, Joseph; Bellamy, Ronald; Barber, Scott
Subject: RE: 11/21/2009 TMI Contamination Control Event

Mike - Thanks for the heads up. I have been on the periphery of this issue. Ron or Scott can give you more details if needed.

I'll also forward a recent staff communication in this matter.

Richard S. Barkley, PE
Technical Communications Assistant, Region I
(610) 337-5065

(b)(6)

EX-6

 Please consider the environment before printing this e-mail. Thank you.

From: Cullingford, Michael
Sent: Monday, November 23, 2009 10:17 AM
To: Barkley, Richard
Cc: Gitter, Joseph
Subject: FW: 11/21/2009 TMI Contamination Control Event

Richard: fyi.....mike

From: Cullingford, Michael
Sent: Monday, November 23, 2009 10:13 AM
To: Schwartzman, Jennifer
Subject: FW: 11/21/2009 TMI Contamination Control Event

A summary of the subject TMI event as we know it today. Based on what we know, it is likely that this event would not even be rated on the INES scale. No operating limit was exceeded and no contamination outside the containment building has been detected.

Approximately at 4 PM Saturday 11/21 TMI had an event involving loss of contamination control inside containment. At the time the reactor was defueled with a hole cut in the containment wall to support the ongoing SG replacement outage. The licensee is not sure at this time what activity inside containment led to the problem. Their investigation is focusing on two activities (1) "A" piping loop decontamination activities or (2) some work on a drain line on the B" SG.

At the time of the event 175 workers were inside containment. Of these workers 151 people were selected for detailed monitoring based on nasal smears and portal monitor readings. Of the 151, preliminarily, about 19 people have potentially received doses greater than 10 mR. The highest dose to a worker was approximately 38 mR, far below the yearly NRC limit of 5000-mrem. No site worker left the site with external contamination. Airborne contamination levels inside containment have been restored to pre-event levels and cleanup of

DH

NRP

containment surfaces is in progress. The tarp that was covering the containment opening was contaminated on its inside surface and is in the process of being replaced.

With the open equipment hatch and the SG opening there was the potential for a release outside of containment. At the time of the event a slight positive pressure existed in containment. This has now been corrected to what it should be, ie a slightly negative pressure. Based on readings from radiation monitors present at the SG opening and the duration of the positive pressure, the estimates of release levels are still less than one percent of the quarterly limit in the licensee's offsite dose calculation manual.