

April 30, 2010

Mr. Scott Head, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 340 RELATED TO
SRP SECTION 3.11 FOR THE SOUTH TEXAS PROJECT COMBINED
LICENSE APPLICATION

Dear Mr. Head

By letter dated September 20, 2007, STP Nuclear Operating Company (STP) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **30** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 4668

Enclosure:
Request for Additional Information

cc: William Mookhoek
John Price

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 4668

Enclosure:
Request for Additional Information

cc: William Mookhoek
John Price

Distribution:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BAbeywickrama, NRO
JStrnisha, NRO
MNorato, NRO
SKirkwood, OGC
RidsNroDeCIB2
RidsNroDnrlNge2

ADAMS Accession No. : ML101200203

NRO-002

OFFICE	CIB2/TR	CIB2/BC	NGE2/PM	NGE2/L-PM
NAME	JStrnisha	MNorato	TTai	GWunder
DATE	4/26/10	4/26/10	4/30/10	4/30/10

***Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information No. 4668 Revision 3

**South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013**

**SRP Section: 03.11 - Environmental Qualification of Mechanical and Electrical Equipment
Application Section: 3.11**

QUESTIONS for Component Integrity, Performance, and Testing Branch 2 (ESBWR/ABWR Projects)
(CIB2)

03.11-7

Subsection 3.11.7 “Operational Information,” of the STP Units 3 & 4 FSAR states the following: “The EQ Program for STP 1 & 2 has been reviewed and approved by the NRC (NUREG-0781 Supplement 4, Safety Evaluation Report Related to the Operation of South Texas Projects Units 1 & 2”) and has been fully implemented. The EQ Program for the STP 3 & 4 will be consistent with the STP 1 & 2 Program, taking into consideration the appropriate differences between the existing and new units.”

As discussed in Regulatory Guide 1.206 and Commission Paper SECY-05-0197, COL applicants must fully describe their operational programs to avoid the need for ITAAC regarding those programs. Therefore, the NRC staff requests that STPNOC delete reference to the STP 1 & 2 operating plant EQ program and address the operational aspects of the EQ program in the STP Units 3 & 4 FSAR.