

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPMA.1.1

### Determine Maintenance of Active License Status

PREPARED/  
REVISED BY:

\_\_\_\_\_  
Date/

VALIDATED BY:

\*

\_\_\_\_\_  
Date/

APPROVED BY:

\_\_\_\_\_  
(Operations Training Manager)

\_\_\_\_\_  
Date/

CONCURRED:

\*\*

\_\_\_\_\_  
(Operations Representative)

\_\_\_\_\_  
Date/

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

**NUCLEAR TRAINING**  
**REVISION/USAGE LOG**

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial Issue, Adapted from watts Bar A.1-1 2009 NRC exam	Y	1/18/2010	All	M. Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

Task Determine License Status Active/Inactive  
Knowledge of Conduct of Operations requirements

JA/TA task #

K/A Ratings:  
2.1.1 3.8/4.2

Task Standard:

Evaluation Method : Simulator \_\_\_\_\_ In-Plant \_\_\_\_\_ Classroom X

Performer: \_\_\_\_\_  
NAME

Start time \_\_\_\_\_

Performance Rating : SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish time \_\_\_\_\_

Evaluator: \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

COMMENTS

---

---

---

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. A **Critical step** is identified bold type in the SAT/UNSAT column.
2. Any UNSAT requires comments.
3. This JPM will be performed in a classroom

Validation Time: CR \_\_\_\_\_ Local \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

OPDP-10

**REFERENCES:**

	Reference	Title	Rev No.
	OPDP-10	License Status Maintenance, reactivation and Proficiency for Non-Licensed Positions	1

Task Number	Task Title	Cont TRN
	Maintain Active NRC License	

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

Four Senior Reactor Operators have the following history:

1. All four SRO's have off-shift assignments at the plant, are current in License Operator Requalification Training, and have had a medical examination in the last year.
2. None of the 4 SRO's have worked any shift since 12/01/09.
3. Active/Inactive status and time on shift since October 1, 2009 are listed on the following page for each of the Senior Reactor Operators.



## INITIATING CUES:

1. You are to determine if each of the Senior Reactor Operators License Status is Active to work the Unit 1 SRO position on the 0700 - 1900 shift on January 31, 2010. Include reasons for determining active or inactive status.

<b>Operator A</b>	<b>License was active on October 1, 2009.</b>	
	10/02/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/03/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/04/09	Worked 0700-1900 shift in the Tagging Office.
	10/05/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/06/09	Worked 0700-1900 shift as Unit 2 SRO. SRO performed an observation at the Training Center for ILT in the simulator for 3 hours.
	11/14/09	Worked 1900-0700 shift as Unit 1 SRO.
<b>Operator B</b>	<b>License was active on October 1, 2009.</b>	
	10/07/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/08/09	Worked 0700-1900 shift as Unit 1 SRO. Absent from the Control Room for 1 hour while conducting a plant tour with another Senior Reactor Operator who is reactivating their license.
	10/09/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/10/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/11/09	Worked 0700-1900 shift as Unit 2 SRO.
<b>Operator C</b>	<b>License was active on October 1, 2009.</b>	
	10/01/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/02/09	Worked 0700-1900 shift in the Tagging Office.
	10/03/09	Worked 0700-1900 shift as Unit 1 CRO.
	10/05/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/14/09	Worked 1900-0700 shift as Unit 2 SRO.
	11/02/09	Worked 0700-1900 shift in the WCC.
<b>Operator D</b>	<b>License was inactive on October 1, 2009.</b>	
	10/5/09 thru 10/09/09 worked 40 hours under the direction of the Unit 1 SRO and completed all requirements for license reactivation.	
	11/12/09	Worked 0700-1900 shift as Unit 1 SRO.
	11/13/09	Worked 0700-1900 shift as Unit 1 SRO.
	11/15/09	Worked 0700-1900 shift as Unit 2 SRO.
	11/21/09	Worked 1900-0700 shift as Unit 1 SRO.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 1.:</u> Determine the Active / Inactive status of Operator A license.</p> <p><u>STANDARD:</u> Applicant determines the licensee is <u>Inactive</u> because the operator did not work the required qualified 5 twelve hour shifts in a license position during the previous quarter. The shift on 10/06/09 DOES NOT count due to the 3 hour absence. OPDP-10, Section 3.2.4.B states "Absences from the Control Room for extended periods (i.e., Fitness-for-Duty testing) will not count towards shift functions."</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p> <p>Start Time</p> <p>_____</p>
<p><u>STEP 2.:</u> Determine the Active / Inactive status of Operator B license</p> <p><u>STANDARD:</u> Applicant determines the licensee is <u>Active</u> because the operator worked 5 twelve hour shifts in a license position during the previous quarter. The 1 hour time during which the plant tour was conducted does count as "actively performing the functions of an operator."</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p> <p>_____</p>
<p><u>STEP 3.:</u> Determine the Active / Inactive status of Operator C license.</p> <p><u>STANDARD:</u> Applicant determines the license is <u>Inactive</u> because the operator did not work the required 5 twelve hour shifts in a license position during the previous quarter. The shifts worked in the tagging office and the WCC are not qualified positions.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 4.:</u> Determine the Active / Inactive status of Operator D license.</p> <p><u>STANDARD:</u> Applicant determines the license is <u>Active</u> because the license was reactivated in the previous quarter, including working 40 hours under the direction of the Unit 1 SRO.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p> <p>_____ Stop Time</p>

End Of JPM

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

Four Senior Reactor Operators have the following history:

1. All four SRO's have off-shift assignments at the plant, are current in License Operator Requalification Training, and have had a medical examination in the last year.
2. None of the 4 SRO's have worked any shift since 12/01/09.
3. Active/Inactive status and time on shift since October 1, 2009 are listed on the following page for each of the Senior Reactor Operators.

## INITIATING CUES:

1. You are to determine if each of the Senior Reactor Operators License Status is Active to work the Unit 1 SRO position on the 0700 - 1900 shift on January 31, 2010. Include reasons for determining active or inactive status.

<b>Operator A</b>	<b>License was active on October 1, 2009.</b>	
	10/02/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/03/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/04/09	Worked 0700-1900 shift in the Tagging Office.
	10/05/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/06/09	Worked 0700-1900 shift as Unit 2 SRO. SRO performed an observation at the Training Center for ILT in the simulator for 3 hours.
	11/14/09	Worked 1900-0700 shift as Unit 1 SRO.
<b>Operator B</b>	<b>License was active on October 1, 2009.</b>	
	10/07/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/08/09	Worked 0700-1900 shift as Unit 1 SRO. Absent from the Control Room for 1 hour while conducting a plant tour with another Senior Reactor Operator who is reactivating their license.
	10/09/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/10/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/11/09	Worked 0700-1900 shift as Unit 2 SRO.
<b>Operator C</b>	<b>License was active on October 1, 2009.</b>	
	10/01/09	Worked 0700-1900 shift as Unit 1 SRO.
	10/02/09	Worked 0700-1900 shift in the Tagging Office.
	10/03/09	Worked 0700-1900 shift as Unit 1 CRO.
	10/05/09	Worked 0700-1900 shift as Unit 2 SRO.
	10/14/09	Worked 1900-0700 shift as Unit 2 SRO.
	11/02/09	Worked 0700-1900 shift in the WCC.
<b>Operator D</b>	<b>License was inactive on October 1, 2009.</b>	
	10/5/09 thru 10/09/09 worked 40 hours under the direction of the Unit 1 SRO and completed all requirements for license reactivation.	
	11/12/09	Worked 0700-1900 shift as Unit 1 SRO.
	11/13/09	Worked 0700-1900 shift as Unit 1 SRO.
	11/15/09	Worked 0700-1900 shift as Unit 2 SRO.
	11/21/09	Worked 1900-0700 shift as Unit 1 SRO.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM123

### CONTAINMENT FORMALDEHYDE STAY TIME CALCULATION

**PREPARED/  
REVISED BY:**

Date/

**VALIDATED  
BY:**

\*

Date/

**APPROVED  
BY:**

Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

## NUCLEAR TRAINING

### REVISION/USAGE LOG

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/REVISED BY:
0	New JPM	Y	12/5/08	All	T. Wooley
1	Revised due to inaccuracies regarding respiratory requirement not applicable.	N	12/9/08	2, 6	M. Chambers
2	Updated KA Task, revised initial conditions	Y	1/06/10	All	M Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

**Task:**

Calculation Containment Formaldehyde stay time and Determine respiratory protection requirements.

**JA/TA task:**

**K/A Ratings:**

2.1.26 (3.4 / 3.6) Knowledge of Industrial Safety Procedures

**Task Standard:**

Calculate containment formaldehyde stay time and determine respiratory protection requirements in accordance with 0-TI-OPS-000-001.0.

**Evaluation Method :** Simulator \_\_\_\_\_ In-Plant \_\_\_\_\_ Classroom  X

**Performer:** \_\_\_\_\_  
NAME

Start Time \_\_\_\_\_

**Performance Rating :** SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish Time \_\_\_\_\_

**Evaluator:** \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

**COMMENTS**

---

---

---

---

---

---

---

---

---

---



**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Critical steps identified by an asterisk (\*).
2. Sequenced steps identified by an "s".
3. Any **UNSAT** requires comments.
4. Ensure Operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time:** CR. \_\_\_\_\_ **Local** \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

0-TI-OPS-000-001.0, Containment Formaldehyde Stay Time Calculation  
Calculator

**References:**

	Reference	Title	Rev No.
1.	0-TI-OPS-000-001.0	Containment Formaldehyde Stay Time Calculation	5

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. This JPM will be performed in the classroom. I will provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

- Unit 1 is in Mode 1 at 100% power.
- A Level Switch inside lower containment needs repair.
- 0-SI-OPS-000.011.0, Containment Access Control during Modes 1 – 4, has been initiated in preparation for a containment entry to investigate the alarm condition.
- The containment entry requires at least 120 minutes.
- A Chemistry sample taken today at 0900 hours yielded a lower containment formaldehyde concentration of 1.32 ppm.
- Section 4.0, Prerequisite Actions, of 0-TI-OPS-000-001.0 is complete.

**INITIATING CUES:**

You have been directed by the US to:

- a) Calculate the allowable containment stay time for the given formaldehyde concentration in accordance with 0-TI-OPS-000-001.0
- AND**
- b) Identify all required actions to complete the level switch repair in accordance with 0-TI-OPS-000-001.0, Containment Formaldehyde Stay Time Calculation.

<p><b>STEP *1.:</b> Unit 1 Lower Containment Entry  <b>CALCULATE</b> Unit 1 Lower containment stay time <b>USING</b> the following equation:</p> $\frac{0.3 \text{ ppm} \times 480 \text{ minutes}}{\text{sample recorded in Step 5.1[1] (1.32)}} = \text{_____ minutes}$ $\frac{.3 \times 480}{1.32} = \frac{144}{1.32} = 109.1$ <p><b>STANDARD:</b> Operator calculates a containment stay time of 109.1 (± 1) minutes using equation found in applicable section (5.1) of 0-TI-OPS-000-001.0.</p>	<p>___ SAT          ___ UNSAT          Start Time _____    <b>Critical Step</b></p>
<p><b>STEP 2.:</b> Identify all required actions to complete level switch repair in accordance with step 7 of TI:</p> <p>Operator determines Job duration exceeds Stay time</p> <p>[7] <b>IF</b> any required task CANNOT be performed within allowed stay time, <b>THEN PERFORM</b> the following ...</p> <p>[7.1] Contact Industrial Safety for additional guidance</p> <p>[7.2] Evaluate or notify supervisor to evaluate the need for lower Containment Purge in accordance with 0-SO-30-3.</p> <p>[7.3] DO NOT CONTINUE task UNTIL one of the following conditions are met:                  Job Safety Analysis has been performed                  OR                  Stay Time is Acceptable</p> <p><b>EXAMINER NOTE:</b> If applicant states that the level switch repairs cannot be performed unless a respirator is worn, this is not correct.</p> <p><b>STANDARD:</b> Operator determines Job duration exceeds Calculated Stay Time.</p> <p>Operator determines that the level switch repair cannot be performed until the following criteria are completed:          1- A Job Safety Analysis has been performed          2- Industrial Safety is contacted          3- An evaluation of the need for Lower Containment Purge</p> <p><b>COMMENTS:</b></p>	<p>___ SAT          ___ UNSAT    <b>Critical Step</b>            Stop Time _____</p>

End of JPM

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. This JPM will be performed in the classroom. I will provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- Unit 1 is in Mode 1 at 100% power.
- A Level Switch inside lower containment needs repair.
- 0-SI-OPS-000.011.0, Containment Access Control during Modes 1 – 4, has been initiated in preparation for a containment entry to investigate the alarm condition.
- The containment entry requires at least 120 minutes.
- A Chemistry sample taken today at 0900 hours yielded a lower containment formaldehyde concentration of 1.32 ppm.
- Section 4.0, Prerequisite Actions, of 0-TI-OPS-000-001.0 is complete.

### **INITIATING CUES:**

You have been directed by the US to:

- a) Calculate the allowable containment stay time for the given formaldehyde concentration in accordance with 0-TI-OPS-000-001.0,  
**AND**
- b) Identify all required actions to complete the level switch repair in accordance with 0-TI-OPS-000-001.0, Containment Formaldehyde Stay Time Calculation.

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. This JPM will be performed in the classroom. I will provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

- Unit 1 is in Mode 1 at 100% power.
- A Level Switch inside lower containment needs repair.
- 0-SI-OPS-000.011.0, Containment Access Control during Modes 1 – 4, has been initiated in preparation for a containment entry to investigate the alarm condition.
- The containment entry requires at least 120 minutes.
- A Chemistry sample taken today at 0900 hours yielded a lower containment formaldehyde concentration of 1.32 ppm.
- Section 4.0, Prerequisite Actions, of 0-TI-OPS-000-001.0 is complete.

### INITIATING CUES:

You have been directed by the US to:

- a) Calculate the allowable containment stay time for the given formaldehyde concentration in accordance with 0-TI-OPS-000-001.0, section 5.1 step 3.
- AND**
- b) Identify all required actions to complete the level switch repair in accordance with 0-TI-OPS-000-001.0, Containment Formaldehyde Stay Time Calculation, Section 5.1, Step 7.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

**JPM 410-1  
SRO A2**

## Review Surveillance for Approval

<b>PREPARED/ REVISED BY:</b>	_____	Date/
<b>VALIDATED BY:</b>	* _____	Date/
<b>APPROVED BY:</b>	_____	Date/
	(Operations Training Manager)	
<b>CONCURRED:</b>	** _____	Date/
	(Operations Representative)	

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

## NUCLEAR TRAINING

### REVISION/USAGE LOG

[illegible]

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

## COMMENTS

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. This JPM will be performed in a classroom setting.
2. Any unsat requires comments.

**Validation Time:** CR. 20 minutes

**Local** \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

Ruler  
Calculator

**References:**

	Reference	Title	Rev No.
1.	0-SI-SXX-068-137.3	Measurement of Reactor Coolant Pump Seal Injection Flow for Units 1 and 2	6
2	SPP-3.5	Regulatory Requirements	21
3.	TS	Technical Specifications	Latest
4.	TR	Technical Requirements	Latest

=====

**READ TO OPERATOR**

**DIRECTIONS TO TRAINEE:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

- You are the Unit 1 Unit Supervisor.
- 1A-A CCP is I/S, discharge pressure 2400 psig (PI-62-92A)
- RCS Pressure 2240 psig (PI-68-334)
- 0-SI-SXX-068-137.3, Measurement of Reactor Coolant Pump Seal Injection Flow for Units 1 and 2, has just been completed.

**INITIATING CUES:**

1. Perform the Unit Supervisor review of the completed surveillance.
2. Identify any actions required.
3. Identify all required notifications that the Shift Manager must make.



<p><b>STEP 1.:</b>      Reviews sections 4.0, 4.1, 4.2, 4.3 and 4.4 of surveillance</p> <p><b>STANDARD:</b>    Determines all required initials and signatures are present, steps performed have required place keeping.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time _____</p>
<p><b>The following steps are from Section 6.0.</b></p>	
<p><b>STEP 2.:</b>      [6.1.1] ENSURE RCS pressure reading is 2235 +/- 20 psig</p> <p><b>STANDARD:</b>    SRO reviews step and ensure RCS pressure is within 2235 psig +/- 20 psig.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 3.:</b>      [6.1.2] ENSURE CCP A-A is operating.....</p> <p><b>STANDARD:</b>    SRO reviews step and ensures CCP AA is in service</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b>      [6.1.3] RECORD pressure reading in MCR.....</p> <p style="padding-left: 100px;">[6.1.3.a] PI-68-334 _____ psig</p> <p><b>STANDARD:</b>    SRO reviews step and ensures RCS pressure recorded is within 2235 +/- 20 psig. Initial conditions RCS pressure 2240 psig on PI-68-334.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b>      [6.1.3] RECORD pressure reading in MCR....(Continued)</p> <p style="padding-left: 100px;">[6.1.3.b] PI-62-92A _____ psig</p> <p><b>STANDARD:</b>    SRO reviews step and ensures CCP discharge pressure recorded is 2400. Initial conditions 1A-A CCP discharge pressure is 2400 psig</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 6.:</b> [6.1.4] PERFORM calculation to determine differential pressure.....</p> <p><b>STANDARD:</b> SRO reviews calculation for differential pressure and determines that</p> <ul style="list-style-type: none"> <li>• Operator recorded RCS pressure as 2230 psig rather than 2240 psig.</li> <li>• Differential pressure is actually 160 psid rather than 170 psid as recorded.</li> </ul> <p>SRO initiates a SR (PER) on the Human Performance Error. Initiation of SR is Not a Critical Step)</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 7.:</b> [6.1.5] IF pressure drop is less than 100 psig.....</p> <p><b>STANDARD:</b> SRO determines step 6.1[5] is N/A since pressure drop is greater than 100 psig.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 8.:</b> [6.1.6] RECORD the seal injection flow rate to each of the four RCP's.....</p> <p><b>STANDARD:</b> SRO determines flow rates are recorded for each RCP loop and that the total Injection flow rate was calculated correctly.</p> <p><b>COMMENTS:</b> <math>9.4 + 9.6 + 9.3 + 9.7 = 38 \text{ gpm}</math></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

<p><b>STEP 9.:</b> [6.1.7] FIND the point on the figure in Appendix A corresponding to DP.....</p> <p><b>STANDARD:</b> Determines that with the correct DP, Acceptance Criteria is <b>not</b> met for the current seal injection flows.</p> <p>The following actions or notifications may be performed in this step or in JPM step 9.</p> <p>SRO determines the following actions must be performed:</p> <ul style="list-style-type: none"> <li>• Perform SI Section 6.3, Throttle Adjustment of Seal Injection Needle Valves</li> <li>• Enter LCO 3.5.6, 4 hours to adjust valves or be in Hot Standby in the next 6 hours</li> <li>• Make notifications, in accordance with SPP-3.5 to Duty Plant Manager, Plant Manager, Site VP and Corporate Duty officer (Unplanned entry into a LCO with time duration 72 hours or less.</li> <li>• SRO is initiate a SR (PER) on the Human Performance Error. (Not a critical step)</li> </ul> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 10.:</b> [6.1.8] IF the plotted point for differential pressure versus seal injection flow falls outside the "acceptable region".....</p> <p><b>STANDARD:</b> SRO determines that the plotted point is not in the acceptable region and therefore the following actions/notifications are required:</p> <ul style="list-style-type: none"> <li>• Perform SI Section 6.3, Throttle Adjustment of Seal Injection Needle Valves</li> <li>• Enter LCO 3.5.6, 4 hours to adjust valves or be in Hot Standby in the next 6 hours</li> <li>• Make notifications, in accordance with SPP-3.5, Appendix D – Site Event Notification Matrix, due to an Unplanned entry into a LCO with time duration 72 hours or less: <ul style="list-style-type: none"> <li>◦ Duty Plant Manager</li> <li>◦ Plant Manager</li> <li>◦ Site VP</li> <li>◦ Corporate Duty Officer</li> <li>◦</li> </ul> <p>(NOTE: These notifications may be accomplished by the SM notifying Operations Management and the Duty Plant manager. The Duty Plant Manager is responsible for the remaining internal management notifications as noted in the matrix. See note above the matrix in Appendix D)</p> </li> <li>• Initiate a SR (PER) (initiation of SR is not a critical step)</li> </ul> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p> <p>Stop Time_____</p>

**DIRECTIONS TO TRAINEE:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

- You are the Unit 1 Unit Supervisor.
- 1A-A CCP is I/S, discharge pressure 2400 psig (PI-62-92A)
- RCS Pressure 2240 psig (PI-68-334)
- 0-SI-SXX-068-137.3, Measurement of Reactor Coolant Pump Seal Injection Flow for Units 1 and 2, has just been completed.

**INITIATING CUES:**

1. Perform the Unit Supervisor review of the completed surveillance.
2. Identify any actions required.
3. Identify all required notifications that the Shift Manager must make.

# Surveillance Task Sheet (STS)

Work Order:

SI Key:

Procedure: 0-SI-SXX-068-137.3

Train/Loop:

Unique Data:

Title: Measurement of RCP Seal Injection Flow for Unit 1 & 2

Perf Sect: OPS

Test Reason: Quarterly

Unit: 0

Authorization to Begin: SRO

Date

Time

Data Sheet: One Complete copy

Issued:

Extension:

Frequency: NONE

FO: N

TS: Y

ASME XI: N

Mode:

SX

Applicable Modes: 1,2,3,4,5,6

Perfor Modes: 1,2,3,4,5,6

Clearance Required:

Sched. Rec. #:

Dry Cask Storage:

Subsequent Reviews:

Initial

Date

Cognizant Engr

Cem Admin Reviewer

Was this a Complete or Partial Performance?  
(Explain Partial in "Remarks" below)

Complete ☒ Partial ☐

Were all Tech Spec/Tech Req/ISFSI CoC/ODCM/Fire Prot  
Req/AMSAC acceptance criteria satisfied?

Yes ☒ No ☐ N/A ☐

Were all other acceptance criteria satisfied?

Yes ☒ No ☐ N/A ☐

If all Tech Spec Tech Req/ISFSI CoC/ODCM/Fire Prot  
Req/AMSAC were not satisfied, was an LCO/TR/ODCM  
Action required ((Explain in "Remarks"))

Yes ☐ No ☒ N/A ☒

Print Name	Test Performer's Signature	Initial	Section
Reactor Operator X	Reactor Operator X	Rox	OPS
Reactor Operator Y	Reactor Operator Y	Roy	OPS
Senior Reactor Op	Senior Reactor Operator	SRK	OPS

Reactor Operator X Reactor Operator Y TODAY  
Test Director Lead Performer Date

Acceptance Criteria Review: SRO

Date

Time

(ASME XI SIs require review within 96 hours)

Independent Reviewer

PERMANENT COMMENTS:

REMARKS:

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT

SURVEILLANCE INSTRUCTION

**0-SI-SXX-068-137.3**

**MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW  
FOR UNITS 1 AND 2**

Revision 6

**QUALITY RELATED**

PREPARED BY: MS Leenerts

RESPONSIBLE ORGANIZATION: SE/NSSS

APPROVED BY: MR Cooper

EFFECTIVE DATE: 03/21/2001

LEVEL OF USE: **CONTINUOUS USE**

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 2 of 21
--------------------	--	---

REVISION  
DESCRIPTION

Revised to clarify seal injection flow calculation.  
Revised to incorporate the impacts of TS change 00-05 (TS 4.1.2.1.c and TS 4.1.2.2.c changed to TRM 4.1.2.1.c and TRM 4.1.2.2.c). Non Intent change

<b>SQN</b> <b>1, 2</b>	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	<b>0-SI-SXX-068-137.3</b> Rev 6 Page 3 of 21
---------------------------	--	--

TABLE OF CONTENTS  
PAGE 1 OF 1

Section	Title	Page
	<b>TABLE OF CONTENTS</b>	<b>3</b>
<b>1.0</b>	<b>INTRODUCTION.....</b>	<b>4</b>
1.1	Purpose .....	4
1.2	Scope .....	4
1.2.1	Test to be Performed .....	4
1.2.2	Requirements Fulfilled .....	5
1.2.3	Modes .....	5
1.3	Test Frequency/Conditions .....	5
<b>2.0</b>	<b>REFERENCES .....</b>	<b>5</b>
2.1	Performance References .....	5
2.2	Developmental References .....	6
<b>3.0</b>	<b>PRECAUTIONS AND LIMITATIONS .....</b>	<b>6</b>
<b>4.0</b>	<b>PREREQUISITE ACTIONS.....</b>	<b>7</b>
4.1	Preliminary Actions .....	7
4.2	Measuring and Test Equipment, Parts, and Supplies .....	7
4.3	Field Preparations.....	8
4.4	Approvals and Notifications .....	8
<b>5.0</b>	<b>ACCEPTANCE CRITERIA.....</b>	<b>9</b>
<b>6.0</b>	<b>PERFORMANCE .....</b>	<b>9</b>
6.1	Centrifugal Charging Pump A-A.....	9
6.2	Centrifugal Charging Pump B-B.....	13
6.3	Throttle Adjustment of Seal Injection Needle Valves .....	17
<b>7.0</b>	<b>POST SURVEILLANCE ACTIVITIES .....</b>	<b>19</b>
7.1	Restoration .....	19
7.2	Results.....	19
<b>8.0</b>	<b>RECORDS .....</b>	<b>20</b>
	<b>APPENDIX A .....</b>	<b>21</b>



<b>SQN</b> <b>1, 2</b>	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 4 of 21
---------------------------	--	---

UNIT   i  

## 1.0 INTRODUCTION

### 1.1 Purpose

This Surveillance Instruction (SI) provides detailed steps to measure total injection flow to the reactor coolant pump seals for Units 1 and 2. The purpose of this SI is to ensure adequate resistance exists in the seal injection lines so that in the event of Loss of Coolant Accident (LOCA) the safety injection flow will not be less than assumed in the accident analysis. If desired, this SI can be used to improve system balance and used to verify final valve positions meet the Acceptance Criteria.

### 1.2 Scope

#### 1.2.1 Test to be Performed

Measurements of seal injection flow shall be performed while in Mode 1, 2 or 3 with the RCS pressure at  $2235 \pm 20$  psig.

- A. This SI will verify during this test that the total injection flow to the RCP seals meets the requirements of Technical Specifications for seal injection flow limits.
  - 1. If Acceptance Criteria are not met, the seal injection line needle valves will be adjusted to provide required system resistance.
  - 2. Needle valves will be sealed in position after adjustment.
- B. This Instruction shall verify that these valves are sealed in position after the adjustment. (Reference TRM 4.1.2.1.c & 4.1.2.2.c.)

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 5 of 21
--------------------	--	---

UNIT 1

### 1.2.2 Requirements Fulfilled

Performance of this Instruction meets the requirements of TS 4.5.6 and partially fulfills the requirements of TRM 4.1.2.1.c and 4.1.2.2.c.

### 1.2.3 Modes

Plant operating modes for which the requirements covered by this Instruction shall be satisfied (applicable modes) and during which the test can be performed (performing modes) are:

- A. Applicable Modes 1, 2, and 3.
- B. Performance Mode 1, 2, or 3.

### 1.3 Test Frequency/Conditions

This Instruction shall be performed at least once per 31 days and after any seal work on RCPs. This Instruction is not required to be performed until RCS pressure has stabilized at 2215 to 2255 psig. When the 31 day limit has been exceeded or seal work has been performed, this instruction must be performed within 4 hours after stabilization within these limits.

## 2.0 REFERENCES

### 2.1 Performance References

- A. SPP-3.1, Corrective Action Program.
- B. SPP-8.1, Conduct of Testing.
- C. 1-SO-62-1, 2-SO-62-1, Chemical & Volume Control System.

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 6 of 21
--------------------	--	---

UNIT 1

## 2.2 Developmental References

- A. Writer's Guide.
- B. Technical Specifications Surveillance Requirement 4.5.6 and Technical Requirements Manual 4.1.2.1.c and 4.1.2.2.c.
- C. Technical Specification Figure 3.5.6-1, Seal Injection Flow Limits.
- D. Westinghouse letter TVA-86-671 from L. L. Williams to John A. Raulston, dated June 27, 1986 (RIMS No. B45 860707 607).
- E. Westinghouse letter TVA-84-057 from R. S. Howard to John A. Raulston, dated March 16, 1984 (RIMS No. LOO 840322161).
- F. LER SQRO-50-327/86044, Inadequate Verification of ECCS Flow Due to Procedural Inadequacy.
- G. Design Criteria, SQN-DC-V-27.3, Safety Injection System
- H. Technical Specification Change 98-10.
- I. Technical Specification Change 00-05.

## 3.0 PRECAUTIONS AND LIMITATIONS

- ~~A.~~ RCS pressure must be maintained at  $2235 \pm 20$  psig throughout performance of this surveillance.
- ~~B.~~ Failure to meet Acceptance Criteria may result in entering Limiting Condition for Operation (LCO) 3.5.6, which may result in adjusting manual seal injection needle valves to give a flow within limits in 4 hours.

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 7 of 21
-------------	---	---

Unit 1

Date TODAY

#### 4.0 PREREQUISITE ACTIONS

✓ **NOTE 1** Throughout this Instruction, during an IF-THEN statement, the step should be marked N/A when stated IF condition does not occur.

✓ **NOTE 2** The Surveillance Task Sheet may be completed as information becomes available.

#### 4.1 Preliminary Actions

✓ **[1] ENSURE** Instruction to be used is a copy of the effective version, and

**RECORD** applicable Pretest Data on Surveillance Task Sheet.

Rox  
Initials

✓ **[2] ENSURE** NO clearances or system off normal configurations exist which would prevent completion of testing.

Rox  
Initials

✓ **[3] IF** configurations or clearances prevent performance of this Instruction, **THEN**

**NOTIFY** Unit SRO and responsible Supervisor.

Rox  
Initials

#### 4.2 Measuring and Test Equipment, Parts, and Supplies

None.

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT  PUMP SEAL INJECTION FLOW FOR UNITS 1  AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 8 of 21
--------------------	--	---

Unit 1

Date TODAY

#### 4.3 Field Preparations

**NOTE**

Steps within Section 4.3 (Field Preparations) may be performed in any order.

**(1) VERIFY** the following personnel are available to support the test as required:

**A** Assistant Unit Operator (AUO). ☒

**B** Radiological Control (RADCON). ☒

Rox  
Initials

**(2) VERIFY** Radiation Work Permits are available for test performance, **OR**

**OBTAIN** RWPs as required.

Rox  
Initials

**(3) VERIFY** plant is in Mode 1, 2, or 3.

Rox  
Initials

#### 4.4 Approvals and Notifications

**(1) OBTAIN** unit SRO's permission to perform this Instruction.

Skoll-1 1 TODAY 1 NOW  
Unit SRO Date Time

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 9 of 21
-------------	---	---

Unit 1

Date TODAY

## 5.0 ACCEPTANCE CRITERIA

- ☒ A. Total flow rate to the RCP seals must be within the "acceptable region" shown in the figure in Appendix A with RCS pressure at  $2235 \pm 20$  psig.

## 6.0 PERFORMANCE

- ☒ NOTE 1 Component's prefix is omitted throughout procedure; it shall be 1 or 2 as per unit tested.
- ☒ NOTE 2 This instruction is written such that either section 6.1 or section 6.2 can be performed to take advantage of the pump in operation.
- ☒ NOTE 3 Section 6.3 may be performed to balance seal injection flows when desired.

### 6.1 Centrifugal Charging Pump A-A

- ☒ NOTE 1 All steps in this section may be marked N/A if CCP B-B is in service.
- ☒ NOTE 2 N/A the Indicator/Computer Point not used in Steps [3] and [6]
- ☒ NOTE 3 If instrument reading does not meet Acceptance Criteria of  $2235 \pm 20$  psig, then acceptable pressure will have to be established or wait for required pressure and then repeat Step 6.1 [1].

- ☒ [1] ENSURE reactor coolant pressure reading is  $2235 \pm 20$  psig at one of the following: (Check one used.)
- A. at **[PI-68-334]** Main Control Room (MCR) or
- B. P0481A (corresponding Computer Point),
- OR
- C. at **[PI-68-323]** MCR or
- D. P0482A (corresponding Computer Point)

☒

☒ N/A

☐

☒

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 10 of 21
--------------------	--	--

 Unit i

 Date TODAY

### 6.1 Centrifugal Charging Pump A-A (Continued)

**[2] ENSURE** Centrifugal Charging pump (CCP) A-A is operating and supplying normal charging and seal flow in accordance with 1,2-SO-62-1.

Rox  
Initials

**[3] RECORD** pressure readings in MCR for the following:

**[PI-68-334]** 2240 psig or  
**[P0481A]** N/A psig, OR  
**[PI-68-323]** \_\_\_\_\_ psig or  
**[P0482A]** ✓ psig.

☒

**[PI-62-92A]** 2400 psig or  
**[P0142A]** N/A psig.

☒

Rox  
Initials

**[4] PERFORM** calculation to determine differential pressure (between PT-62-92 and pressurizer):

Step 6.1 [3] B 2400 psig - (minus) Step 6.1 [3] A 2230 psig = 170 psid

Rox  
Initials

Rox  
Checker

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 11 of 21
-------------	---	--

Unit 1

Date TODAY

6.1 Centrifugal Charging Pump A-A (Continued)

- ~~[5]~~ IF pressure drop is less than 100 psig, THEN  
**ADJUST [FCV-62-89]** CLOSED to increase header  
pressure, and  
**REPEAT** Steps 6.1 [3] and 6.1 [4].

N/A  
Initials

✓ **NOTE**

Failure to meet Acceptance Criteria results in entering Limiting Condition for Operation (LCO) 3.5.6 for seal injection flow. The flow rate must be reduced to meet Acceptance Criteria within 4 hours by adjustment of seal injection needle valves.

- ~~[6]~~ **RECORD** the seal injection flow rate to each of the four reactor coolant pumps (RCPs), and  
**CALCULATE** total flow rates below by adding seal injection flow rates in each RCP loop.

~~A.~~ RCP Loop 1 **[FI-62-1A]** 9.4 gpm or  
F0704A N/A gpm

Rox  
Initials

~~B.~~ RCP Loop 2 **[FI-62-14A]** 9.6 gpm or  
F0703A N/A gpm

Rox  
Initials



SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 12 of 21
-------------	---	--

Unit 1

Date TODAY

### 6.1 Centrifugal Charging Pump A-A (Continued)

☒ RCP Loop 3 **[FI-62-27A]** 9.3 gpm or

F0702A N/A gpm

Rox  
Initials

☒ RCP Loop 4 **[FI-62-40A]** 9.7 gpm or

F0701A N/A gpm

Rox  
Initials

☒ Total Seal Injection Flow Rate = A + B + C + D.  
= 38 gpm

Rox  
Initials

Rox  
Checker

☒ **FIND** the point on the figure in Appendix A corresponding to the DP from Step 6.1[4] and Seal Injection Flow from Step 6.1[6]E.

Rox  
Initials

Rox  
Checker

**Acceptance Criteria** Plotted point for differential pressure versus seal injection flow falls within the "acceptable region" of the figure in Appendix A.

☒ **[8] IF** the plotted point for differential pressure versus seal injection flow falls outside the "acceptable region" of the figure in Appendix A,  
**THEN**

**NOTIFY** Unit SRO that LCO 3.5.6 should be entered AND

**PERFORM** Section 6.3.

N/A  
Initials

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 15 of 21
-------------	---	--

Unit 1

Date TODAY

**6.2 Centrifugal Charging Pump B-B (Continued)**

- [5] IF pressure drop is less than 100 psig, **THEN**  
**ADJUST [FCV-62-89]** CLOSED to increase header  
pressure, and  
**REPEAT** Steps 6.2 [3] and 6.2 [4].

NIA  
Initials

**NOTE** Failure to meet Acceptance Criteria results in entering Limiting  
Condition for Operation (LCO) 3.5.6. The leakage rate must be  
reduced to meet Acceptance Criteria within 4 hours by adjustment  
of seal injection needle valves.

- [6] **RECORD** the seal injection flow rate to each of the four  
reactor coolant pumps (RCPs), and  
**CALCULATE** total flow rates below by adding seal  
injection flow rates in each RCP loop.

A. RCP Loop 1 **[FI-62-1A]** \_\_\_\_\_ gpm or

F0704A \_\_\_\_\_ gpm

B. RCP Loop 2 **[FI-62-14A]** \_\_\_\_\_ gpm or

F0703A \_\_\_\_\_ gpm

C. RCP Loop 3 **[FI-62-27A]** \_\_\_\_\_ gpm or

F0702A \_\_\_\_\_ gpm

D. RCP Loop 4 **[FI-62-40A]** \_\_\_\_\_ gpm or

F0701A \_\_\_\_\_ gpm

E. Total Seal Injection Flow Rate = A + B + C + D.

= \_\_\_\_\_ gpm

NIA  
Initials

\_\_\_\_\_  
Initials

\_\_\_\_\_  
Initials

\_\_\_\_\_  
Initials

\_\_\_\_\_  
Initials

✓  
Checker

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 16 of 21
-------------	---	--

Unit 1

Date TODAY

## 6.2 Centrifugal Charging Pump B-B (Continued)

- [7] **FIND** the point on the figure in Appendix A corresponding to the DP from Step 6.2[4] and Seal Injection Flow from Step 6.2[6]E.

N/A  
Initials  
✓  
Checker

### Acceptance Criteria

Plotted point for differential pressure versus seal injection flow falls within the "acceptable region" of the figure in Appendix A.

- [8] **IF** the plotted point for differential pressure versus seal injection flow falls outside the "acceptable region" of the figure in Appendix A,  
**THEN**

**NOTIFY** Unit SRO that LCO 3.5.6 should be entered and

**PERFORM** Section 6.3.

N/A  
Initials

<b>SQN</b> 1, 2	<b>MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2</b>	0-SI-SXX-068-137.3 Rev 6 Page 17 of 21
--------------------	--	--

Unit 1

Date TODAY

### 6.3 THROTTLE ADJUSTMENT OF SEAL INJECTION NEEDLE VALVES

**NOTE 1** Section 6.3 can be done with **[FCV-62-93]** in automatic or manual.

**NOTE 2** The goal is to have equal seal flow to each RCP and positioning of **[FCV-62-89]** and **[FCV-62-93]** to provide optimized control for normal plant operation and transients. An example is **[FCV-62-89]** throttled approximately 60-70 percent Open, **[FCV-62-93]** throttled approximately 30-40 percent Open, and Charging to RCS pressure between 130 to 160 psig. Other conditions may also provide acceptable results.

**NOTE 3** Opening throttle valves, 62-556 through 559, will result in opening of **[FCV-62-89]** to maintain seal flow with a decrease in charging header pressure. Closing throttle valves, 62-556 through 559, will result in closing **[FCV-62-89]** to maintain seal flow with an increase in charging header pressure.

**CAUTION** Do not allow seal injection flow to drop below 6 gpm during the following step to prevent seal damage. Maintain pressurizer level within normal operating band.

**NOTE 4** Steps [1] and [2] can be done together.

**[1] ADJUST** RCP seal injection needle valves to achieve approximately the same flow rate at 8 gpm (6 to 10 gpm tolerance) on each RCP loop.

N/A  
Initials

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 18 of 21
-------------	---	--

Unit 1

Date TODAY

### 6.3 THROTTLE ADJUSTMENT OF SEAL INJECTION NEEDLE VALVES (Continued)

- [2] **MAINTAIN** Pressurizer level and seal injection flow rates at normal operating conditions by adjusting **[FCV-62-93]** and **[FCV-62-89]** as necessary.

NA  
Initials

- [3] **RECORD** adjustments to the seal injection needle valves.

RCP-SEAL (LOOP NO)	VALVE	ADJUSTMENT (Example - 1/4 , 2, turns etc.)			
1	62-556	___ turns OPEN <input checked="" type="checkbox"/>	CLOSED <input type="checkbox"/>	NA <input type="checkbox"/>	✓
2	62-557	___ turns OPEN <input checked="" type="checkbox"/>	CLOSED <input type="checkbox"/>	NA <input type="checkbox"/>	✓
3	62-559	___ turns OPEN <input checked="" type="checkbox"/>	CLOSED <input type="checkbox"/>	NA <input type="checkbox"/>	✓
4	62-558	___ turns OPEN <input checked="" type="checkbox"/>	CLOSED <input type="checkbox"/>	NA <input type="checkbox"/>	✓

N/A  
Initials

- [4] **PERFORM** section 6.1 or section 6.2 to verify Acceptance Criteria after seal injection needle valve adjustments have been made.

N/A  
Initials

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 19 of 21
-------------	---	--

Unit 1

Date TODAY

7.0

## POST SURVEILLANCE ACTIVITIES

### NOTE

If difficulty is encountered in automatic pressurizer level control after adequate seal flow is obtained System Engineering should be notified to evaluate cause.

7.1

## Restoration

[1] IF valves were adjusted, THEN

ENSURE that lead seals are installed on the seal injection line needle valves listed below:

	RCP-SEAL (LOOP NO)	VALVE	1ST/IV
A.	1	62-556	N/A
B.	2	62-557	/
C.	3	62-559	/
D.	4	62-558	✓

[2] ENSURE [HIC-62-93A] MCR is in AUTO.

Rox  
Initials  
Rox  
IV

7.2

## Results

[1] ENSURE any LCOs are exited and testing is recorded on Surveillance Task Sheet.

Rox  
Initials

[2] ENSURE SRO and UO are aware of completion of testing and test results.

Rox  
Initials

SQN 1, 2	MEASUREMENT OF REACTOR COOLANT PUMP SEAL INJECTION FLOW FOR UNITS 1 AND 2	0-SI-SXX-068-137.3 Rev 6 Page 20 of 21
-------------	---	--

Unit 1

Date TODAY

## 8.0 RECORDS

### NOTE

Signature and spaces are provided on Surveillance Task Sheet for review/approval of test results. Additional sheets may be added as necessary.


[1]

COMPLETE applicable sections of Surveillance Task Sheet.

Roy  
Initials

<b>SQN</b> <b>1, 2</b>	<b>MEASUREMENT OF REACTOR COOLANT  PUMP SEAL INJECTION FLOW FOR UNITS 1  AND 2</b>	<b>0-SI-SXX-068-137.3</b> Rev 6 Page 21 of 21
---------------------------	--	---

**APPENDIX A**  
**Page 1 of 1**





# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## ADMIN SRO A.3 JPM

### Approval of a Waste Gas Tank Release

PREPARED/  
REVISED BY:

Date/

VALIDATED BY:

\*

Date/

APPROVED BY:

Date/

(Operations Training Manager)

CONCURRED:

\*\*

Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

Task:

Approval of a Waste Gas Tank Release

JA/TA task:

5030010102 (SRO)  
0690150102 (SRO)

K/A Ratings:

2.3.6 (2.0/3.8)

2.3.11 Ability to Approve Release Permits. (CFR: 41.13 / 45.4 / 45.10) 2.0 / 3.8

Task Standard:

Candidate identifies ...

- (1) Determine the required actions for RM-90-118 being inoperable.
- (2) Review Release package, 0-SI-CEM-077-410.4 for approval.

Valuation Method : Simulator   X   In-Plant           

Performer:

NAME

Start Time           

Performance Rating : SAT        UNSAT        Performance Time           

Finish Time           

Evaluator:

SIGNATURE

DATE

COMMENTS

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any UNSAT requires comments
2. This task can be performed in a classroom setting.

Validation Time: CR. 20 min Local                     

**Tools/Equipment/Procedures Needed:**

OPDP-1, Conduct of Operations

**References:**

	Reference	Title	Rev No.
1.	SQN ODCM	Offsite Dose Calculation Manual	55
2.	0-SI-CEM-077-410.4	Waste Gas Decay Tank Release	15

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. This JPM will be performed in a classroom. I will provide the initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

- The operating crew is preparing to release the Waste Gas Decay Tank 'C' at 1900 today.
- Release can not be rescheduled.
- 0-RM-90-118A, Waste Gas Radiation Monitor, is inoperable.
- Release path is Unit 2 Shield Building Vent
- The monthly projected offsite dose limits have not been exceeded.
- 0-SI-CEM-077-410.4 has been complete through Section 6.2 –Pre-Release Instructions- Chemistry, for release of Waste Gas Decay Tank C.

**INITIATING CUES:**

You are the Unit 1 US and are to:

1. Determine any required actions (TS, TRM, and/or ODCM) for 0-RM-90-118 being inoperable during a Waste Gas Decay Tank Release.
2. Review release package, 0-SI-CEM-077-410.4, *and* complete all applicable steps in Section 6.3 for approval of WGDT C release.

Job Performance Checklist

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 1.:</b> Operator reviews TS, TRM and ODCM for requirements for making a Waste Gas Tank Release with 0-RM-90-118 inoperable.</p> <p><b>STANDARD:</b> SRO addresses requirements for release of WGDT with RM-90-118 inoperable.</p> <p>ODCM 1.1.2 Action 40 <i>Release with the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, the contents of the tank(s) may be released to the environment provided that prior to initiating the release:</i></p> <p><i>a. At least two independent samples of the tank's contents obtained by two technically qualified members of the facility staff are analyzed,</i></p> <p><b><u>and</u></b></p> <p><i>b. At least two technically qualified members of the Facility Staff independently verify the release rate calculations</i></p> <p><b><u>and;</u></b></p> <p><i>c. At least two technically qualified members of the Facility Staff independently verify the discharge valve lineup.</i></p> <p><b><i>Otherwise, suspend release of radioactive effluents via this pathway.</i></b></p>	<p>Start Time _____</p> <p>____ SAT</p> <p>____ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 2.:</b> US/SRO reviews release package for approval:</p> <p><b>STANDARD:</b> US reviews release package for WGDT C and identifies <u>two</u> conditions that prevent the package from being approved:</p> <p>1- US Identifies that chemistry did not complete the Section 6.2, Step [2] to meet the ODCM requirements for chemistry to obtain two independent samples and independently analyze these samples.</p> <p>2. US identified that data recorded in Section 6.2, step [11] for Total Body Dose Rate (mrem/yr) did not meet the acceptance criteria.</p>	<p>____ SAT</p> <p>____ UNSAT</p> <p><b>Critical Step</b></p> <p>Stop Time _____</p>

END OF JPM

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. This JPM will be performed in a classroom. I will provide the initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- The operating crew is preparing to release the Waste Gas Decay Tank 'C' at 1900 today.
- Release can not be rescheduled.
- 0-RM-90-118A, Waste Gas Radiation Monitor, is inoperable.
- Release path is Unit 2 Shield Building Vent
- The monthly projected offsite dose limits have not been exceeded.
- 0-SI-CEM-077-410.4 has been complete through Section 6.2 –Pre-Release Instructions- Chemistry, for release of Waste Gas Decay Tank C.

### **INITIATING CUES:**

You are the Unit 1 US and are to:

1. Determine any required actions (TS, TRM, and/or ODCM) for 0-RM-90-118 being inoperable during a Waste Gas Decay Tank Release.
2. Review release package, 0-SI-CEM-077-410.4, *and* complete all applicable steps in Section 6.3 for approval of WGDT C release.

**SPP-8.1-2 - Chronological Test Log (CTL)**

SPP-8.1-2 [10-17-2008]



Sequoyah Nuclear Plant

**Unit 0**

Surveillance Instruction

**0-SI-CEM-077-410.4**

**Waste Gas Decay Tank Release**

Revision 0015

Quality Related

Level of Use: Reference Use

Effective Date: 09-03-2009

Responsible Organization: CEM, Chemistry

Prepared By: W. Kenneth Kimsey

Approved By: Diedre B. Nida



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 2 of 42</b>
-----------------------	-------------------------------------	--

#### Revision Log

<b>Revision or Change Number</b>	<b>Effective Date</b>	<b>Affected Page Numbers</b>	<b>Description of Revision/Change</b>
0014	12/19/2007	pages 14, 19, 42	Added tracking mechanism for tracking setpoint changes. PER 134683.
0015	09/03/2009	pages 6 and 10.	Updated sampling reference.

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 3 of 42</b>
-----------------------	-------------------------------------	--

## Table of Contents

<b>1.0</b>	<b>INTRODUCTION .....</b>	<b>5</b>
1.1	Purpose .....	5
1.2	Scope.....	5
1.2.1	Tests to be Performed .....	5
1.2.2	Requirements Fulfilled .....	5
1.3	Frequency and Conditions .....	6
<b>2.0</b>	<b>REFERENCES .....</b>	<b>6</b>
2.1	Performance References .....	6
2.2	Developmental References.....	6
<b>3.0</b>	<b>PRECAUTIONS AND LIMITATIONS .....</b>	<b>6</b>
<b>4.0</b>	<b>PREREQUISITE ACTIONS .....</b>	<b>7</b>
4.1	Preliminary Actions .....	7
4.2	Approvals and Notifications .....	7
<b>5.0</b>	<b>ACCEPTANCE CRITERIA.....</b>	<b>7</b>
<b>6.0</b>	<b>PERFORMANCE.....</b>	<b>8</b>
6.1	Pre-Release Instructions - Operations .....	8
6.2	Pre-Release Instructions - Chemistry .....	10
6.3	Release Instructions - Operations.....	15
<b>7.0</b>	<b>POST PERFORMANCE ACTIVITY-CHEMISTRY .....</b>	<b>18</b>
<b>8.0</b>	<b>RECORDS.....</b>	<b>19</b>
<b>Appendix A:</b>	<b>Correction Curve .....</b>	<b>20</b>
<b>Appendix B:</b>	<b>Release Data .....</b>	<b>21</b>
<b>Appendix C:</b>	<b>Sample Requirements .....</b>	<b>22</b>
<b>Appendix D:</b>	<b>Gaseous Release Permit Processing.....</b>	<b>23</b>
<b>Appendix E:</b>	<b>Opening Permits .....</b>	<b>28</b>
<b>Appendix F:</b>	<b>Closing Permits .....</b>	<b>35</b>
<b>Appendix G:</b>	<b>Editing Sample Entry/Concentrations Screen.....</b>	<b>39</b>

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 4 of 42</b>
-----------------------------	-------------------------------------	--

# **Table of Contents (continued)**

<b>Appendix H:</b>	<b>Updating the CDAS Setpoint Screen .....</b>	<b>42</b>
--------------------	--	-----------

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 5 of 42</b>
-----------------------	-------------------------------------	--

## 1.0 INTRODUCTION

### 1.1 Purpose

This Instruction provides detailed steps to document the radiochemical analyses required by the Sequoyah Offsite Dose Calculation Manual (ODCM) for release of Waste Gas Decay Tanks (WGDTs) contents. WGDTs are common equipment.

### 1.2 Scope

#### 1.2.1 Tests to be Performed

The following activities are performed in connection with the release of Waste Gas Decay Tank contents.

- A. Verification of the noble gas dose rate from the Shield Building exhaust due to WGDT releases.
- B. Determination of the radiation monitor response prior to each release.
- C. Verification that the effluent flow rate measuring device is operable during the release of waste gas.
- D. Verification of radioactive gaseous effluent monitoring.

#### 1.2.2 Requirements Fulfilled

Performance of this Instruction partially fulfills Offsite Dose Calculation Manual (ODCM) Surveillance Requirements (SR's).

<b>Surveillance Requirements</b>	<b>Applicable Modes</b>	<b>Performance Modes</b>
ODCM p. 2.2.2.1.1, Table 2.2-2, Item A	All	All
ODCM p. 2.1.2.1.a, Table 1.1-2, Item 1.a	All	All
ODCM p. 2.1.2.1.b, Table 1.1-2, Item 1.b	All	All
ODCM p. 2.2.2.2.	All	All
ODCM p. 2.2.2.4.	All	All
ODCM p. Control 1.1.2, Table 1.1-2, Action 40	All	All

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 6 of 42</b>
-----------------------	-------------------------------------	--

### 1.3 Frequency and Conditions

This Instruction is performed in any mode when a release is required from the WGDT. Verification of the flow rate monitor (0-FE-77-230) is required once per four (4) hours when waste gas is being released.

## 2.0 REFERENCES

### 2.1 Performance References

- A. 0-SO-77-15, Waste Gas Decay Tank Release
- B. SPP-8.1, Conduct of Testing.
- C. 0-TI-CEM-260-011.21, Chemical Analytical Methods - Gas Analysis
- D. 0-TI-CEM-000-016.40, Primary Sampling - Waste Gas
- E. 0-TI-CEM-030-030.0, Manual Calculation of Plant Gas, Iodine and Particulate Release Rates for Offsite Dose Calculation Manual (ODCM) Compliance

### 2.2 Developmental References

- A. TI-18, Radiation Monitoring
- B. Sequoyah Nuclear Plant Offsite Dose Calculation Manual (ODCM)
- C. PT-476 (2-18-80), Preoperational Test of FE-77-230
- D. TVA Drawing 47W560-16
- E. PER SQP890667 and 930807

## 3.0 PRECAUTIONS AND LIMITATIONS

- ~~A.~~ If the monthly projected offsite dose limits have been exceeded, the release cannot be made unless the waste gas decay tank has been held a minimum of 60 days for radioactive decay. The Cognizant Chemist should be contacted for any monthly projected offsite dose limits.
- ~~B.~~ The setpoint for the shield building radiation monitors (RM-90-400) can **NOT** be changed without a change to the ODCM.

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 7 of 42</b>
-----------------------------	-------------------------------------	--

#### 4.0 PREREQUISITE ACTIONS

##### NOTE

During the performance of this Instruction, any IF-THEN statement may be marked N/A when the corresponding stated condition does NOT occur.

#### 4.1 Preliminary Actions

##### NOTE

Sampling of the Waste Gas Decay Tanks can be performed prior to Radiation Monitor checks as long as a second independent sample is collected and analyzed if 0-RM-90-118 is inoperable.

- ~~(1)~~ **ENSURE** Instruction to be used is a copy of the effective version. ☒
- ~~(2)~~ **RECORD** the start date and time on the Surveillance Task Sheet. ☒
- ~~(3)~~ **COMPLETE** the Test Performers block on the Surveillance Task Sheet. ☒
- ~~(4)~~ **INITIATE** SPP-8.1 Chronological Test Log. ☒
- ~~(5)~~ **TRANSMIT** the release package to the main control room for radiation monitor checks. ☒

#### 4.2 Approvals and Notifications

None

#### 5.0 ACCEPTANCE CRITERIA

Acceptance criteria are based on administrative limits related to the site release limit and the design flow rate of each release pathway. Regulatory limits will **NOT** be exceeded until a site evaluation is complete. Acceptance criteria are noted where comparison with test data is made.

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 8 of 42
---------------	------------------------------	---

## 6.0 PERFORMANCE

### NOTE

US/SRO is defined as a Unit Supervisor who is also Senior Reactor Operator qualified.

6.1

### Pre-Release Instructions - Operations

[1] **RECORD** Waste Gas Decay Tank (WGDT) being released.

C  
WGDT

[2] **OBTAIN** approval of the US/SRO for radiation monitor checks.

Sroy / TODAY / Now  
US/SRO Date Time

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 9 of 42</b>
-----------------------------	-------------------------------------	--

# 6.1 Pre-Release Instructions - Operations (continued)

- ~~[3]~~ IF [0-RM-90-118] is operable, THEN  
**PERFORM** source check response, and  
**COMPLETE** the following table.

Background Response (cpm)	Source Check Response (cpm)	Monitor Setpoint (cpm)	Operable? Yes/No	Initials
N/A	N/A	N/A	NO	Roy

~~Acceptance Criteria:~~ Source Check Response > Background.

<b>NOTE</b>				
For the purposes of this Instruction, if the flow instrumentation for the shield building is INOPERABLE, then the monitor is considered NOT OPERABLE, and a background of "0" is used for permitting the release.				

- ~~[4]~~ IF [RE-90-400] is operable for unit that will receive flow, THEN  
**COMPLETE** the following table:

Unit	Background (μCi/sec)	Monitor Setpoint (μCi/sec)	Initials
2	$8.1 \text{ E}^{-2}$	23,400	Roy

[5] **TRANSMIT** release permit to Chemistry Laboratory.

Roy



<b>SQN</b> Unit 0	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> Rev. 0015 Page 10 of 42
----------------------	-------------------------------------	---

## 6.2 Pre-Release Instructions - Chemistry

**[1]**

**ENSURE** that radwaste operator has aligned the applicable WGDT to the waste gas analyzer.



### NOTES

- 1) ✓ Second sample signoff in the following step should be marked N/A if 0-RM-90-118 is OPERABLE. If 0-RM-90-118 is NOT OPERABLE, a second sample must be independently collected and analyzed.
- 2) ✓ All noble gas samples must be analyzed within one hour of sample collection. Otherwise, another sample must be collected.

**[2]**

**SAMPLE** applicable WGDT in accordance with 0-TI-CEM-000-016.40 and

**COMPLETE** the following table.

Sample	Sample Time	Analysis Time	Analyst
First	TODAY 1215	TODAY 1230	CLY
Second	N/A		

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 11 of 42</b>
-----------------------	-------------------------------------	---

## 6.2 Pre-Release Instructions - Chemistry (continued)

[3]

IF Waste Gas Analyzer is OPERABLE, THEN

**RECORD** oxygen and hydrogen concentrations from Waste Gas Analyzer in the table below Step 6.2[4] and **N/A** grab sample analyses data blanks.

[4]

IF Waste Gas Analyzer is NOT OPERABLE, THEN

**RECORD** Grab Sample analysis data in table below, and

**N/A** Waste Gas Analyzer data blanks.

N/A

Item	Waste Gas Analyzer Data (%)	Grab Sample Analyses Data (%)	Initials
Oxygen Concentration	0.53	N/A	cl4
Hydrogen Concentration	0.01	↓	cl4

[5]

**RECORD** tank pressure of WGDT to be released in the following table, and

**N/A** all remaining blanks.

WGDT Number	Indicator Number	Pressure (psig)
A	0-PIS-77-115	N/A
B	0-PIS-77-114	↓
C	0-PIS-77-113	64
D	0-PIS-77-100	N/A
E	0-PIS-77-101	↓

WGDT Number	Indicator Number	Pressure (psig)
F	0-PIS-77-102	N/A
G	0-PIS-77-145	↓
H	0-PIS-77-146	↓
J	0-PIS-77-147	↓

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 12 of 42
---------------	------------------------------	--

## 6.2 Pre-Release Instructions - Chemistry (continued)

~~[6]~~ IF hydrogen concentration is greater than 40 percent, **OR**  
IF oxygen concentration is greater than 5 percent, **THEN**

**PERFORM** either Step 6.2[6.1] or 6.2[6.2] as appropriate.

~~[6.1]~~ **REQUEST** Operations to dilute tank prior to release, and  
**WHEN** notified of completion of tank dilution, **THEN**

**GO TO** Step 6.2[1], **OR**

~~[6.2]~~ **OBTAIN** support for release rate calculations from  
System Engineering and/or Cognizant Chemist, and

**RECORD** the support provided in the "Remarks" section  
of Surveillance Task Sheet.

N/A

~~[7]~~ **INFORM** Operations of completion of sampling so they can  
realign the appropriate WGDT.

✓

### NOTES

- 1) ✓ If two samples were required, the analysis results associated with the higher noble gas concentration should be used for further release permit processing.
- 2) ✓ The EMS release rate setpoint calculations for 1,2-RM-90-400 are labeled as  $\mu\text{Ci/s}$  rather than cpm.

~~[8]~~ **ANALYZE** the sample(s) collected above, within one hour, in  
accordance with Appendix C for principal gamma emitters  
(noble gas).

✓

~~[9]~~ **PROCESS** release permit in accordance with Appendix E, and  
**ENSURE** the expected release rate (RM-90-400 from Page 1  
of the special report) is less than 23,400  $\mu\text{Ci/s}$ .

✓

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 13 of 42</b>
-----------------------------	-------------------------------------	---

## 6.2 Pre-Release Instructions - Chemistry (continued)

~~[10]~~ IF the total body dose rate determined in the last step is greater than 47.8 mrem/yr or the noble gas release rate is >23,400  $\mu\text{Ci/s}$ , THEN

**REPROCESS** release at a lower release rate by Step 6.2[9] above (applicable section of Appendix E release processing).

N/A

~~[11]~~ **COMPLETE** the following tables using results from analysis performed above.

Dose Rates	Data	Acceptance Criteria	Initials
Total body dose rate (mrem/yr):	19.4 E <sup>+1</sup>	$\leq 4.78\text{E}+01$	clx
Skin dose rate (mrem/yr):	4.59 E <sup>-4</sup>	$\leq 2.87\text{E}+02$	clx

Parameter	Data	Acceptance Criteria	Initials
0-RM-90-118 setpoint (cpm)	NA	$\leq 1.88\text{E}+03^{(3)}$	clx/clx
1,2 RE-90-400 Expected Response ( $\mu\text{Ci/sec}$ )	0.17617	$\leq 2.34\text{E}+04^{(2)}$	clx/clx
Maximum allowable release rate from Appendix D analysis (CFM)	50	$\leq 57^{(1)}$	clx/clx

(1) Maximum release flow rate that flow instrumentation can measure.

(2) This value is based on ODCM Rev. 45 which is 9.55% of the release rate limit for Xe-133 at 500 mRem/y and can NOT be changed without a change to the ODCM (this value is equivalent to  $\sim 1.73\text{E}-03 \mu\text{Ci/cc}$ ).

(3) This is a default setpoint defined in the ODCM. Temporary changes can be made up to  $\leq 32,526 \text{ CPM}$  (the ODCM Limit).

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 14 of 42
---------------	------------------------------	--

## 6.2 Pre-Release Instructions - Chemistry (continued)

- ~~(12)~~ IF the setpoint for 0-RM-90-118 in step 6.2[11] is greater than step 6.1[3], THEN  
**UPDATE** the CDAS CHEM5 setpoint screen in accordance with Appendix H. H/H

### NOTE

Appendix A is based on the setpoint of PCV-77-117 (2.0 psig) and a temperature of 80°F.

- ~~(13)~~ **DETERMINE** the expected pressure drop across flow orifice **[0-FE-77-230]** using Appendix A, the maximum allowable release rate from Step 6.2[11] above and hydrogen concentration from Steps 6.2[3] or 6.2[4].

720 / Cly  
inches of H<sub>2</sub>O                      Performer

- ~~(14)~~ **RECORD** release number and the allowable pressure drop across flow orifice **[0-FE-77-230]** as the smaller of Step 6.2[13] or the administrative limit of ≤14 inches of water on Appendix B. ☒

- ~~(15)~~ IF **[0-RE-90-118]** is **INOPERABLE**, THEN

**OBTAIN** independent verification of Steps 6.2[13] and 6.2[14] above.

≤14 / Cly / TODAY / Now  
inches of H<sub>2</sub>O                      Ind. Verifier                      Date                      Time

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 15 of 42
---------------	------------------------------	--

## 6.2 Pre-Release Instructions - Chemistry (continued)

~~[16]~~ **SIGNOFF** for item A and either item B or item C and  
**CIRCLE** B or C to indicate which one was satisfied. ☒

A. Approval of pre-release data generated by this Instruction.

Cly / TODAY / Now  
 Performer Date Time

B. Verification that monthly projected offsite dose limits  
 (ODCM SR 2.2.2.4) have **NOT** been exceeded, based on  
 most recent performance of SI-422.1, **OR**

C. Verification, with Operations support, that selected WGDT  
 has been held a minimum of 60 days and all applicable  
 requirements have been met.

Cly / TODAY / Now  
 Performer Date Time

~~[17]~~ **TRANSMIT** release package to Operations with authorization  
 to release. ☒

## 6.3 Release Instructions - Operations

[1] **REVIEW** Steps 6.1[3] and 6.1[4] and Steps 6.2[11] monitor  
 data. \_\_\_\_\_

[2] **IF** radiation monitor 0-RM-90-118 setpoint change is required,  
 (when setpoint in Step 6.2[11] is greater than the setpoint in  
 Steps 6.1[3]), **THEN**

**REQUEST** a setpoint change. \_\_\_\_\_

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 16 of 42</b>
-----------------------	-------------------------------------	---

### 6.3 Release Instructions - Operations (continued)

- [3] **IF** a release is to be made outside of normal release hours (0900 - 1600), **THEN**

**OBTAIN** US/SRO justification and initials in remarks section of Surveillance Task Sheet. \_\_\_\_\_

- [4] **OBTAIN** US/SRO approval of pre-release data generated by this Instruction and approval for this release.

\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
US/SRO                      Date                      Time

- [5] **INITIATE** release of selected WGDT contents in accordance with 0-SO-77-15 at or below the flow rate (i.e., pressure drop) recorded on Appendix B, and

**RECORD** release start time and information requested in the table in Appendix B for release initiation and at one-half hour intervals. \_\_\_\_\_

#### NOTE

**OPERABLE** status of 0-FE-77-230 can be determined by noting deflection of indicator.

- [6] **IF** 0-FE-77-230 is INOPERABLE at initiation of release, **THEN**

**GO TO** Step 6.3[8]. \_\_\_\_\_

- [7] **IF** 0-FE-77-230 becomes INOPERABLE during release, **THEN**

**PERFORM** the following substeps:

- [7.1] **STOP** release. \_\_\_\_\_

- [7.2] **NOTIFY** US/SRO. \_\_\_\_\_

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 17 of 42</b>
-----------------------	-------------------------------------	---

### 6.3 Release Instructions - Operations (continued)

- [8] **IF** release is to continue with [0-FE-77-230] INOPERABLE,  
**THEN**

**PERFORM** the following substeps.

- [8.1] **ENSURE** that a test gauge (0 - 20 inches of H<sub>2</sub>O suggested) is installed across [0-FE-77-230]. \_\_\_\_\_
- [8.2] **ENSURE** serial number, range and calibration due date of test gauge along with installing Instrument Mechanic's initials are recorded in remarks section of Appendix B. \_\_\_\_\_
- [8.3] **ENSURE** pressure readings from test gauge are recorded in place of [0-FE-77-230] readings on Appendix B. \_\_\_\_\_

- [9] **IF** [0-RM-90-118] or [RM-90-400] alarms, **THEN**

**NOTIFY** On-shift Chemistry Personnel who will contact the Cognizant Chemist/System Engg. for further guidance in processing tank contents. \_\_\_\_\_

- [10] **WHEN** release is complete or stopped, **THEN**

**RECORD** the following on Appendix B. \_\_\_\_\_

- [10.1] Release stop time ☐
- [10.2] WGDT psig ☐
- [10.3] Initials ☐

- [11] **IF** radiation monitor setpoint changes were made (Step 6.3[2]), **THEN**

**RETURN** the radiation monitors to their initial setpoints. \_\_\_\_\_

- [12] **NOTIFY** the US/SRO and On-shift Chemistry Personnel that this release is complete. \_\_\_\_\_

- [13] **REVIEW** 0-SO-77-15. \_\_\_\_\_

- [14] **ATTACH** 0-SO-77-15 to this release package. \_\_\_\_\_

- [15] **TRANSMIT** the release package to the Chemistry Laboratory for post release evaluation. \_\_\_\_\_



<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 18 of 42</b>
-----------------------------	-------------------------------------	---

## 7.0 POST PERFORMANCE ACTIVITY-CHEMISTRY

- [1] **CLOSE** the permit, and

**DETERMINE** the release total body and skin dose rates during the WGDT release according to Appendix F. ☐

- [2] **COMPLETE** the following table. ☐

<b>Dose Rate (mrem/yr)</b>	<b>Data</b>	<b>Acceptance Criteria</b>	<b>Initials</b>
Total Body Dose Rate		< 4.78 E+01	
Skin Dose Rate		< 2.87 E+02	

- [3] **IF** any Acceptance Criteria were NOT met, **THEN**

**PERFORM** the following actions. ☐

- [3.1] **REVERIFY** and **REANALYZE** sample. ☐

- [3.2] **RESAMPLE** and **REANALYZE**. ☐

- [3.3] **REVIEW** of Operations logs, System Operating Instructions, etc. ☐

- [3.4] **EVALUATE** all release pathways to determine if a violation of offsite dose criteria has occurred. ☐

- [4] **IF** the investigation above does NOT resolve the failure to meet the Acceptance Criteria, **THEN**

**INITIATE** an evaluation in accordance with 0-TI-CEM-030-030.0, and

**NOTIFY** the SM immediately of the results of the above evaluation. ☐

- [5] **COMPLETE** the SPP-8.1 Chronological Test Log. ☐

- [6] **ENSURE** all records, evaluations, analyses, calculations, and the SPP-8.1 Chronological Test Logs are attached to this data package. ☐

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 19 of 42</b>
-----------------------	-------------------------------------	---

## 7.0 POST PERFORMANCE ACTIVITY-CHEMISTRY (continued)

- [7] **RECORD** the completion date and time on the Surveillance Task Sheet. ☐
- [8] **COMPLETE** the Test Performers block on the Surveillance Task Sheet, if not already done. ☐
- [9] **IF** the CDAS CHEM5 screen was changed in Step 6.2[12],  
**THEN**  
**RETURN** it to initial setpoint in accordance with Appendix H. ☐

## 8.0 RECORDS


The completed SI package is a QA document controlled in accordance with SPP-2.4.

**Appendix A**  
**(Page 1 of 1)**

**Correction Curve**

**Expected Pressure Drop Across 0-FE-77-230<sup>1</sup>**

Hydrogen: As indicated by curves  
 Oxygen: 0-5% (By Volume)  
 Balance: Nitrogen



Based on 2.0 psig and 80°F.

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 21 of 42
---------------	------------------------------	--

Appendix B  
(Page 1 of 1)

Release Data

Release Number:	2010012.037.001.G	Unit:	2	Date:	TODAY
-----------------	-------------------	-------	---	-------	-------

Release Start Time:		Release Stop Time:		Tank ID:	
Pressure drop limit across 0-FE-77-230 <u>≤ 14</u> inches of H <sub>2</sub> O			Admin. pressure drop limit. ≤ 14.0 inches of H <sub>2</sub> O		
Parameter			Data		
Time:					
Countrate for 0-RM-90-118, (cpm):					
RM-90-400 response, (μCi/sec or μCi/cc) <sup>(2)</sup>					
Shield Building exhaust flow rate, (cfm) <sup>(1)</sup>					
Pressure drop across 0-FE-77-230 or IM's test gauge, (inches of H <sub>2</sub> O)					
Waste Gas Decay Tank pressure, (psig)					
Operator in charge of release, (initials)					

Remarks:

(1) Actual flow rate for applicable Shield Building vent (Computer point 1, 2Y2210A for applicable Unit). If flow measuring instrumentation is NOT OPERABLE, total design flow rate of fans in operation is used (for example, ABGTS design flow rate is 9000 cfm).

(2) If flow indicator is NOT OPERABLE, record μCi/cc vs μCi/sec.

<b>SQN</b> Unit 0	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> Rev. 0015 Page 22 of 42
----------------------	-------------------------------------	---

**Appendix C**  
**(Page 1 of 1)**

**Sample Requirements**

**1.0 SAMPLE REQUIREMENTS**

**NOTE**

Noble gas samples must be counted within 60 minutes from sample collection for 2000 seconds in order to meet ODCM LLDs. If > 60 minutes has elapsed from collection time, collect another sample.

**1.1 COUNTING ANALYSIS**

- [1] **COUNT** the sample by following the CAS SAMPLE PROCESSING MENU.



**NOTE**

REFER TO Appendix D of this instruction for Gaseous Release Permit Processing.

- [2] **PERFORM** Appendix E.



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 23 of 42</b>
-----------------------	-------------------------------------	---

**Appendix D  
(Page 1 of 5)**

**Gaseous Release Permit Processing**

**1.0 DEFINITIONS**

**1.1 Effluent Management System (EMS) - Introduction to Gaseous Permits**

The gaseous effluent permit definition form is used to input defining data for a new permit and to edit data for a permit already in the database. To move around in the screen, use the following keys:

<b>TAB key:</b>	Moves the cursor forward through the screen. No data is changed when using TAB.
<b>CTRL P:</b>	The CTRL key is held down and the "P" key is pressed to move the cursor backward through the screen. No data is changed.
<b>RETURN key:</b>	Terminates an input. This key will blank, or zero, a data field.
<b>PF1 key:</b>	Moves the cursor to the command line at the bottom of the screen. Repeated pressing of this key at the command line will expose any other commands, if available. This key is also used to call data onto the screen from some menus.
<b>PF3 key:</b>	Used to return to the previous screen, or to a previous sub-section. Also known as the END key.
<b>PF4 key:</b>	Exits from the EMS software. Also known as the QUIT key.

In addition to the above keys, all function keys listed on the command line at the bottom of the screen have a code in parentheses that corresponds to the key with that label. To perform the stated command, press the key enclosed in parentheses. The function can also be performed by typing the command name with the cursor located on the command line. Commands associated with the gaseous effluent permit definition screen include:

<b>HELP:</b>	Provides assistance or additional information.
<b>PERMITS:</b>	Provides a list of existing permit entry numbers.
<b>SAMPLES</b>	Displays a list of samples in the database.
<b>FILL:</b>	Allows the computer to calculate blank data fields.
<b>SAVE:</b>	Inscribes data in the database. Use after entering or altering data on the Permit Definition Form and before using the PROCESS command.
<b>PROCESS:</b>	Sends data entered on the Permit Definition Form to the system for calculation of setpoints and doses.

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 24 of 42</b>
-----------------------	-------------------------------------	---

**Appendix D  
(Page 2 of 5)**

**Gaseous Release Permit Processing**

**1.1 Effluent Management System (EMS) - Introduction to Gaseous Permits (continued)**

The concentrations table is used to review nuclides and concentrations in a given sample, or to edit the nuclides and concentrations in a given sample. Commands associated with the concentration table include:

<b>HELP:</b>	Provides assistance or additional information.
<b>COMPOSITES:</b>	Reads in current monthly/quarterly composite nuclide data for a specific release point.
<b>VMS-GSP:</b>	Reads in gamma nuclide data from a specific release sample.
<b>SAVE:</b>	Used after editing nuclide and concentration data.
<b>DELETE:</b>	Used to delete sample nuclide data.

The results form displays the values resulting from the system's calculations of dose rates and doses, and indicates whether these values have exceeded the applicable limits. This form also displays the set-points for radiation monitors. Commands associated with the results form include:

<b>HELP:</b>	Provides assistance or additional information.
<b>OPEN:</b>	Places the permit in an "open" status so pre-release reports can be generated.
<b>CLOSE:</b>	Ends the permit processing after the release is complete and the permit is updated with real release data.
<b>DELETE:</b>	Deletes dose and activity data for a release permit from the database.
<b>REPORT:</b>	Provides printouts of pre-release and post-release data.

<p><b>SQN</b> <b>Unit 0</b></p>	<p><b>Waste Gas Decay Tank Release</b></p>	<p><b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 25 of 42</b></p>
-------------------------------------	--	--



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> Rev. 0015 Page 26 of 42
-----------------------	-------------------------------------	---

**Appendix D  
(Page 4 of 5)**

**Gaseous Release Permit Processing**

**1.2 Gaseous Release Permit Numbers (continued)**

**NOTE**

The short form of the SI number appears in EMS.

FOLLOWING IS A LISTING OF GASEOUS RELEASE POINT NUMBERS:

23	MISCELLANEOUS UNDEFINED GAS
24	U1 CVE 119(99) NG (0-SI-CEM-030-415.0)
25	U2 CVE 119(99) NG (0-SI-CEM-030-415.0)
26	U1 INCORE INST RM PG 0-SI-CEM-030-410.3
27	U1 CONTAINMENT VENT 0-SI-CEM-030-410.1
28	U1 CONTAINMENT PURGE 0-SI-CEM-030-410.2
29	U2 CONTAINMENT PURGE 0-SI-CEM-030-410.2
30	U2 INCORE INST RM PG 0-SI-CEM-030-410.3
31	U2 CONTAINMENT VENT 0-SI-CEM-030-410.1
32	U1 WGDT A (0-SI-CEM-077-410.4)
33	U2 WGDT A (0-SI-CEM-077-410.4)
34	U1 WGDT B (0-SI-CEM-077-410.4)
35	U2 WGDT B (0-SI-CEM-077-410.4)
36	U1 WGDT C (0-SI-CEM-077-410.4)
37	U2 WGDT C (0-SI-CEM-077-410.4)
38	U1 WGDT D (0-SI-CEM-077-410.4)
39	U2 WGDT D (0-SI-CEM-077-410.4)
40	U1 WGDT E (0-SI-CEM-077-410.4)
41	U2 WGDT E (0-SI-CEM-077-410.4)
42	U1 WGDT F (0-SI-CEM-077-410.4)
43	U2 WGDT F (0-SI-CEM-077-410.4)
44	U1 WGDT G (0-SI-CEM-077-410.4)
45	U2 WGDT G (0-SI-CEM-077-410.4)
46	U1 WGDT H (0-SI-CEM-077-410.4)
47	U2 WGDT H (0-SI-CEM-077-410.4)
48	U1 WGDT J (0-SI-CEM-077-410.4)
49	U2 WGDT J (0-SI-CEM-077-410.4)
50	ABGTS U1 DISCHARGE (0-SI-CEM-030-415.0)
51	U1 EGTS (0-SI-CEM-030-415.0)
52	U2 EGTS (0-SI-CEM-030-415.0)
53	AUX. BLDG. EXH. NG (0-SI-CEM-030-415.0)
54	SERVICE BLDG EXHAUST NG (0-SI-CEM-030-415.0)

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 27 of 42</b>
-----------------------	-------------------------------------	---

**Appendix D  
(Page 5 of 5)**

**Gaseous Release Permit Processing**

**1.2 Gaseous Release Permit Numbers (continued)**

55	ABGTS U2 DISCHARGE (0-SI-CEM-030-415-0.)
56	U1 CVE 119(99) P/I (0-SI-CEM-030-407.2)
57	U2 CVE 119(99) P/I (0-SI-CEM-030-407.2)
58	U1 SHIELD BLDG VENT NG (0-SI-CEM-030-415.0)
59	U2 SHIELD BLDG VENT NG (0-SI-CEM-030-415.0)
62	AUX BLDG EXHAUST P/I (0-SI-CEM-030-407.2)
63	U1 SHLD BLDG EXH P/I (0-SI-CEM-030-407.2)
64	U2 SHLD BLDG EXH P/I (0-SI-CEM-030-407.2)
65	SERVICE BLDG EXHAUST P/I (0-SI-CEM-030-407.2)
66	U1 CVE 119(99) H-3 (0-SI-CEM-030-415.0)
67	U2 CVE 119(99) H-3 (0-SI-CEM-030-415.0)
68	AUX BLDG EXHAUST H-3 (0-SI-CEM-030-415.0)
69	U1 SHLD BLDG EXH H-3 (0-SI-CEM-030-415.0)
70	U2 SHLD BLDG EXH H-3 (0-SI-CEM-030-415.0)
71	SERVICE BLDG EXH H-3 (0-SI-CEM-030-415.0)

SQN Unit 0	Waste Gas Decay Tank Release	0-SI-CEM-077-410.4 Rev. 0015 Page 28 of 42
---------------	------------------------------	--

**Appendix E**  
**(Page 1 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE**

- ~~[1]~~ **REVIEW** the gamma isotopic analysis results for correctness. ☒
- ~~[2]~~ **CORRECT** any errors prior to processing. ☒
- ~~[3]~~ **WHEN** all of the data has been verified, **THEN**  
**LOG ON** a CAS computer terminal (if **NOT** already logged on). ☒
- ~~[4]~~ **SELECT** the item on the Main Menu associated with "Effluent Management", and  
**PRESS** "Return". ☒
- ~~[5]~~ **SELECT** "Process Gaseous Permit" option from the Effluent Management Menu, and  
**PRESS** "Return". ☒

**NOTE**

In the following step, if a "?" is entered at the "Enter Release Point Number:" prompt, a list of gaseous release point numbers will appear.

- ~~[6]~~ **ENTER** the appropriate release point number at the prompt "Enter Release Point Number:", and  
**PRESS** "Return". ☒

**NOTE**

The terminal will indicate that three samples may be required; however only one is required for a WGDT release.

- ~~[7]~~ **PRESS** the Return key three times. ☒

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 29 of 42</b>
-----------------------------	-------------------------------------	---

**Appendix E**  
**(Page 2 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE**  
**(continued)**

~~[8]~~ **ENTER** the noble gas sample number, and

**PRESS** "Return".



~~[9]~~ **SELECT** the "Define and Open a New Gaseous Permit" option from the menu.



<b>SQN</b> Unit 0	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> Rev. 0015 Page 30 of 42
----------------------	-------------------------------------	---

**Appendix E**  
**(Page 3 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE**  
**(continued)**

**NOTE**

Information on the last permit for this release point will be displayed, and the system will ask if you want to define and open a permit.

**[10] TYPE "Y" for Yes, and**  
**PRESS "Return".**

**NOTE**

In the following step, the estimated start time can be obtained from Operations, past experience, etc. Examples: 23-May-99 13:00, 5/23/99 13:00.

**[11] ENTER** the estimated start time at the "Release Start" field,  
and

**PRESS "Return".**

**[12] TAB** through the "Release End" field.

**[13] ENTER** the estimated release flow rate (routinely 50 CFM),  
and

**PRESS "Return".**

**[14] PRESS "Return"** at the "Release Volume" field to zero the  
field.

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 31 of 42</b>
-----------------------------	-------------------------------------	---

**Appendix E**  
**(Page 4 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE**  
**(continued)**

**NOTE**

The following pressure may change prior to release; however, it is only being used to estimate pre-release offsite dose.

**[15] OBTAIN** the initial pressure information from Operations, and  
**ENTER** the value in the "Initial Pressure" field.

**[16] PRESS** "Return".

**NOTE**

Based on the design of the Waste Gas Analysis System the following final pressure value should never be zero; however, this value is being used to estimate the maximum activity released and maximum offsite dose.

**[17] PRESS** "Return" to zero the "Final Pressure" field.

**[18] ENTER** the appropriate initials in the "Collected By" field, and  
**PRESS** "Return".

**[19] PRESS** the "Fill" command to update the screen.

**[20] VERIFY** all data is correct.

**[21] MAKE** any required changes.

**[22] PRESS** the "Save" command key.

**[23] PRESS** the "Process (Do)" command.

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 32 of 42</b>
-----------------------	-------------------------------------	---

**Appendix E  
(Page 5 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE  
(continued)**

**NOTE**

The "Sample Entry/Concentrations" screen will appear. After the following step, a message will appear that says the particulate and iodine sample configurations could NOT be opened. This message can be ignored.

**[24]** **PRESS** the "VMS-GSP" command to read the spectral data information from the sample counted for this release.

☒

**[25]** **VERIFY** all nuclides and concentration values against the printed gamma spec summary report(s).

☐

**NOTE**

If the radiation monitor is NOT OPERABLE and the permit is being opened using the sample with the highest Noble Gas Concentration, the file may still need to be edited. The pre-release file should reflect all identified isotopes, excluding natural products, and the highest concentration between the two samples.

**[26]** **IF** the radiation monitor **[0-RM-90-118]** is NOT OPERABLE,  
**THEN**

**COMPARE** all non-natural nuclides and concentration values against the printed gamma spec summary report and/or corrected results for both samples and

**EDIT** in accordance with Appendix G.

☒

**[27]** **IF** natural occurring nuclides are present, **THEN**

**EDIT** in accordance with Appendix G.

☐

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 33 of 42</b>
-----------------------	-------------------------------------	---

**Appendix E  
(Page 6 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE  
(continued)**

~~[28]~~ **IF** the concentration for a nuclide or a nuclide is to be added, removed or edited, **THEN**

**EDIT** in accordance with Appendix G. ☒

~~[29]~~ **SELECT** the "Process (Do)". ☒

~~[30]~~ **ENTER** the [0-RM-90-118] monitor's background as determined by Operations, and

**PRESS** "Return". ☒

~~[31]~~ **PRESS** the "Process (Do)" key. ☒

~~[32]~~ **ENTER** the background for [RM-90-400] as determined by Operations, and

**PRESS** "Return". ☒

~~[33]~~ **PRESS** the "Process (Do)" key. ☒

~~[34]~~ **REVIEW** all data on the results screen, and

**ENSURE** no limits are exceeded. ☒

~~[35]~~ **IF** no limits are exceeded, **THEN**

**PRESS** the "Process (Do)" key to open the permit. ☒

**NOTE**

If limits are exceeded, the release will have to be reprocessed utilizing a lower flow rate.

~~[36]~~ **IF** limits are exceeded and all input data is correct, **THEN**

**CONTACT** the Cognizant Chemist or Designee before proceeding.

n/A



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 34 of 42</b>
-----------------------	-------------------------------------	---

**Appendix E  
(Page 7 of 7)**

**Opening Permits**

**1.0 PROCESSING WASTE GAS DECAY TANK FOR RELEASE  
(continued)**

~~[37]~~ **AFFIRM** that a permit is to be opened.



~~[38]~~ **PRESS** the "Report" command.



~~[39]~~ **PRESS** "Return" to obtain a default number of copies, **OR**

**IF** needed, **THEN**

**INPUT** more copies, and

**PRESS** "Return".



~~[40]~~ **WAIT** for reports to print out, **THEN**

**PRESS** the PF4 key to exit EMS.



~~[41]~~ **REVIEW** the pre-release report.



~~[42]~~ **IF** the data is correct, **THEN**

**SIGN, ATTACH** , and **LOG** applicable data in the SI package.



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 35 of 42</b>
-----------------------	-------------------------------------	---

**Appendix F  
(Page 1 of 4)**

**Closing Permits**

**1.0 POST- ANALYSIS**

- [1] **VERIFY** the information in 0-SI-CEM-077-410.4 is complete on the returned release package. ☐
- [2] **LOG ON** the CAS computer (if **NOT** already logged on). ☐
- [3] **SELECT** the item associated with "Effluent Management", and   
**PRESS** "Return". ☐
- [4] **SELECT** "Process Gaseous Permit", and   
**PRESS** "Return". ☐
- [5] **ENTER** the Release Point Number, and   
**PRESS** "Return". ☐
- [6] **PRESS** "Return" four times to move out of the sample number section. ☐
- [7] **SELECT** "Close A Gaseous Permit". ☐
- [8] **TAB** to move to the "Permit Number" field. ☐
- [9] **IF** the Permit Number is correct, **THEN**   
**PRESS** "Process (Do)" key. ☐
- [10] **ENTER** the actual start time at the "Release Start" time field, and   
**PRESS** "Return". ☐

**NOTE**

The Stop Time may have to be adjusted if there were any interruptions during the release.

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 36 of 42</b>
-----------------------	-------------------------------------	---

**Appendix F  
(Page 2 of 4)**

**Closing Permits**

**1.0 POST- ANALYSIS (continued)**

- [11] **ENTER** the actual stop time in the "Release End" time field,  
and  
  
**PRESS** "Return". ☐
- [12] **PRESS** "Return" at the "Release Flow Rate" field to zero the  
field. ☐
- [13] **PRESS** "Return" at the "Release Volume" field to zero the  
field. ☐
- [14] **ENTER** the correct initial pressure value in the "Initial  
Pressure" field, and  
  
**PRESS** "Return". ☐
- [15] **ENTER** the correct final pressure value in the "Final Pressure"  
field, and  
  
**PRESS** "Return". ☐
- [16] **PRESS** the "Fill" key to update the screen. ☐
- [17] **REVIEW** the screen and  
  
**VERIFY** all data is correct. ☐
- [18] **IF** correct, **THEN**  
  
**PRESS** the "Save" key. ☐
- [19] **PRESS** the "Process (Do)" key. ☐

**NOTE**

The "Sample Entry/Concentrations" screen will appear.

- [20] **VERIFY** all nuclides and concentration values are correct. ☐

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 37 of 42</b>
-----------------------	-------------------------------------	---

**Appendix F  
(Page 3 of 4)  
Closing Permits**

**1.0 POST- ANALYSIS (continued)**

<b>NOTES</b>	
1)	Editing data in the following step requires a password which is available from Chemistry Supervision.
2)	In the following step, the SAVE command is only required if the data has been edited.

- [21] **IF** the concentration for a nuclide or a nuclide is to be added, removed, or edited, **THEN**
- EDIT** in accordance with Appendix G. ☐
- [22] **SELECT** the "Process (Do)". ☐
- [23] **IF** all information is correct and no limits are exceeded **THEN**
- PRESS** the "Process (Do)" key to close the permit. ☐
- [24] **ENTER** "Y", and
- PRESS** "Return". ☐
- [25] **PRESS** the "Report" command. ☐
- [26] **PRESS** "Return" to obtain a default number of copies, **OR**
- IF** needed, **THEN**
- INPUT** more copies. ☐
- [27] **REVIEW** the printout, and
- VERIFY** the data is correct.
- [28] **PRESS** the PF4 key to exit. ☐

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 38 of 42</b>
-----------------------	-------------------------------------	---

**Appendix F  
(Page 4 of 4)**

**Closing Permits**

**1.0 POST- ANALYSIS (continued)**

[29] **SIGN** and **ATTACH** the printout to the SI, and

**LOG** applicable data in the SI.



<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 39 of 42</b>
-----------------------	-------------------------------------	---

**Appendix G  
(Page 1 of 3)**

**Editing Sample Entry/Concentrations Screen**

**NOTES**

- 1) The system will read in the gamma spectral data from the sample counted for this release. Editing of the concentration table may be required. Movement within the table is accomplished by using the arrow keys and the "Tab" key.
- 2) If the radiation monitor is NOT operable and the permit is opened with the highest ECL concentration editing may still be required. The pre-release file should have all identified isotopes included as well as the highest activity of each isotope identified included.
- 3) Editing data requires a "Return" before saving.
- 4) When editing data, use applicable password EMS or SEMS.

**1.0 ADDITION OF A NUCLIDE AND CONCENTRATION**

[1] **IF** a Nuclide and concentration is to be added, **THEN**

**PERFORM** the following:

[1.1] **PLACE** the cursor below the last nuclide, and

**ADD** the nuclide to the list. ☐

[1.2] **PRESS** TAB, and

**ENTER** the concentration, and

**PRESS** "Return". ☐

[2] **IF** other nuclides need to be added, **THEN**

**REPEAT** sub-steps 1.0[1.1] and 1.0[1.2]. ☐

[3] **PRESS** "Save" command key (F10). ☐

[4] **ENTER** "Y" at the prompt "Has this been authorized? (Y/N)". ☐

<b>SQN</b> <b>Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> <b>Rev. 0015</b> <b>Page 40 of 42</b>
-----------------------------	-------------------------------------	---

**Appendix G**  
**(Page 2 of 3)**

**Editing Sample Entry/Concentrations Screen**

**1.0 ADDITION OF A NUCLIDE AND CONCENTRATION (continued)**

- [5] **ENTER** the appropriate password when prompted, and  
**PRESS** "Return". ☐

**2.0 EDITING A NUCLIDE AND CONCENTRATION**

- [1] **IF** a concentration for a nuclide is to be edited, **THEN**

**PERFORM** the following:

- [1.1] **PLACE** the cursor on the nuclide to be edited. ☐
- [1.2] **PRESS** TAB, and  
**ENTER** the concentration, and  
**PRESS** "Return". ☐
- [2] **IF** other nuclides need to be edited, **THEN**  
**REPEAT** sub-steps 2.0[1.1] and 2.0[1.2]. ☐
- [3] **PRESS** "Save" command key (F10). ☐
- [4] **ENTER** "Y" at the prompt "Has this been authorized? (Y/N)". ☐
- [5] **ENTER** the appropriate password when prompted, and  
**PRESS** "Return". ☐

**3.0 REMOVAL OF A NUCLIDE AND CONCENTRATION**

- [1] **IF** a nuclide and concentration is to be removed, **THEN**

**PERFORM** the following:

- [1.1] **PLACE** the cursor on the nuclide to be removed. ☐
- [1.2] **PRESS** the Remove Key or Delete Key on the keyboard. ☐

<b>SQN Unit 0</b>	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4 Rev. 0015 Page 41 of 42</b>
-----------------------	-------------------------------------	---

**Appendix G  
(Page 3 of 3)**

**Editing Sample Entry/Concentrations Screen**

**3.0 REMOVAL OF A NUCLIDE AND CONCENTRATION (continued)**

- [1.3] **ENTER** "Y" at the prompt "Has this been authorized?  
(Y/N)". ☐
- [1.4] **PRESS** "Return". ☐
- [1.5] **ENTER** "SEMS" when prompted for the password, and  
**PRESS** "Return". ☐
- [1.6] **TYPE** "R" and **PRESS** "Return" When prompted by  
sample or row. ☐
- [2] **IF** other nuclides need to be removed, **THEN**  
**REPEAT** Step 3.0[1]. ☐



<b>SQN</b> Unit 0	<b>Waste Gas Decay Tank Release</b>	<b>0-SI-CEM-077-410.4</b> Rev. 0015 Page 42 of 42
----------------------	-------------------------------------	---

**Appendix H**  
**(Page 1 of 1)**

**Updating the CDAS Setpoint Screen**

**1.0 UPDATING THE CDAS SETPOINT SCREEN**

**NOTE**

The common rad monitors are on U1 screen.

- [1] **SELECT** the Rad Mon button from U1/U2 CDAS CHEMISTRY MAIN VIEW. ☐
- [2] **CHANGE** Security Level to level 7, and  
**USE** CHEMSET as the User name and password. ☐
- [3] **SELECT** GASEOUS RAD MON SETPOINTS (CHEM 5) button. ☐
- [4] **SELECT** the rad monitor button of the monitor to be changed. ☐
- [5] **SELECT** the F2 key to zero the field. ☐
- [6] **SET** the cursor to the left of the decimal, and  
**TYPE** in the new setpoint. ☐

**NOTE**

Under the Date Modified Field the message NOT SAVED will momentarily be displayed then the date will appear.

- [7] **SELECT** the F3 key to save the new setpoint. ☐
- [8] **SELECT** the F1 Key. ☐
- [9] **VERIFY** the as left setpoint. ☐
- [10] **SELECT** the Chemistry Rad Mon Menu button. ☐
- [11] **SELECT** the Chemistry Main View button (Chem\_D1) button. ☐

KENTUCKY VALLEY AUTHORITY  
SEQUOYAH NUCLEAR PLANT

12 APP. B.9

BATCH GASEOUS EFFLUENT PERMIT

2010012.037.001.G

Unit # 1

Allocation 100.%

REQUEST:

X NORMAL  
UNPLANNED

RELEASE POINT  
U2 WGDTC (SI-410.4)

ESTIMATED START:  
Today 19:00:00

RELEASE VOLUME (EST.)  
2.6122E+03 CF

DISCHARGE POINT  
U2 SHIELD BUILDING EXHAUST

ESTIMATED STOP:  
Today 19:52:15

II. SAMPLE IDENTIFICATION:

NUMBER

9888

COLLECTION DATE/TIME

Today 00:03:00

ANALYSIS DATE/TIME

Today 00:18:46

Noble Gas File Name : CAS\_SAM:S090211001.cnf

Particulate File Name: N/A

Radioiodine File Name: N/A

III. RADIOANALYSIS - GASEOUS:

CUMULATIVE DOSES

PROJ. BETA DOSE(31-DAY)

1.57E-04 mrad < 0.40

AIR DOSE-BETA(Q)

1.06E-04 mrad < 10.00

AIR DOSE-BETA(A)

0.06E-04 mrad < 20.00

PROJ. GAMMA DOSE(31-DAY)

3.62E-04 mrad < 0.20

AIR DOSE-GAMMA(Q)

2.45E-04 mrad < 5.00

AIR DOSE-GAMMA(A)

2.45E-04 mrad < 10.00

PROJ. ORGAN DOSE(31-DAY)

3.27E-04 mrem < 0.30

ORGAN DOSE(Q)

2.22E-04 mrem < 7.50

ORGAN DOSE(A)

2.22E-04 mrem < 15.00

YEARLY DOSE RATES

ALOC T-BODY DOSE RATE

9.71E-04 mrem/yr < 500.

ALLOC SKIN DOSE RATE

2.29E-03 mrem/yr < 3000.

ALLOC ORGAN DOSE RATE

0.00E+00 mrem/yr < 1500.

Setpoint Option: Dose Rates

IV. RADIATION MONITOR(S):

NUMBER

0-RM-90-118

(NG)

SETPOINT

1880.0

CPM

EXPECTED RESPONSE

35.132

CPM

2-RM-90-400

(NG)

0.19997

uCi/s

0.17617

uCi/s

V. AUTHORIZATION:

MAX. VOLUME

2.6122E+03 CF

MAX. EFFLUENT FLOW RATE

5.0000E+01 CFM

The above-named source has been sampled and analyzed and is in compliance with the Offsite Dose Calculation Manual. Release is authorized for the volume and flow rates specified.

-----  
NESSEE VALLEY AUTHORITY  
DUOYAH NUCLEAR PLANT

page 1 of 9

TI-12 APP. B.9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

-----  
PART I: PRE-RELEASE DATA

-----  
RELEASE POINT ( 37): U2 WGDTC (SI-410.4)  
DISCHARGE POINT ( 8): U2 SHIELD BUILDING EXHAUST

Permit Issued: 21-jan-2009 10:42:08

Release Type: Batch

Rad Monitor: (C.4 ) 0-RM-90-118  
Rad Monitor Bckgrnd: 3.5000E+01 CPM  
Estim. Waste Flow: 5.0000E+01 CFM  
Estim. Waste Volume: 2.6122E+03 CF  
Estim. Release Start: 21-jan-2009 12:00:00  
Estim. Release End: 21-jan-2009 12:52:15 Initial Pressure : 6.4000E+01  
Estim. Duration: 52.2449 MIN Final Pressure : 0.0000E+00

-----  
PART II: PRE-RELEASE CALCULATIONS

-----  
Sample Entry # : 9888  
Noble Gas File Name : CAS\_SAM:S090211001.cnf  
Particulate File Name: N/A  
Radioiodine File Name: N/A  
Gas sample time: 21-jan-2009 00:03:00 Sampled by: WDT

Gas Monitor Response: 3.51E+01 CPM  
Setpoint Option: Dose Rates  
Allocated Total Body Dose Rate: 9.71E-04 mrem/yr % Limit = 0.0%  
Allocated Skin Dose Rate: 2.29E-03 mrem/yr % Limit = 0.0%  
Allocated Max Organ Dose Rate: 0.00E+00 mrem/yr % Limit = 0.0%

Max Monitor Setpoints: 0-RM-90-118 2-RM-90-400  
-----  
Noble Gas : 1.88E+03 CPM 2.00E-01 uCi/s  
Particulate : 0.00E+00 ^^^^^^ 0.00E+00 ^^^^^^  
Radioiodine : 0.00E+00 ^^^^^^ 0.00E+00 ^^^^^^

Flag:

Flags: A-Release Curies > Local Limit N-Noble Gas Dose Rate > Limit  
S-Release Curies > Site Limit O-Organ Dose Rate > Limit

	Analysis Date	Measured Concen.	Est. Curies
Noble Gases	21-jan-2009 00:18:46	4.03E-06 uCi/cc	2.98E-04
Particulates	21-jan-2009 00:18:46	0.00E+00 uCi/cc	0.00E+00
Radioiodines	21-jan-2009 00:18:46	0.00E+00 uCi/cc	0.00E+00

-----  
Approved By: 

Date  
1/21/2009

-----  
TENNESSEE VALLEY AUTHORITY  
KNOXBOYAH NUCLEAR PLANT

page 2 of 9

TI-12 APP. B.9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data  
-----

2009012.037.001.G

ISOTOPIC IDENTIFICATION - Unit 1  
-----

	: Pre-Disp.	: Post-Disp.:	Release	: Estimated :
	: Measured :	:	Rate	: Curies :
Isotope :	uCi/cc	: uCi/cc	: uCi/sec	: Released :
XE-133 N:	4.03E-06	: 6.61E-13	: 9.52E-02	: 2.98E-04
Totals :	4.03E-06	: 6.61E-13	: 9.52E-02	: 2.98E-04 :

-----

-----  
KENTUCKY VALLEY AUTHORITY  
DUOYAH NUCLEAR PLANT

page 3 of 9

11-12 APP. B.9

Gaseous Radioactive Waste Release Permit

2009012.037.001.G

Pre-Release Supplementary Data  
-----

Calculated Gamma & Beta : Calculated Doses at Site Boundary.

Air Doses @ Site Boundary: Gamma and Beta Air Doses, Tot-body and Skin

: Doses and Dose Rates.

Type of Activity : Noble Gases

Controlling Sector : N

Unit number : 1  
-----

:Site	:Tot-body	:Skin Dose	:Gamma Air	:Beta Air	:Unalloc.	:Unalloc.
:Boundary	:Dose	:mrem	:mrad	:mrad	:Tot-body	:Skin
:Dist (km)	:mrem	:	:	:	:Dose Rate	:Dose Rate
:	:	:	:	:	:mrem/year	:mrem/year

-----

N : 9.50E-01 : 1.93E-08 : 4.56E-08 : 2.32E-08 : 6.89E-08 : 1.94E-04 : 4.59E-04  
-----

page 4 of 9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

```

Report Category      : Calculated Dose Rate to Man (mrem/year) from this
                     : Release at Site Boundary.
Type of Activity     : Radioiodines and Particulates
Age Group & Pathway(s) :
Controlling Sector   :
Unit number          : 1

```

[illegible]

VERMONT VALLEY AUTHORITY  
JOYAH NUCLEAR PLANT

page 5 of 9

TI-12 APP. B.9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

Report Category : Cumulative Dose at Site Boundary  
Type of Activity : Noble Gases  
Location : N at 0.950 km.  
Unit number : 1

	:Tot-body :mrem	:Skin :mrem	:Gamma Air :mrad	:Beta Air :mrad
This Release	: 1.93E-08	: 4.56E-08	: 2.32E-08	: 6.89E-08
31D Prior:	:	:	:	:
To Rel	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
31D After:	:	:	:	:
Release	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
31 Day Limit	: 0.00E+00	: 0.00E+00	: 2.00E-01	: 4.00E-01
31 Day Limit	: 0.00%	: 0.00%	: 0.12%	: 0.03%
Qtr Prior:	:	:	:	:
To Rel	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
Qtr After:	:	:	:	:
Release	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
Quarterly:	:	:	:	:
Limit	: 0.00E+00	: 0.00E+00	: 5.00E+00	: 1.00E+01
% Quarter:	:	:	:	:
Limit	: 0.00%	: 0.00%	: 0.00%	: 0.00%
Ann Prior:	:	:	:	:
To Rel	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
Ann After:	:	:	:	:
Release	: 2.32E-04	: 3.46E-04	: 2.45E-04	: 1.06E-04
Annual Limit	: 0.00E+00	: 0.00E+00	: 1.00E+01	: 2.00E+01
% Annual Limit	: 0.00%	: 0.00%	: 0.00%	: 0.00%

NESSEE VALLEY AUTHORITY  
JOYAH NUCLEAR PLANT

page 6 of 9

TI-12 APP. B.9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

Report Category : Projected Dose at Site Boundary  
Type of Activity : Noble Gases  
Location : N at 0.950 km.  
Unit number : 1

	:Tot-body :mrem	:Skin :mrem	:Gamma Air :mrad	:Beta Air :mrad
--	--------------------	----------------	---------------------	--------------------

This Release	: 1.93E-08	: 4.56E-08	: 2.32E-08	: 6.89E-08
--------------	------------	------------	------------	------------

31D Prior: To Rel	: 3.43E-04	: 5.11E-04	: 3.62E-04	: 1.57E-04
----------------------	------------	------------	------------	------------

31D After: Release	: 3.43E-04	: 5.11E-04	: 3.62E-04	: 1.57E-04
-----------------------	------------	------------	------------	------------

31 Day Limit	: 0.00E+00	: 0.00E+00	: 2.00E-01	: 4.00E-01
-----------------	------------	------------	------------	------------

31 Day nit	: 0.00%	: 0.00%	: 0.18%	: 0.04%
---------------	---------	---------	---------	---------

Qtr Prior: To Rel	: 1.02E-03	: 1.52E-03	: 1.07E-03	: 4.65E-04
----------------------	------------	------------	------------	------------

Qtr After: Release	: 1.02E-03	: 1.52E-03	: 1.07E-03	: 4.65E-04
-----------------------	------------	------------	------------	------------

Quarterly: Limit	: 0.00E+00	: 0.00E+00	: 5.00E+00	: 1.00E+01
---------------------	------------	------------	------------	------------

% Quarter: Limit	: 0.00%	: 0.00%	: 0.02%	: 0.00%
---------------------	---------	---------	---------	---------

Ann Prior: To Rel	: 4.04E-03	: 6.01E-03	: 4.26E-03	: 1.84E-03
----------------------	------------	------------	------------	------------

Ann After: Release	: 4.04E-03	: 6.01E-03	: 4.26E-03	: 1.84E-03
-----------------------	------------	------------	------------	------------

Annual Limit	: 0.00E+00	: 0.00E+00	: 1.00E+01	: 2.00E+01
-----------------	------------	------------	------------	------------

% Annual Limit	: 0.00%	: 0.00%	: 0.04%	: 0.01%
-------------------	---------	---------	---------	---------



Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

Report Category	: Cumulative Maximum Individual Dose (mrem) for
Type of Activity	: Controlling Age Group at Controlling Location
Age Group & Pathway(s)	: Radioiodines and Particulates
Location	: at 0.000 km.
Unit number	: 1

[illegible]

2009012.037.001.G

[illegible]

-----  
NESSEE VALLEY AUTHORITY  
QUOYAH NUCLEAR PLANT

page 9 of 9

TI-12 APP. B.9

Gaseous Radioactive Waste Release Permit  
Pre-Release Supplementary Data

2009012.037.001.G

-----  
Report Category : Fuel Cycle Dose  
Type of Activity : Noble Gases  
Location : N at 0.950 km.  
Unit number : 1  
-----

-----  
:Tot-body :Skin :  
:mrem :mrem :  
-----

This : :  
Release : 1.35E-08 : 3.19E-08 :  
-----

Projected: : :  
Prior Rel: 2.83E-03 : 4.21E-03 :  
-----

Projected: : :  
After Rel: 2.83E-03 : 4.21E-03 :  
-----

Annual : : :  
Limit : 2.50E+01 : 2.50E+01 :  
-----

Annual : : :  
Limit : 0.00% : 0.00% :  
-----

Cumulativ: : :  
Prior Rel: 1.63E-04 : 2.42E-04 :  
-----

Cumulativ: : :  
After Rel: 1.63E-04 : 2.42E-04 :  
-----

Annual : : :  
Limit : 2.50E+01 : 2.50E+01 :  
-----

% Annual : : :  
Limit : 0.00% : 0.00% :  
-----

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM19AP3

**Classify the Event per the REP  
(LOCA with Significant Fuel Failure)**

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

**NUCLEAR TRAINING**  
**REVISION/USAGE LOG**

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/REVISED BY:
0	New JPM, adapted from JPM 19AP2	Y	1/11/10	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
SRO  
JOB PERFORMANCE MEASURE

**Task:**

Classify the Event per the REP (LOCA with Significant Fuel Failure)

JA/TA task # : 3440030302 (SRO)  
3440190302 (SRO)

**K/A Ratings:**

2.4.29 (2.6/4.0)	2.4.38 (2.2/4.0)	2.4.44 (2.1/4.0)
2.4.30 (2.2/3.6)	2.4.40 (2.3/4.0)	
2.4.37 (2.0/3.5)	2.4.41 (2.3/4.1)	

**Evaluation Method :** Simulator \_\_\_\_\_ In-Plant \_\_\_\_\_ Classroom   X  

**Performer:**

NAME

Start Time \_\_\_\_\_

**Performance Rating :** SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish Time \_\_\_\_\_

**Evaluator:**

SIGNATURE

DATE

**COMMENTS**

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any **UNSAT** requires comments.
2. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.
3. Clock must be available in classroom and visible to examiner and examinees.

**Caution:**      **DO NOT LET THE EXAMINEE FAX THE NOTIFICATION FORM OFFSITE!**

**Validation Time:** CR. 15 mins      Local                     

**Tools/Equipment/Procedures Needed:**

EPIP-1 thru 5, for each student in classroom  
FR Procedures  
Steam Tables, for each student in classroom  
Clock must be available in classroom that all examinees and evaluator can see.

**References:**

	Reference	Title	Rev No.
1.	EPIP-1	Emergency Plan Initiating Conditions Matrix	42
2.	EPIP-4	Site Area Emergency	30

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps of this JPM shall be performed in a classroom or in the simulator (simulator will not be set up to match the scenario).

The evaluator will provide initiating cues. Time begins when directed by evaluator. When the declaration has been made, raise your hand, the evaluator will record the time, and then continue the procedure.

Raise your hand again when you have completed the TVA Initial Notification Form, to the point of notifying the ODS.

### **INITIAL CONDITIONS:**

1. Unit 2 is at 100% RTP and stable.
2. Unit 1 experienced an AUTO SI from a small RCS leak which quickly escalated to a LOCA and a high containment pressure.
3. RCS pressure has stabilized at 600 psig.
4. Subcooling is 10°F.
5. Crew is entering FR-C.2 Core Cooling, Orange Path.
6. RVLIS lower range is indicating 40%.
7. The ONLY ECCS pump available and in service is the 1B-B RHR pump.
8. Containment Spray pumps are running.
9. Maximum containment pressure was 5 psig.
10. Containment radiation level are as follows:  
~1.8E+02 Rem/hr on RM-90-273A and RM-90-274.  
~1.7E+02 Rem/hr on RM-90-271A and RM-90-272.
11. EPS *is not* available in MCR.
12. All radiological releases are within Tech Spec limits.
13. There are no indications of an Onsite Security Event.

### **INITIATING CUES:**

You are the Unit 1 US and have assumed the SED position, until the TSC is staffed.

You are to perform each of the following:

1. Classify this event per EPIP 1,  
and
2. Fill out TVA Initial Notification Form and make Protective Action Recommendations, if any.

**THIS IS A TIME CRITICAL JPM**  
**Time begins when directed by evaluator.**



Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><u>STEP 1.:</u> Refers to EPIP-1 to determine level of event.</p> <p><u>STANDARD:</u> Operator refers to EPIP-1, Section 1, Fission Product Barrier Matrix. Operator determines that they have met the conditions of:</p> <p>1.1.5 Loss, "Containment High Radiation" <b>AND</b> 1.2.2 Loss "RCS leak results in subcooling &lt;40°F" <b>and / or</b> 1.2.4 Loss RVLIS &lt;42% with no RCP's running *(1.1.1 Potential, "Core Cooling Orange" may also be selected but not required)</p> <p>Declaration of event must be made in <b>15 minutes</b> from the time the task was accepted.</p> <p><b>Record Time of Declaration:</b> _____</p> <p><b>Time from Task Acceptance to Declaration:</b> _____</p> <p>Utilizing "Emergency Class Criteria", operator determines the need to declare a <b>SITE AREA EMERGENCY</b> based on Loss of two barriers. Time of Declaration is recorded when the operator raises his hand.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p> <p><b>Task Start Time</b> _____</p>	
<p><b>The following steps implement EPIP-4:</b></p>		
<p><u>STEP 2.:</u> Implements EPIP-4 SITE AREA EMERGENCY, Section 3.1 [1] If TSC is operational...</p> <p><u>STANDARD:</u> Operator N/A's this step, per initiating cues the TSC is not staffed.</p>	<p>___ SAT</p> <p>___ UNSAT</p>	
<p><u>STEP 3.</u> [3] ACTIVATE Emergency Paging System (EPS) as follows:</p> <p><u>STANDARD:</u> Operator recalls from initial conditions, that EPS has is not available from the control room and continues goes to Step [4].</p>	<p>___ SAT</p> <p>___ UNSAT</p>	

- Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>STEP 4.</b> [4] Complete Appendix B (TVA INITIAL NOTIFICATION FOR SITE AREA EMERGENCY).</p> <p><b>STANDARD:</b> Operator fills out Appendix B through step 7, prior to Notifying the ODS.</p> <ol style="list-style-type: none"> <li>1. This is a DRILL</li> <li>2. This is [Their name, Shift Manager at SQN Plant] Sequoyah has declared a SITE AREA EMERGENCY affecting [Unit 1]</li> <li>3. EAL Designator(s): <b>1.2.2 LOSS; and/or 1.2.4 LOSS; AND 1.1.5 LOSS</b> (1.1.1 POTENTIAL may also be listed but not required)</li> <li>4.. Brief description of incident: <b>[Core Cooling Orange Path AND Containment High Radiation AND RCS leak results in subcooling &lt;40°F]</b></li> <li>5.. Radiological Conditions <b>[Minor releases within federally approved limits.]</b></li> <li>6. Event Declared: <b>[Time and Date]</b></li> <li>7. Protective Action Recommendation: <b>[None].</b></li> <li>8. Please repeat back the information you have received to ensure accuracy.</li> <li>9. When completed, FAX this information to the ODS.</li> </ol>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>	
<p><b>STEP 5.</b> [5] <b>NOTIFY ODS.</b></p> <p style="text-align: right;">             _____              Initial                      Time           </p> <p><b>NOTE:</b> Evaluator Enter time call is made to the ODS _____</p> <p>Time from Declaration (step 1) to ODS Notification: _____</p> <p><b>STANDARD:</b> Operator raises hand as signal that they have completed TVA Initial Notification form and are ready to Notify the ODS. ODS should be notified within 10 minutes after declaration of the event.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p> <p>Stop Time: _____</p>	

End of JPM

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps of this JPM shall be performed in a classroom or in the simulator (simulator will not be set up to match the scenario).

The evaluator will provide initiating cues. Time begins when directed by evaluator. When the declaration has been made, raise your hand, the evaluator will record the time, and then continue the procedure.

Raise your hand again when you have completed the TVA Initial Notification Form, to the point of notifying the ODS.

### **INITIAL CONDITIONS:**

1. Unit 2 is at 100% RTP and stable.
2. Unit 1 experienced an AUTO SI from a small RCS leak which quickly escalated to a LOCA and a high containment pressure.
3. RCS pressure has stabilized at 600 psig.
4. Subcooling is 10°F.
5. Crew is entering FR-C.2 Core Cooling, Orange Path.
6. RVLIS lower range is indicating 40%.
7. The ONLY ECCS pump available and in service is the 1B-B RHR pump.
8. Containment Spray pumps are running.
9. Maximum containment pressure was 5 psig.
10. Containment radiation levels are as follows:
  - ~1.8E+02 Rem/hr on RM-90-273A and RM-90-274.
  - ~1.7E+02 Rem/hr on RM-90-271A and RM-90-272.
11. EPS *is not* available in MCR.
12. All radiological releases are within Tech Spec limits.
13. There are no indications of an Onsite Security Event.

### **INITIATING CUES:**

You are the Unit 1 US and have assumed the SED position, until the TSC is staffed. You are to perform each of the following:

1. Classify this event per EPIP 1,  
and
2. Fill out TVA Initial Notification Form and make Protective Action Recommendations, if any.

**THIS IS A TIME CRITICAL JPM**  
Time begins when directed by evaluator.

APPENDIX B  
TVA INITIAL NOTIFICATION FOR SITE AREA EMERGENCY

TVA INITIAL NOTIFICATION FOR SITE AREA EMERGENCY

1. ☒ This is a Drill ☐ This is an Actual Event - Repeat - This is an Actual Event
2. This is SED "Name", Sequoyah has declared a **SITE AREA EMERGENCY**  
affecting: ☒ Unit 1 ☐ Unit 2 ☐ Both Unit 1 and Unit 2

3. EAL Designator(s): 1.1.5L and 1.2.2L +/or 1.2.4L

4. Brief Description of the Event: Core Cooling Orange Path  
Containment High Rad, RCS Leak, Subcooling <40°F

(Note: 1.1.1P, 1.1.4P, 1.2.2P can be listed but are not critical)

5. Radiological Conditions: (Check one box under each Airborne AND Liquid column.)

Airborne Releases Offsite

- ☒ Minor releases within federally approved limits<sup>1</sup>  
☐ Releases above federally approved limits<sup>1</sup>  
☐ Release information not known

(<sup>1</sup>Tech Specs)

Liquid Releases Offsite

- ☒ Minor releases within federally approved limits<sup>1</sup>  
☐ Releases above federally approved limits<sup>1</sup>  
☐ Release information not known

(<sup>1</sup>Tech Specs)

6. Event Declared: Time: (time declared) Date: Today

7. Provide Protective Action Recommendation: ☒ None

8. Please repeat back the information you have received to ensure accuracy. ☐

9. When completed, FAX this information to the ODS. ☐

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps of this JPM shall be performed in a classroom or in the simulator (simulator will not be set up to match the scenario).

The evaluator will provide initiating cues. Time begins when directed by evaluator. When the declaration has been made, raise your hand, the evaluator will record the time, and then continue the procedure.

Raise your hand again when you have completed the TVA Initial Notification Form, to the point of notifying the ODS.

### **INITIAL CONDITIONS:**

1. Unit 2 is at 100% RTP and stable.
2. Unit 1 experienced an AUTO SI from a small RCS leak which quickly escalated to a LOCA and a high containment pressure.
3. RCS pressure has stabilized at 600 psig.
4. Subcooling is 10°F.
5. Crew is entering FR-C.2 Core Cooling, Orange Path.
6. RVLIS lower range is indicating 40%.
7. The ONLY ECCS pump available and in service is the 1B-B RHR pump.
8. Containment Spray pumps are running.
9. Maximum containment pressure was 5 psig.
10. Containment radiation levels are as follows:
  - ~1.8E+02 Rem/hr on RM-90-273A and RM-90-274.
  - ~1.7E+02 Rem/hr on RM-90-271A and RM-90-272.
11. EPS is *not* available in MCR.
12. All radiological releases are within Tech Spec limits.
13. There are no indications of an Onsite Security Event.

### **INITIATING CUES:**

You are the Unit 1 US and have assumed the SED position, until the TSC is staffed. You are to perform each of the following:

1. Classify this event per EPIP 1,  
and
2. Fill out TVA Initial Notification Form and make Protective Action Recommendations, if any.

**THIS IS A TIME CRITICAL JPM**  
Time begins when directed by evaluator.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM 190

### Reactivity Balance Calculation

PREPARED/  
REVISED BY:

Date/

VALIDATED BY:

\*

Date/

APPROVED BY:

Date/

(Operations Training Manager)

CONCURRED:

\*\*

Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

### REVISION/USAGE LOG

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial Issue	Y	3/17/04	ALL	G.S. Poteet
Pen/ink	Made corrections resulting from validation	N	5/12/04	2, 4-7	G.S. Poteet
1	Developed for 6/7-14/04 NRC Exam. Transferred to JPM Bank.	N	6/15/04	All	J. Kearney
2	Revised to update to the latest procedure revision, enhanced initial conditions.	Y	1/11/10	All	M Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
AUO/RO/SRO  
JOB PERFORMANCE MEASURE

**Task:** Perform a Reactivity Balance Calculation per 0-SO-62-7, Appendix E

**JA/TA TASK #: 0040070101 (RO)**

**K/A Ratings:**

2.1.25 (3.9/4.2)  
004 A4.04 (3.2/3.6)

004 K5.20 (3.6/3.7)

**Task Standard:**

Operator performs 0-SO-62-7 Appendix E, Reactivity Balance Calculation

**Evaluation Method:** Simulator   X   In-Plant       

Performer: \_\_\_\_\_  
NAME

Start Time \_\_\_\_\_

Performance Rating: SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish Time \_\_\_\_\_

Evaluator: \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

## COMMENTS



**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Critical steps identified.
2. Any UNSAT requires comments
3. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

Validation Time: CR. 35 min Local           

**Tools/Equipment/Procedures Needed**

1. Cycle Nuclear Design Report (NDR)
2. 0-SO-62-7 Boron Concentration Control
3. Highlighter and ruler

**References:**

	Reference	Title	Rev No.
A.	0-SO-62-7	Boron Concentration Control	56
B.	TI-44	Boron Tables	12

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be performed for this JPM. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

1. Unit 1 is currently stable at 20 %.
2. Control rod Bank D is at 160 steps.
3. RCS boron concentration is 1400 ppm.
4. 1U0981Core burnup is 600 MWD/MTU.
5. Reactor Engineering has provided following Xenon data:  
     $XE_1 = -2430$  pcm  
     $XE_2 = -2250$  pcm

**INITIATING CUES:**

Perform 0-SO-62-7, Appendix E, Reactivity Balance calculation, in preparation for a change in reactor power from 20% with Control Rods at 160 steps on D Bank, to 70% with Control Bank D at 228 steps, using a 3%/hour power increase rate.

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><u>STEP 1.:</u> Obtain a copy of the procedure.</p> <p><u>STANDARD:</u> Operator obtains a copy of 0-SO-62-7 Boron Concentration Control, Appendix E Reactivity Balance Calculation.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>	
<p><u>STEP 2.:</u> [1] ENTER the following Data:</p> <p>Current RCS Boron</p> <p><b><u>NOTE</u></b> <i>Per initial conditions RCS boron concentration is 1400 ppm</i></p> <p><u>STANDARD</u> Operator enters 1400 ppm from INITIAL CONDITIONS</p>	<p>___ SAT</p> <p>___ UNSAT</p>	
<p><u>STEP 3.:</u> Core Burnup</p> <p><b><u>NOTE</u></b> <i>Per initial conditions computer point 1U0981 indicates 600 MWD/MTU</i></p> <p><u>STANDARD</u> Operator uses 1U0981 data from initial conditions, and enters 600 MWD/MTU on Appendix E.</p>	<p>___ SAT</p> <p>___ UNSAT</p>	
<p><u>STEP 4.:</u> Current Reactor Power</p> <p><b><u>NOTE</u></b> <i>Per initial conditions, current reactor power is 20%.</i></p> <p><u>STANDARD:</u> Operator enters 20% per Initial Conditions</p>	<p>___ SAT</p> <p>___ UNSAT</p>	
<p><u>STEP 5.:</u> Final Reactor Power</p> <p><b><u>NOTE</u></b> <i>Per initial conditions, final reactor power is 70%.</i></p> <p><u>STANDARD:</u> Operator enters 70% per Initial Conditions</p>	<p>___ SAT</p> <p>___ UNSAT</p>	
<p><u>STEP 6.:</u> Total Reactor Power Change</p> <p><u>STANDARD:</u> Operator determines power change to be 50%.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>	

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 7.:</u> Rate of Reactor Power change</p> <p><u>STANDARD:</u> Operator enters 3%/hr per initial conditions.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *8.:</u> Number of hours to change power</p> <p><u>STANDARD:</u> Operator calculates number of hours to change power; 50% / 3%/hour and enters results: 16 2/3 hours (or 16.67 hours, or 16 hours and 40 minutes).</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *9.:</u> Current Rod Position</p> <p><u>STANDARD:</u> Operator enters 160 steps on Bank D per Initial Conditions</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *10.:</u> Final Rod Position</p> <p><u>STANDARD:</u> Operator enters 228 steps per Initial Conditions</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *11.:</u> <b>[2] CALCULATE</b> change in boron concentration by performing the following: [a] <math>\Delta\rho_{\text{POWER DEFECT}}</math></p> <p><math>\Delta\rho_{\text{POWER DEFECT}} = \text{___ pcm PD}_1 - \text{___ pcm PD}_2 = \text{___ pcm}</math></p> <p><u>NOTE:</u> Use "eye-ball" interpolation between closest parameter lines. Band accuracy 1/2 increment presented on figure.</p> <p><u>STANDARD:</u> Operator uses proper curve, Figure 1, U1C17 Power Defect BOL, 1400 ppm line (long dash line) to enter data. For 20% operator should enter 350 pcm. For 70%, operator should enter 1100 pcm.</p> <p><math>\Delta\rho_{\text{POWER DEFECT}} = 350 \text{ pcm PD}_1 - 1100 \text{ pcm} = -750 \text{ pcm}</math></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP *12.:</u> [b] <math>\Delta\rho_{\text{XENON}}</math></p> <p><math>\Delta\rho_{\text{XENON}} = -2250 \text{ pcm XE}_2 - (-2430 \text{ pcm}) \text{ XE}_1 = 180 \text{ pcm}</math></p> <p><u>STANDARD:</u> Operator enters Xenon values (provided in the initial conditions) and calculates the change in reactivity due to Xenon.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP *13.:</u> [c] <math>\Delta p_{RODS}</math></p> <p><math>\Delta p_{RODS} = \text{_____ pcm Rods}_2 - \text{_____ pcm Rods}_1 = \text{_____ pcm}</math></p> <p><u>NOTE:</u> Use "eye-ball" interpolation between closest parameter lines. Band accuracy ½ increment presented on figure.</p> <p><u>STANDARD:</u> Operator uses proper curve Figure 4, 25% line for 160 steps operator should enter -480 (-450 to -525 pcm). For 228 steps, operator should enter 0.</p> <p><math>\Delta p_{RODS} = (0) \text{ pcm Rods}_2 - -480 \text{ (Acceptable Range -450 to -525) pcm Rods}_1 = 480 \text{ (Acceptable Range 450 to 525 pcm)}</math></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 14.:</u> [d] Change in reactivity due to Power Defect, Xenon and Rods</p> <p><math>[a] + [b] + [c] = \text{_____ pcm}</math></p> <p><u>STANDARD:</u> Operator calculates Change in reactivity due to power defect, Xenon and rods:  <math>-750 \text{ pcm} + 180 \text{ pcm} + 480 \text{ (450 to 525) pcm} = -90 \text{ pcm}</math>  (Acceptable Range -120 pcm to -45 pcm)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 15.:</u> [e] Change in Boron Reactivity</p> <p>Substep [d] X (-1) = 90 pcm</p> <p>(Acceptable Range 120 pcm to 45 pcm)</p> <p><u>STANDARD:</u> Operator calculates the change in Boron Reactivity, by multiplying substep [d] by -1.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 16.:</u> [f] Change in Boron Concentration</p> <p>Substep [e] / Boron Worth</p> <p><u>STANDARD:</u> Operator Records change in boron reactivity and determines the Boron Worth pcm/ppm from Figure 7.  Substep [e] / -6.25 pcm/ppm Boron worth = 14.4  (Acceptable Range 19.2 – 7.2 pcm)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<u>STEP 17.:</u>	[3] Ensure independently verified by SRO in accordance with Appendix J.	___ SAT
<u>STANDARD:</u>	Operator notifies the US an independent verification is required in accordance with Appendix J.	___ UNSAT
		End Time _____

End of JPM

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 164 of 201
------------	-----------------------------	---

APPENDIX E  
Page 1 of 18

KEY JPM190  
P.15

REACTIVITY BALANCE CALCULATION

**NOTE 1** One calculation is required for each major change. Calculation is an approximation of required Boron change. Eyeball interpolation of graphs is expected.

**NOTE 2** Dilution or Boration value for power change from  $P_1$  % to  $P_2$  % power in time period T with rods moving from step position  $R_1$  to  $R_2$ . (Subscript convention: 1 = current point, 2 = target point)

[1] ENTER the following data:

DATA REQUIRED	DATA	Where To Get
Current RCS Boron	<u>1400</u> ppm	Chem Lab or Estimate using Appendix O
Core Burnup	<u>600</u> MWD/MTU	ICS U0981
Current Reactor power	<u>20</u> %	NIS or ICS
Final Reactor power	<u>70</u> %	As required for plant conditions
Total Reactor Power change	<u>50</u> Δ%	Δ Current and final Reactor power
Rate of Reactor power change	<u>.3</u> %/hr	As required for plant conditions
Number of hours to change power	<u>16 2/3</u> hr(s) <small>16 h 40 m 16.67</small>	As required for plant conditions
Current Rod Position	<u>160</u> steps	ICS or MCR Board
Final Rod Position	<u>228</u> steps	Estimate number of rod steps required to control ΔI and rod withdrawal requirements for power change.

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 165 of 201
------------	-----------------------------	---

APPENDIX E  
Page 2 of 18

Key JPM 190  
p 2/5

**CAUTION** Follow sign conventions explicitly. (See Example Power Increase and Power decrease.)

[2] CALCULATE change in boron concentration by performing the following:

Parameter	Where To Get	Calculation	Value
[a] $\Delta\rho$ POWER DEFECT	Attached Power Defect Curves: Unit 1: Figure 1, 2, or 3 Unit 2: Figure 8, 9, or 10.	$\underline{350} \text{ pcm PD}_1 - \underline{1100} \text{ pcm PD}_2 =$ (current)	$\underline{-750} \text{ pcm}$ $\Delta\rho$ POWER DEFECT (negative for power increase)
[b] $\Delta\rho$ XENON	Xenon <sub>1</sub> : From ICS* or REACTF (either current conditions or projection to initial condition). Xenon <sub>2</sub> : From ICS* or REACTF (projection over time period T). *(ICS Xenon values must add negative sign).	NOTE: Xenon reactivity must be <u>negative</u> $\underline{-2250} \text{ pcm XE}_2 - \underline{-2430} \text{ pcm XE}_1 =$ (current)	$\underline{180} \text{ pcm}$ $\Delta\rho$ XENON (negative for rise in Xenon conc)
[c] $\Delta\rho$ RODS	Attached Rod Worth Curves: Unit 1: Figure 4, 5, or 6 Unit 2: Figure 11, 12, or 13.	$\underline{0} \text{ pcm Rods}_2 - \underline{-480} \text{ pcm Rods}_1 =$ (current) (Range 450 to 525 pcm)	$\underline{480} \text{ pcm}$ $\Delta\rho$ RODS (450 to 525) (negative for rod insertion)
[d] $\Delta\rho$ POWER DEFECT + XENON + RODS (CHANGE IN REACTIVITY DUE TO POWER DEFECT, XENON, AND RODS)		$\underline{[a]} \text{ pcm } \Delta\rho \text{ POWER DEFECT} + \underline{[b]} \text{ pcm } \Delta\rho \text{ XENON} + \underline{[c]} \text{ pcm } \Delta\rho \text{ RODS} =$	$\underline{-90} \text{ pcm}$ Acceptable Range $\underline{-120 \text{ pcm to } -45 \text{ pcm}}$
[e] $\Delta\rho$ BORON (CHANGE IN BORON REACTIVITY)		$(\underline{[d]} \text{ pcm } \Delta\rho \text{ POWER DEFECT + XENON + RODS}) \times (-1) =$	$\underline{90} \text{ pcm}$ $\Delta\rho$ BORON (120 to 45)
[f] $\Delta\text{ppm}$ BORON (CHANGE IN BORON CONCENTRATION)		$(\underline{[e]} \text{ pcm } \Delta\rho \text{ BORON}) \div (\underline{-6.25} \text{ pcm/ppm Boron Worth}) =$ from Fig. 7 (U-1) or Fig. 14 (U-2)	$\underline{-14.4} \text{ ppm}$ (negative for dilution, positive for boration) (-19.2 to -7.2 ppm)


[3] ENSURE independently verified by SRO in accordance with Appendix J.  
(N/A if performed by an SRO to verify data provided by Rx. Eng)

APPENDIX E  
Page 5 of 18

Key JPM190  
p3/5

Figure 1 U1C17 Power Defect BOL

**NOTE** Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-23 to 6-27




**APPENDIX E**  
 Page 8 of 18

*Key JPM190*  
*p4/s*

**Figure 4 U1C17 Inserted Rod Worth BOL**

**NOTE**      Use "eye-ball" interpolation between closest parameter lines.




SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 174 of 201
------------	-----------------------------	---

APPENDIX E  
Page 11 of 18

Key JPM 196  
p 5/5

Figure 7 U1C17 Differential Boron Worth

**NOTE** Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-7

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All steps shall be performed for this JPM. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. Unit 1 is currently stable at 20 %.
2. Control rod Bank D is at 160 steps.
3. RCS boron concentration is 1400 ppm.
4. 1U0981 Core burnup is 600 MWD/MTU.
5. Reactor Engineering has provided following Xenon data:  
     $XE_1 = -2430$  pcm  
     $XE_2 = -2250$  pcm

### INITIATING CUES:

Perform 0-SO-62-7, Appendix E, Reactivity Balance calculation, in preparation for a change in reactor power from 20% with Control Rods at 160 steps on D Bank, to 70% with Control Bank D at 228 steps, using a 3%/hour power increase rate.

TENNESSEE VALLEY AUTHORITY  
SEQUOYAH NUCLEAR PLANT  
SYSTEM OPERATING INSTRUCTIONS

**0-SO-62-7**

**BORON CONCENTRATION CONTROL**

Revision 56

**QUALITY RELATED**

PREPARED BY: Olivia Taylor

RESPONSIBLE ORGANIZATION: OPERATIONS

APPROVED BY: J. K. WILKES

EFFECTIVE DATE: 07/06/09

LEVEL OF USE: **CONTINUOUS USE**

REVISION

DESCRIPTION: Minor editorial change made to correct UNID issue in Section 8.15  
(09001012)

**PERFORMANCE OF THIS PROCEDURE MAY IMPACT REACTIVITY**

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 2 of 201
--------------------------	------------------------------------	---------------------------------------

## TABLE OF CONTENTS

Page 1 of 3

Section Title	Page
<b>1.0 INTRODUCTION .....</b>	<b>5</b>
1.1 Purpose .....	5
1.2 Scope.....	5
<b>2.0 REFERENCES.....</b>	<b>5</b>
2.1 Performance References .....	5
2.2 Developmental References.....	6
<b>3.0 PRECAUTIONS AND LIMITATIONS.....</b>	<b>7</b>
<b>4.0 PREREQUISITE ACTIONS .....</b>	<b>9</b>
<b>5.0 STARTUP/STANDBY READINESS .....</b>	<b>13</b>
5.1 Automatic Makeup .....	13
<b>6.0 NORMAL OPERATION .....</b>	<b>17</b>
6.1 At Power Routine Dilution.....	17
6.2 Dilute.....	19
6.3 Alternate Dilute .....	25
6.4 Borate .....	29
6.5 Manual Makeup Control (preferred method for VCT makeup in Modes 1 and 2)	33
<b>7.0 SHUTDOWN.....</b>	<b>39</b>
<b>8.0 INFREQUENT OPERATION .....</b>	<b>40</b>
8.1 Blending to Spent Fuel Pit Using Blender via SFP Cooling Pump Suction Pressure Indicators .....	40
8.2 Blending to Spent Fuel Pit Using Blender via Bull Hose directly to Spent Fuel Pit .....	50
8.3 Makeup to RWST .....	58
8.3.1 Blending to Refueling Water Storage Tank (RWST) Using Boric Acid Blender	58
8.3.2 High Boron Concentration Makeup to RWST .....	63
8.4 Makeup to the Reactor Coolant System from the RWST in Modes 1-4 when Automatic/Manual Makeup is unavailable .....	69

<b>SQN 1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 3 of 201
--------------------	------------------------------------	---------------------------------------

## TABLE OF CONTENTS

Page 2 of 3

Section	Title	Page
8.5	Manual Makeup to the Reactor Coolant System from the RWST in Modes 5 or 6 .....	72
8.6	Blending to Transfer Canal Using Boric Acid Blender .....	75
8.7	Blending to the Holdup Tank (HUT) Using Boric Acid Blender.....	83
8.8	Flushing Unit 1 Blender/Piping Using Primary Water (Maintenance Activities)....	93
8.9	Flushing Unit 2 Blender/Piping Using Primary Water (Maintenance Activities)....	99
8.10	Rapid Boration using Emergency Borate Valve.....	106
8.11	Manual Blending to RCS During Refill Operations in Mode 5 or 6 .....	109
8.12	Blending to "B" Holdup Tank (HUT) Using Unit 1 Boric Acid Blender .....	116
8.13	Blending to Refueling Water Storage Tank (RWST) Using a Boric Acid Blender.	125
8.13.1	Blending to Unit 2 Refueling Water Storage Tank (RWST) Using Unit 1 Boric Acid Blender.....	125
8.13.2	Blending to Unit 1 Refueling Water Storage Tank (RWST) Using Unit 2 Boric Acid Blender.....	138
8.14	Unit 1 Alternate divert path using RCL sampling system.....	150
8.15	At Power Boration to Maintain Steady State Power Conditions.....	155
<b>9.0</b>	<b>RECORDS .....</b>	<b>157</b>
<b>APPENDIXES</b>		
APPENDIX A:	HOSE CONNECTION UTILIZING MAINTENANCE SUPPORT	158
APPENDIX B:	BORIC ACID FLOW RATE CALCULATIONS.....	159
APPENDIX C:	CALCULATION OF BORIC ACID AND PRIMARY WATER INTEGRATOR SETTING FOR MANUAL MAKEUP TO VCT (RCS)	161
APPENDIX D:	CALCULATION FOR AMOUNT OF BORIC ACID OR PRIMARY WATER (TI-44) .....	163
APPENDIX E:	REACTIVITY BALANCE CALCULATION .....	164
APPENDIX F:	CALCULATION OF BORIC ACID AND PRIMARY WATER INTEGRATOR SETTING FOR MANUAL MAKEUP TO RWST OR HOLDUP TANK .....	182
APPENDIX G:	CALCULATION OF INTEGRATOR SETTINGS FOR MANUAL BLEND DURING RCS FILL .....	185

<b>SQN 1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 4 of 201
--------------------	------------------------------------	---------------------------------------

## TABLE OF CONTENTS

Page 3 of 3

Section Title	Page
<b>APPENDIXES</b>	
APPENDIX H: INDEPENDENT VERIFICATION OF CALCULATION OF BORIC ACID AND PRIMARY WATER INTEGRATOR SETTING FOR MANUAL MAKEUP TO VCT (RCS).....	188
APPENDIX I: INDEPENDENT VERIFICATION OF CALCULATION FOR AMOUNT OF BORIC ACID OR PRIMARY WATER (TI-44) ..	190
APPENDIX J: INDEPENDENT VERIFICATION OF REACTIVITY BALANCE CALCULATION .....	191
APPENDIX K: INDEPENDENT VERIFICATION OF CALCULATION OF BORIC ACID AND PRIMARY WATER INTEGRATOR SETTING FOR MANUAL MAKEUP TO RWST OR HOLDUP TANK .....	193
APPENDIX L: INDEPENDENT VERIFICATION OF CALCULATION OF INTEGRATOR SETTINGS FOR MANUAL BLEND DURING RCS FILL .....	196
APPENDIX M: CALCULATION OF BORIC ACID CONTROLLER SETTING FOR AUTO MAKEUP.....	198
APPENDIX N: INDEPENDENT VERIFICATION FOR CALCULATION OF BORIC ACID CONTROLLER SETTING FOR AUTO MAKEUP .....	199
APPENDIX O: ESTIMATION OF CURRENT RCS BORON CONCENTRATION.....	200
<b>SOURCE NOTES .....</b>	<b>201</b>
<b>ATTACHMENTS</b>	
ATTACHMENT 1: POWER CHECKLIST 1-62-7.01	
ATTACHMENT 2: POWER CHECKLIST 2-62-7.02	
ATTACHMENT 3: VALVE CHECKLIST 1-62-7.03	
ATTACHMENT 4: VALVE CHECKLIST 2-62-7.04	

<b>SQN 1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 5 of 201
--------------------	------------------------------------	---------------------------------------

## **1.0 INTRODUCTION**

### **1.1 Purpose**

To provide instructions for operation of the Boron Control System.

### **1.2 Scope**

This instruction provides detailed steps for the following modes of operation:

Automatic Makeup

At Power Routine Dilution

Dilute and Alternate Dilute

Borate

Manual Makeup Control (preferred method for VCT makeup in Modes 1 and 2)

Blending to Spent Fuel Pit Using Boric Acid Blender via SFP

Cooling Pump Suction Pressure Indicators

Blending to Spent Fuel Pit Using Boric Acid Blender via Bull Hose

Directly to Spent Fuel Pit

Blending to RWST Using Boric Acid Blender

Makeup to the Reactor Coolant System from the RWST in modes 1-4 when the Automatic/Manual Makeup is unavailable.

Manual Makeup to the Reactor Coolant System from the RWST in modes 5 or 6

Blending to Transfer Canal Using Boric Acid Blender

Blending to the Holdup Tank using Boric Acid Blender

Flushing Unit 1 Blender/Piping Using Primary Water (Maintenance Activities)

Flushing Unit 2 Blender/Piping Using Primary Water (Maintenance Activities)

UNIT 2 Alternate divert path using RCL sampling system

## **2.0 REFERENCES**

### **2.1 Performance References**

#### **A. Procedures**

1. 0-SO-62-10, Boric Acid Batch, Transfer, and Storage System
2. 0-SO-78-1, Spent Fuel Pit Cooling System

#### **B. Technical Instructions - TI-44, Boron Tables**



<b>SQN 1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 6 of 201
--------------------	------------------------------------	---------------------------------------

## **2.2 Developmental References**

### **A. Procedures**

1. SOI-62.2, Boron Concentration Control
2. O-PI-OPS-000-633.0, Aux. Cont. Rm. Switch Alignment Verification
3. Westinghouse Vendor Manual SQN-VM 4990

### **B. Technical Specifications**

1. 3.1.1.1
2. 3.1.1.2
3. 3.9.1
4. 3.10.1
5. Bases 3/4.1.3

### **C. Technical Requirements Manual**

1. 3.1.2.1
2. 3.1.2.2
3. 3.1.2.3
4. 3.1.2.4
5. 3.1.2.5
6. 3.1.2.6
7. Bases 3/4.1.2

### **D. FSAR**

1. 9.3.4.2.5
2. 9.3.4.2.2
3. 9.3.4.2.6
4. 15.2.4
5. 15.2.14.1
6. 15.4.6.1

### **E. TVA Drawings**

1. 47W809-1
2. 47W809-2
3. 47W809-5

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 7 of 201
--------------------------	------------------------------------	---------------------------------------

### 3.0 PRECAUTIONS AND LIMITATIONS

- A. The mode selector switch should be returned to the **AUTO** makeup mode after any dilution or boration operation. The control switch must be turned to **START** in order for the auto makeup to function.
- B. At least one Reactor Coolant Pump or one RHR Pump must be in operation during dilution operations. **[C.6]**
- C. Maintain Pressurizer boron concentration within 50 ppm of reactor coolant loop boron concentration. This can be accomplished by turning pressurizer heaters on and allowing sprays to maintain RCS pressure within program. If Normal Spray is NOT available, then Auxiliary Spray should be used (1, 2-SO-62-1) in conjunction with pressurizer backup heaters.
- D. Axial flux difference should be maintained within limits by using the control bank of rods while changing boron concentration.
- E. Prior to making a positive reactivity change, Tech Specs and TRM should be referenced to ensure the unit is not in a LCO action that prohibits a positive reactivity change. **[C.1]**
- F. A boron sample should be obtained whenever reactor makeup water is added to the VCT, unless the unit is at power and results of the makeup are as expected.
- G. When making an RCS dilution of  $\geq 3000$  gallons, it should be done in batches with an RCS boron concentration verification at the halfway point (e.g., 1500 gallons). Allow at least 15 minutes between batches. **[C.5] [C.7]**
- H. Simultaneous makeup to the RWST and the RCS should be avoided to prevent the possibility of injecting unborated (or under borated) water into the core. **[C.4] [C.6] [C.7]**
- I. Reactivity balance calculations are required for any power changes more than 1%, except when immediate boration is required to maintain rods above the insertion limit or as required during an Rapid Shutdown or Load Reduction (AOP-C.03) or dropped/misaligned rod recovery (AOP-C.01). Although stated in the procedure that only one calculation is required for a major change in Reactor Power, calculations should be current and take into account the time dependency of parameters used in the calculation. [e.g. one calculation to decrease RX power to 70% power to remove a MFP is acceptable]. In the event of a large power manipulation (GO startup or shutdown) several calculations will be required. A calculation should be performed for the increase to 30% Reactor power, another for an increase to 50%, and so on. These calculations may be correlated to GO plateaus.

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 8 of 201
--------------------------	------------------------------------	---------------------------------------

### 3.0 PRECAUTIONS AND LIMITATIONS (CONTINUED)

- J. Boric Acid Controller adjustment is required for B-10 depletion for automatic and manual makeup to improve the accuracy of the blend. The B-10 depletion value for each unit can be obtained from the Rx Eng Information file located on the site intranet. Reactor Eng Information ICON can be found on the control room PC's.
- K. An unanticipated power change greater than 5 MWT, rod motion greater than 1 step (in or out), or  $T_{AVG}$  greater than 0.5°F, require a PER and should be evaluated as a potential reactivity management event per SPP-10.4, Reactivity Management Program.
- L. Boron concentration measurement inaccuracies and integrator calibration tolerance may result in a small difference between RCS boron concentration and blend boron concentration. This may result in a small change in  $T_{avg}$  (~1/4°F) and thermal power (by a few megawatts) after makeup.
- M. Manual Makeup (Section 6.5) of approximately 200 gallons or less is preferred over allowing the system to automatically make up in Modes 1 and 2. Performing manual makeup and limiting the volume of makeup is preferred to reduce the impact on reactivity, RCP seal performance (due to reduced pressure/temperature transients) and RCS chemistry (due to reduced VCT pressure changes). During transient conditions, emergencies, or during plant cooldown, automatic makeup may be used as necessary.
- N. The potential exists that the blender piping contains primary water. This will result in a dilution and a small reactivity addition.
- O. Completely emptying the BAT's for all valve work is not required to establish a safe work boundary. The valves on the lower portions the tanks require an empty tank to establish safe conditions. The tank drain, level instrument isolation and pump suction line are all at or near the bottom of the tank. These are listed in the table below:

<b>BAT A</b>	<b>BAT C</b>	<b>BAT B</b>
1-VLV-62-1049	0-VLV-62-1049	2-VLV-62-1049
1-VLV-62-1058	0-VLV-62-1058	2-VLV-62-1058
1-VLV-62-1088	0-VLV-62-1088	2-VLV-62-1088

The other valves associated with the Boric Acid Transfer Pumps can be worked with some level remaining in the tanks. As a margin of safety, a maximum of 85% should be used to establish safe working conditions.

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 9 of 201
--------------------------	------------------------------------	---------------------------------------

Unit 1

Date TODAY

#### 4.0 PREREQUISITE ACTIONS

✓ **NOTE** Throughout this Instruction where an **IF/THEN** statement exists, the step should be **N/A** if condition does not exist.

~~(1)~~ **ENSURE** the instruction to be used is a copy of the effective version.

Rox

~~(2)~~ **ENSURE** Precautions and Limitations, Section 3.0, has been reviewed.

Rox

~~(3)~~ **REVIEW** the following Status Files for any off-normal alignments that may impact performance:

Status File	✓
Unit 1	<input checked="" type="checkbox"/>
Unit 2	<input checked="" type="checkbox"/>
Radwaste	<input checked="" type="checkbox"/>

~~(4)~~ **ENSURE** Chemical and Volume Control System is in operation.

Rox

~~(5)~~ **IF** in modes 1, 2, or 3, **THEN**  
**ENSURE** requirements of TRM L.C.O. 3.1.2.6 are met,  
**OR**  
**COMPLY** with applicable actions.

Rox

~~(6)~~ **IF** in modes 4, 5, or 6, **THEN**  
**ENSURE** requirements of TRM L.C.O. 3.1.2.5 are met,  
**OR**  
**COMPLY** with applicable actions.

Rox

~~(7)~~ **IF** Primary Water required for the evolution to be performed, **THEN**  
**ENSURE** Primary Makeup Water system in service.

N/A

N/A

<b>SQN</b> 1,2	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 10 of 201
-------------------	------------------------------------	--

Unit 1

Date TODAY

#### 4.0 PREREQUISITE ACTIONS (Continued)

##### **NOTE**

The following step is performed at the discretion of the RO and/or SRO.

**[8]** WHEN performing a dilution or boration, THEN

**[a]** IF Normal pressurizer spray is available, THEN  
**ENERGIZE** pressurizer heaters so sprays can equalize the boron concentration between the pressurizer and the RCS

N/A

**[b]** IF Normal pressurizer spray is NOT available, THEN  
**PLACE** Auxiliary Spray in service (1, 2-SO-62-1) in conjunction with pressurizer backup heaters. (N/A if not applicable)

N/A

**[9]** ENSURE appropriate Valve Checklist has been completed (N/A if not applicable).

VALVE CHECKLIST	INITIALS
1-62-7.03	<u>Rox</u>
2-62-7.04	<u>N/A</u>

**[10]** ENSURE appropriate Power Checklist had been completed (N/A if not applicable).

POWER CHECKLIST	INITIALS
1-62-7.01	<u>Rox</u>
2-62-7.02	<u>N/A</u>

**[11]** IF Boric Acid Tank is the borated water source, THEN

**ENSURE** Boric acid pump aligned properly in accordance with 0-SO-62-10.

N/A

**[12]** IF using the RWST for the borated water source, THEN

**ENSURE** LCV-62-135 and/or LCV-62-136 **OPERABLE**.

N/A

##### **NOTE**

Step **[13]** may be marked N/A if boration must be immediately initiated to maintain shutdown margin OR if performing a rapid boration using FCV-62-138 in preparation for RCS cooldown.

**[13]** IF reactor is subcritical AND an RCS boration or dilution is required, THEN  
**PERFORM** Appendix D.

N/A

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 11 of 201
--------------------------	------------------------------------	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

#### 4.0 PREREQUISITE ACTIONS (Continued)

##### ~~NOTE 1~~

Step [14] may be marked N/A for any of the following conditions:

- Minor power changes (Reference Section 3.0)
- If boration must be immediately initiated to maintain control rods above the insertion limit
- During an emergency shutdown (AOP-C.03)
- Recovery of a dropped or misaligned rod (AOP-C.01).
- If initiating a rapid boration using FCV-62-138 immediately prior to reactor shutdown in preparation for RCS cooldown.
- During low power physics testing per 0-RT-NUC-000-003.0 if boration/dilution values have been provided and verified by Reactor Engineering.

##### ~~NOTE 2~~

Appendix D and E may be used to verify data provided by Reactor Engineering. IV is not required if Appendices are performed by an SRO to verify Rx. Engineering data.

~~[14]~~ IF reactor is critical **AND** RCS boration or dilution will be performed, **THEN**

**PERFORM** the following:

~~[a]~~ Appendix E Reactivity balance calculation.

~~[b]~~ Appendix D Calculation for amount of boric acid or primary water (TI-44).

~~[15]~~ IF performing a Spent Fuel Pit boration, **THEN**

**ENSURE** RCL has provided supporting data.

Rnf

N/A

N/A

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 12 of 201
------------	-----------------------------	--

Unit 1

Date TODAY

#### 4.0 PREREQUISITE ACTIONS (Continued)

**[16] REVIEW** Unit and Radwaste Status Files for any off normal alignments that may impact performance.

Ray

**[17] ENSURE** each performer and verifier documents their name and initials:

Print Name	Initials
Reactor Operator X	ROX

**[17] INDICATE** below which performance section of this instruction will be used and the reason for this performance:

- ☐ 5.0 STARTUP/STANDBY READINESS
- ☐ 6.0 NORMAL OPERATION
- ☐ 7.0 SHUTDOWN
- ☐ 8.0 INFREQUENT OPERATION

REASON:

Appendix E Reactivity  
Balance Calculation

**End of Section 4.0**

## APPENDIX E

Page 1 of 18

## REACTIVITY BALANCE CALCULATION

**NOTE 1** One calculation is required for each major change. Calculation is an approximation of required Boron change. Eyeball interpolation of graphs is expected.

**NOTE 2** Dilution or Boration value for power change from  $P_1$  % to  $P_2$  % power in time period T with rods moving from step position  $R_1$  to  $R_2$ . (Subscript convention: 1 = current point, 2 = target point)

**[1] ENTER** the following data:

DATA REQUIRED	DATA	Where To Get
Current RCS Boron	_____ ppm	Chem Lab or Estimate using Appendix O
Core Burnup	_____ MWD/MTU	ICS U0981
Current Reactor power	_____ %	NIS or ICS
Final Reactor power	_____ %	As required for plant conditions
Total Reactor Power change	_____ $\Delta$ %	$\Delta$ Current and final Reactor power
Rate of Reactor power change	_____ %/hr	As required for plant conditions
Number of hours to change power	_____ hr(s)	As required for plant conditions
Current Rod Position	_____ steps	ICS or MCR Board
Final Rod Position	_____ steps	Estimate number of rod steps required to control $\Delta I$ and rod withdrawal requirements for power change.



## APPENDIX E

Page 2 of 18

**CAUTION** Follow sign conventions explicitly. (See Example Power Increase and Power decrease.)**[2] CALCULATE** change in boron concentration by performing the following:

Parameter	Where To Get	Calculation	Value
<b>[a]</b> $\Delta p$ POWER DEFECT	Attached Power Defect Curves: <u>Unit 1</u> : Figure 1, 2, or 3 <u>Unit 2</u> : Figure 8, 9, or 10.	_____ pcm PD <sub>1</sub> - _____ pcm PD <sub>2</sub> = (current)	_____ pcm $\Delta p$ POWER DEFECT (negative for power increase)
<b>[b]</b> $\Delta p$ XENON	Xenon <sub>1</sub> : From ICS* or REACTF (either current conditions or projection to initial condition). Xenon <sub>2</sub> : From ICS* or REACTF (projection over time period T). *(ICS Xenon values must add negative sign).	<b>NOTE:</b> Xenon reactivity must be <u>negative</u> _____ pcm XE <sub>2</sub> - _____ pcm XE <sub>1</sub> = (current)	_____ pcm $\Delta p$ XENON (negative for rise in Xenon conc)
<b>[c]</b> $\Delta p$ RODS	Attached Rod Worth Curves: <u>Unit 1</u> : Figure 4, 5, or 6 <u>Unit 2</u> : Figure 11, 12, or 13.	_____ pcm Rods <sub>2</sub> - _____ pcm Rods <sub>1</sub> = (current)	_____ pcm $\Delta p$ RODS (negative for rod insertion)
<b>[d]</b> $\Delta p$ POWER DEFECT + XENON + RODS (CHANGE IN REACTIVITY DUE TO POWER DEFECT, XENON, AND RODS)			_____ pcm
		_____ <b>[a]</b> _____ pcm $\Delta p$ POWER DEFECT + _____ <b>[b]</b> _____ pcm $\Delta p$ XENON + _____ <b>[c]</b> _____ pcm $\Delta p$ RODS =	
<b>[e]</b> $\Delta p$ BORON (CHANGE IN BORON REACTIVITY)		( _____ <b>[d]</b> _____ pcm $\Delta p$ POWER DEFECT + XENON + RODS ) X (-1) =	_____ pcm $\Delta p$ BORON
<b>[f]</b> $\Delta ppm$ BORON (CHANGE IN BORON CONCENTRATION)		( _____ <b>[e]</b> _____ pcm $\Delta p$ BORON ) $\div$ ( _____ pcm/ppm Boron Worth ) = from Fig. 7 (U-1) or Fig. 14 (U-2)	_____ ppm (negative for dilution, positive for boration)

**[3] ENSURE** independently verified by SRO in accordance with Appendix J.  
(N/A if performed by an SRO to verify data provided by Rx. Eng)

<b>SQN</b> <b>1,2</b>	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 166 of 201
--------------------------	------------------------------------	---

## APPENDIX E

Page 3 of 18

### Example Power Increase

**NOTE** Typical values displayed in this example are not Unit and Cycle specific, however, the following example indicates proper sign convention.

Current RCS boron	1000 ppm
Core burnup	3000 MWD/MTU
Current reactor power	70%
Final reactor power	100%
Total reactor power change	30%
Rate of reactor power change	5%/hr
Number of hours to change power	6 hours
Current rod position	180 steps
Final Rod Position	220 steps

### Reactivity Balance:

$$[a] \Delta\rho_{\text{Power Defect}} = 1210 \text{ pcm PD1} - 1720 \text{ pcm PD2} = -510 \text{ pcm}$$

$$[b] \Delta\rho_{\text{Xenon}} = -2262 \text{ pcm XE2} - (-2436) \text{ pcm XE1} = +174 \text{ pcm}$$

$$[c] \Delta\rho_{\text{Rods}} = -10 \text{ pcm Rods2} - (-275) \text{ pcm Rods1} = +265 \text{ pcm}$$

$$[d] \Delta\rho_{\text{POWER DEFECT + XENON + RODS}} = -510 \text{ pcm} + 174 \text{ pcm} + 265 \text{ pcm} = -71 \text{ pcm}$$

$$[e] \Delta\rho_{\text{BORON}} = -71 \text{ pcm} \times (-1) = +71 \text{ pcm}$$

### Change in Boron PPM:

$$[f] (+71) \text{ pcm Boron} \div (-6.35) \text{ pcm/ppm Boron worth} = -11 \text{ ppm (dilution)}$$

<b>SQN</b> 1,2	<b>BORON CONCENTRATION CONTROL</b>	0-SO-62-7 Rev. 56 Page 167 of 201
-------------------	------------------------------------	---

## APPENDIX E

Page 4 of 18

### Example Power Decrease

#### NOTE

Typical values displayed in this example are not Unit and Cycle specific, however, the following example indicates proper sign convention.

Current RCS boron	500 ppm
Core burnup	18000 MWD/MTU
Current reactor power	100%
Final reactor power	80%
Total reactor power change	-20%
Rate of reactor power change	-5%/hr
Number of hours to change power	4 hours
Current rod position	220 steps
Final Rod Position	200 steps

#### Reactivity Balance:

$$[a] \Delta\rho_{\text{Power Defect}} = 2630 \text{ pcm PD1} - 2100 \text{ pcm PD2} = +530 \text{ pcm}$$

$$[b] \Delta\rho_{\text{Xenon}} = -3030 \text{ pcm XE2} - (-2884) \text{ pcm XE1} = -146 \text{ pcm}$$

$$[c] \Delta\rho_{\text{Rods}} = -220 \text{ pcm Rods2} - (-20) \text{ pcm Rods1} = -200 \text{ pcm}$$

$$[d] \Delta\rho_{\text{POWER DEFECT + XENON + RODS}} = +530 \text{ pcm} + (-146 \text{ pcm}) + (-200 \text{ pcm}) = +184 \text{ pcm}$$

$$[e] \Delta\rho_{\text{BORON}} = +184 \text{ pcm} \times (-1) = -184 \text{ pcm}$$

#### Change in Boron PPM:

$$[f] (-184) \text{ pcm Boron} \div (-7.47) \text{ pcm/ppm Boron worth} = +25 \text{ ppm (boration)}$$

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 168 of 201
------------	-----------------------------	---


## APPENDIX E

Page 5 of 18

Figure 1 U1C17 Power Defect BOL

### NOTE

Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-23 to 6-27

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 169 of 201
------------	-----------------------------	---


## APPENDIX E

Page 6 of 18

Figure 2 U1C17 Power Defect MOL

### NOTE

Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-23 to 6-27.

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 170 of 201
------------	-----------------------------	---


## APPENDIX E

Page 7 of 18

**Figure 3 U1C17 Power Defect EOL**

### NOTE

Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-23 to 6-27

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 171 of 201
------------	-----------------------------	---


## APPENDIX E

Page 8 of 18

Figure 4 U1C17 Inserted Rod Worth BOL

### NOTE

Use "eye-ball" interpolation between closest parameter lines.



Reference : NDR Table 6-34.


APPENDIX E

Page 9 of 18

Figure 5 U1C17 Inserted Rod Worth MOL

NOTE

Use "eye-ball" interpolation between closest parameter lines.




Reference : NDR Table 6-34.



APPENDIX E  
Page 10 of 18

Figure 6 U1C17 Inserted Rod Worth EOL

**NOTE** Use "eye-ball" interpolation between closest parameter lines.



Reference : NDR Table 6-34.


SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 174 of 201
------------	-----------------------------	---

## APPENDIX E

Page 11 of 18

Figure 7 U1C17 Differential Boron Worth

**NOTE** Use "eye-ball" interpolation between closest parameter lines.




Reference: NDR Table 6-7

APPENDIX E  
Page 12 of 18

Figure 8 U2C16 Power Defect BOL

**NOTE** Use "eye-ball" interpolation between closest parameter lines.




Reference: NDR Table 6-23 to 6-27, Total Power Defect

APPENDIX E  
Page 13 of 18

Figure 9 U2C16 Power Defect MOL

**NOTE** Use "eye-ball" interpolation between closest parameter lines.




Reference: NDR Table 6-23 to 6-27, Total Power Defect

SQN 1,2	BORON CONCENTRATION CONTROL	0-SO-62-7 Rev. 56 Page 177 of 201
------------	-----------------------------	---

**APPENDIX E**  
Page 14 of 18

**Figure 10 U2C16 Power Defect EOL**


**NOTE** Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-23 to 6-27, Total Power Defect

APPENDIX E  
Page 15 of 18

Figure 11 U2C16 Inserted Rod Worth BOL


**NOTE** Use "eye-ball" interpolation between closest parameter lines.

Reference: NDR Table 6-34, HFP Integral Rod Worth as a function of Steps withdrawn and burnup for Banks CD, CC, CB in overlap.

APPENDIX E  
Page 16 of 18

Figure 12 U2C16 Inserted Rod Worth MOL

**NOTE** Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-34, HFP Integral Rod Worth as a function of Steps withdrawn and burnup for Banks CD, CC, CB in overlap.


## APPENDIX E

Page 17 of 18

Figure 13 U2C16 Inserted Rod Worth EOL

## NOTE

Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-34, . HFP Integral Rod Worth as a function of Steps withdrawn and burnup for Banks CD, CC, CB in overlap.




APPENDIX E

Page 18 of 18

Figure 14 U2C16 Differential Boron Worth

NOTE Use "eye-ball" interpolation between closest parameter lines.



Reference: NDR Table 6-7, HFP Differential Boron Worth

# Surveillance Task Sheet (STS)

Order:

SI Key:

Procedure: 0-SI-OPS-068-137.0

Train/Loop:

Unique Data:

Title: Reactor Coolant system Water Inventory

Perf Sect: OPS

Test Reason: Daily

Unit: 0

Data Sheet: One Complete copy

Issued:

Extension:

Frequency: NONE

FO: N

TS: Y

ASME XI: N

Applicable Modes: 1,2,3,4,5,6

Perfor Modes: 1,2,3,4,5,6

Clearance Required:

Sched. Rec. #:

Authorization to Begin: SRO

TODAY  
Start Date

Now  
Time

Completion Date

Time

Mode:

SX

Dry Cask Storage:

Subsequent Reviews:

Initial

Date

Cognizant Engr

Cem Admin Reviewer

Was this a Complete or Partial Performance?  
(Explain Partial in "Remarks" below)

Complete [ ] Partial [ ]

Were all Tech Spec/Tech Req/ISFSI CoC/ODCM/Fire Prot  
Req/AMSAC acceptance criteria satisfied?

Yes [ ] No [ ] N/A [ ]

Were all other acceptance criteria satisfied?

Yes [ ] No [ ] N/A [ ]

If all Tech Spec Tech Req/ISFSI CoC/ODCM/Fire Prot  
Req/AMSAC were not satisfied, was an LCO/TR/ODCM  
Action required ((Explain in "Remarks"))

Yes [ ] No [ ] N/A [ ]

Print Name

Test Performer's Signature

Initial

Section

Reactor Operator X  
Reactor Operator Y

Reactor Operator X  
Reactor Operator Y

Rox  
Rox

OPS  
OPS

Reactor Operator X  
Test Director

Reactor Operator X  
Lead Performer

TODAY  
Date

Acceptance Criteria Review: SRO  
(ASME XI SIs require review within 96 hours)

Date

Time

Independent Reviewer

PERMANENT COMMENTS:

REMARKS:

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM 43-2 Manual RO A2

### PERFORM REACTOR COOLANT SYSTEM WATER INVENTORY (137.0)

**PREPARED/  
REVISED BY:** \_\_\_\_\_ **Date/** \_\_\_\_\_

**VALIDATED BY:** \* \_\_\_\_\_ **Date/** \_\_\_\_\_

**APPROVED BY:** \_\_\_\_\_ **Date/** \_\_\_\_\_  
(Operations Training Manager)

**CONCURRED:** \*\* \_\_\_\_\_ **Date/** \_\_\_\_\_  
(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

## NUCLEAR TRAINING

## REVISION/USAGE LOG

[illegible]

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

**Task:** Perform RCS Leakage Calculation (0-SI-OPS-068-137.0)

**JA/TA task # : 0020010201 (RO)**

**K/A Ratings:** 2.2.12 (3.7/4.1)  
002A4.01 (3.5/3.8)  
002K405 (3.8/4.2)  
002K504 (3.1/3.4)

**Task Standard:**

Upon completion of this task, the operator will have correctly determined RCS leakage per 0-SI-OPS-068-137.0 and notify the SRO of Tech Spec and EPIP requirements.

**Evaluation Method :** Simulator   X   In-Plant       

Performer: \_\_\_\_\_  
NAME

Start Time \_\_\_\_\_

**Performance Rating:** SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish Time \_\_\_\_\_

Evaluator: \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

SIGNATURE

DATE \_\_\_\_\_

## COMMENTS

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any UNSAT requires comments.
2. Ensure calculator is available for operators use.
3. A copy of 0-SI-OPS-068-137.0 and previously performed procedural steps must be provided to the operator for task performance.

**Validation Time: CR.** 20 mins

**Local** \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

0-SI-OPS-068-137.0

**References:**

	Reference	Title	Rev No.
1.	0-SI-OPS-068-137.0	Reactor Coolant System Water Inventory	22
2	TS	Technical Specifications	Latest

=====

## **READ TO OPERATOR**

### **DIRECTIONS TO TRAINEE:**

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

1. Unit-1 is in MODE 1.
2. The RCS leakage surveillance required by T.S. 4.4.6.2.1 is due this shift and the ICS computer is not available
3. The off going crew initiated performance of 0-SI-OPS-068-137.0, Section 6.1 and Appendix C are complete.  
Appendix D is complete through section 1.4

4. SG leakages

SG # 1	SG # 2	SG # 3	SG # 4
3.2 gpd	2.2 gpd	2.3 gpd	4.8 gpd

5. SI-50 and SI-137.5 were completed last night at 2300.
6. Chemistry supervisor reported no additions or samples taken from the RCS during the selected performance period.
7. CLA Levels initial and final are as follows:

CLA	LI	INITIAL	FINAL
1	63-129	7692	7692
2	63-109	7677	7677
3	63-89	7672	7672
4	63-89	7680	7680

8. CCPIT/HUT leakage and "other" leakage is 0 gpm
9. Do all calculations to three decimal places, or to 1/1000.
10. Data collected for performance of this leak rate is documented in Appendix C and was collected over 124 minutes

### **INITIATING CUES:**

You are the Unit-1 CRO and have been directed to complete the performance of 0-SI-OPS-068-137.0 Appendix "D" and Section 6.1.1 through step 8.

<p><b>STEP 1.:</b> Operator begins with Appendix D, Step 1.5 <b>Total RCS Leakage:</b></p> <p><b>STANDARD:</b> Operator continues at step 1.5 of Appendix D and totals leakage from steps 1.1 (VCT) , 1.3[3] (PZR)and 1.4 RCS Temp Corr  (1.46 + 0.031 + -0.066 = 1.425 GPM)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p> <p>_____</p> <p><b>Start Time</b></p>
<p><b>STEP 2.:</b> 2.1 Pressurizer Relief Tank PRT Leakage = <math>\frac{\text{Final Volume} - \text{Initial Volume}}{\text{Delta Time}}</math></p> <p><b>STANDARD:</b> Operator obtains volumes that were calculated in Appendix "C" Section 6.0 and determines the PRT leakage to be 0.242 GPM = (8622 - 8592) / 124.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 3.:</b> 2.2 Reactor Coolant Drain Tank RCDT Leakage = <math>\frac{\text{Final Volume} - \text{Initial Volume}}{\text{delta time}}</math></p> <p><b>STANDARD:</b> Operator obtains volumes that were calculated in Appendix "C" Section 7.0 and determines the RCDT leakage to be 0.033 = (85.4 - 81.3) / 124.)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 4.:</b> 2.3 Steam Generator</p> <p><b>STANDARD:</b> Operator utilizes information provided in the initial conditions or contacts Chemistry</p> <p><b>NOTE 1:</b> S/G leakages from initial conditions are as follows: [a] SG 1=3.2 GPD [b] SG 2=2.2 GPD [c] SG 3=2.3 GPD [d] SG 4=4.8 GPD</p> <p><b>NOTE 2:</b> Per initial conditions, SI-50 and SI 137.5 were completed yesterday at 2300.</p> <p><b>STANDARD:</b> Operator obtains SG leakages from initial conditions: Performs calculation and determines Total SG leakage = .3.2 + 2.2 + 2.3 + 4.8 = <math>\frac{12.5 \text{ GPD}}{1440 \text{ min/day}}</math> = 0.009</p> <p>Records performance times for SI-50 and SI-137.5, from initial conditions</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>



<p><b>STEP 5.:</b> 2.4 Cold Leg Accumulators</p> <p><b>NOTE:</b> Operator should use note and determine CLA leakage can be marked N/A. If calculation is performed, result should be 0 GPM since the start and end levels of all accumulators remained constant.</p> <p><b>STANDARD:</b> Operator determines CLA leakage is either not applicable and N/A's the step or records zero.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 6.:</b> 2.5 Other identified leakage</p> <p><b>NOTE:</b> Operator should use note and determine other leakage can be marked N/A or utilize initial condition that states no other leakage.</p> <p><b>STANDARD:</b> Operator determines "other" leakage is either not applicable and N/A's the step or records zero.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 7.:</b> 2.6 Total Identified Leakage</p> <p><b>NOTE:</b> Operator should use initial conditions to determine that the CCPIT/HUT leakage is zero.</p> <p>Total Identified Leakage = PRT + RCDT + SG + CLA + CCPIT/HUT + OTHER  <math>TIL = 0.242 + 0.033 + 0.009 + 0 + 0 + 0 = 0.284</math></p> <p><b>STANDARD:</b> Operator totals the individual contributions to total leakage and determines identified leakage to be 0.284 GPM.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 8.:</b> 3.0 Unidentified leakage</p> <p>Unidentified leakage = Total Leakage – Identified leakage</p> <p><math>UL = 1.425 - 0.284 = 1.141 \text{ gpm}</math></p> <p><b>STANDARD:</b> Operator should subtract identified leakage from step 2.6 from total leakage determined in step 1.5 and find unidentified leakage to be <math>\approx 1.141</math> GPM.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Operator continues with section 6.1.1	
<p><b>STEP 9.:</b> 6.1.1 [1] CALCULATE total RCS leakage, identified leakage...</p> <p>Total RCS Leakage = 1.425 gpm Identified Leakage = 0.242 gpm Unidentified Leakage = 1.141 gpm</p> <p><u>STANDARD:</u> Operator records leakage values determined from Appendix D.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 10.:</b> 6.1.1 [2] If identified leakage is less than zero...</p> <p><u>STANDARD:</u> The operator should mark this step N/A since the leakage is greater than zero.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 11.:</b> 6.1.1 [3] If identified leakage is more negative...</p> <p><u>STANDARD:</u> The operator should mark this step N/A since the leakage is greater than zero.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 12.:</b> 6.1.1 [4] If an identified leakage more positive...</p> <p><u>STANDARD:</u> The operator should mark this step N/A since the leakage is greater than zero.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 13.:</b> 6.1.1 [5] Record maximum leak rate from an individual steam generator...</p> <p><u>STANDARD:</u> The operator should reference Appendix "D" or the initiating cue to determine the maximum steam generator leakage is 4.8 GPD from S/G # 4 and the total leakage is 0.009 GPM</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 14.:</b> 6.1.1 [6] Check appropriate box to indicate whether acceptance criteria were met.....</p> <p><u>Technical Specifications:</u>  Max individual SG leakage                      check Yes  Total Identified                                      check Yes  Total unidentified                                   check <b>NO</b></p> <p><u>Administrative Acceptance</u>  SG leakage <math>\leq</math> 75 GPD                              check Yes</p> <p><u>STANDARD:</u> The operator should check "Yes" for acceptance criteria met for S/G leakage and total identified leakage BUT "No" for unidentified leakage less than 1.0.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 15.:</b> 6.1.1 [7] If any Technical Specification acceptance criteria NOT satisfied.....</p> <p>Notify SM  Refer to REP  Refer to AOP- R.01 or AOP-R.05</p> <p>NOTE to Evaluator: Follow up question to determine procedure transition may be required.</p> <p><u>STANDARD:</u> The operator should address each sub-step.  The SM is notified that TS acceptance criteria were not met based on <b>unidentified</b> leakage greater than <b>1 gpm</b>.</p> <ul style="list-style-type: none"> <li>▪ SM/US is notified</li> <li>▪ Refer to EPIP 1 for the REP implementation</li> <li>▪ Refer AOP-R.05, RCS Leak and Leak Source identification*</li> </ul> <p>(SI also references AOP-R.01, Steam Generator Tube Leak in this step, but RO should recognize that AOP-R.01 is not applicable)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>*Critical Step</b></p>
<p><b>STEP 16.:</b> 6.1.1 [8] If leakage is within Tech Spec limits but exceeds...</p> <p><u>STANDARD:</u> The operator should mark this step N/A since S/G leakage is within all acceptance criteria.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>_____ Stop Time</p>

END OF JPM

## READ TO OPERATOR

### DIRECTIONS TO TRAINEE:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

- Unit-1 is in MODE 1.
- The RCS leakage surveillance required by T.S. 4.4.6.2.1 is due this shift and the ICS computer is not available
- The off going crew initiated performance of 0-SI-OPS-068-137.0, Section 6.1 and Appendix C are complete.  
Appendix D is complete through section 1.4

- SG leakages

SG # 1	SG # 2	SG # 3	SG # 4
3.2 gpd	2.2 gpd	2.3 gpd	4.8 gpd

- SI-50 and SI-137.5 were completed last night at 2300.
- Chemistry supervisor reported no additions or samples taken from the RCS during the selected performance period.
- CLA Levels initial and final are as follows:

CLA	LI	INITIAL	FINAL
1	63-129	7692	7692
2	63-109	7677	7677
3	63-89	7672	7672
4	63-89	7680	7680

- CCPIT/HUT leakage and "other" leakage is 0 gpm
- Do all calculations to three decimal places, or to 1/1000.
- Data collected for performance of this leak rate is documented in Appendix C and was collected over 124 minutes

### INITIATING CUES:

You are the Unit-1 CRO and have been directed to complete the performance of 0-SI-OPS-068-137.0 Appendix "D" and Section 6.1.1 through step 8.

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT

SURVEILLANCE INSTRUCTION

0-SI-OPS-068-137.0

REACTOR COOLANT SYSTEM WATER INVENTORY

Revision 22

QUALITY RELATED

PREPARED/PROOFREAD BY: OLIVIA HEAD

RESPONSIBLE ORGANIZATION: OPERATIONS

APPROVED BY: J. K. WILKES

EFFECTIVE DATE: 04/24/08

LEVEL OF USE: **CONTINUOUS USE**

REVISION

DESCRIPTION: Revised to change the manual calculation formulas for temperature correction and PZR leakage rates per engineering guidelines. A normalized equation will be used with the specific gravity of water at 70 degrees (07001541). Made conservative administrative changes to Post Performance Activity section based on management directive.

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 2 of 61
------------------------------------	---	---

## TABLE OF CONTENTS

Page 1 of 2

<b>Section</b>	<b>Title</b>	<b>Page</b>
<b>1.0</b>	<b>INTRODUCTION .....</b>	<b>4</b>
1.1	Purpose .....	4
1.2	Scope .....	4
	1.2.1 Surveillance Test to be Performed.....	4
	1.2.2 Requirements Fulfilled .....	4
	1.2.3 Modes .....	4
1.3	Frequency and Conditions.....	4
<b>2.0</b>	<b>REFERENCES .....</b>	<b>5</b>
2.1	Performance References .....	5
2.2	Developmental References .....	5
<b>3.0</b>	<b>PRECAUTIONS AND LIMITATIONS .....</b>	<b>6</b>
3.1	Manual Calculations .....	8
3.2	Plant Computer .....	9
<b>4.0</b>	<b>PREREQUISITE ACTIONS .....</b>	<b>11</b>
4.1	Preliminary Actions .....	11
4.2	Measuring and Test Equipment, Parts, and Supplies.....	12
4.3	Field Preparations .....	13
4.4	Approvals and Notifications .....	13
<b>5.0</b>	<b>ACCEPTANCE CRITERIA .....</b>	<b>14</b>
<b>6.0</b>	<b>PERFORMANCE.....</b>	<b>15</b>
6.1	Data Collection for MANUAL calculation method .....	16
	6.1.1 Calculation of RCS Leakage using the MANUAL method.....	21
	6.1.2 Restoration using the MANUAL method .....	26
6.2	RCS Leakage Using the Plant Computer .....	28

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 3 of 61
------------------------------------	---	---

## TABLE OF CONTENTS

Page 2 of 2

Section	Title	Page
<b>7.0</b>	<b>POST PERFORMANCE ACTIVITY .....</b>	<b>39</b>
	APPENDIX A: IDENTIFICATION OF RCS LEAKAGE .....	41
	APPENDIX B: REACTOR COOLANT DRAIN TANK LEAKAGE .....	42
	APPENDIX C: INITIAL/FINAL DATA .....	45
	APPENDIX D: RCS LEAKAGE CALCULATIONS .....	50
	APPENDIX E: PRESSURIZER RELIEF TANK (PRT) LEVEL VS. VOLUME .....	59
	<b>Source Notes .....</b>	<b>61</b>

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 4 of 61
------------------------------------	---	---

## **1.0 INTRODUCTION**

### **1.1 Purpose**

This Instruction provides detailed steps for performing a water inventory balance on the Reactor Coolant System (RCS).

### **1.2 Scope**

#### **1.2.1 Surveillance Test to be Performed**

This SI performs a detailed water inventory balance on the RCS to determine the total identified and unidentified RCS leakage. These values are then compared to applicable sections of Technical Specification (TS) Limiting Condition for Operation (LCO) 3.4.6.2 and to the administrative limits on S/G leakage and unidentified leakage.

#### **1.2.2 Requirements Fulfilled**

- A. Performance of this instruction completely fulfills TS 3.4.6.2 surveillance requirement (SR) 4.4.6.2.1 & 4.4.6.2.2.
- B. Performance of this instruction may be utilized to fulfill TS LCO 3.4.6.1 action a. or 3.4.6.1 action b. on a 24 hour frequency, however is not required until 12 hours after establishment of steady state operation.

#### **1.2.3 Modes**

Plant operating modes for which the surveillance requirements covered by this Instruction must be satisfied (applicable modes) and during which the test can be performed (performance modes) are:

- A. Applicable Modes: 1, 2, 3, and 4
- B. Performance Modes: 1 through 5

### **1.3 Frequency and Conditions**

- A. This SI must be performed at least once every 72 hours, however is not required to be performed until 12 hours after establishment of steady state plant conditions.
- B. This SI may be performed at least once every 24 hours to satisfy LCO 3.4.6.1 action a.
- C. This SI may be performed at least once every 24 hours to satisfy LCO 3.4.6.1 action b. in lieu of performance of SI-183, *Lower Containment Gaseous and Particulate Radioactivity Monitoring During Periods of Radiation Monitor Inoperability*.



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 5 of 61
------------------------------------	---	---

## 2.0 REFERENCES

### 2.1 Performance References

- A. 0-SI-CEM-000-050.0, *72-Hour Chemistry Requirements*.
- B. 1, 2-SI-CEM-068-137.5, *Primary-To-Secondary Leakage Via Steam Generators*

### 2.2 Developmental References

- A. SQN Unit 1 & 2 Technical Specifications.
- B. SI-137.1, *Reactor Coolant System Unidentified Leakage Measurement*.
- C. SQN Final Safety Analysis Report (FSAR), Chapter 5.2.7 and Table 5.1-1.
- D. Westinghouse Calculation No. PDC-76-23, *Pressurizer Level Channel Cross Reference*, G. Richard, November 15, 1976. (Information Sheet from Westinghouse, S. O. No. TVA 320).
- E. Westinghouse Letter TVA-88-533, *Steam Generator Secondary Water Volume*, T. A. Lordi to J. B. Hosmer, February 11, 1988.
- F. TVA Drawings 47W801-2; 47W809-1,2; 47W813-1; and 47W830-1.
- G. Westinghouse Drawing 1099J91.
- H. TI-41.68, *Scaling and Setpoint Document Reactor Coolant System*.
- I. ONP-STD-4.4.7, Attachment 1, *Writer's Guide for Technical Documents*.
- J. Safety Evaluation, Reg Guide 1.121 Eval of SQN 1 S/G Circumferential Defect.
- K. STA Log.
- L. SPP-8.1, *Conduct of Testing*.
- M. Westinghouse Safety Evaluation, SECL-91-431, *Circumferential Oriented Primary Water Stress Corrosion Cracking - WEXTEx Region*.
- N. Integrated Computer System, NSSS Critical Design Review, Chapter 9, RCS Leakage Rate.
- O. TSC 05-09.
- P. WCAP-16423-NP, *Pressurized Water Owners Group Standard Process and Methods for Calculating RCS Leak Rate for Pressurized Water Reactors*.

SQN  1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 6 of 61
------------------	---	---

### 3.0 PRECAUTIONS AND LIMITATIONS

- A. Stability of the RCS during performance of this test is of utmost importance. It is essential that the end points for RCS temperature and pressure be as close as possible to the RCS temperature and pressure values used at the beginning of the test.
- B. Two hours is the minimum test duration. Use of a longer test duration (3, 4 or 6 hours) is preferred, but not required.
- C. The administrative limit for primary-to-secondary leakage to an individual SG is 75 GPD. This reduced limit is due to the circumferential cracking of SG tubes at the tube sheet caused by primary water stress corrosion cracking. The limit is obtained from EPRI PWR Primary-To-Secondary Leak Guidelines.
- D. All attempts to identify RCS leakage in accordance with Appendix A must be completed before proceeding past section 6.1. This is not meant to delay the completion of this test; rather, to identify as many sources of RCS leakage as possible while performing section 6.1.
- E. The Reactor Coolant Drain Tank (RCDT) level data may be marked N/A if conditions do not permit obtaining RCDT level. The leakage into the RCDT in this case will be accounted for as unidentified leakage.
- F. During the performance of this Instruction, it is expected that the unidentified leakage will occasionally be determined to be less than zero (i.e., negative leakage). If negative leakage is calculated to be more negative than  $-0.10$  gpm, then the following sequence of actions are taken: **[C.2]**

  - 1. A minimum of one hour of additional data is collected and all calculations are re-performed (at the discretion of the Test Director, any two-hour block or longer of data may be used provided all PRECAUTIONS AND LIMITATIONS are satisfied). **[C.2]**
  - 2. If the unidentified leakage calculated using the additional data is equal to or more positive than  $-0.10$  GPM, this value may be recorded as an acceptable result. **[C.2]**

SQN  1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 7 of 61
------------------	---	---

### 3.0 PRECAUTIONS AND LIMITATIONS (Continued)

3. If the re-calculated unidentified leakage calculated using the additional data is more negative than  $-0.10$  GPM, the test must be continued until: **[C.2]**
  - a. The calculated value of unidentified leakage is equal to or more positive than  $-0.10$  GPM, or
  - b. The total RCS leakage is less than or equal to  $1.0$  gpm, or
  - c. A condition occurs which causes the test to be aborted (e.g., makeup to the VCT).
4. If an unidentified leakage equal to or more positive than  $-0.10$  GPM can not be obtained but the total RCS leakage is less than or equal to  $1.0$  GPM, the calculated value of unidentified leakage may be recorded as an acceptable result provided an investigation is initiated by Systems Engineering and Operations to determine the source of the negative calculation. If the total RCS leakage is greater than  $1.0$  GPM (coincident with an unidentified leakage more negative than  $-0.1$  GPM), then non-RCS inleakage may be masking the true RCS leakage and the validity of the test is questionable. Under these conditions, the test must be continued until the above described criteria are satisfied or a condition occurs which causes the test to be aborted. **[C.2]**
5. If four consecutive tests result in negative values for unidentified leakage, an investigation into the source of the in-leakage must be initiated regardless of whether or not the above described criteria are satisfied. **[C.2]**

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 8 of 61
------------------------------------	---	---

### 3.0 PRECAUTIONS AND LIMITATIONS (Continued)

#### 3.1 Manual Calculations

- ~~A~~ The final RCS temperature must be within  $\pm 1^{\circ}\text{F}$  of the initial RCS temperature or the final data is VOID and must be retaken.
- ~~B~~ The final core power level must be within  $\pm 2.0\%$  of the initial core power level or the final data is VOID and must be retaken.
- ~~C~~ All pumps, coolers, valve alignments, etc. which could affect RCS leakage results must remain constant for 30 minutes before starting and throughout the performance, unless specified by this Instruction or otherwise directed by the Unit Senior Reactor Operator (SRO).
- ~~D~~ The same instrumentation shall be used when recording initial and final values of RCS parameters. Differences between two instruments monitoring the same parameter could be misinterpreted as RCS leakage.
- ~~E~~ No samples shall be taken from, nor chemical additions made to, the RCS during the performance of this instruction. An exception is RCS Zinc Injection, which is not detectable within the instrumentation and testing parameters.
- ~~F~~ If any of the following events occur during the performance, the data is VOID and the test must be restarted or the system returned to normal.
  - ~~1~~ Emergency boration.
  - ~~2~~ Diversion of letdown to the holdup tanks.
  - ~~3~~ Makeup from any source.
  - ~~4~~ Change in purification demineralizers or filter lineup.
  - ~~5~~ Failure of any instrument channel used to obtain initial readings.
  - ~~6~~ Failure to use data for at least a two (2) hour time period.
  - ~~7~~ VCT level falls below 10% or low VCT level alarm annunciates.
  - ~~8~~ Restarting the primary water pumps if they were stopped before the initial data was collected.

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 9 of 61
------------------------------------	---	---

### 3.0 PRECAUTIONS AND LIMITATIONS (Continued)

#### 3.2 Plant Computer *N/A*

- A. All pumps, coolers, valve alignments, etc. which could affect RCS leakage results remained constant during data collection, except where makeup was accounted for by the plant computer.
- B. Preferably no samples shall be taken from, nor chemical additions made to the RCS. However, the Plant Computer program has provisions for accounting for RCS leakage changes. Any samples or additions should be noted in the Remarks section Data Package Cover Sheet. An exception is RCS Zinc Injection, which is not detectable within the instrumentation and testing parameters.
- C. CVCS and RCS should remain nearly constant (i.e., no diversion of letdown to holdup tanks, no changes in CVCS demineralizer lineup, no changes to filter lineups, and no RCS make-up from any source.
- D. If any of the following events occur, the data is VOID and the test must be restarted or the system returned to normal.
  - 1. Plant Computer becomes inoperable.
  - 2. Emergency boration.
  - 3. Diversion of letdown to the holdup tanks.
  - 4. Makeup from any source that is not accounted for by the Plant Computer program.
  - 5. RCS Dilution
  - 6. Change in purification demineralizers or filter lineup.
  - 7. Failure to use data for at least a two (2) hour time period.
- E. The Plant Computer leakage report shall be attached to the completed SI package to provide documentation in lieu of manually entered data.

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 10 of 61
------------------------------------	---	--

### 3.2 Plant Computer (Continued) *N/A*

- F. The ICS will periodically store data to history for each computer point flagged as an archive point. Depending on the amount of data that is being stored or archived at one time, the computer may take a short period of time to archive the data creating what appears to be a gap in the data. If a selected start or stop time coincides with one of these "archive gaps", one of the following alarm messages may appear during the calculation:

"START TIME IN ARCHIVE GAP. CALCULATION CANCELLED"

"END TIME IN ARCHIVE GAP. CALCULATION CANCELLED".

If either of these messages is received, move the start and/or stop time a few minutes and repeat the calculation.

- G. Performance of any of the following while performing the leakage calculation may result in RCS leak rate uncertainty:

1. RCS Makeup or Dilution (Data will be considered Void.)
2. Changing level in the PRT and / or the RCDT.
3. Removal from service of any of the instruments listed in Section 4.1 Step [2].
4. Procedures or activities that result in Control Rod motion.

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 11 of 61
------------------------------------	---	--

Unit i

Date Today

#### 4.0 PREREQUISITE ACTIONS

##### **NOTE**

Throughout this Instruction where an **IF/THEN** statement exists, the step should be **N/A** if condition does not exist.

#### 4.1 Preliminary Actions

- [1] **ENSURE** Instruction to be used is a copy of the effective version.

- [2] **IF** ICS Points are to be used for leakage determination, **THEN IDENTIFY** ICS Points that are inservice prior to performing leakage calculation:

Computer Points Needed to Perform RCS Water Inventory at 100% Power			
Parameter	Instrument	Computer Point	I/S
Inputs to Total Leakage			
RCS Temperature Correction			
RCL AVG Tav <sub>g</sub> <sup>(1)</sup>		U0484	<input checked="" type="checkbox"/>
Loop 1 Tav <sub>g</sub>	T-68-2	T0400A	<input type="checkbox"/>
Loop 2 Tav <sub>g</sub>	T-68-25	T0420A	<input type="checkbox"/>
Loop 3 Tav <sub>g</sub>	T-68-44	T0440A	<input type="checkbox"/>
Loop 4 Tav <sub>g</sub>	T-68-67	T0460A	<input type="checkbox"/>
Pzr. Pressure 1/2/3/4 Avg <sup>(2)</sup>		U0482	<input type="checkbox"/>
Pzr. Pressure Ch. I	P-68-340	P0480A	<input type="checkbox"/>
Pzr. Pressure Ch. II	P-68-334	P0481A	<input type="checkbox"/>
Pzr. Pressure Ch. III	P-68-323	P0482A	<input type="checkbox"/>
Pzr. Pressure Ch. IV	P-68-322	P0483A	<input type="checkbox"/>
Pressurizer			
Pzr. Level <sup>(3)</sup>		U0483	<input type="checkbox"/>
Pzr. Level Ch. I	L-68-339	L0480A	<input type="checkbox"/>
Pzr. Level Ch. II	L-68-335	L0481A	<input type="checkbox"/>
Pzr. Level Ch. III	L-68-320	L0482A	<input type="checkbox"/>
Volume Control Tank			
VCT Level	L-62-130	L0112A	<input type="checkbox"/>
Inputs to Identified RCS Leakage			
RCDT Level	L-77-1	L2400A	<input type="checkbox"/>
PRT Level	L-68-300	L0485A	<input checked="" type="checkbox"/>

(1) RCL AVG Tav<sub>g</sub> is the average of the four narrow range loop temperatures.

(2) Pzr. Pressure 1/2/3/4 Avg is the average of the four narrow range Pressurizer Pressure Channels.

(3) Pzr. Level is the average of the three Pressurizer Level Channels

Roy

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 12 of 61
------------------------------------	---	--

#### 4.2 Measuring and Test Equipment, Parts, and Supplies

**NOTE** ✓ The tables in this section may be completed during the performance of section 6.1, as necessary.

~~(1)~~ IF any RCS leak sources will be quantified using a stopwatch and container, **THEN**

**RECORD** the following information for all stopwatches and containers to be used.

TVA ID Number		Calibration Due Date
Stopwatch	Container	
N/A		



<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> Rev: 22 Page 13 of 61
-------------------------	---	---

Unit 1

Date Today

**4.2 Measuring and Test Equipment, Parts, and Supplies (Continued)**

**[2]** IF any other special test equipment will be used during the performance of this Instruction, **THEN**

**RECORD** the following information for each additional piece of test equipment to be used.

Test Equipment	Model	Accuracy	TVA ID	Calibration Due Date
N/A				

N/A

**4.3 Field Preparations**

**[1]** **ENSURE** reactor power and RCS average temperature (T-avg) are stable and have varied less than  $\pm 2\%$  and  $\pm 1^\circ\text{F}$ , respectively, during the calculation test interval.

Rox

**4.4 Approvals and Notifications**

**NOTE**

During data collection using the Manual Calculation Method (Sect. 6.1), RCS chemical additions and / or sampling invalidate the data and will require a re-initiation of SI performance. During data collection using the Plant Computer (Sect. 6.2), it is preferred that RCS chemical additions and / or sampling not take place. If chemical additions or samples are required, then volume **MUST** be accounted for, in gallons per minute. RCS dilution is not allowed during either method of data collection.

**[1]** **CONTACT** Chemistry Lab to verify that performance of this SI and limitations imposed on sampling will **NOT** interfere with any sampling required by Technical Specifications or Technical Requirements Manual.

Rox

SQN  1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 14 of 61
------------------	---	--

Unit 1

Date TODAY

## 5.0 ACCEPTANCE CRITERIA

- ☒ A. The Technical Specification acceptance criteria is as follows:
  - ☒ 1. The primary-to-secondary leakage must be less than or equal to 150 GPD through any one steam generator.
  - ☒ 2. The total identified RCS leakage must be less than or equal to 10 GPM.
  - ☒ 3. The total unidentified leakage must be less than or equal to 1 GPM.
- ☒ B. If any of the Technical Specification criteria are **NOT** satisfied, the SM must be notified and action requirement (b) of LCO 3.4.6.2 satisfied.
- ☒ C. The administrative acceptance criteria for total primary-to-secondary leakage is less than or equal to 75 GPD through any one steam generator. AOP-R.01, *Steam Generator Tube Leak*, contains required actions and criteria for plant shutdown.

<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> Rev: 22 Page 15 of 61
-------------------------	---	---

Unit           

Date TODAY

## 6.0 PERFORMANCE

### ✓ NOTE 1

Manipulation of any of the following valves during this test could effect the results of this test.

VALVE	DESCRIPTION
FCV-63-24	CLA fill line isolation valve
FCV-63-71	Check valve test line isolation valve
FCV-63-84	Check valve test line isolation valve
VLV-68-601	Test header isolation valve to HUT

### ✓ NOTE 2

Maintaining the pressurizer pressure control and pressurizer level control systems in the automatic mode during data collection will improve RCS stability.

~~[1]~~ IF using the Plant Computer, THEN  
GO TO Section 6.2.

N/A

~~[2]~~ IF using MANUAL calculations, THEN  
GO TO Section 6.1.

✓

<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> Rev: 22 Page 16 of 61
-------------------------	---	---

Unit 1

Date TODAY

### 6.1 Data Collection for MANUAL calculation method

**[1]** **ENSURE** VCT level is such that makeup is not anticipated for the duration of this test.

Rox

✓ **NOTE 1** The applicable section of 1, 2-SO-77-1 is dependent upon where the RCDT is to be pumped.

✓ **NOTE 2** The following step may be marked N/A if conditions do not permit obtaining RCDT level.

**[2]** **IF** reactor coolant drain tank (RCDT) level is greater than 30% as indicated by 1, 2-LI-77-1, **THEN**

**GO TO** 1, 2-SO-77-1.

**PERFORM** the applicable section, **AND**

**RETURN** to step **[3]** of this section.

N/A

✓ **NOTE** The following step may be marked N/A if conditions do not permit obtaining RCDT level.

**[3]** **PLACE** both RCDT pumps hand switches in the **PULL-TO-LOCK** position:

PUMP	HANDSWITCH	REQUIRED POSITION	INITIALS
A	HS-77-4A	PULL-TO-LOCK	<u>Rox</u>
B	HS-77-6A	PULL-TO-LOCK	<u>Rox</u>

✓ **NOTE** Steam generator primary to secondary leak rates required by section 2.3 of Appendix D may be obtained from the Chemistry Lab at the time the following notification is performed.

**[4]** **NOTIFY** Chemistry Lab of the following:

**[a]** **ENSURE** no chemical additions to, nor take samples from, the RCS until further notice. An exception is RCS Zinc Injection, which is not detectable within the instrumentation and testing parameters.

Rox

**[b]** **ENSURE** 0-SI-CEM-000-050.0 has been performed within the last 72 hours.

Rox

<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 17 of 61
-------------------------	---	--

Unit 1

Date TODAY

### 6.1 Data Collection for MANUAL calculation method (Continued)

**[5]** ENSURE the following system lineup ESTABLISHED:

VALVE	DESCRIPTION	POSITION	INITIALS
FCV-62-118	VCT Isolation Valve	To VCT	Rox
FCV-62-128	Blender Output to VCT	CLOSED	Rox
FCV-62-144	Blender Output to CCPs	CLOSED	Rox
FCV-62-138	Emerg Boration to CCPs	CLOSED	Rox
PCV-68-301	PRT Vent to RCDT	CLOSED	Rox
FCV-68-310	PRT Drain to RCDT	CLOSED	Rox

**NOTE**

Primary water pumps should be shut off only if primary water inleakage is suspected, the last performance of this SI resulted in a negative value for unidentified leakage, or if directed by the Unit SRO.

**[6]** IF primary water pumps will be shut off during data collection, THEN

**[a]** PLACE both primary water pumps hand switches in the PULL-TO-LOCK position:

PUMP	HANDSWITCH	POSITION	INITIALS
A	HS-81-3A	PULL-TO-LOCK	N/A
B	HS-81-7A	PULL-TO-LOCK	↓

**[b]** ENSURE [0-81-519], Primary Water Unit Crosstie Valve is LOCKED CLOSED.

N/A

**[7]** IF RCS conditions are NOT stable and it is desired to do a calculation from the current time, THEN

WAIT approximately 30 minutes to allow RCS parameters to stabilize, AND

RECORD any remarks regarding RCS stability in the chronological test log.

N/A

<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 18 of 61
-------------------------	---	--

Unit \_\_\_\_\_

Date TODAY

### 6.1 Data Collection for MANUAL calculation method (Continued)

✓ **NOTE** The following step may be marked N/A if conditions do not permit obtaining RCDT level.

~~[8]~~ IF pump down of the RCDT is required during the 30-minute waiting period, **THEN**

~~[a]~~ **GO TO** 1, 2-SO-77-1.

N/A

~~[b]~~ **PERFORM** the applicable section, **AND**  
**RETURN** to step [8][c] of this section.

↓

~~[c]~~ **RETURN** both RCDT pumps handswitches to the **PULL-TO-LOCK** position:

PUMP	HANDSWITCH	POSITION	INITIALS
A	HS-77-4A	PULL-TO-LOCK	<u>N/A</u>
B	HS-77-6A	PULL-TO-LOCK	<u>↓</u>

~~[9]~~ IF additional methods will be used to quantify RCS leakage, **THEN**

**INITIATE** performance of Appendix A.

N/A

✓ **NOTE 1** When bench board instruments are used, the first instrument read will initiate the timed duration of this test (minimum of 2 hours).

✓ **NOTE 2** RCS T-avg should be maintained within a  $\pm 1.0^{\circ}\text{F}$  band for at least 5 minutes before data collection is initiated.

~~[10]~~ **RECORD** initial RCS data required by Appendix C. ☒

~~[11]~~ **ENSURE** all readings are taken at approximately the same time. [C.1]

Roy

~~[12]~~ IF pump down(s) of the RCDT (level > 45%) is required before final RCS data is recorded, **THEN**

**COMPLETE** RCDT pump down in accordance with Appendix B before proceeding to step [13].

N/A

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 19 of 61
------------------------------------	---	--

Unit i

Date TODAY

### 6.1 Data Collection for MANUAL calculation method (Continued)

✓ **NOTE 1**

Two hours is the minimum test duration. If desired, the final data may be voided and retaken to lengthen the test. Increasing the length of the test will reduce the adverse impact of variations in RCS temperature and reactor power.

✓ **NOTE 2**

When using bench board instruments, the last instrument read will determine the finish time of the data collection.

✓ **NOTE 3**

RCS T-avg should be maintained within a  $\pm 1.0^{\circ}\text{F}$  band for at least 5 minutes before data collection is initiated.

Ⓢ **[13]**

**WHEN** a minimum of two hours has elapsed since initial data collection, **THEN [C.1]**

**[a] RECORD** final RCS data required by Appendix C.

☒

**[b] ENSURE** all readings are taken at approximately the same time. **[C.1]**

☒

Ⓢ **[14]**

**IF** Appendix A is being used to quantify additional RCS leakage sources, **THEN**

**ENSURE** Appendix A has been completed.

N/A

Ⓢ **[15]**

**WHEN** final data collection has been completed, **THEN**

**CHECK** appropriate boxes to indicate whether initial and final data are acceptable.

Ⓢ **A**

Were final reactor power and RCS temperature within  $\pm 2\%$  and  $\pm 1^{\circ}\text{F}$ , respectively, of their initial readings?

☒ ☐  
YES NO

Ⓢ **B**

Have all pumps, coolers, valve alignments, etc. which could affect RCS leakage results remained constant during data collection (except as specified otherwise by this Instruction or the Unit SRO).

☒ ☐  
YES NO

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 20 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

**6.1 Data Collection for MANUAL calculation method (Continued)**

- ☒ C. Have the CVCS and RCS remained nearly constant (i.e., no VCT makeup, no diversion of letdown to holdup tanks, no changes in CVCS demineralizer lineup, no changes to filter lineups, and either no RCS make-up from any source)? ☒ YES ☐ NO
- ☒ D. Were sampling and chemical additions to the RCS (with the exception of RCS Zinc Injection) stopped during data collection? ☒ YES ☐ NO
- ☒ E. Were the same instruments/points used for recording initial and final data? ☒ YES ☐ NO
- ☒ F. Were initial and final RCDT data taken at the same time as the other data? ☐ N/A ☒ YES ☐ NO
- ☒ G. Was data collection performed over a minimum of two hours? ☒ YES ☐ NO

Roy

☒ [16] IF any box in step [15] is checked "NO", THEN

- [a] **TERMINATE** this test.
- [b] **NOTIFY** the Unit SRO that the test was invalid.
- [c] **NOTE** in Remarks section of chronological test log why test has been aborted.
- [d] **OBTAIN** a working copy of this procedure to restart test **AND**
- MAINTAIN** the working copy in this SI package.

N/A

↓



<b>SQN</b>  1 & 2	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> Rev: 22 Page 21 of 61
-------------------------	---	---

Unit 1

Date TODAY

### 6.1.1 Calculation of RCS Leakage using the MANUAL method

**[1]** **CALCULATE** total RCS leakage, identified leakage and unidentified leakage in accordance with Appendix D, **AND**

**RECORD** below:

- A. Total RCS leakage = \_\_\_\_\_ GPM
- B. Identified leakage = \_\_\_\_\_ GPM
- C. Unidentified leakage = \_\_\_\_\_ GPM \_\_\_\_\_

**NOTE** Copies of Appendices C, or D may be used to perform steps [2] through [9] provided all copies are included in the data package.

**[2]** IF unidentified leakage is less than zero by more than -0.1 gpm (i.e., negative leakage), **THEN [C.2]**

**[a]** **COLLECT** a minimum of one hour of additional data. ☐

**[b]** **RECALCULATE** all RCS leakage terms in accordance with Appendix D. ☐

**[c]** **RECORD** below:

- A. Total RCS leakage = \_\_\_\_\_ GPM
- B. Identified leakage = \_\_\_\_\_ GPM
- C. Unidentified leakage = \_\_\_\_\_ GPM \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 22 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

### 6.1.1 Calculation of RCS Leakage using the MANUAL method (Continued)

#### NOTE

An unidentified leakage more negative than  $-0.10$  GPM may be recorded as an acceptable result provided the total RCS leakage is equal to or less than  $1.0$  GPM and there is an on-going investigation to determine the source of the inleakage. **[C.2]**

**[3] IF** unidentified leakage is more negative than  $-0.10$  GPM,  
**THEN**

**CONTINUE** data collection and calculation of RCS leakage terms in accordance with Appendices C, or D by changing the time interval or performing a new calculation until an unidentified leakage term more positive than  $-0.10$  GPM is obtained or total RCS leakage is equal to or less than  $1.0$  GPM (or until test must be aborted), **AND [C.2]**

**RECORD** results below (N/A any blanks not used).

A. Calculations completed:

-Time \_\_\_\_\_  
 -Total RCS leakage = \_\_\_\_\_ GPM  
 -Identified leakage = \_\_\_\_\_ GPM  
 -Unidentified leakage = \_\_\_\_\_ GPM \_\_\_\_\_

B. Calculations completed:

-Time \_\_\_\_\_  
 -Total RCS leakage = \_\_\_\_\_ GPM  
 -Identified leakage = \_\_\_\_\_ GPM  
 -Unidentified leakage = \_\_\_\_\_ GPM \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 23 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

### 6.1.1 Calculation of RCS Leakage using the MANUAL method (Continued)

C. Calculations completed:

-Time \_\_\_\_\_

-Total RCS leakage = \_\_\_\_\_ GPM

-Identified leakage = \_\_\_\_\_ GPM

-Unidentified leakage = \_\_\_\_\_ GPM \_\_\_\_\_

**[4] IF** an unidentified leakage more positive than -0.10 GPM could not be obtained, **OR**

**IF** four consecutive performances of this Instruction have resulted in a negative value of unidentified leakage, **THEN**

**NOTIFY** Unit SRO and/or cognizant Systems Engineer that an investigation to determine the source of inleakage to the RCS must be initiated. **[C.2]** \_\_\_\_\_

**NOTE** 'Maximum' may be the same as 'Total' if activity/leakage is too low to identify an individual steam generator.

**[5] RECORD** maximum leak rate from an individual steam generator and total leak rate from all four steam generators from section 2.3 of Appendix D.

A. Max. individual SG leakage = \_\_\_\_\_ GPD

B. Total SG leakage = \_\_\_\_\_ GPM \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 24 of 61
------------------------------------	---	--

Unit\_\_\_\_\_

Date\_\_\_\_\_

### 6.1.1 Calculation of RCS Leakage using the MANUAL method (Continued)

- [6] CHECK** appropriate box to indicate whether the following acceptance criteria were satisfied.

#### TECHNICAL SPECIFICATION ACCEPTANCE CRITERIA:

Maximum individual SG leakage is less than or equal to 150 GPD.

☐ Yes  
☐ No

The total identified leakage is less than or equal to 10.0 GPM.

☐ Yes  
☐ No

The total unidentified leakage is less than or equal to 1.0 GPM.

☐ Yes  
☐ No

#### ADMINISTRATIVE ACCEPTANCE CRITERIA:

The maximum individual SG leakage is less than or equal to 75 GPD.

☐ Yes  
☐ No

- [7] IF** any of the Technical Specification acceptance criteria stated in step **[6]** is NOT satisfied, **THEN**

**[a] NOTIFY** SM that RCS leakage exceeds limit and LCO 3.4.6.2 action (b) must be satisfied.

☐

**[b] REFER** to EPIP-1 for REP implementation.

☐

**[c] REFER TO** AOP-R.01, *Steam Generator Tube Leak*, or AOP-R.05, *RCS Leak and Leak Source Identification*, as applicable.

☐

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 25 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

### 6.1.1 Calculation of RCS Leakage using the MANUAL method (Continued)

**[8] IF** leakage is within Tech Spec limits but exceeds administrative acceptance criteria for S/G leakage,  
**THEN**

**[a] NOTIFY** SM that primary-to-secondary leakage exceeds administrative limit. ☐

**[b] REFER TO** AOP-R.01, *Steam Generator Tube Leak*. ☐

**[9] WHEN** all data collection has been completed, **THEN**

**NOTIFY** Chemistry Lab that RCS sampling/chemical additions may be resumed, as necessary. \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 26 of 61
------------------------------------	---	--

Unit\_\_\_\_\_

Date\_\_\_\_\_

### 6.1.2 Restoration using the MANUAL method

- [1] IF** the following RCDT handswitch(es) can be returned to their normal alignment, **THEN**

**PLACE** the applicable handswitch(es) in the required position:

PUMP	HANDSWITCH	POSITION	INITIALS
A	HS-77-4A	P-AUTO	<u>1<sup>st</sup></u> <u>IV</u>
B	HS-77-6A	P-AUTO	<u>1<sup>st</sup></u> <u>IV</u>

- [2] IF** the RCDT pump handswitch(es) cannot be returned to the required position, **THEN**

**NOTIFY** the US and **VERIFY** the position is documented and controlled by an approved configuration control process.

- [3] IF** the Primary Water Pump(s) were stopped for data collection, **AND**

- [a] IF** handswitch(es) are to be returned to the required position, **THEN**

**PLACE** the pump handswitch(es) to the required position in accordance with the applicable SO:

PUMP	HANDSWITCH	POSITION	INITIALS
A	HS-81-3A	START/MAN <input type="checkbox"/> P-AUTO <input type="checkbox"/>	<u>1<sup>st</sup></u> <u>IV</u>
B	HS-81-7A	START/MAN <input type="checkbox"/> P-AUTO <input type="checkbox"/>	<u>1<sup>st</sup></u> <u>IV</u>

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 27 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

### 6.1.2 Restoration using the MANUAL method (Continued)

**[b]** IF handswitch(es) cannot be returned to the required position, **THEN**

**NOTIFY** the US and **VERIFY** the position is documented and controlled by an approved configuration control process. \_\_\_\_\_

**[4]** **ENSURE** the following valves are in their required position:

VALVE	REQUIRED POSITION	FIRST PERSON	INDEPENDENT VERIFICATION
FCV-77-9	A AUTO/OPEN	_____	_____
FCV-77-10	A-P AUTO/OPEN	_____	_____
FCV-62-128	P-AUTO	_____	_____
FCV-62-144	P-AUTO	_____	_____
FCV-62-118	P-AUTO	_____	_____
FCV-62-138	CLOSED	_____	_____
PCV-68-301	CLOSED	_____	_____
FCV-68-310	CLOSED	_____	_____

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 28 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER

**NOTE** VCT level should be in a range between Auto make-up and Auto divert to the HUT before starting the test. Desired range 25 to 60%. Dilution of the RCS will void data collected.

**[1] CHECK** VCT level in desired range:

**[a] IF** VCT level approaching Auto make-up,

**THEN**

**ADJUST** VCT level using 0-SO-62-7 (manual make-up). \_\_\_\_\_

**[b] IF** VCT level approaching divert to HUT,


**THEN**

**DIVERT** letdown flow to the HUT by turning **[HS-62-118A]** to the **DIVERT** position.

**[2] WHEN** VCT level in desired range,

**THEN**

**PLACE** **[HS-62-118A]** in **VCT** position



**NOTE 1** Plant computer uses historical data for calculations. The minimum test duration is two hours. Use of a longer test duration (3, 4 or 6 hours) is preferred, but not required.

**NOTE 2** Stable conditions result in reactor power and RCS average temperature (T-avg) having not varied more than  $\pm 2\%$  and  $\pm 1^\circ\text{F}$ , respectively, and pressurizer, PRT, VCT, and RCDT levels not changing excessively over the calculation period.

**[3] MAINTAIN** plant conditions as stable as possible (minimum of 2 hours).

**N/A**



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 29 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER

**NOTE 1** SG leak rates are obtained by 1, 2-SI-CEM-068-137.5. 0-SI-CEM-000-050.0 is performed every 72 hours and at activity levels which will determine if those leak rates from the last performance of 1, 2-SI-CEM-068-137.5 have increased.

**NOTE 2** Individual steam generator leakage may be **N/A'd** if activity is too low to be separately identified.

**[4] REQUEST** from Chemistry Lab the following:

**[a]** SG 1 Leakage = \_\_\_\_\_ GPD

**[b]** SG 2 Leakage = \_\_\_\_\_ GPD

**[c]** SG 3 Leakage = \_\_\_\_\_ GPD

**[d]** SG 4 Leakage = \_\_\_\_\_ GPD

Total SG leakage = \_\_\_\_\_ GPD = 21/8 GPM  
1440 min/day

Date/Time 0-SI-CEM-000-050.0 performed:

N/A  
Date \_\_\_\_\_ Time \_\_\_\_\_

Date/Time 1, 2-SI-CEM-068-137.5 performed:

5/1  
Date \_\_\_\_\_ Time \_\_\_\_\_

**NOTE** Selected performance period (time interval) is that period chosen by the operator to perform this instruction. Water additions or samples taken from RCS must be converted to gallons per minute.

**[e] DETERMINE** the amount of any chemical additions made to or samples taken from the RCS during the selected performance period, with the exception of RCS Zinc Injection, which is not detectable within the instrumentation and testing parameters.  
(to be recorded in computer as "Other Sources" in gpm):



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 30 of 61.
------------------------------------	---	---

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

- [5] IF** volume from any source (chemical addition, sampling, or make-up) cannot be determined from the selected performance period, **THEN**

**PERFORM** one of the following (N/A other):

- [a] CHANGE** the selected performance period (time interval) so known volume changes can be used **AND REPEAT** the instruction.

**OR**

- [b] PERFORM** Section 6.1, step **[1]** through **[14]**, **THEN**

**GO TO** to step **[6]**.

- [6] IF** pump down of the RCDT is a frequent occurrence, **THEN**

**PERFORM** one of the following (N/A other):

- [a] WAIT** for computer to build a file history (greater than 2 hours) after the RCDT is initially pumped down **AND REPEAT** the instruction.

**OR**

- [b] COMPLETE** RCDT pump down in accordance with Appendix B.

- [7] IF** in-leakage to the CLA, **THEN**

- [a] RECORD** initial CLA levels in Appendix C and wait at least 2 hours.

- [b] WHEN** greater than 2 hours has elapsed, **THEN**

**RECORD** final CLA levels in Appendix C.

N/A



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 31 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**NOTE 1** Plant Computer cannot look ahead and determine leakage rates. All leakage rates must be determined from past points.

**NOTE 2** The ICS will periodically store data to history for each computer point flagged as an archive point. Depending on the amount of data that is being stored or archived at one time, the computer may take a short period of time to archive the data creating what appears to be a gap in the data. If a selected start or stop time coincides with one of these "archive gaps", one of the following alarm messages may appear during the calculation:


"START TIME IN ARCHIVE GAP. CALCULATION CANCELLED"

"END TIME IN ARCHIVE GAP. CALCULATION CANCELLED".

If either of these messages is received, move the start and/or stop time a few minutes and repeat the calculation.

**[8] INITIATE RCS Leakage Program using the Plant Computer**  
by performing the following:

- [a] SELECT** NSSS & BOP menu on monitor.
- [b] SELECT** SI-137.0, RCS leakage screen on monitor.
- [c] ENSURE** correct START date and time entered in Plant Computer.
- [d] ENSURE** correct STOP date and time entered in Plant Computer.



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 32 of 61
------------------------------------	---	--

Unit\_\_\_\_\_

Date\_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**NOTE** If data is to be manually inserted into the computer, then the start/stop times to be entered into the computer must encompass the time interval the data was taken.

**[9] MANUALLY** enter the following:

**[a]** SG leakages from Chemistry.

**NOTE** CLA leakage calculations may be marked **N/A** if the RCS pressure is greater than 683 psig and quantification of the CLA leakage is not required.

**[b]** CLA initial and final volumes from Appendix C (if required).

**[c]** CCPIT/HUT leakage (N/A if not required).

**[d]** Other sources, such as Appendix B or Chemistry sampling (N/A if not required).

**[10] INITIATE** execute for calculation results.

*Handwritten marks:*  
A vertical line with checkmarks and boxes on the right margin.  
Top: A checkmark and the letters "NA".  
Middle: Three empty square boxes.  
Bottom: A checkmark and an empty square box.

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 33 of 61
------------------------------------	---	--

Unit\_\_\_\_\_

Date\_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**[11] WHEN** data collection has been completed, **THEN**

**CHECK** the following to indicate whether data is acceptable:

- A. **VERIFY** dates and times entered for the leak rate performance period are correct and data collection performed over a minimum of two hours.
- B. **VERIFY** all sampling and chemical additions to the RCS were stopped during data collection or have been accounted for. (with the exception of RCS Zinc Injection).
- C. **VERIFY** all pumps, coolers, valve alignments, etc. which could affect RCS leakage results remained constant during data collection, except where makeup was accounted for by the plant computer.
- D. **VERIFY** the CVCS and RCS remained nearly constant (i.e., no diversion of letdown to holdup tanks, no changes in CVCS demineralizer lineup, no changes to filter lineups, and no RCS make-up from any source, except where makeup was accounted for by the plant computer.
- E. **VERIFY NO** RCS dilution occurred during data taking period.

N/A

---



---



---



---



---



---

↓

STEP CONTINUED ON NEXT PAGE

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 34 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

E. **RECORD** the ICS Points that were available during performance of leakage calculation:

Computer Points Needed to Perform RCS Water Inventory at 100% Power			
Parameter	Instrument	Computer Point	√
Inputs to Total Leakage			
RCS Temperature Correction			
RCL AVG Tav <sub>g</sub> <sup>(1)</sup>		U0484	<input checked="" type="checkbox"/>
Loop 1 Tav <sub>g</sub>	T-68-2	T0400A	<input type="checkbox"/>
Loop 2 Tav <sub>g</sub>	T-68-25	T0420A	<input type="checkbox"/>
Loop 3 Tav <sub>g</sub>	T-68-44	T0440A	<input type="checkbox"/>
Loop 4 Tav <sub>g</sub>	T-68-67	T0460A	<input type="checkbox"/>
Pzr. Pressure 1/2/3/4 Avg <sup>(2)</sup>		U0482	<input type="checkbox"/>
Pzr. Pressure Ch. I	P-68-340	P0480A	<input type="checkbox"/>
Pzr. Pressure Ch. II	P-68-334	P0481A	<input type="checkbox"/>
Pzr. Pressure Ch. III	P-68-323	P0482A	<input type="checkbox"/>
Pzr. Pressure Ch. IV	P-68-322	P0483A	<input type="checkbox"/>
Pressurizer			
Pzr. Level <sup>(3)</sup>		U0483	<input type="checkbox"/>
Pzr. Level Ch. I	L-68-339	L0480A	<input type="checkbox"/>
Pzr. Level Ch. II	L-68-335	L0481A	<input type="checkbox"/>
Pzr. Level Ch. III	L-68-320	L0482A	<input type="checkbox"/>
Volume Control Tank			
VCT Level	L-62-130	L0112A	<input type="checkbox"/>
Inputs to Identified RCS Leakage			
RCDT Level	L-77-1	L2400A	<input type="checkbox"/>
PRT Level	L-68-300	L0485A	<input checked="" type="checkbox"/>

(1) RCL AVG Tav<sub>g</sub> is the average of the four narrow range loop temperatures.

(2) Pzr. Pressure 1/2/3/4 Avg is the average of the four narrow range Pressurizer Pressure Channels.

(3) Pzr. Level is the average of the three Pressurizer Level Channels

F. **IF** ICS Points recorded in Section 4.1 [2] do NOT match those recorded in Section 6.2 Step [11] E, **THEN**

**ENSURE** evaluation of the validity of the data is performed by engineering.

N/A

N/A

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 35 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**[12] IF any substep in step [11] cannot be completed, THEN**

**[a] TERMINATE** this test.

**[b] NOTIFY** the Unit SRO that the test was invalid.

**[c] NOTE** in chronological test log why test has been aborted.

**[d] OBTAIN** a working copy of this procedure to restart test **AND**

**MAINTAIN** the working copy in this SI package.

**[e] ENSURE [HS-62-118A]** in P-AUTO.

N/A

---



---



---



---



---



---

1<sup>st</sup> IV

**[13] IF calculation inputs are invalid, THEN**

**[a] INITIATE MANUAL** function to correct inputs.

**[b] INITIATE** execute function for calculated results.

**[14] PRINT** a hard copy of the results.

**[15] ATTACH** hard copy program output (printout) to surveillance procedure package.

**[16] WHEN** all data collection has been completed, **THEN**

**NOTIFY** Chemistry Lab that RCS sampling/chemical additions may be resumed, as necessary.

**[17] IF Sect. 6.2 Step [5][b]** was performed for manual data collection, **THEN**

**PERFORM** section 6.1.2 for restoration of equipment.

☐

☐

☐

☐

☐

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 36 of 61
------------------------------------	---	--

Unit\_\_\_\_\_

Date\_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**NOTE 1** Due to the calculation methodology of rounding off numbers, Unidentified Leakage and Identified Leakage may not add up to computer generated total RCS leakage when leakage is small.

**NOTE 2** An unidentified leakage more negative than  $-0.10$  GPM may be recorded as an acceptable result provided the total RCS leakage is equal to or less than  $1.0$  GPM and there is an on-going investigation to determine the source of the inleakage. **[C.2]**

**[18] IF** unidentified leakage is more negative than  $-0.10$  GPM,  
**THEN**

**REPEAT** data collection by changing and/or lengthening the time interval until an unidentified leakage term more positive than  $-0.10$  GPM is obtained or total RCS leakage is equal to or less than  $1.0$  GPM (or until test must be aborted), **AND [C.2]**

**RECORD** results below (N/A any blanks not used).

A. Calculations completed:

-Time Interval N/A  
 -Total RCS leakage = \_\_\_\_\_ GPM  
 -Identified leakage = \_\_\_\_\_ GPM  
 -Unidentified leakage = \_\_\_\_\_ GPM

B. Calculations completed:

-Time Interval \_\_\_\_\_  
 -Total RCS leakage = \_\_\_\_\_ GPM  
 -Identified leakage = \_\_\_\_\_ GPM  
 -Unidentified leakage = ✓ \_\_\_\_\_ GPM



<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 37 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**[19] IF** an unidentified leakage more positive than  $-0.10$  GPM could not be obtained, **OR**

**IF** four consecutive performances of this Instruction have resulted in a negative value of unidentified leakage,  
**THEN**

**NOTIFY** Unit SRO and/or cognizant Systems Engineer that an investigation to determine the source of inleakage to the RCS must be initiated. **[C.2]**

N/A

**[20] CHECK** appropriate box to indicate whether the following acceptance criteria were satisfied.

### TECHNICAL SPECIFICATION ACCEPTANCE CRITERIA:

The maximum individual SG leakage is less than or equal to 150 GPD.

☐ Yes  
☐ No

The total identified leakage is less than or equal to 10.0 GPM.

☐ Yes  
☐ No

The total unidentified leakage is less than or equal to 1.0 GPM.

☐ Yes  
☐ No

### ADMINISTRATIVE ACCEPTANCE CRITERIA:

The maximum individual SG leakage is less than or equal to 75 GPD.

☒ Yes  
☒ No

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 38 of 61
------------------------------------	---	--

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 6.2 RCS LEAKAGE USING THE PLANT COMPUTER (Continued)

**[21] IF** any of the Technical Specification acceptance criteria stated in step **[20]** is NOT satisfied,  
**THEN**


- [a] NOTIFY** SM that RCS leakage exceeds limit and LCO 3.4.6.2 action b must be satisfied.
- [b] REFER** to EPIP-1 for REP implementation.
- [c] REFER TO** AOP-R.01, *Steam Generator Tube Leak*, or AOP-R.05, *RCS Leak and Leak Source Identification*, as applicable.

**[22] IF** leakage is within Tech Spec limits but exceeds administrative acceptance criteria for S/G leakage,  
**THEN**

- [a] NOTIFY** SM that primary-to-secondary leakage exceeds administrative limit.
- [b] REFER TO** AOP-R.01, *Steam Generator Tube Leak*.

**[23] WHEN** leakage test is complete, **THEN**

**ENSURE** **[HS-62-118A]** in P-AUTO.



**END OF TEXT**

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 39 of 61
------------------------------------	---	--

Unit 1

Date TODAY

## 7.0 POST PERFORMANCE ACTIVITY

[1] **NOTIFY** Unit SRO that test has been completed. \_\_\_\_\_

**NOTE**                      Graphs of RCS leakage trends are available on  
S:\Engineering\System\Systems Notebook\068 - Reactor Coolant  
System\Trending\SI-137\Current data.

[2] **EVALUATE** unidentified leakage results:

[a]    **COMPARE** unidentified leakage result to value  
from previous (last) performance on this unit. ☐

[b]    **COMPARE** unidentified leakage result to leakage  
trend graph maintained by Engineering. ☐

[3] **IF** any of the following conditions are met:

- RCS unidentified leakage exceeds 0.10 gpm
- OR**
- RCS unidentified leakage has risen by more than 0.03 gpm  
from last performance
- OR**
- RCS unidentified leakage shows a sustained rising trend  
above previous baseline (typical) value

**THEN**

**PERFORM** the following:

[a]    **PERFORM** an additional official leak rate calculation  
to validate results (using different time interval). \_\_\_\_\_

(step continued on next page)

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 40 of 61
------------------------------------	---	--

Unit 1

Date TODAY

## 7.0 POST PERFORMANCE ACTIVITY

**[b] IF** rise in leak rate is confirmed by additional calculation(s),  
**THEN**  
**PERFORM** the following:

1. **EVALUATE** recent activities to determine possible causes of rise in leak rate. ☐
2. **INITIATE** RCS leak search:
  - **REFER TO** AOP-R.05, *RCS Leak and Leak Source Identification*. ☐
  - **REQUEST** assistance from Systems Engineering as required. ☐
3. **INITIATE** performance of this SI at least shiftly to monitor leakage trend UNTIL SM determines leak rate is stable (NOT rising). ☐
4. **ENSURE** PER initiated. ☐

**[c] IF** rise in leak rate is NOT confirmed by additional calculation(s),  
**THEN**  
**LOG** results in narrative log. ☐

**[d] INITIATE** performance of OPDP-9 Emergent Issues. \_\_\_\_\_

**END OF TEXT**

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 41 of 61
------------------------------------	---	--

## APPENDIX A

Page 1 of 1

Unit \_\_\_\_\_

Date \_\_\_\_\_

### IDENTIFICATION OF RCS LEAKAGE

- NOTE 1** Any attempts to isolate RCS leakage before completing the appropriate section of this Instruction will make the initial and final data VOID.
- NOTE 2** An acceptable method for calculating leakage is to collect leakage in a container of known volume and time the fill with a stopwatch. Leakage calculated in the following step must be a positive number or zero.
- NOTE 3** All test equipment used in the following step must be listed in section 4.2.

- [1] MEASURE and RECORD** any other RCS leakage, source of the leakage, and method used to calculate leakage below (N/A any blanks not used).

LEAKAGE SOURCE	METHOD USED	APPLICABLE DATA	LEAK RATE (GPM)
N/A			

- [2] SUM** all leak rates identified in step [1], AND

**RECORD** below:

Total leak rate = \_\_\_\_\_ GPM

N/A

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 42 of 61
------------------------------------	---	--

# APPENDIX B

Page 1 of 3

Date TO DAY

Unit i

## REACTOR COOLANT DRAIN TANK LEAKAGE

**NOTE** The following steps provide instructions for pumping down the RCDT after the initial RCDT pump down has been completed. These instructions may be performed as many times as necessary or marked **N/A** if they are not required.

[1] **ENSURE** initial time and RCDT level/volume from Appendix C have been recorded on Data Sheet B-1.

[2] **WHEN** RCDT approaches 50% level, **THEN**

**RECORD** final time and RCDT level on Data Sheet B-1.

**NOTE** The applicable section of 1,2-SO-77-1 is dependent upon where the RCDT is to be pumped.

[3] **GO TO** 1,2-SO-77-1

**PERFORM** the applicable section, **AND**

**RETURN** to step [4] of this appendix.

[4] **RETURN** both RCDT pumps handswitches to the **PULL-TO-LOCK** position:

PUMP	HANDSWITCH	POSITION	INITIALS
A	HS-77-4A	PULL-TO-LOCK	
B	HS-77-6A	PULL-TO-LOCK	

[5] **RECORD** new initial time and RCDT level on Data Sheet B-1.

N/A

✓

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> <b>Page 43 of 61</b>
------------------------------------	---	---

**APPENDIX B**

Page 2 of 3

 Date TODAY

 Unit           

- [6] CONVERT** initial and final RCDT levels to gallons using Table E-2 of Appendix E, **AND**

**RECORD** on Data Sheet B-1.

- [7] CALCULATE** RCDT leakage using the following equation, **AND**

$$\text{RCDT Leak Rate} = \frac{(\text{Initial Volume Gal}) - (\text{Final Volume Gal})}{(\text{min.}) \Delta \text{Time}}$$

**RECORD** on Data Sheet B-1.

- [8] WHEN** final RCS leakage data has been collected, **THEN**

**CALCULATE** total of all calculated RCDT leakages, **AND**

**RECORD** on Data Sheet B-1.

- [9] CALCULATE** average RCDT leakage using the following equation, **AND**

$$\text{Avg. RCDT Leak Rate} = \frac{(\text{Total of All Calculated Leakage GPM})}{(\text{Number of Data Points Taken})}$$

**RECORD** on Data Sheet B-1.

N/A  
 □  
 □  
 □

<b>SQN</b> <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 44 of 61
--------------------------------	---	--

**APPENDIX B**

Page 3 of 3

Date TODAY

Unit 1

**DATA SHEET B-1**

Data Points Taken	Initial Time	Initial Level (%)	Initial Volume (Gal)	Final Time	Final Level (%)	Final Volume (Gal)	Calculated Leak Rate (GPM)
1	N/A						
2							
3							
4							
5							
6							
7							
8							
9							
10							
TOTAL OF ALL CALCULATED RCDT LEAK RATES							

Average RCDT leak rate = \_\_\_\_\_ GPM

Data Recorded By 1  
Date \_\_\_\_\_

Date Reviewed By 1  
Date \_\_\_\_\_



SQN 1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 45 of 61
--------------	---	--

# APPENDIX C

Page 1 of 5

Date TODAY

Unit i

## INITIAL/FINAL DATA

**NOTE 1** N/A steps in this Appendix, except for 8.0 (if applicable) if the Plant Computer RCS Leakage program is being used.

**NOTE 2** Copies of this Appendix may be used if more than one data set is required provided all copies are included in the data package.

Initials Data Start Time: 0438 / TODAY  
Date

### 1.0 VOLUME CONTROL TANK (VCT) LEVEL

Instrument Used: L0112MA ☐ LI-62-129 ☒  
(Check One)  
48.1 % 38.7 %  
Initial Level Final Level

### 2.0 PRESSURIZER (PZR) LEVEL

Instrument Used: U0483MA ☐ LI-68-320 ☒  
(Check One) LI-68-335A ☐ LI-68-339A ☐  
60.3 % 60.2 %  
Initial Level Final Level

### 3.0 PRESSURIZER PRESSURE

Instrument Used: P > 1700 psig U0482MA ☐ PR-68-340 ☒  
(Check One) PI-68-334 ☐ PI-68-342A ☐  
P < 1700 psig P0499MA ☐ PI-68-342A ☐ PI-68-66 ☐  
2237 psig 2234 psig  
Initial Press Final Press

Initial Data Recorded By: Roy / TODAY  
Date  
Final Data Recorded By: Roy / TODAY  
Date

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 46 of 61
------------------------------------	---	--

**APPENDIX C**

Page 2 of 5

Unit 1

Date TODAY

**4.0 RCS TEMPERATURE (T-AVG)**

Instrument Used: T > 530 °F  
(Check One)

U0484MA ☐

TI-68-2E ☒

T < 530 °F

U0486MA ☐

TR-68-1 ☐

U0489MA ☐

576.9 °F  
Initial Level

577.1 °F  
Final Temp

**5.0 REACTOR POWER**

Instrument Used: U1127 Percent Rated Core Thermal Power  
(Check One)

☐

XI-92-5005C Power Range NIS

☒

XI-92-5006C Power Range NIS

☐

U0485 Average Delta T (use when reactor power  
less than 15% OR less than 40% with LEFM  
unavailable)

☐

100.1 %  
Initial Pwr

99.9%  
Final Pwr

Initial Data Recorded By: Rox / TODAY  
Date

Final Data Recorded By: Ray / TODAY  
Date

SQN 1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 47 of 61
--------------	---	--

# APPENDIX C

Page 3 of 5

Date TODAY

Unit 1

## 6.0 PRESSURIZER RELIEF TANK (PRT) LEVEL

### NOTE

Five PRT level readings should be taken approximately one minute apart. Table E-1 of App. E is used to convert PRT level (%) to gallons.

Instrument Used:  
(Check One)

L0485MA ☐

LI-68-300 ☒

Initial Level: (1) 62 % (2) 62 % (3) 63 % (4) 62 % (5) 62 %

62.2 %  
Avg Level

8592 gal  
Avg Volume

Final Level: (1) 62 % (2) 63 % (3) 62 % (4) 63 % (5) 62 %

62.4 %  
Avg Level

8622 gal  
Avg Volume

## 7.0 REACTOR COOLANT DRAIN TANK (RCDT) LEVEL

### NOTE 1

RCDT Level (7.0) may be marked N/A if conditions do not permit obtaining RCDT level.

### NOTE 2

Final RCDT data may be marked N/A if App. C will be used to calculate average RCDT leakage; however, initial data must be recorded. Table E-2 of Appendix E is used to convert RCDT level (%) to gallons.

Instrument Used:

L2400MA ☐

LI-77-1 ☒

23.5 %  
Initial Level

24.7 %  
Final Level

81.3 gal  
Initial Volume

85.4 gal  
Final Volume

Initial Data Recorded By: Roy 1 TODAY  
Date

Final Data Recorded By: Roy 1 TODAY  
Date

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 48 of 61
------------------------------------	---	--

**APPENDIX C**

Page 4 of 5

 Date TODAY

 Unit 1
**8.0 COLD LEG ACCUMULATOR (CLA) LEVEL**

**NOTE** CLA data may be marked N/A if RCS pressure is greater than 683 psig and quantification of CLA leakage is not required.

**8.1 CLA 1**

 Instrument Used:  
(Check One)

N/A LI-63-129 ☐ LI-63-119 ☐  
 Initial Volume gal Final Volume gal

**8.2 CLA 2**

 Instrument Used:  
(Check One)

LI-63-109 ☐ LI-63-99 ☐  
 Initial Volume gal Final Volume gal

**8.3 CLA 3**

 Instrument Used:  
(Check One)

LI-63-89 ☐ LI-63-81 ☐  
 Initial Volume gal Final Volume gal

 Initial Data Recorded By: \_\_\_\_\_ / \_\_\_\_\_  
Date

 Final Data Recorded By: \_\_\_\_\_ / \_\_\_\_\_  
Date



SQN 1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 50 of 61
--------------	---	--

## APPENDIX D

Page 1 of 9

Date TODAY

Unit 1

### RCS LEAKAGE CALCULATIONS

- NOTE 1** All calculations must be performed manually. Verification may be performed using the computer.
- NOTE 2** All calculations should be carried out to two places after the decimal. Signs must be carried through all calculations.
- NOTE 3** Calculations in this Appendix may need to be performed more than once. If multiple calculations are required, copies of this Appendix may be used.

#### 1.0 TOTAL RCS LEAKAGE

##### (1.1) Volume Control Tank (VCT)

$$\text{VCT Leakage} = \frac{[(\frac{48.1}{\text{Initial Level}} \%) - (\frac{38.7}{\text{Final Level}} \%) ] \times 19.27 \text{ gal/\%}}{\Delta \text{ Time}}$$

$$\text{VCT Leakage} = \frac{124 \text{ min.}}{1.461} \text{ GPM}$$

##### 1.2 Pressurizer (PZR)– UNIT 2 only

N/A

(11) **CALCULATE** initial PZR volume by using the following equation:

**NOTE 1**  $V_f$  (specific volume of a fluid) and  $V_g$  (specific volume of a gas) values for current plant conditions can be found using a copy of the steam tables.

**NOTE 2** In the following equation the multiplier is the Pressurizer Volumetric Constant determined by engineering.

$$\text{Initial PZR Vol} = \left( \frac{\text{PZRLevel}}{V_f} + \frac{100\% - \text{PZRLevel}}{V_g} \right) * 2.02 \text{ gal} * \frac{\text{ft}^3}{\text{lb}_m} * \% \text{level}$$

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 51 of 61
------------------------------------	---	--

**APPENDIX D**

Page 2 of 9

 Date TODAY

 Unit 1

$$\text{Initial PZR Vol} = \left( \frac{\text{NIA} \frac{\%}{\text{ft}^3/\text{lb}_m} + \frac{100 - \%}{\text{ft}^3/\text{lb}_m}} \right) * 2.02 \frac{\text{gal} * \text{ft}^3}{\text{lb}_m * \% \text{level}}$$

Initial PZR Vol = \_\_\_\_\_ gal

Performed By \_\_\_\_\_

Reviewed By \_\_\_\_\_

**(2) CALCULATE** Final PZR volume by using the following equation:

**NOTE 1**

$V_f$  (specific volume of a fluid) and  $V_g$  (specific volume of a gas) values for current plant conditions can be found using a copy of the steam tables.

**NOTE 2**

In the following equation the multiplier is the Pressurizer Volumetric Constant determined by engineering.

$$\text{Final PZR Vol} = \left( \frac{\text{PZRLevel}}{V_f} + \frac{100\% - \text{PZRLevel}}{V_g} \right) * 2.02 \frac{\text{gal} * \text{ft}^3}{\text{lb}_m * \% \text{level}}$$

$$\text{Final PZR Vol} = \left( \frac{\%}{\text{ft}^3/\text{lb}_m} + \frac{100 - \%}{\text{ft}^3/\text{lb}_m} \right) * 2.02 \frac{\text{gal} * \text{ft}^3}{\text{lb}_m * \% \text{level}}$$

Final PZR Vol = \_\_\_\_\_ gal

Performed By \_\_\_\_\_

Reviewed By \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 52 of 61
------------------------------------	---	--

# APPENDIX D

Page 3 of 9

Unit 1

Date TODAY

**3** CALCULATE PZR leakage rate by using the following equation:

$$\text{PZR Leakage} = \frac{\text{Initial PZR Volume} - \text{Final PZR Volume}}{\Delta \text{time}}$$

$$\text{PZR Leakage} = \frac{\text{N/A gal} - \text{gal}}{\text{min}}$$

$$\text{PZR Leakage} = \text{gpm}$$

Performed By

Reviewed By

## 1.3 Pressurizer (PZR)– UNIT 1 only

**4** CALCULATE initial PZR volume using the following equation:

**NOTE 1**  $V_f$  (specific volume of a fluid) and  $V_g$  (specific volume of a gas) values for current plant conditions can be found using a copy of the steam tables.

**NOTE 2** In the following equation the multiplier is the Pressurizer Volumetric Constant determined by engineering.

$$\text{Initial PZR Vol} = \left( \frac{\text{PZRLevel}}{V_f} + \frac{100\% - \text{PZRLevel}}{V_g} \right) * 2.01 \text{ gal} * \text{ft}^3 / \text{lb}_m * \% \text{level}$$

$$\text{Initial PZR Vol} = \left( \frac{60.3 \%}{0.02697 \text{ ft}^3 / \text{lb}_m} + \frac{100 - 60.3\%}{0.1568 \text{ ft}^3 / \text{lb}_m} \right) * 2.01 \text{ gal} * \text{ft}^3 / \text{lb}_m * \% \text{level}$$

$$\text{Initial PZR Vol} = \underline{5002.9} \text{ gal}$$

Performed By

Reviewed By



SQN 1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 53 of 61
--------------	---	--

# APPENDIX D

Page 4 of 9

Date TODAY

Unit 1

**[2] CALCULATE** Final PZR volume using the following equation:

## NOTE 1

$V_f$  (specific volume of a fluid) and  $V_g$  (specific volume of a gas) values for current plant conditions can be found using a copy of the steam tables.

## NOTE 2

In the following equation the multiplier is the Pressurizer Volumetric Constant determined by engineering.

$$\text{Final PZR Vol} = \left( \frac{\text{PZRLevel}}{V_f} + \frac{100\% - \text{PZRLevel}}{V_g} \right) * 2.01 \text{ gal} * \text{ft}^3 / \text{lb}_m * \% \text{level}$$

$$\text{Final PZR Vol} = \left( \frac{60.2 \%}{0.02695 \text{ ft}^3 / \text{lb}_m} + \frac{100 - 60.2 \%}{0.1571 \text{ ft}^3 / \text{lb}_m} \right) * 2.01 \text{ gal} * \text{ft}^3 / \text{lb}_m * \% \text{level}$$

$$\text{Final PZR Vol} = \underline{4999.1} \text{ gal}$$

Rox

Performed By

Rox

Reviewed By

**[3] CALCULATE** PZR leakage rate using the following equation:

$$\text{PZR Leakage} = \frac{\text{Initial PZR Volume} - \text{Final PZR Volume}}{\Delta \text{time}}$$

$$\text{PZR Leakage} = \frac{5002.9 \text{ gal} - 4999.1 \text{ gal}}{124 \text{ min}}$$

$$\text{PZR Leakage} = \underline{0.0306} \text{ gpm}$$

Rox

Performed By

Rox

Reviewed By

SQN 1 & 2	REACTOR COOLANT SYSTEM WATER INVENTORY	0-SI-OPS-068-137.0 Rev: 22 Page 54 of 61
--------------	---	--

# APPENDIX D

Page 5 of 9

Unit 1

Date TODAY

## 1.4 RCS Temperature Correction[C.1]

### NOTE

The multiplier used in the following equation is the RCS Temperature Correction Volumetric constant as determined by engineering.

#### A Initial Conditions:

$$\text{RCS pressure} = \underline{2237} \text{ psig} + 14.7 = \underline{2251.7} \text{ psia}$$

$$\text{RCS temperature} = \underline{576.9} \text{ }^{\circ}\text{F}$$

$$\text{Specific volume (v}_i\text{)} = \underline{0.3090} \text{ ft}^3/\text{lbm}$$

$$\text{Density} = 1/v_i = \underline{3.2362} \text{ lbm/ft}^3$$

#### B Final Conditions:

$$\text{RCS pressure} = \underline{2234} \text{ psig} + 14.7 = \underline{2248.7} \text{ psia}$$

$$\text{RCS temperature} = \underline{577.1} \text{ }^{\circ}\text{F}$$

$$\text{Specific volume (v}_i\text{)} = \underline{0.3084} \text{ ft}^3/\text{lbm}$$

$$\text{Density} = 1/v_i = \underline{3.2425} \text{ lbm/ft}^3$$

#### C Temperature Correction:

$$[(\underline{3.2362} \text{ lbm/ft}^3) - (\underline{3.2425} \text{ lbm/ft}^3)] * 1298.19 \text{ gal*ft}^3/\text{lb}_m$$

$$\text{Temp Corr.} = \frac{\text{Initial Density} - \text{Final Density}}{\text{time}}$$

$$\text{Temperature Correction} = \underline{-0.0660} \text{ GPM}$$

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 55 of 61
------------------------------------	---	--

## APPENDIX D

Page 6 of 9

Date TODAY

Unit 1

### 1.5 Total RCS Leakage

$$\text{Total RCS Leakage} = \left( \frac{\quad}{\text{VCT}} \right) + \left( \frac{\quad}{\text{PZR}} \right) + \left( \frac{\quad}{\text{Temp Corr}} \right)$$

$$\text{Total RCS Leakage} = \quad \text{GPM}$$

Performed By \_\_\_\_\_

Reviewed By \_\_\_\_\_

## 2.0 IDENTIFIED LEAKAGE

**NOTE** Leakage into the PRT or CLA tanks will always be a positive value (or zero) when RCS pressure is greater than the specific tank's pressure. If negative leakage is calculated under these conditions, that tank's leakage must be set equal to zero.

### 2.1 Pressurizer Relief Tank (PRT)

$$\text{PRT Leakage} = \frac{\left[ \left( \frac{\quad \text{gal}}{\text{Final Volume}} \right) - \left( \frac{\quad \text{gal}}{\text{Initial Volume}} \right) \right]}{\left( \frac{\quad \text{min}}{\Delta \text{ Time}} \right)}$$

$$\text{PRT Leakage} = \quad \text{GPM}$$

**NOTE** RCDT Level (2.2) may be marked N/A if conditions do not permit obtaining RCDT level.

### 2.2 Reactor Coolant Drain Tank (RCDT)

$$\text{RCDT Leakage} = \frac{\left[ \left( \frac{\quad \text{gal}}{\text{Final Volume}} \right) - \left( \frac{\quad \text{gal}}{\text{Initial Volume}} \right) \right]}{\left( \frac{\quad \text{min}}{\Delta \text{ Time}} \right)}$$

$$\text{RCDT Leakage} = \quad \text{GPM}$$

Performed By \_\_\_\_\_

Reviewed By \_\_\_\_\_

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 56 of 61
------------------------------------	---	--

# APPENDIX D

Page 7 of 9

Date \_\_\_\_\_

Unit \_\_\_\_\_

## 2.3 Steam Generator (SG)

**NOTE 1** SG leak rates are obtained by 1, 2-SI-CEM-068-137.5.  
0-SI-CEM-000-050.0 is performed every 72 hours and looks at activity levels which will determine if those leak rates from the last performance of 1, 2-SI-CEM-068-137.5 have increased.

**NOTE 2** Individual steam generator leakage may be N/A'd if activity is too low to be separately identified.

A. SG1 Leakage = \_\_\_\_\_ GPD

B. SG2 Leakage = \_\_\_\_\_ GPD

C. SG3 Leakage = \_\_\_\_\_ GPD

D. SG4 Leakage = \_\_\_\_\_ GPD

Total SG leakage = \_\_\_\_\_ GPD = \_\_\_\_\_ GPM  
1440 min/day

Date/Time 0-SI-CEM-000-050.0 performed: \_\_\_\_\_ / \_\_\_\_\_  
Date Time

Date/Time 1, 2-SI-CEM-068-137.5 performed: \_\_\_\_\_ / \_\_\_\_\_  
Date Time

\_\_\_\_\_  
Recorded by

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 57 of 61
------------------------------------	---	--

# APPENDIX D

Page 8 of 9

Unit \_\_\_\_\_

Date \_\_\_\_\_

## 2.4 Cold Leg Accumulators (CLA)

### NOTE

CLA leakage calculations may be marked **N/A** if RCS pressure is greater than 683 psig and quantification of CLA leakage is not required.

$$A. \text{ CLA 1 Leakage} = \frac{\left[ \left( \frac{\text{Final Volume}}{\text{gal}} \right) - \left( \frac{\text{Initial Volume}}{\text{gal}} \right) \right]}{\left( \frac{\Delta \text{ Time}}{\text{min}} \right)}$$

CLA 1 Leakage = \_\_\_\_\_ GPM

$$B. \text{ CLA 2 Leakage} = \frac{\left[ \left( \frac{\text{Final Volume}}{\text{gal}} \right) - \left( \frac{\text{Initial Volume}}{\text{gal}} \right) \right]}{\left( \frac{\Delta \text{ Time}}{\text{min}} \right)}$$

CLA 2 Leakage = \_\_\_\_\_ GPM

$$C. \text{ CLA 3 Leakage} = \frac{\left[ \left( \frac{\text{Final Volume}}{\text{gal}} \right) - \left( \frac{\text{Initial Volume}}{\text{gal}} \right) \right]}{\left( \frac{\Delta \text{ Time}}{\text{min}} \right)}$$

CLA 3 Leakage = \_\_\_\_\_ GPM

$$D. \text{ CLA 4 Leakage} = \frac{\left[ \left( \frac{\text{Final Volume}}{\text{gal}} \right) - \left( \frac{\text{Initial Volume}}{\text{gal}} \right) \right]}{\left( \frac{\Delta \text{ Time}}{\text{min}} \right)}$$

CLA 4 Leakage = \_\_\_\_\_ GPM

Total CLA leakage = \_\_\_\_\_ GPM

\_\_\_\_\_  
Performed By

\_\_\_\_\_  
Reviewed By

<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 58 of 61
------------------------------------	---	--

## APPENDIX D

Page 9 of 9

Unit \_\_\_\_\_

Date \_\_\_\_\_

### 2.5 Other Identified Leakage

**NOTE** The following value may be marked **N/A** if no additional identified leakage sources (i.e., Appendix A) are to be included.

Other identified leakage (Appendix A) = \_\_\_\_\_ GPM

### 2.6 Total Identified Leakage

Total identified leakage =  $\frac{\text{PRT}}{\text{PRT}} + \frac{\text{RCDT}}{\text{RCDT}} + \frac{\text{SG}}{\text{SG}}$   
+  $\frac{\text{Total CLA}}{\text{Total CLA}} + \frac{\text{CCPIT/HUT}}{\text{CCPIT/HUT}} + \frac{\text{Other}}{\text{Other}}$

Total identified leakage = \_\_\_\_\_ GPM

### 3.0 UNIDENTIFIED LEAKAGE

Unidentified leakage =  $\frac{\text{Total leakage}}{\text{Total leakage}} - \frac{\text{Identified leakage}}{\text{Identified leakage}}$

Unidentified leakage = \_\_\_\_\_ GPM

\_\_\_\_\_  
Performed By

\_\_\_\_\_  
Reviewed By







<b>SQN</b>  <b>1 &amp; 2</b>	<b>REACTOR COOLANT SYSTEM WATER INVENTORY</b>	<b>0-SI-OPS-068-137.0</b> <b>Rev: 22</b> Page 61 of 61
------------------------------------	---	--

### SOURCE NOTES

<b>REQUIREMENTS STATEMENT</b>	<b>SOURCE DOCUMENT</b>	<b>IMPLEMENTING STATEMENT</b>
Take RCDT data over same interval as other data. The test should last at least two hours. All T-avg changes shall be considered.	NRC Exit with C. Chung (1-30-88)	<b>C.1</b>
Steps to take when negative unidentified leakage is calculated.	NRC Inspection Report 50-327,328/89-16. Revised corrective action for NOV 50-327, 328/89-16-02 L44 891226 801	<b>C.2</b>
Procedures that do not contain appropriate verification requirements will be revised. This item is not annotated within the procedure, since the entire procedure must meet the verification program requirements	TROI NCO 970071001	<b>C.3</b>

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

**JPM # Admin 2.4 0210**

## Calculating Maximum Reactor Vessel Vent Time

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).



SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

**Task**  
Calculating Maximum Reactor Vessel Vent Time  
Respond to Voids in the Reactor Vessel per FR-I.3

**JA/TA task #**  
  
3110130601

**K/A Ratings:**  
2.4.13 4.0/4.6

**Task Standard:**

**Evaluation Method :** Simulator \_\_\_\_\_ In-Plant \_\_\_\_\_ Classroom  X

**Performer:** \_\_\_\_\_  
NAME

Start time \_\_\_\_\_

**Performance Rating :** SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish time \_\_\_\_\_

**Evaluator:** \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

**COMMENTS**

---

---

---

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. **Critical step** are identified.
2. Any **UNSAT** requires comments
3. This JPM will be performed in a classroom setting.
4. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

Validation Time: CR 15 min Local                     

Tools/Equipment/Procedures Needed:

**REFERENCES:**

	Reference	Title	Rev No.
	EA-0-7	Calculating Maximum Reactor Vessel Vent Time	2

Task Number	Task Title	Cont TRN
3110130601	Respond to Voids in the Reactor Vessel per FR-I.3	Y

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. All steps shall be performed for this task. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

Pzr Level is ~95%  
 RCS Pressure is 1000 psig (PI-68-62)  
 NO RCP's Running  
 RVLIS Upper Plenum Range ~95%  
 Unit 1 is performing FR-I.3, Voids in Reactor Vessel, Step 20  
 1U0983 indicates 223°F  
 1U0928 is inoperable  
 Containment Hydrogen Concentration per Chemistry Supervisor is 1.3% (15 minutes ago)  
 TSC is not available at this time

**INITIATING CUES:**

The US has directed you to perform EA-0-7 to calculate the maximum reactor vessel vent time. Return completed performance of EA-07 to the US.  
**PERFORM all calculations to the nearest tenth.**

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 1.:</b> [1] <b>OBTAIN</b> and <b>RECORD</b> the following data: RCS Pressure</p> <p><b>NOTE:</b> <i>Per initial conditions, PI-68-62, RCS pressure, is indicating~1000 psig</i></p> <p><b>STANDARD:</b> Operator records RCS pressure as provided in the initial conditions or from the cue.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 2.:</b> Containment lower compartment average air temperature (Tctmt)</p> <p><b>NOTE:</b> <i>Per initial conditions, computer point U0983 indicates 223°F</i></p> <p><b>STANDARD:</b> Operator records 223°F for the lower compartment temperature.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 3.:</b> Containment lower compartment volume at standard temperature and pressure (A)</p> <p><b>NOTE:</b> <i>Per initial conditions, Computer point U0928 is inoperable.</i></p> <p><b>STANDARD:</b> Operator records that the computer point is not available.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b> Containment Hydrogen Concentration (H)</p> <p><b>NOTE:</b> <i>Per initial conditions, Chemistry Supervisor reported Containment Hydrogen concentration 1.3 % ~ fifteen minutes ago.</i></p> <p><b>STANDARD:</b> Operator records hydrogen concentration provided in cue.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b> [2.a] <b>DETERMINE</b> containment lower compartment volume at standard temperature and pressure (A) a. If computer point U0928 available.....</p> <p><b>NOTE:</b> <i>Per initial conditions, U0928 is not available operator continues with the next substep.</i></p> <p><b>STANDARD:</b> Operator N/A this substep.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 6.:</b> [2.b] IF computer point U0928 NOT available, THEN <b>CALCULATE</b> A as follows:</p> $\frac{383,000 \text{ cu ft}}{(460 + 223^{\circ}\text{F})} \times \frac{492^{\circ}\text{R}}{683^{\circ}} = \frac{492}{683} = 383,000 \times .7 = 268,100 \text{ cu ft}$ <p><b>STANDARD:</b> Operator performs substep b, and determines A= 268,100 cu ft</p>	<p>___ SAT ___ UNSAT <b>Critical Step</b></p>
<p><b>STEP 7.:</b> [3] <b>DETERMINE</b> maximum hydrogen volume that can be vented (B) WHILE maintaining containment hydrogen concentration less than 3%.</p> $B = \frac{(3\% - H\%) \times A \text{ CU FT}}{100\%} = \frac{1.7 \times 268,100}{100} = 4557.7$ <p><b>STANDARD:</b> Operator utilizes data from step 4.2.1 for Containment Hydrogen concentration (3%-1.3%= 1.7%) and step 4.2.2 (b) for the lower compartment volume, and performs calculation to determine the max hydrogen volume that can be vented while maintaining the containment hydrogen concentration less than 3%.</p>	<p>___ SAT ___ UNSAT <b>Critical Step</b></p>
<p><b>STEP 8.:</b> [4.a] <b>DETERMINE</b> hydrogen flow rate as a function of RCS pressure (C): a. <b>RECORD</b> RCS pressure</p> $\frac{1000}{4.2.1} \text{ psig}$ <p><b>STANDARD:</b> Operator records RCS pressure as given in the initial conditions.</p>	<p>___ SAT ___ UNSAT</p>
<p><b>STEP 9.:</b> [4.b] <b>DETERMINE</b> hydrogen flow rate (C ) Using Curve 8, Hydrogen Flow vs RCS Pressure:</p> $C = \frac{3250 \text{ ( range 3150-3350) }}{\text{(Curve 8)}} \text{ SCFM}$ <p><b>STANDARD:</b> Operator uses the RCS pressure from 4.2.1 to determine hydrogen flow rate using Curve 8. Range 3250 +/- 100 SCFM.</p>	<p>___ SAT ___ UNSAT <b>Critical Step</b></p>

## Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 10.:</b> [5] <b>CALCULATE</b> maximum venting time (T):</p> $T = \frac{B \text{ CU FT}}{C \text{ Standard CU FT/Minute}}$ $T = \frac{4557.7}{3250 (3150 \text{ to } 3350)} = 1.4 \text{ +/- } 0.1 \text{ minutes}$ <p><b><u>Cue:</u></b></p> <p><b><u>STANDARD:</u></b> Operator calculates the maximum venting time.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 11.:</b> Operator returns complete performance of EA-0-7 to the Unit Supervisor.</p> <p><b><u>STANDARD:</u></b> Operator returns complete performance of EA-0-7 to the Unit Supervisor.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

End Of JPM



## CALCULATION SUMMARY SHEET FOR EXAMINER

### Determine Lower Compartment Volume (A)

$$A = 383,000 \text{ cu ft} \times \frac{492^{\circ}\text{R}}{(460 + T_{\text{ctmt}}^{\circ}\text{F})}$$

$$A = \frac{383,000 \text{ cu ft}}{1} \times \frac{492^{\circ}\text{R}}{(460 + 223^{\circ}\text{F})} = \frac{492}{683} = 383,000 \times 0.7 = 268,100 \text{ cu ft}$$

### Determine Max Hydrogen Volume That Can Be Vented (B)

$$B = \frac{(3\% - H\%) \times A \text{ cu ft}}{100\%}$$

$$B = \frac{(3\% - H\%) \times A \text{ CU FT}}{100\%} = \frac{1.7 \times 268,100}{100} = 4557.7$$

### Determine Hydrogen Flow rate (C)

$$C = \frac{\text{SCFM.}}{(\text{Curve 8})}$$

$$C = 3250 \text{ (range 3150-3350) SCFM}$$

### Calculate Max Vent Time (T)

$$T = \frac{B \text{ cu ft}}{C \text{ standard cu ft/minute}}$$

$$T = \frac{4557.7}{3220 \text{ (3200 to 3250)}} = 1.4 \text{ minutes } \pm 0.1 \text{ minutes}$$

End of Sheet

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues. All steps shall be performed for this task in a classroom. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

Pzr Level is ~95%  
RCS Pressure is 1000 psig (PI-68-62)  
NO RCP's Running  
RVLIS Upper Plenum Range ~95%  
Unit 1 is performing FR-I.3, Voids in Reactor Vessel, Step 20  
1U0983 indicates 223°F  
1U0928 is inoperable  
Containment Hydrogen Concentration per Chemistry Supervisor is 1.3%  
(15 minutes ago)  
TSC is not available at this time

### INITIATING CUES:

The US has directed you to perform EA-0-7 to calculate the maximum reactor vessel vent time.

Return completed performance of EA-07 to the US.

**PERFORM all calculations to the nearest tenth.**

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM21-1A

### Respond to a Failure of PRM N-41

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
(Operations Training Manager)

\_\_\_\_\_  
Date/

**CONCURRED:**

\*\*

\_\_\_\_\_  
(Operations Representative)

\_\_\_\_\_  
Date/

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING  
REVISION/USAGE LOG

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial Issue	Y	1/26/10	All	M Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

**Note: This JPM satisfies Simulator Manipulation "AA".**

**K/A Ratings:**

**Task Standard:**

**Evaluation Method:** Simulator   X   In-Plant           

NAME

Finish Time \_\_\_\_\_

SIGNATURE

## COMMENTS

[illegible]

### SPECIAL INSTRUCTIONS TO EVALUATOR:

1. Any UNSAT requires comments.
2. Acknowledge any associated alarms.
3. Initialize simulator in IC #13.
4. **Booth operator:**
  - a. Select N-41 on NR45.
  - b. Verify Rx power <75% on PRNIs, NR-45 and ΔT recorder, TR-68-2A
1. Approximately 1 minute after operator assumes shift, Activate **IMF NI07A f:120**.
2. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time:** CR. 9 mins Local \_\_\_\_\_

### **Tools/Equipment/Procedures Needed:**

AOP-I.01, Section 2.0 & 2.3, AR-M6-A, AR-M4-B

### **References:**

	Reference	Title	Rev No.
1.	AOP-I.01	Nuclear Instrument Malfunction	9
2.	1-AR-M6-A	Reactor Protection and Safeguards	15
3.	1-AR-M4-B	NIS/ROD CONTROL	28

### READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

Unit 1 is operating at ~46% reactor power, all controls are in AUTOMATIC.

### INITIATING CUES:

1. You are the OATC and are to monitor the control board and respond per licensed duties to operating conditions.
2. You will be required to respond, as a *single performer*, to any abnormality that occurs.
3. When any required actions/procedures have been completed notify the SM.

# STEP/STANDARD

SAT/UNSAT

<p><b>STEP 1.:</b> Operator places rods in Manual.</p> <p><b>STANDARD:</b> Operator places rods in manual after verifying rod motion is not warranted due to no power change or Tave/Tref mismatch. Rods are placed in manual without referencing a procedure, prior to exceeding insertion of &gt;25 steps.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT ___ UNSAT</p> <hr/> <p>Start Time</p> <p><b>Critical Step</b></p>
<p><b>STEP 2.:</b> Operator evaluates malfunction to determine Power Range Monitor (N-41) failed high.</p> <p><b>Cue:</b> <i>After operator locates AOP-I.01 procedure, provide operator a copy.</i></p> <p><b>STANDARD:</b> Operator recognizes Power Range Monitor (N-41) failed high, determines AOP-I.01, Section 2.3 is the appropriate procedure. AOP-I.01 may be entered directly or by transitions from any one of the procedures below:</p> <ul style="list-style-type: none"> <li>• AOP-C.01 section 2.1 step [3]</li> <li>• 1-AR-M6-A windows [B-1] or [D-1]</li> <li>• 1-AR-M4-B windows [D-3] and [E-3]</li> </ul> <p><b>COMMENTS:</b></p>	<p>___ SAT ___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>AOP-I.01, Nuclear Instrument Malfunction</b></p>	
<p><b>STEP 3.:</b> 2.3 [1] <b>PLACE</b> rod control in Man.</p> <p><b>STANDARD:</b> Operator verifies HS-85-5110 is in manual, or states Rods have already been placed in manual.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT ___ UNSAT</p>

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 4.:</u>      2.3 [2] <b>STABILIZE</b> reactor power at current level.</p> <p><u>STANDARD:</u>    Operator checks other power range instruments and determines that reactor is stable.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 5.:</u>      2.3 [3] <b>EVALUATE</b> the following Tech Specs for applicability:</p> <p><u>Cue:</u>          <b>SM will evaluate Tech Specs.</b></p> <p><u>STANDARD:</u>    Operator requests SM to evaluate Tech Specs</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 6.:</u>      2.3 [4] <b>PLACE</b> the following switches located on the Detector Current Comparator drawer [M-13, N50] in position corresponding to failed power Range Channel:</p> <ul style="list-style-type: none"> <li>•      UPPER SECTION</li> </ul> <p><u>STANDARD:</u>      Detector Current comparator "Upper Section" switch in the PRN-41 position. Channel defeat light on.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 7.:</u>      2.3 [4] <b>PLACE</b> the following switches located on the Detector Current Comparator drawer [M-13, N50] in position corresponding to failed power Range Channel:</p> <ul style="list-style-type: none"> <li>•      LOWER SECTION</li> </ul> <p><u>STANDARD:</u>      Detector Current comparator "Lower Section" switch in the PRN-41 position. Channel defeat light on.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>



STEP/STANDARD	SAT/UNSAT
<p><u>STEP 8.:</u>      2.3 [4] <b>PLACE</b> the following switches located on the Detector Current Comparator drawer [M-13, N50] in position corresponding to failed power Range Channel:</p> <p style="padding-left: 40px;">Appropriate ROD STOP BYPASS</p> <p><u>STANDARD:</u>      Rod Stop Bypass switch in "BYPASS PRN-41" position.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 9.:</u>      2.3 [4] <b>PLACE</b> the following switches located on the Detector Current Comparator drawer [M-13, N50] in position corresponding to failed power Range Channel:</p> <ul style="list-style-type: none"> <li>• Appropriate Power Mismatch Bypass switch (XX-92-5037)</li> </ul> <p><u>STANDARD:</u>      Power Mismatch Bypass switch in the "Bypass PRN-41" position.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 10.:</u>      2.3 [5] <b>DEFEAT</b> failed Power Range channel Using Comparator Channel defeat switch:</p> <ul style="list-style-type: none"> <li>• Comparator and Rate Drawer [M-13, N37]</li> </ul> <p><u>STANDARD:</u>      Comparator Channel Defeat switch is placed in the N-41 position. Comparator defeat light on.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 11.:</u>      2.3 [6] <b>RESTORE</b> T-avg to within 1.5°F of T-ref USING one of the following:</p> <p><u>Cue:</u>      <b><i>CRO is evaluating Tavg and Tref deviation and restoration.</i></b></p> <p><u>STANDARD:</u>      Operator acknowledges CRO will perform this step and continues with procedure.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 12.:</u> 2.3 [7] <b>ENSURE</b> OPERABLE Power Range channel selected to the following:</p> <ul style="list-style-type: none"> <li>• Nuclear Power Recorder [M4, NR-45]</li> <li>• Nuclear Power Recorder [M4, NR-45] (<math>\Delta</math>I)</li> </ul> <p><u>STANDARD:</u> Operator Uses Touch Screen to ensure the recorder is not selected for PR Channel I or <math>\Delta</math>I Channel 1. Operator should select the highest operable power range channel and an operable <math>\Delta</math>I Channel. (Operator could select view for all points on NR-45)</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p>
<p><u>STEP 13.:</u> 2.3 [7 continued] <b>ENSURE</b> RCS Temp <math>\Delta</math>T recorder (green pen) [M-5, XS-68-2B]</p> <p><u>STANDARD:</u> Operator checks position of XS-68-2B. Ensures it is <u>NOT</u> selected for LOOP ONE.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p>
<p><u>STEP 14.:</u> 2.3 [8] <b>RETURN</b> rod control to AUTO if desired.</p> <p><u>Cue:</u> <b><i>CRO will perform this step.</i></b></p> <p><u>STANDARD:</u> Operator acknowledges this step is being addressed by the CRO and continues with procedure.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p>
<p><u>STEP 15.:</u> 2.3 [9] <b>CHECK</b> reactor power greater than 75%.</p> <p><u>STANDARD:</u> Operator verifies power less than 75% (current power is ~ 46%), goes to RNO "GO TO Step 11."</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p>

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 16.:</u>      2.3[11] <b>NOTIFY</b> IM to remove failed power range channel from service USING appropriate Appendix:</p> <p><u>Cue:</u>            <i><b>Role play as MSS or IM, inform operator that a crew will be in the MCR within the hour to perform Appendix "A" of AOP-I.01.</b></i></p> <p><u>STANDARD:</u>    Operator communicates with IMs or MSS to request performance of Appendix "A" of AOP-I.01 for removal of N-41 from service.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p>
<p><u>STEP 17.:</u>      <b>NOTIFY</b> SM that N-41 failed, its control functions have been defeated, IMs have been notified to remove it from service.</p> <p><u>STANDARD:</u>    Operator informs SM.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT ___ UNSAT</p> <p>_____ Stop Time</p>

End of JPM

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

Unit 1 is operating at ~46% reactor power, all controls are in AUTOMATIC.

### **INITIATING CUES:**

1. You are the OATC and are to monitor the control board and respond per licensed duties to operating conditions.
2. You will be required to respond, as a *single performer*, to any abnormality that occurs.
3. When any required actions/procedures have been completed notify the SM.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM 1-AP

### Emergency Boration (Stuck Rods)

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
8	Transfer from WP. Minor enhancements.	N	8/12/94	All	HJ Birch
9	Boron Conc. changes	N	9/16/94	All	HJ Birch
10	Chg due to Rev B procedure.	Y	9/9/95	All	HJ Birch
11	Incorp previous pen/inks: which corrected step 10 to continue with procedure instead of transition (JPM performance comment. Moved Tave cue from step 14 to 17 added step to determine fully inserted, 12 steps. Latest EA-68-4 & ES-0.1 Rev Chgd 'rods full out' to 'rods >12 steps', added step to use the computer to verify Rods position	N	1/19/96	6	HJ Birch
12	Major flow change for the start of EA-68-4	Y	2/2/98	All	HJ Birch
13	Revision to ES-0.1 had no impact. Made step 28 a critical step. Revised K/A ratings. Reformatted critical steps.	N	9/23/98	All	JP Kearney
pen/ink	ES-0.1 procedure revision had no impact	N	8/22/00	4	S. R. Taylor
pen/ink	Minor clarification	N	11/27/01	4, 6, 7, 9	L. Pauley
14	Incorporated change to EA-68-4. Change was editorial in nature	N	8/12/02	All	J P Kearney
15	Incorporated REV. 1C changes to ES-0.1 and EA-68-4	Y	9/8/03	All	G S Poteet
16	Incorporated comments	N	3/30/04	All	G.S. Poteet
17	Made minor editorial changes throughout. Updated to current revisions of EA-68-4 and ES-0.1.	N	7/27/04	All	MG Croteau
18	Updated to current revisions of EA-68-4 and ES-0.1. Made minor editorial changes throughout.	Y	9/20/2005	All	JJ Tricoglou
19	Revised format and updated IC. Added candidate cue sheet and minor revisions to match procedure references.	N	11/21/07	All	R Putnam
20	Added H3 auto generate of Handout. Remove handout page. Minor step chgs base on previous procedure changes.	N	7/15/08	5, 7, 9	H J Birch
21	Updated procedure revisions, deleted steps to realign Emergency Boration, validation time change to 15 minutes.	Y	1/31/10	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

## COMMENTS

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Sequenced steps identified by an "s"
2. Any **UNSAT** requires comments
3. Initialize the simulator in IC-118.
4. **Insert the following:**
  - a. **IMF RD13A f:1**
  - b. **IMF RD13E f:1**
  - c. Override **IOR ZDIHS62138A f:0**
  - d. **IMF RD07C5 (F-8)**
  - e. **IMF RD07D8 (H-14)**
  - f. **IMF AN\_OV\_325** CPU alarm for Control Rods Dev & Seq- Nuisance alarm
5. **INITIATE** a reactor trip.
6. Close TDAFW valves and freeze the simulator after you have acknowledged the control board alarms.
7. The Console operator can be used to acknowledge alarms not associated with the JPM.
8. Ensure operator performs the following required actions for **SELF-CHECKING**:
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time:** CR. 15 mins Local \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

1. EA-68-4,
2. ES-0.1
3. Calculator for examiner and examinee

**REFERENCES:**

	Reference	Title	Rev No.
A.	EA-68-4	Emergency Boration	10
B.	ES-0.1	Reactor Trip Response	32

=====



## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

1. The reactor has tripped with no safety injection and the Immediate Actions of E-0, Reactor Trip or Safety Injection, were completed.
2. The transition was made to ES-0.1 "Reactor Trip Response".
3. BAT A is aligned to Unit 1 via 1A BATP

### **INITIATING CUES:**

1. You are directed to PERFORM step 6 of ES-0.1.
2. NOTIFY the US/SRO when you have completed all actions required by Step 6 of ES-0.1.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 1.:</u>     <b>OBTAIN</b> the appropriate procedure(s).</p> <p><u>STANDARD:</u> Operator obtains a copy of ES-0.1 (and EA-68-4 at step 3 of JPM)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time ____</p>
<p><b>NOTE:</b>     <b>The next three steps of the JPM are from ES-0.1.</b></p> <p><u>STEP 2.</u>     6. <b>CHECK</b> if emergency boration required:</p> <p>                 a. <b>VERIFY</b> all control rods fully inserted</p> <p><u>STANDARD:</u> Determine that two rods F8 and H14 are indicating full out by checking rod bottom lights and rod position indicators for control rod position. Enter Step 6.a RNO.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 3.</u>     <b>IF</b> all rod bottom lights are de-energized, <b>THEN</b> <b>RESTORE</b> power to RPIs by switching Instrument Rack B Transfer Switch to ALTERNATE. [M-7, lower switch]</p> <p><u>STANDARD:</u> Operator determines this step N/A since power is available.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4.</u>     <b>IF</b> any of the following conditions exists:</p> <ul style="list-style-type: none"> <li>• two or more RPI's indicate greater than 12 steps</li> </ul> <p><b>OR</b></p> <ul style="list-style-type: none"> <li>• two or more control rod positions CANNOT be determined,</li> </ul> <p><b>THEN</b> <b>EMERGENCY BORATE USING EA-68-4, EMERGENCY BORATION</b></p> <p><u>STANDARD:</u> Operator transitions to EA-68-4, Emergency Boration</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<b>EA-68-4, Emergency Boration</b>	
<p><u>STEP 5.</u>     [4.1.1] <b>IF</b> entering this instruction from any of the following:</p> <p><u>STANDARD:</u> Operator determines this step is N/A, since procedure entry was from ES-0.1, Reactor Trip Response.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 6.</b> [4.1.2] <b>IF</b> entering this instruction from ES-0.1 <b>AND</b> any of the following conditions are met:</p> <ul style="list-style-type: none"> <li>• RCS temperature less than 540°F <b>AND</b> core burnup is greater than 12,000 MWD/MTU</li> <li><b>OR</b></li> <li>• RCS temperature less than 530°F</li> </ul> <p><b>Cue:</b> <i>If checked, cue that RCS temperature reads 547 degrees on all loops.</i></p> <p><b>STANDARD:</b> Operator recognizes that emergency boration is not required based on temperature.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 7.</b> [4.1.3] <b>IF</b> rod positions <b>CANNOT</b> be verified due to RPI's de-energized,</p> <p><b>STANDARD:</b> Operator determines this step is N/A, since procedure entry was from ES-0.1, Reactor Trip Response due to two stuck rods, continue with next step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 8.</b> [4.1.4] <b>IF</b> entering this instruction from ES-0.1 <b>AND</b> any of the following conditions are met:</p> <ul style="list-style-type: none"> <li>• Two or more control rods indicating greater than 12 steps</li> <li><b>OR</b></li> <li>• Two or more rod positions <b>CANNOT</b> be determined due to RPIs unavailable</li> </ul> <p><b>THEN</b> <b>PERFORM</b> the following:</p> <ol style="list-style-type: none"> <li><b>IF</b> using BAT as a boration source <b>GO TO</b> Section 4.2, Emergency Boration from BAT</li> <li><b>IF</b> using RWST as a boration source <b>GO TO</b> Section 4.3, Emergency Boration from RWST</li> </ol> <p><b>NOTE:</b> Since Section 4.3 is an acceptable path, if the operator chooses this path give the following cue:</p> <p><b>Cue:</b> <i>If the operator chooses to go to section 4.3, role play as US and state that the preferred boration method is via the BAT.</i></p> <p><b>STANDARD:</b> Operator selects Section 4.2.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>NOTE:</b> The following steps are from Section 4.2.</p> <p><b>STEP 9:</b> [4.2.1] <b>PLACE</b> boric acid transfer pumps to fast speed.</p> <p><b>NOTE:</b> Standard 1 and 2 can be done in any order.</p> <p><b>STANDARD:</b> 1) Pump(s) stopped. <b>Green</b> light on HS 2) Speed selector switch placed on "FAST" position 3) Pump(s) restarted, <b>Red</b> light on right comes on for fast speed. 4) <b>(Starting only 1A pump is acceptable)</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 10.:</b> [4.2.2] <b>ADJUST</b> emergency borate valve <b>[FCV-62-138]</b> to maintain flow between 35 and 150 gpm on <b>[FI-62-137A]</b>.</p> <p><b>NOTE:</b> <b>FCV-62-138 will not operate.</b></p> <p><b>STANDARD:</b> Operator recognizes that FCV-62-138 will not operate. Operator continues with procedure.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 11.:</b> [4.2.3] <b>MONITOR</b> emergency boration flow: a. <b>CHECK</b> emergency boration flow established on <b>[FI-62-137A]</b>.</p> <p><b>NOTE:</b> <b>Since FCV-62-138 will not operate, this step will have no affect on flow. Operator may continue with the next step.</b></p> <p><b>STANDARD:</b> Operator determines FCV-62-138 will not open and no flow is available. Continues with next step. This is a MONITOR step which requires checking a process repeatedly at an unspecified interval.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 12.:</b> [4.2.3.b] <b>IF</b> boric acid flow less than 35 gpm, <b>THEN CLOSE</b> recirculation valve for the BAT aligned to the blender: <b>[1-FCV-62-237]</b> for BAT A.</p> <p><b>NOTE:</b> There is no boric acid flow indicated on FI-62-137A at this time. This is a monitor step and if or when flow is established on this FI the operator should verify flow greater than 35 gpm, or throttle recirculation valve as necessary to establish 35 gpm. <b>Placing the recirculation valve in closed, without a flow path will dead head the boric acid transfer pump.</b> See Attachment 1 Boric Acid Flowpath and Valves.</p> <p><b>STANDARD:</b> Operator should continue with the next step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 13.:</b> [4.2.4] <b>IF</b> emergency boration flow NOT established, <b>THEN ALIGN</b> normal boration path:</p> <p>[4.2.4a] <b>VERIFY</b> VCT outlet valves <b>[LCV-62-132]</b> and <b>[LCV-62-133]</b> OPEN</p> <p><b>STANDARD:</b> Operator verifies valve positions using indicator lights for LCV-62-132 and 133 on control panel, red lights illuminated.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 14.:</b> [4.2.4.b] <b>ALIGN</b> normal boration to VCT outlet:</p> <ul style="list-style-type: none"> <li>• <b>OPEN [FCV-62-140].</b></li> <li>• <b>OPEN [FCV-62-144].</b></li> </ul> <p><b>STANDARD:</b> Operator verifies FCV-62-140 is already OPEN (red light illuminated, green light dark) and opens FCV-62-144 by placing HS-62-144 to the OPEN position (right) and verifies red light illuminated and green light dark.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 15.:</b> [4.2.4.c] <b>CHECK</b> boration flow greater than 35 gpm on <b>[FI-62-139]</b>.</p> <p><b>CUE:</b> <i>If operator notifies the SRO that emergency boration has been established acknowledge flow has been established.</i></p> <p><b>STANDARD:</b> Operator ensures flow rate is greater than 35 gpm. May notify SRO that emergency boration flow has been established.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 16.:</b> [4.2.5] <b>IF</b> boration flow NOT established, <b>THEN</b> PERFORM one of the following...</p> <p><b>STANDARD:</b> Operator N/A's this step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 17.:</b> [4.2.6] <b>VERIFY</b> charging flow established.</p> <p><b>STANDARD:</b> Operator verifies charging flow established on FI-62-93.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 18.:</b> [4.2.7] <b>MAINTAIN</b> boric acid flow between 35 and 150 gpm.</p> <p><b>STANDARD:</b> Operator monitors flow on FI-62-139 between 35 and 50 gpm.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 19.:</b> [4.2.8] <b>Monitor</b> BAT level.</p> <p><b>STANDARD:</b> Operator monitors BAT level on LI-62-238.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 20.:</b> [4.2.9] <b>IF</b> FR-S.1 ATWS or FR-S.2 Loss of core Shutdown condition exists, <b>THEN....</b></p> <p><b>STANDARD:</b> Operator N/A's this step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 21.:</b> [4.2.10] <b>IF</b> emergency boration required for RCS cooldown, <b>THEN DETERMINE</b> required boric acid volume based on RCS Temperature</p> <p><b>STANDARD:</b> Operator N/As this step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>


Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 22.:</b> [4.2.11] <b>IF</b> any of the following conditions are met:</p> <ul style="list-style-type: none"> <li>• 2 or more control rods greater than 12 steps</li> <li>OR</li> <li>• 2 or more control rods positions CANNOT be determined</li> </ul> <p><b>THEN PERFORM</b> one of the following:</p> <ul style="list-style-type: none"> <li>• Determine Boric Acid Volume from Table</li> <li>OR</li> <li>• <b>CALCULATE</b> required boric acid volume <b>USING</b> 0-SI-NUC-000-038.0 and TI-44.</li> </ul> <p><b>CUE:</b> <i>If operator decides to use SI-38, tell them the preferred method to determine Boric Acid volume is from the table in EA-68-4.</i></p> <p><b>STANDARD:</b> Operator Determines boric acid volume using table and determines that 5040 gallons of boric acid are required.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 23.:</b> <b>CALCULATE</b> time to inject boric acid volume determined in EA-68-4 step 11 at established flow rate:</p> <p><b>NOTE:</b> <math>5040 / (\text{flow indicated by FI-62-139}) = \text{_____ minutes}</math></p> <p><b>STANDARD:</b> Operator determines the time required to inject 5040 gallons of boric acid based on the flow rate they establish. 5040 gal/ flow rate on FI-62-139 = _____ minutes +/- 1 minute</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 24.:</b> <b>WHEN</b> either of the following conditions exists:</p> <ul style="list-style-type: none"> <li>• FR-0 Subcriticality Status Tree is GREEN</li> <li><b>AND</b></li> <li>• Required Boric Acid Volume has been injected to RCS</li> <li>OR Adequate SDM verified</li> <li>OR Conditions which require Emergency Boration no longer exist,</li> </ul> <p><b>THEN GO TO</b> Section 4.4 for Termination of Boron.</p> <p><b>Cue:</b> <i>When the operator determines the time, cue them that the JPM is complete.</i></p> <p><b>STANDARD:</b> Operator notifies the US that boration has been established to RCS.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

**End of JPM**

# Attachment 1

## Emergency Boration Flowpath/Valves



## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. The reactor has tripped with no safety injection and the Immediate Actions of E-0, Reactor Trip or Safety Injection, were completed.
2. The transition was made to ES-0.1 "Reactor Trip Response".
3. BAT A is aligned to Unit 1 via 1A BATP

### INITIATING CUES:

1. You are directed to PERFORM step 6 of ES-0.1.
2. NOTIFY the US/SRO when you have completed all actions required by Step 6 of ES-0.1.



# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM2 RO/SRO

### Remove Excess Letdown from Service

**PREPARED/  
REVISED BY:** \_\_\_\_\_ **Date/** \_\_\_\_\_

**VALIDATED BY:** \* \_\_\_\_\_ **Date/** \_\_\_\_\_

**APPROVED BY:** \_\_\_\_\_ **Date/** \_\_\_\_\_  
(Operations Training Manager)

**CONCURRED:** \*\* \_\_\_\_\_ **Date/** \_\_\_\_\_  
(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

## REVISION/USAGE LOG

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial Issue	Y	1/18/2010	All	M. Hankins

See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

Task  
Place excess letdown in service to the VCT /RCDT

JA/TA task #  
0040160101

K/A Ratings:

004 A4.06 (3.6/3.1)  
A4.06 (3.6/3.1)

004 A4.05 (3.6/3.1)

Task Standard: Remove Excess letdown from service in accordance with 1-SO-62-6, Excess Letdown, section 7.0

Evaluation Method : Simulator ☒ In-Plant ☐

Performer: \_\_\_\_\_  
NAME

Start time \_\_\_\_\_

Performance Rating : SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_

Finish time \_\_\_\_\_

Evaluator: \_\_\_\_\_  
SIGNATURE / DATE

COMMENTS

---

---

---

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. A **Critical step** is identified bold type in the SAT/UNSAT column.
2. Any **UNSAT** requires comments
3. Task should begin at the IC198, B CCP I/S, Excess LD I/S, LD I/S at ~73 gpm.
5. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.
6. **Place a Pink Tag on 1-HIC-62-93, which is in manual.**

Validation Time: CR 7 min Local                     

Tools/Equipment/Procedures Needed:

**REFERENCES:**

Procedure	Title	Rev No.
1-SO-62-6	Excess Letdown	17
1-AR-M5-B	Annunciator Response	36

Task Number	Task Title	Cont TRN
0040160101	Place excess letdown in service to the VCT /RCDT	

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be performed for this task. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

The Unit is operating at 100% power.  
A Leaking valve required Normal Letdown to be removed from service.,  
Excess letdown was placed in service while the repairs were made.  
Excess letdown temperature is ~207°F and 45 psig on 1-PI-62-57.  
The leaking valve has now been repaired.  
Normal Letdown has been restored to service in accordance with 1-SO-62-1.  
1-HIC-62-93 is in manual, per section 5.0 of 1-SO-62-6, Excess Letdown.  
1-SO-62-6, Section 4.0, 5.0 and 7.0 step 1 are complete.

**INITIATING CUES:**

You are the U-1 OATC. You have been directed to remove excess letdown from service using 1-SO-62-6, Section 7.0.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 1.:</b> IF letdown is to be placed in service, <b>THEN RETURN</b> to service per 1-SO-62-1.</p> <p><b>STANDARD:</b> Operator verifies letdown is in service. Initial conditions stated</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>_____</p> <p>Start Time</p>
<p><b>STEP 2.:</b> <b>CLOSE [1-FCV-62-56]</b> Excess Letdown Heat Exchanger outlet valve.</p> <p><b>STANDARD:</b> Operator turns the potentiometer in the clockwise direction until the pointer (needle) is in the CLOSE or ZERO position. Operator may verify a decrease in temperature on TI-62-58 and pressure decrease on PI-62-57.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p>
<p><b>STEP 3.:</b> <b>VERIFY [1-FCV-62-59]</b> Excess Letdown 3-way valve in <b>NORMAL</b>.</p> <p><b>STANDARD:</b> Operator verifies the HS for FCV-62-59 is in NORMAL.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b> <b>CLOSE [1-FCV-62-55]</b> Excess Letdown containment isolation valve.</p> <p><b>STANDARD:</b> Operator places HS in closed and verifies green light illuminated and red light dark</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b> <b>CLOSE [1-FCV-62-54]</b> COLD LEG Loop #3 Excess Letdown valve.</p> <p><b>STANDARD:</b> Operator places HS to close and verifies green light illuminated and red light dark</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 6.:</b> IF charging is in service, <b>THEN</b> <b>ADJUST</b> seal injection flow to 6-11 gpm using <b>[1-FCV-62-89]</b></p> <p><b>STANDARD:</b> Operator turns potentiometer CCW to close (demand moves to the right toward 100% or CLOSE) to reduce seal injection flow to between 6 and 11 gpm.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 7.:</b> IF auto operation is desired and system conditions will allow it, <b>THEN</b> <b>PLACE [1-FCV-62-93]</b> in <b>AUTO</b>.</p> <p><b>STANDARD:</b> Prior to placing charging in automatic, the Operator should adjust Pressurizer level, by taking the lever to the right to decrease charging flow (or to the left to increase charging flow) as needed to match Pzr Level and Program Level. When program level and actual level are matched, the Auto/Manual Toggle should be placed in the Auto (Down) position.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 8.:</b> <b>NOTIFY</b> RADCON that Excess Letdown is REMOVED from SERVICE.</p> <p><b>CUE:</b> <i>Acknowledge as RADCON that Excess Letdown has been removed from service.</i></p> <p><b>STANDARD:</b> Operator should call RADCON and notify them Excess Letdown has been removed from service on Unit 1.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 9.:</b> <b>ENSURE [1-FCV-70-85]</b> Excess Letdown HX CCS FCV is <b>CLOSED</b>.</p> <p><b>NOTE</b> Operator should address the need to have a CV (Concurrent Verifier) present prior to operating the valve.</p> <p><b>STANDARD:</b> Operator takes the HS for 1-FCV-70-85 to CLOSE position (to the left) and verifies green light illuminated and red light dark.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 10.:</u>     <b>ENSURE [1-HS-70-85A]</b> is in the A-Auto position.</p> <p><u>NOTE</u>            Operator should address the need to have a CV (Concurrent Verifier) present prior to operating the valve.</p> <p><u>STANDARD:</u>    Operator places the HS in the A-Auto position (mid position).</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p>
<p><u>STEP 11.:</u>     <b>INDEPENDENTLY VERIFY....</b></p> <p><u>NOTE</u>            The next four steps are independent verification of manipulations previously made by the operator</p> <p>      <u>CUE:</u>        <i><b>Tell the operator the independent verifications were performed by another operator.</b></i></p> <p><u>STANDARD:</u>    Operator requests an independent verification for previous manipulations.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 12.:</u>     <b>IF</b> operation at greater than 200°F has occurred, <b>THEN CONTACT</b> Systems Engineering to evaluate Grinnell Valve maintenance requirements.</p> <p><u>STANDARD:</u>    Operator notifies the US that excess letdown temperature exceeded 200°F, therefore System Engineering must be notified to evaluate Grinnell Valve maintenance requirements.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>_____ STOP TIME</p>

**End of JPM**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. I will provide initiating cues and reports on other actions when directed by you. All steps shall be performed for this task. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

The Unit is operating at 100% power.  
A Leaking valve required Normal Letdown to be removed from service.,  
Excess letdown was placed in service while the repairs were made.  
Excess letdown temperature is ~207°F and 45 psig on 1-PI-62-57.  
The leaking valve has now been repaired.  
Normal Letdown has been restored to service in accordance with 1-SO-62-1.  
1-HIC-62-93 is in manual, per section 5.0 of 1-SO-62-6, Excess Letdown.  
1-SO-62-6, Section 4.0, 5.0 and 7.0 step 1 are complete.

### **INITIATING CUES:**

You are the U-1 OATC. You have been directed to remove excess letdown from service using 1-SO-62-6, Section 7.0.



# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM # 152-1

### Swap RHR Pumps (Train B to Train A) With Level in the Pressurizer

PREPARED/  
REVISED BY:

\_\_\_\_\_  
Date/

VALIDATED BY:

\*

\_\_\_\_\_  
Date/

APPROVED BY:

\_\_\_\_\_  
(Operations Training Manager)

\_\_\_\_\_  
Date/

CONCURRED:

\*\*

\_\_\_\_\_  
(Operations Representative)

\_\_\_\_\_  
Date/

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	New JPM based on JPM 152, changed to swap from Train B to Train A RHR pump.	Y	12/03/09	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

**Task:** Swap RHR Pumps (Train B to Train A) with Level in the Pressurizer  
**JATA task # :** 0050030101 (RO)  
0050080101 (RO)

**K/A Ratings:**

005K4.03 (2.9/3.2)	005A1.01 (3.5/3.6)	005A4.02 (3.4/3.1)
005K4.10 (3.1/3.1)	005A1.02 (3.3/3.4)	005A4.01 (3.6/3.4)
005A4.01 (3.6/3.4)		

**Task Standard:**

'A' Train RHR is placed in service injecting to Loops 2 & 3.

**Evaluation Method :** Simulator ☒ In-Plant ☐

=====

**Performer:** \_\_\_\_\_  
NAME Start time \_\_\_\_\_

**Performance Rating :** SAT \_\_\_\_\_ UNSAT \_\_\_\_\_ Performance Time \_\_\_\_\_ Finish time \_\_\_\_\_

**Evaluator:** \_\_\_\_\_ / \_\_\_\_\_  
SIGNATURE DATE

=====

**COMMENTS**

---

---

---

---

---

---

---

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Initialize IC-197. Ensure Train B RHR is in service with flow aligned through FCV-63-94 to Loops 1 & 4.
2. An extra operator will be required to acknowledge alarms and monitor S/G levels, RCS temp, RCS press.
3. Any **UNSAT** requires comments
4. Ensure operator performs the following required actions for **SELF-CHECKING**:
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.
5. Ensure 74-530 valve is closed.
6. **Override alarm SR Hi Flux at SD**

Validation Time: CR. 15 minutes Local                     

Tools/Equipment/Procedures Needed:  
0-SO-74-1, Section 8.3.1

**REFERENCES:**

	Reference	Title	Rev No.
1.	0-SO-74-1	Residual Heat Removal System	69

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

1. Unit 1 had been in Mode 5 for 72 hours to repair a leak on the #1 Steam Line.
2. RHR pump B is in-service and supplying letdown
2. RCS boron is 1400 ppm and the previous shift determined that Train A RHR boron concentration is 1450 ppm.
3. Shutdown margin required boron concentration is 1200 ppm.
4. Train B RHR pump needs to be shutdown to allow Maintenance to add oil to the motor.
5. Train A RHR has been checked out locally by the Auxiliary Bldg AUO and is ready for service.
6. Two AUO's are briefed and standing by in the Auxiliary Building to assist in swapping the pumps.
7. 0-SO-74-1 Prerequisite Actions are complete.

**INITIATING CUES:**

You are the Unit 1 OATC and the SRO has directed you to place Train A RHR in service and remove Train B RHR from service, using 0-SO-74-1 Section 8.3.1, step [1].  
Align Train A injection flowpath to loops 2 & 3.  
Notify the SRO when you have Train A RHR in service.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 1.:</b> Obtain copy of 0-SO-74-1 and determine appropriate section</p> <p><b>STANDARD:</b> Operator obtains a copy of 0-SO-74-1 and determines Section 8.3.1 is the section for Placing Train A RHR I/S.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>
<p><b>STEP 2.:</b> <b>IF</b> adjustment is required on CCS flow through RHR Hxs, <b>THEN ENSURE [FCV-70-156]</b> RHR Hx A CCS outlet is <b>THROTTLED</b>.</p> <p><b>NOTE:</b> Operator may decide to keep FCV-70-156 at current position.</p> <p><b>STANDARD:</b> Operator ensures HS-70-156 has a RED &amp; GREEN light LIT with flow indicated on 0-M-27A.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 3.:</b> <b>ENSURE [FCV-74-16]</b> RHR Hx A Outlet is CLOSED.</p> <p><b>STANDARD:</b> Operator ensures FCV-74-16 RHR Hx A Outlet CLOSED, HIC-74-16 @ 100%.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b> <b>START</b> RHR Pump A-A with [HS-74-10A].</p> <p><b>STANDARD:</b> Operator may address making a plant announcement prior to starting 1A-A RHR Pump (not critical). Starts pump and verifies RED light LIT on HS, verifies amps.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 5.:</b> <b>VERIFY [FCV-74-12]</b> RHR Pump A-A miniflow OPENS or greater than 500 gpm in indicated on FI-74-12.</p> <p><b>Cue:</b> IF dispatched: <b>FI-74-12 indicates &gt;500 gpm.</b></p> <p><b>STANDARD:</b> Operator verifies FCV-74-12 is open by Red light LIT on handswitch OR checks with AUO locally to verify &gt;500 gpm flow indicated on local flow indicator FI-47-12.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 6.:</b> <b>IF</b> aligning Train A RHR cooling to loops 2 and 3, <b>THEN PERFORM</b> the following: [a] <b>ENSURE [FCV-63-93]</b> OPEN.</p> <p><b>STANDARD:</b> Operator opens FCV-63-93, verifies red light illuminated, green light dark.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>STEP 7.:</b> [b] <b>ADJUST [FCV-74-16]</b> to establish flow from train A RHR.</p> <p><b>STANDARD:</b> Operator adjusts FCV-74-16 RHR Hx A Outlet OPEN, using HIC-74-16, to the approximate valve of HIC-74-28, to obtain ~2000 gpm flow (~68-70% demand on HIC).</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 8.:</b> [c] <b>ADJUST [FCV-74-28] AND [FCV-74-32]</b> to reduce Train B RHR flow.</p> <p><b>STANDARD:</b> Operator closes FCV-74-28 RHR Hx B Outlet, place HIC-74-28 to 0%.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 9.:</b> [d] <b>VERIFY [FCV-74-24]</b> RHR Pump B-B miniflow OPENS OR greater than 500 gpm in indicated on FI-74-24.</p> <p><b>Cue:</b> IF dispatched: <i>FI-74-24 indicates &gt;500 gpm.</i></p> <p><b>STANDARD:</b> Operator verifies FCV-74-24 is open by Red light LIT on handswitch or checks with AUO locally to verify &gt;500 gpm flow indicated on local flow indicator FI-47-24.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 10.:</b> [e] <b>CLOSE [FCV-74-35]</b> RHR Hx B Outlet.</p> <p><b>STANDARD:</b> Operator closes FCV-74-35, green light illuminated, red light dark.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 11.:</b> [f] <b>ENSURE [FCV-74-33]</b> RHR Hx A Outlet OPEN.</p> <p><b>STANDARD:</b> Operator ensures FCV-74-33 RHR Hx A Outlet OPEN, red light illuminated, green light dark.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 12.:</b> [g] <b>OPEN [VLV-74-530]</b> RHR Hx A to Letdown Hx.</p> <p><b>NOTE:</b> <i>Console operator needs to modify remote function RHR03 to 100.</i></p> <p><b>Cue:</b> <i>AUO reports that VLV-74-530 has been opened locally, operator should discuss the need for CV.</i></p> <p><b>STANDARD:</b> Operator directs an AUO to OPEN VLV-74-530 RHR Hx A to Letdown Hx.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 13.:</u> [h] <b>STOP</b> RHR Pump B-B with <b>[HS-74-20A]</b>.</p> <p><u>STANDARD:</u> Operator stops RHR pump 1B-B, verifies GREEN light on handswitch.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 14.:</u> [i] <b>OPEN</b> <b>[HCV-74-36]</b> RHR Hx A Bypass.</p> <p><b>NOTE:</b> Console operator needs to modify remote function RHR06 to 100.</p> <p><b>Cue:</b> AUO reports HCV-74-36 is opened (including CV).</p> <p><u>STANDARD:</u> Operator directs an AUO to OPEN HCV-74-36 RHR Hx A Bypass.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 15.:</u> [j] <b>CLOSE</b> <b>[HCV-74-37]</b> RHR Hx B Bypass.</p> <p><b>NOTE:</b> Console operator needs to modify remote function RHR07 to 0.</p> <p><b>Cue:</b> AUO reports HCV-74-37 has been closed locally (including CV).</p> <p><u>STANDARD:</u> Operator directs an AUO to CLOSE HCV-74-37 RHR Hx B Bypass.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 16.:</u> [k] <b>CLOSE</b> <b>[VLV-74-531]</b> RHR Hx B-B to Letdown Hx.</p> <p><b>NOTE:</b> Console operator needs to modify remote function RHR04 to 0.</p> <p><b>Cue:</b> AUO report s VLV-74-531 has been closed an AUO locally (including CV).</p> <p><u>STANDARD:</u> Operator directs an AUO to close HCV-74-531.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 17.:</u> [l] <b>ENSURE</b> <b>[FCV-63-94]</b> CLOSED.</p> <p><u>STANDARD:</u> Operator closes FCV-63-94, green light illuminated, red light dark</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 18.:</u> <b>IF</b> aligning RHR cooling to loops 1 and 4, <b>THEN ENSURE</b> the following valves are in the required position.</p> <p><b>NOTE:</b> Step is NA'd, initiating Cues direct alignment to loops 2 &amp; 3.</p> <p><u>STANDARD:</u> Operator NA's the step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>NOTE:</b> Initial flow values ~ 2500-2800 gpm.</p> <p><b>STEP 19.:</b> <b>THROTTLE</b> one or both of the following to maintain desired cooling rate: FCV-74-16, RHR Hx A Outlet, AND/OR FCV-74-32, RHR Hx Bypass.</p> <p><b>STANDARD:</b> Operator may throttle FCV-74-16 and/or FCV-74-32 to stabilize RCS temperature and establish RHR flowrates at approximately the same values that were present prior to the flowpath realignment.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 20.:</b> <b>WHEN</b> injection flow is &gt; 1250 gpm, <b>THEN VERIFY [FCV-74-12]</b> RHR Pump A-A miniflow is CLOSED.</p> <p><b>STANDARD:</b> Operator verifies FCV-74-12 closed, GREEN light LIT on handswitch.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 21.:</b> <b>IF</b> cooling water is to be removed from Train B Hx, <b>THEN CLOSE [FCV-70-153].</b></p> <p><b>Cue:</b> <i>Leave cooling water aligned to Train B at its current flowrate.</i></p> <p><b>STANDARD:</b> Operator NA's step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 22.:</b> NOTIFY U1 US that Train A of RHR is in service to loops 2 &amp; 3 and Train B of RHR has been removed from service.</p> <p><b>STANDARD:</b> None.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p>Stop Time___</p>

End of JPM



## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. Unit 1 had been in Mode 5 for 72 hours to repair a leak on the #1 Steam Line.
2. RHR pump B is in-service and supplying letdown
2. RCS boron is 1400 ppm and the previous shift determined that Train A RHR boron concentration is 1450 ppm.
3. Shutdown margin required boron concentration is 1200 ppm.
4. Train B RHR pump needs to be shutdown to allow Maintenance to add oil to the motor.
5. Train A RHR has been checked out locally by the Auxiliary Bldg AUO and is ready for service.
6. Two AUO's are briefed and standing by in the Auxiliary Building to assist in swapping the pumps.
7. 0-SO-74-1 Prerequisite Actions are complete.

### INITIATING CUES:

You are the Unit 1 OATC and the SRO has directed you to place Train A RHR in service and remove Train B RHR from service, using 0-SO-74-1, Section 8.3.1, step [1]. Align Train A injection flowpath to loops 2 & 3.  
Notify the SRO when you have Train A RHR in service.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

**JPM # 65-1**

## Re-establishment of Containment Pressure Control Following High Pressure Conditions

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING  
REVISION/USAGE LOG

REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/REVISED BY:
0	New JPM adapted from JPM 65 for NRC exam 0210.	Y	1/14/10	ALL	M Hankins

V - Specify if the JPM change will require another validation.  
See cover sheet for criteria.

## COMMENTS

### **SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any **UNSAT** requires comments.
2. Acknowledge any associated alarms.
3. Initialize Simulator in IC: #116, verify containment pressure 0.6 psig.
4. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time:** CR 15 min Local \_\_\_\_\_

### **Tools/Equipment/Procedures Needed:**

0-SO-30-8 Sections 3.0, 4.0, and 5.2

### **References:**

	Reference	Title	Rev No.
A.	0-SO-30-8	Containment Pressure Control	29
B.	0-SI-CEM-030-410.1	Containment Vent to Aux Building Exhaust	31

=====

### **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- Unit 1 is in Mode 1 recovering from an Air Line break in containment. The air leak was discovered on a section of the header that allowed isolation without affecting any equipment.
- During isolation efforts, containment pressure increased to approximately 0.6 psig.
- EAM's are in the Adverse Containment condition.
- Purge is **not** in progress
- 0-SI-CEM -030-410.1, Containment Vent to Aux Building Exhaust, is in progress and approved by SRO and Radiochemical Laboratory Supervisor.
- RM-90-101, 106 and 112 and 130 are in service and indicating Normal.
- RM-90-106B is indicating 2.84 E+02; previous sample (yesterday) was 2.83E+02.
- Prerequisite Actions (Section 4.0) are complete for 0-SO-30-8.
- Power checklist 1-30-8.02 is complete with no deviations.

### **INITIATING CUES:**

1. The US directs you, to vent containment using 0-SO-30-8, section 5.2.1.
2. Inform the US when Containment pressure is decreasing.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>The following steps are from Section 5.2.1 of 0-SO-30-8:</b></p> <p><b>STEP 1.:</b>       <b>ENSURE</b> 1-30-8.02 power checklist complete.</p> <p><b>STANDARD:</b> Power checklist 1-30-8.02 is complete with no deviations per initial conditions.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>
<p><b>STEP 2.:</b>       <b>ENSURE</b> the check valve portion of the containment vacuum relief assembly is capable of closing by observing monitor lights on panel (panel M-9).</p> <p><b>STANDARD:</b> Operator checks monitor lights on panel (panel M-9) to ensure valves are closed, green lights are ON.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 3.:</b>       <b>IF</b> the unit is in MODES 1, ,2 or 3, <b>THEN</b> <b>NOTIFY</b> the US/SRO that the EAM will be placed in the Adverse Containment condition for venting containment.</p> <p><b>STANDARD:</b> Per initial conditions, EAM's are in the Adverse Cntmt condition for venting containment.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b>       <b>EVALUATE</b> entry into LCO 3.6.6. Vacuum Relief Lines.</p> <p><b>Cue:</b>       <i><b>Play role of SRO and state you will evaluate the LCO.</b></i></p> <p><b>STANDARD:</b> Operator informs the US/SRO LCO 3.6.6, Vacuum Relief Lines needs to be evaluated.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b>       <b>IF</b> the Unit is in Modes 1, 2, 3, <b>THEN</b> <b>PERFORM</b> the following: [5.1] <b>IF</b> the EAM is <b>NOT</b> in the Adverse Cntmt condition....</p> <p><b>STANDARD:</b> Operator recognizes the EAMs are in the Adverse Cntmt condition. Operator should N/A step [5.1] and complete [5.2] and [5.3].</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 6.:</b>       [5.2] <b>ENSURE</b> blue purge/vent operation permissive lights illuminated for each steam generator.</p> <p><b>STANDARD:</b> Operator verifies blue purge/vent permissive lights are illuminated for each S/G (M-4 above SG NR levels indicators).</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 7.:</b>       [5.3] <b>VERIFY</b> window 30 "S/G Level Adverse Setpoint" illuminated on XA-55-3C.</p> <p><b>STANDARD:</b> Operator verifies XA-55-3C window 30 illuminated.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT				
<u>STEP 8.:</u>	<p>[6] <b>IF</b> the Unit is in Modes 1-4, <b>THEN</b> [6.1] <b>VERIFY</b> Radiochemical Laboratory has a current weekly performance of 0-SI-CEM-030-410.1 in progress.</p> <p><u>STANDARD:</u> Per initial conditions, 0-SI-CEM-030-410.1 is in progress and approved by SRO and Radiochemical Laboratory Supervisor.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 9.:</u>	<p>[6.2] <b>IF</b> the noble gas count rate for lower containment ....</p> <p><u>STANDARD:</u> Operator determines from initial conditions that noble gas has not increased by 50% since last sample and N/A's the step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 10.:</u>	<p>[6.3] <b>IF</b> the lower containment noble gas radiation monitor is inoperable.....</p> <p><u>STANDARD:</u> Operator determines RM-90-106 is operable by looking at RM or per initial conditions and N/A's the step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 11.:</u>	<p>[7] <b>ENSURE</b> that the Shield Building Annulus Vacuum Control System is in service and maintaining a negative 5.0 inches of H<sub>2</sub>O as indicated on M-9, [PDI-30-126] or [PDI-30-127] <b>OR</b> EGTS in service <b>OR</b> EGTS testing in progress.</p> <p><u>STANDARD:</u> Operator obtains reading from PDI-30-126 or 127 on panel M-9, AB-Annulus Vacuum reading ~ 5"of water.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 12.:</u>	<p>[8] <b>VERIFY NO</b> abnormal or unexplainable radiation levels exist inside containment.</p> <p><u>STANDARD:</u> Operator checks RM-90-106 and 112 for abnormal radiation levels in containment, determine radiation levels are normal and signs of step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 13.:</u>	<p>[9] <b>VERIFY</b> that <b>NO</b> containment vent isolation signal exists.</p> <p><u>STANDARD:</u> Operator checks XA-55-6C windows C5 &amp; C6 dark to verify that a containment vent isolation signal is not present.</p>	<p>___ SAT</p> <p>___ UNSAT</p>				
<u>STEP 14.:</u>	<p>[10] <b>ENSURE</b> at least ONE of the following radiation monitors in service:</p> <table><tr><td>U-1 Containment</td><td>1-RM-90-130</td></tr><tr><td>Purge Exhaust Monitors</td><td>1-RM-90-131</td></tr></table> <p><u>STANDARD:</u> Operator verifies the RM-90-130 per initial conditions is in service (No Alarms and Not Blocked).</p>	U-1 Containment	1-RM-90-130	Purge Exhaust Monitors	1-RM-90-131	<p>___ SAT</p> <p>___ UNSAT</p>
U-1 Containment	1-RM-90-130					
Purge Exhaust Monitors	1-RM-90-131					

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT							
<p><u>STEP 15.:</u> [11] <b>VERIFY</b> that all personnel have been evacuated from the annulus and that all doors are closed.</p> <p><b>Cue:</b> <i>when asked, Role play Rad Con and state all personnel are out of the annulus and the doors are closed.</i></p> <p><u>STANDARD:</u> Operator calls Rad Con and verifies that all personnel have been evacuated from the annulus and that all doors are closed.</p>	<p>___ SAT</p> <p>___ UNSAT</p>								
<p><u>STEP 16.:</u> [12] <b>ENSURE</b> at least one of the following radiation monitors in service for the appropriate unit:</p> <p>AB Vent: 0-RM-90-101B</p> <p>Upper Compartment: 1-RM-90-112 A, B</p> <p>Lower compartment: 1-RM-90-106 A, B</p> <p><u>STANDARD:</u> Operator verifies the absence of applicable instrument malfunction alarms on 0-M-12, the RM's above are in service and Normal per initial conditions.</p>	<p>___ SAT</p> <p>___ UNSAT</p>								
<p><u>STEP 17.:</u> [13] <b>ENSURE</b> PROTECTED EQUIPMENT DO NOT INOP tags placed on the following radiation monitors block switches as appropriate: (N/A tags not placed).</p> <table><tr><td><b>BLOCK SWITCH</b></td><td><b>MONITOR</b></td></tr><tr><td>0-HS-90-136A1</td><td>1-RM-90-130</td></tr><tr><td>0-HS-90-136A2</td><td>1-RM-90-131</td></tr><tr><td>0-HS-90-136A3</td><td>0-RM-90-101B</td></tr></table> <p><b>Cue:</b> <i>An Extra Operator will place Protected Equipment tags.</i></p> <p><u>STANDARD:</u> Operator addresses placing PROTECTED EQUIPMENT Tags on Rad monitor Block Switches.</p>	<b>BLOCK SWITCH</b>	<b>MONITOR</b>	0-HS-90-136A1	1-RM-90-130	0-HS-90-136A2	1-RM-90-131	0-HS-90-136A3	0-RM-90-101B	<p>___ SAT</p> <p>___ UNSAT</p>
<b>BLOCK SWITCH</b>	<b>MONITOR</b>								
0-HS-90-136A1	1-RM-90-130								
0-HS-90-136A2	1-RM-90-131								
0-HS-90-136A3	0-RM-90-101B								
<p><u>STEP 18.:</u> [14] <b>IF</b> aligning the lower compartment purge isolation valves using the <u>NORMAL</u> flow path, <b>THEN PERFORM</b> steps [a] thru [f].</p> <p><b>NOTE:</b> This step will be satisfied in steps 19 thru 22.</p> <p><u>STANDARD:</u> Operator selects the normal flow path as stated in initial conditions.</p>	<p>___ SAT</p> <p>___ UNSAT</p>								



Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 19.:</u> [14.1] <b>ENSURE</b> [FCV-30-37] is CLOSED.</p> <p><u>STANDARD:</u> Operator verifies green light ON for FCV-30-37</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 20.:</u> [14.2] <b>ENSURE</b> [FCV-30-40] is CLOSED.</p> <p><u>STANDARD:</u> Operator verifies green light ON for FCV-30-40</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 21.:</u> [14.3] <b>OPEN</b> [FCV-30-14 &amp; 56] with [HS-30-14].</p> <p><u>STANDARD:</u> Operator places HS-30-14 in the OPEN position and places HS-30-14 in the A-AUTO position.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 22.:</u> [14.4] <b>VERIFY</b> [FCV-30-14 &amp; 56] OPEN.</p> <p><u>STANDARD:</u> Operator verifies red lights illuminated ON [FCV-30-14 &amp; 56].</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 23.:</u> [14.5] <b>OPEN</b> [FCV-30-15 &amp; 57] with HS-30-15.</p> <p><u>STANDARD:</u> Operator places HS-30-15 in the OPEN position and places HS-30-15 in the A-AUTO position.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 24.:</u> [14.6] <b>VERIFY</b> FCV-30-15 &amp; 57 <b>OPEN</b>.</p> <p><u>STANDARD:</u> Operator verifies red lights illuminated for FCV-30-15 &amp; 57 and places HS-30-15 in the A-AUTO position.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 25.:</u> [15] <b>IF</b> aligning the lower compartment purge isolation valves using the <u>Alternate</u> flow path <b>THEN PERFORM</b> steps [15.1] thru [15.8].</p> <p><u>STANDARD:</u> Operator should NA this step since the NORMAL flow path is being used.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 26.:</u> [16] <b>OPEN</b> Annulus exhaust isolation valve FCV-30-54 with HS-30-54.</p> <p><u>STANDARD:</u> Operator opens FCV-30-54 with HS-30-54. Verifies valve open by observing red light ON.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 27.:</u> [17] <b>RECORD</b> time purge isolation valves are OPENED. TIME _____</p> <p><u>STANDARD:</u> Operator records the time purge valves were opened.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 28.:</u> [18] <b>IF</b> the Annulus Vacuum Control System is in service and the standby Annulus Vacuum Control Fan is available, <b>THEN</b> <b>PERFORM</b> the following <b>START</b> the standby Annulus Vacuum Control Fan.</p> <p><u>STANDARD:</u> Operator starts the standby Annulus Vacuum Control Fan.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 29.</u> IF a high radiation alarm occurs on any of the following RM's</p> <p><u>STANDARD:</u> Operator checks RM's, and verifies all alarms are clear.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 30.</u> Operator notifies US that containment vent is in progress.</p> <p><u>CUE:</u> <i>Another operator will complete the vent.</i></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>STOP TIME</p>

END OF JPM

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

- Unit 1 is in Mode 1 recovering from an Air Line break in containment. The air leak was discovered on a section of the header that allowed isolation without affecting any equipment.
- During isolation efforts, containment pressure increased to approximately 0.6 psig.
- EAM's are in the Adverse Containment condition.
- Purge is **not** in progress
- 0-SI-CEM -030-410.1, Containment Vent to Aux Building Exhaust, is in progress and approved by SRO and Radiochemical Laboratory Supervisor.
- RM-90-101, 106 and 112 and 130 are in service and indicating Normal.
- RM-90-106B is indicating 2.84 E+02; previous sample (yesterday) was 2.83E+02.
- Prerequisite Actions (Section 4.0) are complete for 0-SO-30-8.
- Power checklist 1-30-8.02 is complete with no deviations.

### INITIATING CUES:

3. The US directs you, to vent containment using 0-SO-30-8, section 5.2.1.
4. Inform the US when Containment pressure is decreasing.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

**JPM # 34-1**

## Establishing Secondary Heat Sink Using Main Feedwater or Condensate

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial issue	Y	1/31/10	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.



### **SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Critical steps are identified.
2. Any **UNSAT** requires comments
3. Acknowledge any associated alarms.
4. Initialize simulator in **IC: 119** Steam Dump Pressure Mode Setpoint-968 psig  
All AFW pumps are shutdown, MDAFW A-A tagged, TDAFW pump and MDAFW B-B trip on Reactor Trip. RX trip due Rod control problems (multiple rod drops), adjust steam dumps in pressure mode to control Tavg 544-546°F.
5. Allow S/G narrow range levels are <~20%. (allow SD to steam off to reduce S/G level if necessary)
6. Console operator will role play as CRO and acknowledge/clear alarms as needed.
7. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

Validation Time: CR. 30 mins Local \_\_\_\_\_

### **Tools/Equipment/Procedures Needed:**

EA-2-2

### **References:**

	Reference	Title	Rev No.
1.	EA-2-2	Establishing Secondary Heat sink using Main Feedwater or Condensate	8

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

1. Unit 1 has experienced a Reactor Trip due multiple dropped rods.
2. MDAFW pump A-A is tagged out for maintenance,  
MDAFW pump B-B tripped on electrical fault and the  
TDAFW pump tripped on mechanical overspeed just after RX trip.
3. Unit has transitioned to ES-0.1 and is ready to perform the RNO for STEP 5.
4. All four S/G levels have been decreasing.
5. AFW Flow to the S/Gs can NOT be established.

### **INITIATING CUES:**

1. You are the CRO and the US directed you to establish Main Feedwater flow  
USING EA-2-2, Establishing Secondary Heat Sink Using Main Feedwater or Condensate System.
2. Inform the US when Main Feedwater or Condensate flow has been established to **one** S/G.

<p><b>STEP 1.:</b> Obtain copy of the appropriate procedure.</p> <p><b>STANDARD:</b> Operator may obtain a copy of ES-0.1 and review step 5 RNO, for transition step to EA-2-2.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>
<p>EA-2-2 Establishing Secondary Heat Sink Using MFW or Condensate System Section 4.1</p>	
<p><b>STEP 2.:</b> [1] <b>IF</b> directed by ES-0.1, Reactor Trip Response, to establish Main Feedwater flow, <b>THEN PERFORM</b> Section 4.2.</p> <p><b>STANDARD:</b> Operator recognizes Section 4.2 is the correct section for performance and transitions to section 4.2.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p>EA-2-2 Establishing Secondary Heat Sink Using MFW or Condensate System Section 4.2</p>	
<p><b>STEP 3.</b> [1] <b>REFER TO</b> the following EAPs to attempt to restore AFW flow in parallel with this procedure:</p> <ul style="list-style-type: none"> <li>• EA-3-10 Establishing MDAFW flow</li> <li>• EA-3-9, establishing TDAFW flow</li> </ul> <p><b>CUE:</b> <i>Maintenance and Ops personnel have been dispatched to restore MDAFW pumps A and B and the TDAFWP, EA-3-10 and EA-3-9 are in progress.</i></p> <p><b>STANDARD:</b> Operator contacts the US and or the MSS to have personnel dispatched to establish AFW flow.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b> [2] <b>CLOSE</b> MFW Regulating valves.</p> <p><b>STANDARD:</b> Operator ensures the MFW Reg valves output signal is zero, on 1-FIC 3-35, 48, 90 and 103 and check lights for MFW Reg valves on 1-XX-3-35.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b> [3] <b>ENSURE</b> MFW Regulating Bypass valves CLOSED.</p> <p><b>STANDARD:</b> Operator ensures MFW Bypass valves CLOSED using 1-LIC-3-35, 48, 90, 103</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 6.:</b> [4] <b>CYCLE</b> Reactor Trip breakers.</p> <p><b>STANDARD:</b> Operator places 1-HS-99-7 in the CLOSE position, and places 1-RT-1 in the trip position. Rx trip breaker lights turn red and then green.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>



<p><b>STEP 7.:</b> [5] <b>RESET</b> FW Isolation signal. [M-3]</p> <p><b>STANDARD:</b> Operator depresses pushbuttons 1-HS-3-99A and 99B, and Annunciator Window 1-XA-55-6B, LOW Tavg Reactor Trip MFW Valves Actuated alarm clears.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 8.:</b> [6] <b>OPEN</b> FW isolation valves for S/G's to be fed.</p> <p><b>STANDARD:</b> Operator opens at least one FWI valve(s) for S/G to be fed, using 1-HS-3-33A, 47A, 87A or 100A, red light on green light off.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 9.:</b> [7] <b>PERFORM</b> Section 4.4 to establish Main Feedwater flow to S/G's.</p> <p><b>STANDARD:</b> Operator transitions to Section 4.4.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
Section 4.4	
<p><b>STEP 10.:</b> [1] <b>DISPATCH</b> operator to <b>PERFROM</b> Appendix A, Part I to remove fuses to disable intermediate heater string Isolation.</p> <p><b>Cue</b> <i>Respond as an AUO and tell operator you will perform Appendix A to remove fuses to disable intermediate heater string isolation.</i></p> <p><b>STANDARD:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 11.:</b> [2] <b>ENSURE</b> Condensate Inlet and Outlet valves for at least one LP Heater String OPEN.</p> <p><b>STANDARD:</b> Operator verifies LP Heater Inlet/Outlet valves OPEN for at least one LP heater string, red light illuminated and green lights dark for (A) 1-HS 2-45A and 55A, OR (B) 1-HS-2-56A and 65A, OR (C) 1-HS-2-66A and 75A.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 12.:</b> [3] <b>ENSURE</b> the following condensate pumps RUNNING:</p> <ul style="list-style-type: none"> <li>• 2 Hotwell pumps</li> <li>• 1 CBP (with suction valve open)</li> <li>• 1 Injection water pump</li> </ul> <p><b>STANDARD:</b> Operator ensures 2 HW pumps, 1 CBP with suction valve open and 1 injection water pump running.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 13.:</b> [4] <b>ENSURE</b> MFPT Recirc Valves in MANUAL and CLOSED:</p> <ul style="list-style-type: none"> <li>MFPT A 1-FIC-3-70</li> <li>MFPT B 1-FIC-3-84</li> </ul> <p><b>STANDARD:</b> Operator ensures recirc valves for the MFP's, 1-FIC-3-70 and 3-84, are in manual (amber light illuminated) and closed (indicator to the right).</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 14.:</b> [5] <b>ENSURE</b> MFW Reg controllers in MANUAL and Output Zero.</p> <p><b>STANDARD:</b> Operator ensures Main FRV are in manual (toggle switch to manual) and closed (output demand 0) using 1-FIC-3-35, 48, 90, 103, and checks green status lights illuminated on 1-XX-3-35 (red dark).</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 15.:</b> [6] <b>ENSURE</b> MFW Bypass Reg valves controllers in MANUAL and output ZERO.</p> <p><b>STANDARD:</b> Operator ensures all MFW Reg Bypass valves are in Manual (amber light illuminated) and output ZERO using 1-LIC-3-35, 48, 90, and 103.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 16.:</b> [7] <b>IF</b> a flowpath is not available through at least one Intermediate Heater string.....</p> <p><b>STANDARD:</b> Operator N/A's this step, flow path is available.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 17.:</b> [8] <b>ENSURE</b> Inlet and Outlet valves for at least one string of Intermediate and High Pressure Heaters OPEN:</p> <ul style="list-style-type: none"> <li>High Pressure FW Heaters (panel M-3) <ul style="list-style-type: none"> <li>(A) 1-HS-3-3A and 10A OR</li> <li>(B) 1-HS-3-13A and 20A OR</li> <li>(C) 1-HS-3-23A and 30A</li> </ul> </li> <li>Intermediate Pressure FW Heaters (Panel M-2) <ul style="list-style-type: none"> <li>(A) 1-HS-2-110A and 128A OR</li> <li>(B) 1-HS-2- 130A and 147A OR</li> <li>(C) 1-HS-2- 149A and 167A</li> </ul> </li> </ul> <p><b>STANDARD:</b> Operator verifies at least one string of IP (M-2) and HP (M-3) heater string isolation valves are OPEN.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 18.:</b> [9] <b>IF</b> starting MFW pump A, <b>THEN PERFORM</b> the following:</p> <p style="margin-left: 40px;">[9.a] <b>ENSURE</b> MFP a drain hand-switch <b>[HS-46-14]</b> in OPEN position</p> <p style="margin-left: 40px;"><u>STANDARD:</u> OPERATOR ensures the MFPT drain hand-switch <b>[HS-46-14]</b> is in OPEN position (HS to the right on M-3)</p>	<p>___ SAT</p> <p>___ UNSAT</p>															
<p><b>STEP 19.:</b> [9.b] <b>ENSURE</b> the following valves are OPEN:</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="width: 20%;">VALVE</th> <th style="width: 50%;">DESCRIPTION</th> <th style="width: 30%;">OPEN ✓</th> </tr> </thead> <tbody> <tr> <td>FCV-2-205</td> <td>MFPT Condenser A Inlet Isol [M2]</td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>FCV-2-210</td> <td>MFPT Condenser A Outlet Isol [M2]</td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>FCV-2-221</td> <td>MFWP A Inlet Valve [M2]</td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> <tr> <td>FCV-3-67</td> <td>MFWP A Outlet Valve [M3]</td> <td style="text-align: center;"><input type="checkbox"/></td> </tr> </tbody> </table> <p><u>STANDARD:</u> OPERATOR ensures the MFPT condenser Inlet and Outlet Isolation valves are OPEN, FCV-2-205 and 210, and the MFP Inlet and Outlet isol Valves are open, FCV-2-221 and 3-67.</p>	VALVE	DESCRIPTION	OPEN ✓	FCV-2-205	MFPT Condenser A Inlet Isol [M2]	<input type="checkbox"/>	FCV-2-210	MFPT Condenser A Outlet Isol [M2]	<input type="checkbox"/>	FCV-2-221	MFWP A Inlet Valve [M2]	<input type="checkbox"/>	FCV-3-67	MFWP A Outlet Valve [M3]	<input type="checkbox"/>	<p>___ SAT</p> <p>___ UNSAT</p>
VALVE	DESCRIPTION	OPEN ✓														
FCV-2-205	MFPT Condenser A Inlet Isol [M2]	<input type="checkbox"/>														
FCV-2-210	MFPT Condenser A Outlet Isol [M2]	<input type="checkbox"/>														
FCV-2-221	MFWP A Inlet Valve [M2]	<input type="checkbox"/>														
FCV-3-67	MFWP A Outlet Valve [M3]	<input type="checkbox"/>														
<p><b>CUE:</b> <i>IF asked, state 0-GO-12, Appendix A was not performed.</i></p> <p><b>STEP 20.:</b> [9.c] <b>IF</b> <b>[VLV-1-611]</b> MFP pump A HP steam Isolation .....</p> <p><b>CUE:</b> <i>IF operator dispatches personnel to open valve Inform them that VLV-1-611 is already open.</i></p> <p><u>STANDARD:</u> Operator dispatches an operator to check valve open locally, or acknowledges that 0-GO-12, Appendix A was not performed.</p>	<p>___ SAT</p> <p>___ UNSAT</p>															
<p><b>STEP 21.:</b> [9.d] <b>RESET</b> MFPT A USING <b>[HS-46-9A]</b>.</p> <p><u>STANDARD:</u> Operator places HS in the reset position and verifies the red light illuminates green light is dark, alarm clears for MFP trip.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>															

<p><b>STEP 22.:</b> [9.e] <b>PLACE</b> MFPT A <b>[SIC-46-20A]</b> in MANUAL and with ZERO output.</p> <p><b>STANDARD:</b> Operator places MFPT A SIC-46-20 to manual and sets output signal to 0.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 23.:</b> [9.f] <b>ENSURE</b> MFPT A and B master speed controller <b>[PC-46-20]</b> in MANUAL and with output at 0.</p> <p><b>STANDARD:</b> Operator places MFPT A and B master speed controller [PC-46-20] in MANUAL and sets output at 0.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 24.:</b> [9.g] <b>DO NOT CONTINUE</b> until suction flow path established to MFP.</p> <p><b>STANDARD:</b> Operator has previously verified suction flow path is available to MFP, and continues with procedure.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 25.:</b> [9.h] <b>ENSURE</b> <b>[FIC-3-70]</b> MFPTA recirc valve in MANUAL and OPEN.</p> <p><b>STANDARD:</b> Operator verifies the MFP A recirc valve is in manual, amber light illuminated and opens valve (toggle switch to the left).</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 26.:</b> [9.i] <b>PLACE</b> MFPT A speed controller <b>[SIC-46-20A]</b> in AUTO.</p> <p><b>STANDARD:</b> Operator places MFPT A speed controller in AUTO.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 27.:</b> [9.k] <b>VERIFY</b> the governor valve positioner is indicating CLOSED.</p> <p><b>STANDARD:</b> Operator verifies 1-HS-46-13A green light illuminated and/or checks 1-ZI-46-13B (M-3) indicating 0.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 28.:</b> [9.k] <b>IF</b> MFPT governor valve <b>NOT</b> indicating CLOSED, <b>THEN</b> ....</p> <p><b>STANDARD:</b> Operator N/A's this step, valve is closed.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 29.:</b> [9.l] <b>OPEN</b> MFPT A stop valves by placing HP stop valve switch <b>[HS-46-15A]</b> to raise.</p> <p><b>NOTE:</b> HP and LP stop valve will open when the HS is placed in raise. Either HS placed in raise will open the valves. If HS-46-16A is used to open stop valves then make a comment. Critical task is SAT if HS-46-16A is used.</p> <p><b>STANDARD:</b> OPERATOR holds the HS-46-15A in raise position until the red light is illuminated and green light is dark.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 30.:</b> [9.m] <b>RAISE</b> MFPT A speed by <b>PERFORMING</b> one of the following:</p> <p>1) <b>IF</b> MCR operation of governor valve positioner is available, <b>PLACE [HS-47-13A]</b> to RAISE to open the steam chest valves.</p> <p><b>STANDARD:</b> OPERATOR places HS-47-13A in RAISE to open GV while monitoring MFP loading. MFP speed should stabilize at ~3300 rpm as seen on 1-SI-46-20A.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 31.:</b> [9.m] (continued)</p> <p>2) <b>IF</b> MCR operation of governor valve positioner unavailable, <b>THEN...</b></p> <p><b>STANDARD:</b> Operator N/A's this step since governor valve positioner was available.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 32.:</b> [9.n] <b>WHEN</b> MFPT speed controller controlling MFPT speed, <b>THEN ENSURE</b> governor valve positioner is fully raised.</p> <p><b>NOTE:</b> MFPT speed controller takes over speed control when MFPT accelerates to ~ 3300 rpm on 1-SI-46-20A.</p> <p><b>STANDARD:</b> Operator ensures Governor Valves Positioner is fully raised, red light illuminated and green light dark.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 33.:</b> [9.o] <b>ADJUST</b> MFPT speed <b>USING</b> Master Controller <b>[PC-46-20]</b> UNTIL feedwater header pressure is ~ 80 psid greater than steam header pressure.</p> <p><b>STANDARD:</b> Operator adjusts [PC-46-20] in manual to increase FW header pressure to 80 psid greater than steam header pressure while monitoring PI-3-1, # 1 HTR Inlet Pressure (on M-3 panel), and PI-1-33, Main Steam Header Pressure (on M-4 panel). Operator may also monitor FW/SG delta P on: ICS/Secondary Mimics/Feedwater screen.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 34.:</b> [10] IF starting MFP pump B.....</p> <p><b>STANDARD:</b> OPERATOR N/A's this step.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 35.:</b> [11] <b>IF</b> RCS temperature is less than 550°F, <b>THEN GO TO</b> Step 13.</p> <p><b>STANDARD:</b> OPERATOR verifies temperature is &lt;550°F and continues with step 13.</p>	<p>___ SAT</p> <p>___ UNSAT</p>

<p><b>STEP 36.:</b> [13] <b>ADJUST</b> MFW regulating Bypass valve controller to establish required feed flow.</p> <p><b>CAUTION</b> IF automatic SI signals are NOT blocked, feed flow should be carefully controlled to prevent rapid cooldown which could result in low steam flow line pressure SI actuation (and subsequent feedwater isolation).</p> <p><b>NOTE</b> 0.2 X10<sup>6</sup> lbm/hr feed is equivalent to ~440 gpm. Due to inaccuracy of flow indication at low end of scale, feed flow should be determined based on a rise in indicated flow.</p> <p><b>NOTE TO EVALUATOR:</b> If operator notifies the US that FW flow is established to one SG in this step, then N/A step 37 and record stop time in step 38.</p> <p><b>STANDARD:</b> Operator adjusts MFW Reg Bypass valve in manual by adjusting the lever to the right to establish feed water flow to at least one steam generator. Monitors for an indication of flow on FW Flow Indicators or level increase in the selected steam generator(s).</p> <p>Operator may notify the US that FW flow has been established to at least one S/G, this ends the JPM as FW flow is established to one SG.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 37.:</b> [14] <b>MONITOR</b> Hotwell level and <b>CONTROL</b> as necessary.</p> <p><b>NOTE:</b> If operator notified US that FW was established in previous step then this step is not required.</p> <p><b>STANDARD:</b> Operator may state that they are monitoring HW level on 1-LR-2-12 (M-3), and using 1-LIC-2-3 and 1-LIC-2-9 for auto makeup and dumpback.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 38.:</b> Inform the US/SRO when feedwater flow has been established.</p> <p><b>STANDARD:</b> Operator informs the US/SRO FW flow has been established.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>_____ Stop Time</p>

**End of JPM**

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. Unit 1 has experienced a Reactor Trip due multiple dropped rods.
2. MDAFW pump A-A is tagged out for maintenance,  
MDAFW pump B-B tripped on electrical fault and the  
TDAFW pump tripped on mechanical overspeed just after RX trip.
3. Unit has transitioned to ES-0.1 and is ready to perform the RNO for STEP 5.
4. All four S/G levels have been decreasing.
5. AFW Flow to the S/Gs can NOT be established.

### INITIATING CUES:

1. You are the CRO and the US directed you to establish main feedwater flow USING EA-2-2, Establishing Secondary Heat sink Using Main Feedwater or Condensate System.
2. Inform the US when Main Feedwater or Condensate flow has been established to **one** S/G.



# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM # 77-1AP

Perform D/G Load Test on 1B-B D/G  
(with high crankcase press)

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
8	Revised to reflect revision changes in SI-7B, changed critical steps for consistency with JPM 77-5AP reviewed/approved 4/20/99, corrected typos and incorporated comments from 1999 cycle 5 requal performances of JPM 77-2AP. Flow of the JPM is not affected.	N	10/13/99	All	SR Taylor
pen/ink	0-AR-M26-B Rev chg only	N	8/9/00	4	SR Taylor
pen/ink	Minor change to step 6, SO-83 Rev update.	N	8/17/00	4	SR Taylor
pen/ink	0-AR-M26-B Rev chg only	N	8/28/00	4	SR Taylor
pen/ink	1-SI-OPS-082-007.B Rev chg only	N	6/21/01	4	WR Ramsey
pen/ink	1-SI-OPS-082-007.B rev 25 Update minor changes related to stopwatch usage	N	09/07/01	ALL	WR Ramsey
pen/ink	minor enhancement changes and 1-SI-OPS-082-007.B Revision update	N	03/21/02	ALL	WR Ramsey
9	Incorporated pen/ink changes; updated to latest revisions of referenced documents; no impact on JPM flow	N	8/20/02	All	J P Kearney
10	Updated references	N	12/10/03	4	JJ Tricoglou
	Revised remote functions/annunciator overrides to conform to new simulator configurations.	N		8, 9	
11	Updated to current revisions and IC.	N	8/11/04	All	MG Croteau
12	Updated to current revision of procedure	Y	12/03/09	ALL	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

SEQUOYAH NUCLEAR PLANT  
RO/SRO  
JOB PERFORMANCE MEASURE

**Task:**

Perform D/G Load Test on 1B-B D/G

**JA/TA task # :**

0640020101    0640040101    0640060101    (RO)

**K/A Ratings:**

064A4.01 (4.0/4.3)	064A1.04 (2.8/2.9)
064A4.02 (3.3/3.4)	064A4.03 (3.2/3.3)
064A2.09 (3.1/3.3)	064A3.06 (3.9/3.9)

**Task Standard:**

Perform D/G Operability Test per 1-SI-OPS-082-007.B, specifically manually start the D/G. Emergency stop D/G on high crankcase pressure annunciation.

**Evaluation Method :** Simulator   X   In-Plant           

**Performer:**

NAME

Start Time           

**Performance Rating :** SAT        UNSAT        Performance Time       

Finish Time           

**Evaluator:**

SIGNATURE

/ DATE

**COMMENTS**

---

---

---

---

---

---

---

---

---

---

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any **UNSAT** requires comments
2. Acknowledge any associated alarms.
3. Initialize Simulator in IC: #16.
4. A console operator will be needed to insert override and play role of AUO on Radio.
5. Operator will need assistance during D/G start (at step 5). An extra simulator operator or the console operator needs to be present to perform this timing.
6. Place Protected equipment tag on the A DG.
7. **AT JPM step 13, Console operator should insert IRF EGR08 f:1 to reset 86LOR and then notify operator - 86 LOR is reset.**
7. **When operator starts JPM step #25, prior to D/G breaker closure, insert IMF AN\_OV\_958 f:2.**
8. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time:** CR 30 minutes      Local \_\_\_\_\_

**Tools/Equipment/Procedures Needed:**

1. 1-SI-OPS-082-007.B, Through Section 6.1 and Appendix "C".
2. "Signed off" copy of entire section 4.
3. 0-AR-M26-B window D-2.

**References:**

	Reference	Title	Rev No.
1.	1-SI-OPS-082-007.B	Electrical Power System Diesel Generator 1B-B	50
2.	0-AR-M26-B	Annunciator 0-XA-55-26B	27

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

1. Both units are at 100% RTP.
2. All systems are OPERABLE, except for the 1B-B D/G.
3. 0-GO-16 has been completed on all the A train equipment.
4. Maintenance has been completed on the 1B-B D/G and the clearance has been removed.
5. The D/G has been rolled and is in standby alignment using 0-SO-82-2.
6. The AUO at the D/G building has completed Appendix A of 1-SI-OPS-082-007.B and all parameters are within limits. Two AUO's are standing by for DG start.
7. The U1 Control Room AUO has verified breaker 1934 is in the Disconnect position.
8. D/G-DAQ has been installed.
9. Room fire protection is in service.
10. The U1 US/SRO has reviewed the completed work package for the 1B-B D/G, all that remains is to perform 1-SI-OPS-082-007.B for the PMT.
11. Section 4.0 and Appendix A of 1-SI-OPS-082-007.B are complete.
12. Section 6.1 is complete thru step 6.

### **INITIATING CUES:**

1. Perform 1-SI-OPS-082-007.B, beginning with Section 6.1, step 7.c.

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><u>STEP 1.:</u> Operator obtains a copy of the appropriate procedure.</p> <p><b>NOTE:</b> Initial conditions cover steps in procedure up to the transition to Appendix "C".</p> <p><u>STANDARD:</u> Operator obtains a copy of 1-SI-OPS-082-007.B. Begins in section 6.1, Step 7.c, and transitions to Appendix C.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>
Appendix C		
<p><u>STEP 2.:</u> [1] <b>ENSURE</b> 0-HS-82-48 1B-B D/G mode selector switch in the UNIT position.</p> <p><u>STANDARD:</u> 0-HS-82-48 in UNIT position on 0-M-26. Green light ON.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 3.:</u> [2] <b>PLACE</b> 1-HS-57-74 D/G 1B-B Synchronize Switch in the SYN position.</p> <p><b>NOTE:</b> 0-EI-82-35 and 0-XI-82-33 will indicate running voltage &amp; frequency.</p> <p><u>STANDARD:</u> 1-HS-57-74 in "SYN" position on 0-M-26</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>NOTE</u> Operator may discuss notes preceding step 3 with the DAQ operator and the stopwatch operator to ensure expectations for starting and stopping the DAQ and Stopwatches are clear.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4.</u> [3] <b>PERFORM</b> the following to initiate D/G start signal: [3.1]<b>IF</b> the D/G DAQ is to be used, <b>THEN</b> <b>NOTIFY</b> D/G-DAQ Operator to <b>START</b> the D/G-DAQ.</p> <p><b>NOTE:</b> Operator must coordinate the start of the D/G-DAQ just prior to D/G start actuation.</p> <p><b>CUE:</b> Tell D/G operator there is extra operator that will time the DG start with a stopwatch.</p> <p><u>STANDARD:</u> Operator notifies the <b>D/G-DAQ</b> operator to start the <b>D/G-DAQ</b>.</p>		

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b><u>NOTE:</u></b> The DG operator will NOT be able to operate the stop watch alone. Another operator simulates the DG start timing. Only one stopwatch is required since the DAC is used.</p> <p><b><u>STEP 5.:</u></b> [3.2] <b>PROCEED</b> with the countdown: 3,2,1, START.</p> <p><b><u>STANDARD:</u></b> Operator ensures operator is ready with stop watch and announces the countdown to start the D/G. Only one stopwatch is required since the DAQ is being used.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b><u>STEP 6.:</u></b> [3.3] <b>DEPRESS</b> 0-HS-82-46A, DG 1B-B Emergency Start Switch <b>AND START</b> Stopwatch(es).</p> <p><b><u>STANDARD:</u></b> 0-HS-82-46A momentarily depressed. Green light will go "out" and red light will come "on" above D/G mimic. [Not critical: Stop watch is started. D/G running alarm will ANN to indicate D/G &gt; 40 rpm. Incoming voltage and frequency are verified on 0-EI-82-34 and 0-XI-82-32.]</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b><u>STEP 7.:</u></b> [3.4] When voltage &gt;6800 volts and Frequency &gt;58.8 HZ, THEN STOP stopwatch.</p> <p><b><u>STANDARD:</u></b> Stop stopwatch when voltage &gt;6800 volts and Frequency &gt;58.8 HZ.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b><u>STEP 8.:</u></b> [4] <b>ENSURE</b> 1-FCV-67-67, ERCW cooling water supply valve is OPEN.</p> <p><b><u>STANDARD:</u></b> ERCW valve 1-FCV-67-67 red light comes "on" and green light goes "out" on 0-M-27A panel.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b><u>STEP 9.:</u></b> [5] Record the time from the Stopwatches:</p> <p><b><u>CUE:</u></b> <b>STOP WATCH E123, TIME 9.5 SECONDS</b></p> <p><b><u>STANDARD:</u></b> Operator records the stop watch ID number and seconds for DG start and checks acceptance criteria met: &lt;10 seconds Generator Voltage ≥ 6800 V Frequency ≥ 58.8 Hz</p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 10.:</b> [6] <b>RECORD</b> the steady state values for the following:</p> <p>A. 0-EI-82-34, DG 1B-B incoming Voltage. B. 0-XI-82-32, DG 1B-B incoming Frequency.</p> <p><b>STANDARD:</b> Operator records <b>D/G voltage</b> (as indicated on INC Voltage Gen 1B-B 0-EI-34) is <math>\geq 6800</math> but <math>\leq 7260</math> volts and <b>frequency</b> (as indicated on INC Freq Gen 1B-B 0-XI-82-32) is <math>\geq 59.9</math> Hz and <math>\leq 60.1</math> Hz Checks acceptance criteria to verify readings are within limits</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 11.:</b> [7] <b>RECORD</b> Voltage Regulator Control Current.</p> <p><b>Cue:</b> <i>Voltage Regulator Control Current is 1.8 dc amps.</i></p> <p><b>STANDARD:</b> Operator records Voltage Regulator Control Current.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 12.:</b> [8] <b>ENSURE</b> D/G 1B-B <b>86 LOR</b> red light NOT ILLUMINATED, at D/G local relay panel.</p> <p><b>Cue:</b> <i>Role play as D/G operator - 86 LOR local red light is not illuminated.</i></p> <p><b>STANDARD</b> Operator verifies red light on 86 LOR at D/G is not illuminated.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 13.:</b> [9] <b>RESET 86 LOR</b> lockout relay, on D/G local relay panel.</p> <p><b>Cue:</b> <b>When the D/G AUO is requested to reset 86LOR, the Console operator should insert IRF EGR08 f:1 to reset 86LOR and then notify operator - 86 LOR is reset.</b></p> <p><b>STANDARD:</b> 86 LOR is reset locally, operator continues.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 14.:</b> [10] <b>VERIFY</b> [86LOR] reset by amber light 0-XI-82-49 illuminated on 0-M-26.</p> <p><b>STANDARD:</b> Operator verifies Amber light on 0-M-26 is lit.</p>	<p>___ SAT</p> <p>___ UNSAT</p>



Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>STEP 15.:</b> [11] <b>IF</b> the D/G-DAQ was used , <b>THEN</b> <b>RECORD</b> the time required to achieve <math>\geq 58.8</math> HZ and <math>\geq 6800</math> Volts from the <b>D/G-DAQ</b> computer.</p> <p><b>NOTE:</b> Evaluator can initial for DG-DAQ Operator if asked</p> <p><b>Cue:</b> <i>Time was 9.5 seconds for D/G-DAQ.</i></p> <p><b>STANDARD:</b> Operator checks acceptance criteria met, in &lt; 10 seconds generator voltage <math>\geq 6800</math> volts and frequency <math>\geq 58.8</math> Hz.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 16.:</b> [12] IF step 1.0[6] is &lt;59.9 or &gt;60.1, THEN INITIATE a PER.</p> <p><b>STANDARD:</b> Parameters in Step 1.0 [6] were within limits, no PER required, operator N/A's step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 17.:</b> [13] <b>RECORD</b> start as ambient in 0-SI-OPS-082-007.M.</p> <p><b>CUE:</b> <b>Another operator will record D/G start in 0-SI-OPS-082-007.M.</b></p> <p><b>STANDARD:</b> Operator addresses logging the start in 0-SI-OPS-082-007.M.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 18.:</b> [14] <b>RETURN</b> to Section 6.1, Step 10.</p> <p><b>STANDARD:</b> Operator returns to the appropriate section and step of the procedure. (Exits Appendix C)</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<b>Section 6.1 Step 10</b>		
<p><b>STEP 19.:</b> [10] <b>PERFORM</b> the following to wipe the Automatic Voltage Control Rheostat:</p> <p>[10.1] <b>RECORD</b> voltage from 0-EI-82-34.</p> <p><b>STANDARD:</b> OPERATOR records voltage and continues with next step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 20.:</b> [10.2] <b>ENSURE</b> 0-HS-82-42, DG 1B-B Voltage Regulator Switch in the Pull-to P-AUTO position</p> <p><b>STANDARD:</b> Operator verifies 0-HS-82-42 in the Pull To PAUTO position.</p>		<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 21.:</u> [10.3] <b>DECREASE</b> voltage to 6700 volts on 0-EI-82-34 using 0-HS-82-42.</p> <p><u>STANDARD:</u> Operator decreases voltage to 6700 volts on EI-82-34.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 22.:</u> [10.4] <b>INCREASE</b> voltage to 7300 volts on 0-EI-82-34 using 0-HS-82-42.</p> <p><u>STANDARD:</u> Operator increases voltage to 7300 volts on EI-82-34.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 23.:</u> [10.5] <b>RETURN</b> voltage to value recorded in 6.1 [10.1]</p> <p><u>STANDARD:</u> Operator returns voltage to reading recorded in step 6.1[10.1], ~ 7000 Volts (+/- 200 volts)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 24.:</u> [11] <b>PLACE</b> 0-HS-82-48, DG 1B-B Mode Selector Switch, in PARALLEL position.</p> <p><u>STANDARD:</u> 0-HS-82-48 rotated to the PARALLEL position. Red light "on" &amp; green light "off".</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>EVALUATOR NOTE:</u> While operator is adjusting the speed control in the next step have console operator insert IMF AN-OV-958 f:2</p>	
<p><u>STEP 25.:</u> [12] <b>ADJUST</b> 0-HS-82-43 DG 1B-B Speed Control Switch to obtain a synchroscope indication of slowly rotating in FAST direction.</p> <p><u>STANDARD:</u> Operator adjusts speed control hand switch 0-HS-82-43 such that synchroscope (XI-82-31) is moving slowly in the fast direction (slowly clockwise).</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p>The steps [27] thru [29] are from 0-AR-M26-B</p>	
<p><u>STEP 26.:</u> <b>RESPOND TO</b> annunciator panel 0-M-26B window D-2.</p> <p><u>STANDARD:</u> Operator pulls AR 0-M-26B and consults for window D-2, OR depresses the emergency stop button for D/G 1B-B.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 27.:</u> [1] <b>IF</b> D/G running with no valid accident (blackout or SI) signal present, <b>THEN ENSURE</b> D/G shutdown by depressing emergency stop pushbutton 0-HS-82-47A.</p> <p><u>STANDARD:</u> Operator depresses emergency stop button for Diesel Generator 1B-B.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 28.:</b> [2] <b>IF</b> D/G running with valid accident (blackout or SI) signal present...</p> <p><b>STANDARD:</b> Operator N/A's this step, D/G is being run for PMT.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 29.:</b> [3] <b>DISPATCH</b> personnel to D/G Bldg to verify alarm, <b>AND CHECK</b> crankcase trip device actuated [0-PS-82-5026/2] or [0-PS-82-5025/2].</p> <p><b>Cue:</b> <i>AUO informs Unit Operator that crankcase pressure alarm is in on local panel and 0-PS-82-5026/2 is actuated on engine 2.</i></p> <p><b>STANDARD:</b> Operator contacts AUO at the Diesel Generator Building to confirm crankcase pressure alarm.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 30.:</b> <b>NOTIFY</b> US/SRO of Emergency Stop of Diesel Generator 1B-B.</p> <p><b>Cue:</b> <i>US/SRO instructs operator to standby for further instructions.</i></p> <p><b>STANDARD:</b> Operator informs US/SRO of Emergency stop of Diesel Generator 1B-B.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Stop Time___</p>

END of JPM

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. Both units are at 100% RTP.
2. All systems are OPERABLE, except for the 1B-B D/G.
3. 0-GO-16 has been completed on all the A train equipment.
4. Maintenance has been completed on the 1B-B D/G and the clearance has been removed.
5. The D/G has been rolled and is in standby alignment using 0-SO-82-2.
6. The AUO at the D/G building has completed Appendix A of 1-SI-OPS-082-007.B and all parameters are within limits. Two AUO's are standing by for DG start.
7. The U1 Control Room AUO has verified breaker 1934 is in the Disconnect position.
8. D/G-DAQ has been installed.
9. Room fire protection is in service.
10. The U1 US/SRO has reviewed the completed work package for the 1B-B D/G, all that remains is to perform 1-SI-OPS-082-007.B for the PMT.
11. Section 4.0 and Appendix A of 1-SI-OPS-082-007.B are complete.
12. Section 6.1 is complete thru step 6.

### INITIATING CUES:

1. Perform 1-SI-OPS-082-007.B, beginning with Section 6.1, step 7.c.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM13AP1-1

### Transfer to Hot Leg Recirculation

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	New JPM adapted from JPM 13AP1 for NRC exam 02 2010, updated special instructions to the evaluator, added Appendix A with Hot Leg Recirc flowpath and major valve manipulations for examiner. Revised to end JPM after flow established for train A SI pump.	Y	1/18/10	All	M Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

### Transfer to Hot Leg Recirculation

006020 A4.02 (3.9/3.8)

[illegible]

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Critical steps identified.
2. Any UNSAT requires comments.
3. Initialize Simulator to IC #120, after automatic containment sump swapover is initiated, perform required alignment of ECCS to Containment Sump per ES-1.3. Insert the following remote functions:
  - a. **IRF RHR14 f:1** (FCV-63-1)
  - b. **IRF SIR06 f:0** (FCV-63-22) (Verify power on during setup)
  - c. **IOR ZDIHS63172A f:0 (Fails FCV-63-172 closed)**
5. If sump recirc IC is not available, then initialize to IC #16 and complete the following setup:
  - a. Insert **IMF TH01A f:10** (10% LOCA on Loop #1 Hot Leg) and trip RCPs.
  - b. After automatic containment sump swapover is initiated, perform required alignment of ECCS to containment sump per ES-1.3.
  - c. Place operating power on FCV-63-1 (remote function **IRF RHR14 f:1**).
  - d. When RWST level decreases to 8% realign containment spray pump suction to containment sump per ES-1.3.
  - e. Ensure operating power **ON** FCV-63-22 (Check remote function main menu for **IRF SIR06 f:0**, this task should have been performed in E-1).
  - f. Insert override **IOR ZDIHS63172A f:0 (Fails [FCV-63-172] CLOSED)**
  - g. Acknowledge and clear ALL alarms.
  - h. Freeze simulator after realignment of containment spray suction to containment sump.
6. Insert overrides to silence following nuisance alarms:
  - a. **IMF AN\_OV\_304 f:3** (Saturation Margin Trouble)
  - b. **IMF AN\_OV\_420 f:3** (Lower Compt Moisture High)
  - c. **IMF AN\_OV\_96 f:3** (Turbine Zero Speed)
  - d. Change plaque next to FCV-63-22 to indicate power restored to valve.
7. Ensure Operator performs the following required actions for **SELF-CHECKING**;
  - a. Reviews the intended action and expected response.
  - b. Compares the actual response to the expected response.
8. Appendix A Hot Leg Recirculation Flowpath is available for examiner.

**Validation Time: CR. 15 mins Local \_\_\_\_\_**

**Tools/Equipment/Procedures Needed:**

ES-1.4, Transfer to Hot Leg Recirculation

**References:**

	Reference	Title	Rev No.
1.	ES-1.4	Transfer to Hot Leg Recirculation	5



**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

1. All ECCS components and Containment Spray pumps are aligned and taking suction from containment sump per ES-1.3, Transfer To RHR Containment Sump.
2. RCS pressure is less than 180 psig. RHR spray is NOT in service.
3. Both RHR pumps are in service.
4. 5 hours have elapsed since the time of the event.

**INITIATING CUES:**

1. As the OATC, you are directed to transfer to hot leg recirculation in accordance with ES-1.4, Transfer to Hot Leg Recirculation.
2. Notify the US/SRO when you have completed ES-1.4.

Job Performance Checklist:

**STEP/STANDARD**

**SAT/UNSAT**

<p><b>STEP 1:</b> Obtain a copy of the appropriate procedure.</p> <p><b>STANDARD:</b> Operator obtains a copy of ES-1.4.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time ____</p>
<p><b>STEP 2:</b></p> <p>1. DETERMINE if RHR spray should be isolated:</p> <p>a. CHECK RHR spray IN SERVICE:</p> <ul style="list-style-type: none"> <li>• Train A RHR spray valve FCV-72-40 OPEN</li> <li>OR</li> <li>• Train B RHR spray valve FCV-72-41 OPEN.</li> </ul> <p><b>STANDARD:</b> Operator determines FCV-72-40 and FCV-72-41 closed, verifies green lights ON and red lights OFF for both valves. Operator goes to RNO step [a] and then proceeds to step 2.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 3:</b></p> <p>2. CHECK RHR pump A-A RUNNING.</p> <p><b>STANDARD:</b> Operator checks RHR pump A-A running, verifies red light ON and green light OFF. Operator may also verify pump amps normal (EI-74-5A).</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP *4:</b></p> <p>3. ALIGN RHR Train A for hot leg recirculation:</p> <p>a. CLOSE RHR Train A cold leg isolation valve FCV-63-93.</p> <p><b>NOTE:</b> Alarm on M-6D, window E-6, Group 6 Monitor Lights Component Off Normal will come in when FCV-63-93 is closed.</p> <p><b>STANDARD:</b> Operator places FCV-63-93 to Close, verifies green light ON and red light OFF.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

**STEP/STANDARD**

**SAT/UNSAT**

<p><u>STEP 5:</u>      3. ALIGN RHR Train A for hot leg recirculation: b. ENSURE RHR Train B discharge crosstie valve FCV-74-35 CLOSED.</p> <p><u>STANDARD:</u> Operator ensures FCV-74-35 Closed, verifies green light ON and red light OFF.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *6:</u>      3. ALIGN RHR Train A for hot leg recirculation: c. OPEN RHR Train A discharge crosstie valve FCV-74-33.</p> <p><u>STANDARD:</u> Operator places FCV-74-33 to Open, verifies red light ON and green light OFF.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP *7:</u>      3. ALIGN RHR Train A for hot leg recirculation: d. OPEN RHR HL injection valve FCV-63-172.</p> <p><u>NOTE:</u>      <b>FCV-63-172 fails to open. Operator must transition to RNO Column and realign RHR trains to cold legs.</b></p> <p><u>STANDARD:</u> Operator places FCV-63-172 to Open. Operator determines FCV-63-172 will NOT open, verifies green light remains ON. Operator goes to RNO Column.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>NOTE:</u>      <b>Begin alternate path steps, RNO for Step 3:</b></p> <p><u>STEP 8:</u>      1) ENSURE RHR hot leg injection valve FCV-63-172 CLOSED.</p> <p><u>STANDARD:</u> Operator ensures FCV-63-172 Closed, verifies green light ON and red light OFF.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

**STEP/STANDARD**

**SAT/UNSAT**

<p><u>STEP *9:</u>      2) ENSURE RHR Train A discharge crosstie valve FCV-74-33 CLOSED.</p> <p><u>STANDARD:</u> Operator places FCV-74-33 to Close, verifies green light ON and red light OFF.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP *10:</u>      3) ENSURE RHR Train A cold leg isolation valve FCV-63-93 OPEN.</p> <p><b>NOTE:</b>      <b>Alarm on M-6D, window E-6, Group 6 Monitor Lights Component Off Normal will clear when FCV-63-93 is open.</b></p> <p><u>STANDARD:</u> Operator places FCV-63-93 to Open, verifies red light ON and green light OFF.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><u>STEP 11:</u>      4) IF FCV-63-172 is NOT capable of opening from MCR, THEN GO TO Step 11.</p> <p><u>STANDARD:</u> Operator determines FCV-63-172 not able to be opened and goes to Step 11.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 12:</u>      11. CHECK SI pump A-A RUNNING.</p> <p><u>STANDARD:</u> Operator checks SI pump A-A running, verifies red light ON and green light OFF.</p> <p>Operator may also verify pump amps normal on 1-EI-63-12A.</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP *13:</u>      12. ALIGN SI pump A-A for hot leg recirculation: a. ENSURE SI pump A-A STOPPED.</p> <p><u>STANDARD:</u> Operator places SI pump A-A to Stop, verifies green light ON and red light OFF (HS-63-10A).</p> <p><u>COMMENTS:</u></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

**STEP/STANDARD**

**SAT/UNSAT**

<p><b>STEP *14:</b> 12. ALIGN SI pump A-A for hot leg recirculation: b. CLOSE SI Train A crosstie valve FCV-63-152.</p> <p><b>NOTE</b> Alarm on M-6D, window E-6, Group 6 Monitor Lights Component Off Normal will come in when FCV-63-152 is fully closed.</p> <p><b>STANDARD:</b> Operator places FCV-63-152 to Close, verifies green light ON and red light OFF.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP *15:</b> 12. ALIGN SI pump A-A for hot leg recirculation: c. WHEN FCV-63-152 closed, THEN PERFORM the following: 1) OPEN SI Train A hot leg injection FCV-63-156.</p> <p><b>STANDARD:</b> Operator places FCV-63-156 to Open, verifies red light ON and green light OFF.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP *16:</b> 12. ALIGN SI pump A-A for hot leg recirculation: c. WHEN FCV-63-152 closed, THEN PERFORM the following: 2) START SI pump A-A.</p> <p><b>STANDARD:</b> Operator places SI pump A-A to Start, verifies red light ON and green light OFF (HS-63-10A). Operator may also verify pump amps normal on 1-EI-63-12A.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>NOTE</b> JPM will be terminated when operator establishes SI Train A flow on FI-63-151.</p> <p><b>STEP 17:</b> 13. VERIFY SI Train A discharge flow on FI-63-151.</p> <p><b>STANDARD:</b> Operator verifies SI Train A discharge flow indicated on FI-63-151.</p> <p><b>CUE:</b> Tell operator JPM is terminated at this step.</p> <p><b>COMMENTS:</b></p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>_____ Stop Time</p>

END of JPM

**After both SI pumps aligned for Hot Leg Recirculation  
Close FCV-63-22 SI pump CL injection**

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM. I will provide initiating cues and reports on other actions when directed by you. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

1. All ECCS components and Containment Spray pumps are aligned and taking suction from containment sump per ES-1.3, Transfer To RHR Containment Sump.
2. RCS pressure is less than 180 psig. RHR spray is NOT in service.
3. Both RHR pumps are in service.
4. 5 hours have elapsed since the time of the event.

### INITIATING CUES:

1. As the OATC, you are directed to transfer to hot leg recirculation in accordance with ES-1.4, Transfer to Hot Leg Recirculation.
2. Notify the US/SRO when you have completed ES-1.4.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM # 189AP

### Radiation Monitor 0-RE-90-122 Flushing After Hi Radiation Signal Isolation of Release (Alternate Path)

**PREPARED/  
REVISED BY:**

\_\_\_\_\_  
Date/

**VALIDATED BY:**

\*

\_\_\_\_\_  
Date/

**APPROVED BY:**

\_\_\_\_\_  
Date/

(Operations Training Manager)

**CONCURRED:**

\*\*

\_\_\_\_\_  
Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).



## NUCLEAR TRAINING

### REVISION/USAGE LOG

REVISION NUMBER		V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	Initial Issue	Y	1/19/04	All	S. Poteet
1	Revised to update to latest procedure revision	Y	12/07/09	ALL	M. Hankins

V - Specify if the JPM change will require another Validation (Y or N).  
See cover sheet for criteria.

Radiation Monitor 0-RE-90-122 Flushing After Hi Radiation Signal Isolation of Release.

068 K6.10 (2.5/2.9)

The operator completes flushing of 0-RE-90-122 after isolation due to high radiation.

© 2008 Pearson Education, Inc. All rights reserved. This publication is protected by copyright. Any unauthorized distribution or reproduction of this work may result in legal action against the individual(s) responsible.

Start Time

Finish Time

1997 1998 1999 2000 2001 2002 2003 2004 2005 2006 2007 2008 2009 2010 2011 2012 2013 2014 2015 2016 2017 2018 2019 2020 2021 2022 2023 2024 2025 2026 2027 2028 2029 2030 2031 2032 2033 2034 2035 2036 2037 2038 2039 2040 2041 2042 2043 2044 2045 2046 2047 2048 2049 2050 2051 2052 2053 2054 2055 2056 2057 2058 2059 2060 2061 2062 2063 2064 2065 2066 2067 2068 2069 2070 2071 2072 2073 2074 2075 2076 2077 2078 2079 2080 2081 2082 2083 2084 2085 2086 2087 2088 2089 2090 2091 2092 2093 2094 2095 2096 2097 2098 2099 2100 2101 2102 2103 2104 2105 2106 2107 2108 2109 2110 2111 2112 2113 2114 2115 2116 2117 2118 2119 2120 2121 2122 2123 2124 2125 2126 2127 2128 2129 2130 2131 2132 2133 2134 2135 2136 2137 2138 2139 2140 2141 2142 2143 2144 2145 2146 2147 2148 2149 2150 2151 2152 2153 2154 2155 2156 2157 2158 2159 2160 2161 2162 2163 2164 2165 2166 2167 2168 2169 2170 2171 2172 2173 2174 2175 2176 2177 2178 2179 2180 2181 2182 2183 2184 2185 2186 2187 2188 2189 2190 2191 2192 2193 2194 2195 2196 2197 2198 2199 2200 2201 2202 2203 2204 2205 2206 2207 2208 2209 2210 2211 2212 2213 2214 2215 2216 2217 2218 2219 2220 2221 2222 2223 2224 2225 2226 2227 2228 2229 2230 2231 2232 2233 2234 2235 2236 2237 2238 2239 2240 2241 2242 2243 2244 2245 2246 2247 2248 2249 2250 2251 2252 2253 2254 2255 2256 2257 2258 2259 2260 2261 2262 2263 2264 2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283 2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302 2303 2304 2305 2306 2307 2308 2309 2310 2311 2312 2313 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2334 2335 2336 2337 2338 2339 2340 2341 2342 2343 2344 2345 2346 2347 2348 2349 2350 2351 2352 2353 2354 2355 2356 2357 2358 2359 2360 2361 2362 2363 2364 2365 2366 2367 2368 2369 2370 2371 2372 2373 2374 2375 2376 2377 2378 2379 2380 2381 2382 2383 2384 2385 2386 2387 2388 2389 2390 2391 2392 2393 2394 2395 2396 2397 2398 2399 2400 2401 2402 2403 2404 2405 2406 2407 2408 2409 2410 2411 2412 2413 2414 2415 2416 2417 2418 2419 2420 2421 2422 2423 2424 2425 2426 2427 2428 2429 2430 2431 2432 2433 2434 2435 2436 2437 2438 2439 2440 2441 2442 2443 2444 2445 2446 2447 2448 2449 2450 2451 2452 2453 2454 2455 2456 2457 2458 2459 2460 2461 2462 2463 2464 2465 2466 2467 2468 2469 2470 2471 2472 2473 2474 2475 2476 2477 2478 2479 2480 2481 2482 2483 2484 2485 2486 2487 2488 2489 2490 2491 2492 2493 2494 2495 2496 2497 2498 2499 2500 2501 2502 2503 2504 2505 2506 2507 2508 2509 2510 2511 2512 2513 2514 2515 2516 2517 2518 2519 2520 2521 2522 2523 2524 2525 2526 2527 2528 2529 2530 2531 2532 2533 2534 2535 2536 2537 2538 2539 2540 2541 2542 2543 2544 2545 2546 2547 2548 2549 2550 2551 2552 2553 2554 2555 2556 2557 2558 2559 2560 2561 2562 2563 2564 2565 2566 2567 2568 2569 2570 2571 2572 2573 2574 2575 2576 2577 2578 2579 2580 2581 2582 2583 2584 2585 2586 2587 2588 2589 2590 2591 2592 2593 2594 2595 2596 2597 2598 2599 2600 2601 2602 2603 2604 2605 2606 2607 2608 2609 2610 2611 2612 2613 2614 2615 2616 2617 2618 2619 2620 2621 2622 2623 2624 2625 2626 2627 2628 2629 2630 2631 2632 2633 2634 2635 2636 2637 2638 2639 2640 2641 2642 2643 2644 2645 2646 2647 2648 2649 2650 2651 2652 2653 2654 2655 2656 2657 2658 2659 2660 2661 2662 2663 2664 2665 2666 2667 2668 2669 2670 2671 2672 2673 2674 2675 2676 2677 2678 2679 2680 2681 2682 2683 2684 2685 2686 2687 2688 2689 2690 2691 2692 2693 2694 2695 2696 2697 2698 2699 2700 2701 2702 2703 2704 2705 2706 2707 2708 2709 2710 2711 2712 2713 2714 2715 2716 2717 2718 2719 2720 2721 2722 2723 2724 2725 2726 2727 2728 2729 2730 2731 2732 2733 2734 2735 2736 2737 2738 2739 2740 2741 2742 2743 2744 2745 2746 2747 2748 2749 2750 2751 2752 2753 2754 2755 2756 2757 2758 2759 2760 2761 2762 2763 2764 2765 2766 2767 2768 2769 2770 2771 2772 2773 2774 2775 2776 2777 2778 2779 2780 2781 2782 2783 2784 2785 2786 2787 2788 2789 2790 2791 2792 2793 2794 2795 2796 2797 2798 2799 2800 2801 2802 2803 2804 2805 2806 2807 2808 2809 2810 2811 2812 2813 2814 2

[illegible]

**SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Critical steps identified.
2. Any UNSAT requires comments
3. Ensure operator performs the following required actions for **SELF-CHECKING**:
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

Validation Time: CR. \_\_\_\_\_

Local 30 minutes

**Tools/Equipment/Procedures Needed**

0-SO-77-1 Section 8.2

**References:**

	Reference	Title	Rev No.
1.	0-SO-77-1	Waste Disposal System	47

=====

**READ TO OPERATOR**

**Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated for this JPM. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

**INITIAL CONDITIONS:**

1. A release from the CDCT has just been initiated using 0-SO-77-1 Waste Disposal System and 0-SI-CEM-077-400.1 Liquid Waste Effluent Batch Release.
2. The calculated high radiation trip setpoint for 0-RM-90-122 is 8.59 E+04 cpm, per 0-SI-CEM-077-400.1, Liquid Waste Effluent Batch Release.
3. A high radiation signal on 0-RE-90-122 occurred shortly after initiation of the release, causing an isolation of the release.
4. 0-RCV-77-43 has been verified CLOSED.
5. All Prerequisite Actions are complete (Section 4.0)

**INITIATING CUES:**

You are the RadWaste AUO and have been directed by the Unit 1 SRO to perform Section 8.2 of 0-SO-77-1 to flush 0-RE-90-122 after the High Radiation Isolation. Inform the Unit 1 SRO when Section 8.2 is complete.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 1.:</b> Obtain a copy of the appropriate procedure.</p> <p><b>STANDARD:</b> The operator obtains a copy of 0-SO-77-1, Section 8.2</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time _____</p>
<p><b>STEP 2.:</b> Section 4.0 Prerequisite Actions</p> <p><b>Cue:</b> <i>If asked, state all prerequisite actions are complete per initial conditions.</i></p> <p><b>STANDARD:</b> Operator may review Prerequisite Actions, but all steps have already been complete.</p>	
<p><b>STEP 3.:</b> [1] <b>ENSURE [0-RCV-77-43]</b> Radiation Control Valve is CLOSED.</p> <p><b>Cue:</b> <i>If asked, state 0-RCV-77-43 is closed per the Initial Conditions.</i></p> <p><b>STANDARD:</b> Operator verifies that valve is closed by reviewing INITIAL CONDITIONS portion of JPM, or can verify valve closed locally (AB el. 669', West Wall of SFP.)</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 4.:</b> [2] <b>ENSURE [0-77-689A]</b> Radiation Monitor Inlet isolation Valve is OPEN.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689A] is open.</i></p> <p><b>STANDARD:</b> Operator ensures [0-77-689A] Radiation Monitor Inlet isolation Valve is OPEN by turning HW in the CW direction only enough to verify valve movement (indicates the valve is open), and then returns valve to original position.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 5.:</b> [3] <b>OPEN [0-77-689B]</b> Discharge to FDCT Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689B] moves in the counter clockwise direction until snug.</i></p> <p><b>STANDARD:</b> Operator OPENS [0-77-689B] Discharge to FDCT Isolation Valve by turning HW in the CCW direction until HW is snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>STEP 6.:</b> [4] <b>CLOSE [0-77-689C]</b> Radiation Monitor Return to Release Header Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689C] moves in the clockwise direction until snug.</i></p> <p><b>STANDARD:</b> Operator CLOSES [0-77-689C] Radiation Monitor Return to Release Header Isolation Valve by turning HW in the CW direction until HW is snug.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 7.:</b> [5] <b>VERIFY [0-RE-90-122]</b> radiation monitor pump is running.</p> <p><b>Cue:</b> <i>0-HS-90-122B RED light ON; GREEN light OFF.</i></p> <p><b>STANDARD:</b> Operator verifies that [0-RE-90-122] radiation monitor pump is running.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 8.:</b> [6] <b>ALLOW [0-RE-90-122]</b> Radiation Monitor to flush to FDCT for 5 minutes.</p> <p><b>Cue:</b> <i>Inform operator that 5 minutes have elapsed.</i></p> <p><b>STANDARD:</b> Operator allows flush for at least 5 minutes prior to proceeding to next step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>STEP 9.:</b> [7] <b>OPEN [0-77-689C]</b></p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689C] moves in the counter clockwise direction until snug.</i></p> <p><b>STANDARD:</b> Operator OPENS [0-77-689C] Radiation Monitor Return to Release Header Isolation Valve by turning HW in the CCW direction until HW is snug.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP *10.:</b> [8] <b>CLOSE [0-77-689B]</b></p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689B] moves in the clockwise direction until snug.</i></p> <p><b>STANDARD:</b> Operator CLOSES [0-77-689B] Discharge to FDCT Isolation Valve by turning HW in the CW direction until HW is snug.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT								
<p><b>STEP 11.:</b> [9] <b>RECORD</b> 0-RE-90-122 reading:</p> <p>0-RE-90-122 Reading _____ cpm</p> <p><b>NOTE:</b> <b>ALTERNATE PATH BEGINS HERE.</b></p> <p><b>Cue:</b> <i>Inform operator that 0-RE-90-122 is reading 9.00 E+04 cpm</i></p> <p><b>STANDARD:</b> Operator enters 9.00 E+04 cpm for 0-RE-90-122 data.</p>	<p>___ SAT</p> <p>___ UNSAT</p>									
<p><b>STEP * 12.:</b> [10] <b>IF</b> the reading in step [9] is below the trip setpoint. <b>THEN RETURN</b> to instruction where exited</p> <p><b>NOTE:</b> <b>RE high radiation trip setpoint, 8.59 E+04 cpm, was provided in the INITIAL CONDITIONS.</b></p> <p><b>STANDARD:</b> Operator determines that the current 0-RE-90-122 reading remained greater than the trip setpoint 8.59 E+04 cpm and continues with step [11].</p>	<p>___ SAT</p> <p>___ UNSAT</p>									
<p><b>STEP 13.:</b> [11] <b>IF</b> the reading obtained in step [9] is still above the trip setpoint, <b>THEN PERFORM</b> the following steps to lower the radiation monitoring reading:</p> <p><b>NOTE:</b> <b>Valve is located in CDCT room</b></p> <p>[11.a] <b>CLOSE</b> applicable tank isolation valve from release header. (N/A tanks not aligned)</p> <table border="1"> <thead> <tr> <th>Tank Being Released</th> <th>Isolation Valve</th> <th>Initials</th> </tr> </thead> <tbody> <tr> <td>CDCT</td> <td>0-77-679</td> <td>_____</td> </tr> <tr> <td>Monitor Tank</td> <td>0-77-1306</td> <td>_____</td> </tr> </tbody> </table> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-679] moves in the clockwise direction until snug.</i></p> <p><b>STANDARD:</b> Operator CLOSSES [0-77-679] Cask Decon Collector Tank by turning HW in the CW direction until HW is snug. Operator enters an "N/A" for the Monitor Tank.</p>	Tank Being Released	Isolation Valve	Initials	CDCT	0-77-679	_____	Monitor Tank	0-77-1306	_____	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
Tank Being Released	Isolation Valve	Initials								
CDCT	0-77-679	_____								
Monitor Tank	0-77-1306	_____								

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><b>NOTE:</b> Valve is located in CDCT room.</p> <p>STEP14.: [11.b] <b>OPEN [0-VLV-59-735]</b> Demin Flush To Radwaste Isol.</p> <p><b>Cue:</b> <i>Inform the operator that the handle for [0-VLV-59-735] moves in the counter clockwise direction until handle is in line with pipe.</i></p> <p>STANDARD: Operator OPENS [0-VLV-59-735] Demin Flush To Radwaste Isol by turning handle in the CCW direction until handle is in line with pipe.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p>STEP15.: [11.c] <b>OPEN [0-77-689B]</b> Discharge to FDCT Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689B] moves in the counter clockwise direction until snug.</i></p> <p>STANDARD: Operator OPENS [0-77-689B] Discharge to FDCT Isolation Valve by turning HW in the CCW direction until HW is snug.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p>STEP 16.: [11.d] <b>CLOSE [0-77-689C]</b> Radiation Monitor Return to Release Header Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689C] moves in the clockwise direction until snug.</i></p> <p>STANDARD: Operator CLOSES [0-77-689C] Radiation Monitor Return to Release Header Isolation Valve by turning HW in the CW direction until HW is snug.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p>STEP 17.: [11.e] <b>WHEN</b> count rate on [0-RE-90-122] decreases to its minimum value, <b>THEN</b></p> <p><b>Cue:</b> <i>0-RE-90-122 reading has lowered to 8.00 E+02 cpm and is stable.</i></p> <p>STANDARD: Operator reads count rate on 0-RE-90-122.</p>		<p>___ SAT</p> <p>___ UNSAT</p>

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT								
<p>STEP 18.: [11.e.1] <b>OPEN [0-77-689C]</b> Radiation Monitor Return to Release Header Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689C] moves in the counterclockwise direction until snug.</i></p> <p>STANDARD: Operator OPENS [0-77-689C] Radiation Monitor Return to Release Header Isolation Valve by turning HW in the CCW direction until HW is snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>									
<p>STEP 19.: [11.e.2] <b>CLOSE [0-77-689B]</b> Discharge to FDCT Isolation Valve.</p> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-689B] moves in the clockwise direction until snug.</i></p> <p>STANDARD: Operator CLOSES [0-77-689B] Discharge to FDCT Isolation Valve by turning HW in the CW direction until HW is snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>									
<p>STEP 20.: [11.f] <b>CLOSE [0-VLV-59-735]</b> Demin Flush To Radwaste Isol.</p> <p><b>Cue:</b> <i>Inform the operator that the handle for [0-VLV-59-735] moves in the clockwise direction until perpendicular with pipe.</i></p> <p>STANDARD: Operator CLOSES [0-VLV-59-735] Demin Flush To Radwaste Isol by turning handle until handle is perpendicular with pipe.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>									
<p>STEP 21.: [11.g] <b>OPEN</b> applicable tank isolation valve previously closed in step [a] (N/A tanks not aligned):</p> <table border="1" data-bbox="354 1377 1102 1495"> <thead> <tr> <th>Tank Being Released</th> <th>Isolation Valve</th> <th>Initials</th> </tr> </thead> <tbody> <tr> <td>CDCT</td> <td>0-77-679</td> <td>_____</td> </tr> <tr> <td>Monitor Tank</td> <td>0-77-1306</td> <td>_____</td> </tr> </tbody> </table> <p><b>Cue:</b> <i>Inform the operator that the HW for [0-77-679] moves in the counter clockwise direction until snug.</i></p> <p>STANDARD: Operator OPENS [0-77-679] Cask Decon Collector Tank by turning HW in the CCW direction until HW is snug, and N/A's valve for the Monitor Tank.</p>	Tank Being Released	Isolation Valve	Initials	CDCT	0-77-679	_____	Monitor Tank	0-77-1306	_____	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
Tank Being Released	Isolation Valve	Initials								
CDCT	0-77-679	_____								
Monitor Tank	0-77-1306	_____								



Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p>STEP 22.: [h] <b>IF</b> hi radiation alarm will not clear, <b>THEN NOTIFY</b> the appropriate US/SRO that alarm will not clear.</p> <p><b><u>Cue:</u></b> <i>0-RE-90-122 high radiation alarm is clear</i> <i>If asked, rad monitor 0-RE-90-122 is still reading 8.00 E+2 cpm.</i></p> <p><b>STANDARD:</b> Operator determines that 0-RE-90-122 alarm has cleared by observing verifying XA-55-L2C Window C-3 DARK in RadWaste AUO shack OR Calling Main Control Room and verifying alarm status.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p>STEP 23.: [12] <b>RETURN</b> to instruction where exited.</p> <p><b>STANDARD:</b> Operator informs Unit 1 US/SRO that 0-SO-77-1 is complete</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>End Time___</p>

**End of JPM**

## READ TO OPERATOR

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated for this JPM. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

1. A release from the CDCT has just been initiated using 0-SO-77-1 Waste Disposal System and 0-SI-CEM-077-400.1 Liquid Waste Effluent Batch Release.
2. The calculated high radiation trip setpoint for 0-RM-90-122 is 8.59 E+04 cpm, per 0-SI-CEM-077-400.1, Liquid Waste Effluent Batch Release.
3. A high radiation signal on 0-RE-90-122 occurred shortly after initiation of the release, causing an isolation of the release.
4. 0-RCV-77-43 has been verified CLOSED.
5. All Prerequisite Actions are complete (Section 4.0)

### **INITIATING CUES:**

You are the RadWaste AUO and have been directed by the Unit 1 SRO to perform Section 8.2 of 0-SO-77-1 to flush 0-RE-90-122 after the High Radiation Isolation. Inform the Unit 1 SRO when Section 8.2 is complete.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM # 44

Venting the A-A RHR Pump due to  
Cavitation While in Mid-Loop Operation

PREPARED/  
REVISED BY:

Date/

VALIDATED BY:

\*

Date/

APPROVED BY:

Date/

(Operations Training Manager)

CONCURRED:

\*\*

Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
1	Transfer from WP. Minor enhancements.	N	8/31/95	All	HJ Birch
2	Incorp prev pen/ink which chgd performance time from 20 to 24. AOP-R.03 replaced AOI-14. Minor JPM chgs to match new procedure	N	3/5/96	3,4,5	HJ Birch
pen/ink	AOP-R.03 Rev chg. Procedure step 14d referenced in JPM became 15d.	N	6/8/96	4,5,8	HJ Birch
pen/ink	AOP-R.03 Rev chg added train designation to valves. For JPM to save confusion: added a note that valves in ( ) are B Train.	N	2/6/97	4,5	HJ Birch
pen/ink	AOP-R.03 Rev chg only requal comment - FCV is normally blocked. Chg cue to block fell off.	N	8/12/97	4	HJ Birch
		N	5/13/98	4	HJ Birch
pen/ink	AOP R.03 revision had no impact. Revised K/A ratings. Reformatted critical steps.	N	8/13/98	All	JP Kearney
pen/ink	AOP-R.03 revision had no impact. Updated procedure revision only	N	9/25/98	2,4	JP Kearney
pen/ink	AOP Rev Change only	N	9/22/99	4	SR Taylor
pen/ink	Corrected proceduredstep number references in initiating cues and in JPM steps 1 & 14 due to AOP Rev Change and updated rev level.	N	8/21/00	4,5,8	SR Taylor
pen/ink	Added item 7 to initial conditions to eliminate confusion during performance.	N	08/02/01	4	WR Ramsey
3	Incorporated pen/ink changes; revised per recent changes to AOP-R.03; No impact on JPM flow	N	8/20/02	4	J P Kearney
4	Updated to current revision.	N	9/15/04	All	MG Croteau
5	Updated to current revision.	N	10/03/05	All	MG Croteau
6	Proc chg eliminated several vlv manipulation steps.	Y	2/9/09	All	H J Birch
7	Update to divide JPM steps to reflect current procedure revision	Y	11/3/2009	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.

### **SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any **UNSAT** requires comments
2. ***This JPM may be performed on either unit or train depending on accessibility. The Evaluator MUST clearly specify which UNIT and TRAIN the task is to be performed on when reading the initial conditions and initiating cues.***
3. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.
4. If a ladder is needed to operate any equipment the trainee should locate a ladder and state that they would use the ladder to operate the valve, it is not necessary to bring the ladder to the work location.

**Validation Time:** CR. \_\_\_\_\_ **Local** 15 mins

### **Tools Needed:**

AOP-R.03, Section 2.1 step 17. and Appendix J

### **References:**

	Reference	Title	Rev No.
A.	AOP-R.03	RHR System Malfunctions	22

=====

### **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- 1) Unit \_\_\_ is in Mode 5 following a refueling outage.
- 2) The RCS is at Mid-loop with the A-A (B-B) RHR pump aligned for Shutdown Cooling.
- 3) Hoses are not installed at 74-512 and 513
- 4) The flow block gag device on discharge valve FCV-74-16 (74-28) on the A-A (B-B) RHR Hx fell off and the FCV failed full open, causing vortexing in the RCS loop, resulting in air being drawn into the A-A (B-B) RHR pump suction and pump casing.
- 5) Rad Con Techs are standing by to support the venting operation.
- 6) The A-A (B-B) RHR pump is in the Pull-to-Lock position.
- 7) Repairs have been completed on the flow block gag for FCV-74-16 (74-28) and the valve is now functional.

### **INITIATING CUES:**

- 1) The operators in the MCR have unsuccessfully attempted to get the A-A (B-B) RHR pump back in service.
- 2) You are the Unit\_\_\_ Aux. Bldg. AUO. You have been directed to locally vent the A-A (B-B) RHR pump using AOP-R.03 Using Appendix J.
- 3) When you have completed the local venting notify the CRO on the unit.

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><u>STEP 1.:</u> Obtain a copy of the appropriate procedure</p> <p><u>STANDARD:</u> Operator obtains a copy of AOP-R.03, Appendix J</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time ___</p>
<p><u>STEP 2.</u> OBTAIN M-5 key and radio.</p> <p><u>Cue:</u> <b>After explaining how to obtain M-5 Key and radios, inform operator that they have both.</b></p> <p><u>STANDARD:</u> Operator explains how to obtain M-5 Key and radios, procedure contains note stating keys may be obtained from AOP-C.04 cabinet or could be checked out from the Shift Manger clerks office, radios made be obtained from AUO work station (OFO), MCR, SM office</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 3.</u> <b>IDENTIFY</b> applicable unit:</p> <ul style="list-style-type: none"> <li>• Unit 1 _____</li> <li>• Unit 2 _____</li> </ul> <p><u>STANDARD:</u> Operator identifies proper unit as determined from the initiating cues</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 4.</u> <b>IDENTIFY</b> RHR Pump(s) to be vented (specified by MCR).</p> <ul style="list-style-type: none"> <li>• Train A _____</li> <li>• Train B _____</li> </ul> <p><u>STANDARD:</u> Operator identifies proper RHR pump as determined from the initiating cues</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><u>STEP 5.:</u> <b>UNLOCK</b> and <b>CLOSE</b> pump discharge valve on affected train: [RHR pump Room, 653']</p> <ul style="list-style-type: none"> <li>• 74-520 (Train A)</li> <li><b>OR</b></li> <li>• 74-521 (Train B)</li> </ul> <p><u>Cue:</u> <b>Lock is removed; HW turned several times in the CW direction and is now snug.</b></p> <p><u>STANDARD:</u> Operator locates VLV-74-520 (74-521), unlocks and turns the HW in the CW direction until snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 6.:</b>      <b>UNLOCK and OPEN</b> pump discharge vent on affected train:                          [RHR pump room]</p> <ul style="list-style-type: none"> <li>• 74-516 (Train A)</li> <li style="text-align: center;"><b>OR</b></li> <li>• 74-517 (Train B)</li> </ul> <p><b><u>Cue:</u></b>      <i>Lock is removed; HW turned several times in the CCW direction and is now snug.</i></p> <p><b><u>STANDARD:</u></b> Operator locates VLV-74-516 (74-517), unlocks and turns the HW in the CCW direction until snug and states that the valve will be open for approximately 10 minutes.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 7.:</b>      <b>VENT</b> for 10 minutes.</p> <p><b><u>Cue:</u></b>      <i>10 minutes have elapsed.</i></p> <p><b><u>STANDARD:</u></b> Operator states that once the valve is open they will vent for 10 minutes.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 8.:</b>      <b>CLOSE</b> RHR pump discharge vent valve on affected train:</p> <ul style="list-style-type: none"> <li>• 74-516 (Train A)</li> <li style="text-align: center;"><b>OR</b></li> <li>• 74-517 (Train B)</li> </ul> <p><b><u>Cue:</u></b>      <i>The HW turned several times in the CW direction and is now snug.</i></p> <p><b><u>STANDARD:</u></b> Operator locates valve 74-516 (74-517) turns the HW in the CW direction until snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 9.:</b>      <b>OPEN</b> RHR pump discharge valve on affected train.</p> <ul style="list-style-type: none"> <li>• 74-520 (Train A)</li> <li style="text-align: center;"><b>OR</b></li> <li>• 74-521 (Train B)</li> <li>•</li> </ul> <p><b><u>Cue:</u></b>      <i>The HW turned several times in the CCW direction and is now snug.</i></p> <p><b><u>STANDARD:</u></b> Operator locates VLV-74-520 (74-521), turns the HW in the CCW direction until snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b>STEP 10.:</b>      <b>FULLY OPEN</b> pressure transmitter instrument drain valve for 5 minutes on affected train: [Racks outside RHR pump room]</p> <ul style="list-style-type: none"> <li>• PT-74-13 (Train A)</li> </ul> <p style="text-align: center;"><b>OR</b></p> <ul style="list-style-type: none"> <li>• PT-47-26 (Train B)</li> </ul> <p><b>Cue:</b>      <i>HW turned CCW until snug, 5 minutes have elapsed.</i></p> <p><b>STANDARD:</b> Operator locates drain valve for PT-74-13 (26), turns HW in the CCW direction until snug, leaves open for 5 minutes.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 11.:</b>      <b>CLOSE</b> pressure transmitter instrument drain valve on affected train:</p> <ul style="list-style-type: none"> <li>• PT-74-13 (Train A)</li> </ul> <p style="text-align: center;"><b>OR</b></p> <ul style="list-style-type: none"> <li>• PT-47-26 (Train B)</li> </ul> <p><b>Cue:</b>      <i>HW turned CW until snug.</i></p> <p><b>STANDARD:</b> Operator turns HW in the CW direction until snug.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
<p><b>STEP 12.:</b>      <b>NOTIFY</b> MCR that RHR pump Venting is complete on the affected train.</p> <p><b>Cue:</b>      <i>Acknowledge report and instruct operator to resume normal duties.</i></p> <p><b>STANDARD:</b> Operator communicates with the UO in the MCR and informs him/her that the A-A (B-B) RHR pump has been vented in accordance with Appendix J of AOP-R.03.</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Stop Time___</p>

END OF JPM



## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- 1) Unit \_\_\_ is in Mode 5 following a refueling outage.
- 2) The RCS is at Mid-loop with the A-A (B-B) RHR pump aligned for Shutdown Cooling.
- 3) Hoses are not installed at 74-512 and 513.
- 4) The flow block gag device on discharge valve FCV-74-16 (74-28) on the A-A (B-B) RHR Hx fell off and the FCV failed full open, causing vortexing in the RCS loop, resulting in air being drawn into the A-A (B-B) RHR pump suction and pump casing.
- 5) Rad Con Techs are standing by to support the venting operation.
- 6) The A-A (B-B) RHR pump is in the Pull-to-Lock position.
- 7) Repairs have been completed on the flow block gag for FCV-74-16 (74-28) and the valve is now functional.

### **INITIATING CUES:**

- 1) The operators in the MCR have unsuccessfully attempted to get the A-A (B-B) RHR pump back in service.
- 2) You are the Unit\_\_\_ Aux. Bldg. AUO. You have been directed to locally vent the A-A (B-B) RHR pump using AOP-R.03 Using Appendix J.
- 3) When you have completed the local venting notify the CRO on the unit.

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated. I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- 1) Unit \_\_\_ is in Mode 5 following a refueling outage.
- 2) The RCS is at Mid-loop with the A-A (B-B) RHR pump aligned for Shutdown Cooling.
- 3) Hoses are not installed at 74-512 and 513.
- 4) The flow block gag device on discharge valve FCV-74-16 (74-28) on the A-A (B-B) RHR Hx fell off and the FCV failed full open, causing vortexing in the RCS loop, resulting in air being drawn into the A-A (B-B) RHR pump suction and pump casing.
- 5) Rad Con Techs are standing by to support the venting operation.
- 6) The A-A (B-B) RHR pump is in the Pull-to-Lock position.
- 7) Repairs have been completed on the flow block gag for FCV-74-16 (74-28) and the valve is now functional.

### **INITIATING CUES:**

- 1) The operators in the MCR have unsuccessfully attempted to get the A-A (B-B) RHR pump back in service.
- 2) You are the Unit\_\_\_ Aux. Bldg. AUO. You have been directed to locally vent the A-A (B-B) RHR pump using AOP-R.03 Using Appendix J.
- 3) When you have completed the local venting notify the CRO on the unit.

# SEQUOYAH NUCLEAR PLANT JOB PERFORMANCE MEASURE

## JPM # 91-1

### Transfer Controls to the Auxiliary Mode Per Checklist 3

PREPARED/  
REVISED BY:

\_\_\_\_\_ Date/

VALIDATED BY:

\*

\_\_\_\_\_ Date/

APPROVED BY:

\_\_\_\_\_ Date/

(Operations Training Manager)

CONCURRED:

\*\*

\_\_\_\_\_ Date/

(Operations Representative)

\* Validation not required for minor enhancements, procedure Rev changes that do not affect the JPM, or individual step changes that do not affect the flow of the JPM.

\*\* Operations Concurrence required for new JPMs and changes that affect the flow of the JPM (if not driven by a procedure revision).

NUCLEAR TRAINING					
REVISION/USAGE LOG					
REVISION NUMBER	DESCRIPTION OF REVISION	V	DATE	PAGES AFFECTED	PREPARED/ REVISED BY:
0	New JPM, adapted from JPM91AP, revised to require partial performance fo checklist 3, no alternate path. Also updated steps to latest procedure revision, revised steps concerning Time Critical Action Clock starts as addressed AOP-N.01.	Y	1/23/2010	All	M Hankins

V - Specify if the JPM change will require another validation (Y or N).  
See cover sheet for criteria.



### **SPECIAL INSTRUCTIONS TO EVALUATOR:**

1. Any **UNSAT** requires comments.
2. *The SHUTDOWN BOARD LOGIC CABINETS are not locked, it will NOT be necessary to open the cabinet, having the operator locate the correct cabinet and describing his/her actions will suffice.*
3. *The AOP-C.04 cabinet is sealed. It is not necessary to open the cabinet and retrieve the key. Having the operator locate the cabinet and discuss his/her actions will suffice.*
4. AOP-N.01 directs the operators to go to the AOP-C.04 cabinet in 6.9KV SDBD Rm via el. 690 radcon Portal to avoid entering the fire area. For this JPM students can enter the 6.9 KV SDBD thru the MCR. Access from the AB to the 6.9 KV SDBD is normally prohibited by RADCON, exception in emergencies.
5. Evaluators review Attachment 1 and 2.
6. The clock starts for time critical actions in AOP-C.04 when ANY of the conditions listed in AOP-N.01 Appendix E are met. Timing for Time Critical Actions in this JPM will start one minute prior to the operator being notified to perform the checklist. Operator should be allowed a few minutes to review checklist prior to checklist performance.
7. Ensure operator performs the following required actions for **SELF-CHECKING**;
  - a. Identifies the correct unit, train, component, etc.
  - b. Reviews the intended action and expected response.
  - c. Compares the actual response to the expected response.

**Validation Time: CR.** \_\_\_\_\_

**Local** 20 minutes

#### **Tools Needed:**

AOP-C.04 Checklist 3

#### **References:**

	Reference	Title	Rev No.
A.	AOP-C.04	Control Room Inaccessibility	18

=====

## **READ TO OPERATOR**

### **Directions to Trainee:**

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated.

**WHEN ENTERING A UNIT TRIP HAZARD ZONE ENSURE YOU DO NOT TOUCH ANY SWITCHES WITHIN THAT ZONE.**

**DO NOT OPEN ANY COMPARTMENTS.**

I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

- 1) Both units were operating at 100% power, both units entered AOP-N.01 due to a fire in the spreader room.
- 2) Operators have dispatched AUO's to the AOP-C.04 cabinets. AUO's are standing by awaiting instructions.

### **INITIATING CUES:**

- 1) You are the Control Room AUO and have been directed by the UO to report to the AOP-C.04 Cabinet in the 6.9 KV Shutdown Bd Room A.
- 2) The CRO has assigned you to report to the AOP-C.04 cabinet and review Checklist 3 for performance.
- 3) When notified that AOP-C.04 is entered, Perform Checklist 3.
- 4) NOTIFY the ACR when a CCP has been restored to service.

## **THIS IS A TIME CRITICAL JPM**

**Clock Start for Time Critical Actions is one minute prior to the operator being notified to PERFORM the checklist.**

Job Performance Checklist:

STEP/STANDARD	SAT/UNSAT
<p><b><u>NOTE 1</u></b> This checklist has Time Critical Actions. Time limits are identified at applicable steps. The clock starts for Time Critical Actions in AOP-C.04 when ANY of the entry conditions listed in AOP-N.01 are met.</p> <p><b><u>NOTE 2</u></b> For JPM performance the clock start for Time Critical Actions is one minute before the operator is notified to perform checklist.</p> <p><b><u>STEP 1.:</u></b> Obtain a copy of the appropriate checklist(s).</p> <p><b><u>STANDARD:</u></b> Operator obtains a copy of AOP-C.04, Checklist 3. (Checklist is obtained by the operator for review prior to entering AOP-C.04)</p>	<p>___ SAT</p> <p>___ UNSAT</p> <p>Start Time___</p>
<p><b><u>STEP 2.:</u></b> [1] <b>OBTAIN</b> the following from AOP-C.04 Cabinet:</p> <ul style="list-style-type: none"> <li>• C415A Key</li> <li>• Flashlight</li> </ul> <p><b><u>NOTE:</u></b> The AOP-C.04 cabinet is sealed. It is not necessary to open the cabinet and retrieve the key or a flashlight. Having the operator locate the cabinet and discuss his/her actions will suffice.</p> <p><b><u>STANDARD:</u></b> Operator locates the AOP-C.04 cabinet in the A-A 6.9 KV Shutdown Board Room (north end) and states that they would get a C415A Key and a flashlight.</p>	<p>___ SAT</p> <p>___ UNSAT</p>
<p><b><u>STEP 3.:</u></b> Operator is notified that AOP-C.04 has been entered by the MCR, Timing for Time Critical Actions started one minute ago.</p> <p><b><u>CUE:</u></b> <i>Tell OPERATOR that AOP-C.04 has been entered in the Main Control Room for Both units. Timing for Time Critical Actions started one minute ago</i></p> <p><b><u>STANDARD:</u></b> N/A.</p>	<p><b>Record time AOP-C.04 was entered in MCR</b> (Present time minus 1 minute)</p> <p>_____</p> <p><b>This time starts the clock for Time Critical Actions</b></p>



Job Performance Checklist:

STEP/STANDARD						SAT/UNSAT																		
<p><b>STEP 4.</b> [2] <b>ATTEMPT</b> to STOP both Unit 1 CCP's by.....(5 minutes)</p> <p>[2.a] <b>PLACE</b> CCP transfer switch in AUX (Lift Lever below switch to break seal and allow transfer switch operation)</p> <p>[2.b] <b>ATTEMPT to STOP CCP USING</b> HS on Bkr cmpt</p> <table border="1"> <thead> <tr> <th>CCP</th> <th>Breaker Location</th> <th>Transfer Switch</th> <th>AUX √</th> <th>Control Switch</th> <th>Stopped √</th> </tr> </thead> <tbody> <tr> <td>1A-A</td> <td>6.9 SDBD 1AA Compt 18</td> <td>1-XS-62-108</td> <td><input type="checkbox"/></td> <td>1-HS-62-108C</td> <td><input type="checkbox"/></td> </tr> <tr> <td>1B-B</td> <td>6.9 SDBD 1BB Compt 18</td> <td>1-XS-62-104</td> <td><input type="checkbox"/></td> <td>1-HS-62-104C</td> <td><input type="checkbox"/></td> </tr> </tbody> </table> <p><b>CUE:</b> <u>1st Shutdown Bd –</u></p> <ul style="list-style-type: none"> <li>Lever is up and Switch Transferred.</li> <li>Initially CCP has Red Light ON – Green Light OFF.</li> <li>After operator places HS to Stop Bkr has green light ON, Red Light is OFF.</li> </ul> <p><b>CUE:</b> <u>2nd Shutdown Bd –</u></p> <ul style="list-style-type: none"> <li>Lever is up and Switch Transferred.</li> <li>CCP has Green Light ON – Red Light OFF.</li> </ul> <p><b>STANDARD:</b> Operator places <b>BOTH</b> Xfr switches in AUX and Ensures <b>BOTH</b> CCP are OFF. Critical time 5 minutes from time enter AOP-C.04.</p>						CCP	Breaker Location	Transfer Switch	AUX √	Control Switch	Stopped √	1A-A	6.9 SDBD 1AA Compt 18	1-XS-62-108	<input type="checkbox"/>	1-HS-62-108C	<input type="checkbox"/>	1B-B	6.9 SDBD 1BB Compt 18	1-XS-62-104	<input type="checkbox"/>	1-HS-62-104C	<input type="checkbox"/>	<p>____ SAT</p> <p>____ UNSAT</p> <p><b>Critical Step</b></p> <p>Time _____</p> <p><b>Δ minutes from AOP-C.04 entry</b></p> <p>_____</p> <p>(5 minutes or less to meet critical task)</p>
CCP	Breaker Location	Transfer Switch	AUX √	Control Switch	Stopped √																			
1A-A	6.9 SDBD 1AA Compt 18	1-XS-62-108	<input type="checkbox"/>	1-HS-62-108C	<input type="checkbox"/>																			
1B-B	6.9 SDBD 1BB Compt 18	1-XS-62-104	<input type="checkbox"/>	1-HS-62-104C	<input type="checkbox"/>																			
<p><b>STEP 5.</b> [3] <b>ENSURE</b> [0-XS-82-122] GEN 1B-B Transfer switch in AUX CONT RM position. [inside SD Bd 1B-B Logic Cabinet panel 4, bottom row]</p> <p><b>NOTE:</b> <b>DO NOT ALLOW OPERATOR TO OPEN PANEL DOOR – operator can explain process, or show operator Attachment 1- Logic cabinet</b></p> <p><b>Cue:</b> <u>Switch is in the AUX position</u></p> <p><b>STANDARD:</b> Operator places DG 1B-B Transfer Switch to AUX CONT RM position</p>						<p>____ SAT</p> <p>____ UNSAT</p> <p><b>Critical Step</b></p>																		
<p><b>STEP 6.</b> [4] <b>CHECK</b> if 6.9KV Shutdown Board 1B-B is Energized – Voltmeter cmpt 12</p> <p><b>CUE:</b> <u>Voltage is as indicated (or cue ~7000 V)</u></p> <p><b>STANDARD:</b> Operator checks SD Bd 1B is energized, using voltmeter on compartment 12, and checks YES box.</p>						<p>____ SAT</p> <p>____ UNSAT</p>																		


Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT																							
<p><b>STEP 7.</b> [5] <b>IF</b> 6.9KV Shutdown Bd 1B-B is NOT energized...</p> <p><u>STANDARD:</u> Operator will N/A this step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>																							
<p><b>STEP 8.</b> [6] <b>PLACE</b> the following transfer switches in AUX position on 6.9KV Shutdown Bd 1B-B:</p> <table border="1"> <thead> <tr> <th>Equipment</th> <th>Compt</th> <th>Switch</th> <th>Position</th> </tr> </thead> <tbody> <tr> <td>ALT brk 6.9 UB 1D 1728</td> <td>16</td> <td>1-XS-57-71</td> <td><input type="checkbox"/> AUX</td> </tr> <tr> <td>Nor Supply Brk 6.9 UB 1C 1726</td> <td>11</td> <td>1-XS-57-68</td> <td><input type="checkbox"/> AUX</td> </tr> <tr> <td>ERCW Pump N-B</td> <td>9</td> <td>0-XS-67-452</td> <td><input type="checkbox"/> AUX</td> </tr> <tr> <td>ERCW Pump L-B</td> <td>8</td> <td>0-XS-67-440</td> <td><input type="checkbox"/> AUX</td> </tr> <tr> <td>Emerg Supply Brk 1BB 1914</td> <td>6</td> <td>1-XS-57-73</td> <td><input type="checkbox"/> AUX</td> </tr> </tbody> </table> <p><u>CUE 1:</u> <i>Latch lifted, XS rotated clockwise, and indicates in the AUX. position.</i></p> <p><u>STANDARD:</u> All Nor/Aux switches, addressed, are correctly placed in the Auxiliary position, and placekeeping boxes are checked.</p>	Equipment	Compt	Switch	Position	ALT brk 6.9 UB 1D 1728	16	1-XS-57-71	<input type="checkbox"/> AUX	Nor Supply Brk 6.9 UB 1C 1726	11	1-XS-57-68	<input type="checkbox"/> AUX	ERCW Pump N-B	9	0-XS-67-452	<input type="checkbox"/> AUX	ERCW Pump L-B	8	0-XS-67-440	<input type="checkbox"/> AUX	Emerg Supply Brk 1BB 1914	6	1-XS-57-73	<input type="checkbox"/> AUX	<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>
Equipment	Compt	Switch	Position																						
ALT brk 6.9 UB 1D 1728	16	1-XS-57-71	<input type="checkbox"/> AUX																						
Nor Supply Brk 6.9 UB 1C 1726	11	1-XS-57-68	<input type="checkbox"/> AUX																						
ERCW Pump N-B	9	0-XS-67-452	<input type="checkbox"/> AUX																						
ERCW Pump L-B	8	0-XS-67-440	<input type="checkbox"/> AUX																						
Emerg Supply Brk 1BB 1914	6	1-XS-57-73	<input type="checkbox"/> AUX																						
<p><b>NOTE:</b> The following step ensures one ERCW pump will sequence on following a blackout. If ERCW pump L-B or N-B is already running (breaker closed), the running pump should be selected.</p> <p><b>STEP 9:</b> [7] <b>PLACE</b> breaker control switch for ERCW pump L-B <b>OR</b> N-B in START momentarily (1B SD BD cmpt 8 or 9) [If a pump is running the running pump should be selected]</p> <p><u>CUE:</u> <i>L-B Pump Red Light ON N-B Pump Green Light ON</i></p> <p><u>STANDARD:</u> Operator ensures the HS for ERCW pump L-B (Compartment 8) on 1B-B 6.9KV shutdown board has been placed to start momentarily. [If N-B pump is started this should be a comment not an Unsat]</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>Critical Step</b></p>																							
<p><b>STEP 10.</b> [8] <b>CHECK</b> if 6.9KV Shutdown Board 1B-B is Energized – Voltmeter cmpt 12</p> <p><u>CUE:</u> <i>Voltage is as indicated (~7000 Volts)</i></p> <p><u>STANDARD:</u> Operator checks SD Bd 1BB energized utilizing voltmeter on compartment 12, and checks YES box.</p>		<p>___ SAT</p> <p>___ UNSAT</p>																							

Job Performance Checklist:

STEP/STANDARD		SAT/UNSAT
<p><u>STEP 11.</u> [9] IF 6.9KV Shutdown Bd 1B-B is NOT energized....</p> <p><u>STANDARD:</u> Operator N/A's this step.</p>		<p>___ SAT</p> <p>___ UNSAT</p>
<p><b>NOTE</b> AUO performing checklist 5 notifies operator performing checklist 3, by face to face communication, that CCP suction is aligned to the RWST.</p> <p><u>STEP 12.</u> [10] <b>WHEN</b> Unit 1 CCP suction has been aligned to the RWST, <b>THEN PERFORM</b> the following [13 minutes]</p> <ul style="list-style-type: none"> <li>IF CCP 1A-A is NOT running THEN START CCP 1B-B [cmpt 18]</li> </ul> <p><u>Cue 1:</u> <i>AUO with Checklist 5 has opened FCV-62-135</i></p> <p><u>NOTE:</u> Operator ensured both CCPs were off earlier and may state this, or may verify 1A-A is not running.</p> <p><u>Cue 2:</u> <i>If checked - 1A-A CCP Green Light only When Operator goes to "START" with 1B-B HS state Red Light ON- Green Light OFF [~ 32 Amps indicated]</i></p> <p><u>STANDARD:</u> Operator STARTS 1B-B CCP. <b>TIME</b> Critical Action 13 minutes from the time AOP-C.04 is entered.</p>		<p>___ SAT</p> <p>___ UNSAT</p> <p><b>CRITICAL STEP</b></p> <p>Time _____</p> <p><b>Δ minutes from AOP-C.04 entry</b></p> <p>_____</p> <p>(13 minutes or less to meet critical task)</p>
<p><b>NOTE</b> Per initiating cues the operator should notify the ACR that a CCP has been started, and state they have completed their assigned task.</p>		<p><b>STOP Time</b></p> <p>_____</p>

End of JPM



ATTACHMENT 1

## READ TO OPERATOR

### Directions to Trainee:

I will explain the initial conditions, and state the task to be performed. All steps shall be simulated. **WHEN ENTERING A UNIT TRIP HAZARD ZONE ENSURE YOU DO NOT TOUCH ANY SWITCHES WITHIN THAT ZONE. DO NOT OPEN ANY COMPARTMENTS.**

I will provide initiating cues and indicate any steps to be discussed. When you complete the task successfully, the objective for this job performance measure will be satisfied. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### INITIAL CONDITIONS:

- 1) Both units were operating at 100% power, both units entered AOP-N.01 due to a fire in the spreader room.
- 2) Operators have dispatched AUO's to the AOP-C.04 cabinets. AUO's are standing by awaiting instructions.

### INITIATING CUES:

- 1) You are the Control Room AUO and have been directed by the UO to report to the AOP-C.04 Cabinet in the 6.9 KV Shutdown Bd Room A.
- 2) The CRO has assigned you to report to the AOP-C.04 cabinet and review Checklist 3 for performance.
- 3) When notified that AOP-C.04 is entered, Perform Checklist 3.
- 4) NOTIFY the ACR when a CCP has been restored to service.

## THIS IS A TIME CRITICAL JPM

**Clock Start for Time Critical Actions is one minute prior to the operator being notified to PERFORM the checklist.**