

Southern Nuclear
Operating Company, Inc.
2000 West Tower Road
P.O. Box 1200
Birmingham, AL 35202-1200
Tel: 205-992-5000



May 4, 2010

Docket Nos.: 50-321

NL-10-0664

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Edwin I. Hatch Nuclear Plant-Unit 1
Cycle 25 Version 1 Core Operating Limits Report

Ladies and Gentlemen:

In accordance with Technical Specification 5.6.5.d., Southern Nuclear Operating Company (SNC) submits the enclosed Core Operating Limits Report (COLR) for Edwin I. Hatch Nuclear Plant-Unit 1 Cycle 25 Version 1.

This letter contains no NRC commitments. If there are any questions, please contact Mr. N. J. Stringfellow at 205-992-7037.

Respectfully submitted,

A handwritten signature in black ink that reads "Mark J. Ajluni".

M. J. Ajluni
Manager - Nuclear Licensing

MJA/PAH/

Enclosure: Core Operating Limits Report HNP Unit 1 Cycle 25 Version 1

U. S. Nuclear Regulatory Commission
NL-10-0664
Page 2

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President (w/o enclosure)
Mr. D. R. Madison, Vice President – Hatch (w/o enclosure)
Ms. P. M. Marino, Vice President – Engineering (w/o enclosure)
RType: CHA02.004

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. R. E. Martin, NRR Project Manager – Hatch
Mr. E.D. Morris, Senior Resident Inspector – Hatch
Mr. P. Boyle, NRR Project Manager

State of Georgia
Mr. C. Clark, Commissioner-Department of Natural Resources

**Edwin I. Hatch Nuclear Plant - Unit 1
Cycle 25 Core Operating Limits Report**

Enclosure

CORE Operating Limits Report Unit 1 Cycle 25, Version 1

**SOUTHERN NUCLEAR OPERATING COMPANY
EDWIN I. HATCH NUCLEAR PLANT**

**Unit 1 Cycle 25
CORE OPERATING LIMITS REPORT**

Version 1

Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201

Edwin I. Hatch Nuclear Plant
Unit 1 Cycle 25 Core Operating Limits Report

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	Introduction	1
2.0	APLHGR Limits	2
3.0	MCPR Operating Limits	5
4.0	LHGR Limits	17
5.0	PBDA Amplitude Setpoints	23
6.0	References	24

Plant Hatch Unit 1 Cycle 25
Core Operating Limits Report

TABLES

<u>Table No.</u>	<u>Title</u>	<u>Page</u>
1-1	Equipment-Out-of-Service Limitations	1
3-1	MCPR Operating Flexibility Options	7
4-1	LHGR Operating Flexibility Options	18
4-2	LHGR Limit versus Peak Pellet Exposure	18
5-1	OPRM Setpoint	23

FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
2-1	Flow-Dependent APLHGR Multiplier (MAPFAC _F) versus Core Flow	3
2-2	APLHGR Limit versus Average Planar Exposure	4
3-1A	Power-Dependent MCPR Limit (MCPR _P) versus Core Power from 24% to 45% of Rated Core Power	8
3-1B	Power-Dependent MCPR Limit (MCPR _P) versus Core Power from 24% to 45% of Rated Core Power (<i>Turbine Bypass Valves Inoperable</i>)	9
3-2	Flow-Dependent MCPR Limit (MCPR _F) versus Core Flow	10
3-3A	Power-Dependent MCPR Multiplier (K _P) versus Core Power	11
3-3B	Power-Dependent MCPR Multiplier (K _P) versus Core Power (<i>EOC-RPT System Out of Service and Turbine Bypass Valves Inoperable Simultaneously</i>)	12
3-3C	Power-Dependent MCPR Multiplier (K _P) versus Core Power (<i>Main Turbine Pressure Regulator System in TLCO 3.3.13.c</i>)	13
3-4A	MCPR Limits versus Average Scram Time (<i>BOC to EOR-4944 MWd/st</i>)	14
3-4B	MCPR Limits versus Average Scram Time (<i>EOR-4944 MWd/st to EOR-1444 MWd/st</i>)	15
3-4C	MCPR Limits versus Average Scram Time (<i>EOR-1444 MWd/st to EOC</i>)	16

Plant Hatch Unit 1 Cycle 25
Core Operating Limits Report

<u>Figure No.</u>	<u>Title</u>	<u>Page</u>
4-1	Flow-Dependent LHGR Multiplier (LHGRFAC _F) versus Core Flow	19
4-2A	Power-Dependent LHGR Multiplier (LHGRFAC _P) versus Core Power	20
4-2B	Power-Dependent LHGR Multiplier (LHGRFAC _P) versus Core Power (<i>Main Turbine Pressure Regulator System in TLCO 3.3.13.c</i>)	21
4-3	LHGR versus Peak Pellet Exposure	22

1.0 INTRODUCTION

The Core Operating Limits Report (COLR) for Plant Hatch Unit 1 Cycle 25 is prepared in accordance with the requirements of Technical Specification 5.6.5. The core operating limits presented herein were developed using NRC-approved methods (References 1 through 6). Results from the reload analyses for the fuel in Unit 1 Cycle 25 are documented in References 3 through 5.

The following core operating limits are included in this report:

- a. Average Planar Linear Heat Generation Rate (APLHGR) – Technical Specification 3.2.1
- b. Minimum Critical Power Ratio (MCPR) – Technical Specification 3.2.2
- c. Linear Heat Generation Rate (LHGR) – Technical Specification 3.2.3

From a fuel thermal limits perspective, the following limitations are placed on Unit 1 operation.

TABLE 1-1

Equipment-Out-of-Service Limitations

Equipment / Condition	Limitation
EOC-RPT Out of Service and Turbine Bypass Valves Inoperable Simultaneously	Option B scram speeds must be met (in place) at CTP \geq 45% RTP
Main Turbine Pressure Regulator System in TLCO 3.3.13.c	Option B scram speeds must be met (in place) at CTP \geq 45% RTP
Single-Loop Operation (SLO)	<ul style="list-style-type: none"> • CTP \leq 2000 MWth • Core Flow \leq 56% of Rated


Also included in this report are the maximum allowable scram setpoints for the Period Based Detection Algorithm (PBDA) in the Oscillation Power Range Monitor (OPRM).

The power distribution limits in this report apply to plant operation with all equipment in service, unless otherwise specified.

2.0 APLHGR LIMITS (Technical Specification 3.2.1)

The APLHGR limit for each six inch axial segment of each fuel assembly in the core is the applicable APLHGR limit taken from Figure 2-2 multiplied by the flow-dependent multiplier, $MAPFAC_F$, from Figure 2-1.

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



Operating Conditions		MAPFAC _F
F	SLO / TLO	
30 ≤ F ≤ 61	TLO	0.86
61 < F	TLO	1.00
30 ≤ F	SLO	0.80

F = Percent of Rated Core Flow

FIGURE 2-1

Flow-Dependent APLHGR Multiplier (MAPFAC_F) versus Core Flow

Plant Hatch Unit 1 Cycle 25
Core Operating Limits Report

Average Planar Exposure (GWd/st)	APLHGR Limit (kW/ft)
0.00	12.82
14.51	12.82
19.13	12.82
57.61	8.00
63.50	5.00




FIGURE 2-2

APLHGR Limit versus Average Planar Exposure

3.0 MCPR OPERATING LIMITS (Technical Specification 3.2.2)

The MCPR operating limit (OLMCPR) is a function of core power, core flow, average scram time, number of operating recirculation loops, EOC-RPT system status, operability of the turbine bypass valves, and the status of the main turbine pressure regulator system.

With both recirculation pumps in operation (TLO), the OLMCPR is determined as follows:

- a. For $24\% \leq \text{power} < 45\%$, the power-dependent MCPR limit, MCPR_p , as determined by Table 3-1.
- b. For power $\geq 45\%$, the OLMCPR is the greater of either:
 - 1) The flow-dependent MCPR limit, MCPR_f , from Figure 3-2,

or
 - 2) The product of the power-dependent multiplier, K_p , and the rated-power OLMCPR, as determined by Table 3-1.

As shown on Figures 3-1A, 3-1B, 3-2, 3-4A, 3-4B, and 3-4C, the OLMCPR with only one recirculation pump in operation (SLO) is equal to the two loop (TLO) OLMCPR plus 0.02.

These limits apply to all modes of operation with feedwater temperature reduction, as well as operation with normal feedwater temperatures.

In Figures 3-4A, 3-4B, and 3-4C, Option A scram time OLMCPRs correspond to $\tau = 1.0$, where τ is determined from scram time measurements performed in accordance with Technical Specifications Surveillance Requirements 3.1.4.1 and 3.1.4.2. Option B values correspond to $\tau = 0.0$. For scram times between Option A and Option B, the rated-power OLMCPR corresponds to τ . If τ has not been determined, Option A limits must be used.

Plant Hatch Unit 1 Cycle 25
Core Operating Limits Report

The average scram time of the control rods, τ , is defined as:

$$\tau = 0, \text{ or } \frac{\tau_{ave} - \tau_B}{\tau_A - \tau_B}, \text{ whichever is greater.}$$

where: $\tau_A = 1.08$ sec (Technical Specification 3.1.4, Table 3.1.4-1, scram time limit to notch 36).

$$\tau_B = \mu + 1.65 * \sigma * \left[\frac{N_1}{\sum_{i=1}^n N_i} \right]^{1/2}$$

where: $\mu = 0.822$ sec (mean scram time used in the transient analysis).

$\sigma = 0.018$ sec (standard deviation of μ).

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

where: $n =$ number of surveillance tests performed to date in the cycle.

$N_i =$ number of active control rods measured in the i th surveillance test.

$\tau_i =$ average scram time to notch 36 of all rods in the i th surveillance test.

$N_1 =$ total number of active rods measured in Technical Specifications Surveillance Requirement 3.1.4.1.

TABLE 3-1

M CPR Operating Flexibility Options


Rated Power OLM CPRs	
BOC to EOR – 4944	Figure 3-4A
EOR – 4944 to EOR – 1444	Figure 3-4B
EOR – 1444 to EOC	Figure 3-4C

M CPR_p from ≥ 24% to < 45% Power	
Turbine Bypass Valves Operable	Figure 3-1A
Turbine Bypass Valves Inoperable	Figure 3-1B

K_p for Power ≥ 45% of Rated			
EOC-RPT System In Service	Turbine Bypass Valves Operable	Main Turbine Pressure Regulator System Status	
Yes	Yes	TLCO 3.3.13.a or b	Figure 3-3A
No	Yes	TLCO 3.3.13.a or b	Figure 3-3A
Yes	No	TLCO 3.3.13.a or b	Figure 3-3A
No	No	TLCO 3.3.13.a or b	Figure 3-3B*
Yes/No	Yes/No	TLCO 3.3.13.c	Figure 3-3C*

EOC = End of rated conditions (100% power, 100% flow, ARO, with nominal feedwater temperature)
 * Option B scram speeds must be met (in place) at CTP ≥ 45% RTP

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$MCPR_p(TLO) = A + B \cdot P$$

$$MCPR_p(SLO) = MCPR_p(TLO) + 0.02$$


F	P	A	B
≤ 60	24 ≤ P < 28	2.1500	0.00000
> 60	24 ≤ P < 28	3.3400	-0.03000
≤ 60	28 ≤ P < 45	2.0810	-0.00624
> 60	28 ≤ P < 45	2.4861	-0.01067

P = Percent of Rated Core Power
 F = Percent of Rated Core Flow

FIGURE 3-1A

Power-Dependent MCPR Limit (MCPR_p) versus Core Power
 from 24% to 45% of Rated Core Power

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$MCPR_p(TLO) = A + B \cdot P$$

$$MCPR_p(SLO) = MCPR_p(TLO) + 0.02$$


F	P	A	B
≤ 60	24 ≤ P < 28	4.3600	-0.07000
> 60	24 ≤ P < 28	6.5876	-0.11670
≤ 60	28 ≤ P < 45	2.0810	-0.00624
> 60	28 ≤ P < 45	2.4861	-0.01067

P = Percent of Rated Core Power
 F = Percent of Rated Core Flow

FIGURE 3-1B

Power-Dependent MCPR Limit (MCPR_p) versus Core Power
 from 24% to 45% of Rated Core Power
 (Turbine Bypass Valves Inoperable)

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$MCPR_{F(TLO)} = A + B \cdot F$
 $MCPR_{F(SLO)} = MCPR_{F(TLO)} + 0.02$


Flow	A	B
$30 \leq F \leq 66.041$	1.697	-0.00586
$66.041 < F$	1.310	0.00000

F = Percent of Rated Core Flow

FIGURE 3-2

Flow-Dependent MCPR Limit (MCPR_F) versus Core Flow

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$K_p = A + B \cdot P$$


P	A	B
45 ≤ P < 60	1.6702	-0.00867
60 ≤ P	1.3750	-0.00375

P = Percent of Rated Core Power

FIGURE 3-3A

Power-Dependent MCPR Multiplier (K_p) versus Core Power

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$K_p = A + B \cdot P$$


P	A	B
45 ≤ P < 60	1.6702	-0.00867
60 ≤ P < 90	1.3308	-0.00301
90 ≤ P	1.5961	-0.00596

P = Percent of Rated Core Power

FIGURE 3-3B

**Power-Dependent MCPR Multiplier (K_p) versus Core Power
 (EOC-RPT System Out of Service and
 Turbine Bypass Valves Inoperable Simultaneously)**

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$K_p = A + B \cdot P$$


P	A	B
$45 \leq P < 70$	1.6268	-0.00451
$70 \leq P$	2.0367	-0.01037

P = Percent of Rated Core Power

FIGURE 3-3C

**Power-Dependent MCPR Multiplier (K_p) versus Core Power
 (Main Turbine Pressure Regulator System in TLCO 3.3.13.c)**

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report




Operating Conditions		OLMCPR(TLO)	
EOC-RPT	Bypass Valves	$\tau = 0.0$	$\tau = 1.0$
In Service	Operable	1.31	1.33
Out of Service	Operable	1.36	1.47
In Service	Inoperable	1.34	1.37
Out of Service	Inoperable	1.40	1.51

OLMCPR(SLO) = OLMCPR(TLO) + 0.02

FIGURE 3-4A

**MCPR Limits versus Average Scram Time
 (BOC to EOR - 4944 MWd/st)**

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report




Operating Conditions		OLMCPR(TLO)	
EOC-RPT	Bypass Valves	$\tau = 0.0$	$\tau = 1.0$
In Service	Operable	1.35	1.38
Out of Service	Operable	1.39	1.50
In Service	Inoperable	1.38	1.41
Out of Service	Inoperable	1.42	1.53

$OLMCPR(SLO) = OLMCPR(TLO) + 0.02$

FIGURE 3-4B

MCPR Limits versus Average Scram Time
 (EOR – 4944 MWd/st to EOR – 1444 MWd/st)

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



Operating Conditions		OLMCPR(TLO)	
EOC-RPT	Bypass Valves	$\tau = 0.0$	$\tau = 1.0$
In Service	Operable	1.38	1.41
Out of Service	Operable	1.44	1.61
In Service	Inoperable	1.42	1.45
Out of Service	Inoperable	1.47	1.64

$OLMCPR(SLO) = OLMCPR(TLO) + 0.02$

FIGURE 3-4C

MCPR Limits versus Average Scram Time
 (EOR - 1444 MWd/st to EOC)

4.0 LHGR LIMITS (Technical Specification 3.2.3)

The LHGR limit for each six inch axial segment of each fuel rod in the core is the applicable rated-power, rated-flow LHGR limit taken from Table 4-2 multiplied by the smaller of either:

- a. The flow-dependent multiplier, $LHGRFAC_F$, from Figure 4-1,

or
- b. The power-dependent multiplier, $LHGRFAC_P$, as determined by Table 4-1.

Table 4-2 shows the exposure-dependent LHGR limits for all fuel types in the core, including the UO_2 rods which contain no gadolinium. The LHGR limit is based on initial Gd content in a six inch segment of a fuel rod and the maximum initial Gd content anywhere in the same rod. The first column in Table 4-2 shows the segment Gd concentration and the second column shows the maximum Gd concentration for each fuel type. For exposures between the values shown in Table 4-2, the LHGR limit is based on linear interpolation. For illustration purposes, Figures 4-3 shows the LHGR limits for UO_2 rods and for the most limiting (7.0 w/o) Gd rods in the core.

TABLE 4-1

LHGR Operating Flexibility Options

LHGRFAC_p	
Main Turbine Pressure Regulator System Status	
TLCO 3.3.13.a or b	Figure 4-2A
TLCO 3.3.13.c	Figure 4-2B*

* Option B scram speeds must be met (in place) at CTP ≥ 45% RTP


TABLE 4-2

LHGR limit versus Peak Pellet Exposure

Six Inch Segment Gd (w/o)	Rod Maximum Gd (w/o)	LHGR limit at BOL (kW/ft)	LHGR limit at Knee 1 (kW/ft)	Exp. at Knee 1 (GWd/st)	LHGR limit at Knee 2 (kW/ft)	Exp. at Knee 2 (GWd/st)	LHGR limit at EOL (kW/ft)	Exp. at EOL (GWd/st)
0.00	0.00	13.400	13.400	14.515	8.000	57.607	5.000	63.504
0.00	5.00	13.100	13.100	14.190	7.821	56.317	4.888	62.082
5.00	5.00	12.521	12.521	12.389	7.475	55.443	4.672	61.335
6.00	6.00	12.255	12.255	12.276	7.316	54.999	4.572	60.845
5.00	7.00	12.300	12.300	12.132	7.343	54.424	4.590	60.212
6.00	7.00	12.100	12.100	12.095	7.224	54.275	4.515	60.047
7.00	7.00	12.000	12.000	12.174	7.164	54.589	4.478	60.394

BOL = Beginning of Life (zero exposure)
 EOL = End of Life (maximum licensed pellet exposure)

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$LHGRFAC_F = A + B \cdot F$$


Operating Conditions		Values of Variables	
F	SLO / TLO	A	B
$30 \leq F < 50.70$	SLO / TLO	0.4574	0.006758
$50.70 \leq F < 80.29$	TLO	0.4574	0.006758
$50.70 \leq F$	SLO	0.8000	0.000000
$80.29 \leq F$	TLO	1.0000	0.000000

F = Percent of Rated Core Flow

FIGURE 4-1

Flow-Dependent LHGR Multiplier (LHGRFAC_F) versus Core Flow

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



$$LHGRFAC_p = A + B \cdot P$$


Operating Conditions		Values of Variables	
P	F	A	B
24 ≤ P < 28	F > 60	0.17924	0.009670
24 ≤ P < 28	F ≤ 60	0.26124	0.011670
28 ≤ P < 45	All	0.52261	0.003617
45 ≤ P	All	0.47760	0.005224

P = Percent of Rated Core Power
 F = Percent of Rated Core Flow

FIGURE 4-2A

Power-Dependent LHGR Multiplier (LHGRFAC_p) versus Core Power

Plant Hatch Unit 1 Cycle 25
 Core Operating Limits Report



LHGRFAC_p = A + B*P

Operating Conditions		Values of Variables	
P	F	A	B
24 ≤ P < 28	F > 60	0.17924	0.009670
24 ≤ P < 28	F ≤ 60	0.26124	0.011670
28 ≤ P < 70	All	0.52261	0.003617
70 ≤ P	All	0.25270	0.007473

P = Percent of Rated Core Power
 F = Percent of Rated Core Flow

FIGURE 4-2B

**Power-Dependent LHGR Multiplier (LHGRFAC_p) versus Core Power
 (Main Turbine Pressure Regulator System in TLCO 3.3.13.c)**

Plant Hatch Unit 1 Cycle 25
Core Operating Limits Report

UO2 Rods	
Peak Pellet Exposure (GWd/st)	LHGR (kW/ft)
0.000	13.400
14.515	13.400
57.607	8.000
63.504	5.000

Limiting Gd Rods	
Peak Pellet Exposure (GWd/st)	LHGR (kW/ft)
0.000	12.000
12.174	12.000
54.589	7.164
60.394	4.478




FIGURE 4-3

LHGR versus Peak Pellet Exposure

5.0 PBDA AMPLITUDE SETPOINTS

The amplitude trip setpoint in the Period Based Detection Algorithm in the OPRM system shall not exceed the values reported in the Table below. This applies to instruments 1C51K615 A, B, C, and D.

TABLE 5-1

OPRM Setpoint

OLMCPR	OPRM Setpoint
≥ 1.31	1.15

6.0 REFERENCES

1. "General Electric Standard Application for Reactor Fuel," NEDE-24011-P-A-16, October 2007, and the US Supplement, NEDE-24011-P-A-16-US, October 2007.
2. GNF letter MJM-SNC-HT1-09-077.DOC, "H1 R24 SRLR and FBIR," M. Mneimneh to S. Hoxie-Key, November 19, 2009.
3. Global Nuclear Fuel document 0000-0099-0707-SRLR, "Supplemental Reload Licensing Report for Edwin I. Hatch Nuclear Power Plant Unit 1, Reload 24 Cycle 25," Revision 0, November 2009.
4. Global Nuclear Fuel document 0000-0099-0707-FBIR, "Fuel Bundle Information Report for Edwin I. Hatch Nuclear Power Plant Unit 1, Reload 24 Cycle 25," Revision 0, November 2009.
5. SNC Nuclear Fuel Document NF-10-013, "Hatch-1 Cycle 25 Reload Licensing Analysis Report," Version 1, February 2010.
6. GNF Document DB-0012.03, "Fuel-Rod Thermal-Mechanical Performance Limits for GE14C," Rev. 2, September 2006.