



APPLY CAULK AT INTERFACE OF TRAY WRAP & SUPPORT WRAP

COVER SUPPORTS WITH 5 LAYERS OF E-54 MAT; 12" MIN.

CENTER A MINIMUM 4" (10.2cm) WIDE INTERAM E-54 COLLAR OVER THE FINAL LAYER SEAMS.

SECURE THE FINAL MAT LAYER WITH BANDS AT INTERVALS NOT TO EXCEED 12" (30.5cm); TYPICAL OF BOTH TRAYS AND SUPPORTS

SOLID BOTTOM OR LADDER-BACK STEEL CABLE TRAY

PLACE STRUT WHERE REQUIRED AT INTERVALS NOT TO EXCEED 15"

4" MINIMUM LONGITUDINAL OVERLAP EACH LAYER, INCLUDING COLLAR

COVER ALL SEAMS & EXPOSED EDGES EACH LAYER WITH FOIL TAPE

SPACER: 1" TO 3" WIDE E-54 MAT APPLY AT INTERVALS NOT TO EXCEED 15"

WRAP CABLE TRAYS WITH 6 LAYERS OF INTERAM E 54 MAT WITH 1 SPACER

ALLOW A MIN. 2" (5.1cm) OFFSET BETWEEN EACH LAYER (TYP.)

FILL OPEN TYPE CHANNEL SUPPORTS WITH MAT PIECES & SEAL END WITH NOMINAL 1/2" THICKNESS OF CAULK.