

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-247CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 51 to Facility Operating License No. DPR-26, issued to Consolidated Edison Company of New York, Inc. (the licensee), which revised Technical Specifications for operation of the Indian Point Nuclear Generating Unit No. 2 (the facility) located in Buchanan, Westchester County, New York. The amendment is effective as of the date of issuance.

The amendment revises the Technical Specifications concerning an error in the allowable pressurizer heatup rate, definitions of hot shutdown, quadrant power tilt ratio, and surveillance intervals, steam generator tube inservice inspection reports, outage times for the boric acid transfer and storage system, inservice inspections and testing (ISI/IST) requirements separately covered by the IP-2 Inservice Inspection and Testing Program, station battery load test intervals, and a number of editorial matters.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license

7904116037

- 2 -

amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the applications for amendment dated November 2, 1977 and January 6, 1978; (2) Amendment No. 51 to License No. DPR-26; and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. and at the White Plains Public Library, 100 Martine Avenue, White Plains, New York. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland this 19th day of March, 1979.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors