

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Westinghouse AP1000 Subcommittee
Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, April 22, 2010

Work Order No.: NRC-203

Pages 1-115

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

SUBCOMMITTEE ON THE WESTINGHOUSE AP1000 DCD AND

AP1000 STANDARD CONTENT COL

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY,

APRIL 22, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:30 a.m., Mr. Harold
Ray, Chairman, presiding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SUBCOMMITTEE MEMBERS PRESENT:

2 HAROLD B. RAY, Chairman

3 J. SAM ARMIJO

4 SAID ABDEL-KHALIK

5 SANJOY BANERJEE

6 DENNIS C. BLEY

7 MARIO V. BONACA

8 CHARLES H. BROWN, JR.

9 MICHAEL T. RYAN

10 JOHN D. SIEBER

11 WILLIAM J. SHACK

12

13 CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

14 WILLIAM HINZE

15 THOMAS S. KRESS

16 BOZIDAR STOJADINOVIC

17

18 NRC STAFF PRESENT:

19 WEIDONG WANG

20 PETER C. WEN

21 EILEEN MCKENNA

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ALSO PRESENT:

ROB SISK

DICK HESSLER

CHUCK BROCKHOFF

TOBEY BURNETT (via telephone)

ED CUMMINS

WALT LYMAN (via telephone)

PHIL KOTWICKI

MARK STELLA (via telephone)

MIKE MELTON

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

C O N T E N T S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Opening Remarks and Objectives 4

Introductions and Opening Comments 9

RCP materials and other questions 11

Elbow taps 33

Screening criteria for striping 78

HDPE connections 98

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:29 a.m.

1
2
3 CHAIR RAY: If we could come to order
4 please. This meeting is a meeting of the AP1000
5 Reactor Subcommittee for any of you who are in the
6 wrong room, a standing subcommittee of the Advisory
7 Committee on Reactor Safeguards.

8 I'm Harold Ray, Chairman of the
9 subcommittee. ACRS Members in attendance are Mario
10 Bonaca, Charles Brown, Bill Shack, Mike Ryan, Dennis
11 Bley, Said Abdel-Khalik, Sam Armijo, Jack Sieber,
12 Sanjoy Banerjee, did I miss anyone?

13 We also have in attendance our consultant
14 Tom Kress and we will later have consultant Bill Hinze
15 and we have with us our consultant Bozidar
16 Stogadinovic. I'm sorry, you must get a lot of
17 apologizes, but I'll try and do better.

18 In any event because we're starting with a
19 closed meeting on a subject that the latter two of our
20 consultants Bill and Bozidar are not directly involved
21 in. They will be joining us after the closed meeting
22 is over on the first subject that we will be
23 addressing.

24 We'll go into closed meeting after I am
25 done with my remarks and NRO has made their opening

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remarks.

2 Weidong Wang is the designated federal
3 official for this meeting and he is joined by ACRS
4 staff member Peter Wen. The main purpose of this
5 meeting is to review first status of Vogtle Units 3
6 and 4 AP1000 combined operating license application in
7 the area of large areas -- loss of large areas of the
8 plant due to explosions or fire.

9 Secondly, the status of the shield
10 building redesign activities for the AP 1000. And
11 third, action items from the past AP1000 subcommittee
12 meetings.

13 This review is part of the ongoing review
14 of the proposed amendment to the AP1000 pressurized
15 water reactor design control document and review of
16 the associated referenced combined operating license
17 application.

18 In the past we had four two-day meetings
19 of the AP1000 subcommittee; in July, October and
20 November 2009 and then in February of 2010.

21 And I'll say parenthetically to the
22 members after we go off the record late this
23 afternoon, I will be wanting to have a discussion
24 about their availability for the next scheduled two-
25 day meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 At this meeting we will hear presentations
2 from NuStart, Westinghouse and NRC staff. We have
3 received no written requests -- no written comments or
4 request for time to make oral statements to members of
5 the public regarding today's meeting.

6 Portions of this meeting will be closed,
7 as I indicated earlier, in order to discuss
8 unclassified safeguards, information or information
9 that is proprietary to the applicants and its
10 contractors, which go to 5 USC 552b(c)(3) and (4).

11 Attendance at those portions of the
12 meeting dealing with such information will be limited
13 to NuStart, Westinghouse representative, NRC staff and
14 its consultants and those individuals and
15 organizations who have entered into an appropriate
16 confidentiality agreement with them.

17 Consequently, we need to confirm that we
18 have only eligible observers and participants in the
19 room for the closed portion.

20 The subcommittee will gather information,
21 analyze relevant issues and facts and formulate a
22 proposed positions and actions as appropriate for
23 deliberation by the full committee.

24 The rules for participation in today's
25 meeting have been announced as part of the notice of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meeting previously published in the Federal Register.

2 A transcript of the meeting is being kept
3 and will be made available as stated in the Federal
4 Register notice, therefore we request that
5 participants in this meeting use the microphones
6 located throughout the meeting room when addressing
7 the subcommittee.

8 The participants should first identify
9 themselves and speak with sufficient clarity and
10 volume so that they may be readily heard.

11 We'll now proceed with the meeting, and
12 first Said wished to make a statement.

13 MEMBER ABDEL-KHALIK: Thank you,
14 Mr. Chairman. I will not participate in discussions
15 specifically related to the Reference COL application
16 because of a conflict.

17 CHAIR RAY: Thank you. With that, the
18 next item on the agenda is to have any introductory
19 remarks from NRO. Eileen?

20 MS. MCKENNA: Yes, thank you. My name is
21 Eileen McKenna, AP1000 Projects in the Office of New
22 Reactors.

23 As you indicated, the first topic this
24 morning is a combined license topic and we are
25 providing this informational briefing by NuStart and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 by the staff because this is an area where we do not
2 have an SER with Open Items to bring before the
3 committee earlier and we wanted to have the
4 opportunity to have any dialog and exchange on the
5 topic before we reached the final SER Phase 5 dialog
6 with the committee.

7 So we hope that you'll find this
8 informative and we look forward to your discussion.
9 And with that, I'll turn it over to NuStart.

10 CHAIR RAY: Well, let's see, we need to
11 close the meeting, I believe.

12 MS. MCKENNA: Yes, we do.

13 CHAIR RAY: All right. With that then,
14 I'll ask that those who are not part of this
15 discussion of loss of large areas, which is security
16 related or unclassified safeguards information, I
17 would ask leave the room until we again open the
18 meeting for open items after this is over.

19 Thank you Bozinar. Anyone else?

20 MEMBER RYAN: Is there a bridge line open?

21 CHAIR RAY: Good point Mike, it wasn't in
22 the prepared statements, but I should ask. Do we have
23 a bridge line? Does anyone know?

24 PARTICIPANT: Yes, we have one.

25 CHAIR RAY: Is it open?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: Yes, he says cut it off
2 automatically.

3 CHAIR RAY: All right, thank you. But,
4 definitely that's an issue to be addressed at this
5 time and we'll reestablish the bridge line once the
6 closed session meeting has ended. So we'll wait a
7 minute. So, give us a minute, please.

8 (Whereupon, the Open Session went off the record at
9 8:36 a.m. and went back on the record at
10 10:08 a.m.)

11 CHAIR RAY: We will come back into order
12 please. We will be, I believe, Weidong is this
13 correct, pass around copies of the action items? I'll
14 assume that that will take place during the course of
15 the first part of this meeting.

16 We'll get to looking at it later. We have
17 items on our agenda for today from that list that
18 hopefully we'll have a discussion sufficient to close
19 the items or if not, identify precisely anything else
20 that may be needed.

21 So, the first item on the list, as shown
22 on the screen here now, is AP 1000 reactor coolant
23 pump flywheel. Rob, go ahead.

24 MR. SISK: Thank you, Mr. Chairman and
25 good morning. Today we are hoping in the next

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 available time slot here between now and lunch to
2 close out four of the action items that I believe are
3 currently on the list and look forward to a
4 discussion.

5 We'll start first with the reactor coolant
6 pump flywheel. I'd like to introduce Dick Hessler as
7 one of our subject matter experts in the PRA area, as
8 I believe the questions were centered around how the
9 reactor coolant pump flywheel was handled within PRA.

10 So Dick, why don't you go ahead?

11 MR. HESSLER: Yes. I'm Dick Hessler, I
12 work at Westinghouse. I'm in the risk-applications
13 and methods group. And we're the group that works on
14 the AP 1000 PRA model.

15 The purpose of this presentation is to
16 respond to an ACR request for information on the
17 reactor coolant pump flywheel failure frequency that's
18 used in the AP 1000 PRA model.

19 The AP 1000 PRA model does not explicitly
20 model the failure of the reactor coolant pump flywheel
21 and consequently, we don't have a failure frequency to
22 present to you because it's not explicitly included in
23 the model.

24 But what I want to do on the next couple
25 of slides is explain how we got to that point. One of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the -- probably the most likely failure consequence of
2 a flywheel failure would be a locked rotor initiating
3 event in the reactor coolant pump that the failure
4 occurred.

5 In our PRA model, we group initiating
6 events together and run them through our event tree
7 analysis. And these events are grouped based on the
8 commonalities of what would be required to mitigate
9 the initiating event.

10 So, the flywheel failure we would
11 categorize as a locked rotor event. There are other
12 things, you could have a bearing failure that could
13 also cause a locked rotor event.

14 But if we were to explicitly analyze it,
15 we would probably put it in the locked rotor event
16 category. The locked rotor event category is combined
17 with other single-loop loss of reactor coolant flow
18 events.

19 And, for example, these would be if you
20 had a shaft failure of some sort and lost your
21 impeller force or if you lost power to a single
22 reactor coolant pump. That would be a single-loop
23 loss of reactor coolant flow.

24 So the locked rotor gets combined with
25 those, then the effects of those on the plant are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analyzed and the single-loop loss of reactor coolant
2 flow events are combined with other initiating events
3 and analyzed in the PRA model under the category of
4 transient with main feed water.

5 Because they all share that same
6 characteristic that you haven't done anything to
7 affect main feed water, you have a transient which
8 caused a reactor trip main feed water is available,
9 now you're going to see how you're going to mitigate
10 that.

11 MEMBER BONACA: Would the flow course vary
12 from event to event?

13 MR. HESSLER: Yes, it would. But that's a
14 very short term effect and in the PRA model we're
15 looking out over 24-hours.

16 So some of the initial event conditions
17 that are more important when you talk about safety
18 analysis are less important when we're looking at the
19 success criteria, the longer term success criteria for
20 PRA.

21 CONSULTANT KRESS: Do you actually have a
22 value for the locked rotor initiating event in the
23 PRA?

24 MR. HESSLER: No, we don't. And that's a
25 good lead-in to the next slide. When we look at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transient with main feed water event frequency, it's
2 dominated by spurious reactor trip and turbine trip
3 events.

4 So there was not a specific number
5 calculated for locked rotor because when you look at
6 the numbers, it would contribute -- you wouldn't
7 notice the contribution if you added it to a spurious
8 reactor trip and turbine trip frequency.

9 So we didn't even get as far as
10 calculating a locked rotor number as we were going
11 down these chain of events. So what we have is again,
12 your question was what's the failure frequency used in
13 the PRA.

14 The answer is, we don't have a specific
15 failure frequency, but the logic that was used to get
16 there is that the flywheel failure is a subset of a
17 locked rotor event category.

18 Locked rotor event is a subset of the
19 single-loop loss of reactor coolant flow events. And
20 those are a subset of the transient with main feed
21 water events, which are highly dominated by just your
22 spurious reactor trip and turbine trip.

23 MEMBER BLEY: I'm going to back you up to
24 the first thing you told us.

25 MR. HESSLER: Sure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Do you have analysis showing
2 that a ruptured flywheel can't penetrate the boundary
3 and can't lead the vibration such that it generates a
4 LOCA?

5 MR. HESSLER: There was an analysis --

6 MEMBER BLEY: Something where you did
7 doesn't --

8 MR. HESSLER: Right. Yes.

9 MEMBER BLEY: -- get you through the
10 impact.

11 MR. HESSLER: And that's right. That's
12 right. It doesn't -- what it's saying is we're not
13 looking at it from the standpoint of creating a LOCA.

14 MEMBER BLEY: And you have --

15 MR. HESSLER: There was -- it's my
16 understanding, we have a report, it's my understanding
17 it was submitted to the NRC as a response to an RAI.

18 And the report was done by Curtiss Wright
19 and the title is "Structural Analysis Summary for the
20 AP 1000 Reactor Coolant Pump High Inertial Flywheel."

21 The document number is AP 1000 RCP-06-009 and the
22 non-proprietary version is -NP.

23 It's revision 2 and there is a section in
24 that document -- I'm not an expert on that document by
25 any means.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: I read that document and
2 it did have a very good explanation of the
3 consequences of such a failure and they showed what
4 they did to demonstrate the structures around it.

5 The surrounding structure was strong
6 enough to prevent missiles from flying off of the
7 pump. And so, you know, the full committee hasn't
8 addressed it, but it looked pretty strong to me.

9 My issue on this thing was what testing
10 has the Curtiss Wright or anyone else done to
11 demonstrate that failure of that flywheel, that
12 retainer ring which holds that heavy metal is, you
13 know, have you done any stress corrosion cracking
14 testing in environments of interest.

15 And the way I understand the pump, it's a
16 very -- it's not subject to routine inspection,
17 particularly the retainer ring and the flywheel are
18 contained in an Alloy 625-welded sealed can.

19 And there's no provisions that I could
20 find for routine inspection to make sure that that
21 wasn't leaking, do something, a failure of a weld,
22 stress corrosion crack, whatever.

23 And this material, this 18-chrome, 18-
24 manganese material is a very high strength material
25 and it's not commonly used in PWR water environments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I asked, has anybody done any stress corrosion
2 cracking test of that retainer ring material.

3 The response I got, or at least somebody
4 sent me was that, yes, there's been some stress
5 corrosion cracking tested in other environment and
6 it's very good material, which doesn't answer the
7 question because stress corrosion cracking is very
8 specific material and in environment.

9 So unless you've tested in the environment
10 of interest, you really haven't tested it. So, my
11 interest is what, you know, can you -- is there enough
12 testing been done to demonstrate that in the event
13 that you get water in between the Alloy 625 can or the
14 retainer ring is operating under very high stress,
15 very high strength material, have you demonstrated
16 that it's got some stress corrosion cracking
17 resistance or not.

18 And so far, I haven't seen any evidence
19 that there's been any testing done. In fact, I think
20 that was the feedback we got from the staff.

21 CHAIR RAY: Before anyone responds
22 further, may I ask those on the bridge line to make
23 sure their phones are on mute. There's quite a bit of
24 background noise coming over the bridge line as people
25 are breathing and doing other multi-tasking chores.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Thank you.

2 Please go ahead and respond. What you
3 recited is precisely what we captured in this action
4 item or part of the action item.

5 MEMBER ARMIJO: Yes. And you have it
6 exactly right. And it may be my misunderstanding, but
7 it looks like this is a component that is not going to
8 be inspected very frequently.

9 It's going to operate for very, very long
10 times and you're not going to disassemble that pump to
11 inspect that Alloy 625-can to see if the welds are
12 holding and if you've got leakage into the retainer
13 ring region or not.

14 So if that's the case, you have to do a
15 lot, in my opinion, to demonstrate that even if it did
16 leak and you didn't spot it during some interim
17 inspection, that it's a good material and it will
18 retain and it won't be subject to cracking like the
19 stress-corrosion mechanism.

20 So that's the whole story of my concern.

21 MEMBER BONACA: Wouldn't the vibrations be
22 picked up?

23 MEMBER ARMIJO: I didn't hear you Mario.

24 MEMBER BONACA: Wouldn't the vibrations in
25 the pumps resulting from the condition they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 describing?

2 MEMBER ARMIJO: Well, no. If it's just
3 cracking and it creates a, you know, a stress
4 corrosion crack, it's not going to unbalance it, it's
5 going to fall apart if it gets -- if the crack gets
6 big enough, you can just fracture the component.

7 And so, if there's been some testing in
8 PWR water of this material, it would give me a lot of
9 comfort. But if there's been no testing, I don't
10 think you can say, well I tested it in this other
11 environment, therefore it ought to be good in PWR
12 water.

13 CHAIR RAY: Well, isn't it canned --
14 you're talking about the can leaking and getting in
15 there.

16 MEMBER ARMIJO: The can leaks.

17 MEMBER BROWN: There's no inspection of
18 the can.

19 CHAIR RAY: No, I understand that.

20 MEMBER ARMIJO: Now if you're going to
21 inspect that can periodically you have to take the
22 pump apart and I don't think that's part of the plan.

23 So if you don't inspect that weld, then
24 you have to assume that it might leak and if it does
25 leak, is the material resistant to PWR water stress

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 corrosion cracking. That's the simple --

2 MEMBER BROWN: So you're looking for some
3 type of test like thermal cycling test --

4 MEMBER ARMIJO: No, no. Stress corrosion
5 --

6 MEMBER BROWN: -- or just SCC?

7 MEMBER ARMIJO: The industry guys know how
8 to do stress corrosion cracking tests.

9 MEMBER BROWN: On the Alloy 625.

10 MEMBER ARMIJO: Of Alloy 600, Alloy 625.

11 MEMBER SHACK: No, he wants the 18/18.

12 MEMBER ARMIJO: Yes, you take the 18/18.

13 MEMBER SHACK: I mean it is true Sam that
14 the 625 has a good history in PWR water.

15 MEMBER ARMIJO: I know 625 is good, but
16 even so, this is a really important component and so
17 many of our important welds are inspected. This
18 component I don't think is inspected. It's
19 inspectable, but I don't think that's the plan to do
20 that routinely.

21 MR. SISK: Well, let me, if I can, check
22 on the phone. We do have one of our subject matter
23 experts. Dale Wiseman, are you online? Dale Wiseman?

24 What we will do, because I do think we
25 should take -- what I'd like to do is focus a response

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on the material and the testing of the reactor coolant
2 pump, which is what I'm hearing. And Dick was
3 addressing primarily the PRA, to resolve the PRA
4 concerns and we will get back to you on the material
5 question.

6 MEMBER ARMIJO: Yes, we tried to be
7 explicit in our -- in the language in our action item
8 4 just to make sure that nobody misunderstood what we
9 were looking for.

10 And so I don't know how it became, also
11 became a PRA question.

12 CHAIR RAY: Well there were two questions
13 here, Sam as you can see here. And I want to make
14 sure, just from an accounting standpoint, that we take
15 care of Tom's question, which we were pursuing a few
16 minutes ago.

17 Is there anything more that's needed?
18 We've had the PRA discussion here which was intended
19 to be responsive.

20 CONSULTANT KRESS: I think normal lock
21 rotors are nominated by this, but I'm concerned that
22 Sam's issue may change the lock rotor frequency. So I
23 would like to see, and I turn to Sam, that's why I say
24 okay.

25 CHAIR RAY: All right. So, but we could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say we have an answer at least based on the assumption
2 given relative to PRA. The question is whether the
3 assumption --

4 MEMBER BLEY: Before we say that, I
5 wouldn't say that.

6 CHAIR RAY: Okay. I was going to come to
7 you next Dennis, but --

8 MEMBER BLEY: Okay. We're moving on.

9 CHAIR RAY: No, I'm just trying to keep
10 track of things, that's all. Go ahead, please.

11 MEMBER BLEY: I agree with Tom. It's not
12 unreasonable that if this happens you'll get a locked
13 rotor. That is a possible outcome, but there are
14 other possible outcomes and the question is, have they
15 been considered and it sounds like the answer is no,
16 not in the PRA.

17 And Sam's issue could elevate it to the
18 point that maybe it really ought to be.

19 CONSULTANT KRESS: Yes, that's my concern.

20 CHAIR RAY: Okay. What are the outcomes
21 of concern here in addition to locked rotor? There
22 was a question of penetration reactor coolant pump and
23 I wanted to figure out are you satisfied that even if
24 this thing fails every other day that the penetration
25 of the reactor coolant pump boundary is not --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: There is a lot of margin
2 in that structure around that flywheel. But, you
3 know, that's just me.

4 CONSULTANT KRESS: Okay. That high
5 inertia --

6 MEMBER ARMIJO: That's not my concern. My
7 concern is it shouldn't read have untested material
8 that's basically uninspectable.

9 CHAIR RAY: Okay. I hear you and we'll
10 capture that. But again, I'm trying to figure out is
11 that associated with any particular threat sequence?

12 MEMBER ARMIJO: Yes, because I don't know
13 if all lock rotor events are the same. You know, if
14 this rotor locks up when it's running at full speed
15 when a flywheel comes apart, it may be different than
16 some other type of locked rotor event. I think it
17 would be a pretty violent --

18 CONSULTANT KRESS: Well as the best I
19 remember, that high inertia flywheel was put in there
20 because you needed the coast-down in order to provide
21 that cooling. And I'm not sure whether or not your
22 event, not necessarily results in a locked rotor, but
23 might affect the coast-down ability of the pump.

24 MEMBER ARMIJO: It would be a pretty
25 violent thing if that thing came apart.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CONSULTANT KRESS: Yes, well, you know, it
2 could just get slowed down in there or, you know, it
3 doesn't have to fail all the way.

4 MEMBER ARMIJO: I wouldn't want to be
5 around it --

6 CHAIR RAY: All right. So it's the
7 thermal hydraulic implications potentially that --

8 MEMBER ARMIJO: Yes.

9 CHAIR RAY: -- not the penetration reactor
10 coolant pressure boundary.

11 MEMBER ARMIJO: Basically we test all the
12 materials. It's not a pressure coolant boundary
13 system, but it is a very important component. And if
14 it was subject to routine inspection, periodic
15 inspection, I'd be less worried.

16 But if you're not going to do that, you
17 should really test the materials in the environment
18 that could be there.

19 CHAIR RAY: Okay.

20 MR. SISK: So it's the question then
21 looking at the material, I guess I'm separating that
22 out because the plant is capable of dealing with the
23 locked rotor event and I guess that's to analyze.

24 MEMBER ARMIJO: I think I agree with that,
25 but, you know, basically it's have you tested 18-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 chrome, 18-manganese retainer ring material of
2 properties you intend to use in PWR water just in case
3 it's exposed to that environment.

4 MR. SISK: And I wanted to make sure I
5 captured that correctly as a material question not
6 really a safety question in that the locked rotor
7 event is captured from a safety aspect.

8 MEMBER ARMIJO: Well, that's for the
9 committee to decide.

10 CHAIR RAY: Yes. I think Rob, the way to
11 best carry this forward is the subcommittee or members
12 of the committee are not satisfied that we should be
13 unconcerned about failure of this flywheel.

14 And given that fact, in other words,
15 answer to the question that we got satisfies the
16 narrow issue, but it doesn't say, and therefore don't
17 worry about failure of the rotor flywheel. I'm sure
18 you guys don't either.

19 And so the question is then, well, okay
20 given that we continue to have a concern that this
21 material may be susceptible to the kind of failure
22 that Sam's described, how can we resolve that concern?

23 Okay?

24 So we go the PRA answer, we appreciate
25 that. If there's any more questioning on that we'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be taking advantage of the fact that we --

2 MEMBER SIEBER: Would that include the
3 demonstration that the plant could withstand a locked
4 rotor plus if the rotor did disintegrate it wouldn't
5 penetrate the pressure house. Either one of those
6 would be an alternate way to resolve it, right?

7 CHAIR RAY: Well, that's why I asked Jack
8 if Sam was satisfied with what he had reviewed about
9 penetration the pressure boundary.

10 MEMBER SHACK: As a safety question?

11 CHAIR RAY: Yes. And I believe he said he
12 was. I mean, you may look at it and come to a
13 different conclusion. But we have a reference to look
14 at in terms of what hazard does a flywheel failure
15 present to the reactor coolant pressure boundary from
16 a standpoint of either a loss coolant accident or an
17 interconnected system event cooling, motor cooling
18 system leak,.

19 MEMBER SIEBER: It's a safety question.

20 CHAIR RAY: What?

21 MEMBER SIEBER: It is the safety aspect of
22 the question, however.

23 CHAIR RAY: It is, at least it's one of
24 them at least. He was talking about the possibility
25 that the thermal hydraulic question --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Well it's an initiator and
2 if you can prevent an initiator by demonstrating by
3 test that it's resistant to this problem, then
4 everybody should be much more comfortable.

5 CHAIR RAY: Dennis, are you satisfied
6 here?

7 MEMBER BLEY: I haven't read that report.
8 I have to go look at it. I guess the other thing,
9 and the flywheel is not on the boundary, but it's
10 attached to the whole pump mechanism.

11 So if instead of ripping apart and
12 stopping, it causes some severe vibration, then you
13 could lose seals and you could have -- no, there's
14 probably more likely LOCAs than that.

15 MEMBER ARMIJO: The narrow question of
16 whether a missile will fly through that super heavy
17 structure I think is pretty solid because they have
18 tons of margin.

19 MEMBER BROWN: This doesn't have seals,
20 this is a canned rotor pump. If you --

21 MEMBER ARMIJO: It's sealed to the -- the
22 bonnet where the pump attaches to the --

23 CHAIR RAY: To the steam generator lower
24 head.

25 MEMBER SIEBER: Yes, you've got a couple.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: For low-head pumps for
2 current generation of reactors the frequencies are
3 soon to be E 10 to the minus 4 for the failure of the
4 locked rotor. You know, is there any parallel
5 information that can be used for current pumps?

6 Because given the frequency, then some
7 fuel damage is allowed in license space for cooling
8 events.

9 MR. HESSLER: A frequency, I guess, could
10 be determined. I'm not aware that it has been for the
11 AP 1000 RCP. I didn't see it, I didn't look at that
12 report in detail, but it looked like they were
13 focusing on meeting stress limits, you know, how far -
14 -

15 MEMBER ARMIJO: They just assumed it fell
16 apart at full speed with lots of margins on all of
17 these things and they looked at the body of the -- of
18 the pump body and it's really robust and they
19 concluded it wouldn't -- missiles wouldn't fly through
20 that thing.

21 And in that narrow sense it was pretty
22 convincing, but there are other issues, you know, I
23 didn't look into it. But my question was, why would
24 we ever use an untested material retaining such
25 massive components turning at such high speeds. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's where I'm at.

2 CHAIR RAY: All right. So we still have a
3 concern that would be best addressed by saying this
4 material is not going to be susceptible to stress
5 corrosion cracking in the event it's exposed to
6 reactor coolant system or service.

7 MEMBER ARMIJO: Or the plan is for
8 periodic inspection of the can around it. And --

9 CHAIR RAY: Yes. That's another problem -
10 -

11 MEMBER ARMIJO: That's another solution,
12 but, you know, I'd rather test. I'm a metallurgist,
13 so I like to test everything.

14 CHAIR RAY: Okay. Is that clear enough
15 now Rob?

16 MR. SISK: Yes, sir.

17 CHAIR RAY: I'm trying to narrow it down,
18 but still satisfy the issue. I don't think saying,
19 well it won't penetrate the boundary or we can
20 withstand a locked rotor puts it to bed. If it's a
21 critical component as it is here. And by the way,
22 there are two flywheels right?

23 MEMBER ARMIJO: Top and bottom.

24 CHAIR RAY: And we're talking about both
25 of them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: And this is the change
2 from the old AP 1000 pump.

3 MR. SISK: I appreciate the clarity and
4 we'll have the materials and be able to discuss that
5 in more detail in the future.

6 CHAIR RAY: All right. I'm sorry, that,
7 you know, I'm just a bookkeeper here I'm trying to
8 check things off. But, we're not going to check this
9 one off. What do you got next?

10 MR. SISK: The next part we're going to
11 talk about flow measurement and I'd like to invite Mr.
12 Chuck Brockhoff to join us up front.

13 MR. WANG: This is the next slide, number
14 10 in the table.

15 CHAIR RAY: Thank you Weidong.

16 MEMBER BANERJEE: I'm sorry, this is elbow
17 taps?

18 MR. SISK: This is the elbow taps,
19 correct, sir.

20 MR. BROCKHOFF: Yes, sir. My name is
21 Chuck Brockhoff and I'm one of the lead system design
22 engineers for AP 1000 and I wanted to go through a
23 large handful of slides on our flow -- alternative
24 flow measurement process, we've suggested to do in DCD
25 Rev. 17.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There were questions in a previous meeting
2 on RCS flow measurements specifically how we do that
3 and questions relative to the uniformity of flow.

4 I wasn't there for the meeting, but the
5 gist of it was the questions about the use of elbow
6 taps for flow measurements, some information on
7 uniformity of flow to provide some additional
8 background how we'll monitor RCS flow measurements for
9 the system and the alternative methods that we've
10 proposed then are going to use both hot leg and cold
11 leg flow taps that we have.

12 The RCS flow is one of three DNB
13 perimeters in tech spec 341. So these surveillances
14 are in the tech spec to go in and make sure that we
15 have the required flow. And obviously we tripped the
16 reactor on 90 percent flow and that's our safety
17 analysis with uncertainties.

18 The Westinghouse generic tech specs, the
19 standard improved tech specs are NUREG-1431 and they
20 have the use of the precision calorimetric from the
21 secondary system as a basis for flow measurement.

22 We've developed the AP 1000 generic tech
23 specs from that really changing only the differences
24 that were technically related.

25 And generally that precision calorimetric

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculates reactor power from feed water perimeters
2 and then we look at T_c minus T_H and we just divide that
3 by and come up with flow maintenance. So that's the
4 typical method that we do

5 The accuracy isn't affected by anything
6 that affects the temperatures. In this case hot leg
7 streaming, for example, would give you non-uniform
8 flows and that has some effect on accuracy.

9 AP 1000 geometry and the low leakage
10 loading patterns may potentially contribute to hot leg
11 streaming and we considered that uncertainty in our
12 calculation.

13 The tech spec surveillance requirements
14 3.4.1.4 as we've written it, allows the use of an
15 alternative precision flow measurement, which is the
16 use of d/p taps.

17 We're going to do something different for
18 our plant that we can do on startup that a traditional
19 plant typically doesn't have. And the goal was
20 eventually to get to slide seven and we can look at
21 the details of that.

22 So what we're doing is we're allowing an
23 in situ test of hot leg and cold leg flow taps, flow
24 d/ps in the channels to be an alternative method to
25 calculate flow instead of using precision calorimetric

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 divide by temperatures, delta T.

2 This president exists already in plants
3 that's licensed for Farley, South Texas, Diablo
4 Canyon, Seabrook and Watts Bar. And basically that
5 surveillance requirement says that we can use flow
6 measurement or calorimetric divided by the
7 temperature.

8 So there's an alternative way. So we're
9 basically doing that except we're using both hot leg
10 and cold leg instrumentation.

11 MEMBER ABDEL-KHALIK: Just for reference,
12 what is the uncertainty in the RTD measurement?

13 MR. BROCKHOFF: I believe it is -- wait a
14 minute, uncertainty in the RTD?

15 MEMBER ABDEL-KHALIK: Right.

16 MR. BROCKHOFF: Let me ask Rick Tully, are
17 you online?

18 MR. BURNETT: No, Tobey Burnett here.

19 MR. BROCKHOFF: Okay. Tobey, do you know
20 that answer to the RTD uncertainty? I don't actually
21 do the uncertainty calculations.

22 MR. BURNETT: The RTDs themselves are
23 quite accurate, they're well within one degree
24 Fahrenheit. However, they can only measure the
25 temperature of that platinum coil.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There will be variations, at least plus or
2 minus 10 degrees between the temperature of any RTD
3 and the mixed mean hot leg temperature. That's the
4 sorts of the error we're speaking of.

5 MEMBER ABDEL-KHALIK: So you're measuring
6 T hot and T cold individually?

7 MR. BURNETT: Yes.

8 MEMBER ABDEL-KHALIK: So the uncertainty
9 comes in, in both measurements?

10 MR. BROCKHOFF: And the uncertainty
11 calculation would account for that. So the DCD, Rev.
12 17 application that proposes to do the baseline flow
13 measurement testing at the time of startup.

14 When we build the plant, we go in and test
15 it with perfect flow conditions essentially and that
16 gives us a maximum flow of what we would expect to see
17 under conditions and then use that for in situ
18 calibration of the flow instruments for both hot leg
19 and cold leg bends later on through plant life.

20 So we would use those full elements for
21 further flow measurement as an alternative to the
22 precision flow rate that we would calculate.

23 But the key is, and we'll look at how we
24 do this in a couple of slides, is we would take a
25 bunch of baseline data that typically wouldn't be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 available for an existing plant that backfitted this.

2 And that becomes our benchmark for the rest of the
3 plant operating history.

4 MEMBER ARMIJO: Would you recalibrate
5 periodically?

6 MR. BROCKHOFF: There's a requirement to
7 calibrate every refueling cycle. So if you measure
8 d/p and you calculate that to be a flow, then from
9 there on out you set that d/p and adjust the
10 instrument to make that read it when you recalibrate
11 the same value.

12 So that way you can see if d/p changes due
13 to corrosion or some other problem, degradation of the
14 pump impeller performance, you'll see the flow
15 decrease over time. If you plug steam generator
16 tubes, you get lower flow.

17 But it's all based on that benchmark Day
18 One Data.

19 MEMBER ABDEL-KHALIK: Let's just stick
20 with the first bullet. Is this a primary measurement
21 or a derived measurement?

22 MR. BROCKHOFF: Let me go through on slide
23 seven and answer that question. We looked at the d/p
24 that comes to the sensor and we use that to calculate.
25 So it's an actually measured value from the flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instrument itself.

2 MEMBER ABDEL-KHALIK: No. The question is
3 you're saying that during startup you'll have some
4 other means of measuring flow and you will use those
5 to do in situ calibration of your delta P measurement
6 versus flow in whatever secondary measurements you
7 doing.

8 And the question is, are those additional
9 baseline measurements primary measurements or derived
10 measurements?

11 MR. BROCKHOFF: Well they would be a
12 primary measurement. For example --

13 MEMBER ABDEL-KHALIK: You measure the flow
14 directly?

15 MR. BROCKHOFF: No, you don't -- we use
16 the d/p. We measure differential pressure directly,
17 we could measure pump rotor speed because we have a
18 speed sensor on it.

19 MEMBER ABDEL-KHALIK: Right.

20 MR. BROCKHOFF: So we're measuring process
21 perimeters that we use to calculate the flow. The
22 differential pressure sensor has a characteristic that
23 would tell us the differential pressure it's measuring
24 the flow tap.

25 For example, we expect it maybe to be 24

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 psid at 100 percent flow with the sensor.

2 MEMBER BANERJEE: But even the calibration
3 is not a direct measurement.

4 MEMBER SIEBER: No, you're getting it from
5 the secondary calorimetric.

6 MEMBER BANERJEE: I mean you could make a
7 direct measurement using time of flight or something,
8 clearly, but I think the answer to your question is
9 it's not.

10 MR. BROCKHOFF: No. For example, the pump
11 manufacturer gives you a pump speed versus flow curve
12 for that pump based on that impeller configuration.
13 So when you put it in the loop, if you have this
14 certain rotational speed of the pump you know the
15 impeller is delivering this volumetric flow rate.

16 Then that fits into the -- you know where
17 on the head curve you are as far as delivering flow.

18 MEMBER ABDEL-KHALIK: But the fact that
19 this is coming from the pump manufacturer doesn't mean
20 that the flow rate indicated on the pump
21 characteristic is actually a directly measured
22 quantity.

23 MR. BROCKHOFF: No, but eventually when we
24 do the -- I'll show you later on the pre-operational
25 startup test. When we do the startup test, we back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculate to verify the flow.

2 So until we do the precision calorimetric
3 and some other precision measurements that we do, we
4 try to correlate them all as part of our baseline
5 report.

6 MEMBER BANERJEE: So let me clarify this.

7 So imagine that you have a venturi in a line and
8 they're using that to measure the flow. All right,
9 you have issues, maybe the venturi throat gets a
10 little rough over time.

11 MR. BROCKHOFF: Yes.

12 MEMBER BANERJEE: So how do you calibrate
13 this or ultrasonic flow meter? One possible way is to
14 use a time of flight measurement, which is that
15 imagine that you activate with a 14 MeV neutron source
16 or something, I'm just giving a taught experiment,
17 which has been done by the way.

18 And you then look at when that pulse
19 passes another point using a radiation detector. Now
20 knowing that distance and knowing the time it took,
21 you first can get precisely a flow rate.

22 Now there are issues maybe with averaging
23 a little bit, but nonetheless those have been taken
24 care of in many straight pipes, okay.

25 The issue that's coming up here is how do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you -- is this a direct measurement or indirect
2 measurement, that's his question. Clearly if you knew
3 the amount of power to be generated precisely as you
4 can, and you knew the temperature precisely without
5 the RTD, then it's a direct measurement, okay.

6 That's the question. Now, I'm waiting for
7 your answer too. So just to explain what the question
8 is, all the things you've said are not direct
9 measurements, up to now.

10 MR. BROCKHOFF: No. The final direct
11 measurement will be during our startup testing where
12 we do a precision calorimetric, we know the
13 uncertainty of the instruments and we back calculate
14 the flow and we would cross compare that to all the
15 flow measurements and the other indirect measurements
16 --

17 MEMBER BANERJEE: Perhaps explain this
18 precision calorimetric. If you're going to do that,
19 then let's go on.

20 MR. BROCKHOFF: Yes. When we get to slide
21 seven it lists all the things that --

22 MEMBER BANERJEE: Well what is it? What
23 is this precision calorimetric?

24 MR. BROCKHOFF: The precision calorimetric
25 that we do is we basically take enthalpy rise across

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the feed water with systems in the generator pressure
2 to the feed water temperature so we have a temperature
3 uncertainty there with the precision flow meter.

4 And that calculates the heat transferred
5 out of the primary and then on the primary loop, we
6 know the T_H of the core and T_C going back to the core
7 and so we take that power and divide by that delta T
8 and that gives us our mass-flow rate of the reactor
9 coolant system.

10 MEMBER BANERJEE: I guess that's the
11 question he asked. What's the uncertainty on those
12 temperature measurements?

13 MR. BROCKHOFF: On the -- well that's what
14 Tobey was answering. We do have a specific
15 uncertainty calculation that's done for all of our
16 temperature and pressure, anything that gives us trip
17 or safeguards actuation, there's a set point study
18 that combines those, there's a methodology that we use
19 to do that.

20 So we would know what those values are
21 based on the instruments we pick. And when we
22 calculate the flow rate, it obviously conservatively
23 applies those uncertainties.

24 I don't know what they are specifically
25 without looking at the uncertainty report, but we do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evaluate that and that's one of the requirements that
2 make sure our actuation set points are correct for the
3 plant.

4 MR. BURNETT: This is Tobey again. With
5 response to -- in response to that direct question,
6 what is the accuracy of that, on existing plants we
7 achieve accuracy in the vicinity 1 percent give or
8 take.

9 On AP 1000 we are confident we will be
10 able to achieve 3 percent. We probably may get within
11 2 percent, it might be less than that. The limiting
12 factor is our ability to measure the mixed mean hot
13 leg temperature because temperatures will be different
14 in different parts of the hot leg.

15 MEMBER BANERJEE: I guess that was exactly
16 the question.

17 MEMBER ABDEL-KHALIK: It's not just that
18 the temperature is non-uniform, but it's the -- you're
19 measuring these two quantities independently, you're
20 not measuring the temperature difference directly.

21 MR. BROCKHOFF: Yes.

22 MEMBER ABDEL-KHALIK: And therefore you
23 have uncertainty in both hot leg measurement and the
24 cold leg measurement.

25 MR. BURNETT: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: And the measurement
2 itself.

3 MR. BURNETT: The uncertainty in measuring
4 the hot leg temperature swaps out all of the other
5 uncertainties.

6 MEMBER ABDEL-KHALIK: But if you look at
7 that, that's --

8 MR. BURNETT: It's by far the largest.

9 MEMBER ABDEL-KHALIK: -- that is a
10 significant fraction, the uncertainty is a significant
11 fraction of the delta T, but I suspect much more than
12 3 percent. But we'll wait and hear.

13 MEMBER BANERJEE: You are going to have to
14 defend the 3 and 2 percent, okay.

15 MR. BROCKHOFF: Yes, sir. We would have
16 to defend the value that we include in our uncertainty
17 calculation, which it factors into each of the
18 individual measurements.

19 Every measurement includes the
20 instrumentation uncertainty plus the physical process.

21 For example, in the hot leg we have six RTDs that
22 measure in the same plane so we can get a better
23 indication of any potential streaming effects, so.

24 But the end result is we would like to
25 eventually use those flow elements and we do use those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flow elements throughout the cycle variations, which
2 you'll see in just a minute.

3 And this, I put this drawing in so you
4 could see where this actually lies. There's an elbow
5 going up to the hot leg right here and there's an
6 elbow in the cold leg between the pump and the vessel
7 or bed.

8 And we use this taps here and taps for
9 each cold leg and there will be multiple taps in each
10 location.

11 MEMBER ARMIJO: And they are located
12 where?

13 MR. BROCKHOFF: Well, the taps are located
14 typically, the pressure variation gets on the outside
15 of the bend from the centrifugal force going through
16 there.

17 So your hot pressure tap is here and the
18 low pressure tap would be in the inside of the elbow.

19 And so this methodology exists in every Westinghouse
20 plant in the downcomer between the steam generator
21 going over the reactor coolant pump, the elbow --

22 MEMBER BANERJEE: But it's a question of
23 calibration, really.

24 MR. BROCKHOFF: Yes, sir.

25 MEMBER BANERJEE: Because the original

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question arose because, you know, the roughness of the
2 walls and all these things change over a period of
3 time. So you've got to periodically recalibrate them,
4 which is what you're saying you do every refueling
5 outage, right?

6 MR. BROCKHOFF: Yes.

7 MEMBER BANERJEE: If I understand you.

8 MR. BROCKHOFF: Yes, sir. What happens,
9 if we measure day one values, this differential
10 pressure, and we use the instrumentation to calculate
11 a flow that we eventually determine is to be correct,
12 that d/p that exists at that flow condition always is
13 used to reestablish the calibration of that
14 instrument.

15 And what happens is that over time if you
16 get smoothness of the walls getting better, the d/p
17 would actually go up because physical flow increases.

18 If you plug generators, the flow goes down
19 and the d/p would go down and therefore your indicated
20 flow would go down. But every refueling cycle you
21 calibrate back to the original d/p should equal this
22 value from that instrument.

23 And so whatever the physical changes
24 you'll see that reflected in your indicated value.
25 Flow would typically go down over time as you plug

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 generators and your pump impeller performance degrades
2 maybe over 60 years.

3 So you're using that benchmarked data day
4 one to tell you what the correct calibration should be
5 because the taps don't change, you can change an
6 instrument channel, but in the end result, this d/p
7 set into the prime standard measurement d/p
8 transmitter should give you this output. And whether
9 the flow physically changes, you will see that.

10 MEMBER BANERJEE: Well the issue is this,
11 that the pressure drop or pressure change across the
12 elbow is related in some complicated way to the flow
13 rate, let's say volumetric flow rate.

14 Now it's a complicated problem because the
15 water is there and they're affected by the wall
16 roughness and there's a whole lot of things.

17 So what you're trying to do is calibrate
18 this periodically to understand how the relationship
19 between the pressure difference and the volumetric
20 flow is affected.

21 MR. BROCKHOFF: Yes.

22 MEMBER BANERJEE: Now what we are
23 concerned about is, yes, that's nice, we want to know
24 how accurate your benchmark against which you're doing
25 this calibration is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Because let's say if you're doing this
2 based on a heat balance, which is what you're
3 suggesting, then it becomes a function of how
4 accurately you can measure reactor power and how
5 accurately you measure temperature or how accurately
6 you're measuring some flow rate somewhere else.

7 We haven't yet closed that loop, okay. We
8 understand that you recalibrate, we're still open as
9 to how you do that.

10 MR. BROCKHOFF: Okay. Let me see if I can
11 get to slide seven. I think it will show you the
12 range of things we're looking at to make them all --

13 MEMBER ABDEL-KHALIK: Just before we get
14 there. This may be a cartoon, but is the angle of the
15 bend in the hot leg as shallow as this one shows?

16 MEMBER SIEBER: Yes.

17 MR. BROCKHOFF: That's the 3-D, yes, sir.

18 It's not an --

19 MEMBER ABDEL-KHALIK: But, I mean, you
20 know, the field installation is going to --

21 MEMBER BANERJEE: It's not 45 degrees.

22 MEMBER ABDEL-KHALIK: It's not a 90
23 degree, it's not 120 degrees --

24 MR. BROCKHOFF: It's not 90 degrees. It's
25 about 45. I forget the specific geometry, but I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 believe 45 degrees.

2 But anyway, this is a 3-D sketch that
3 shows the relative configuration of the two elbows.

4 MR. BURNETT: We calculate approximately a
5 25 psi delta P between the inside and outside of the
6 hot leg elbow.

7 MEMBER ABDEL-KHALIK: Despite the
8 relatively sort of minor bend that you have in there
9 rather than a large angle bend?

10 MR. BROCKHOFF: It's not a 90 degree bend,
11 it's approximately a 45 degree --

12 MR. BURNETT: I can't vouch for how
13 representative the picture is, but as I say, we
14 calculate about 25 psi delta P from the -- between
15 inside and outside of the bend. It is not a long
16 radius bend.

17 MEMBER ABDEL-KHALIK: It sure looks like
18 it.

19 MEMBER BANERJEE: That's probably
20 accurate, that 25 degrees, yes. Whatever the artistic
21 picture is because that's where we worry about reflux
22 condensation, not in your system. It's pretty sharp.

23 MR. BROCKHOFF: Now, as part of our
24 startup procedure there's two tests that we do. In
25 14-210 we do a flow measurement prior to criticality

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to verify that we get about 90 percent of flow.

2 We know what we get from the design and
3 what we expect to see. And the goal is this is our
4 design basis number that used in safety analysis and
5 we expect to get maybe like 102 percent or something.

6 And then as part of our startup testing,
7 we actually take the reactor critical and we do
8 calorimetrics on our way up to 100 percent power. So
9 when we get to 100 percent power, we know that we're
10 at 100 percent power and that we should be at least 90
11 percent or more of flow and expect more beginning to
12 life.

13 MEMBER SIEBER: Those are secondary
14 calorimetrics.

15 MR. BROCKHOFF: Yes, sir. They're
16 secondary calorimetrics across using precision --

17 MEMBER SIEBER: As opposed to primary
18 calorimetrics.

19 MR. BROCKHOFF: Yes, sir. Our standard is
20 that we use is a secondary calorimetric.

21 MEMBER SIEBER: Over the last 50 years?

22 MR. BROCKHOFF: Yes.

23 MEMBER SIEBER: Okay.

24 MR. BROCKHOFF: Yes, I've done many of
25 them. Anyway, so we will do a calorimetric at 100

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 percent power and we'll calculate flow using a
2 precision calorimetric but we also think we can get
3 better overall accuracy by evaluating data from other
4 sources, which we'll look at next in establishing this
5 baseline for the plant.

6 The baseline flow measurement that we will
7 document in an engineering report at the completion of
8 the plant start up testing is to measure reactor d/p
9 compared to the factory tests that we use with the
10 d/p.

11 We've got d/p measured in the plant and
12 the testing made at the factory. We can use RCP motor
13 current for example, as an indication of power. We
14 have the differential pressures available from the
15 taps and we also may choose to install other
16 differential pressure measurements as part of the
17 testing once we evaluate what we want to do to plant
18 his.

19 And then the at power contribution is a
20 delta T and a calorimetric we just talked about using
21 T_H versus T_C . And we can use T_H and T_C in the loop, we
22 can also use core exit thermocouples that give us a
23 better distributed average of T_H for a measurement.

24 So there's lots of different things we
25 look at and the end result would be that knowing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instrumentation uncertainties as measured, we would go
2 back and try to determine what the overall uncertainty
3 was in flow measurement.

4 And the report would basically give us
5 some flow rated X plus or minus gallons per minute
6 based on the overall process on accuracies in each
7 individual --

8 MEMBER ABDEL-KHALIK: Do you really expect
9 to be able to use the core exit T_c measurements to give
10 you a better estimate of the hot leg temperature?

11 MR. BROCKHOFF: It will give us supporting
12 data for it. I suspect it won't be the thing that we
13 use. But one, it can give us one expectation of the
14 distribution coming out of the core.

15 The accuracy though obviously isn't the
16 same as the accuracy loop instruments.

17 MEMBER ABDEL-KHALIK: Not just that, but
18 do you know the individual flow within individual
19 assemblies that are right below these T_c s?

20 MR. BROCKHOFF: No, you obviously don't.
21 So it's an input that we can use to help us understand
22 is there some benefit we can gain from that.

23 You're right, we don't know the flow
24 through an individual channel and there's not of other
25 things that can contribute. There's leakage around

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the vessel that comes into play, because that
2 eventually comes back in the hot leg.

3 So the goal is to look at the range of
4 instrumentation and information we have and that we
5 can maybe add special stuff to go in and evaluate this
6 and give us a benchmark that the plants that use this
7 today didn't have when they established this process.

8 So we think we'll have better information
9 and we'll figure out how we want to use this and how
10 we can best --

11 MEMBER ABDEL-KHALIK: And yet the
12 statement was made earlier that in current plants you
13 can measure the flow within 1 percent and in this case
14 you expect to be able to measure it within 3 percent.

15 MR. BROCKHOFF: I don't think --

16 MEMBER ABDEL-KHALIK: Could you explain
17 why that's different?

18 MR. BROCKHOFF: I didn't say 1 percent of
19 flow measurement.

20 MEMBER ABDEL-KHALIK: Somebody on the
21 phone said that.

22 MR. BURNETT: Yes, this is Tobey Burnett.
23 What would you like explained, please?

24 MEMBER ABDEL-KHALIK: Why is it that the
25 uncertainty in flow for the AP 1000 is expected to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 greater than that for current plants?

2 MR. BURNETT: Predominately the two loop
3 geometry, second to that the very large hot leg pipe
4 diameter and the very low large -- the extreme low
5 leakage loading pattern.

6 The low leakage loading pattern will cause
7 large variations in temperature coming out of the
8 different core's assemblies. Those will not be
9 completely mixed at all in the hot leg.

10 So the variations in hot leg temperatures
11 at different places, as I've said, we expect to see
12 plus or minus 10 degrees from the average.

13 Now we have 14 total hot leg RTDs at
14 different locations. Each one of them individually is
15 accurate to well within 1 degree. In the cold leg
16 there are a total of 12 RTDs, averages of all of them
17 we expect to be good to within a few tenths of a
18 degree.

19 However, the variation in hot leg
20 temperature, as I've indicated, means that there is
21 uncertainty in the average of the hot leg RTD
22 temperatures and the mixed mean hot leg temperature.

23 MEMBER ABDEL-KHALIK: Thank you.

24 CONSULTANT KRESS: I would envision each
25 of these methods give you a different flow value and a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different estimating uncertainty. I'm not sure how
2 you look at all those measurements and come up with
3 this bottom line and some sort of average flow with an
4 average uncertainty. I don't know how to combine all
5 those things.

6 MR. BURNETT: Each method will have -- has
7 its own uncertainty associated with it and it will be
8 the purpose of the report to reconcile all the
9 variations and explain the differences beside the
10 uncertainties.

11 I'll point out that two plants that I know
12 of, the core exit thermocouples turned out to be the
13 most accurate means of determining flow. There are
14 other plants where the core exit thermocouples prove
15 to be of no value for that.

16 So all we can do is say we will examine
17 them and extract whatever information we can from it.

18 MEMBER BANERJEE: Now, when you do those
19 d/p measurements on the elbows the uncertainty also
20 takes into account that you periodically recalibrate
21 them, is that --

22 MR. BURNETT: No, the elbows themselves
23 are not recalibrated, only the instruments that
24 measure the d/p.

25 MEMBER BANERJEE: Right. But there's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different relate as time evolves the relation between
2 d/p and flow will change or maybe expected to change
3 due to changes in roughness and other factors, right?

4 MR. BURNETT: We do not expect any
5 significant change in flow due to roughness of piping.

6 There has been a very small change in measured
7 reactor coolant pump performance because of the
8 phenomena called impeller smoothing.

9 We do not believe that there would be any
10 significant effect on the roughness of the pipes in
11 the reactor coolant piping system.

12 MEMBER BANERJEE: So you don't expect the
13 d/p-flow relationship to change over time?

14 MR. BURNETT: Say again please?

15 MEMBER BANERJEE: So you don't expect the
16 d/p versus flow relationship to change over time?

17 MR. BURNETT: No, we do not.

18 MEMBER BANERJEE: And is that borne out by
19 current operating plants?

20 MR. BURNETT: Yes.

21 MEMBER BANERJEE: And how do you know
22 that? Do you periodically check that relationship?

23 MR. BURNETT: That was the basis for the
24 work that was done on the plants that mentioned on the
25 first slide, Farley, South Texas, Seabrook and so on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In those cases for these plants and treatment plants,
2 measurements over various cycles indicated no changes
3 in the delta P.

4 However, in that case there was a reason
5 to be concerned about that because those were bends,
6 elbows in the cold leg and the concern was that they
7 could be impacted by changes in steam generator two
8 plugging.

9 The indication -- the results of the
10 measurements over time indicated that there was no
11 impact.

12 MEMBER BANERJEE: And how did you
13 determine that? Was that by doing some precision
14 measurements? That's what we were trying to
15 understand.

16 MR. BURNETT: On those plants the basis
17 had been the calorimetric delta T method.

18 MEMBER BANERJEE: And where was this
19 calorimetric delta T done, on the primary side of the
20 secondary?

21 MR. BURNETT: Well, the primary is the hot
22 leg and cold leg temperature, the secondary is the
23 feed water calorimetric, feed water flow temperature
24 and steam pressure.

25 MEMBER BANERJEE: So was that the primary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 measurement that you used to determine whether this
2 d/p changed or not? Was it the latter measurement or
3 the primary measurement?

4 MR. BURNETT: Originally that method, feed
5 water calorimetrics and primary delta T had been the
6 primary method used to measure flow.

7 MEMBER BANERJEE: And is that what you
8 used to determine that the d/p was not changing with
9 time over the hot leg and cold leg bends?

10 MR. BURNETT: That substantiated it.

11 MEMBER BANERJEE: What other method was
12 there?

13 MR. BURNETT: I beg your pardon?

14 MEMBER BANERJEE: What other method -- if
15 you just say this act substantiated it --

16 MR. BURNETT: Oh, one does not expect the
17 elbow tap delta P to change with time. It is a
18 function of the geometry and since the geometry does
19 not change, one does not expect the calibration -- the
20 delta P characteristics to change. That's why I said
21 it was substantiated.

22 MEMBER BANERJEE: Yes, but that's not what
23 you find with Venturis that were used --

24 MR. BURNETT: Venturis can foul and since
25 they are very sensitive to the throat diameter, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can occur. But when you have 31-inch ID pipe, no
2 fouling is not a factor.

3 MEMBER BANERJEE: Well it's not the
4 fouling which is what caused the problem with the
5 Venturis, the throat roughness.

6 MEMBER SIEBER: It depends on the Venturi.

7 MEMBER BANERJEE: Yes. The problem is a
8 different one because when you go around the bed, what
9 you set up is a secondary flow, which is very, very
10 sensitive to all roughness. Therefore, I can't take
11 that as the primary answer, you must check that
12 against some other measurement.

13 So if you say that you check it against
14 delta Ts and things, that's fine, but I wouldn't go
15 into the assumption that you're not expecting the
16 shape to change.

17 Nobody expects the shape to change, it's
18 the roughness which changes. Maybe the roughness
19 doesn't change on the primary side, I don't know, but
20 I wouldn't assume it.

21 MR. BROCKHOFF: Sir?

22 MEMBER SIEBER: Do you use the elbow taps
23 in the primary system, the differential pressure,
24 which is an indicator of flow for any safety signal in
25 the plant reactor trip, for example?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BROCKHOFF: We use the hot leg for low
2 flow trip indication.

3 MEMBER SIEBER: Hot leg temperature or --

4 MR. BROCKHOFF: No, we use the hot leg
5 flow tapping. Well, the temperature is used for o/p
6 and o/t delta T indication.

7 MEMBER SIEBER: Right. What do you use
8 the flow, is there a reactor trip that comes from a
9 flow signal?

10 MR. BROCKHOFF: Yes, sir. A low flow, at
11 90 percent in the hot leg. So that tells us we lost
12 flow to either steam generator and we could generate a
13 trip. That's why the original 90 percent in that
14 previous slide. At any rate, let me --

15 MEMBER ARMIJO: How deep into the flow do
16 your --

17 MEMBER BANERJEE: I thought they were on
18 the wall.

19 MEMBER ARMIJO: -- are they wall taps or
20 do they go in a couple inches?

21 MR. BROCKHOFF: They're wall taps.

22 MEMBER ARMIJO: They're right on the wall,
23 so it's surprising that surface roughness or oxidation
24 over time wouldn't change the d/p.

25 MEMBER BANERJEE: Well, they do, so it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not correct that they don't. They do change, that's
2 the thing. So there is a -- definitely we know with
3 Venturis, it's not fouling, it's simply roughness
4 changes which causes this problem.

5 Okay. So there is a significant issue.
6 Now maybe it doesn't happen in this case, but in
7 general it does. So it's not a general conclusion.

8 MR. BROCKHOFF: Well the purpose -- again,
9 the purpose to integrate everything is to try to
10 compare the various measurements against one another
11 and to have this baseline report to start with.

12 CHAIR RAY: Well, but wait. I think
13 there's a key point here which Sanjoy keeps coming
14 back to, which is does the characteristic change d/p,
15 elbow d/p over time? Because that's not going to be
16 discerned by any of the --

17 MEMBER BANERJEE: No, it's true because of
18 the comparison periodically calibrated. So I --

19
20 CHAIR RAY: Yes, but you were asking if
21 you could infer the change in the characteristic of
22 the elbow d/p versus flow and I thought he said no.

23 MEMBER BANERJEE: No I think maybe I got
24 the wrong end of the stick, but I thought that
25 periodically you could compare that with your delta T

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 measurements and things but on startup and things like
2 this where your core temperature variations are not
3 that great.

4 MEMBER SHACK: I think the difference was
5 that Sanjoy looked to that answer to really answer the
6 question.

7 MEMBER BANERJEE: I thought it was
8 answered actually.

9 MEMBER SHACK: What we heard was his
10 initial conclusion that it wasn't going to change, but
11 that's, you know, it's a semantics sort of thing. I
12 mean, the --

13 MR. CUMMINS: Maybe I can help. The tech
14 specs for you to every outage to calibrate the flow
15 with a calorimetric. So yes, you must, yes you must
16 calibrate it with a calorimetric.

17 MR. BURNETT: No.

18 MEMBER BANERJEE: That answers the
19 question, you don't need to say more.

20 MR. BURNETT: No.

21 CHAIR RAY: Somebody's saying no.

22 MEMBER BANERJEE: Yes, Tobey.

23 MR. BROCKHOFF: Let Tobey talk, he knows
24 best.

25 MR. LYMAN: May I interject something here

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at this point? Walt Lyman, right. Concerning elbow
2 taps, we use as a reference the ASME fluid meters
3 book, which itself refers to many, many elbow tap
4 tests.

5 And one of the conclusions that the tests
6 have come out with is that roughness on the surface of
7 the elbow has no effect on the measurement. And
8 that's what we rely on as backup as a reference.

9 Meanwhile, the plant data that we have
10 does not indicate that there's a systematic effect on
11 flow with time.

12 MEMBER BANERJEE: Well, but you do have
13 the ability to check that, right?

14 MR. BURNETT: I would disagree with that.
15 That is it is my belief that once you have a flow
16 calculated for -- once you know what the d/p
17 characteristic of the elbow is, it will be superior to
18 any other means by which you can check flow.

19 You can look at what we call the
20 calorimetric delta T method on later cycles and that
21 will help you determine how much in error the
22 calorimetric delta T is with time.

23 MEMBER BANERJEE: I guess we're not going
24 to resolve this.

25 MR. BURNETT: But if you want to know the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flow, then look at the delta P from the elbow taps.

2 MEMBER BANERJEE: I guess we now go back
3 to Said's original question.

4 MEMBER ABDEL-KHALIK: Let me just put the
5 question differently. Do you expect the relationship
6 between, let's say hot leg flow and delta P in the tap
7 to be a unique relationship independent of the
8 temperature distribution within the hot leg?

9 MR. BURNETT: Essentially yes. That is,
10 we do not expect it to change with time.

11 MEMBER ABDEL-KHALIK: No, no, no, no.
12 That's not the question. The question is, is it
13 independent of the temperature distribution within the
14 hot leg.

15 If you're telling me that the temperature
16 across the hot leg can vary by as much as plus or
17 minus 10 degrees from the average hot leg temperature,
18 the question then is is this a unique relationship?

19 If you have a -- now, it's not just
20 geometry --

21 MR. BURNETT: Part of it will be somewhat
22 stable, but not necessarily because they are forced by
23 the variation in the core exit temperatures and the
24 peripheral assemblies will always be cooler than the
25 average toward the center, but there will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 variations in the core power distribution and core
2 exit temperatures.

3 MEMBER ABDEL-KHALIK: I think we're sort
4 of drifting from the core of the question. You
5 implied that the delta P across the tap versus flow is
6 dependent only on the geometry.

7 So if I had significant variations in
8 density of the fluid that's going through this pipe,
9 that doesn't have any impact on this relationship?

10 MR. BURNETT: It has an impact, but I
11 submit that that is second order because the variation
12 and density. We're not talking about the difference
13 in density between the hot leg and cold leg, we're
14 talking about less than plus or minus 10 degrees
15 maximum.

16 MEMBER ABDEL-KHALIK: What is delta T
17 across the core?

18 MR. BURNETT: Average between hot leg and
19 cold leg about 75 degrees.

20 MEMBER ABDEL-KHALIK: Okay. So 20 degrees
21 out of 75, that's a significant fraction, don't you
22 think?

23 MR. BURNETT: Yes.

24 MEMBER BANERJEE: And the effect of the
25 roughness, by the way even if it is small, is because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you've got wall taps. And the problem that happens
2 with wall taps is that if you change the roughness in
3 their vicinity, their measurement changes
4 significantly.

5 So unless you can guarantee absolutely
6 that the taps stayed perfect -- how large are these
7 taps in size? How big are they? Are they --

8 MR. BROCKHOFF: I believe they're one
9 inch.

10 MEMBER BANERJEE: One inch taps?

11 MR. BROCKHOFF: Yes, sir. That's our
12 standard smallest line size.

13 MEMBER BANERJEE: And these are flush with
14 the wall?

15 MR. BROCKHOFF: Interior wall, yes, sir.

16 MEMBER BANERJEE: They are just little
17 holes?

18 MR. BROCKHOFF: So there's no turbulence
19 added by the tap.

20 MEMBER BANERJEE: Well there's always
21 turbulence because you get a --

22 MR. BROCKHOFF: I mean not protrusion
23 other than the turbulence of the actual hole itself.

24 MEMBER BANERJEE: So typically what
25 happens at these taps is that you get a little vortex

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sitting in there and usually they're affected. Now
2 you may have a magic tap, which is not.

3 Having made pressure tap measurements all
4 my life, I see this as not that easy to guarantee that
5 doesn't change. But maybe it doesn't, I don't know.
6 I'm not going to pursue it, so let's leave it. Move
7 on.

8 CHAIR RAY: Well, Sanjoy I --

9 MEMBER BANERJEE: I'm so skeptical that
10 things don't change. Even in an experiment in the lab
11 they change over a period of time.

12 CHAIR RAY: I'm happy to move on, but I
13 don't want to drop this item. Can we narrow it down
14 to this question that you are still discussing --

15 MEMBER BANERJEE: Well I think that -- you
16 know what I'm most satisfied with actually is that you
17 have several different methodologies that you
18 periodically check it and then it just becomes a
19 matter of opinion. Which is more accurate or not? I
20 don't think it's particularly relevant to the
21 discussion.

22 We simply wanted to be sure that you had a
23 robust way to measure things which did not only depend
24 on elbow measurements. So I think you answered those
25 two things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR RAY: So you're satisfied that you
2 don't need any further follow up?

3 MEMBER BANERJEE: No, because they have
4 many redundant methods that can do a reconciliation, I
5 mean the procedure seems okay. They are going to do
6 secondary site measurements, they're going to do
7 primary site, you know, startup, tech specs.

8 CHAIR RAY: Do you want to carry it any
9 further?

10 MEMBER ABDEL-KHALIK: I mean, I'm not
11 really concerned about the 90 percent core flow trip
12 signal or any of this stuff. There are other things
13 that are highly dependent on core flow as you're well
14 aware.

15 When you calculate how much sub-cooled
16 boiling you'll have in the hot channels, that will
17 depend -- that will be very sensitive to core flow.

18 And therefore, you know, when you talk
19 about crud accumulation in the hot bundles, et cetera,
20 that will be dependent on this. And any calculation
21 that you may make about boron deposition and impact on
22 shut down margin and all that will be significantly
23 affected by whatever calculation of core flow you'll
24 come up with.

25 CHAIR RAY: But given Sanjoy's assessment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that there are multiple methods that are going to be
2 cross checked against each other, it seemed like the
3 only issue was the time duration variation and the
4 elbow tap measurement.

5 MEMBER ABDEL-KHALIK: I agree with the
6 issue as posed by Tom. Each one of these will give
7 you a different answer, will give you a different
8 uncertainty and I'm not sure how you'll come up with
9 that bottom line.

10 MEMBER BANERJEE: Presumably they have to
11 satisfy somebody that they've been reconciled.

12 MEMBER ABDEL-KHALIK: It will satisfy the
13 90 percent requirement, that's not a problem. That's
14 not a problem.

15 CHAIR RAY: Would you like to frame a
16 further item?

17 MEMBER ABDEL-KHALIK: I don't know how to
18 pose the question other than, you know, perhaps the
19 way that Tom posed it, is how are you going to
20 reconcile all these different presumably independent
21 ways of estimating a core flow and the uncertainty in
22 core flow. Is that?

23 CONSULTANT KRESS: That's my question.

24 MEMBER ABDEL-KHALIK: Right.

25 MR. BROCKHOFF: And that's one of the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's really one of the tasks from our engineering
2 report is to do that with to the satisfaction of staff
3 review. I mean, that's our plan.

4 MEMBER BANERJEE: But I don't think it's
5 satisfactory to refer to some ASME document and say
6 that, you know, this is why we have such faith in this
7 measurement.

8 MR. BROCKHOFF: Well I think the may and
9 the faith is the different ways that we measure it and
10 satisfy that if there is variation we've identified
11 it, we think from the various methods that are
12 available.

13 CHAIR RAY: Okay. Are we satisfied with
14 the staff review then of what they do in accordance
15 with this multiple sources of checking flow? Anybody
16 want to carry an additional item otherwise we're going
17 to close this and move on? Thank you Rob.

18 MR. SISK: Excuse me Chairman, is this
19 closed?

20 CHAIR RAY: Yes. It's closed until we
21 open it again.

22 MR. SISK: Fair enough. I'd like to
23 invite Mr. Phil Kotwicki up to one more item that we'd
24 like to discuss this morning, I think it's item 29 on
25 your action item list. It's the criteria for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 striping.

2 CHAIR RAY: Actually, it's thermal
3 stratification and cycling and striping, more
4 elegantly stated. Harold will be back in a minute,
5 but we can proceed.

6 MR. KOTWICKI: Okay. My name is Phil
7 Kotwicki, I'm a member of the AP 1000 piping and
8 support group. We're going to talk about thermal
9 stratification and cycling and striping.

10 That issue is something that we basically
11 follow the MRP-146 guidelines to do our screening.
12 Basically a first step is to look at your normally
13 stagnant branch lines and the MRP-146 was really
14 looking at just the lines that feed into the reactor
15 coolant loop.

16 What's changed over the years is this
17 potential for turbulent penetration or swirling that
18 can move up into or down into lines that typically you
19 wouldn't expect that to occur with.

20 Normally, you can do the first step just
21 by starting with a P&ID or piping and instrument
22 diagram to look at the paths and look at flows
23 stagnant systems to see where you're going.

24 There are three example. Again, these are
25 pretty much pictures out of the MRP-146. You've got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an up-horizontal configuration, you got basically a
2 horizontal piping configuration or a downward
3 horizontal piping configuration.

4 And again, there is no flow into or out of
5 these lines other than what you would get from this
6 penetration that we're talking about. You can get,
7 obviously, migration of denser colder water downward
8 and less dense hotter water upward, but that's less of
9 an issue than some of these other a little more
10 complicated penetration issues.

11 What we found and what MRP-146 has
12 identified is that when you do have a certain level of
13 stratification, you can kind of tie this to an
14 endurance-limit kind of thinking so that the global
15 vending that you would get from a stratified pipe in
16 addition to the local stresses that would induce to
17 give you a peak stress kind of value when you've got
18 maybe a 50 degree top to bottom across, a cross-
19 section kind of temperature differential.

20 It's kind of the threshold where you're
21 starting to get concerned. So if you get a value less
22 than that, you're basically looking at something that
23 is less than the endurance limit and if you've got 10
24 million cycles, it's still okay.

25 MEMBER BANERJEE: How are these -- was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there some sort of accelerated testing done to come up
2 with these criteria? Because it depends on the number
3 of cycles, right?

4 MR. KOTWICKI: Right. I mean they're
5 basically going into the fatigue curves and saying
6 this value is at what, 2.5 times 10 to the seventh and
7 it gives you this value. And as long as that number
8 of cycles associated with that stress --

9 MEMBER BANERJEE: So it's expected to last
10 60 years or whatever the number is?

11 MEMBER SIEBER: It's pure elastic.

12 MEMBER SHACK: He's not really trying to
13 design this, he wants to get down to where the
14 endurance limit, to where the life is very, very long.
15 And so, you know.

16 MEMBER BANERJEE: Okay. So you're going
17 to asymptotic?

18 MEMBER SHACK: Right.

19 MEMBER BANERJEE: And saying that this is
20 the --

21 MEMBER SHACK: Since it's not truly
22 asymptotic he's always going to give you a number, but
23 it's a number that's out to like 10 to the seven
24 cycles. It's a very large number, you're not going to
25 sit there and try to count them, you just --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: And this is established
2 over a basis of experiments?

3 MEMBER SHACK: Right. Well, experiments,
4 you don't do any experiments at the 10 to the seven.

5 MEMBER BANERJEE: You can do it with the
6 rapid cycling?

7 MEMBER SHACK: Yes, you could -- I haven't
8 seen those too many out there, but yes, you get them
9 as far out as you can and then you have rules for how
10 to conservatively extrapolate.

11 MEMBER BANERJEE: Extrapolate, okay.

12 MR. KOTWICKI: Again, the screening is
13 really the first step in a larger process. The
14 screening is trying to say can I look at something and
15 dismiss it immediately or do I need to carry it along
16 as a potentially susceptible situation, so.

17 The real small sizes we really don't
18 expect to see, and we're identifying two-inch and
19 smaller as that size to kind of dismiss because the
20 type of penetration we're talking about isn't really
21 significant for that.

22 Pressure devices in the line, very
23 relatively long vertical sections where, you know,
24 something can happen in the vertical section, but
25 unless the horizontal turn is close enough, you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really not going to be too concerned about it, so.

2 MEMBER ABDEL-KHALIK: Could you explain
3 the last bullet on this? What does it mean when
4 something's greater than the maximum or less than the
5 minimum specified in XYZ?

6 MR. KOTWICKI: When we're looking -- there
7 are ranges for this vertical length of piping where if
8 it's long enough you don't need to worry about it,
9 this phenomena developing into the horizontal section.

10 So if all of this is going on in the
11 vertical section, you're not really getting
12 stratification. You don't get -- you can get
13 stratification at a vertical section, but it doesn't
14 really do you any damage.

15 When you get it in the horizontal section
16 is when it starts causing bending and issues that
17 you're concerned with. So they're identifying a
18 maximum and a minimum in this document to be concerned
19 with. Your question?

20 MEMBER BANERJEE: I guess it would be nice
21 if those limits were clearer is what you meant. How
22 much is it?

23 MR. KOTWICKI: Well, it will be -- it will
24 depend on pipe size and other perimeters.

25 MEMBER BANERJEE: Right. So there's some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 relationship they've given you.

2 MR. KOTWICKI: I mean if you've got a 30-
3 inch pipe it may -- it will be a different value than
4 if it's --

5 MEMBER BANERJEE: Is it sort of an L by B
6 or something?

7 MR. KOTWICKI: That probably factors into
8 it, I'm not sure that I completely understand where
9 those things came from, from this particular document,
10 but.

11 MEMBER BANERJEE: I mean, the main thing
12 is that this document exists as guidance.

13 MR. KOTWICKI: Yes.

14 MEMBER BANERJEE: When I ask the question
15 I remembered from tests that were done in France back
16 in the maybe 20, 25 years ago which showed this
17 closed-end pipes that they were very serious effects
18 due to the vortices going in and out and creating
19 thermal striping.

20 MR. KOTWICKI: Right.

21 MEMBER BANERJEE: And obviously EPRI did
22 something about it after that.

23 MR. KOTWICKI: Well, this has got a
24 history, there have been --

25 MEMBER BANERJEE: It's been going on for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 long time.

2 MR. KOTWICKI: -- come up where, you know,
3 cracking has occurred and leakage has occurred.

4 MEMBER BANERJEE: Right.

5 MR. KOTWICKI: We've got a new design we
6 want to be looking at this type of thing.

7 MEMBER BANERJEE: Yes, so let's go on.

8 MEMBER SHACK: This is screening for both
9 the stratification and the striping? I look at them
10 as different.

11 MR. KOTWICKI: Well, yes. The striping is
12 a little peculiar, and again, this is really if you've
13 got stratification, you really need stratification to
14 get striping, it's just a different phenomenon in a
15 downstream phenomenon in the way we would look at it.

16 I think of striping more as you've got a
17 pretty well defined boundary of cold and hot and that
18 boundary --

19 MEMBER SHACK: Shifts up and down.

20 MR. KOTWICKI: -- tends to fluctuate. So,
21 until you get the stratification, you don't have the
22 striping. So we'll screen according to that in the
23 first place.

24 MEMBER BANERJEE: It's really the striping
25 which gives you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KOTWICKI: Right.

2 MEMBER BANERJEE: -- the moving?

3 MR. KOTWICKI: Yes. And that's the kind
4 of thing we would look at, you know, as part of a
5 fatigue analysis. And what we've done -- and we've
6 already gone through at least the screening aspect of
7 this in the AP 1000 plant.

8 We've identified in the DCD those lines
9 that again, the first cut, these are potentially
10 susceptible to thermal stratification and potentially
11 striping.

12 So we've listed the lines, it doesn't
13 necessarily mean that all of these lines are going to
14 be something we need to do something very positive
15 about, but what it does indicate is that we will take
16 these lines, potentially go to a next step of doing an
17 analysis to define what that level of stratification
18 is.

19 If that's bad enough, then we'll take the
20 next step of doing, you know, incorporate a fatigue
21 analysis. The MRP-146 says, you know, depending on
22 where you are with all of these types of inputs, do I
23 do more inspection, should I monitor this line, should
24 I change the layout it's so bad, do I get a UC factor
25 that says this is horrible you better do something

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 else.

2 So, the screening is just the first part
3 that says here's what you have that's susceptible, you
4 know, the next step do an analysis and see whether
5 that susceptibility is high enough to worry about.

6 You know, the next step might be, you
7 know, some kind of a design change, but --

8 MEMBER BANERJEE: But when is this process
9 going to be closed? I mean, this is an ongoing
10 process right now, right?

11 MR. KOTWICKI: The overall process of
12 addressing the issue of thermal stratification and
13 striping, you know, you got the screening, which is
14 all we're really talking about here, you've got the
15 analysis, this would factor in to the ultimate fatigue
16 analysis.

17 So we have that factor and this, I expect,
18 to be -- we're hoping we're done with this by the end
19 of the year.

20 CHAIR RAY: This, being the screening?

21 MR. KOTWICKI: This being the screening
22 analysis and the follow up analysis and incorporation
23 into a fatigue analysis.

24 MEMBER BANERJEE: So assuming that you buy
25 into the screening, which there's no reason why not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to, those are essentially the lines which appear to
2 need some further analysis.

3 MR. KOTWICKI: Well, and we'll say
4 potentially susceptible to.

5 MEMBER BANERJEE: Yes, potentially
6 susceptible. So now let's say that you do more
7 detailed work on these and a couple of them turn out
8 to be problematic, what would you do about it? You
9 might change something, right, but you're going to
10 close this whole process by the end of the year?

11 MR. KOTWICKI: Well, and again, if a
12 little more severe action is required, then we may
13 need, you know, a regulatory review of a change.

14 But if we do something that says, I can't
15 stand the way that this thing is laid out because it's
16 giving me problems, I may change the layout. We
17 wouldn't be anxious to do that.

18 MEMBER BANERJEE: Obviously not. But
19 there is sort of, if you like a sort of a process now
20 in motion that one you screen, two you do some
21 analysis, three you come to some decisions as to
22 whether anything needs to be changed.

23 Some of these changes, if any, may not
24 have any regulatory impact, but some of them might.
25 So that's eventually potentially a small number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 items which might need regulatory blessing at some
2 point that it's okay.

3 And I'm wondering if that whole process
4 can be done by the end of the year, because it looks
5 like you've got to do a fair amount of analysis with
6 all these lines there.

7 MR. KOTWICKI: Right. And it's not like
8 we haven't started.

9 MEMBER BANERJEE: Right.

10 MR. KOTWICKI: I mean we're not starting
11 today. I mean we've done one of the follow-up steps
12 when we say analysis is this CFD analysis. So this is
13 --

14 MEMBER BANERJEE: Well I have some
15 concerns about that because when you are looking at
16 things like sharp interfaces, if the CFD analysis
17 isn't being carefully tested against experiments,
18 there are issues with how say it seems like turbulence
19 behave near sharp interfaces.

20 And most commercial CFD methods are not
21 very good at predicting this. It can give you some
22 qualitative information, but I don't think it can give
23 you some quantitative information.

24 Now, maybe the French can do it because
25 they've been involved with this problem for a long

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time, but I don't know if you have access to their
2 codes. You're probably using some standard like
3 FLUENT or STAR-CD or I don't know what.

4 MR. KOTWICKI: Yes, we're using CFX.

5 MEMBER BANERJEE: Oh, CFX. So these
6 probably will have potentially problems in what is
7 happening with these interfaces. So I don't think
8 they can be used in a quantitative way. They can
9 indicate qualitative, what's going on.

10 So your -- my concern would be how much
11 reliance you can place on CFD versus, you know, actual
12 experimental data that exists in these range of sizes
13 and things. And they may be quite a bit, I don't
14 know.

15 MR. KOTWICKI: And I agree with you. You
16 can do an analysis, and anyone that does an analysis
17 needs to look at it and say do I believe these
18 results.

19 MEMBER BANERJEE: And I have a problem
20 with CFD.

21 MR. KOTWICKI: Well, you're not the only
22 one. The one thing that we've committed to do is
23 specifically monitor the surge line for our first
24 plant.

25 MEMBER BANERJEE: That sounds very robust.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KOTWICKI: And are we able to predict
2 what we're able to measure. So, I mean, if those are
3 night-and-day different, then somebody's got to go
4 back and maybe look at --

5 MEMBER SHACK: Well just in terms of data,
6 you've been monitoring surge lines --

7 MEMBER BANERJEE: Yes, that's what I was
8 going to ask.

9 MR. KOTWICKI: We've got a very unique
10 surge line on this plant.

11 MEMBER SHACK: No, but as far as verifying
12 the tool.

13 MEMBER BANERJEE: At least supporting it.

14 MEMBER SHACK: Supporting the tool.
15 Verifying is a strong word, right.

16 MR. KOTWICKI: Well, can you simulate or
17 test for everything you can possibly think of? I mean
18 you're really not going to get to that.

19 MEMBER BANERJEE: What brought this on was
20 your ADS four lines and, you know, things are
21 different in this design. So part of the question is
22 associated with that and the new factors compared to
23 your other plants.

24 MR. KOTWICKI: We are certainly doing more
25 of this type of analysis than we've done for other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants, so.

2 MEMBER ABDEL-KHALIK: If you're concerned
3 about this issue for the hot leg, does that translate
4 into some constraints? The hot leg is one of the
5 lines that you will analyze, does that translate into
6 some constraints on correlating patterns?

7 MR. KOTWICKI: I don't think so. I
8 started out by staying for all intents and purposes,
9 this is for stagnant conditions, so this is not for
10 hot or cold leg during normal conditions, these are
11 shutdown conditions where the hot leg would be
12 involved in something like this.

13 MEMBER BANERJEE: It has to be
14 significantly stratified.

15 MR. KOTWICKI: Right. In fact, it's not
16 even full in that particular case that we're talking.

17 And I think the last I heard, and this DCD input is a
18 little dated in the sense that, I think the operating
19 mode that was causing the problem actually went away.

20 So, I'm not even sure it's part of the system design
21 anymore, so.

22 MEMBER BANERJEE: What was that?

23 MR. KOTWICKI: I believe it was mid-LOOP
24 operation.

25 MEMBER BANERJEE: Can you just explain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that a little bit?

2 MR. KOTWICKI: I think, of course, and I'm
3 not a systems guru, but during shutdown this thing can
4 be half full or whatever and you can have transients
5 that could potentially occur during this condition
6 that you've got a stratified case and you've got some
7 kind of flow coming into or out of that that is
8 potentially giving you something that you want to
9 analyze for.

10 So that's why it was screened in and why
11 it was there for just initial set of lines that
12 potentially susceptible.

13 CHAIR RAY: Are you satisfied Sanjoy?

14 MEMBER BANERJEE: Yes. Well, I'm
15 satisfied by the procedure, I'm just wondering how
16 it's going to close, but that's a separate issue.

17 CHAIR RAY: Well, he's got a last slide
18 here which doesn't actually use the word close, but it
19 uses the word closure, which is the DAC closure, is
20 when it's satisfied, which you were asking about
21 something much sooner than that I think.

22 MEMBER BANERJEE: I was just asking about
23 the schedule, what that says is this will be closed in
24 the DAC.

25 MEMBER SHACK: Yes, but they're going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get rid of the DAC, that's still the plan isn't it or
2 isn't it?

3 MR. CUMMINS: Ed Cummins. No, the piping
4 DAC --

5 MEMBER SHACK: That's the piping of
6 course.

7 MR. CUMMINS: This is a piping DAC issue
8 and basically Phil's comment that if you finish that
9 around the end of the year, that doesn't support our
10 current licensing schedule. So we've retained our
11 position on the piping DAC in making it not included
12 in the revision to the circ pipe design.

13 CHAIR RAY: Anything else? Going once,
14 going twice? All right we're a little behind
15 schedule. We're going to go ahead with the last
16 action item because when we come back from lunch, we
17 want to go into a closed session for the shield
18 discussion.

19 MR. SISK: Mr. Chairman, for that last
20 item, did we resolve the question or is there --

21 CHAIR RAY: This item is closed.

22 MR. SISK: This item is closed.

23 CHAIR RAY: Check it that way, and Rob
24 I'll do the same.

25 MR. SISK: Thank you. The last item

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 before we get started I'm going to kind of be a Parrot
2 up here, but is Mark Stella online?

3 MR. STELLA: Yes, Mark Stella is here.

4 MR. SISK: Okay. Mark, we're going to get
5 to the high-density polyethylene piping I believe it's
6 item 50 --

7 MR. WANG: Forty.

8 MR. SISK: Forty. Thank you.

9 CHAIR RAY: Go.

10 MR. SISK: Okay. The purpose of this
11 discussion is to provide information regarding the
12 criteria for use of the high-density polyethylene
13 piping in AP 1000. That's where we use this and
14 summarize a little bit of the advantages of it.

15 I won't go through the questions on -- the
16 ACRS question on high-density, but what I will do is
17 slip to the fourth slide in the interest of time.

18 MEMBER RYAN: Oh, no, don't rush.

19 MR. SISK: Very well. High-density
20 polyethylene piping is not used in safe related fluid
21 system applications in AP 1000, it's Class D or lower.

22 The usage adheres to the requirements of Code Case N-
23 755.

24 NRC has approved safe related applications
25 at high-density pipe at at least two other operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants, but I do want to kind of reiterate that we're
2 not using it as the key application at this point.

3 We're also not using it to transport
4 radioactive process fluids. All the high-density
5 piping applications that we use is low-grade. And
6 generally speaking, we use it in two applications, SWS
7 flowdown alternate make-up lines and the -- I don't
8 see it on here, but I thought the fire lines we also
9 had it used.

10 HD piping is routed underground to
11 eliminate the possibility of impact damage and
12 material degradation due to UV. Underground
13 installation methodology used to ensure protection of
14 piping for distortion and damage of above ground live
15 loads.

16 MEMBER SHACK: Are all those spelled out
17 in the Code Case of acceptable methods for doing that
18 or is that your judgment?

19 MR. SISK: Mark?

20 MR. STELLA: There are the guidance in the
21 Code Case for use of HDPE in various safety-related
22 applications I don't recall whether all the details
23 are spelled out, but I'm sure that it references
24 acceptable ASTM standards and the use of vendor
25 standards for installation, use of thrust blocks and,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you know, supports where necessary.

2 I can't recall off the top of my head, I
3 haven't looked at that Code Case in a couple of
4 months, so.

5 MEMBER SHACK: Okay. But it would lead
6 you to other standards I presume?

7 MR. STELLA: Yes, it would. There are a
8 plethora of other standards ranging from standard-
9 specific for making the heat fusion joints to, you
10 know, the supports and installation of thrust blocks,
11 for example, where the pipe ends and comes up out of
12 the ground and where there are transitions between
13 HDPE and metallic pipe where you need to take into
14 account the different thermal expansion capabilities
15 of the two types of pipe.

16 So it's not, you know, when these things
17 are being -- the systems are being designed and being
18 installed, this isn't just being done in a way that is
19 unguided. There is substantial guidance for the use
20 of these HDPE pipes.

21 The largest-bore pipe that I know of right
22 now in AP 1000 is no more than 10 inches for AP 1000.

23 We have probably pipe of that size in the part of the
24 RWS and WWS, but those are all site-specific
25 applications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I'm not familiar with exactly what
2 they're using, but the blowdown and alternate make-up
3 lines in SWS are smaller bore piping to begin with.

4 MEMBER SHACK: Now the staff has approved
5 this for some applications, have they approved the
6 Code Case or just is this still application specific?

7 MR. MELTON: This is Mike Melton. The
8 staff approved a specific application for Catawba and
9 for Calloway.

10 MEMBER ARMIJO: What was the application?

11 MR. MELTON: I can't speak for the
12 stations, but they were Class 3 applications and then
13 they went on and did much extensive pipe replacements
14 with the varied piping.

15 MEMBER BROWN: What's Class 3, I'm sorry?

16 MR. MELTON: ASME Class 3?

17 MEMBER BROWN: Yes, what is Class 3? You
18 said they're Class 3 applications.

19 MR. MELTON: Oh, I'm sorry. Safety Class
20 3 applications, NC Systems.

21 MR. CUMMINS: So things like essential
22 service water, that's the kind of things they're
23 using.

24 MEMBER BROWN: Support systems?

25 MR. MELTON: Support systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: Yes, they're safety related
2 because they are needed in the whole decay heat
3 removal scheme in an active plant.

4 MEMBER BROWN: Okay. So there is some
5 safety. And those things have already been approved,
6 this does not have those though according to your
7 charts? It says it's not used in safety applications.

8 MR. CUMMINS: That's right.

9 MR. MELTON: That's correct.

10 MEMBER ARMIJO: But in the AP 1000
11 application, is it your intent to use it for all
12 varied piping that is?

13 MR. STELLA: This is Mark Stella again.
14 No, we don't intend to use it for all varied pipe.
15 There are only specific applications we use it for.

16 I might point out that these applications
17 are all (b)(31)(1) and there is general guidance in
18 (b)(31)(1) for the use of plastic pipe limitations,
19 but we apply the more restrictive Code Case N-755
20 limits.

21 For example, pressure 150 pounds or less
22 and temperature no greater than 140 degrees. Those
23 are the pressure temperature conditions above which we
24 do not use HDPE.

25 MEMBER RYAN: You mentioned the blowdown,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you know, might be contained in these pipes is and
2 blowdown can be guaranteed to be radioactive material-
3 free forever?

4 MR. SISK: I'm going to repeat Mark's
5 viewpoint. The --

6 MEMBER RYAN: I'm asking can blowdown be
7 radioactive material-free?

8 MR. SISK: Mark, you had a question?

9 MR. STELLA: No, I missed it, please
10 repeat.

11 MR. SISK: Can the blowdown line be
12 guaranteed to be radioactive free for the life --

13 MEMBER RYAN: Radioactive material-free
14 for the life of the plant or its extended life?
15 Probably not.

16 MR. STELLA: All right, the service water
17 system cools the Component Cooling System. The
18 Component Cooling System could see some contamination
19 from leaking -- small leaks in heat exchanger tubes
20 that it services; however, with the plate type heat
21 exchanger we have, there really is no pathway other
22 than a plate, leak across the plate or any water from
23 the CCS to enter the SWS.

24 If there were leaks in the gaskets, for
25 example, they would be leaks to location of the heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exchanger rather than into the other fluid stream.

2 So, maybe the word guarantee can't be
3 used, but there's a very high probability that there
4 would be little chance of any radiation in the service
5 water system.

6 We do have a radiation detector on the
7 blowdown line; however, so that we can isolate the
8 blowdown line if there is an indication of carryover
9 of low amounts of radiation in the service water
10 system.

11 MEMBER RYAN: Well the radioactive
12 material it might be carrying, you know, I guess you'd
13 have to talk about detection limits and all that sort
14 of stuff.

15 But these kinds of things are the sources
16 of what has been a, you know, pain in the neck kind of
17 problem dealing with, you know, underground piping
18 contamination.

19 And I'm curious if you can't guarantee
20 it's not going to be present during the life of the
21 plant, is there a monitoring alternative that you
22 thought about, about, you know, having wall-in-wall
23 pipe or some kind of detection program to assess
24 whether it's performing as expected.

25 MR. SISK: Mark, did you hear the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question?

2 MR. STELLA: No. I'm having trouble
3 hearing --

4 MEMBER RYAN: I'm sorry, I guess I'm on
5 the backside or something.

6 MR. STELLA: -- with the speaker.

7 MEMBER RYAN: If it's not -- I mean high
8 probability is good, but 100 percent probability is
9 better. But I'm struggling with the fact that small
10 amounts of contamination have caused lots of headaches
11 and how do we avoid that?

12 Well, we can, you know, beef up the system
13 in some way or we can have improved detection or
14 improved, you know, monitoring systems. And I'm
15 curious if you've thought about improved monitoring
16 systems to identify any small amounts of contamination
17 that may be present.

18 MR. STELLA: Well, the blowdown line has a
19 radiation detector on it.

20 MEMBER RYAN: What is it capable of
21 seeing?

22 MR. STELLA: It's very sensitive, it's
23 sensitivity goes down to about 10 to the eighth
24 microcuries per cc.

25 MEMBER RYAN: I'm going to guess you mean

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 10 to the minus eighth microcuries?

2 MR. STELLA: Minus eight, I'm sorry.

3 MEMBER RYAN: Okay.

4 MR. STELLA: I forgot that.

5 MEMBER RYAN: That would be much better.

6 That's all right, I just want to make sure
7 the record didn't have 10 to the eighth.

8 MR. STELLA: Yes, thank you. And to get
9 radiation into the service water system, you would
10 have to first have it in the Component Cooling System,
11 that also has a very sensitive radiation detector and
12 one can detect radiation down to that level as well.

13 So the, you know, you would be able to
14 identify and terminate the leak into the CCS then
15 clean it up and again, eliminate the potential for any
16 carryover to the service water system.

17 MEMBER RYAN: Ten to the minus eighth
18 microcuries per cc is a fraction of a picocurie per
19 liter per cc, rather.

20 MR. STELLA: Yes.

21 MEMBER RYAN: That's really low. And an
22 in-line system, that's amazing actually.

23 MR. STELLA: Well, the CCS detector is a
24 side-stream system where we take a small amount of
25 flow off and run it through the detector.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: Oh, I see.

2 MR. STELLA: So that's the one where we
3 have the money put to be very decisive. I don't know
4 exactly the sensitivity of the SWS detector, but that
5 may be a see-through type detector and in that case it
6 would be slightly less sensitive, we're in the 10 to
7 the minus sixth, 10 to the minus seventh range, then.

8 We haven't decided on the specific type of
9 detector for that application yet.

10 MEMBER RYAN: Okay. Let me shift gears
11 just a bit. What's the service life of this piping if
12 exposed to sunlight?

13 MR. STELLA: It certainly embrittles the
14 piping.

15 MEMBER RYAN: I know that. But that's the
16 lifetime of it. I mean --

17 MR. STELLA: The lifetime of the piping is
18 somewhere between 50 and 100 years, up to 100 years
19 according to the manufacturers --

20 MEMBER RYAN: That's buried.

21 MR. STELLA: -- without any issues.

22 MEMBER RYAN: That's buried though, what
23 about if parts of it or joints whatever might be in
24 sunlight or see daylight?

25 MR. STELLA: Well, we utilized the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 underground installation to prevent that from
2 occurring. The only time it would see sunlight would
3 be during the joining process before it were put in
4 the trench or --

5 MEMBER RYAN: Okay. But there's no
6 inspection locations or any kind of access ports?
7 Nothing comes above ground anywhere?

8 MR. SISK: It's all below grade.

9 MEMBER RYAN: All --

10 MR. STELLA: No the only part of it that
11 comes out of the underground run, it usually comes out
12 into a vault, if we have to transition between the
13 HDPE --

14 MEMBER RYAN: And the metal.

15 MR. STELLA: -- and metallic pipe so that
16 we can run the remainder of the line out in the open
17 and that would still be covered. But that would also
18 be available for inspection --

19 MEMBER RYAN: Got it.

20 MR. STELLA: -- when that transition
21 occurs.

22 MEMBER RYAN: Are there any questions
23 about the materials used for the adhesive to join
24 sections?

25 MR. SISK: They're welded.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STELLA: We don't use adhesive, we
2 expect use the fusion butt weld methodology --

3 MEMBER RYAN: Okay, great.

4 MR. STELLA: -- which is basically just
5 melting the two butt ends of the pipe that are put
6 together under controlled conditions, pressure
7 temperature and time.

8 MEMBER RYAN: One last question. Is there
9 any plan for confirmatory measurements on the buried
10 pipe both with regard to any leakage of fluid, water,
11 whatever it is and then subsequently --

12 MR. STELLA: I'm sorry, would you repeat
13 that, I didn't get it.

14 MEMBER RYAN: How are you going to inspect
15 and confirm the performance of the buried underground
16 pipe over time, long times, you know, plant life?

17 MR. STELLA: It is probably, if we bury
18 it, that would be difficult. If it runs in the
19 trench, or covered trench that's easier to do. The
20 large sections pipes would be in a covered trench.

21 The smaller ones may just be buried and in
22 that case, to confirm the performance would be a
23 chore. These pipes, though, basically the blowdown
24 line conveys water to the circulating water system
25 cooling tower sump and the other pipe that we use it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in is the alternate make-up line to the service water
2 system cooling tower basin.

3 So, these are not neither radioactive nor
4 super high pressure applications, I mean high pressure
5 in the sense of being near the working pressure of
6 plastic pipe.

7 So, I guess, you know, it's possible to if
8 they're running in a trench to check and see if
9 there's any leakage.

10 The ideal, of course, would be to make
11 sure that you have the fusion welds made correctly and
12 if you need further confirmation that they are made
13 correctly besides the use of the approved procedures
14 and perimeters, then there's always an ultrasonic
15 method of evaluating the weld bead that can be used.

16 The time of flight diffraction type of
17 method has been developed for this kind of pipe.

18 MEMBER RYAN: Do you have any plans to do
19 more simple pressure tests on the welded pipe to see
20 if they hold pressure for some period of time to
21 verify integrity or anything of that sort or?

22 MR. STELLA: I don't think we have any
23 plans other than what's required by (b)(31)(1) and N-
24 755 at this time.

25 MEMBER RYAN: So that would not include a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure test, is that right?

2 MR. CUMMINS: This is Ed Cummins. I think
3 that B3011 requires hydrotest at 1.5 times the design
4 pressure.

5 CHAIRMAN RAY: The initial.

6 MR. CUMMINS: Yes.

7 SPEAKER: It's not an ISI requirement.

8 MEMBER RYAN: That's all I have.

9 CHAIRMAN RAY: Okay. All right. Rob, do
10 you want to finish up?

11 Anything more you want to say?

12 MR. SISK: Well, I think we probably by
13 dialogue went through most of the slides. I can flip
14 through them quickly or -

15 MEMBER ARMIJO: Just go through quickly,
16 because I think we have covered these things.

17 MR. SISK: Yes, I'll continue on. I think
18 the one we're supposed to start is the advantages of
19 high-density piping material are essentially inert and
20 are not affected by chemical and galvanic corrosion.
21 The operating lifetime of a properly constructed HDPE
22 piping system is estimated to be up to a hundred
23 years. Joints produced with proper fusion conditions
24 are leak free and not susceptible to degradation
25 caused by exposure to process fluid, groundwater or by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 surface water infiltration around the exterior of the
2 pipeline.

3 The HDPE piping sections and associated
4 fittings are joined in the field by fusion, butt
5 welding, we talked about that just a little bit ago,
6 using specialized equipment. I had the picture of the
7 equipment up here just a little bit ago.

8 The fusion conditions required to produce
9 a strong void-free weld zone between adjacent HDPE
10 pipe sections are well known, Key fusion parameters,
11 the temperature of fusion zone, compression pressure
12 on pipe faces being joined and fusion time.

13 A nondestructive means for evaluating the
14 fusion joint integrity is available. That was also
15 mentioned by Mark. The time of flight diffraction, an
16 ultrasonic methodology, appropriate installation
17 methods and supports are needed to control stresses
18 and moments in systems using HDPE piping.

19 ASTM and manufacturing installation
20 standards do exist. Thermal expansion coefficients
21 are higher than for metallic piping and must be
22 accommodated.

23 MEMBER ABDEL-KHALIK: And would you use
24 this for final protection?

25 MR. SISK: Mark?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STELLA: Well, we have been discussing
2 using it for the underground portion of the fire
3 protection system. But at this time, we do not have
4 any HDPE in the fire protection system AP1000.

5 MEMBER ARMIJO: If you didn't use the HDPE,
6 what would you use for those fire protection lines?

7 Cast iron or coated carbon steel or what?

8 MR. STELLA: It's an iron pipe that we
9 presently have in the system.

10 MEMBER ARMIJO: So, all of this could be a
11 potentially superior material. I think you've chosen
12 to stay -

13 MR. STELLA: Yes, there are arguments both
14 ways, I think. And that's why we haven't gone to
15 HDPE.

16 MR. SISK: Okay. There's a picture of the
17 butt fusion method used on the HDPE piping, up on the
18 screen.

19 Generally speaking, we are being very
20 limited in our use of HDPE not using it in safety-
21 related applications, not using it for normally
22 radioactive or treating any type of fluids. And,
23 therefore, we think this is not a significant concern
24 for AP1000.

25 CHAIRMAN RAY: Charlie, do you have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question?

2 MEMBER BROWN: Yes, just that you have -
3 you talked about the required 1.5 times design
4 pressure test, but are you actually - you say you can
5 - there's a test, this time of flight ultrasonic test.

6 Were you actually going to do that or is
7 it just something that we can, but we may or may not
8 decide?

9 I mean, it seems like you ought to
10 maximize the utilization and make sure these things
11 are solid and there's not some minor weakness that -
12 minor fusion that may pass the test, but doesn't
13 adequately fuse that may show up in the other test.

14 And so, sounds like you're doing one test.
15 I'm just curious if you're going to do the other one
16 at the same time.

17 MR. SISK: Mark, did you hear the question?

18 MR. STELLA: I did hear the question. I
19 know that we're in the process of developing our -
20 just to finish the first draft or maybe the first real
21 issue of an HDPE piping installation procedure for one
22 of our early AP1000 sites. These are being done on a
23 site-specific basis at this point.

24 I haven't read it yet to see if it
25 requires the use of the nondestructive evaluation. My

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 understanding is that once you have qualified the
2 joints, the pressure and temperature, etcetera, it's
3 fairly certain that if you use the same parameters
4 each time and make sure that you follow the joining
5 procedures, butting the faces together and making sure
6 they're perfectly aligned, etcetera, that you can rely
7 on a good weld being made.

8 And I believe the procedure would require
9 before that, before going into production, if you
10 will, that test joints be made by the individuals who
11 are going to run the fusion machine and ensure that
12 they were capable of reliably creating these good
13 joints.

14 MEMBER BROWN: What you're effectively
15 saying, it's largely a process control as opposed to a
16 test verifier.

17 MR. STELLA: Correct. And, again, we're
18 not using the HDPE piping in -

19 MEMBER BROWN: I understand.

20 MR. STELLA: - high-pressure systems that
21 carry -

22 MEMBER BROWN: What is the pressure level
23 in those?

24 MR. STELLA: - well water that's been
25 concentrated a few times by running through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cooling tower.

2 MEMBER BROWN: Are we talking about a few
3 pounds or are we talking about a few hundred pounds?

4 MR. STELLA: Oh, we're talking less than
5 100 psig in either case.

6 CHAIRMAN RAY: Thank you. Okay. We're a
7 little past 12:00. I'm going to ask that we be back
8 and ready to start at one o'clock in closed session
9 for the shield building.

10 MEMBER ABDEL-KHALIK: Mr. Chairman, let me
11 just make a comment regarding -

12 CHAIRMAN RAY: Sure.

13 MEMBER ABDEL-KHALIK: I still believe that
14 the issue with regard to uncertainty of RCS flow
15 measurement, it's perhaps a little premature to close
16 this item.

17 I believe the questions raised regarding
18 how the different methods will be reconciled is
19 significant and we should find out how that is going
20 to be resolved.

21 MEMBER ARMIJO: Well, if I could just add
22 to that. Westinghouse said that they have used this
23 pressure sensor technique in other plants, and also
24 compared it with a calorimetry and other things.

25 So, if it's already been reconciled in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operating plants, it would be helpful if we could get
2 that information to see how you've actually done it.

3 MEMBER SIEBER: It basically goes back 50
4 years.

5 MEMBER ARMIJO: Well, I think that's the
6 issue. And if you're going to do it the same way if
7 we've seen how you've done it on operating plants, it
8 might resolve the problem.

9 MEMBER ABDEL-KHALIK: It's finally up to
10 the membership. I mean, it's a personal concern that
11 we haven't really heard enough that would assure us
12 that all these different methods somehow will lead to
13 a closure especially in light of the large temperature
14 variations that you would expect in this case in the
15 hot leg temperature.

16 CHAIRMAN RAY: Would it be appropriate to
17 frame maybe a - I'm trying to keep these things as
18 clear - as much clarity as possible to word a new
19 action item that has - comes out of this and basically
20 says we want to understand how these multiple millions
21 of -

22 MEMBER ABDEL-KHALIK: I mean, to put it as
23 sharply as possible, we'd like to see how the
24 uncertainty in-core flow is determined and how much is
25 that uncertainty.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: And that would include
2 looking at how these various methods -

3 MEMBER ABDEL-KHALIK: Right. Is it two
4 percent? Is it five percent?

5 CHAIRMAN RAY: Okay.

6 MEMBER ABDEL-KHALIK: We know it's greater
7 than one percent. That's the statement that has been
8 made.

9 MEMBER SIEBER: I think you need to put
10 that in the framework of how accurate you actually
11 need to know it. If all they use it for is to -

12 MEMBER ABDEL-KHALIK: I'd be happy with
13 that as well.

14 MEMBER SIEBER: - indicate the loss of
15 low, you know, you may have tremendous margin there.
16 And if you use it for other safety-related purposes,
17 you have to identify those and justify the accuracy
18 for the application in which it's being used.

19 CHAIRMAN RAY: Okay. I would like just for
20 bookkeeping purposes again rather than continue that
21 same action item, I'd like to precisely word one that
22 meets the needs of all the members who have an
23 interest here and establish an action item that has
24 got clarity around what it is we're still concerned
25 about.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I think I understand what it is, but I'll
2 ask Weidong to do that. I don't want to just leave
3 this thing unresolved that we came in here with. I'd
4 rather -

5 MEMBER ABDEL-KHALIK: Right now the issue
6 is pretty focused. What is the uncertainty and how do
7 you go about estimating it?

8 CHAIRMAN RAY: Weidong, I'd like you to
9 check with Said, Sanjoy and Jack as to the wording of
10 that action item to make sure all of their thoughts
11 are captured. Okay?

12 MEMBER BROWN: Is Item 40 closed now?

13 CHAIRMAN RAY: Item 40 is closed, yes.
14 That's right.

15 Okay. We have now gone on a little bit
16 further. We'll make it five minutes after 1:00 to
17 resume.

18 (Whereupon, the meeting went off the
19 record at 12:09 p.m. for a lunch recess and went back
20 on the record at 1:02 p.m. in Closed Session to resume
21 in Open Session at 6:41 p.m.)

22 CHAIR RAY: Let me just say to my
23 colleagues you did get a list of action items. We
24 referred to it in the portion of the meeting before
25 lunch. Before I ask for your input on this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 afternoon's discussion, let me just say that you're
2 most welcome to identify after the meeting anything
3 pertaining to today's meeting that you'd like to add
4 to the action item list so you don't need to feel like
5 right now you've got to come up with whatever it is
6 that may be nagging at you and that you would like to
7 see us follow-up on. This was an informational
8 briefing. Rev 2 is yet to come in. It will get a lot
9 of review, so this is mostly a time for us to get up
10 to speed and ready to do what we need to do.

11 Having said all of that, let me go around,
12 though, as we always do and see if there's anything to
13 go on the record as part of this meeting. Let me
14 start with our consultants, and I'll start with you,
15 Tom. Anything you want to . . .

16 CONSULTANT KRESS: Well, I don't have any
17 real problems. I have some impressions, if you'd like
18 those. It's pretty late. I have some impressions.

19 CHAIR RAY: Well, it's up to you to decide
20 whether it's, given the hour, it's something you want
21 to put on the record or not.

22 CONSULTANT KRESS: Well, maybe I'll wait
23 and just put it down in writing.

24 CHAIR RAY: That's fine. We welcome your
25 reports. We look forward to them. But, again, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you'd like to share with the other members here
2 anything, you're welcome to do so.

3 MS. MCKENNA: Well, in general, I think
4 the Westinghouse and staff's approach is an
5 appropriate way to do it, given the nature of the
6 threat. And I think they're doing what they can to
7 address it.

8 CHAIR RAY: You said Westinghouse, but, of
9 course, you meant the COLA applicant, as well.

10 MS. MCKENNA: Yes, COLA applicant.

11 CHAIR RAY: I made that mistake.

12 MS. MCKENNA: I still think there's some
13 issues with respect to the flow measurement that we'll
14 need to resolve.

15 CHAIR RAY: We now have a new action item
16 that we will follow-up on.

17 MS. MCKENNA: Good. I'm glad to hear
18 that. There's probably still an open question with
19 respect to the striping issue with respect to the hot
20 leg. I don't think it's been addressed appropriately
21 yet. I think more needs to be done on the striping
22 fatigue analysis of the hot leg.

23 CHAIR RAY: Sanjoy, do you have any
24 comment on that?

25 MR. BANERJEE: Well, I agree with Tom, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they are going to, they --

2 CHAIR RAY: You gentlemen don't need to
3 remain, but if you're comfortable you can sit there.

4 MR. BANERJEE: They have intentions of
5 dealing with this, but it wasn't entirely clear to me
6 whether it would be done as a part of the
7 certification or part of the COLA. If it's a part of
8 the COLA, I'm not going to worry about it right now.
9 They have time to resolve it, I guess. I better ask
10 Eileen what the situation is there.

11 MS. MCKENNA: Well, I think when this came
12 up earlier it indicated that this is part of, it would
13 be part of the piping analysis and piping DAC, which
14 is not going to be completed as part of the
15 certification based on the review schedule that we
16 have and the schedule that's in play for completing
17 the analysis.

18 MR. BANERJEE: Can you give us the
19 schedule for the COLA and the certification, as best
20 as you know.

21 MS. MCKENNA: No, no, no.

22 MR. BANERJEE: Okay.

23 CHAIR RAY: Okay. Well, listen, Tom, what
24 we'll do is, we did close that item, but go ahead and
25 put something in your report that we can then assess

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to see if there's any more we should do, other than to
2 recognize that this is an issue that needs -- in other
3 words, if there's something that isn't going to be
4 addressed and should be, that, I think, is what we're
5 looking for. Anything else?

6 CONSULTANT KRESS: Well, I think they
7 pretty much resolved any problems we may have with the
8 buried plastic piping. Oh, I guess I'm really
9 impressed, quite positively, with what they're doing
10 with field design and look forward to the final
11 resolution but certainly think they're approaching it
12 the right way, and I like what I hear and what I see.

13 CHAIR RAY: Thank you. Bozidar, do you
14 want to say anything?

15 CONSULTANT STOJADINOVIC: It's in this e-
16 mail queue here I have an action item on the welds for
17 the plates that we discussed. And another action item
18 that I will add, and that is for the pushover analyses
19 that I would like to just wait for Revision 2 data and
20 evaluate that. But I think it's smart to wait for
21 Revision 2 and review that. That will provide a lot
22 more answers than we've already got.

23 CHAIR RAY: All right. I hope today was a
24 helpful start on --

25 CONSULTANT STOJADINOVIC: Definitely. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think that the progress from the previous revisions is
2 obvious, and it is in the right direction. Hopefully,
3 we'll get that in Revision 2.

4 CHAIR RAY: Bill?

5 CONSULTANT HINZE: Well, a few comments.
6 Coming into the meeting, I felt that there was a need
7 for demonstration and clarification on a number of the
8 items that I've reviewed and looked at, and I think
9 that this meeting has been very helpful in that regard
10 and also looking forward to the Rev 2. I do think,
11 too, that the large-scale tests, I had some qualms
12 about how useful they would be and how representative
13 they might, but those have been alleviated as a result
14 of this discussion, and that's great. And I think
15 that particularly the cyclic studies are extremely
16 important. I think Bob's kind of summary comments
17 have been very helpful, as well.

18 To tell you the truth, when I came into
19 the meeting, I had concerns about whether the SB would
20 act as a unit. And I think from a seismic standpoint,
21 that's extremely important. And I have a much better
22 feeling about that now and a much warmer feeling about
23 that. I'm not a structural engineer, but I'm amazed
24 and very pleased with the massive structures that we
25 see at the joint of the roof and the walls.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 One of my major concerns was related to
2 the fatigue loading and what we've seen and, thus, the
3 duration problem. And I think that what we've seen
4 today as a result of the large-scale tests is that
5 this may not be a never mind but it's certainly much
6 less than I was anticipating, and I look forward to
7 the additional tests.

8 I also really want to be supportive of
9 something that Bob said in his summary, and that is
10 the need for the kind of an increased seismic margin.

11 There are a lot of unknowns here, and I think that
12 his advice on this has been very helpful.

13 CHAIR RAY: Very good. Thank you. Jack?

14 MEMBER SIEBER: I guess, overall, I'm
15 pretty impressed that the applicant and its partners
16 have laid a pretty good foundation for the seismic
17 analysis of composite structures and the shield
18 building. On the other hand, the analysis isn't
19 complete, and I think a lot of the conceptual problems
20 are resolved at this point in time. But there is
21 still additional work to do, so I await the completion
22 of that work.

23 CHAIR RAY: Thank you. Sam?

24 MEMBER ARMIJO: I share Jack's views. I
25 think the work has been very impressive. I think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experimental work was really first class. I'm glad to
2 see it. I still have some concerns about those
3 transition regions. I come from an environment where
4 testing is everything where you can't model from
5 almost first principles, although we do a lot of
6 empirical stuff in the fuel business also.

7 But the other thing we haven't talked too
8 much about is the welds on the plates. There's going
9 to be maybe thousands of feet of weld, and the quality
10 of those welds is something we haven't discussed. I'd
11 like to hear a little bit more about that sometime in
12 the future. My guess is that it will turn out okay
13 and that even if you have a few defective welds it
14 probably wouldn't make a great big difference, but we
15 ought to understand that.

16 CHAIR RAY: Would you just make an action
17 item? Because I think that's clearly the case. We
18 need to have something to make sure we get back to the
19 weld process, the inspection, the design, and so on of
20 the --

21 MEMBER ARMIJO: Yes, because we didn't
22 spend much time on that. But, otherwise, I learned a
23 lot. I'm not a structural guy, I'm not a concrete
24 guy, but I learned a lot. That's all I have.

25 CHAIR RAY: Sanjoy?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BANERJEE: I don't think I have
2 anything to add to my colleagues here, other than to
3 compliment Westinghouse for an excellent presentation,
4 which I enjoyed very much.

5 CHAIR RAY: Dennis?

6 MEMBER BLEY: Yes, same thing. I learned
7 a lot from it, and I felt more confident than I was
8 coming in.

9 CHAIR RAY: Said?

10 MEMBER ABDEL-KHALIK: I have no added
11 comments.

12 CHAIR RAY: Mike?

13 MEMBER RYAN: No added comments, except I
14 add my thanks and, again, I think it's an impressive
15 body of work to get you to the stage you're at now,
16 and it will get better as time goes on. I look
17 forward to hearing more about it.

18 MEMBER SHACK: Very helpful and well-done
19 meeting. My thanks.

20 CHAIR RAY: Harold?

21 MEMBER BROWN: Very much the same here. I
22 thought the presentations were excellent.

23 CHAIR RAY: And Mario?

24 MEMBER BONACA: I was impressed by the
25 work they did and they do. After reading the material

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in preparation, I expected them to be much behind in
2 the design of the containment, and I was impressed by
3 the progress they've made.

4 CHAIR RAY: Okay. Thank you very much.
5 We'll go off the record now. And at the risk of being
6 killed, I am going to ask my --

7 (Whereupon, the foregoing matter went off
8 the record at 6:51 p.m.)

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

AP1000 Reactor Coolant Pump Flywheel

April 22, 2010

Purpose

- Respond to ACRS request for information on the reactor coolant pump (RCP) flywheel failure frequency used in the AP1000 Probabilistic Risk Assessment (PRA) model

AP1000 PRA Model Information

- AP1000 PRA does not explicitly model the failure of the RCP flywheel
- A RCP flywheel failure frequency has not been used in the AP1000 PRA model


AP1000 PRA Model Information

- RCP flywheel failure could result in a locked rotor initiating event
- The locked rotor initiating event is combined with other single loop loss of reactor coolant flow initiating events
- Single loop loss of reactor coolant flow events are combined with other initiating events in the Transient with Main Feedwater event category

AP1000 PRA Model Information

- Transient with Main Feedwater event frequency is dominated by spurious reactor trip and turbine trip initiating events
- The RCP flywheel failure initiating event is
 - a subset of locked rotor events
 - which are a subset of single loop loss of reactor coolant flow events
 - which are a subset of Transient with Main Feedwater events
- Therefore a RCP flywheel failure frequency has not been used in the PRA model

AP1000 RCP
CONFIGURATION FOR
PROTOTYPE TEST
APRIL 15, 2009



AP1000 RCP Outline

Upper Flywheel Assembly

Lower Flywheel Assembly

ACRS Meeting

AP1000 RCS Flow Measurement

April 2010

Chuck Brockhoff

AP1000 System Design

Purpose

- Provide information regarding RCS flow measurements and uniformity of flow
- ACRS Question
 - Elbow taps for RCS flow measurement
 - Request additional information including a discussion of the uniformity of flow
 - Please provide additional background information on the Westinghouse change for monitoring RCS flow reflecting an alternate testing method to the precision heat balance
 - The alternate testing method includes utilization of d/p measurements on both hot and cold legs


AP1000 RCS Flow Measurement

- Westinghouse Improved Standard Tech Specs (ISTS) prescribes ‘precision calorimetrics’ as the method to measure RCS flow.
- The feedwater calorimetric measures reactor power and then uses delta-T (T-hot to T-cold) to calculate the RCS flow
- Accuracy is impacted by hot leg temperature streaming (non-uniform temperatures in hot leg)
 - AP1000 geometry and low leakage loading pattern may contribute to hot leg streaming
- Technical Specification SR 3.4.1.4 allows the use of alternative precision flow methods in addition to the traditional calorimetric
 - This alternate approach is to use in-situ calibration of the hot leg elbow and cold leg bend d/p channels
 - Precedent exists for this method – Farley / South Texas / Diablo Canyon / Seabrook / Watts Bar

AP1000 Plant Application DCD Rev 17

- Baseline RCS Measurement of RCS flow at the time of plant startup utilizing multiple sources
- Use that flow determination for in-situ calibration of the RCS flow elements
 - Hot leg elbows and cold leg bends
- Use those flow elements for all further RCS flow measurements

AP1000 Reactor Coolant Piping



Requirements for Plant startup

- The following reactor plant startup requirements apply:
 - DCD 14.2.10.1.17: “The estimated reactor coolant flow rate from data taken PRIOR to initial criticality equals or exceeds 90 percent of the minimum value required by the plant Technical Specifications for full power operation.”
 - DCD 14.2.10.4.11: “The reactor coolant system flow determined from the measurements at approximately 100 percent rated thermal power equals or exceeds the minimum value required by the plant Technical Specifications.”
- Westinghouse expects that:
 - The “precision calorimetrics” method will be adequate to meet this requirement
 - Better accuracy can be achieved by evaluating data available from multiple test sources

Baseline Flow Measurement

- The Baseline Flow Measurement will be documented in an engineering report based on all measurements available of RCS flow at time of plant startup

- These measurements and tests include:
 - RCS pump d/p (compared to factory tests)*
 - RCS pump motor power (compared to factory tests)*
 - Hot leg elbow and cold leg bend d/p*
 - All other RCS d/p measurements available*
 - ΔT and calorimetric during power escalation
 - Core exit T/C, T-cold, calorimetric power

- The engineering report will reconcile all measurements and report the determined flow ($X \pm Y$ gpm) at specified conditions

* = Used for pre-criticality test flow confirmation

Baseline Flow Measurement

- Baseline Flow Measurement will be used to calibrate the RCS elements (hot leg elbow and cold leg bend d/p channels)
- All future RCS flow measurements will be based on measurements of d/p channels in hot leg elbows and cold leg bends
 - The observed d/p will be converted to a measured flow based on the d/p corresponding to the baseline flow measurement
 - Instruments used to measure d/p will be calibrated at refueling intervals
- Uncertainty will include allowances for:
 - Uncertainty in baseline flow measurements
 - Uncertainty in d/p measurement channels in hot leg elbows and cold leg bends

Baseline Flow Measurement

- The 12-hour RCS flow check (SR 3.4.1.3) will be made with installed process instrumentation (consistent with operating plants)
 - The current licensing basis is determination of gross change in indicated RCS flow on a relative basis
- The refueling interval RCS flow check (now SR 3.4.1.5) will be performed to measure flow based on calibrated loop differential pressures with consideration of appropriate instrument uncertainties in the error allowance

Uncertainties

- Both the hot leg elbow and cold leg bend d/p channels are expected to have uncertainties that cannot be resolved until as-built plant startup measurements are performed
 - The hot leg elbows have nearby piping connections that may introduce d/p measurement uncertainties
 - The cold leg bends (with taps at the end of the bend) have a large bend radius that causes a low d/p signal
- Therefore Westinghouse has taken the precaution of using either or both as an alternate to the “precision calorimetric” method of RCS flow determination

Summary

- The RCS flow measurement strategy provides an accurate and verifiable method of demonstrating that RCS flow meets requirements
- The accuracy (and value) of measured RCS flow will be established in the Reactor Coolant Flow Measurement Report following plant startup

Questions

Screening Criteria for Thermal Stratification, Cycling and Striping (TASCS) in AP1000

April 2010



Screening Criteria Document

Materials Reliability Program: Management of Thermal Fatigue in Normally Stagnant Non-Isolable Reactor Coolant System Branch Lines (MRP-146), EPRI, Palo Alto, CA, June 2005, 1011955

MRP-146 Screening


Identify all normally stagnant branch lines connected to the RCS piping with a potential for:

- In-leakage via valves from a high-pressure source toward the RCS header piping
- Potential for turbulence/swirl penetration

Piping and instrumentation diagrams (P&IDs) are used to identify these paths

Lines with Potential for Valve Inleakage


Example of an up-horizontal (UH) branch line piping configuration



"L" is the distance from the RCS header pipe ID to any location of interest along the branch pipe. L/D_i is the number of diameters from the run pipe ID.


Lines with Potential for Valve Inleakage

Example of a horizontal (H) branch line piping configuration



Lines with Potential for Turbulence/Swirl Penetration

Example of a down-horizontal (DH) branch line piping configuration



MRP-146 Screening

Significant Temperature Threshold

For steady stratification during normal operation, a guideline of 50°F measured metal top-to-bottom temperature difference is provided.

As long as this limit is not exceeded, no further action is required (Section 2.1.5)

MRP-146 Screening

No further evaluation required if any of the following conditions are met:

- For UH lines, piping from RCS nozzle to first check valve is ≤ 2 inch nominal pipe size
- In-leakage path includes pressure relief or other pressure control devices
- For top connected piping, the vertical section is sufficiently long such that swirl penetration cannot reach the upper horizontal sections
- For bottom connected piping, vertical length between RCS piping and horizontal section is greater than the maximum, or less than the minimum specified in MRP-146, Sec. 2.2.3

AP1000 Lines Susceptible to TASCs

- PRHR supply line from RCS hot leg to PRHR heat exchanger
- Passive residual heat removal (PRHR) return line from PRHR heat exchanger to steam generator channel head
- Automatic Depressurization System (ADS) stage 4 lines from RCS hot legs to the stage 4 depressurization valves
- RCS hot leg lines
- RCS cold leg lines
- Pressurizer surge line
- Normal residual heat removal suction lines from the hot legs to the isolation valves
- Direct Vessel Injection (DVI) lines
- Chemical and Volume Control System (CVS) purification return line

(Reference DCD 3.9.3.1.2)

Evaluation and Further Actions

1. For susceptible lines, a CFD analysis is performed to study the flow mechanism and determine the temperature distribution
 - Thermal gradients used to obtain bending stresses
 - Thermal gradients also included in fatigue analysis
2. Recommendations are provided to avoid the potential for thermal fatigue degradation

Evaluation and Further Actions

- Results will be available during piping DAC closure/audit

AP1000 HDPE Follow-up Questions

April 22, 2010

Purpose

- Provide information regarding the criteria for use of high density polyethylene (HDPE) piping in AP1000 applications
- List all AP1000 systems using HDPE piping
- Summarize advantages of HDPE piping

HDPE Use in AP1000

- ACRS Question

- HDPE - Underground piping (fluids) and conduit (electrical) and how they perform with regard to groundwater intrusion and surface water infiltration. The concern includes the pipe, connections and material performance at the connections (joint adhesives “welding” materials, etc.). A related question are any of the tritium task force results and recent experiences reported for Vermont Yankee and Indian Point raising issues for such piping. (Mike Ryan)

AP1000 HDPE Application Criteria

- HDPE piping is not used in safety-related fluid systems applications in AP1000
 - usage adheres to requirements of Code Case N-755
 - NRC has approved safety-related applications of HDPE piping in at least two operating plants
- HDPE piping is used in underground applications only
- HDPE piping is not used in systems that carry normally radioactive process fluids
 - complies with RG 1.143 restriction

AP1000 HDPE Application Criteria

- HDPE piping is used only for
 - SWS blowdown and alternate makeup lines
 - May be used in certain site-specific RWS and WWS applications
- HDPE piping is routed underground to eliminate the possibility of impact damage and material degradation (embrittlement) due to UV exposure
- Underground installation methods used ensure protection of piping from distortion and damage by above-ground live loads

Advantages of HDPE Piping

- HDPE pipe materials are essentially inert and are not affected by chemical or galvanic corrosion
- The operating lifetime of properly constructed HDPE piping systems is estimated to be up to 100 years
- Joints produced with proper fusion conditions are leak-free and not susceptible to degradation caused by exposure to process fluid or ground water, or by surface water infiltration around the exterior of the pipeline

Ensuring Long-Term Leak-Free Performance of HDPE Piping

- HDPE pipe sections and associated fittings are joined in the field by fusion (butt welding) using specialized equipment [SLIDE 9]
- The fusion conditions required to produce a strong, void-free weld zone between adjacent HDPE pipe sections are well-known
- Key fusion parameters
 - temperature of fusion zone
 - compression pressure on pipe faces being joined
 - fusion time

Ensuring Long-Term Leak-Free Performance of HDPE Piping

- A non-destructive means of evaluating fusion joint integrity is available
 - Time of Flight Diffraction (TOFD) - ultrasonic
- Appropriate installation methods and supports are needed to control stresses and moments in systems using HDPE piping
 - ASTM and manufacturer installation standards exist
 - thermal expansion coefficients are higher than for metallic piping and must be accommodated

Butt Fusion of HDPE Piping



Conclusion

HDPE piping use is not a regulatory issue for AP1000

Questions
