



Westinghouse

Westinghouse Electric Company
Nuclear Power Plants
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355
USA

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, D.C. 20555

Direct tel: 412-374-6206
Direct fax: 724-940-8505
e-mail: sisk1rb@westinghouse.com

Your ref: Docket No. 52-006
Our ref: DCP_NRC_002866

May 7, 2010

Subject: AP1000 Response to Proposed Open Item (Chapter 8)

Westinghouse is submitting the following responses to the NRC open item (OI) on Chapter 8. These proposed open item responses are submitted in support of the AP1000 Design Certification Amendment Application (Docket No. 52-006). The information included in these responses is generic and is expected to apply to all COL applications referencing the AP1000 Design Certification and the AP1000 Design Certification Amendment Application.

Enclosure 1 provides the response for the following proposed Open Item(s):

OI-SRP8.3.2-EEB-09 R2

Questions or requests for additional information related to the content and preparation of this response should be directed to Westinghouse. Please send copies of such questions or requests to the prospective applicants for combined licenses referencing the AP1000 Design Certification. A representative for each applicant is included on the cc: list of this letter.

Very truly yours,

John DeBlasio

for/
Robert Sisk, Manager
Licensing and Customer Interface
Regulatory Affairs and Standardization

/Enclosure

1. Response to Proposed Open Item (Chapter 8)

*DO63
NRC*

cc:	D. Jaffe	- U.S. NRC	1E
	E. McKenna	- U.S. NRC	1E
	C. Proctor	- U.S. NRC	1E
	T. Spink	- TVA	1E
	P. Hastings	- Duke Power	1E
	R. Kitchen	- Progress Energy	1E
	A. Monroe	- SCANA	1E
	P. Jacobs	- Florida Power & Light	1E
	C. Pierce	- Southern Company	1E
	E. Schmiech	- Westinghouse	1E
	G. Zinke	- NuStart/Entergy	1E
	R. Grumbir	- NuStart	1E
	B. Seelman	- Westinghouse	1E

ENCLOSURE 1

AP1000 Response to Proposed Open Item (Chapter 8)

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

RAI Response Number: **OI-SRP8.3.2-EEB-09 (RAI-SRP8.3.2-EEB-09)**

Revision: 2

Question:

The AP1000 is designed to sustain a load rejection from 100 percent power with the turbine generator continuing stable operation while supplying the plant house loads. The staff is concerned about the transient conditions where a significant voltage spike during islanding could cause high dc voltage conditions on the output side of the battery chargers. The operating experience (see Information Notice 2006-18) reveals that the voltage spike either due to malfunction of the main generator exciter or during islanding could go as high as 130% which could go undetected by normally provided relaying and could cause damage to the safety-related equipment or miss-operation. In this regard, describe how the protective features of the inverter and the new battery chargers would be coordinated so that any voltage transient will not result in inadvertent loss of the inverters or the batteries.

Westinghouse Response:

The load rejection from power effect on the IDS system was addressed in a previous RAI response. To summarize that response, the battery charger input circuit will conduct power to charge the batteries when AC power is available. This is recognized as the proper function of the battery charger in both the DCD and the FSER. The battery charger is specified to return to operation after voltage drifts outside of an acceptable input voltage range. The battery charger is also specifically defined within both the DCD and FSER as a qualified isolation device, isolating the battery and the inverter from the non safety related AC system. During the period where the battery charger is not conducting (if voltage goes out of range either high or low) the battery will carry the load. This is standard operation of a battery/ battery charger system in that the battery serves the load when the charger is not available.

The AP1000 has considered over-voltage events with the potential to have effects upon plant safety related equipment as provided under the direction of IN2006-18.

Specifically addressing the similarity of the Forsmark event referenced in IN2006-18, it is noted that there are several fundamental differences between a unit in Sweden and operating US plants, and additional differences between existing US plants and the AP1000.

- A first, fundamental difference is the potential to attribute magnitude of effect on the grounding system in country (Sweden) and in plant at the Forsmark unit. This is identified in footnote 1 of page 8 of the draft of the DİDELSYS task group report.
- Also, it is specifically noted in the NRC operating experience briefing (NPEC meeting 7/16/2008) that this event is "unlikely for US reactors".
- The OE briefing identifies US configuration of, "DC systems are supplied by battery chargers/ rectifier which are in turn powered from the AC distribution system". This is specifically the AP1000 configuration. (Slide 14) The configuration shown on slide 7 of the OE briefing shows the fault path between the rectifier and the inverter. This is not an AP1000 configuration. This configuration lent itself to propagating the fault.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

- The OE briefing goes on to credit the EDG battery with the ability to "start and control the emergency diesel generator loads for about 2 hours". (Slide 14) This is the capacity of the AP1000 non safety related battery which starts and powers the controls of the non-safety related DGs.
- The AP1000 goes beyond this capability in that there is no requirement to start EDGs in order to achieve or maintain safe shutdown as the batteries alone have that capability without support of the DGs.
- It is recognized that "U.S. plants are required per the 10CFR50.63 to be able to keep the core cooled and maintain containment integrity with a loss off offsite power & unavailability of EDGs" (slide 15). The AP1000 accomplishes this station blackout scenario with safety related batteries alone.

In conclusion the AP1000 has similar capability to existing US plants in capability to isolate and operate DGs to achieve required core cooling and containment integrity without EDGs through the use of non safety DGs, safety power systems, and the diverse actuation system powered from the non safety DC system and ultimately from an additional diverse internal UPS providing power for ultimate critical safe actions if required.

Question: OI-SRP8.3.2-EEB-09

In RAI-SRP8.3.2-EEB-09, the NRC staff stated that the AP1000 is designed to sustain a load rejection from 100 percent power with the turbine generator continuing stable operation while supplying the plant house loads. The staff is concerned about the transient conditions where a significant voltage spike during islanding could cause high dc voltage conditions on the output side of the battery chargers. Operating experience (see NRC Information Notice (IN) 2006-18, "Significant Loss of Safety-Related Electrical Power at Forsmark, Unit 1, in Sweden" dated August 17, 2006) has shown that the voltage spike either due to malfunction of the main generator exciter or during islanding could go as high as 130 percent which could go undetected by normally- provided relaying and could cause damage to the safety-related equipment or mis-operation. In this regard, the applicant was asked to describe how the protective features of the inverter and the new battery chargers would be coordinated so that any voltage transient would not result in inadvertent loss of the inverters or the batteries.

In a letter dated June 23, 2009, the applicant stated that the battery charger input circuit will conduct power to charge the batteries when ac power is available. The battery charger is specified to return to operation after voltage drifts outside of an acceptable input voltage range. The battery charger is also a qualified isolation device, isolating the battery and the inverter from the non-safety related ac system. During the period where the battery charger is not conducting the battery will carry the load. In addition, the applicant stated that it has considered over voltage events with the potential to have effects upon plant safety-related equipment as provided under the direction of IN 2006-18. However, the applicant did not provide the details of how to avoid this kind of event in AP1000 design or identification of potential vulnerabilities and actions that could reduce the challenges for the control room operators. This potential event is significant in that it can cause the common mode failure in all four trains and, therefore, could result in the loss of all four trains of safety-related ac and dc power. Transient voltages on the ac

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

input to the battery chargers can result in high dc voltages that could lead to failures of critical electrical and electronic components including electrical inverters unless they are properly protected. During such a voltage transient, the inverter voltage surge protection could trip before actuation of the battery charger protection if the battery charger and inverter direct current voltage protection settings are very close to each other. Therefore, it is necessary that the safety-related battery chargers and inverter trips be coordinated such that the associated inverters do not trip on during voltage transients on the ac distribution system. This is Open Item OI-SRP8.3.2-EEB-9.

Westinghouse Response to OI-SRP8.3.2-EEB-09:

For the AP1000, Westinghouse recognizes the need for voltage protection of battery chargers and inverters. WEC will include in the component design specifications, a requirement that the UPS system (battery charger/ inverter) will be designed specifically with consideration of the Forsmark incident identified in IN2006-18. The specification will also require a Factory Acceptance Test (FAT), a certified test report, and a Westinghouse Quality Assurance release. The components will be tested separately.

Industry evaluations of this incident identify the lack of coordination described in the RAI/ OI as a primary causative issue. Multiple class 1E manufacturers' equipment modeled the Forsmark incident and demonstrated that the equipment can selectively trip. Protective devices will be set so that the battery charger will not trip on the over-voltage resulting from load rejection and will be set low enough to protect the equipment. Additionally, the inverter DC input protection will be set at least 10% higher than the rectifier (battery charger) output DC protection to prevent the inverter tripping before the rectifier (battery charger). Finally, DCD Tier 1, Table 2.6.3-3 identifies ITAAC to verify the battery chargers and inverters conform to the certified design descriptions.

Reference(s):

None

Design Control Document (DCD) Revision:

None

PRA Revision:

None

Technical Report (TR) Revision:

None



Westinghouse

Westinghouse Electric Company
Nuclear Power Plants
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355
USA

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, D.C. 20555

Direct tel: 412-374-6206
Direct fax: 724-940-8505
e-mail: sisk1rb@westinghouse.com

Your ref: Docket No. 52-006
Our ref: DCP_NRC_002869

May 10, 2010

Subject: AP1000 Response to Request for Additional Information (SRP 3)

Westinghouse is submitting a response to the NRC request for additional information (RAI) on SRP Section 3. This RAI response is submitted in support of the AP1000 Design Certification Amendment Application (Docket No. 52-006). The information included in this response is generic and is expected to apply to all COL applications referencing the AP1000 Design Certification and the AP1000 Design Certification Amendment Application.

Enclosure 1 provides the response for the following RAI(s):

RAI-SRP3.8.2-CIB1-01 R4

Questions or requests for additional information related to the content and preparation of this response should be directed to Westinghouse. Please send copies of such questions or requests to the prospective applicants for combined licenses referencing the AP1000 Design Certification. A representative for each applicant is included on the cc: list of this letter.

Very truly yours,

A handwritten signature in black ink, appearing to read "Robert Sisk".

Robert Sisk, Manager
Licensing and Customer Interface
Regulatory Affairs and Strategy

/Enclosure

1. Response to Request for Additional Information on SRP Section 3

cc:	D. Jaffe	- U.S. NRC	1E
	E. McKenna	- U.S. NRC	1E
	B. Gleaves	- U.S. NRC	1E
	T. Spink	- TVA	1E
	P. Hastings	- Duke Power	1E
	R. Kitchen	- Progress Energy	1E
	A. Monroe	- SCANA	1E
	P. Jacobs	- Florida Power & Light	1E
	C. Pierce	- Southern Company	1E
	E. Schmiech	- Westinghouse	1E
	G. Zinke	- NuStart/Entergy	1E
	R. Grumbir	- NuStart	1E
	D. Lindgren	- Westinghouse	1E

ENCLOSURE 1

Response to Request for Additional Information on SRP Section 3

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

RAI Response Number: RAI-SRP3.8.2-CIB1-01
Revision: 4

Question:

Tier 2, Section 3.8.2.6 of the AP1000 DCD, describes the materials used to fabricate the containment vessel. The material selected satisfies the lowest service metal temperature requirement, established by analysis for the portion of the vessel exposed to the environment when the ambient air temperature is -40 °F. Westinghouse Technical Report APP-GW-GLN-113 (TR-113), "AP1000 Containment Vessel Shell Material Specification," Revision 0, submitted by Westinghouse letter dated May 11, 2007, revised this section by replacing the material specification Supplementary Requirement S17 with Supplementary Requirement S1 concerning the material fabrication process. However, Revision 16 to AP1000, Section 3.8.2.6 was changed to specify the lowest service temperature of -18.5 degrees F instead of -15 °F which was previously stated in Revision 15 of the AP1000 DCD. TR-113 did not specify the change to the service temperature nor provided any justification for this change in service temperature as required by 10 CFR 52.63(a)(1). In NUREG-1793, Section 3.8.2.6, the NRC staff approved -15 °F as the lowest service temperature based on the staff review of Westinghouse calculation APP-PCS-M3C-002, Revision 1, "AP1000 Containment Shell Minimum Service Temperature." Therefore, provide the reason and justification for the change in minimum service temperature of the containment vessel in accordance with 10 CFR 52.63(a)(1), and the analysis that supports the new service temperature proposed in Revision 16 of the AP1000 DCD.

Additional Question (Revision 1)

In a letter dated July 22, 2008, Westinghouse stated that an additional scenario was postulated for the containment vessel shell analysis, which determined that the containment vessel will be subjected to a service metal temperature of -18.5 °F. This evaluation postulated that an SSE event occurred in conjunction with -40 °F outside temperature and inadvertent actuation of active containment cooling. Westinghouse Technical Report APP-GW-GLR-005 (TR-9) only describes the analysis, and inadvertently did not include the corresponding service metal temperature.

Since TR-9 does not include the analysis or the service metal temperature, the NRC staff cannot confirm that -18.5 °F is the lowest service metal temperature of the containment vessel shell, which is fabricated from SA-738 Grade B material. This material must meet the requirements of NE-2000 for fracture toughness (Charpy V-notch test) in the as-welded condition for thicknesses up to and including 1.75 inches, and in the post-weld heat treated condition for thicknesses greater than 1.75 inches. The minimum service temperature is used to determine the testing temperature for the Charpy V-notch tests required by ASME Code, Section III, Subsections NE-2300 and NE-4300. Previously, Westinghouse stated in its letter dated April 22, 2003, that the SA-738, Grade B plate material will be procured using the service metal temperature of -15 °F (i.e., -55 °F Charpy V-notch test temperature as required by ASME

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Code, Section III, Subsections NE-4335.2(b)(2) and Tables NE-4622.7(b)-1, note (2)(b)(1) in order to account for degradation during welding of the heat affected zone in the base material). In addition, Westinghouse stated in a letter dated March 13, 2003, that the previous analysis added an 8 °F conservative factor to obtain a minimum service metal temperature of -15 °F.

Therefore, the NRC staff requires additional information to verify the minimum service metal temperature. This information includes the details of the analysis (e.g., calculation methodology, assumptions made, similarities/differences from previous analysis, etc.) to confirm that -18.5 °F is the lowest service metal temperature to ensure that the material will be tested to have adequate toughness for the design and environment the containment shell will experience. Also, clarification is needed of whether the conservative factors described in the Westinghouse letter dated March 13, 2003, were also used in this analysis. Otherwise, justification for not including these conservative factors should be included

Additional Question (Revision 2)

The response to RAI-SRP 3.8.2-CIB1-01 Rev. 1 was inadequate because it did not provide the information specifically requested in the last paragraph of the Rev. 1 Additional Question. This includes details of the analysis (e.g., calculation methodology, assumptions made, similarities/differences from previous analysis, etc.) and a discussion of the conservatisms.

Additional Question (Revision 3)

- 1) Please provide a plot of the containment shell temperature response in cold conditions discussed in the RAI response, similar to Figure E-1 provided in response to RAI-SRP-6.2.1.1-SPCV-07 (e). This plot covers the part of the transient used to establish steady-state initial conditions
- 2) Is the minimum service metal temperature of -18.5 °F in the AP1000 DCD based on the steady state result or the additional transient scenario discussed in your response to RAI-SRP-6.2.1.1-SPCV-07?

Additional Question: (Revision 4)

DRAFT RAI-SRP3.8.2-CIB1-01, Revision 4, "Containment Min. Metal Service Temperature"

Based on your response (Revision 3) to RAI-SRP3.8.2-CIB1-01, in a letter dated February 17, 2010, the staff has the following supplemental requests for additional information, in order to determine that -18.5°F is the minimum service metal temperature of the steel containment, ensuring that the material will be tested to have adequate toughness for the design and environment the steel containment will experience. Adequate fracture toughness ensures that the material used meets the requirements of GDCs 1, 2 and 16.



Westinghouse

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

1. Your response to RAI-SRP3.8.2-CIB1-01, states that the -30° F external temperature case was used to evaluate the containment shell temperature because wind speed at -30°F is recorded to be faster than at -40°F resulting in a higher velocity through the annulus between the containment and air baffle and therefore greater heat transfer. The NRC staff notes that Westinghouse Document APP-MV50-ZOC-039, Revision 0 used minimum temperatures and corresponding wind speeds from Duluth, Minnesota.

Since temperatures between -40 °F -30 °F, -20 °F, etc. were not used, and a sensitivity study was not performed to show that other temperatures with a higher associated wind speed would not produce a lower calculated minimum service metal temperature, the minimum service metal temperature calculated in Westinghouse Document APP-MV50-ZOC-039, Revision 0 is not bounding. Therefore, in order to complete our evaluation of this issue, we require that WEC either:

- a. perform a bounding calculation using an outside temperature of -40 °F and a maximum wind speed of 48 mph, used in previous calculations, or provide the following information:
 - i. Justify the validity of this Duluth temperature/wind speed data.
 - ii. Discuss the maximum wind speed corresponding to the appropriate temperatures.
 - iii. Discuss why some other temperature with a greater wind speed would not produce a lower service metal temperature.
 - iv. Provide a sensitivity study.
2. In a letter dated February 17, 2010, your response to RAI-SRP3.8.2-CIB1-01 states that the minimum service metal temperature is -0.61° F. Discuss why the minimum service metal temperature of -0.61° F occurs during the start of the steady state run and not at the transient for the inadvertent activation of the fan coolers.
3. Discuss why loss of AC (LOAC) transient runs specified in your RAI response to RAI TR09-008, Revision 4 were performed using an external temperature of -40° F, but an external temperature of -30° F has the lower service metal temperature based on your response to RAI-SRP3.8.2-CIB1-01 and Westinghouse Document APP-MV50-ZOC-039, Revision 0.
4. Westinghouse Document APP-MV50-ZOC-039, Revision 0 states that the minimum service metal temperature is calculated at TC230 level. Confirm that this location is near the bottom of the air baffle plate, and provide the elevation as shown in Figure 3.8.4-1 of the DCD.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

5. Since this is a new analysis (Westinghouse Document APP-MV50-ZOC-039, Revision 0), discuss which parts of your responses (Revisions 0, 1 and 2) to RAI-SRP3.8.2-CIB1-01 are still valid and applicable. For areas that are no longer valid, please provide an update to these areas, such as conservatisms used for WGOTHIC versus previous calculations, etc.

Westinghouse Response: (Revision 0)

An evaluation of AP1000 containment vessel, in the vicinity of large penetrations, was performed by Westinghouse to meet the requirements of COL Information Item 3.8-1. During this evaluation an additional scenario was postulated for the containment vessel shell analysis. The AP1000 plant is designed for sites that can have cold weather conditions with a minimum atmospheric temperature of -40 °F. Therefore, an SSE event was postulated to occur in conjunction with extreme cold weather condition (-40 °F outside temperature) and inadvertent actuation of active containment cooling. The analyses results were documented in an AP1000 calculation. The analyses determined that during this event, the containment vessel will be subjected to an external pressure of 0.9 psid and a 'Service Metal Temperature' of -18.5 °F.

Westinghouse Technical Report APP-GW-GLR-005 submitted to the NRC described these analyses in subsection 2.4.1 of the report. Also, in Table 3.8.2-1 'Load Combinations', at the end of the report, a reference was added for this event. This Table showed the external pressure of 0.9 psid, but inadvertently did not include the corresponding 'Service Metal Temperature' of -18.5 °F.

This change will be incorporated in the next revision of the DCD.

Additional Response (Revision 1):

The Revision 0 change indicated was made in DCD Rev 17.

The additional information required to verify the minimum service metal temperature is provided in Westinghouse document APP-MV50-ZOC-020. Rev 0. This document is made available for review in the Twinbrook office, and provides support for the Lowest Service Metal Temperature of -18.5 °F, corresponding to -40 degree F outside temperature.

Additional Response (Revision 2)

The original calculation supporting a minimum shell temperature of -15 °F represented a simple radial heat balance. The model is shown below:

$$q'' = h_{in} * (T_{cont} - T_{wall,in}) \quad (1)$$

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

$$q'' = k/x * (T_{wall-in} - T_{wall-out}) \quad (2)$$

$$q'' = h_{out} * (T_{wall-out} - T_{amb}) \quad (3)$$

where	q''	is the average heat flux through the shell wall
	h_{in}	is the average heat transfer coefficient between the containment atmosphere and the inside wall of the shell
	T_{cont}	is the average containment atmosphere temperature
	$T_{wall-in}$	is the average temperature of the shell inside surface
	$T_{wall-out}$	is the average temperature of the shell outside surface
	k	is the steel shell thermal conductivity
	x	is the thickness of the steel shell
	h_{out}	is the average heat transfer coefficient between the outside surface of the containment shell and the air in the annulus
and	T_{amb}	is the average temperature of the air in the annulus

For this calculation, the following values were used:

$h_{in} =$	1.0 Btu/hr/ft ² /°F	based on free convection
$T_{cont} =$	50 °F	lower containment limit
$k =$	30 Btu/hr/ft ² /°F	carbon steel thermal conductivity
$x =$	1.75 in	containment average thickness
$h_{out} =$	2.6 Btu/hr/ft ² /°F	based on mixed forced/free convection (Ref. 1)

Solving equations 1-3 simultaneously,

$$T_{wall-in} = -14.7 °F$$

$$T_{wall-out} = -15.1 °F$$

This is the basis for the -15 °F shell temperature reported previously.

For the more detailed calculation, the WGOTHIC computer code was used. The correlations used to calculate the heat transfer coefficients on the shell surfaces were slightly different than those used in the simplified model. Essentially, the free/forced convection model used on the outside surface resulted in a slightly higher heat transfer coefficient which, in turn, resulted in a lower shell temperature. WGOTHIC calculates a heat transfer coefficient of

$$h_{out} = 3.18 \text{ Btu/hr/ft}^2/\text{F}$$



Westinghouse

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

The radial heat balance performed by WGOTHIC results in an average outside shell temperature of -18 °F

References:

1. Holman, J.P., *Heat Transfer*, 4th Ed, McGraw-Hill, 1976.

The conservatisms used for the WGOTHIC calculation are those inherent in the WGOTHIC code and not necessarily those in the March 13, 2003 letter. The conservative factors described in the Westinghouse letter dated March 13, 2003 apply to the manual calculation method and do not apply to the method using WGOTHIC.

Additional Response (Revision 3)

1. There is one transient type that challenges the minimum service metal temperature requirement of -18.5 F. These transients are an inadvertent actuation of the active containment cooling system (VCS). These transients are discussed in depth in RAI-TR09-008. Figure 1 depicts the inadvertent fan cooler operation case at the minimum safety analysis temperature of -40°F, and an additional case at -30 °F. The WGOTHIC computer code was used to analyze these transients. Figure1 shows the minimum service metal temperature for the inadvertent fan cooler case. The transient was completely contained in one case. The case was allowed to equilibrate for 35000s before transient initiation. Operator action is assumed to occur within 60 minutes to shut off the fan coolers and return the transient to normal conditions. Figure 2 depicts the inadvertent fan cooler case at -30°F. This case is evaluated for containment shell temperature because wind speed at -30°F ambient condition is recorded to be faster than at -40°F resulting in a higher velocity through the annulus between the containment and air baffle and therefore greater heat transfer. The increased heat transfer results in a lower shell temperature. For Figures 1 and 2 the minimum service metal temperature is 7.18°F for the -40°F case and -0.61°F for the -30°F case. The transient cases along with the entire spectrum of analyses considering the external pressure and minimum service metal temperature can be found in APP-MV50-Z0C-039 Rev. 0.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Figure 1: Inadvertent Fan Cooler Case at T = -40 F





Figure 2: Inadvertent Fan Cooler Case at T= -30 F



AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Additional Response (Revision 4)

1. To facilitate the staff's closure of this RAI, a bounding case was analyzed to provide an indication of the margin to acceptance criteria associated with the minimum allowable service metal temperature for the AP1000 Containment Vessel. From APP-MV50-Z0C-039 Rev. 0, the LOAC transient (Case 11) at -40°F yielded the lowest service metal temperature of 7.32 °F (Note this was the lowest service metal temperature for the -40 °F transients). For this reason, Case 11 was used as a representative transient to develop a bounding scenario to demonstrate the associated margin to acceptance criteria.

The wind speed for Case 11 was adjusted to achieve 25 ft/s, which corresponds to a 48 mph outside wind speed. The outlet pressure of Boundary Condition (BC) 1 of the Case 11 WGOTHIC base deck was changed to 14.37 psia, to adjust the ΔP magnitude to achieve the 25 ft/s riser velocity. The heat transfer coefficient was recalculated according to the increased velocity in the riser region, and is depicted in Table 1 along with the associated thermophysical properties of air at -40 °F. The HTC was calculated according to the same methodology (application of Dittus-Boelter for turbulent flow in a fluid channel) contained in APP-MV50-Z0C-039 Rev. 0. Figure 3 shows the containment pressure response. It is slightly greater in magnitude (~0.25 psid) than that depicted for Case 11 from APP-SSAR-GSC-039 Rev. 0, but is still within the -0.9 psid constraint.

The associated containment temperature reduction is displayed in Figure 4. Figure 5 displays the velocity in the containment riser region to confirm that the riser velocity was adequately accounted for in the analysis (the actual riser velocity from the raw data was 24.90 ft/s). Note the slight anomaly in the velocity trend. This slight decrease (~0.05 ft/s) is due to the temperature reduction in containment resulting from the LOAC transient. This reduction in temperature actually slows the flow down slightly due to the free convection component of the velocity. This reduction is insignificant to the analysis results and is only explained to facilitate the understanding of the results. The observed minimum service metal temperatures will be discussed and conveyed as a part of the answer to Item 4 of this RAI. For the bounding sensitivity performed to answer this RAI the containment response is still within the service limits depicted in DCD Table 3.8.2-1.

Table 1: HTC for LOAC Transient at -40 F and 25 ft/s.

Dh (ft)	Density (lbm/ft ³)	Kinematic Viscosity (ft ² /s)	Thermal Conductivity (Btu/hr-ft-F)	Thermal Diffusivity(ft ² /s)	Reynolds Number	Prandtl Number	Nusselt Number (Dittus-Boelter)	HTC (BTU/hr-ft ² -F)
2	0.1239402	0.000127742	0.012991811	1.915018E-04	391412.8	0.667056	582.7747	4.732062

[†] The positive 25% uncertainty associated with application of Dittus-Boelter was applied to the calculated value of the HTC to conservatively bound the minimum service metal temperature reported in Revision 4 of this RAI.



AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)




Figure 3: Containment Pressure for LOAC transient at -40 F and 25 ft/s.




Figure 4: Containment Temperature for LOAC transient at -40 F and 25 ft/s.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)




Figure 5: Containment Riser Velocity for LOAC transient at -40 F and 25 ft/s.

2. During performance of APP-MV50-Z0C-039 Rev. 0, it was necessary to run several iterations of each case to dial in the initial conditions accordingly, so that equilibrium conditions could be adequately demonstrated prior to transient initiation. The initial conditions for TC230 were set slightly lower than the equilibrium value, which resulted in the minimum service metal temperature occurring at the beginning of the transient. This inconsistency will be corrected as part of item 5 of this response.
3. The staff had asked for various types of transients to be performed. The inadvertent fan cooler cases were performed to develop meaningful relationships between the source terms of the analysis (humidity, internal temperature, external temperature, wind speed...etc.). Once the relationship of the various source terms was identified, the inadvertent PCS and LOAC cases were strategically chosen to minimize the amount of additional runs required to complete the analysis. While it is quite possible the -30 °F LOAC case could have resulted in a lower service metal temperature, it was Westinghouse's decision to perform the -40 °F LOAC case, because we believed that to be the case for which the staff would be most interested in viewing the results. Additionally, the difference between the -40 °F and -30 °F fan cooler cases was $(8.45^{\circ}\text{F} - 0.67^{\circ}\text{F}) = 7.78^{\circ}\text{F}$. Applying this delta to the -40 °F LOAC case to determine a predicted -30 °F LOAC case would result in $(7.32^{\circ}\text{F} - 7.78^{\circ}\text{F}) = -0.46^{\circ}\text{F}$, which is less than 1 °F lower. However, it does not in any way challenge the allowable minimum service metal temperature of -18.5 °F.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

4. From the WGOTHIC model, TC230 spans control volume (CV) 49 from the 135.25' elevation to the 153.0' elevation. From Figure 6, below it is seen that the 135.25' elevation is below the bottom of the air baffle plate, and the upper elevation of 153.0' is above the air baffle plate, so TC230 spans the region just above the external stiffener to above the bottom of the air baffle plate which is at the 142.0' elevation.




Figure 6: Elevation of Air Baffle and External Stiffener in relation to TC230 span

Figure 7 reports the service metal temperatures for TC230 and TC229. TC229 is included to show that the temperature distribution is fairly uniform from the 135.25' elevation to the 170.0' elevation (top of TC229). This makes sense, as due to the velocity of 25 ft/s a particle of air traveling within the uniform velocity streamline in the constant velocity riser region would only take approximately $34.25\text{ft}/(25\text{ft/s}) = 1.39$ seconds to transport above the top elevation of TC229. Analysis of the raw data shows that the maximum temperature difference between TC229 and TC230 is just less than 1.3 °F for the duration of the transient. Application of this temperature difference to the raw data as an uncertainty in the temperature reported for TC230, would yield a

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

minimum service metal temperature of $-15.78^{\circ}\text{F} + -1.13^{\circ}\text{F} = -16.91^{\circ}\text{F}$. This is still greater than the DCD minimum required service metal temperature of -18.5°F .




Figure 7: Containment Shell minimum service metal temperature for LOAC transient at -40°F and 25 ft/s .

5. The response to item 5 will assume that the results depicted in APP-MV50-Z0C-039 Rev. 0 are the results of record, to satisfy the service limits specified in Chapter 3 of the AP1000 DCD Rev. 17. The results depicted in Item 1 through 4 were strictly conveyed to demonstrate the margin to acceptance criteria, to facilitate the staff's review and acceptance of this RAI and of the adequacy of the CV design.

Revision 0:

Revision 0 of this RAI is still applicable with regards to the bounding limits (-0.9 psid and -18.5°F) previously transmitted. However, please note that the analysis to determine this now comes from APP-MV50-Z0C-039 Rev. 0. The referenced calculation was performed to ensure that the CV service limits were bounded for a wide spectrum of transient initial and faulted conditions. This was accomplished by analyzing three different types of transients:

- i. Inadvertent Actuation of the VCS (Fan Coolers)
- ii. LOAC
- iii. Inadvertent PCS

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

The results of the spectrum of transients performed can be found in APP-MV50-Z0C-039 Rev. 0. The results of the transients do not exceed the structural design limits bounded by the conditions associated with the -0.9 psid and the -18.5 °F transient results conveyed in Rev. 0 of this response.

Revision 1:

Below includes the applicable changes to Revision 1 of this response.

The Revision 0 change indicated was made in DCD Rev 17.

The additional information required to verify the minimum service metal temperature is provided in Westinghouse document APP-MV50-Z0C-039, Rev 0. This document is available for review in the Twinbrook office, and provides support for the bounding Lowest Service Metal Temperature of -18.5 °F, corresponding to -40 degree °F outside temperature.

Revision 2:

The calculation of the HTC from Revision 2 is no longer viable, and is superseded by the Dittus-Boelter correlation applied in APP-MV50-Z0C-039 Rev. 0. The Dittus-Boelter correlation was chosen because it yielded the greatest HTC for a given velocity of air in the containment riser region. For ease of review, the excerpt from the above mentioned calculation conveying the Dittus-Boelter application is displayed below in Figure 8.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Calculation of the HTC's for the WGOTHIC model shell and baffle thermal conductors in the constant velocity region were developed through implementation of the Dittus-Boelter correlation. For the 8.0 ft/s cases the following example calculation displays the application of Dittus-Boelter to the containment annulus region:

D_h = hydraulic diameter of square channel. From Reference 16 the hydraulic diameter of a channel D_h = 2h where h is the channel width. For the riser region the width of the channel is 1ft. so D_h = 2 ft.

$$Re_D = \frac{V \times D}{\nu}$$

For air at -40°F

Where V = fluid velocity = 8.0 ft/s

D = Characteristic Length or Hydraulic Diameter = 2 ft

ν = kinematic viscosity = 0.00012774 ft²/s

$$Re_D = \frac{8.0 \text{ ft/s} \times 2 \text{ ft}}{0.00012774 \text{ ft}^2/\text{s}} = 125,252$$

Pr = ν / α where α is the thermal diffusivity of air = 0.000192 ft²/s, and ν is previously defined as the kinematic viscosity.

$$Pr = \frac{0.00012774 \text{ ft}^2/\text{s}}{0.0001915 \text{ ft}^2/\text{s}} = 0.67$$

$$Nu_D = 0.023 \times 125252^{4/5} \times 0.67^{0.4} = 234.6$$

$$h = \frac{Nu \times k}{D_h} = \frac{234.6 \times 0.012991811(BTU/hr-ft^2-F)}{2 \text{ ft}} = 1.52 BTU/hr-ft^2-F$$

Figure 8: Application of the Dittus-Boelter Correlation for use with WGOTHIC

Further demonstration of the conservatism associated with this calculation of the HTC can be conveyed, by comparing the value of the HTC in Rev. 4, Table 1 of this response with that calculated in Revision 2 of this response. For clarification, a higher HTC will result in a lower calculated service metal temperature.

Revision 3:

Revision 3 should be superseded by the response to Item 4 of Revision 4 of this RAI. The sensitivity performed for Revision 4 of this RAI bounds all scenarios depicted in APP-MV50-Z0C-039 Rev. 0.

AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

It is pertinent at this time to discuss the differences in the performance of APP-MV50-Z0C-039 Rev. 0 as compared to that of APP-MV50-Z0C-020 Rev. 0:

Since no LOAC transients were performed for APP-MV50-Z0C-020 Rev. 0, the discussion will be fairly limited to the comparison of the inadvertent fan cooler cases. However, one major difference in the analyses was that APP-MV50-Z0C-039 Rev. 0 assumed an 8.0 ft/s riser velocity for the -40 °F cases. The use of 8.0 ft/s corresponded to the actual meteorological data taken in Duluth, MN over a 44 year period, for the maximum external wind speeds associated with an external temperature of -40 °F. APP-MV50-Z0C-020 Rev. 0 used the fastest wind speed observed at cold temperatures (-25 °F) to bound all transients. This was not representative of the meteorological data, but was used to bound all conditions.

For the fan cooler cases there were three main differences in the analysis methodology:

1. APP-MV50-Z0C-020 Rev. 0 ramped the fan cooler performance curves from 32 °F, and APP-MV50-Z0C-039 Rev. 0 ramped from 40 °F. The minimum chilled water temperature is 40 °F (APP-VWS-M3-001 Rev. C). Evaluating the fan cooler performance curves from 32 °F is conservative as it allows for greater heat removal at lower temperatures, increasing the calculated ΔT and thus increasing the calculated external pressure.
2. As mentioned previously, APP-MV50-Z0C-039 Rev. 0 used the Dittus-Boelter correlation coupled with a 25% bias to conservatively calculate the HTC. This minimized the minimum service metal temperature and associated external pressure.
3. APP-MV50-Z0C-039 Rev. 0 performed the transient in one case. APP-MV50-Z0C-020 Rev. 0 performed the transient in two cases. One case was performed to establish the initial conditions, and one to depict the associated transient. WGOTHIC is very sensitive to initial conditions, as demonstrated in the plots for Revision 4 of this RAI. The initial conditions must be specified with a low degree of uncertainty and with a steady state condition, to avoid coupling equilibration and transient effects. Allowing the containment to equilibrate for an adequate length of time (~35000 seconds), the transient effects on containment response were more accurately depicted. Additionally, the distributed parameter WGOTHIC model used for these analyses contains approximately 126 volumes, 313 flow paths, and 270 thermal conductors. The task of setting the initial conditions for these parameters with a low degree of uncertainty given the complexity of the model would be extremely difficult. Performance of the transients into one case removes any possible errors associated with incorrectly setting the initial conditions, and provides a true containment response to the transients. This change in methodology is believed to have the greatest impact on the differences in the results depicted in the two calculations.



AP1000 TECHNICAL REPORT REVIEW

Response to Request For Additional Information (RAI)

Design Control Document (DCD) Revision: (Revision 0)

None

PRA Revision:

None

Technical Report (TR) Revision: (Revision 0)

Technical Report APP-GW-GLR-005 (TR 9) will be revised as follows:

Note 6 will be added in Table 3.8.2-1 and will read:

The 'Lowest Service Metal Temperature' corresponding to -40 degree F outside temperature is -18.5 degree F.



Westinghouse