

## ENCLOSURE 2

MFN 10-154

### TRACG04 ATWS Pre-Submittal Planning Presentation

Non-Proprietary Information

#### IMPORTANT NOTICE

Enclosure 2 is a non-proprietary version of Enclosure 1, which has the proprietary information removed. Portions that have been removed are indicated by open and closed double brackets as shown here [[ ]].

**GE Hitachi  
Nuclear Energy**

Non-Proprietary Information


# TRACG BWR/2-6 ATWS LTR Planning Meeting



**HITACHI**

# Objective

Communicate  
Scope and Plan and  
Validate NRC  
Expectations for  
TRACG ATWS  
Application LTR



HITACHI

# Topics

- Scope of LTR
- Scenario specification
- Technical approach
- Submittal schedule



HITACHI

## ATWS LTR Scope

- Applicable to BWR/2-6 and EPU/M+ operation for ATWS and ATWSI
- Use TRACG04P (Model Description NEDE-32176P R4)
- Address M+ LTR SE, IMLTR SE and Migration to TRACG04 LTR SE conditions and limitations
- Follow SRP 15.8 Guidance and Acceptance Criteria
- Follow previous ATWS (ESBWR and Over-pressure LTRs) CSAU Based Methodology




Non-Proprietary Information

# Framework

Use Existing TRACG Code and Model Description

Revise Qualification LTR to add Boron Transport Qualification

Submit ATWS Application LTR



HITACHI

## Historical Limiting Scenarios ATWS (ELTR & M+ LTR)

- Main Steam Isolation Valve Closure (MSIVC)
- Pressure Regulator Failure Open (PRFO)
- Loss of Offsite Power (LOOP) with reduced RHR heat removal capacity

## ATWSI (NEDO-32047 & M+ LTR)

- Turbine Trip with Bypass (TTWBP)
- Recirculation Pump Trip (RPT)

Qualitative assessment to validate limiting scenarios



# CSAU Application to ATWS

- Overall CSAU approach consistent with NUREG/CR-5249

• [[

•

]]





# Summary of TRACG Model Features and Assumptions for ATWS/ATWSI Model Features:

- [[
- 
- 
- 
- ]]

## Assumptions:

- Operator action and timing consistent with EPG/EOPs  
(Including water level strategy and depressurization)



# Boron Transport Model Benchmarking Plan

- [[
- ]]
- Update TRACG Qualification LTR (NEDE-32177P)



# Pool Temperature/Pressure Calculation

- Same principles as STEMP code (Used with ODYN ATWS analysis)
- [[

]]



HITACHI

# ATWSI Analysis Approach

- Obtain approval for generic ATWSI analysis to eliminate plant specific ATWSI limitation (M+ SE Limitation and Condition 12.19)
- GEH has provided plant parameter and nuclear characteristics to facilitate NRC confirmatory calculations
- Establish key plant parameter and nuclear characteristics to develop a reasonably bounding generic approach



Non-Proprietary Information

# Submittal Plan

## Submit in Separate Volumes

- Volume I
  - CSAU steps common to ATWS and ATWSI
- Volume II
  - ATWS Methodology Demonstration
- Volume III
  - ATWSI Generic Solution



HITACHI