

PMSTPCOL PEmails

From: Tai, Tom
Sent: Monday, May 17, 2010 3:59 PM
To: Agles, James
Cc: Chappell, Coley; STPCOL
Subject: STP - RAI 09.05.01-11 (Letter 344)
Attachments: LTR 344 ML1013305170.pdf

Jim,

Attached for your information is an advanced copy of Letter 344 transmitting RAI 4704 for Chapter 9.5.1. The formal hard copy is being sent by mail.

Please call if you have questions.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2219

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED11293E830D0)

Subject: STP - RAI 09.05.01-11 (Letter 344)
Sent Date: 5/17/2010 3:58:57 PM
Received Date: 5/17/2010 3:59:00 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:

"Chappell, Coley" <ccchappell@STPEGS.COM>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Agles, James" <jaagles@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	293	5/17/2010 3:59:00 PM
LTR 344 ML1013305170.pdf	89532	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

May 10, 2010

Mr. Scott Head, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 344 RELATED TO
SRP SECTION 09.05.01 FOR THE SOUTH TEXAS PROJECT COMBINED
LICENSE APPLICATION

Dear Mr. Head

By letter dated September 20, 2007, STP Nuclear Operating Company (STP) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **30** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 4704

Enclosure:
Request for Additional Information

cc: William Mookhoek
James Agles

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 4704

Enclosure:
Request for Additional Information

cc: William Mookhoek
James Agles

Distribution:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BAbeywickrama, NRO
JSegala, NRO
JDreisbach, NRO
DAndrukat, NRO
SKirkwood, OGC
RidsNroDsraSbpa
RidsNroDnrlNge2

ADAMS Accession No. ML101330517

NRO-002

OFFICE	SBPA/SFPT/TR	SBPA/SFPT/BC	NGE2/PM	NGE2/L-PM
NAME	DAndrukat	JDreisbach	TTai	GWunder
DATE	5/4/10	5/4/10	5/4/10	5/10/10

***Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information No. 4704 Revision 3

5/11/2010

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 09.05.01

QUESTIONS for Fire Protection Team (SFPT)

09.05.01-11

In the applicant's response to RAI 09.05.01-9, the applicant confirmed the deletion of a statement referring to the development of a license condition for changes to the fire protection program. In addition, the staff had requested (in RAI 09.05.01-9) that the applicant provide the change process license condition in the FSAR Section 9E. However, the applicant did not include the change process description or a change process license condition in accordance with RG 1.189.

The staff is requesting that the applicant include within Section 9E of the FSAR the credited change process accompanied by a license condition for their self-approval change process of the fire protection program in accordance with RG 1.189.