



HITACHI

GE Hitachi Nuclear Energy

Richard E. Kingston
Vice President, ESBWR Licensing

PO Box 780 M/C A-65
Wilmington, NC 28402-0780
USA

T 910 819 6192
F 910 362 6192
rick.kingston@ge.com

MFN 10-155

Docket No. 52-010

May 17, 2010

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555-0001

Subject: **Supplement to Revised Response to Portion of NRC Request for Additional Information Letter No. 355 Related to ESBWR Design Certification Application - Auxiliary Systems - RAI Number 9.4-53 S01**

Enclosure 1 contains ESBWR Design Control Document (DCD) Revision 8 markups to Tier 1, Table 2.16.2-2. These markups were previously submitted (Reference 1) but were not correctly included in DCD Revision 7 (Reference 2).

If you have any questions about the information provided, please contact me.

Sincerely,

Richard E. Kingston
Vice President, ESBWR Licensing

D063
NRW

Reference:

1. MFN 09-627 Rev 1, Revised Response to Portion of NRC Request for Additional Information Letter No. 355 Related to ESBWR Design Certification Application - Auxiliary Systems - RAI Number 9.4-53 S01, dated February 10, 2010
2. MFN 10-126, ESBWR Standard Plant Design Certification Application Design Control Document, Revision 7, Tier 1 and Tier 2, dated March 29, 2010

Enclosure:

1. Supplement to Revised Response to Portion of NRC Request for Additional Information Letter No. 355 Related to ESBWR Design Certification Application - Auxiliary Systems - RAI Number 9.4-53 S01 – DCD Markups

cc: AE Cabbage USNRC (with enclosures)
J G Head GEH/Wilmington (with enclosures)
DH Hinds GEH/Wilmington (with enclosures)
LF Dougherty GEH/Wilmington (with enclosures)
eDRF Section 0000-0089-7042 Rev 2

Enclosure 1

MFN 10-155

**Supplement to Revised Response to Portion of NRC
Request for Additional Information Letter No. 355
Related to ESBWR Design Certification Application**

Auxiliary Systems

RAI Number 9.4-53 S01

DCD Markups

Table 2.16.2-2

ITAAC For The Reactor Building HVAC

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
<p>12a. The Reactor Building HVAC Accident Exhaust Filters maintains the CONAVS served areas of the reactor building at a minimum negative pressure of 62 Pa (-1/4 inch W.G.) relative to surrounding clean areas when operating.</p>	<p>Testing will be performed to confirm that the Reactor Building HVAC Accident Exhaust Filters maintain the CONAVS area at a minimum negative pressure of 62 Pa (-1/4 inch W.G.) relative to surrounding clean areas when operating each filter train.</p>	<p>The time average pressure differential in the as-built CONAVS served areas of the reactor building as measured by pressure differential indicators is minimum negative pressure of 62 Pa (-1/4 inch W.G.).</p>
<p>12b. The Reactor Building HVAC Accident Exhaust Filters meet RG 1.140 and ASME AG-1 requirements for HEPA and carbon filter efficiency.</p>	<p>The Reactor Building HVAC Accident Exhaust Filters meet RG 1.140 and ASME AG-1 requirements for HEPA and carbon filter efficiency.</p>	<p>The as-built RB HVAC Accident Exhaust filter efficiencies meet the acceptance criteria for <u>laboratory</u> and <u>in place</u> testing in accordance with RG 1.140 and ASME AG-1.</p>
<p>13. The Reactor Building concrete acts as a heat sink that passively maintains the temperature of the Reactor Building rooms within an acceptable range for the first 72 hours following a design basis accident.</p>	<p>A Control Building and Reactor Building Environmental Temperature Analysis for ESBWR will be performed using the as-built heat sink dimensions, the as-built heat sink thermal properties, the as-built heat sink exposed surface area, the as-built thermal properties of materials covering parts of the heat sink, and the as-built heat loads.</p>	<p>The bulk average air temperature in the Reactor Building rooms will not exceed the Thermodynamic Environment Conditions Inside Reactor Building for Accident Conditions on a loss of active cooling for the first 72 hours following a design basis accident, given post design basis accident conditions and reconciled to as-built features and heat loads.</p>