

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title:                   Advisory Committee on Reactor Safeguards  
                          Advanced Boiling Water Reactors  
                          Subcommittee (ABWR)

Docket Number:       (n/a)

Location:               Rockville, Maryland

Date:                    Thursday, March 18, 2010

Work Order No.:       NRC-117

Pages 1-318

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2 DISCLAIMER

3  
4  
5 UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
6 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

7  
8  
9 The contents of this transcript of the proceeding  
10 of the United States Nuclear Regulatory Commission  
11 Advisory Committee on Reactor Safeguards, as reported  
12 herein, is a record of the discussions recorded at the  
13 meeting.

14  
15 This transcript has not been reviewed, corrected,  
16 and edited, and it may contain inaccuracies.

17  
18  
19  
20  
21  
**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 SUBCOMMITTEE ON ADVANCED BOILING WATER REACTORS

8 (ABWR)

9 + + + + +

10 MEETING ON THE SOUTH TEXAS PROJECT COMBINED

11 OPERATING LICENSE APPLICATION (STP COLA)

12 + + + + +

13 THURSDAY, MARCH 18, 2010

14 + + + + +

15 ROCKVILLE, MARYLAND

16 The Subcommittee met, at the Nuclear  
17 Regulatory Commission, Two White Flint North, Room T2B1,  
18 11545 Rockville Pike, at 8:30 a.m., Said Abdel-Khalik,  
19 ACRS Chairman, presiding.

20 ACRS MEMBERS:

21 SAID ABDEL-KHALIK, ACRS Chairman

22 J. SAM ARMIJO, ACRS Vice Chairman

23 JOHN W. STETKAR, ACRS Member-at-Large

24 CHARLES H. BROWN, JR., Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1

JOHN D. SIEBER, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1	C-O-N-T-E-N-T-S	
2	Call to Order and Opening Remarks	8
3	NRO/STPNOC Staff Introductions	10
4	Mark Tonacci, NRO	10
5	Follow-up Items from Previous ACRS	10
6	Meeting on March 2	
7	George Wunder, NRO	10, 12
8	Scott Head, STPNOC	11, 21
9	Part 21 Issues	13
10	George Wunder, NRO	13
11	Action Item	16
12	Thermal-Hydraulic Instability	17
13	George Thomas	17
14	Oak Ridge National Laboratory	
15	Jose March-Leuba	17
16	Oak Ridge National Laboratory	
17	Michael Eudy, NRO	21
18	Jim Tomkins	22
19	STP Licensing	
20	Fuel Topical Reports and Fuel Amendment	26
21	Michael Eudy, NRO	26, 32
22	Japanese ABWR data comparisons	28
23	Michael Eudy, NRO	28
24	Ed Roach	29

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1	Branch Chief, Health Physics	
2		
3	C-O-N-T-E-N-T-S (CONTINUED)	
4	Coley Chappell	32
5	STP Licensing	
6	Japanese Hydrogen Water Chemistry	43
7	Tom Daley	43
8	Mechanical Engineering Group	
9	GALE Code and Uncertainty of	34
10	Effluent Releases	
11	Michael Eudy, NRO	14
12	Steve Schaffer, Technical Expert	14
13	Summary of Open Items	11
14	Mark Tonacci, NRO	11
15	STP COLA FSAR Chapter 5	15
16	SER with Open Items	
17	Scott Head, STPNOC	15
18	Coley Chappell	41
19	STP Licensing	
20	Tom Daley	36, 40
21	Mechanical Engineering Group	
22	Supervisor for STP 3 and 4	
23	Bill Stillwell	33
24	PRA Supervisor for STP 3 and 4	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

		6
1	Action Item	38
2	STP	
3	Action Item	34
4	C-O-N-T-E-N-T-S (CONTINUED)	
5	Neil Ray	38
6	NRC	
7	Kyle Dittman	40
8	Supervisor on I&C Design at STP	
9	Action Item	43
10	STP and NRC staff	
11	Staff Presentation on Chapter 5	47
12	Michael Eudy, NRO	47, 84
13	Steven Downey	49
14	Office of New Reactors	
15	Division of Engineering,	
16	Component Integrity Performance	
17	and Testing Branch 2	
18	Tim Steingass	52, 56, 63, 67
19	Lead Technical Reviewer for	
20	PSI and ISI Operational Programs	
21	Materials and Chemical Engineering	
22	Performance Testing Branch 2	
23	Neil Ray	55
24	NRC	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

		7
1	Chang Li	58
2	Technical Reviewer	
3	Coley Chappell	61, 63
4		
5		
6	C-O-N-T-E-N-T-S (CONTINUED)	
7	STP Licensing	
8	Steve Cashell	62, 64, 66
9	Tech Spec Licensing Engineering	
10	Scott Head, STPNOC	65, 67
11	Action Item	67
12	STP	
13	Tom Scarbrough	67
14	Component Integrity Branch	
15	Summary of Action Items	85
16	STP COLA FSAR Chapter 8	89
17	Scott Head, STPNOC	89
18	Bill Stillwell	89
19	PRA Supervisor for STP 3 and 4	
20	Evan Heacock	90
21	STP	
22	Action Item	145
23	STP and NRC staff	
24	Coley Chappell	151

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1	STP Licensing	
2	Summary of Action Items	154
3	Staff Presentation on Chapter 8	159
4	Adrian Muniz, NRO	159
5	Amar Pal, NRC	195
6	Evan Heacock	167, 197
7		
8	C-O-N-T-E-N-T-S (CONTINUED)	
9	Action Item	190
10	NRC staff	
11	Summary of Action Items	205
12	STP COLA FSAR Chapter 16	207
13	SER with Open Items	
14	Scott Head, STPNOC	207
15	Steve Cashell	208
16	Tech Spec Licensing Engineering	
17	Staff Presentation on Chapter 16	240
18	Michael Eudy, NRO	240
19	Craig Harbuck	241
20	STP COLA FSAR Chapter 17	263
21	SER with Open Items	
22	Scott Head, STPNOC	263
23	Bill Stillwell	263, 269
24	PRA Supervisor for STP 3 and 4	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

		9
1	Tim Walker	265
2	Manager of Quality for STP	
3	Staff Presentation on Chapter 8	286
4	Raj Anand	286, 306
5	Project Manager, Chapter 17	
6	of the South Texas COL application	
7	Garrett Newman	288
8	Reactor Operations Engineer	
9		
10	C-O-N-T-E-N-T-S (CONTINUED)	
11	Quality and Vendor Branch 2	
12	Division of Construction and	
13	Inspection and Operational Programs	
14	Todd Hilsmeier	298
15	PRA group	
16	NRC	
17	Bill Stillwell	297
18	PRA Supervisor for STP 3 and 4	
19	Scott Head, STPNOC	306
20	Action Item	308, 310
21	STP	
22	Public Comments	313
23	John McIntyre	314
24	Charlotte, North Carolina	

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9

Subcommittee Discussion

315

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:29 a.m.

CHAIRMAN ABDEL-KHALIK: (presiding) The meeting will now come to order.

This is a meeting of the ABWR Subcommittee of the Advisory Committee on Reactor Safeguards. I am Said Abdel-Khalik, Chairman of the Subcommittee.

ACRS members in attendance today are Jack Sieber, John Stetkar, Sam Armijo, and Charlie Brown.

Ms. Maitri Banerjee is the Designated Federal Official for this meeting.

The NRC staff review of STP's combined license application has reached the point where they have started to generate the Safety Evaluation Reports with open items for the various chapters. In our March 2nd Subcommittee meeting, we discussed the COLA FSAR and the corresponding SER with open items for Chapters 1, 4, 11, 12, 15, and 18.

In today's meeting, we are scheduled to discuss Chapters 5, 8, 16, and 17. Additionally, we will follow up on several items from the last meeting.

We have scheduled additional ABWR Subcommittee meetings through June, followed by a meeting of the full Committee in the middle of the year.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Although the agenda goes chapter by chapter,  
2 I expect today's discussion to be issue-centered related  
3 to the technical issues in the COLA and the SER.

4           The rules for participation in today's  
5 meeting were announced in The Federal Register on March  
6 9, 2010. Parts of this meeting may need to be closed  
7 to the public to protect proprietary information. I am  
8 asking the NRC staff and the applicant to let us know  
9 when there is a need to close the meeting before we enter  
10 into such discussion and to verify that only people with  
11 the required clearance and need to know are present.

12           We have a telephone bridge line for the public  
13 and stakeholders to hear the deliberations. To minimize  
14 disturbance, the line will be kept in listen-only mode  
15 until the last 10 minutes of this meeting to provide  
16 an opportunity to members of the public joining us through  
17 this bridge line who would like to make a statement or  
18 provide comments. The line will be turned off during  
19 the closed portions of the meeting.

20           As the meeting is being transcribed, I request  
21 that participants in this meeting use the microphones  
22 located throughout this room when addressing the  
23 Subcommittee. Participants should first identify  
24 themselves and speak with sufficient clarity and volume

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so that they can be readily heard.

2 We will now proceed with the meeting, and  
3 I call upon Mr. Mark Tonacci of NRO to begin the  
4 presentation.

5 MR. TONACCI: Good morning. I don't really  
6 have any introductory statement this morning other than  
7 I am glad to be here and look forward to a healthy discussion  
8 today. I am going to turn it over to George Wunder to  
9 kick us off.

10 MR. WUNDER: Good morning, Mr. Chairman.  
11 Good morning, gentlemen. Good morning, Maitri. Thank  
12 you again for having us today.

13 We are going to be presenting today Chapters  
14 5, 8, 16, and 17. I am joined by my fellow Project Managers  
15 Michael Eudy and, later on, by Adrian Muniz, who will  
16 present Chapter 8, and Raj Anand, who will present Chapter  
17 17. The technical staffs who will also be presenting  
18 those chapters will be introduced at that time.

19 I would like to give brief time to Scott  
20 Head to introduce his staff before I launch into my  
21 presentation on action items from last time.

22 MR. HEAD: Thank you, George.

23 Mr. Chairman, thank you for giving us this  
24 opportunity to brief the ACRS again.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           We don't have an introduction presentation  
2           like we did before. I felt, since we have already done  
3           that, along those lines, if we have presented before,  
4           then we aren't going to be introducing ourselves again.

5           But I would note today that we do have Tim  
6           Walker, our Manager of Quality, who will be with us today.

7           He is just back from Japan after observing a number of  
8           activities related to some of our large components that  
9           are being produced in Japan at this point in time.

10           We have Evan Heacock with us today, who is  
11           our lead engineer responsible for electrical activities  
12           and has a lot of ERCOT-related grid experience that we  
13           felt would be useful for the Chapter 8 discussion.

14           We have Bill Stillwell, PRA Supervisor, to  
15           discuss a number of topics today.

16           We have Tom Daley, our Mechanical Supervisor  
17           in Engineering, who will be presenting associated with  
18           Chapter 5.

19           Then, Steve Cashell, expert on tech specs,  
20           that is helping us at the South Texas Project.

21           They will all introduce themselves as we  
22           go through the day.

23           CHAIRMAN ABDEL-KHALIK: Thank you.

24           MR. WUNDER: Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Next slide, please.

2 We have four issues that we would like to  
3 go over that we identified as questions that were raised  
4 in our March 2nd meeting. I believe that Dr. Armijo had  
5 a question regarding the future Fuel Amendment and the  
6 topical reports related to that action, and when they  
7 would be presented.

8 I believe there were also a couple of questions.

9 There was one regarding comparative doses at the operating  
10 Japanese ABWRs as opposed to other operating BWRs, and  
11 we've got Ed Roach, who will be making a presentation  
12 on that.

13 Then, there was another question regarding  
14 the GALE code and its revision, and how that is likely  
15 to affect applicants. We also have a brief presentation  
16 on that.

17 But, first, we would like to address Chairman  
18 Abdel-Khalik's question regarding Part 21 notifications.

19 Next slide, please.

20 There were two issues here. There was a  
21 specific Part 21 notification regarding thermal-hydraulic  
22 stability, but, then, that led to kind of a wider question,  
23 a more generic question, about how we handle Part 21  
24 issues. I would like to give you some background on that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to talk about it generically, and, then, I will turn  
2 it over to the Reactor Systems folks. They can talk about  
3 the specific issue.

4 First off, all Part 21 submittals are reviewed  
5 by the NRC. For NRO, New Reactors, this job falls to  
6 DCIP, the Division of Construction Inspection Programs.

7 DCIP reviews the technical issues and identifies the  
8 technical issues and forwards the Part 21 reports to  
9 the appropriate NRO Branch Chief. The Technical Branch  
10 Chief, in turn, makes a determination on the applicability  
11 of that particular Part 21 issue to any application that  
12 is currently under staff review.

13 Issues that are determined to be of general  
14 concern and rise to that level are addressed in generic  
15 communications, which are issued by the staff. The agency  
16 has a formal procedure for dealing with Part 21 issues.

17 It is an NRR Office letter. It is called LIC-403, but  
18 we have adopted it for use in NRO. We don't yet have  
19 our own procedure, and I don't know that we will ever  
20 have our own because it is a fine procedure for dealing  
21 with Part 21 issues.

22 As far as its application to certified designs,  
23 when a certified design is referenced in a combined license  
24 application, all the identified Part 21 issues that are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 associated with that have to be discussed in the  
2 application.

3 I meant to put up a Federal Register site  
4 here, where we talk about this in a little more detail.

5 It is not here on the slide, but the FR site is 72 FR 49.352.

6 We have also just issued a RIS on this for comment that  
7 discusses and explains our position on this issue in  
8 a little more detail.

9 If you have any questions, I will try to  
10 deal with them. But if not, I can turn it over to the  
11 Reactor Systems fellows for the detailed discussion of  
12 the Part 21.

13 CHAIRMAN ABDEL-KHALIK: Okay. The question,  
14 then, is, do we have a complete list of Part 21s that  
15 were ruled to be applicable to the ABWR that came down  
16 from 1997 until 2010?

17 MR. WUNDER: As far as I know, as far as  
18 being able to lay our finger on a unified list, no. But  
19 they are supposed to have been addressed in the application.

20 They are required to have been addressed in the application,  
21 any Part 21 issue that was identified up until that point.

22 VICE CHAIRMAN ARMIJO: Yes, but I think the  
23 question is, how does the staff know that the applicant  
24 has addressed it, if we don't have a list of all the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 outstanding Part 21s that have come out after the DCD  
2 was --

3 MR. WUNDER: That is an issue that we are  
4 still looking at. We are trying to determine if, in fact,  
5 there are regulations and our procedures are such that  
6 these are guaranteed all to be encompassed, but I cannot  
7 lay my finger on that issue right now. We are still looking  
8 at it, and we are going to make sure that we have closed  
9 it, if there is any kind of a gap there.

10 CHAIRMAN ABDEL-KHALIK: So, as far as we  
11 are concerned, this is still an open item --

12 MR. WUNDER: Yes.

13 CHAIRMAN ABDEL-KHALIK: -- that needs to  
14 be addressed.

15 MR. WUNDER: Yes, sir.

16 CHAIRMAN ABDEL-KHALIK: Okay.

17 MR. WUNDER: We've got procedures. We've  
18 got office procedures in effect, but as far as saying  
19 with metaphysical certitude that we have identified all  
20 these issues, I can't do that today.

21 CHAIRMAN ABDEL-KHALIK: I'm only interested  
22 in physical certitude.

23 (Laughter.)

24 So, we will revisit this issue --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WUNDER: Yes, sir.

2 CHAIRMAN ABDEL-KHALIK: -- once you have  
3 a definitive answer for us.

4 MR. WUNDER: Yes, sir.

5 CHAIRMAN ABDEL-KHALIK: Thank you.

6 MR. WUNDER: I would like to turn it over  
7 to George Thomas now to address thermal-hydraulic  
8 instability.

9 MR. THOMAS: Good morning.

10 In 2001, we were given notification about  
11 the thermal-hydraulic stability issue. Consultant Jose  
12 March-Leuba will talk about the stability issue now.

13 DR. MARCH-LEUBA: Thank you. This is Jose  
14 March-Leuba from Oak Ridge National Laboratory.

15 I have been a consultant for nuclear on the  
16 issue of the stability. So, I can address the Part 21  
17 issues from the stability, in particular.

18 The one you see on the screen is the most  
19 important one. That is the one we call the DIVOM, Part  
20 21, but there are only four quality issues related.

21 In the particular case of the Part 21, if  
22 you understand the process, whenever a graduate student  
23 in a foreign country finds out that there is an issue  
24 that might be related to a safety issue, he raises it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1       There is a small committee of the BWR Owners Group, and  
2       they evaluate, make a notice. They decide, yes, there  
3       is really a potential issue. At that point, they issue  
4       a notification of Part 21.

5               So, the first step is called a notification  
6       that says something may happen; we are evaluating it.

7       At this point, the clock starts running. It lasts,  
8       typically, 30 to 45 days, and the notification is fully  
9       evaluated. Most of them get thrown away; they say, no,  
10      this graduate student was wrong; there is no real safety  
11      issue.

12             If there is a real safety issue, then it  
13      requires a resolution. There is a system. First, you  
14      are notified, and then you accept the notification, and  
15      then you resolve it.

16             In the particular case of the DIVOM, Part  
17      21, the previous methodology allows, or actually requires,  
18      that people use a generic DIVOM correlation which was  
19      deemed to be conservative for every single plant. Some  
20      calculations identified that, indeed, that was not the  
21      case. General Electric and the BWR Owners Group  
22      recommended that people do plant- and cycle-specific  
23      calculations for DIVOM.

24             Now that is a methodology resolution. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 way it was resolved, I have here a copy of the GESTAR  
2 methodology that General Electric uses. They are all  
3 other vendors and they have similar things. They went  
4 into the methodology and they changed, on page -- well,  
5 this is not GESTAR. This is an RAI. But I gave Dr.  
6 Abdel-Khalik a copy of this.

7 They strike out vessel use on generic DIVOM,  
8 and they put usual use of a plant-specific DIVOM. So,  
9 this is how this was originally resolved, and it applies  
10 to ABWR; it applies to ESBR. It applies to every single  
11 operating reactor.

12 From the point of view of the older Part  
13 21s, they apply to the instrumentation and control sections  
14 of the long-term solution. There are some parameter  
15 settings that one uses to adjust the sensitivity for  
16 the detection of the instability before there is a scram.

17 There were some initial recommended values  
18 on the initial approval of the methodology. Afterwards,  
19 given some experience with some events that happened  
20 in 2002, there was a recommendation to tighten that  
21 sensitivity. It was too loose, and the BWR Owners Group  
22 recommended some values.

23 Those values are not incorporated by the  
24 vendor of the I&C system. So, whenever STP implements

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an OPRM scram, solution 3, as they are committed to do,  
2 they will buy from a vendor. Today, they can only buy  
3 from one person. It is GE. It is the only one that has  
4 an approved methodology, an approved instrument that  
5 can be plugged into the protection system.

6 Back when the methodology was approved, there  
7 were two vendors. ABB was in the game, and now they are  
8 not supported anymore. And another vendor can come and  
9 license a different instrumentation, and they can improve  
10 it. It is the responsibility of that vendor to set up  
11 those sensitivity parameters in accordance to the BWROG  
12 recommendations, which follow the Part 21 resolution.

13 So, in conclusion, of all the Part 21 issues,  
14 and I know there are five of them, all of them are taken  
15 care of, and they apply to ABWR, through this procedure.

16 CHAIRMAN ABDEL-KHALIK: When you say "taken  
17 care of", meaning that the process will assure that they  
18 will be taken care of? As far as I'm concerned, I haven't  
19 seen how they are taken care of as of today.

20 MR. THOMAS: See, we got a commitment from  
21 STP that, before they start the plant, they will come  
22 with a new stability analysis that will take care of  
23 all these Part 21 problems.

24 CHAIRMAN ABDEL-KHALIK: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. THOMAS: So, that is okay for us.

2 CHAIRMAN ABDEL-KHALIK: I think if we have  
3 a resolution of the generic question as to how Part 21s  
4 will be addressed, this will automatically be taken care  
5 of. Therefore, we await the general response as to how  
6 the staff intends to assure that all relevant Part 21s  
7 have been, or will be, addressed.

8 Thank you.

9 MR. THOMAS: You're welcome. Thank you.

10 MR. EUDY: Hi. I'm Mike Eudy, Project  
11 Manager. I would like to give this time to South Texas,  
12 if they have anything to add.

13 MR. HEAD: Mr. Chairman, we do have some  
14 points we can make on the specific technical topic of  
15 the one that was just discussed, but if you want us to  
16 wait --

17 CHAIRMAN ABDEL-KHALIK: No, please do.

18 MR. HEAD: Okay. I will ask Jim Tomkins.

19 MR. TOMKINS: Jim Tomkins, STP Licensing.

20 CHAIRMAN ABDEL-KHALIK: Do you have any  
21 visual aids to go with your presentation?

22 MR. TOMKINS: I do not, no. I do not.

23 CHAIRMAN ABDEL-KHALIK: Okay.

24 MR. TOMKINS: So, let me just give a little

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit of the history. In our initial application for the  
2 COLA, we were working with General Electric, and we were  
3 made aware of the Part 21 issues via a licensing topical  
4 report that GE submitted to the NRC. That report was  
5 submitted in support of our COLA application.

6 In Revision 2, when GE was no longer on the  
7 project, we didn't have access to that topical report  
8 any longer. So, in that case, we changed and we made  
9 a commitment. We recognized that we needed to address  
10 the issues GE had identified, and we made a commitment  
11 that we would do that.

12 That commitment, I will just read it. "STPNO  
13 will provide an updated stability option 3 analysis once  
14 fuel is procured and the associated safety analysis is  
15 performed." So, that commitment is absolute. It doesn't  
16 say when we change the fuel. It is when any fuel is procured  
17 that we will do that analysis. That commitment was put  
18 in there specifically to address that issue.

19 So, I guess the point I wanted to make is  
20 we were aware of the issues, and we think we have a plan  
21 to address them. Actually, we are working on stability  
22 as we speak. Westinghouse is doing the work to support  
23 the Fuel Amendment. That will be the avenue by which  
24 we resolve it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: Do you have an answer  
2 at this time to the generic question of how Part 21s  
3 are handled in general?

4 MR. TOMKINS: Well, I can talk a little bit  
5 about our process. In developing the COLA, we followed  
6 Reg Guide 1.206 and the standard review plan. So, for  
7 any sections that had departures in them, we were required  
8 to look at the standard review plan. For sections of  
9 the COLA that didn't have a departure, the certified  
10 design still applied.

11 But recognize that we worked with GE on this  
12 project for, essentially, a year and a half. So, a number  
13 of issues like stability, containment analysis, although  
14 it wasn't really a Part 21, it is sort of in the same  
15 category. So, GE pointed out a number of these issues  
16 to us. Some of them are actually departures. It is their  
17 fixes to the DCD.

18 CHAIRMAN ABDEL-KHALIK: I will ask you the  
19 same question I asked the staff. Do you have a list of  
20 all applicable Part 21s to the sections which you may  
21 have incorporated by reference in the DCD that came about  
22 from 1997 until the present?

23 MR. TOMKINS: I do not believe we have a  
24 list at this point in time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: So, the topical had a list  
2 initially?

3 MR. TOMKINS: Well, the topical really just  
4 addressed ability.

5 MR. HEAD: Okay.

6 MR. TOMKINS: So, that was fairly narrow.  
7 You're asking the generic question --

8 CHAIRMAN ABDEL-KHALIK: Yes, sir, I am.

9 MR. TOMKINS: -- whether I have a global  
10 list?

11 MR. CHAPPELL: This is Coley Chappell, also  
12 from STP Licensing.

13 Part of the issue is that some departures  
14 or information that had to be changed was evaluated for  
15 Part 21, but may not have risen to that level. So, we  
16 will go back and look at that and determine which of  
17 the items might be a Part 21 --

18 CHAIRMAN ABDEL-KHALIK: But, again, the  
19 issue that my colleague raised here, without such a list,  
20 there is no way to guarantee that all those relevant  
21 issues have, indeed, been addressed. That is what we  
22 would like to assure ourselves, that this has been done.

23 MR. TOMKINS: Right. And recognizing your  
24 question at the last meeting was a good question, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have actually undertaken that work. We are having a second  
2 check, if you will --

3 CHAIRMAN ABDEL-KHALIK: Okay.

4 MR. TOMKINS: -- of all the Part 21s to make  
5 sure we've got them all captured.

6 CHAIRMAN ABDEL-KHALIK: All right. Thank  
7 you.

8 MR. EUDY: NRC staff is doing the same.

9 CHAIRMAN ABDEL-KHALIK: Thank you. Okay.  
10 Let's proceed.

11 MR. EUDY: No more questions?

12 Okay. We will go ahead and go to the second  
13 topic of action items, the Fuel Topical Reports and Fuel  
14 Amendment.

15 When we presented Chapter 4 back on March  
16 2nd, there were some questions raised regarding the Fuel  
17 Amendment and topical reports that will be supporting  
18 it. So, due to that interest, we wanted to give you a  
19 little bit of update on how we plan to move forward.

20 South Texas has proposed to send in a Fuel  
21 Amendment when they are closer to their procurement that  
22 will be a licensing amendment after it is already licensed,  
23 to introduce a new fuel. That is going to be in the form  
24 of a Fuel Amendment. We are not aware of any requirement

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to bring it to ACRS, but due to the interest, what we  
2 are proposing is that we are expecting 10 topical reports.

3 Next slide. No one told me, "next slide".  
4 I meant to say to myself, "next slide".

5 (Laughter.)

6 We are expecting 10 topical reports to come  
7 in. Of those, seven currently have what we deem as dual  
8 applicability to both ABWR and BWRs. We have begun  
9 coordination to ensure that all three Subcommittees,  
10 ABWR, Power Uprate, and Thermal-Hydraulic Phenomena,  
11 can determine which of those topical reports they would  
12 like to see. We can do presentations, if you request  
13 them.

14 As of now, two of those topical reports are  
15 in. To give you a little bit of an update, we expect  
16 the first topical report, which is qualification of control  
17 system model, SAFR, that we might have our review finished  
18 in the fall of the 2010. We might be presenting to the  
19 ACRS as well. After June of this year, we should be getting  
20 the remaining eight topical reports phasing in.

21 That is all that I had to present on that  
22 topic. So, if there are any questions, or if South Texas  
23 would like to add anything to that, we will give them  
24 the opportunity.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: Well, at this point, I would just  
2 note we would support whatever briefing the staff and  
3 ACRS agrees upon, whether it is on individual topical  
4 or an all-encompassing presentation. We understand the  
5 interest and somewhat of a first-time evolution, and  
6 we would be happy to support whatever presentations you  
7 request.

8 VICE CHAIRMAN ARMIJO: You provided us with  
9 some viewgraphs of a January meeting, I think, with South  
10 Texas and Westinghouse and the staff. It had a pretty  
11 complete list of topical reports and what the issues  
12 were. So, I think, with that, I think our various  
13 Subcommittees within the ACRS can pick and choose the  
14 ones that we think are most important from our point  
15 of view. We will probably want to review them when you  
16 are ready.

17 MR. EUDY: Certainly. Okay. That's the  
18 plan.

19 Okay, if there's no more questions, I will  
20 move onto the third item, which is Japanese ABWR data  
21 comparisons. I will ask Ed Roach to come up, who is the  
22 Branch Chief for Health Physics. He will give that  
23 presentation.

24 MR. ROACH: Good morning, Mr. Chairman and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Committee. It is a pleasure to be here again.

2 I notice Dr. Ryan is not here, who was the  
3 one who posed these questions, but I hope the information  
4 will get back, or we are willing to come in and present  
5 again, if necessary.

6 From the Committee's last meeting, when we  
7 presented Chapter 12, this open item appeared. It was  
8 based on a comparison to the actual ABWRs that do operate.

9 For us, that would be the one element would be  
10 Kashiwazaki-Kariwa, Units 6 and 7, which operated from  
11 1997 to 2004. We normalized this data to millisieverts  
12 per megawatt-year, which normalizes them across all of -- I  
13 think that was Dr. Ryan's point.

14 So, Kashiwazaki-Kariwa Units 6 and 7 give  
15 you a .49 person-millisieverts megawatt-year. South  
16 Texas, as calculated, would present a .82  
17 person-millisieverts megawatt-year. That is assuming,  
18 basically, an 85 percent capacity factor.

19 Next slide, please.

20 The data we used came from a letter from  
21 GE Hitachi that was part of the ESBWR. However, we did  
22 search out on the ISOE and the U.S. NRC data to compare  
23 various things.

24 This slide shows the assumptions used for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this calculation and a summary of the available data  
2 and the references. This slide also shows that, if you  
3 assume a 92 percent capacity factor, which is the U.S.  
4 average currently from 2000 to 2008, the estimated  
5 collective dose megawatts per year for STP 3 and 4 would  
6 decrease to 0.76 person-millisieverts megawatt-year.  
7 That is approximately 55 percent higher than the K6 and  
8 7 data, but it is still well below the current operating  
9 steam and evidence, history that we have for BWRs in  
10 the U.S.

11 Next slide, please.

12 This chart is from the data in NUREG-0713  
13 and the ISOE Asian Technical Center, ISOE Information  
14 Sheet 33, figure 2, dated 2009. This is the breakdown  
15 of the average collective dose per reactor and the total  
16 collective dose per megawatt-year for U.S. and Japanese  
17 BWRs from 1993 through 2008.

18 The Japanese data was broken down in 1993  
19 to 2004 into conventional and improved units for collective  
20 dose. However, the collective dose per megawatt-year  
21 is only reported as an average for all BWRs. So, it is  
22 very hard for us to parse that information out.

23 Needless to say, the red line, which the  
24 red column would be U.S. and blue would be Japan lines,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 show the overall trend in collective dose per megawatt-year.

2 At .82 person-millisieverts megawatt-year, the estimated  
3 STP 3 and 4 dose per unit would be approximately one-half  
4 the average 2008 U.S. BWR dose, which is 1.4, and a factor  
5 of four below the average 2008 Japanese BWR dose, shown  
6 on the far right of the chart.

7 The spike in the collective dose in 2002  
8 and 2003 in Japan was due to numerous reactor recirculation  
9 pipe and shroud inspection repairs in the BWR plants  
10 there.

11 So, our conclusion is that, as documented  
12 in the SER, this verifies that the radiation protection  
13 measures incorporated in the ABWR, and as described in  
14 the STP 3 and 4 COLA, will provide reasonable assurance  
15 that the occupational doses can be maintained ALARA and  
16 below the limits of 10 CFR 20 during all plant operations.

17 In addition, the estimated annual  
18 occupational dose will be lower than the current U.S.,  
19 Japanese, and international operating averages.

20 CHAIRMAN ABDEL-KHALIK: Good.

21 MR. ROACH: Any questions?

22 (No response.)

23 MR. EUDY: If there are no questions, we  
24 would like to give South Texas the opportunity, if they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had anything to add to that.

2 MR. CHAPPELL: We have one slide, which you  
3 have as a handout.

4 We have previously received information from  
5 Tokyo Electric regarding the outage doses at  
6 Kashiwazaki-Kariwa 1 through 7. What is shown up here  
7 are averages over a specified time, six years. What is  
8 important to note is that K1 through K5 are BWR 5 plants;  
9 K6 and 7 are ABWR.

10 So, this shows a marked lowering of the dose  
11 during outages over this timeframe for ABWR, which is  
12 attributed to improved design, maintenance practices,  
13 and chemistry controls. This is the data point that  
14 supports, I think, the conclusions that the staff has.

15 VICE CHAIRMAN ARMIJO: In some of that  
16 experience of the Japanese, it was with all the repair  
17 work they had to do as a result of IGSCC. In the case  
18 of South Texas, I think you may have told me before,  
19 but are you going to implement the hydrogen water chemistry  
20 to minimize IGSCC risk. Is that part of your plants?

21 MR. TOMKINS: Yes, sir. Some form of  
22 hydrogen water.

23 VICE CHAIRMAN ARMIJO: Some form?

24 MR. TOMKINS: Yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN ARMIJO: Okay. And do you know  
2 if K6 and K7 have that feature or are they just -- just  
3 a curiosity from my --

4 MR. CHAPPELL: I have no idea at this time.

5 MR. TOMKINS: I'm being told they don't.

6 VICE CHAIRMAN ARMIJO: I've heard that, but  
7 I just wanted something from somebody who knows.

8 MR. TOMKINS: Okay, and we have someone --

9 VICE CHAIRMAN ARMIJO: If you could find  
10 out, I would appreciate it.

11 MR. TOMKINS: We will have someone who can  
12 speak to that up here in just a second.

13 VICE CHAIRMAN ARMIJO: Okay.

14 CHAIRMAN ABDEL-KHALIK: Okay. Please  
15 proceed.

16 MR. EUDY: Okay. We'll move on to the final  
17 ACRS action item that we plan to present regarding the  
18 GALE code and uncertainty of effluent releases. Steve  
19 Schaffer, our technical expert, will lead us through  
20 that discussion.

21 MR. SCHAFFER: Good morning.

22 Before I start, there was actually another  
23 question that the Subcommittee raised. We are in the  
24 process of updating our new codes. They wanted to know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what would be the impact of the update on STP? The simple  
2 licensing answer is none. We hold the applicants to the  
3 codes and guidance that are in place six months before  
4 the application is made.

5 From a technical standpoint or a scientific  
6 standpoint, that is not a very satisfying answer, and  
7 we knew that. About three years ago, we started on an  
8 effort to update the codes, but, also, an effort, because  
9 we knew most of the applications that we get in both  
10 for certified designs and for COLAs will begin before  
11 we update all our computer codes. So, we have to use  
12 the old codes. So, we wanted to answer the question,  
13 well, how long could we be by using the new codes -- I'm  
14 sorry -- the old codes on the new plants?

15 So, what I am going to address today is the  
16 GALE code, the GALE86 code, which is the code that we  
17 use to calculate the effluent releases for liquid and  
18 gaseous radionuclides, and how that would apply to the  
19 newer designs, and how long we can be by using these  
20 older codes for the newer designs.

21 Next slide. I think, is there one before  
22 that? Yes, okay.

23 So, we wanted to answer two questions. First,  
24 we wanted to look at the structure of the old code. Would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the structure of the old code, the algorithms, the equations,  
2 that we used really fit the new designs? And then, we  
3 also wanted to answer the question as to how accurate  
4 the GALE86 would predict the releases from the new plant.

5 Okay, I guess we go to the next slide.

6 We looked at the structures and the algorithms.

7 There's two major components to the GALE code, one that  
8 calculates the coolant concentrations, the primary  
9 coolant in the BWR case and the primary and secondary  
10 in the PWR case.

11 The way GALE calculates that is really using  
12 the approach that is in ANSI 18.1. The GALE86 version  
13 uses an older version of this code. There is now an updated  
14 version, updated 1999. When you compare the  
15 concentrations that are in the ANSI standard between  
16 now, the '99 versus the old '86 code, there are a few  
17 changes, most of them to lower the concentrations. There's  
18 also some adjustment factors, depending on the power  
19 levels that you can apply that the standard recommends  
20 to using. Those adjustment factors also indicate that  
21 the coolant concentrations for the new plants would  
22 actually go down compared to the old code.

23 Then, we also looked at how the code calculates  
24 the waste management aspects for the liquid and gaseous

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 streams. We reviewed all of the new designs, the waste  
2 management systems of the new designs, and the new designs  
3 are, basically, just variations of the same practices  
4 that we are doing right now. So, the bottom line is that  
5 the structure and the algorithms of the GALE code are  
6 still okay for the new designs right now.

7 Now, before we go to the next slide, the  
8 next question is, well, how active is the GALE code?  
9 So, we said, well, why don't we benchmark the actual  
10 effluent releases to the results of the GALE code? So,  
11 obviously, we don't have new designs to compare them  
12 to.

13 So, what we did was we thought that, because  
14 the current operating fleet, if we look at the recent  
15 releases that are reported in the current operating fleet,  
16 that sort of reflects the advances in the fuel, the advances  
17 in the coolant chemistry, and the advances in the waste  
18 management technology and practices. So, the current  
19 operating fleet and their present annual releases probably  
20 is the best surrogate that we have for benchmarking the  
21 code to.

22 So, we looked at the annual effluent releases  
23 and compared them to the GALE codes that were calculated  
24 in the updated FSARs. We found six BWR plants and eleven

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PWR plants that had all the information that we could  
2 make the comparison to.

3 In addition, carbon-14 and tritium are a  
4 little bit different. They have embedded values in the  
5 GALE code which allows us to compare the effluent releases  
6 to the embedded values, as opposed to having to run the  
7 calculations, so we could look at a broader spectrum  
8 of plants.

9 All right, we will go to the next slide.

10 What we found was that the GALE overpredicts  
11 most liquid and gaseous effluent releases by a factor  
12 of two, and in most cases, an order of magnitude or more.

13 That "more" is more like more; it could be a factor of  
14 100 to 1,000.

15 In addition, we found that the GALE  
16 predictions, the GALE86 predictions, for tritium and  
17 carbon-14, which are important radionuclides to the dose,  
18 are reasonably accurate.

19 I guess I will entertain any questions.  
20 That sort of ends the presentation.

21 VICE CHAIRMAN ARMIJO: Were there any  
22 significant underpredictions?

23 MR. SCHAFFER: If you look at it on a  
24 year-by-year basis, a plant-by-plant basis, the numbers

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are all over the place. One plant in one particular year  
2 could significantly be underpredicted by the GALE code,  
3 and then next year be significantly overpredicted by  
4 the GALE code.

5 The purpose of the GALE is to look at long-term  
6 averages. When you look at the long-term averages, that's  
7 the results that I am presenting.

8 VICE CHAIRMAN ARMIJO: Okay.

9 CHAIRMAN ABDEL-KHALIK: Any other  
10 questions?

11 MEMBER SIEBER: This sort of assumes that  
12 the GALE code is not very accurate. Is there anything  
13 better or more sophisticated under development by anybody?

14 MR. SCHAFFER: Yes. In fact, part of this  
15 effort that we started three years ago was to develop,  
16 to update the GALE codes. If you remember in our  
17 discussions last meeting, the GALE, a lot of the parameters  
18 in the GALE code are based on operating experience and  
19 empirically-derived.

20 So, we have taken a close look at the  
21 present-day operating experience and have adjusted the  
22 GALE code. We have also imported the newer ANSI standard  
23 for the coolant concentrations and the adjustment factors  
24 there. We have also made it user-friendly, Windows-based.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We are testing it right now, and it should probably be  
2 out within a year.

3 MEMBER SIEBER: Does that mean that the  
4 answers are sort of code-specific? If it is derived from  
5 operating experience from old plants, now you've got  
6 to apply it to a new plant; you don't get the right answers  
7 by a factor of 10 to 1,000. Does that mean that the  
8 algorithms that you use to model the old plant don't  
9 fit the new plant very well?

10 MR. SCHAFFER: No. The algorithms fit. It  
11 is the parameters that you put into the algorithms which  
12 were based on the operating experience that would make  
13 you to overpredict the releases.

14 MEMBER SIEBER: Okay. Thank you.

15 CHAIRMAN ABDEL-KHALIK: Any other  
16 questions?

17 (No response.)

18 MR. EUDY: If there's no more questions,  
19 South Texas, maybe they didn't have anything to add to  
20 this discussion.

21 MR. HEAD: Looks like we are using a  
22 conservative analysis.

23 (Laughter.)

24 CHAIRMAN ABDEL-KHALIK: We will proceed with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the next item on the agenda.

2 MR. TONACCI: Dr. Abdel-Khalik?

3 CHAIRMAN ABDEL-KHALIK: Yes, sir?

4 MR. TONACCI: Can I just kind of run through  
5 these open items, so I understand which ones have to  
6 come back?

7 Obviously, the Part 21 needs to come back.

8 CHAIRMAN ABDEL-KHALIK: Right.

9 MR. TONACCI: The other one on fuel topical  
10 reports, we understand the Committee will choose which  
11 ones they want to hear in the future. But, as far as  
12 that action item for ABWR, that is closed?

13 CHAIRMAN ABDEL-KHALIK: Right.

14 MR. TONACCI: And the one on Japanese  
15 occupational dose, is that closed as well?

16 CHAIRMAN ABDEL-KHALIK: Yes.

17 MR. TONACCI: And the one we just heard on  
18 GALE code, I assume that is closed as well?

19 CHAIRMAN ABDEL-KHALIK: Yes.

20 MR. TONACCI: Thank you.

21 We also had one on temperatures, which will  
22 be presented as part of Chapter 8 and in the future as  
23 part of Chapter 9.

24 CHAIRMAN ABDEL-KHALIK: Yes, Maitri?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. BANERJEE: Maitri Banerjee, ACRS staff.

2 I thought I heard that STP will get back  
3 to the Committee on K6's and K7's use of hydrogen water  
4 chemistry.

5 VICE CHAIRMAN ARMIJO: Just a confirmation,  
6 yes, from today's meeting, you know. Do K6 and K7 use  
7 hydrogen water chemistry of some form or not?

8 MR. HEAD: We are getting ready to give you  
9 some perspective on that in just a second.

10 MS. BANERJEE: Thank you.

11 CHAIRMAN ABDEL-KHALIK: Who is next here?

12 MR. EUDY: Are we going to discuss the  
13 Japanese --

14 MR. HEAD: Yes, we are getting ready to do  
15 Chapter 5, but before we do that, we will answer the  
16 hydrogen water chemistry.

17 CHAIRMAN ABDEL-KHALIK: Okay, please go  
18 ahead.

19 MR. DALEY: Good morning. My name is Tom  
20 Daley. I'm the Mechanical Engineering Group Supervisor  
21 for STP 3 and 4.

22 As way of background, I have been here for  
23 three years. Prior to that, I had the same position for  
24 Stone & Webster on the Lungmen Project in Taipei, also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an ABWR. Over 25 years of working with Sargent & Lundy.

2 I have had the opportunity to work in Korea for over  
3 five years as manager of the Ulchin 3 and 4 and the Younggwang  
4 3 and 4 projects. Those were combustion engineering 80  
5 system NSSS. Site Engineering Manager at the Zimmer  
6 Project before it became a fossil plant, and I'm Project  
7 Engineer on one of the last projects to obtain a  
8 construction permit.

9 Prior to my civilian profession, I was an  
10 engineer officer on a nuclear submarine, have got a BSME  
11 from the Naval Academy, an MSME from Naval Post-Graduate  
12 School, and an MBA from the University of Chicago.

13 I'm a registered professional engineer in  
14 six states and, hopefully, this conference will be a  
15 couple of CEUs that will help me maintain those licenses.

16 Regarding hydrogen water chemistry, the  
17 Japanese don't feel that its use is warranted for the  
18 ABWR. They have upgraded the materials and the  
19 manufacturing processes on the ABWR. So, they have  
20 specifically stated that they don't feel that the use  
21 of hydrogen water chemistry is warranted.

22 They do use hydrogen water chemistry in some  
23 of their boiling water reactors, but, again, they don't  
24 feel it is necessary.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 GE actually made that statement in the DCD  
2 as well, that they don't feel that the use of hydrogen  
3 water chemistry is necessary. However, we have made  
4 provisions to use it.

5 VICE CHAIRMAN ARMIJO: Okay, but the South  
6 Texas Project doesn't share that view?

7 MR. DALEY: We have always had a concept  
8 of defense in depth.

9 VICE CHAIRMAN ARMIJO: Good.

10 MR. DALEY: We believe the literature  
11 supports that using hydrogen water chemistry, even in  
12 a limited amount, will reduce the possibility for stress  
13 corrosion cracking.

14 VICE CHAIRMAN ARMIJO: Well, the unfortunate  
15 thing is these improved materials in the highly-oxidizing  
16 core environment, in fact, do sometimes crack. So, the  
17 defense in depth is extremely valuable, a powerful tool  
18 to protect the plant.

19 MR. DALEY: Yes, sir.

20 VICE CHAIRMAN ARMIJO: Okay, thank you.

21 CHAIRMAN ABDEL-KHALIK: All right. At this  
22 time, we will proceed with the presentation on Chapter  
23 5. We will begin with the presentation by the applicant.

24 MR. HEAD: We're going to present Chapter

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 5 at this time. It is pretty much the standard agenda  
2 for the presentation, and there are people in the room  
3 that could help us address, we hope, questions that could  
4 come up on this chapter.

5 I will turn it over to Coley now to go through  
6 some of the overall specifics.

7 MR. CHAPPELL: My name is Coley Chappell.  
8 I'm with the STP and with the Licensing. It is good  
9 to see you again this morning.

10 I will continue with our discussion to present  
11 Chapter 5 of the FSAR. This deals with the reactor coolant  
12 system and connected systems. There are sections in this  
13 chapter that also talk about the reactor coolant pressure  
14 boundary, how the design is, how it is maintained, and  
15 how it is monitored for any degradation.

16 One of the significant features in this  
17 chapter that we have alluded to before is our Tier 1  
18 departure, which replaces the reactor cooling pump with  
19 a new design. For a discussion on this topic, I will  
20 turn the presentation back over to Tom Daley.

21 MR. DALEY: We feel that the improved  
22 monoblock design is a definite improvement in the type  
23 of pumps to use in the ECCS over the typical Terry  
24 Turbine-type pumps that have been used in the past.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The pump itself is water-lubricated. So,  
2           it eliminates the oil lubrication system. It uses  
3           inner-stage water for shaft sealing. It has an integral  
4           governor speed control system, which eliminates the need  
5           for a bypass line that is typical on Terry Turbine-type  
6           systems.

7           It exhausts directly to the suppression pool.  
8           Any steam condensation prior to startup is collected  
9           in a separate tank and pumped to the condenser. So, it  
10          eliminates the need for a barometric condenser.

11          So, when GE first suggested this pump, we  
12          were very much in favor of doing that. It is used on  
13          a number of auxiliary feedwater system applications  
14          overseas and, also, planned to be used on the Lungmen  
15          Project. So, we feel it is a definite improvement, and  
16          that is why we decided to go with it.

17          VICE CHAIRMAN ARMIJO: Is there any operating  
18          experience on BWRs using this pump?

19          MR. DALEY: No, not on BWRs. This will  
20          be -- well, they are planning on using it on Lungmen,  
21          but there's no operating BWRs right now.

22          VICE CHAIRMAN ARMIJO: So, at Kashi it was  
23          actually 6 and 7 and the other ABWRs in Japan still use  
24          the old Terry?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. DALEY: That is correct.

2 CHAIRMAN ABDEL-KHALIK: John?

3 MEMBER-AT-LARGE STETKAR: I think, if I  
4 recall, if I counted up actual turbine-driven pumps,  
5 there's a listing in an appendix to a technical report.

6 I think I counted 18 of these things installed in operating  
7 plants. Does that sound correct? I mean there's some  
8 on order. But I think there are 18 of them out there.

9 I grew up with Terry Turbine-driven aux  
10 feedwater pumps. What's been the operating experience  
11 with these things? Overspeed trips on startup is the  
12 thing I am interested in.

13 You know, I recognize you've got an integral  
14 governor and all of that kind of good stuff, but the  
15 fact of the matter is the governor valve is fully open  
16 and it has got to kind of snatch when the steam hits  
17 it, the same as the Terry Turbine. So, what's been the  
18 operating experience on those?

19 MR. DALEY: Well, we haven't gotten any  
20 direct feedback from any of the operating stations.  
21 However, we have talked with the manufacturer. We have  
22 had a number of presentations. He tells us this --

23 MEMBER-AT-LARGE STETKAR: Oh, yes, he's  
24 going to tell you that the experience would be worse.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 I would kind of be interested to see what  
3 the operating experience might have been in terms of,  
4 in particular, the thing that the Terry Turbines  
5 traditionally have been susceptible to is the overspeed  
6 trip on a startup.

7 But, with respect to that, a couple of other  
8 questions about not so much the turbine internal design,  
9 but I know you've got electrical and mechanical overspeed  
10 trips on the turbine. If it trips out on mechanical  
11 overspeed, do you have to locally reset the trip valve?

12 I read that it's got a motor-operated, you know, a standard  
13 motor-operated reset for the electrical trip. But if  
14 it is a mechanical trip, you have to locally reset it?

15 MR. DALEY: I believe that is the case.  
16 You've got a similar type of a ratchet sort of a thing  
17 that you have to operate.

18 MEMBER-AT-LARGE STETKAR: I notice that,  
19 because you have this now new pump, that the steam supply  
20 line design has been changed to remove the full bypass  
21 valve around the steam emission valve that used to give  
22 it kind of a little slower --

23 MR. DALEY: Right.

24 MEMBER-AT-LARGE STETKAR: -- startup. Also,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with respect to the existing installed pumps, do you  
2 know whether they have also removed that bypass line,  
3 that they only use a single steam emission line or --

4 MR. DALEY: Yes, sir, as far as I know --

5 MEMBER-AT-LARGE STETKAR: Because that is  
6 outside of the pump supply.

7 MR. DALEY: Right. And you are right, it  
8 looks like it doesn't have quite the same feedback. It  
9 is a direct feedback system on the governor, and the  
10 startup is much more controlled.

11 MEMBER-AT-LARGE STETKAR: It still has to  
12 respond, though, to --

13 MR. DALEY: It still has to respond.

14 MEMBER-AT-LARGE STETKAR: -- the initial,  
15 when the steam emission valve comes, the real steam emission  
16 valve comes open, it still has to respond to that initial  
17 pressure pulse.

18 MR. DALEY: Right, it does have to control  
19 it. I mean it opens, and it has got to shut a little  
20 bit in order to control the steam.

21 MEMBER-AT-LARGE STETKAR: Right, right.

22 MR. DALEY: But I'm not aware that, as far  
23 as I know, this design eliminates the necessity for that  
24 bypass line. So, the other designs --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: I mean, if the  
2 governor works good, yes.

3 MR. DALEY: Right.

4 MEMBER-AT-LARGE STETKAR: And one last  
5 question, and this is sort of a system question. Is the  
6 RCIC system -- I didn't get a chance to read through  
7 all of the controls and system operation. I understand  
8 that the system is supposed to be able to handle cooling  
9 for a nominal eight-hour station blackout period. Is  
10 this RCIC system designed to cycle on and off from low  
11 level to high level to low level in the vessel? In other  
12 words, it is an on/off system? And if so -- well, is  
13 it?

14 MR. DALEY: It has two levels of speed control.

15 I guess you would call it three if you call stop, but  
16 I'm not aware that it actually cycles off if the water  
17 level goes --

18 MEMBER-AT-LARGE STETKAR: Well, it has got  
19 to have a high-level trip on it. I was just curious whether  
20 it was trying to control flow as a function of -- does  
21 it have a level control system or is it just an on/off  
22 level 8 to level, whatever it is, 1 or 2, or something  
23 like that?

24 MR. CHAPPELL: It's a simple control. I mean

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it maintains flow at approximately 800 gpm, and it will  
2 initiate a flow level and, then, high level --

3 MEMBER-AT-LARGE STETKAR: Once you get up  
4 to level 8, it will trip off and then it will come back  
5 on at level 1 or 2, or whatever the second one is?

6 MR. CHAPPELL: Correct.

7 MEMBER-AT-LARGE STETKAR: Do you have any  
8 idea how many times in an eight-hour period it might  
9 cycle on and off?

10 MR. CHAPPELL: I do not.

11 MEMBER-AT-LARGE STETKAR: That would be  
12 interesting to know that. That sort of gives the number  
13 of times that good governor system has to respond to  
14 the steam transient.

15 CHAIRMAN ABDEL-KHALIK: How would you go  
16 about getting that information?

17 MR. HEAD: Well, I am going to ask Bill  
18 Stillwell to step up and answer at least part of the  
19 question.

20 MEMBER-AT-LARGE STETKAR: I knew I would  
21 drive Bill up here.

22 (Laughter.)

23 MR. STILLWELL: Good morning. My name is  
24 Bill Stillwell. I'm the PRA Supervisor for STP 3 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 4.

2 I will talk about the operating experience  
3 a little bit. Shortly after I joined the STP 3 and 4  
4 project, we found out we were going to monoblock design.

5 Fortuitously, about six months prior, we had a site visit  
6 from the Koreans. They said, "If you ever need anything,  
7 let us know." So, when we found we were going to monoblock,  
8 I wrote them a letter and said, "Do you have any operating  
9 experience?"

10 We got a nice letter report back that gave  
11 us operating experience for two of the sites, two of  
12 the units. They said they didn't have enough operating  
13 experience to be comfortable giving us more data, but  
14 the indications were the failure rate for start is about  
15 the same, but it is limited to the two units. They had  
16 about eight years' worth of experience.

17 MEMBER-AT-LARGE STETKAR: So, it is still  
18 kind of --

19 MR. STILLWELL: They feel, based on what  
20 they are seeing at the other units, that it is going  
21 to trend out. It seems to be a more reliable design.

22 What they are seeing is the running failure rate is  
23 decreasing, and the maintenance unavailability is  
24 significantly different.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: Yes. The running  
2 failure rate makes a lot of sense with a simpler governor.

3 MR. STILLWELL: So, that is what we have  
4 for operating experience, and it is based on what I believe  
5 it is Kari gave back to us. That sort of an unofficial  
6 letter report. But if you want to look at it, we can --

7 MEMBER-AT-LARGE STETKAR: No, but if it is  
8 limited --

9 MR. STILLWELL: Yes, it is limited, and we  
10 have not updated since 2007.

11 MEMBER-AT-LARGE STETKAR: Anything on the  
12 number of cycles in a --

13 MR. STILLWELL: Number of cycles, it kind  
14 of depends on the number of SREs that are opening and  
15 what your decayed heat is --

16 MEMBER-AT-LARGE STETKAR: Yes, but, I mean,  
17 you've got to go boil water to figure it out.

18 MR. STILLWELL: You have to go boil the water  
19 and see what happens. I'm not sure that we have done  
20 that or that it was done as part of the original PRA.  
21 We have not done it yet.

22 MEMBER-AT-LARGE STETKAR: You haven't done  
23 it yet?

24 MR. HEAD: Have you got a follow-up question?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: Yes.

2 MR. HEAD: Okay.

3 MEMBER-AT-LARGE STETKAR: Someday he's got  
4 to figure it out for the PRA anyway.

5 MR. HEAD: Yes, but we will attempt at the  
6 next meeting to answer that question. The question is,  
7 during an eight-hour station blackout --

8 MEMBER-AT-LARGE STETKAR: Yes, as I  
9 understand it, the nominal design for it is to be able  
10 to handle an eight-hour station blackout.

11 MR. STILLWELL: Station blackout with no  
12 coolant.

13 MEMBER-AT-LARGE STETKAR: Yes. And as long  
14 as it is a cycle on/off design, I would be interested  
15 to know how many times during that eight-hour period --

16 MEMBER SIEBER: How many opportunities for  
17 failure?

18 MEMBER-AT-LARGE STETKAR: That's right. I  
19 mean, you know, the thing has got to start and stop,  
20 and the steam emission valve goes closed and comes back  
21 open again. It's got to work.

22 MR. CHAPPELL: There's a description in the  
23 technical report that talks about the design and the  
24 different flows that are required. The initial flow rate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 under gpm is set so that it would inject at that level,  
2 and then --

3 MEMBER-AT-LARGE STETKAR: Initially.

4 MR. CHAPPELL: -- it would reach level 8.

5 Then, it lowers to the lower flow, the 400 gpm, subsequently,  
6 to that, to match the decay heat. So, then, that would  
7 prevent it from just maximum injecting and cycling. It  
8 would lower flow rate to reduce the number of cycles.

9 MEMBER-AT-LARGE STETKAR: To reduce the  
10 number of cycles, but it should still -- it may cycle,  
11 if you are just controlling a fixed flow rate.

12 MR. HEAD: Out at 7 or 8 out there --

13 MEMBER-AT-LARGE STETKAR: Yes.

14 VICE CHAIRMAN ARMIJO: What are the backups?

15 I mean, this looks like a very simple, straightforward,  
16 less-complicated pump, but what's a backup if it failed  
17 or tripped on startup when you really needed it? I guess  
18 it is more of a system safety analysis question.

19 MR. DALEY: Well, the back-up valve, of  
20 course, we've got other -- assuming we are in a station  
21 blackout operation, the backup to that system would be  
22 the AC-independent water addition system, which uses  
23 the diesel-driven fire pump and attaches, and it is attached  
24 to the RHR system or low-pressure core flood system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, that would be the backup to this system.

2 VICE CHAIRMAN ARMIJO: But there is only  
3 one RCIC pump, right?

4 MR. DALEY: That's correct.

5 CHAIRMAN ABDEL-KHALIK: Mr. Eudy, did you  
6 want to make a comment?

7 MR. EUDY: Yes, just a recommendation for  
8 procedure. For follow-up items, if you all could help  
9 us differentiate who's got the ball, if it is going to  
10 be staff or --

11 CHAIRMAN ABDEL-KHALIK: I think, in this  
12 case --

13 MR. EUDY: Since last time, we were kind  
14 of, "Is that yours? Is that mine?" What are the  
15 expectations? I think that would help us.

16 CHAIRMAN ABDEL-KHALIK: All right.

17 MR. HEAD: So, we're all agreed this one  
18 is ours?

19 CHAIRMAN ABDEL-KHALIK: Yes, sir.

20 MR. HEAD: Okay. Thank you.

21 CHAIRMAN ABDEL-KHALIK: Please proceed.

22 MR. HEAD: Okay. Any other questions on the  
23 pump at this point?

24 (No response.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   Okay.

2                   MR. CHAPPELL: All right, in addition to  
3 the process cooling Tier 1 change, there are some other  
4 Tier 1 changes that are referenced in this section. Those  
5 are typically consistency changes, for example, and there  
6 is no intent to discuss those any further than what we  
7 have discussed at the last session.

8                   The departures that are presented in this  
9 chapter include some Tier 2 changes, which improve system  
10 performance or availability or correct some details or  
11 inconsistencies in the Tier 2 information.

12                   One of the departures that I want to mention  
13 is Standard Departure 5.4-5. This is an example of using  
14 ABWR and BWR operating experience in Japan. This is an  
15 additional vent line from the reactor water cleanup head  
16 spray that connects it to the vent line on the head.  
17 This prevents hydrogen accumulation in the line. The  
18 departure identified this concern and installed this  
19 additional line with some changes to the figure in Tier  
20 2.

21                   COL license information items in this chapter  
22 have been addressed. In general, we are going to establish  
23 ISI, PSI, IST programs. We also have identifications  
24 of ensuring that our reactor coolant pressure boundary

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 integrity is maintained by establishing tech specs and  
2 procedures that would allow operators to identify and  
3 take appropriate action for any known leakage.

4 We have information related to the vessel  
5 material that we have provided, starting approximately  
6 at the time when the vessel is onsite. We have information  
7 on fracture toughness, and then, this continues on through  
8 development of plant-specific pressure-temperature limit  
9 support, which will provide a methodology for curves.

10 Also included in this chapter is the analysis  
11 which we were just talking about for station blackout,  
12 which includes the two systems, RCIC and the backup,  
13 which is the AC-independent water addition supported  
14 by ADS.

15 ITAAC, impacts of ITAAC associated with this  
16 chapter are very minimal. For example, that of the RHR  
17 system for augmented fuel pool cooling. So, we added  
18 that requirement for that subsystem.

19 CHAIRMAN ABDEL-KHALIK: Before we go a little  
20 too far, I had a question about the lead factor for the  
21 surveillance.

22 MR. CHAPPELL: Yes.

23 CHAIRMAN ABDEL-KHALIK: In one section of  
24 your Chapter 5, you say that the lead factor is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approximately somewhere -- it was changed from 1.2 to  
2 a range of 1 to 1.5.

3 MR. CHAPPELL: That is correct.

4 CHAIRMAN ABDEL-KHALIK: And in another  
5 section, you specify that it is exactly 1.1.

6 MR. CHAPPELL: I believe it says  
7 approximately.

8 CHAIRMAN ABDEL-KHALIK: Right. So, I guess  
9 you feel that these two statements are consistent in  
10 a sense that 1.1 is bounded by the range that you give  
11 in the earlier statement that it is between 1 and 1.5?

12 MR. CHAPPELL: When we responded to an RAI,  
13 the change in the range from -- it initially said 1.0  
14 to 1.5. We responded and clarified that it needed to  
15 be above 1, was the requirement. So, we have the range  
16 is above 1 to approximately 1.5. That is the range.  
17 Then, setting the approximate value at 1.1 is consistent  
18 with that range and is closer to that lower end.

19 CHAIRMAN ABDEL-KHALIK: Okay. Thank you.

20 MEMBER BROWN: Before you leave that, under  
21 the testing of main steam isolation valves, you had noted  
22 that you were testing, before you concur in your initial  
23 test program, under operating conditions. Here's my  
24 question: I have looked, didn't really find, was there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 periodic testing done on these subsequent to this initial  
2 test program?

3 MR. CHAPPELL: Those are isolation valves,  
4 so they will fall under the isolation testing program.

5 MEMBER BROWN: Is there a periodicity with  
6 that?

7 MR. CHAPPELL: Yes.

8 MEMBER BROWN: I mean failure on surveillance  
9 testing and everything else, there's a whole list of  
10 things that are done periodically. I just never did find  
11 the one on main steam isolation.

12 MR. CHAPPELL: Those would be covered under  
13 surveillance, tech spec surveillance and IST testing.

14 MEMBER BROWN: Okay, but I didn't find it.  
15 Do you know, is that a five-year period? Is that a  
16 one-year? Is it 92 days? All these numbers that get  
17 thrown around over surveillance, what is this one for  
18 the isolation valves?

19 MR. CHAPPELL: I understand you question.  
20 I don't have the specific periodicity.

21 MEMBER BROWN: Okay. I mean, if somebody  
22 saw that one, I missed it. I was unable to find the  
23 periodicity on that one. I looked.

24 MR. HEAD: We will take that as a followup

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and maybe, by that Chapter 16 discussion of the tech  
2 specs, we might --

3 MEMBER BROWN: Okay. Yes, that's where I  
4 was looking.

5 MR. HEAD: We might not be able to answer  
6 that one.

7 MR. CHAPPELL: But, generally, to address  
8 the concern, there's testing, an initial test program.  
9 There's also an ITAAC associated with this.

10 MEMBER BROWN: Yes, I understand that part  
11 of it.

12 MR. CHAPPELL: Of course, we will continue  
13 to test it.

14 CHAIRMAN ABDEL-KHALIK: Now, also, in the  
15 materials in the surveillance capsule section, you  
16 indicate that the vessel end-of-life neutron fluence  
17 is approximately 5 times 10 to the 17th. Where does this  
18 number come from? And what are the underlying assumptions  
19 for that number, given the fact that the third capsule  
20 is supposed to be taken out after a fluence not to exceed  
21 5 times 10 to the 17th?

22 This is on your page 5.3-5 of the FSAR.

23 MR. CHAPPELL: Yes, I'm looking at the  
24 capsule program now. I don't have the basis for it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I also understand the same numbers that you have, that  
2 you are looking at, and I think we have to probably take  
3 that as a follow-up item, to understand the basis for  
4 the fluence.

5 CHAIRMAN ABDEL-KHALIK: Right. I guess I  
6 understand that sometime down the road you may be applying  
7 for a power uprate or that you feel design will be different.  
8 The question is, when you say, "approximately," what  
9 does that mean? What's the error bar associated with  
10 that? Where do these numbers come from?

11 VICE CHAIRMAN ARMIJO: Yes, also, in  
12 calculating these fluences and also the  
13 pressure-temperature limits that you calculate, these  
14 are based on a GE7 core. So, when you get your real core  
15 that you are going to put into this plant, will you do  
16 all that over again, come up with new P-T limits --

17 MR. HEAD: Yes, sir.

18 VICE CHAIRMAN ARMIJO: -- and new fluence --

19 MR. HEAD: That will have to all be considered  
20 as the impact on that.

21 VICE CHAIRMAN ARMIJO: So, would there be  
22 some sort of an amendment that is provided to the staff?

23 I just don't know how this --

24 MR. HEAD: If that needs to be changed, then

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that would be a part of the amendment, that it comes  
2 with the fuel or the uprate.

3 VICE CHAIRMAN ARMIJO: Everything that is  
4 affected by the fuel change will be an amendment, including  
5 things like P-T limits, vessel fluence, as well as --

6 MR. HEAD: Yes, if they are impacted either  
7 by that or the stuff that needs to be amended or needs  
8 an NRC approval, okay, would be covered by an amendment.  
9 Anything else, obviously, would be a 50.59, and I think  
10 between the fuel and the uprate, the NRC would be approving,  
11 reviewing and approving what was appropriate to those  
12 two changes.

13 VICE CHAIRMAN ARMIJO: So, maybe I should  
14 ask the staff. Do you expect to receive an amendment  
15 with all these, either confirming that the original numbers  
16 were bounding or telling you what the new numbers are  
17 going to be?

18 MR. DOWNEY: Yes, and their original fluence  
19 values, which they submitted with their  
20 pressure-temperature limit report, they actually provided  
21 a calculation note. That is reviewed by the Reactor  
22 Systems folks.

23 But what will happen after the  
24 pressure-temperature limit report has gone through its

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review, and say some change happens that affects the  
2 fluence values or the ductility reference temperatures,  
3 or any of those inputs. Then, as long as the methodology  
4 doesn't change, they would still have to update all of  
5 their values and update all of their pressure-temperature  
6 limit curves and everything that is affected. That will  
7 come to the staff.

8 MS. BANERJEE: Identify your name, please.

9 MR. DOWNEY: I'm Steven Downey.

10 MS. BANERJEE: Thank you.

11 MR. HEAD: Yes, the PTLR does allow us more  
12 control and allow us to make the changes ourselves, and  
13 then inform NRC of those changes. As long as we stay  
14 within that methodology, that approach would be available  
15 to us.

16 CHAIRMAN ABDEL-KHALIK: But you will follow  
17 up and let us know where this number came from, what  
18 the underlying assumptions were for that number?

19 MR. HEAD: Yes, sir. We have a followup on  
20 the basis for the fluence number and I guess maybe the  
21 error bounds associated with it. I won't predict whether  
22 we can answer that by the tech spec discussion later  
23 today, but we will certainly give it a try.

24 CHAIRMAN ABDEL-KHALIK: All right. Thanks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. RAY: Excuse me. If I may add some little  
2 more, I am Neil Ray with the NRC.

3 What happens in this case is, as several  
4 folks mentioned about PTLR, PTLR was allowed by Generic  
5 Letter 96.3. What happens is, instead of licenses every  
6 time change the limits, NRC allowed them, that you guys  
7 don't have to change the particulars and come to us for  
8 approval, as long as you go through the PTLR process.

9 The process has to be approved by NRC staff,  
10 and that process is quite detailed. For example, it  
11 includes the fluence calculation. It includes  
12 pressure-temperature limits, materializing approval.  
13 It includes, in the PWR case, it includes the PTS  
14 calculation. It includes a partial energy calc, all kinds  
15 of things.

16 They have to commit that every time they  
17 use this, withdraw a risk capsule, they have to obtain  
18 their P-T limits and inform NRC. Inform the NRC; it is  
19 not an approval again.

20 So, that is the process STP has accepted.

21 So, they submitted the PTLR to us, and we are currently  
22 in the review process.

23 CHAIRMAN ABDEL-KHALIK: Okay. Thank you.

24 If you go back to the previous slide, I just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had, actually, maybe even farther back, slide No. 6,  
2 I sort of have a generic concern reading through all  
3 your documents about the system of units you are using  
4 throughout.

5 So, in this case, for example, you are talking  
6 about megapascal gauge. The question is, are you using  
7 a consistent set of units in all your documents that  
8 is also the same units that will be used in control room  
9 instrumentation that is used in your operating training?

10 It seems to me that I'm not sure what your  
11 current units training does, but I would imagine the  
12 people are sort of used to using British units, and the  
13 instrumentation is probably British units. My experience  
14 over the past four years is that one place where people  
15 make big mistakes is in units.

16 So, could you address this issue? What sort  
17 of system of units are you using throughout for this  
18 particular application? Is it consistent with what you  
19 are using at the other units?

20 MR. DALEY: Yes, we are using English units,  
21 both in the engineering and the construction and the  
22 operation of the units.

23 CHAIRMAN ABDEL-KHALIK: But that is not what  
24 your tech specs are written as? You know, that is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the system of units that your tech specs use. I mean  
2 you refer to things in liters per minute or cubic meters  
3 per hour. To me, that is one potential source of big  
4 mistakes.

5 MR. HEAD: We'll answer the tech spec  
6 question when we have Chapter 16. Okay?

7 CHAIRMAN ABDEL-KHALIK: Okay, but how about  
8 answering the general question as to whether or not you  
9 have a consistent system of units that you are using  
10 in your documentation, in your control room  
11 instrumentation, in your training, et cetera? When did  
12 you address that question?

13 MR. DITTMAN: I'll address it.

14 CHAIRMAN ABDEL-KHALIK: Yes, sir.

15 MR. DITTMAN: This is Kyle Dittman. I'm  
16 Supervisor on I&C Design at STP.

17 The DCD or the COLA is in metric, but for  
18 controlling design and for operator training, and all  
19 that stuff, we are converting over to English units.  
20 So, we will be converting to a consistent use of English  
21 units. The DCD, we are converting that over, too. That  
22 will be converted over to English units.

23 CHAIRMAN ABDEL-KHALIK: So, how will that  
24 be reflected in your various chapters of the FSAR? Because,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 currently, they are not in British units.

2 MR. CHAPPELL: That would be a 50.59-like  
3 change to include information that would update. Rather  
4 than do it now, we would make those consistency changes  
5 following COL. Currently, we have engineering documents  
6 that provide units in SI as well as English.

7 MEMBER BROWN: That is really an interesting  
8 one because I have to bring this up, because I watched  
9 the plant manufacturing stuff, and they ended up with  
10 drawings which had SI units on it. The actual requirements  
11 that they had to torque bolts to were English. They were  
12 side-by-side. The guys used the wrong one, and every  
13 bearing got white when they turned on the machine. I  
14 mean it just ground to a massive halt, created about  
15 a two-year delay.

16 I totally missed that. That is just beyond  
17 my belief that you would have mixed units in the various  
18 documents, and that you would keep it that way.

19 CHAIRMAN ABDEL-KHALIK: Is the staff at all  
20 concerned about this issue?

21 MR. CHAPPELL: Well, we are not keeping it  
22 that way.

23 MEMBER BROWN: I mean it just seems like  
24 it drags out. I mean it is going to be a while before

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you get to conversion.

2 But I'm sorry to interrupt. Go ahead.

3 MR. CHAPPELL: No problem, no problem.

4 MR. WUNDER: We are now, yes, definitely  
5 yes.

6 (Laughter.)

7 CHAIRMAN ABDEL-KHALIK: So, I guess you  
8 indicate that you will handle this through a 50.59-type  
9 process to convert completely into British units? Is  
10 this sort of outside the scope of this review then?

11 MR. CHAPPELL: Well, we were talking about,  
12 as far as the FSAR is concerned, that is what that addresses.

13 As far as the high-level engineering documents that would  
14 contain certain values, right now I don't think that  
15 we have one set of numbers for one particular system  
16 in those high-level engineering documents. But when the  
17 specific procedures are developed, then we will certainly  
18 take into consideration the concern that the person doing  
19 the action has one clear path forward and clear instruction.

20 So, that is a very important point to remember moving  
21 forward.

22 CHAIRMAN ABDEL-KHALIK: I think it would  
23 be a good idea to have a followup as to how you are going  
24 to address this concern in a general sense.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER SIEBER: It actually has to go a lot  
2 deeper than just the documents, your licensing documents.

3           It has to go to every document, manufacturing, operations,  
4 maintenance. There's tons of opportunities to make  
5 mistakes.

6           CHAIRMAN ABDEL-KHALIK: Yes. I think, as  
7 I said, over the past 40 years, the majority of the big  
8 problems I have seen are units-related. So, let's try  
9 to get this straight.

10          MR. HEAD: Okay. We will present this as  
11 a topic in more detail at the next ACRS briefing.

12          CHAIRMAN ABDEL-KHALIK: Thank you.

13          MR. EUDY: Staff will do the same.

14          CHAIRMAN ABDEL-KHALIK: Thank you.

15          So, please proceed. Sorry to interrupt.

16          MR. CHAPPELL: No problem.

17          So, I am back to the slide that discusses  
18 ITAAC, the changes to the ITAAC, simplification of RCIC.

19          Also, we have the additional loop of RHR that provides  
20 the cooling. There are a number of other ITAAC that are  
21 associated with reactor coolant pressure boundary, but  
22 there were no changes to those. Those include, for example,  
23 the recirc system and the reactor water cleanup system,  
24 but there were no changes to those.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: Coley, just a  
2 point of information, I have to admit to not doing all  
3 of the homework I should have done. You mentioned an  
4 additional loop of RHR that provides cooling. It is not  
5 a whole new RHR loop, is it? Or is it?

6 MR. CHAPPELL: It is an additional loop of  
7 RHR that is providing supplemental or augmented fuel  
8 for cooling. The DCD design had only two.

9 MEMBER-AT-LARGE STETKAR: Thank you.

10 MR. CHAPPELL: We have added a third for  
11 maintenance flexibility.

12 MEMBER-AT-LARGE STETKAR: Thank you.  
13 Thanks. That's all I need.

14 MR. CHAPPELL: Thank you.

15 MEMBER-AT-LARGE STETKAR: I misunderstood  
16 what I had read. So, thanks.

17 MEMBER SIEBER: There's some of that in other  
18 areas, too.

19 MR. CHAPPELL: No, there is not an additional  
20 loop. It is just an additional mode for one of the three  
21 existing loops.

22 MEMBER-AT-LARGE STETKAR: Okay, that is what  
23 I understood, that originally, if I looked at the DCD,  
24 I could count three RHR pumps, and there were two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 connections --

2 MR. CHAPPELL: Right.

3 MEMBER-AT-LARGE STETKAR: -- for this  
4 auxiliary cooling. Now there are three connections?

5 MR. CHAPPELL: Three connections.

6 MEMBER-AT-LARGE STETKAR: Okay.

7 MR. CHAPPELL: Yes.

8 MEMBER-AT-LARGE STETKAR: Thanks.

9 MR. CHAPPELL: Right.

10 MEMBER-AT-LARGE STETKAR: So, it is not a  
11 new RHR loop? It is an additional connection to an existing  
12 RHR loop?

13 MR. CHAPPELL: It is not a new RHR train.

14 MEMBER-AT-LARGE STETKAR: Okay.

15 MR. HEAD: It is just hooking up the third --

16 MEMBER-AT-LARGE STETKAR: It's hooking up  
17 the third one for this cooling? That's what I thought  
18 I understood, but I had seen it kind of presented as  
19 a new RHR loop, and you talked about it that way.

20 MR. HEAD: "Loop" is the wrong --

21 MEMBER-AT-LARGE STETKAR: Never mind.  
22 Thanks. Okay.

23 MR. CHAPPELL: That covers the material for  
24 Chapter 5 that we want to look at.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: All right. At this  
2 time, we can move to the staff's presentation on Chapter  
3 5.

4 I understand that the Chapter 5 presentation  
5 has a closed part to it?

6 MR. EUDY: We have the availability of it.  
7 The staff does not have a presentation that contains  
8 anything proprietary.

9 CHAIRMAN ABDEL-KHALIK: Okay.

10 MR. EUDY: But if something does come up,  
11 we will rely on South Texas to let us know, or someone  
12 else, that we should move that to a closed session, if  
13 needed.

14 CHAIRMAN ABDEL-KHALIK: All right.

15 MR. HEAD: We will monitor that, but we had  
16 nothing proprietary in ours, and we weren't expecting  
17 to, either.

18 CHAIRMAN ABDEL-KHALIK: Okay.

19 MR. EUDY: Yes, we don't have anything in  
20 ours. They looked at ours and made sure that we didn't  
21 have anything proprietary in our presentation, which  
22 we don't.

23 CHAIRMAN ABDEL-KHALIK: Okay. Please  
24 proceed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. EUDY: Okay. We will now begin the  
2 staff's presentation of the review of South Texas  
3 application with respect to Chapter 5.

4 We have several technical staff involved  
5 for the presentation today. I'm the Project Manager,  
6 Michael Eudy, and we will have Steve Downey, Tim Steingass,  
7 and Tom Scarbrough go through the various technical topics  
8 of interest, which there are several that I will briefly  
9 go through.

10 We are going to talk about reactor vessel  
11 materials. There were COL information items necessary  
12 for that.

13 We will go through the P-T limits information.

14 There is an open item on the P-T limits curve. Pre-service  
15 inspection, pre-service and in-service inspection, we  
16 had some standard departures that affected that.

17 Reactor coolant pressure, boundary leakage,  
18 we have a COL information item and a departure with an  
19 open item, and we have updates to codes and standards  
20 and updates to code cases we will discuss.

21 And finally, we will to into the RCIC turbine  
22 design change, which is a standard departure that has  
23 some other open items that we will discuss.

24 Again, there is nothing proprietary in our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation. If we do have something, we will note that  
2 for the closed session.

3 I will turn it over to Steve Downey.

4 MR. DOWNEY: Good morning, Mr. Chairman and  
5 Committee members. I'm Steven Downey. I'm a Materials  
6 Engineer on staff with the Office of New Reactors, Division  
7 of Engineering, Component Integrity Performance and  
8 Testing Branch 2.

9 I will be discussing the first three topics,  
10 which are fracture toughness data, materials and  
11 surveillance capsule, and the pressure-temperature limits.  
12 They go in COL information item order.

13 Now ABWR CDC COL Information Item 5.4 states  
14 that the fracture toughness data based on limiting reactor  
15 vessel materials will be provided by the COL applicant.

16 As the applicant stated, they responded that the fracture  
17 toughness data will be provided in an update to the FSAR  
18 one year after the receipt of the reactor vessel.

19 The staff finds that this is acceptable  
20 because it provides a reasonable assurance that the  
21 requirements of Appendix G to 10 CFR Part 10 will be  
22 met, and it provides the staff ample time to review the  
23 fracture toughness data prior to fuel load, just in case  
24 any issues may arise.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Next, with regard to the Materials and  
2           Surveillance Capsule Program, DCD COL Item 5.5 states  
3           that the COL applicant will identify the specific materials  
4           in each capsule, the capsule lead factors, the withdrawal  
5           schedule of each capsule, the neutron fluence received  
6           by each capsule at the time of its withdrawal, and the  
7           vessel end-of-life fluence.

8           To address the COL item, the applicant  
9           provided the information to meet those five topic areas  
10          in Section 5.3.4.2 of the FSAR. Also, in response to  
11          some RAIs related to the section, the applicant provided  
12          their complete reactor vessel surveillance program in  
13          a topical report, which they discussed in their  
14          presentation. And also, in FSAR table 13.4-201, the  
15          applicant provided the implementation milestone of the  
16          reactor vessel surveillance program, which will be  
17          implemented prior to fuel load.

18          Based on the staff's review of all the  
19          information provided by the applicant, the staff found  
20          that the reactor vessel surveillance program was in  
21          accordance with ASTM-E185, the 1982 revision, and it  
22          is also fully described, the reactor vessel surveillance  
23          program is fully described in accordance with SECY 05-0197.

24          And the resolution of being in accordance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with these two, the surveillance program is in accordance  
2 with, meets the requirements of 10 CFR Part 50, Appendix  
3 H.

4 Next slide.

5 Now ABWR DCD COL Item 5.6 states that the  
6 COL applicant will submit plant-specific  
7 pressure-temperature limit curves, and to meet the  
8 requirements of 10 CFR, Appendix G, related to  
9 pressure-temperature limits, the applicant has decided  
10 to submit a pressure and temperature limits report,  
11 following the guidelines of Generic Letter 96-03, which  
12 provides seven technical criteria to be addressed in  
13 order to submit the pressure-temperature limits and the  
14 full methodology for their development.

15 The staff is currently evaluating the  
16 pressure-temperature limit report. We have been in  
17 constant contact with the applicant. We have submitted  
18 several RAIs related to the report, which, of course,  
19 the review isn't complete. That is why it is identified  
20 as an open item at this point.

21 Any questions?

22 (No response.)

23 MR. EUDY: Okay, we will ask Tim Steingass  
24 to come up and present the next couple of slides.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STEINGASS: Good morning, everyone. My  
2 name is Tim Steingass. I'm the Lead Technical Reviewer  
3 for PSI and ISI Operational Programs. I'm a Materials  
4 Engineer in the Materials and Chemical Engineering  
5 Performance Testing Branch 2.

6 We will be talking about Section 5.2.4,  
7 Pre-Service and In-Service Inspection and Testing of  
8 the Reactor Coolant Pressure Boundary.

9 Section 5.2.4 addresses PSI and ISI of Class  
10 1 components in the pressure testing boundary. The first  
11 departure that we looked at involved the design, the  
12 transfer from a GE design over to Toshiba.

13 The STD DEP vendor PSI/ISI program is based  
14 on ASME Section XI requirements, with Toshiba responsible  
15 for the RPV design accessibility to perform PSI and ISI  
16 examinations.

17 The COL applicant, however, was responsible  
18 for the remaining components, design accessibility, to  
19 perform PSI and ISI examinations. From this perspective,  
20 we found this acceptable because, in order for the plant  
21 to be robust during operation and find any issues that  
22 may evolve due to failure mechanisms, the design of the  
23 plant that preserves accessibility to enable the  
24 performance of ISI is the appropriate measure to take.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Therefore, the staff concluded that the  
2 design responsibilities meet ASME Section XI requirements  
3 for PSI and ISI examinations and were clearly designated.

4                   VICE CHAIRMAN ARMIJO: When you say, "RPV  
5 design accessibility," I just read it that you mean RPV  
6 and internals and all the things that Toshiba would normally  
7 design?

8                   MR. STEINGASS: Correct.

9                   VICE CHAIRMAN ARMIJO: So, that is really  
10 their scope, to do that?

11                  MR. STEINGASS: It is Toshiba's scope to  
12 design the vessel for accessibility.

13                  To jump back to the DCD, the ABWR DCD was,  
14 of course, one of the first ones we have looked at and  
15 certified. The issue here involved the staff only approved  
16 the design of the RPV. It did not approve the design  
17 for the remainder of the Class 1, 2, and 3 components.

18                  So, therefore, when we looked at the ISI and the PSI  
19 programs, we had to look at the design for the remainder  
20 of the DCD as it applied to Class 1, 2, and 3 with the  
21 vessel already certified.

22                  So, the DCD mix expressly states that  
23 accessibility will be maintained by Toshiba, and the  
24 accessibility and all the other components of an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operational program under a PSI and ISI environment will  
2 be maintained by the COL applicant.

3 VICE CHAIRMAN ARMIJO: I don't see how they  
4 can do it for the vessel internals and the other things  
5 you have to inspect.

6 MR. STEINGASS: I'm sorry, I didn't hear  
7 the question, the comment.

8 VICE CHAIRMAN ARMIJO: You know, I just don't  
9 understand. I may just be belaboring it, but the core  
10 internals, all of those components that have to be inspected  
11 periodically, the only people who can really control  
12 the design of that are the people who design the vessel  
13 and the reactor. I don't think STP does that.

14 MR. STEINGASS: I said that the  
15 responsibility for the design and the accessibility to  
16 enable the inspections is controlled by Toshiba.

17 VICE CHAIRMAN ARMIJO: Okay. Then I  
18 misunderstood.

19 MR. RAY: Excuse me. This is Neil Ray.

20 Let me clarify. I think what you are asking  
21 and his giving an answer is slightly different.

22 VICE CHAIRMAN ARMIJO: I guess I'm asking  
23 an engineering question.

24 MR. RAY: Yes. No, no, no. I understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 your question and he understands also.

2 What Tim says is, when you are talking  
3 accessibility of the vessel, we are talking about vessel  
4 inspection only. We are not talking about vessel internals.  
5 That is the difference here.

6 VICE CHAIRMAN ARMIJO: Okay.

7 MR. STEINGASS: Sorry about that.

8 VICE CHAIRMAN ARMIJO: That's okay.

9 MR. STEINGASS: That was from another project  
10 manager.

11 Let's see, continuing on, STD DEP 52-2,  
12 Examination Categories. Next slide, please.

13 The FSAR stated that pre-service inspection  
14 would extend to 100 percent of the Class 1  
15 pressure-retaining wells and 100 percent of the Category  
16 B-0 control rod drive housing welds, if it was incorporated  
17 into the design. In addition, the departure states that  
18 evaluations will be performed to assure accessibility  
19 to perform the ISI examinations.

20 The staff concluded that the departures met  
21 the requirements of Section XI and accessibility to perform  
22 the ISI examinations and were, therefore, accessible.

23 MEMBER SIEBER: But that just applies to  
24 the pressure boundary?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STEINGASS: Say it again?

2 MEMBER SIEBER: That just applies to the  
3 pressure boundary?

4 MR. STEINGASS: That is correct.

5 MEMBER SIEBER: Not the core internals or  
6 anything like that? Okay.

7 MR. STEINGASS: Correct.

8 STD Departure 5A-1, Ultrasonic Examination  
9 of the RPV. The FSAR stated that the ultrasonic system  
10 for examination of the RPV would meet the requirements  
11 of ASME Appendix VII and VIII for qualification of personnel  
12 and equipment demonstration. The staff concluded that  
13 this departure met the requirements of ASME Section XI  
14 and 10 CFR 50 as acceptable. As you recall, the more  
15 recent version of 10 CFR 50 superseded the use of NUREG  
16 1.150, and Appendix VII and VIII take care of that  
17 requirement.

18 Next slide.

19 Finally, there were no open items.

20 In the need to make things go a little bit  
21 quicker, I am going to pick up this one, Reactor Coolant  
22 Pressure Boundary Leakage Detection, Section 5.2.5.

23 Before I get going, are there any other  
24 questions on 5.2.4 for the Committee?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (No response.)

2 Okay. The reactor coolant pressure boundary  
3 leakage detection systems are designed to detect and,  
4 to the extent practical, identify the source of reactor  
5 coolant leakage. COL Information Item Conversion of  
6 Indicators is written to develop the surveillance  
7 procedures prior to fuel load to direct operators to  
8 convert instrument indicators to a common leakage  
9 equivalent.

10 Departure 7.3-12, Leak Detection and  
11 Isolation System Sump Monitoring, changes the  
12 unidentified leakage tech spec limit from 1 gallon per  
13 minute to 5 gallons per minute.

14 CHAIRMAN ABDEL-KHALIK: Could you give us  
15 the rationale for this change?

16 MR. STEINGASS: Do we have the technical  
17 reviewer here?

18 CHAIRMAN ABDEL-KHALIK: We can start with  
19 STP.

20 MR. STEINGASS: This is the way we decided  
21 to do it.

22 CHAIRMAN ABDEL-KHALIK: Okay.

23 MR. STEINGASS: Go ahead.

24 CHAIRMAN ABDEL-KHALIK: Please use the other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 microphone.

2 MR. LI: My name is Chang Li. I'm the  
3 Technical Reviewer for Section 5.2.5, Reactor Coolant  
4 Pressure Boundary Leakage Detection.

5 I understand the question that you just asked  
6 is the reason why this changed from 1 gpm to 5 gpm leakage  
7 detection criteria. As a reviewer, I think this change  
8 is determined by the applicants. As a reviewer, we review,  
9 when that is changed, whether that is acceptable or not.

10 So, as to why did they changed it, I think  
11 the applicant should address it. On why it is acceptable,  
12 I should address that.

13 CHAIRMAN ABDEL-KHALIK: While you are at  
14 the microphone, why is it acceptable?

15 MR. LI: I think, according to our criterias  
16 in terms of sensitivities, we have a Reg Guide that is  
17 talking about sensitivity of 1 gpm. Actually, on the  
18 tech spec limit of unidentified leakage, 5 gpm, that  
19 was established, I think, in BWR System Standard Tech  
20 Spec for all the BWR systems. I don't know why ABWR,  
21 when they do design certification, they have a criteria  
22 more stringent down to 1 gpm per gallon within an hour,  
23 which is the criteria used for PWR. But the BWR was 5  
24 gpm all the time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, in the design certification stage, they  
2           made that more stringent criteria. Certainly, we found  
3           it acceptable. Now, when they make this departure, change  
4           it to less stringent criteria, we have RAIs, ask questions.

5           I believe the question that they pointed out as our  
6           acceptable, sensitivity criteria, with respect to Reg  
7           Guide 1.4.5, we have that 1 gpm in terms of sensitivities.

8           So, their instrument is able to detect 1 gpm sensitivities,  
9           as they claim to.

10           But, as far as the tech spec, the Reg Guide  
11           doesn't have a criteria to specify. BWR operating  
12           experience, they indicate that the 5 gpm is more practical  
13           for them.

14           I had an extensive discussion when I did  
15           the review in the ESBWR because, at that point, it is  
16           the first time when I am looking from ABWR down to ESBWR,  
17           they changed to 5 gpm. Well, how come? So, you will  
18           be able to make it the 1 gpm, just like all the PWRs,  
19           and they changed to 5. So, we had a very extensive  
20           discussion at the ESBWR review stage.

21           Here, they are taking the same approach,  
22           the applicants, changing it from 1 gpm to the more relaxed  
23           of 5 gpm, which is all the BWR tech spec has.

24           CHAIRMAN ABDEL-KHALIK: Okay. Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Just a side question. The FSAR says that  
2 the limit is 19 liters per minute. So, when you did your  
3 review, did you have to pull out your conversion table  
4 to see whether or not this is reasonable? Or, you just  
5 knew right away that it was 5 gpm?

6           MR. LI: About 5 gpm, that was, I think,  
7 being used for all the BWRs in the tech spec.

8           CHAIRMAN ABDEL-KHALIK: Okay. That is not  
9 the question. So, let's just hear from the applicant  
10 as to the rationale for this change, given the fact that  
11 people are moving in the opposite direction, by and large.

12           MR. CHAPPELL: This departure took DCD limits  
13 that were based on another method for a leak 4 break,  
14 which is not an option, that STP 3 and 4 is using,  
15 implementing. So, we went with a more -- this is more  
16 in line with current operating experience, to make the  
17 unidentified leakage limit from 1 gpm to 5 gpm.  
18 Considering that 1 gpm is at the limit, that that is  
19 the requirement for the analysis, then, that provides  
20 a more reasonable input value to our tech spec limit.

21           CHAIRMAN ABDEL-KHALIK: Could you repeat  
22 that, please?

23           MR. CHAPPELL: I think we may have someone  
24 who wants to add to this.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. CASHELL: Good morning. My name is Steve  
2 Cashell, and I'm the Tech Spec Licensing Engineering.

3 We used IGSCC or non-IGSCC components. A  
4 lot of us went to great lengths to remove any precursors  
5 for IGSCC, because we knew we wanted these particular  
6 limits in our specifications. The BWRs all have gone  
7 to these limits, and so has the ESBWR for ease of operation.

8 And as Coley said, GE had put this in as  
9 an option, if we were to choose the leak-before-break  
10 option, to allow other benefits. We chose not to employ  
11 the leak-before-break option. If you go way back into  
12 history, if the leak-before-break option is not chosen,  
13 then these limits are apparently satisfactory.

14 CHAIRMAN ABDEL-KHALIK: Please proceed.

15 MR. STEINGASS: Okay.

16 CHAIRMAN ABDEL-KHALIK: Thanks.

17 MR. STEINGASS: To continue on with Departure  
18 7.3-12, we just briefly went over the 1-to-5 gallon per  
19 minute change. Then, there was a change of the total  
20 leakage limit over 24 hours from 25 gpm to 30 gpm. In  
21 addition to that, there was an addition of an alarm limit  
22 to 2 gpm within a four-hour period to provide early warning  
23 prior to the tech spec limit. And finally, to develop  
24 procedures prior to fuel load to respond to prolonged

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 low-level RCS leakage.

2 As a result of this change, there is an open  
3 item for the applicant to submit a commitment to complete  
4 the above procedures and make those procedures available  
5 prior to fuel load.

6 CHAIRMAN ABDEL-KHALIK: The 30 gpm for both  
7 unidentified and identified leakage is a big leak. The  
8 question is, how does that compare with current tech  
9 specs for operating BWRs?

10 MR. CHAPPELL: It's consistent.

11 CHAIRMAN ABDEL-KHALIK: It's consistent?

12 VICE CHAIRMAN ARMIJO: What about the  
13 operating ABWRs in Japan? What is their tech spec for  
14 unidentified leakage?

15 MR. CHAPPELL: Steve may want to address  
16 the generic. It is not a direct reference to Japanese  
17 tech specs. I will turn it over to Steve to address that  
18 question.

19 MR. CASHELL: This is Steve again.

20 I do not know the Japanese limit. However,  
21 I know that the BWRs today are, every one is much more  
22 sensitive to leakage. A typical leakage of 4 gallons  
23 per minute, for instance, total leakage increases rapidly.  
24 Today the philosophy is find out what it is; shut down,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if you have to, and find out what it is quickly. No one  
2 today approaches the 30 gpm limit.

3 It's the 5 gpm unidentified that is the more  
4 difficult limit. The 30 gpm is easy to live within.  
5 It is the rapid increase. That is why we added the alarm  
6 of 2 gpm increase over the previous four hours. In other  
7 words, if we see something change rapidly, we get the  
8 alarm, and the typical action likely, if you get it,  
9 will be to shut down, even though that requirement is  
10 not there yet.

11 VICE CHAIRMAN ARMIJO: Yes, but the logic  
12 is kind of funny because you are implementing improved  
13 materials with very good fabrication practices, with  
14 hydrogen water chemistry to protect against IGSCC, but  
15 you allow more leakage, implying that as long as the  
16 leakage isn't from cracks in the pipes, we really don't  
17 care. So, it can leak from seals or some other.

18 You know, it may be the answer was 1 gpm  
19 is just not really tolerable; it's not practical. It  
20 is --

21 MR. CASHELL: That is the most restrictive,  
22 yes. That is the difficult limit.

23 VICE CHAIRMAN ARMIJO: Yes. If it is  
24 basically impractical to do it at 1 gpm, I could see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a logic to saying 5 gpm, but we are not really worried  
2 about the pipe cracking or pressure vessel leakage. But  
3 it just seems strange that it would be you would increase  
4 that tech spec limit, especially if you can find out  
5 from Toshiba what the K6 and K7 tech spec limits are,  
6 and if the Japanese meet 1 gpm, why can't we?

7 MR. HEAD: I want to mirror what Steve has  
8 said. These are tech spec limits. There's a significant  
9 difference between unidentified leakage and total leakage  
10 with respect to public health and safety.

11 From the operating experience, you know,  
12 leakage is something we react to, almost regardless of  
13 the limits. Those tech spec limits require certain  
14 significant actions for the plant. Long before that point  
15 in time, the station is reacting to it.

16 So, for us as a first-time evolution on this,  
17 using current industry limits we felt like is appropriate.

18 Starting off with tech specs that are not in that condition  
19 would be I don't think appropriate at this point.

20 CHAIRMAN ABDEL-KHALIK: But the question  
21 is -- there are two questions that came up. Is the 1  
22 gpm consistent or inconsistent with the sensitivity of  
23 your detection method?

24 MR. HEAD: Steve, just stay up there for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a while, would you?

2 (Laughter.)

3 MR. CASHELL: This is Steve again.

4 The major difference between the PWR and  
5 the BWR is it is very easy to collect your unidentified  
6 or a leakage in a PWR; whereas, for a BWR, it is a convoluted  
7 process where the water drains down and has to drain.

8 So, collecting the 1 gpm to measure it is the problem  
9 for BWRs. That is why this, the 5 and 30 gpm, became  
10 the standard for BWRs. Instruments can detect it if you  
11 can collect it properly.

12 CHAIRMAN ABDEL-KHALIK: And the second  
13 question was, well, what are the tech spec limits for  
14 the Japanese plants? And have they been able to live  
15 within the 1 gpm constraint?

16 MR. HEAD: Okay. We will have to keep that  
17 as an open item because we don't have that answer today.

18 CHAIRMAN ABDEL-KHALIK: Okay. All right.  
19 Thank you.

20 Please proceed.

21 MR. STEINGASS: I have no more items with  
22 regard to 5.2.5. Unless there are any additional questions,  
23 I will turn it over to Tom Scarbrough.

24 CHAIRMAN ABDEL-KHALIK: Okay, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCARBROUGH: Tom Scarbrough in the  
2 Component Integrity Branch.

3 I'm going to talk about several sections.  
4 The first one is Section 5.2.1.1, and its compliance  
5 with 10 CFR 55(a). The STP FSAR incorporated by reference  
6 the DCD without departures or supplements. We looked  
7 at those references, and they were acceptable, except  
8 when we got to the In-Service Testing Program, it wasn't  
9 clear, in fully describing the I&C Program as an operational  
10 program, which OM code addition was going to be applied  
11 to the In-Service Testing Program.

12 In response to that, South Texas indicated  
13 that they would revise their table 1.8-21a to include  
14 ASME OM code 2004 edition in support of the ISC description  
15 for the COL application. And the 2004 edition of the  
16 OM code is incorporated by reference in the regulations,  
17 and therefore, acceptable. So, we have identified this  
18 as a confirmatory item in our SER.

19 Another section was Section 5.2.1.2, which  
20 are the applicable code cases. Once again, the STP FSAR  
21 incorporates the DCD by reference.

22 A standard departure, 1.8-1, indicated that  
23 a more recent Reg Guide 1.84, Revision 33, would be used  
24 for Section 3 code cases. But it didn't spell out

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 specifically which specific code cases were planned to  
2 be used for the In-Service Inspection Program, the  
3 In-Service Testing Program.

4 And in terms of meeting the SECY Paper 05-197  
5 for fully describing their ISI and IST programs, we needed  
6 to know which code cases were currently planned to be  
7 used. So, both of those are identified as open items  
8 in the SER.

9 Now, for the In-Service Testing Program,  
10 we have had an audit with South Texas on their IST program.

11 They are in the process of updating the FSAR, Section  
12 3.9.6, which will spell out the specific code cases for  
13 IST that they plan to use right now. So, that will be  
14 taken care of very shortly.

15 Okay. So, that is the first of 5.2.1.2.  
16 Another portion of that is that South Texas clarified  
17 the use of annulled code cases. There was language in  
18 the DCD which talked about the use of annulled code cases.

19 So, we asked for clarification of that.

20 And they indicated in their response that  
21 where it was specified, they used it as specified in  
22 the purchase order, where accepted by the supplier. That  
23 was consistent with 10 CFR 50.55(a) and (b)(4), (5),  
24 and (6), which talks about the use of annulled code cases.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Another topic in that section had to do with  
2 the use of code cases that are specified in FSAR table  
3 5.2-1 related to code cases that are referenced or listed  
4 in Reg Guide 1.84, Revision 33.

5 There were a number of code cases that had  
6 been superseded or outdated. We asked that that table  
7 be updated to reflect the most recent additions of those  
8 code cases, and that is what they are planning to do  
9 right now. They have indicated where they are going to  
10 do. So, that is a confirmatory item as well. So, that  
11 is being taken care of.

12 Okay. So, that is it for those two sections.  
13 Now next is the 5.4.6, Reactor Core Cooling Isolation  
14 System, and here, as was discussed this morning with  
15 the Standard Departure 2 --

16 CHAIRMAN ABDEL-KHALIK: Excuse me. Would  
17 this be a reasonable time to take a break? This is a  
18 reasonable point to --

19 MR. SCARBROUGH: Yes.

20 CHAIRMAN ABDEL-KHALIK: -- since the  
21 remainder of the presentation pretty much deals with  
22 the --

23 MR. SCARBROUGH: Sure, sure. That would be  
24 fine.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: Okay. Why don't we  
2 take a 15-minute break? We will come back at 10:35.

3 (Whereupon, the foregoing matter went off  
4 the record at 10:20 a.m. and went back on the record  
5 at 10:35 a.m.)

6 CHAIRMAN ABDEL-KHALIK: We're back in  
7 session.

8 Please continue.

9 MR. SCARBROUGH: Thank you.

10 I'm Thomas Scarbrough.

11 Next I was going to talk about Section 5.4.6,  
12 which is the Reactor Core Isolation Cooling System. As  
13 we heard this morning, there is a Standard Departure  
14 at T12.4-3, which talks about the new reactor core isolation  
15 cooling system turbine pump design. There was a  
16 proprietary Toshiba report which describes that new  
17 design.

18 Next slide.

19 Also indicated this morning, there are  
20 several key features of this new design, the monoblock  
21 design where the pump and turbine are within the same  
22 casing; there's no shaft seal required. So, they are  
23 both on the same shaft for the turbine and the pump.  
24 There is no barometric condenser required, which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 eliminates the need to condense shaft steam leakage.  
2 So, that is not necessary anymore.

3 There's no oil lubrication. It is  
4 water-lubricated internally. There's no steam bypass  
5 line for the warmup because the system can handle the  
6 steam directly without the need to bypass some steam  
7 initially.

8 Then, there's less complex -- the system  
9 controls are simplified, so that there is a more prompt  
10 response.

11 So, those are some key aspects of the design.

12 MEMBER-AT-LARGE STETKAR: Tom?

13 MR. SCARBROUGH: Yes?

14 MEMBER-AT-LARGE STETKAR: The  
15 next-to-the-last bullet says, "No steam bypass line  
16 required for warmup." You said, well, because the system  
17 is designed to be able to handle the full-steam emission.

18 I suspect, if I talked to Terry Turbine when they started  
19 installing their turbines back in the, whenever, seventies,  
20 they would have said the same thing. I mean people put  
21 in those bypass lines because they discovered that the  
22 turbines had a propensity to trip on overspeed on startup.

23 What kind of confidence do you have that  
24 this one doesn't do that?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCARBROUGH: Well, one interesting part  
2 that came up in your discussion this morning was the  
3 qualification for the pump. When we reviewed the topical  
4 report, it talked about seismic qualification and the  
5 environmental qualification, but it didn't talk about  
6 functional qualification. That was one of the key points  
7 of the audit, the result of the audit that we performed.

8 They are in the process now of revising the  
9 topical report to describe the functional qualification  
10 for this. Part of that process is going to be being able  
11 to start up without these trips, the start and stop that  
12 you talked about over the time period. Can it handle  
13 starts and stops over a long time period?

14 MEMBER-AT-LARGE STETKAR: Are they going  
15 to run a qualification program similar to diesels where  
16 they have to demonstrate that the thing starts a number  
17 of times successfully without tripping?

18 MR. SCARBROUGH: Yes. That is going to be  
19 its performance requirements. They are going to have  
20 to describe and demonstrate, and there is ITAAC related  
21 to type testing and such. So, we will be following this  
22 similar to the way we were following the squib valve  
23 designs for APWRs, AP1000s, is the need to have that  
24 functional qualification over the entire functional life

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the component.

2 So, yes, that is something, and I made a  
3 note of your point about to make sure that that is part  
4 of the qualification as we do the review for the starting  
5 and stopping and such, and the possibility that it could  
6 trip early, because I heard this morning that there are  
7 issues that maybe they might trip. Even though they are  
8 designed not to, maybe they're not --

9 MEMBER-AT-LARGE STETKAR: The old turbines  
10 were designed not to.

11 (Laughter.)

12 If you had talked to the designer, they would  
13 have told you they didn't trip.

14 MR. SCARBROUGH: So, that's important points  
15 that we will make sure that we look at during the  
16 qualification and review process.

17 MEMBER-AT-LARGE STETKAR: Well, the  
18 designer would tell you they aren't supposed --

19 MEMBER SIEBER: Aren't supposed to trip.

20 MEMBER-AT-LARGE STETKAR: -- aren't  
21 supposed to trip.

22 MEMBER SIEBER: Operators would tell you  
23 they do trip.

24 MEMBER-AT-LARGE STETKAR: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER BROWN: Just a question. Under  
2                   qualifications, if you expect it to operate, stop/start  
3                   over an eight-hour SPO period, I would expect a  
4                   qualification program to establish a number of a series  
5                   to say, okay, maybe we have an SPO, as we would expect.  
6                   Let's test it for five or five three-hour periods and  
7                   see that it never trips. In other words, it goes on and  
8                   off throughout the eight-hour period and never goes off.  
9                   That's what I would have done in my old program.

10                   MEMBER-AT-LARGE STETKAR: Well, I think  
11                   that's what Tom --

12                   MEMBER BROWN: So, you would see that it  
13                   actually operated for the entire eight-hour expected  
14                   period as part of the qualification, without tripping  
15                   as it had to cycle on and off. Is that the process?

16                   MR. SCARBROUGH: Yes, sir. Their  
17                   qualification is going to have to show that it can perform  
18                   the function it is designed to perform. If their analysis  
19                   shows that it has to start and stop several times over  
20                   that time period, they are going to have to qualify it  
21                   for that. So, they are going to have to demonstrate that.  
22                   So, that will be part of --

23                   MEMBER BROWN: Do you ever do an endurance  
24                   test? I mean this thing is going to be there for 40 years

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or longer. See how many of those cycles it could endure?

2 MR. SCARBROUGH: Well, typically, they do  
3 have a design where they have to show that they can handle  
4 whatever the number of challenges over life. I mean they  
5 are going to have to have that type of testing.

6 MEMBER BROWN: All right. Is that part of  
7 your design qualification? Is that a DAC-type --

8 MR. SCARBROUGH: It's not DAC.

9 MEMBER BROWN: It's not piping or I&C?

10 MR. SCARBROUGH: It will be an ITAAC or a  
11 type test ITAAC. They call them type test or type testing,  
12 but it is --

13 MEMBER BROWN: So, it is not an inspection  
14 item at the site though? This is a test that you do at  
15 the vendor --

16 MR. SCARBROUGH: Right, this would be a  
17 vendor pre-installation qualification, is what they will  
18 have to do.

19 And since it is a new design, we will  
20 definitely be paying more attention to it than if it  
21 was a standard design that had been used for years.

22 MEMBER BROWN: Okay.

23 MR. SCARBROUGH: It is like the squib valves;  
24 it will get a lot of attention.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Thank you.

2 MR. SCARBROUGH: The next slide.

3 Just kind of the history of what we did,  
4 we went out and took a look at the topical report initially  
5 to see what was in it, and we asked that it be submitted  
6 on the docket. They did that.

7 We prepared RAIs. Then, we performed an  
8 audit of the design and the RAI responses in November.

9 You can click on the next slide.

10 The results of those RAI responses and the  
11 audit, as I mentioned, the RAI response indicated that  
12 the RCIC turbine pump would be qualified in accordance  
13 with ASME Standard QME-1-2007, which we recently accepted  
14 in Revision 3 of the Reg Guide 1.100.

15 But the topical report doesn't specify any  
16 functional qualification requirement. So, that is  
17 something that we had asked them to go back and revise  
18 the topical report to address that.

19 Another area that we found was that there's  
20 a small non-safety-related pump that assists in shaft  
21 bearing lubrication during standby conditions. Since  
22 that standby condition needs to have lubrication, we  
23 indicated that we expected there would be a surveillance  
24 performed on that small pump to make sure that it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 receiving the lubrication that it needs, so that it will  
2 be ready to perform, if it is needed.

3 Also, we --

4 CHAIRMAN ABDEL-KHALIK: Excuse me.

5 MR. SCARBROUGH: Yes, sir.

6 CHAIRMAN ABDEL-KHALIK: Back to the issue  
7 of the functional qualification provisions, it is not  
8 a matter of just how they are going to do the functional  
9 qualification testing, but it is also a matter of defining  
10 what it is that they are required to demonstrate. For  
11 example, the number of cycles.

12 So, how is this checked during your review  
13 process?

14 MR. SCARBROUGH: Right. Well, the  
15 QME-1-2007 is a qualification process for mechanical  
16 equipment, for pumps and valves. In the section QP in  
17 QME-1, it indicates that you have to go through and set  
18 up whatever performance requirements for your component  
19 and set up your qualification process. So, they will  
20 have to go through and establish an actual testing program  
21 that satisfies QME-1, which covers all the performance  
22 requirements for this new RCIC turbine pump.

23 So, they will have to look at the start/stop  
24 issue, the overspeed issue. All of those performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements will have to be part of developing this  
2 qualification testing program for this. Then, once they  
3 do that, as they get ready to do that, we will expect  
4 them to notify us that they are going to be performing  
5 qualification testing per the ITAAC. We will be able  
6 to go and do inspections of the ITAAC for the ITAAC of  
7 the qualification testing process.

8 CHAIRMAN ABDEL-KHALIK: But there is a step  
9 missing in what you are reviewing, which is reviewing  
10 whether or not the functional qualifications that they  
11 have been specified are, indeed, correct.

12 MR. SCARBROUGH: Yes, that would be part  
13 of the inspection process. Once they actually set up  
14 their qualification testing program, and we conduct  
15 inspections of that ITAAC as part of that, part of our  
16 review would look at, was the qualification testing program  
17 adequate to demonstrate that it will perform its design  
18 requirements?

19 CHAIRMAN ABDEL-KHALIK: Okay.

20 MR. SCARBROUGH: So, that is what we would  
21 be looking at that there. The QME-1 will tell them the  
22 process they have to establish for the qualification.  
23 Then, once they notify us that they are going to do the  
24 testing, we will be conducting inspections to look at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that, how they implement that. And if they missed anything,  
2 like, for example, the start/stop and overspeed, make  
3 sure those are all addressed as part of the qualification  
4 testing program.

5 CHAIRMAN ABDEL-KHALIK: Okay.

6 MR. SCARBROUGH: It has to be part of the  
7 QME QA program under Appendix B. It is also part of the  
8 IST program. It has to be covered under that. So, it  
9 has to be tested that way.

10 Also, as a result of the lessons learned -- we  
11 have had overflow-induced vibration over the years with  
12 boilers -- we did ask questions about how potential  
13 flow-induced vibration would be addressed. The DCD does  
14 indicate in Section 3.9.2 that flow-induced vibration  
15 needs to be addressed as part of design. And, also, during  
16 the startup test program under Section 14.2, there is  
17 specific monitoring that is done for the RCIC turbine  
18 pump to look for that. So, that is going to be addressed  
19 both in design and startup.

20 And we had two open items for this section.

21 The first one had to do with the audit, and that they  
22 need to revise the topical report to address the functional  
23 qualification, however they want to do it. They don't  
24 have to use QME-1, but they have to describe that functional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 qualification. Also, they need to specify surveillance  
2 testing for that standby lubrication pump. So, those  
3 are the two areas that are left open related to the audit.

4 Also, there's another open item related to  
5 the net positive suction head margin for the new ECCS  
6 suction strainer. They need to provide the results of  
7 those pump calculations, and the Systems Branch may be  
8 conducting an audit of those pump calculations, once  
9 we get the results. That might be done in the future.

10 So, that is another area that the Systems Branch will  
11 be looking at.

12 I did want to mention one more thing. A  
13 question came up this morning about the main steam isolation  
14 valves, and where those are addressed in the periodic  
15 testing program, the I&C program. If you look in ABWR  
16 DCD Tier 2, table 3.9-8, on page 3.9-99, the main steam  
17 isolation valves are specified for stroke testing every  
18 three months for all eight of the main steam isolation  
19 valves.

20 Sometimes they will say, well, we can't do  
21 it during power operation because it might cause a plant  
22 trip. They don't have that currently in this ABWR DCD,  
23 but, as they develop their program, I mean this is a  
24 description. So, when they develop the program, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 might decide to indicate that it could cause a plant  
2 trip. So, they have a partial stroke during plant  
3 operation and a full stroke during a fueling outage.  
4 So, that is something that they can work out as they  
5 develop the actual program. But the MSIVs are listed  
6 in the I&C table for quarterly stroke testing right now.

7 MEMBER BROWN: That's in Chapter 16?

8 MR. SCARBROUGH: This is actually in 3.9,  
9 Section 3. It is 3.9 Section 3.9.6 is the IST program.

10 MEMBER BROWN: Okay.

11 MR. SCARBROUGH: And there's a table which  
12 lists every component pump and valve within the I&C program,  
13 and it is table 3.9-8. It goes on for 50 pages. It lists  
14 all of them. Then, they will update that as they actually  
15 develop the programs.

16 MR. HEAD: And that refers to the  
17 surveillance.

18 MR. SCARBROUGH: Right, surveillance for  
19 the site.

20 MEMBER BROWN: Yes, that answered my question.

21 Thank you.

22 MR. SCARBROUGH: And that is all I had on  
23 Chapter 5.

24 MR. EUDY: In terms of chapter wrapup, due

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to the open items and confirmatory items, staff cannot  
2 finalize conclusions on Chapter 5.

3 Are there any additional questions at this  
4 time?

5 CHAIRMAN ABDEL-KHALIK: Are there any  
6 additional questions on Chapter 5?

7 (No response.)

8 No.

9 MR. EUDY: May I take this opportunity to  
10 go over what I think some of the action items are and  
11 the questions?

12 CHAIRMAN ABDEL-KHALIK: Yes, please.

13 MR. EUDY: Okay, good.

14 CHAIRMAN ABDEL-KHALIK: Good.

15 MR. EUDY: One of the questions, I believe  
16 it was for both STP and us, and maybe it is more generic  
17 across the entire application, is the homogeneity or  
18 non-homogeneity of the units that are used in the  
19 documentation we are reviewing, and what their licensing  
20 basis will be. So, that is something we both have.

21 I believe we answered the question regarding  
22 staff expectations regarding PTLR, what we are going  
23 to review and how we are going to deal with that. Okay.

24 And I believe the question about the leakage

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 limits is down to a comparison of what we know with the  
2 Japanese experience. Is that more for South Texas?

3 CHAIRMAN ABDEL-KHALIK: Correct.

4 MR. EUDY: Okay.

5 MR. HEAD: Can I go back on the fluence or  
6 the PTR? Did that answer your fluence question?

7 CHAIRMAN ABDEL-KHALIK: No.

8 MR. HEAD: Or is there still a separate --

9 CHAIRMAN ABDEL-KHALIK: Correct, that's a  
10 separate -- you know, my understanding of your listing  
11 is a methodology which is undergoing review at this time.

12 MR. HEAD: Right, PTLR will be approved,  
13 but it won't be --

14 CHAIRMAN ABDEL-KHALIK: But there is a  
15 specific question as to the fluence.

16 MR. HEAD: Okay. All right.

17 MR. EUDY: So, those are the only ones I  
18 had. So, if South Texas would like to go over the ones  
19 that they have? Oh, sorry.

20 MR. RAY: This is Neil Ray.

21 Do you still have the question about 5 times  
22 10 to the 17th?

23 CHAIRMAN ABDEL-KHALIK: Yes.

24 MR. RAY: Okay. The number generally comes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from ABWR DCD. This is a GE document. They calculated  
2 it based on their calculation and prediction. Using the  
3 GE fuel, that is the number. Since every ABWR DCD is  
4 already 35, STP specifically is using the same number.

5 And from the staff, we do not have any argument  
6 with that number because we know we have enough time  
7 to update the particulars and other associated reactor  
8 integrity issues.

9 So, that specifically answers your  
10 questions.

11 CHAIRMAN ABDEL-KHALIK: So, this number is  
12 consistent with GE 7 fuel?

13 MR. RAY: Yes, yes.

14 CHAIRMAN ABDEL-KHALIK: Whatever you are  
15 sort of incorporating by reference, and when the time  
16 comes for you to provide that amendment for the new fuel,  
17 you will come up with a new set of numbers?

18 VICE CHAIRMAN ARMIJO: Or confirm that that  
19 number is still valid?

20 MR. RAY: Yes.

21 CHAIRMAN ABDEL-KHALIK: Okay. That's fine.

22 Thank you.

23 MR. HEAD: There was the main steam valve  
24 testing and --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: That's closed.

2 MR. HEAD: Okay. So, we have the station  
3 blackout --

4 CHAIRMAN ABDEL-KHALIK: Cycling.

5 MR. HEAD: -- cycling, and as part of that,  
6 there was some more discussion on testing and stuff.  
7 I think we will try to roll that into that, too. I think  
8 that was an interesting discussion there.

9 Is that everything?

10 MR. CHAPPELL: Oh, there were questions about  
11 the Japanese operating experience, the tech spec limit.

12 CHAIRMAN ABDEL-KHALIK: Right. The 1 gpm.

13 MR. CHAPPELL: The 1 gpm.

14 CHAIRMAN ABDEL-KHALIK: Right.

15 MR. CHAPPELL: There were two subparts. No.  
16 1, what was the Japanese limit in the tech specs?

17 CHAIRMAN ABDEL-KHALIK: Right.

18 MR. CHAPPELL: And then, the second was the  
19 1 gpm lower limit, how does that compare to the sensitivity  
20 of the instrumentation?

21 CHAIRMAN ABDEL-KHALIK: Right.

22 MR. CHAPPELL: And we will provide a  
23 comprehensive answer to that.

24 CHAIRMAN ABDEL-KHALIK: I think that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consistent with the list I have been keeping track, and  
2 Maitri will --

3 MS. BANERJEE: The question on units, is  
4 that --

5 MR. EUDY: That's the homogeneity,  
6 non-homogeneity.

7 CHAIRMAN ABDEL-KHALIK: Consistency.

8 All right. Thank you very much.

9 We will now proceed with the presentation  
10 on Chapter 8.

11 MR. HEAD: Looking at our presentation on  
12 Chapter 8, again, the agenda is pretty much our standard  
13 agenda. Today, joining us we have Evan Heacock, and Bill  
14 Stillwell will also be able to weigh-in on whether there  
15 is any risk-related PRA-type questions. Vince is also  
16 available to help us with any questions on the FSAR.

17 So, I will turn it over to Billy at this  
18 point.

19 MR. STILLWELL: We will continue with our  
20 discussion with the FSAR. Chapter 8 is the electrical  
21 systems, specifically the offsite system, outside power  
22 system, and onsite power system. So, this does the  
23 transmission lines to the site and also through the  
24 switchyard.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Included is a supplemental section for  
2 station blackout and, also, an appendix for miscellaneous  
3 electrical systems, such as cathodic protection, heat  
4 tracing, and grounding system.

5           At this point, for the discussion of the  
6 offsite and the onsite systems, I will turn it over to  
7 Evan.

8           MR. HEACOCK: My name is Evan Heacock. I  
9 am with the South Texas Project. I have been with South  
10 Texas for 11 years.

11           I have been doing design and analysis work  
12 and electrical distribution for 20 years. I also sit  
13 on Subcommittee 4 of the Nuclear Power Engineering  
14 Committee, IEEE set. We deal with, basically, all the  
15 power. Our Subcommittee 4 deals with the power standards  
16 for the nuclear power industry.

17           I have also dealt quite a bit with our  
18 transmission operators and owners within the State of  
19 Texas. I deal directly with ERCOT. I have been dealing  
20 with them since I have been at South Texas and, also,  
21 our transmission companies. We have had quite a bit of  
22 dialog back and forth over the years.

23           Also, I deal with the implications that we  
24 have had with the NERC standards that have come out.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have actually been the point-of-contact in establishing  
2 the NERC requirements within the South Texas Project  
3 itself.

4 What I would like to do is start going over  
5 our offsite transmission network. We have a set of bullets  
6 here. But, for ease of describing what is going on, I  
7 would like to go to the next figure and kind of describe  
8 what our overall design is, and to kind of give you a  
9 history of what we have presently. What it shows is what  
10 we are going to.

11 The South Texas Project Units 1 and 2 have  
12 a switchyard with nine incoming transmission lines. The  
13 nine transmission lines tie into various parts of Texas,  
14 major load centers and generation centers within Texas  
15 in Houston, San Antonio, Austin, and the Corpus Christi  
16 area. We have a very diverse and robust tie throughout  
17 the State from a transmission standpoint since we tie  
18 to these various areas.

19 What we are going to for 3 and 4 is that  
20 we will basically take five of the nine transmission  
21 lines and split them up between 1 and 2, and 3 and 4.

22 We will have a separate switchyard for Unit 3 and 4 which  
23 consists of a breaker-and-a-half scheme.

24 As you can see on the drawing, a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 breaker-and-a-half is two buses. There will be a north  
2 bus and a south bus at 345 kV, tied together by three  
3 breakers in the center through each bay, where the center  
4 breaker is the, quote/unquote, "half breaker," which  
5 is shared between two different lines, typically.

6 The lines that we will bring over also will  
7 tie into the major centers within Texas. We go back into  
8 Houston. We will tie into Corpus Christi, and we tie  
9 back to San Antonio with a remote tie-back into the Austin  
10 area through one of the other transmission lines.

11 What we are also required to do is to upgrade  
12 two of our transmission lines on our existing right-of-way.

13 We will not have any new transmission lines come in,  
14 but we do have to upgrade two of our transmissions to  
15 handle the increase of power coming out of the units  
16 themselves.

17 MEMBER-AT-LARGE STETKAR: Which two are  
18 those?

19 MR. HEACOCK: The Hillje lines. Both of them  
20 are the Hillje.

21 MEMBER-AT-LARGE STETKAR: Both of those are  
22 going to be upgraded?

23 MR. HEACOCK: Correct.

24 Also, one of the items, when we are going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through this and dealing with our transmission companies,  
2 we have to do what they call an interconnection study.

3 Basically, the transmission companies and ERCOT rules  
4 say that you need to be able to withstand single-contingency  
5 failures. Worst-case single-contingency for us is the  
6 loss of two lines, mainly because we share common  
7 right-of-way or common towers.

8 If you look over to the righthand side of  
9 the drawing, you will see two arrows going off the side.

10 That is basically one contingency. So, ERCOT has to  
11 plan for the loss of both of those lines any particular  
12 time.

13 MEMBER-AT-LARGE STETKAR: That is one common  
14 tower line over to Velasco?

15 MR. HEACOCK: That's correct. That shares  
16 the same towers, Dow 18 and Dow 24.

17 MEMBER-AT-LARGE STETKAR: And the six lines  
18 that you show going northwest, those are actually three  
19 tower lines, right?

20 MR. HEACOCK: Correct, and two separate,  
21 we qualify those as two separate corridors.

22 MEMBER-AT-LARGE STETKAR: I wanted to ask  
23 you, you don't have much in your presentation on the  
24 offsite power connections. I am going to drill you a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit about those.

2 MR. HEACOCK: That's fine.

3 MEMBER-AT-LARGE STETKAR: In the FSAR, you  
4 talk about those six lines on the common right-of-way.

5 The statement is made that, for the purpose of analysis,  
6 the right-of-way has been considered as two independent  
7 rights-of-way.

8 I guess I question how you do that. I mean  
9 I know how people do that electrically. It is not clear  
10 to me how you do it physically, and whether -- it is  
11 about a 20-mile span, if I remember.

12 MR. HEACOCK: Right, there's 20 miles.

13 MEMBER-AT-LARGE STETKAR: So, I am curious  
14 whether you looked at what happens if you lose all six  
15 of those lines. I'm going to also pull you back because  
16 I recognize that we are talking about Units 3 and 4.  
17 So, we have our Units 3 and 4 box and blinders on. I'm  
18 going to pull you back to the whole site because you  
19 actually are going to have four operating nuclear reactors  
20 at this site that are being fed from, depending on how  
21 I count them, seven or nine transmission lines on maybe  
22 two or maybe three rights-of-way, because it is not clear  
23 whether the line to Blessing, how much credit you can  
24 take for that line.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   What happens if you lose all six of the lines  
2 through a storm, for example, on that north right-of-way?

3                   What happens to the four units?

4                   MR. HEACOCK: Can I go back to your corridor  
5 question first?

6                   MEMBER-AT-LARGE STETKAR: Sure.

7                   MR. HEACOCK: On the 20-mile stretch, why  
8 we say that is two, two of the tower sets of the three  
9 are fairly close to each other. We had a space between  
10 the second and third. So, basically, the general idea  
11 being there is that, if you have a loss of the tower  
12 due to a storm, that the tower will not fall over to  
13 the other section.

14                   So, from the physical standpoint, we are  
15 separating them from a falling over. It will not fall  
16 over and go into the other line. So, that is why we say  
17 two separate ones.

18                   MEMBER-AT-LARGE STETKAR: Okay.

19                   MEMBER SIEBER: That's in the COL.

20                   MR. HEACOCK: Sir?

21                   MEMBER SIEBER: That was written up in the  
22 COL, right?

23                   MR. HEACOCK: Yes. So, that is, basically,  
24 how we have been treating from day one for even 1 and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2.

2 MEMBER-AT-LARGE STETKAR: Well, but 1 and  
3 2, I will give you, you have sort of three  
4 geographically-diverse lines, even if you take Blessing.

5 MR. HEACOCK: True. True.

6 (Laughter.)

7 And the second part of your question is,  
8 if we had a storm or tornado --

9 MEMBER-AT-LARGE STETKAR: What happens,  
10 have you done an analysis to see what happens if you're  
11 operating all four units at the site, 100 percent power,  
12 and a storm comes through, and you eliminate those six  
13 transmission lines? What happens to the units?

14 MR. HEACOCK: Well, the units will trip.

15 (Laughter.)

16 We will end up having to trip the units because  
17 we won't be able to send the power out --

18 MEMBER-AT-LARGE STETKAR: Right.

19 MR. HEACOCK: -- on the remaining  
20 transmission lines. They will be not rated; the Dow lines  
21 will not be able to handle a full four units.

22 MEMBER-AT-LARGE STETKAR: Okay. Now all  
23 four units will trip. What happens to the power supply  
24 back to the units?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: To clarify, they will be  
2 tripped. Now we do have some protection that might trip  
3 it automatically on out-of-step due to the amount of  
4 power trying to be pushed through the main lines, or  
5 it will be mainly tripped by the operation.

6 MEMBER-AT-LARGE STETKAR: You're trying to  
7 push out a lot of --

8 MR. HEACOCK: It would be very hard. More  
9 than likely, they would be automatic, but there could  
10 be a bit of a race there.

11 But what will happen is that, after the trip  
12 of the units, the tie-back for those two Dow lines will  
13 be actually sufficient power to power up the safety loads  
14 and non-safety loads.

15 MEMBER-AT-LARGE STETKAR: For all four  
16 units?

17 MR. HEACOCK: For all four units.

18 MEMBER-AT-LARGE STETKAR: You have analyses  
19 to show that?

20 MR. HEACOCK: We have not done a full analysis  
21 to that. That will be something I will have to take back.

22 But from a voltage regulation standpoint and a power  
23 availability, yes, I am confident that we will have no  
24 problem with the ability to bring power back in to support

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 four units in a shutdown.

2 MEMBER-AT-LARGE STETKAR: You don't take  
3 credit for the Blessing line, as I understand it?

4 MR. HEACOCK: I do not take credit for it  
5 on 3 and 4.

6 MEMBER SIEBER: Do you take credit for  
7 Hillje?

8 MR. HEACOCK: I do not take credit for Hillje,  
9 either.

10 MEMBER SIEBER: Because it crosses  
11 underneath?

12 MR. HEACOCK: Correct.

13 MEMBER SIEBER: And that is not going to  
14 be changed?

15 MR. HEACOCK: That is not going to be changed.

16 MEMBER SIEBER: Okay.

17 MR. HEACOCK: That's not as a credited  
18 offsite source. For our power transmission situation,  
19 yes.

20 MEMBER SIEBER: Well, it works as long as --

21 MR. HEACOCK: Yes, sir.

22 MEMBER SIEBER: -- no wind blows or something  
23 like that.

24 MR. HEACOCK: And to your point, there's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 another point, that we have buried one transmission line  
2 to ensure that we don't have that issue, which is one  
3 of the Dow lines coming over the three.

4 MEMBER-AT-LARGE STETKAR: Well, but that  
5 is a Unit 3/4. As soon as it gets over to Unit 1, it  
6 goes up to the tower --

7 MR. HEACOCK: Well, yes, it does not cross  
8 over anywhere else then.

9 MEMBER-AT-LARGE STETKAR: Yes. Oh, you're  
10 talking in terms of crossover protection?

11 MR. HEACOCK: Right, right.

12 MEMBER SIEBER: Do you have, just off the  
13 top of your head, the ratio of the total expected  
14 momentarily power output of the three units at STP versus  
15 the entire --

16 MR. HEACOCK: ERCOT grid?

17 MEMBER SIEBER: Right.

18 MR. HEACOCK: No, I do not.

19 MEMBER SIEBER: Is it 5 percent, 10 percent,  
20 30 percent?

21 MR. HEACOCK: It would be close to 10. It  
22 would be probably a little less. It depends on the time  
23 of year. But if we are talking about peak load, it would  
24 be about 8 percent of the ERCOT load, and it would be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 higher, of course, in lighter load periods.

2 MEMBER SIEBER: Okay. Well, that is one of  
3 the factors that goes into the stability analysis, which  
4 I take it hasn't been done yet?

5 MR. HEACOCK: We have done a stability  
6 analysis from a standpoint of loss of single largest  
7 units, which is the loss of Unit 3 and 4. I specifically  
8 asked for our transmission companies doing the analysis  
9 to do a stability analysis on both 3 and 4 being tripped,  
10 again with a scenario --

11 MEMBER SIEBER: All four?

12 MR. HEACOCK: No, it is not credible. That  
13 is not a credible scenario as far as FERC, ERCOT, and  
14 NERC rules. That is potentially beyond what they analyzed  
15 for. That is like a quadruple loss.

16 MEMBER SIEBER: Uh-hum, but the switchyards  
17 are tied together, nonetheless.

18 MR. HEACOCK: The switchyards are tied  
19 together, but if you lose one switchyard, it would not  
20 propagate over, because of the breaker schemes and  
21 protection schemes. That is the other reason for having  
22 separate switchyards, too, is that we would not have  
23 failure. A failure in one switchyard will not necessarily  
24 propagate over to the other switchyard and cause a trip

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at the other end. So, we are minimizing that with separate  
2 switchyards. There is a tie, you are correct.

3 MEMBER SIEBER: Okay, I will think about  
4 that.

5 (Laughter.)

6 MR. HEACOCK: That's fine.

7 MEMBER SIEBER: Thank you.

8 MR. HEACOCK: Uh-hum.

9 Any other general questions?

10 CHAIRMAN ABDEL-KHALIK: Please continue.

11 MR. HEACOCK: Okay. Let's go back over our  
12 intro bullets, if we can, just to make sure.

13 We kind of talked about it. We have the  
14 six transmission lines connecting to the South Texas  
15 Project. We talked about we have analyzed the loss of  
16 any double circuit line not affecting the stability of  
17 the units. Grid stability is maintained. We have done  
18 the analysis to show that the loss of both Units 3 and  
19 4 does not cause the grid to go unstable.

20 Again, we talked about the  
21 breaker-and-a-half scheme, which is what we have currently  
22 for even 1 and 2.

23 We have also gone through and looked at failure  
24 modes and effects to show that no single failure prevents

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 offsite power from supporting safety function during  
2 any possible event. Okay?

3 Let me go to slide 7.

4 For one of our major departures that we had  
5 in Chapter 8.3, and it ties into 8.2, was the Standard  
6 Departure 8.3-1, which is where we changed our plant  
7 medium voltage from a 6.9 single voltage distribution  
8 to a dual.

9 MEMBER-AT-LARGE STETKAR: I'm sorry. You  
10 are going to get inside the plant here pretty quick,  
11 aren't you?

12 MR. HEACOCK: Uh-hum.

13 MEMBER-AT-LARGE STETKAR: Let me keep you  
14 back out at the switchyard just for a couple of questions.

15 MR. HEACOCK: Okay.

16 MEMBER-AT-LARGE STETKAR: I noticed that  
17 you make a point that all of the 345-kV breakers out  
18 in the switchyard have double -- there's a dual protection  
19 system out there, double trip coils on each breaker.

20 MR. HEACOCK: Correct. Correct.

21 MEMBER-AT-LARGE STETKAR: What about the  
22 closed coils on the breakers? Are they single-closed  
23 coil, double-closed coils?

24 MR. HEACOCK: That's a good question. Off

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the top of my head, I can't remember if we specified.

2 MEMBER-AT-LARGE STETKAR: That's a  
3 question.

4 MR. HEACOCK: Yes.

5 MEMBER-AT-LARGE STETKAR: Because where I  
6 am headed on this is, if you do lose all offsite power,  
7 and if the cause of that offsite power clears the switchyard,  
8 which oftentimes in the real world it does --

9 MR. HEACOCK: Yes.

10 MEMBER-AT-LARGE STETKAR: -- at some point  
11 in time, you are going to have to reclose those breakers.

12 MR. HEACOCK: Yes.

13 MEMBER-AT-LARGE STETKAR: So, my question  
14 is, if you have two DC power supplies out there, what  
15 is the rated life of the batteries for those DC supplies?  
16 And if you only have single-closing coils on those breakers,  
17 how do you figure out which breakers you can operate  
18 when you need to operate them?

19 MEMBER SIEBER: If you turn the switch --

20 MEMBER-AT-LARGE STETKAR: You try it, and  
21 you find out somebody should have thought about that  
22 today, rather than --

23 (Laughter.)

24 MEMBER SIEBER: Well, a dead battery is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a -- that's a real issue.

2 MR. HEACOCK: Yes, I agree, it is a very,  
3 very real --

4 MEMBER SIEBER: I have seen substations  
5 completely destroyed because the battery was dead.

6 MR. HEACOCK: That is true. It is a very  
7 real scenario. For maintenance of the batteries, we are  
8 imposing requirements for the transmission companies  
9 to test this.

10 I will check on the closed-coil situation.

11 MEMBER-AT-LARGE STETKAR: Check on the  
12 closed-coil, and, also, do you have the rated life on --

13 MR. HEACOCK: No, we have not done it. That  
14 has not been designed yet at this particular point in  
15 time. I expect it to be a 10- to 20-hour battery,  
16 plus -- well, mainly because there's not much load. When  
17 you're sitting idle, there's really not much load on  
18 the 125 out there.

19 MEMBER-AT-LARGE STETKAR: That would be  
20 great.

21 MR. HEACOCK: The other part is that we will  
22 feed the power for the switchyard from 3 and 4 combustion  
23 turbines. So, they will have power continuously, if we  
24 have lost all site sources.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: And that's at  
2 20-megawatts --

3 MR. HEACOCK: Twenty-megawatts turbine  
4 generator.

5 MEMBER SIEBER: One turbine?

6 MR. HEACOCK: One per unit.

7 MEMBER SIEBER: Oh, one per unit? Okay.

8 MR. HEACOCK: Yes. There will be two total.

9 MEMBER SIEBER: Okay. You could almost  
10 start up with that.

11 MR. HEACOCK: Yes.

12 (Laughter.)

13 It would be close, but --

14 MEMBER-AT-LARGE STETKAR: One last question  
15 to kind of close out the switchyard. As I read through  
16 the FSAR and the RAIs, it wasn't clear to me who -- I  
17 will use the term -- owns in a functional sense, not  
18 a legal sense, who owns the switchyard. What company  
19 is responsible for doing the testing and maintenance  
20 work in the Units 3 and 4 switchyard, given the fact  
21 that there are three companies --

22 MEMBER SIEBER: In there.

23 MEMBER-AT-LARGE STETKAR: -- in there?

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Or four, if you consider --

2 MEMBER SIEBER: If you count them.

3 MEMBER-AT-LARGE STETKAR: -- if you count  
4 them.

5 MEMBER SIEBER: Right.

6 MR. HEACOCK: Yes, we're definitely there  
7 with our --

8 MEMBER-AT-LARGE STETKAR: The question is,  
9 who has responsibility for that testing and maintenance  
10 work in the switchyard?

11 MR. HEACOCK: That is a very good question.  
12 What we have, since we are a deregulated industry in  
13 Texas from power generation, we have what we call an  
14 Interconnection Agreement that actually we are working  
15 on to complete this year. That will define roles and  
16 responsibilities for who does what within the switchyard  
17 and the boundaries of who has what responsibility for  
18 what equipment actually in the switchyard.

19 AEP Texas Central Company will have primary  
20 responsibility. This is their transmission area, service  
21 area. Our agreement will be, basically, with AEP.

22 MEMBER SIEBER: That's American Electric  
23 Power?

24 MR. HEACOCK: Right. They bought out the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 old Central Power and Light Company --

2 MEMBER SIEBER: Right.

3 MR. HEACOCK: -- through the Central  
4 Southwest a number of years ago. So, they ended up with  
5 it also being down that way.

6 They will actually have responsibility for  
7 most of the maintenance in the switchyard. That falls  
8 under --

9 MEMBER SIEBER: Well, they have three lines  
10 out of the --

11 MR. HEACOCK: They have two lines.

12 MEMBER SIEBER: Two lines?

13 MR. HEACOCK: Yes.

14 MEMBER-AT-LARGE STETKAR: But it's in their  
15 area.

16 MR. HEACOCK: It's their service area. This  
17 is kind of the strange thing, yes.

18 MEMBER SIEBER: But, I mean, they each have  
19 two?

20 MR. HEACOCK: Center Point will have two.  
21 San Antonio will have -- I have to count these on the  
22 top of my head. Hang on a second. I've got it in here.

23 MEMBER-AT-LARGE STETKAR: There's nine  
24 lines is the problem.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 MEMBER SIEBER: Well, somebody has three.  
3 I can look it up. I've run across it a couple of times,  
4 and it's not important.

5 MR. HEACOCK: Well, let's see, Center Point  
6 will probably maintain three of them, which will be the  
7 tie between 1 and 2, and 3 and 4. They had the Dow line,  
8 and they have one of the Hillje lines.

9 San Antonio has an Elm Creek line. Then,  
10 AEP will have the Blessing line and the Lawn Hill line.

11 MEMBER SIEBER: Okay. Now I guess the  
12 question is, somebody decides they need to do maintenance  
13 on a breaker.

14 MR. HEACOCK: Uh-hum.

15 MEMBER SIEBER: Who does the maintenance,  
16 the company that owns the breaker or somebody else?

17 MR. HEACOCK: What I expect for us to have  
18 is a similar agreement we have presently with 1 and 2  
19 in which they have four owners of that switchyard,  
20 basically.

21 MEMBER SIEBER: Right.

22 MR. HEACOCK: But one company does  
23 maintenance as the, quote/unquote, "managing" partner  
24 for them all, which is Center Point for 1 and 2. I would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expect that to be the same for --

2 MEMBER SIEBER: But you don't have that right  
3 now?

4 MR. HEACOCK: We have not set up the  
5 agreements yet. That's why I say, I expect for us to  
6 in the agreements to be set up where AEP does all that,  
7 because AEP will control the switchyard from breaker  
8 opening, for clearances, and whatnot, to take out a line  
9 for somebody else.

10 MEMBER SIEBER: Who is the system operator?

11 MR. HEACOCK: The system operator for 3 and  
12 4 will be AEP.

13 MEMBER SIEBER: Okay.

14 MR. HEACOCK: It will be out of their control  
15 center in Corpus Christi.

16 MEMBER SIEBER: Okay. So, they will operate  
17 all of the transmission lines out of the plant?

18 MR. HEACOCK: They will operate the STP 3  
19 and 4 and the breaker. The remote end of that will be  
20 operated by the respective companies.

21 MEMBER SIEBER: Right.

22 MR. HEACOCK: Yes.

23 MEMBER SIEBER: You've either got a load  
24 or you don't.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Right.

2 MEMBER-AT-LARGE STETKAR: Speak to your  
3 control of the switchyard here.

4 MR. HEACOCK: Okay. For what we will have  
5 control over for 3 and 4 will be the generator breakers  
6 in the switchyard and the reserve auxiliary transformer  
7 feeds. That will be ours for Unit 3 and Unit 4.

8 MR. HEAD: What about access and knowledge  
9 of what's going on?

10 MR. HEACOCK: Okay. Thank you.

11 MR. HEAD: You're welcome.

12 MR. HEACOCK: Keep prompting.

13 The access will be controlled through South  
14 Texas, similar to what we have for 1 and 2. We have an  
15 access agreement in place that nobody goes in without  
16 notification of the shift supervisor, the shift managers.  
17 They have to get prior ability to get the access.

18 Actually, also, there will be a requirement  
19 that, if any breakers or any lines are controlled by  
20 AEP, they have to notify STP fire to opening those breakers  
21 or closing those breakers, so we know what's going on  
22 out in the switchyard for the breakers and lines. So,  
23 we understand what is occurring.

24 MEMBER SIEBER: The one utility with which

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm quite familiar had dual locks on the gates to the  
2 switchyard. The one which was in the control room for  
3 the plant, the other which was the transmission operators  
4 keep, and it took both of them to get in there. The clearance  
5 was initiated at the plant. In addition to the  
6 transmission line clearance, they controlled the line  
7 itself if, for example, a circuit breaker repair or  
8 something like that was to be done.

9 Do you have something as stringent as that?  
10 Or you just call the controller up on the phone and say,  
11 "We're going in the switchyard. We have to work to do  
12 on this."?

13 MR. HEACOCK: Presently, on 1 and 2 -- we  
14 should implement it on 3 and 4 -- we have one lock. It  
15 is an STP lock, not a transmission. In other words, the  
16 transmission companies do have a key to that particular  
17 lock, but it is limited.

18 The access has to always be given prior to  
19 going into the switchyard. That is a requirement. Before  
20 anybody goes in, they have to notify the control room  
21 to let them know what they are going to be doing in the  
22 switchyard from an activity standpoint.

23 From a clearance standpoint, we are on  
24 notification for those clearances, not part of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clearance process itself.

2 MEMBER-AT-LARGE STETKAR: Evan, just so I  
3 understand, you said STP will have -- you will be able  
4 to operate from the control room, I think you said, the  
5 generator breaker and the reserve aux transformer  
6 breakers.

7 On the diagram that is up on the screen there,  
8 if I look at Unit 3, does that mean that you can operate  
9 the three breakers, both bus-side breakers and the center  
10 breaker, that feed the Unit 3 RATs?

11 MR. HEACOCK: Correct.

12 MEMBER-AT-LARGE STETKAR: Can you operate  
13 the bus-side breaker and the center breaker from the  
14 main power transformer supply or --

15 MR. HEACOCK: Correct.

16 MEMBER-AT-LARGE STETKAR: You can?

17 MR. HEACOCK: Yes.

18 MEMBER-AT-LARGE STETKAR: Okay. So, those  
19 five circuit breakers --

20 MR. HEACOCK: Will be what we have, yes,  
21 access to to operate. And the rest will be --

22 MEMBER-AT-LARGE STETKAR: But you can't,  
23 with the exception of tying that one transmission line  
24 into what would feed the unit aux transformers, you can't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operate any other circuit breakers to reconnect the  
2 transmission line to the plant?

3 MR. HEACOCK: No. We do not have that since  
4 we are deregulated. Basically, we had to ask fairly  
5 sternly to have control over the generator breakers and  
6 the RATs, since that is in the switchyard. But they have  
7 agreed to give us that control.

8 MEMBER BROWN: You said five breakers?

9 MR. HEACOCK: Well, for one unit.

10 MEMBER-AT-LARGE STETKAR: For one unit?

11 MR. HEACOCK: For one unit. There would be  
12 another five for the opposite unit.

13 MEMBER-AT-LARGE STETKAR: I mean, in this  
14 drawing, and I assume this is correct, the only way that  
15 you, from your control room without somebody else's help,  
16 could actually connect power back into either one of  
17 the Units 3 and 4 would be to close the center breaker  
18 from, you know, the center breaker in the cross bus from  
19 the Unit 3 main power transformer. That would tie that  
20 one transmission line.

21 You know, you could make Bus No. 1 live that  
22 way and connect it back over into Unit 4. But that is  
23 the only way. Otherwise, you rely on somebody else --

24 MR. HEACOCK: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: -- to do your  
2 breaker switching?

3 MEMBER SIEBER: Or your turbine --

4 MEMBER-AT-LARGE STETKAR: Well, you know,  
5 I'm thinking about recovering a lot of the power.

6 MR. HEACOCK: You are correct as far as us  
7 being able to do that from the control room itself. We  
8 can always dispatch somebody out to manually close the  
9 breaker, if we have to. That's not always desirable,  
10 but we can do that.

11 That is also consistent with how we operate  
12 1 and 2. We are in the same operation control for 1 and  
13 2.

14 MEMBER SIEBER: Does ERCOT know you can do  
15 that?

16 MR. HEACOCK: ERCOT knows and transmission  
17 companies know. Actually, again, we have communication  
18 paths set up. For 1 and 2, we use a ring-down line to  
19 our transmission companies specifically, so that we can  
20 communicate with them during events.

21 MEMBER SIEBER: So, you actually don't  
22 physically need anything from the transmission company  
23 to get into the switchyard, all of the switchyard?

24 MR. HEACOCK: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Okay.

2 MEMBER BROWN: In order to connect 3 to 4,  
3 do you have to -- I'm just trying to look at your diagram -- do  
4 you have to isolate yourself from the main transmission?

5 MR. HEACOCK: Say that for which one?

6 MEMBER BROWN: Do you have to isolate? In  
7 other words, if you want to feed over to your other plant  
8 because you've got a loss of whatever you need, you need  
9 to get power, the generator went down, or whatever, or  
10 one of your other sources, your other source -- do you  
11 have to isolate yourself from the other lines or not?

12 MR. HEACOCK: Yes, I'm not --

13 MEMBER BROWN: Or do you stay on the grid  
14 or not? I just think about you're providing power. That  
15 is the purpose of the plant.

16 MR. HEACOCK: Yes.

17 MEMBER BROWN: Does this show the generator  
18 breaker?

19 MR. HEACOCK: We probably have another  
20 diagram. We will show you the internal configuration  
21 of the buses.

22 MEMBER BROWN: Okay.

23 MR. HEACOCK: It might be easier to go with  
24 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, I think I looked at  
2 that. It didn't relate to this setup. They were two  
3 separate drawings, and I didn't go do that at the time.

4 MR. HEACOCK: Yes, the idea being that we  
5 would never totally isolate the units from the grid and,  
6 quote/unquote, "from each other". They are always going  
7 to be electrically-connected one way or the other.

8 What we have is diversity, the several  
9 different being RAT, reserve auxiliary transformer A  
10 or B.

11 MEMBER BROWN: No, I saw that in your other  
12 diagram.

13 MR. HEACOCK: Yes.

14 MEMBER BROWN: I got that part.

15 MR. HEAD: Can I set you up again with respect  
16 to the other companies' obligation to us and conditions  
17 in black start and that sort of --

18 MR. HEACOCK: Yes. From the obligations,  
19 for the regulation during the deregulation period, I  
20 was actually very heavily involved with what we needed  
21 to put in place from a protocol standpoint within ERCOT  
22 operating procedures and guidelines.

23 Basically, we ensured that we had, that the  
24 nuclear plants within Texas, not just South Texas, mind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you, had priority, first priority for restoration of  
2 offsite power during a grid blackout.

3 We also have in our Interconnection Agreement  
4 the same general protocol to make sure that they understand  
5 that we are an essential load, to restore back to us  
6 as soon as possible.

7 And the Interconnection is really our legal  
8 tie-back to the transmission companies on how they need  
9 to respond to us and how we respond with them. Okay?

10 Any others?

11 MR. HEAD: I'm good.

12 MR. HEACOCK: Okay. That was a very good  
13 question.

14 Okay. Going into our standard departure,  
15 we started talking about this a minute ago. STP DEP 8.3-1  
16 retains our medium voltage distribution from a purely  
17 6.9 to a dual voltage, medium voltage, 13.8 and 41.60.

18 The power generation buses, which are  
19 basically our balanced-plant loads, since our loads  
20 increase fairly significantly for the units as we went  
21 to electric-driven-type P-pumps and we also have some  
22 very large circulating water pumps.

23 We decided to increase our bus voltage to  
24 13.8 to help with the distribution and voltage problem

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 voltage drop issues and, also, cable sizing. So, the  
2 PG buses, the power generation buses, went to 13.8, which  
3 is Bus A1, B1, C1, and D1.

4 The plant investment protection buses and  
5 the safety buses were changed from 6.9 to 41.60. The  
6 41.60, being a fairly common distribution also within  
7 the plants and general design of others within the U.S.;  
8 the 6.9 has also been used at various plants for their  
9 safety buses, but the 41.60 just kind of mimics more  
10 closely more of the plants. It mimics what we have  
11 basically in Units 1 and 2. We have a three-bus design  
12 at 41.60 also for safety-related buses.

13 We actually also have some DOP 41.60, which  
14 would be similar to the plant investment protection buses.

15 So, 1, 2, 3, 4 are very similar here in this design that  
16 we have going forward.

17 We have, of course, the three-unit auxiliary  
18 transformers. Two of them are dual-winding, 13.8, 41.60,  
19 and auxiliary transformer C is a two-winding 41.60  
20 secondary output.

21 We also have added an additional reserve  
22 auxiliary transformer, mainly due to increases of loads.

23 For startup, instead of an oil-fired boiler, we went  
24 with an electric boiler, which is 20 megawatts. So, we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ended up adding another transformer just to ensure that,  
2 during a startup scenario, we have sufficient power to  
3 bring the unit up with that electric boiler.

4 MEMBER SIEBER: The 13 kV is for the heavy  
5 loads in the plant?

6 MR. HEACOCK: Correct. Correct. All the  
7 major loads. All the very large pumps. Again, the reactor  
8 feed pumps.

9 MEMBER SIEBER: But not safety load?

10 MR. HEACOCK: Not safety, correct. But they  
11 do, the 13.8 buses do feed direct internal pumps through  
12 an adjustable speed drive. The same thing with the reactor  
13 feed pumps.

14 Again, we have four buses. We went to a  
15 four-pump design throughout the plants. So, the four  
16 buses mimic well with the mechanical systems.

17 MEMBER SIEBER: Yes, why did you do that?

18 The original DCD was three. Now you end up with four  
19 buses, but only three diesels.

20 MR. HEACOCK: Well, that's four buses at  
21 the non-safety, but still three buses on the safety.  
22 We did not change the number of safety buses. We still  
23 have three safety buses.

24 MEMBER SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: So, that part really did not  
2 change. It is mainly the medium voltage at which we are  
3 distributing power there in the safety.

4 MEMBER SIEBER: Okay.

5 MR. HEACOCK: Okay? As you can see, we have  
6 added several other bus ties, CTG1, 2, and 3. We basically  
7 can connect just about any kind of a feed that you can  
8 want, back feed, forward feed, for not only outages,  
9 but, also, for emergency conditions.

10 You see that the combustion turbine generator  
11 ties to CTG1. Therefore, we can feed 13.8 buses, if we  
12 need to. We have some requirements to ensure that we  
13 can power a condensate pump for certain scenarios. Then,  
14 we also, going through a transformer, we can feed the  
15 safety buses and the non-safety PIP buses.

16 The design also being that the CTG, on a  
17 loss of voltage on any of the PIP buses, that the CTG  
18 will automatically start on loss of voltage and  
19 automatically connect to two pre-assigned PIP buses.

20 MEMBER-AT-LARGE STETKAR: Okay. I was  
21 hoping you could get to that point, so I could stop you.  
22 I'm confused.

23 MR. HEACOCK: Okay.

24 MEMBER-AT-LARGE STETKAR: The reason I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confused is I read what you just said, and I'm trying  
2 to figure out how this beast actually works.

3 What's the normal breaker alignment on bus  
4 CTG3?

5 MR. HEACOCK: CTG3, the normal breaker?

6 MEMBER-AT-LARGE STETKAR: And in particular,  
7 is the low-side breaker from the 13.8-kV transformer  
8 and the breaker from the RAT normally closed?

9 MR. HEACOCK: No.

10 MEMBER-AT-LARGE STETKAR: The RAT is  
11 normally open?

12 MR. HEACOCK: What we have is we won't have  
13 the transformer, the two winding transformers coming  
14 from CTG1 will not be closed at the same time we have  
15 a feed from RAT B. We would not want to have that path --

16 MEMBER-AT-LARGE STETKAR: Right. So, is RAT  
17 B breaker normally closed?

18 MR. HEACOCK: I'm going to go off the top  
19 of my head, but I believe we do have that as our  
20 normally-closed breaker. That will provide power to CTG3.

21 So, we can automatically also feed or do a bus transfer  
22 to any of the PIP buses.

23 MEMBER-AT-LARGE STETKAR: I'm confused. I  
24 want to know what happens if I lose, for example, UAT

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 A.

2 MR. HEACOCK: Okay.

3 MEMBER-AT-LARGE STETKAR: I mean just lose  
4 UAT A. What happens? And the plant is operating at 100  
5 percent power, and I don't want to get into -- don't  
6 tell me about feedwater pumps tripping and all that kind  
7 of stuff. Electrically, I want to know what happens.

8 MR. HEACOCK: I wasn't going to go anywhere  
9 but electric for you.

10 MEMBER-AT-LARGE STETKAR: Good.

11 (Laughter.)

12 MR. HEACOCK: I don't want to get into that  
13 transient.

14 MEMBER-AT-LARGE STETKAR: Yes, that's  
15 right.

16 MR. HEACOCK: What happens if we lose UAT  
17 A --

18 MEMBER-AT-LARGE STETKAR: UAT A.

19 MR. HEACOCK: -- on a fault?

20 MEMBER-AT-LARGE STETKAR: UAT A just  
21 vaporized.

22 MR. HEACOCK: Okay. It went away.

23 MEMBER-AT-LARGE STETKAR: It went away.

24 MR. HEACOCK: What will happen is, of course,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if it went away, our protective relaying would trip out.

2 Basically, the main power transformers, breakers in the  
3 switchyard would open up. We would lose that feed. So,  
4 we would basically lose feed to A, B, and C --

5 MEMBER-AT-LARGE STETKAR: Okay.

6 MR. HEACOCK: -- which would cause us to  
7 have an under-voltage on PIP buses A2, B2, and C2, also,  
8 A3 and B3.

9 MEMBER-AT-LARGE STETKAR: Right.

10 MR. HEACOCK: Okay. That is the normal  
11 lineup for power for the safety buses. A3 and B3 are  
12 normally powered from the unit auxiliary transformer,  
13 and C3 is powered from the reserve auxiliary transformer.

14 MEMBER-AT-LARGE STETKAR: So far, I've got  
15 you.

16 MR. HEACOCK: Okay.

17 MEMBER-AT-LARGE STETKAR: Thank you.

18 MR. HEACOCK: So, we will lose that. And  
19 what we end up doing is that we go through a dead-bus  
20 transfer. We end up going to diesel generator for Div  
21 1, and diesel generator for Div 2 would start on loss  
22 of voltage, and would, then, connect after it came  
23 up-to-speed, rate of speed and voltage within 20 seconds.

24 MEMBER SIEBER: Automatically.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Automatically, correct. It  
2 would load and close, and those two safety buses would  
3 be loaded on.

4 MEMBER-AT-LARGE STETKAR: Because you don't  
5 have a dead-bus transfer to the, let me just call it,  
6 the RAT, the other source?

7 MR. HEACOCK: Correct.

8 MEMBER-AT-LARGE STETKAR: The RAT supply?

9 MR. HEACOCK: Correct.

10 MEMBER-AT-LARGE STETKAR: Okay.

11 MR. HEACOCK: And Charlie 3 safety bus would  
12 stay powered from its offsite source.

13 MEMBER-AT-LARGE STETKAR: Okay.

14 MEMBER SIEBER: So, you've got 15 seconds  
15 before you close back in?

16 MR. HEACOCK: Correct. It is a 20-second  
17 start time for the diesel.

18 MEMBER SIEBER: Okay, 20 seconds.

19 MR. HEACOCK: Yes.

20 MEMBER-AT-LARGE STETKAR: What happens to  
21 the PIP buses? This is where I'm confused.

22 MR. HEACOCK: The PIP buses will lose power.  
23 They will go out on under-voltage.

24 MEMBER-AT-LARGE STETKAR: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: What we expect to do, it could  
2 go two different ways. If we lose, for whatever reason,  
3 if we have no other power available --

4 MEMBER-AT-LARGE STETKAR: I didn't say that.

5 (Laughter.)

6 MR. HEACOCK: Yes, I know.

7 MEMBER-AT-LARGE STETKAR: I don't want  
8 contingencies here. I want you to explain what happens  
9 to what I said.

10 MEMBER SIEBER: After the reactor trip.

11 MR. HEACOCK: Yes, after the reactor trip.

12 Well, what will end up happening is that we will -- what  
13 we are working toward is doing a dead-bus transfer to  
14 the ultimate source for the PIP buses. So, it would pick  
15 up on an ultimate source, if it available, from like  
16 RAT A.

17 If we do not, what we will have is that we  
18 will send a signal to the CTG, to the combustion turbine  
19 to start, and the combustion turbine will come in speed  
20 and reach its rated voltage and speed, and connect that  
21 way automatically.

22 MEMBER-AT-LARGE STETKAR: But RAT B is still  
23 connected to bus CTG3. Am I going to trip that supply?

24 MR. HEACOCK: No. The logics, we are working

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on logics presently. The logics will dictate that, if  
2 CTG3 bus 3 has power, it will close in on the PIP buses  
3 and repower the PIP buses.

4 MEMBER-AT-LARGE STETKAR: So, the statement  
5 in the FSAR that a selected pair of PIP buses will be  
6 picked up from the CTG isn't --

7 MR. HEACOCK: That's from the CTG, if you  
8 lose --

9 MEMBER-AT-LARGE STETKAR: What it says in  
10 the FSAR, and where I got confused, "On loss of normal  
11 or alternate preferred power" --

12 MR. HEACOCK: Yes.

13 MEMBER-AT-LARGE STETKAR: -- "an automatic  
14 transfer of pre-selected buses occurs via a dead-bus  
15 transfer to the combustion turbine, which automatically  
16 starts on loss of power. The PIP systems for each selected  
17 load group automatically restart to support their loads."

18 That is where I got confused about how --

19 MR. HEACOCK: How it all works? Yes.

20 MEMBER-AT-LARGE STETKAR: How it is going  
21 to work because this was under the description of the  
22 PIP buses.

23 MR. HEACOCK: Correct. No, and that's the  
24 intent being more for that statement, is if we lose,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 truly lose its preferred and alternate, you do not have  
2 voltage sensed anywhere. If we have any voltage from  
3 any of the other sources, it is going to go to that source  
4 first.

5 MEMBER-AT-LARGE STETKAR: I understand if  
6 you think in station blackout loss of offsite power space.

7 I'm trying to think about things, transients that happen  
8 in the real world.

9 MR. HEACOCK: Correct. Then, the logics we  
10 are working on presently to determine that sequence of  
11 events.

12 MEMBER-AT-LARGE STETKAR: You don't really  
13 have the final design for that?

14 MR. HEACOCK: No, we have not. We are working  
15 on it.

16 But the bottom line is what's in the SAR  
17 presently is what we are working for as the general basis,  
18 but we are going through and ensuring that during all  
19 scenarios what you are worried, basically, telling us  
20 that we will not end up with parallel in buses --

21 MEMBER-AT-LARGE STETKAR: Yes, I mean that  
22 is where I got confused --

23 MR. HEACOCK: Right.

24 MEMBER-AT-LARGE STETKAR: -- because I see

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 either in the SAR, the way it is written, if I just think  
2 logically and look at electrical switching, I either  
3 would have to open up the RAT B or wind up paralleling  
4 the combustion --

5 MR. HEACOCK: Correct.

6 MEMBER-AT-LARGE STETKAR: -- turbine  
7 generator with that RAT to satisfy the fact that the  
8 CTG picks up those buses somehow.

9 MR. HEACOCK: Yes. You are correct; they  
10 will not be allowed to be parallel at any time. Like  
11 I said, we are going through with the details and the  
12 logics on that presently.

13 So, we are working through to make sure,  
14 and at no time will we ever allow paralleling the system,  
15 unless it is being tested.

16 MEMBER-AT-LARGE STETKAR: Well, I mean not  
17 allowing paralleling of the system is one thing. Actively  
18 tripping off a reliable source of power to prevent  
19 paralleling is also not necessarily a good idea.

20 MR. HEACOCK: Correct, correct. I would  
21 agree. When we finish our final logics, we will end up  
22 changing that description that you see.

23 MEMBER SIEBER: And trying to sync to it  
24 with a diesel or a combustion turbine has its -- it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a pretty big risk to it.

2 MR. HEACOCK: Yes.

3 MEMBER SIEBER: If you can do it at all,  
4 if you have the controls to do it.

5 MR. HEACOCK: Yes. True.

6 MEMBER-AT-LARGE STETKAR: I would be  
7 interested to see how that all finally works.

8 MR. HEACOCK: Okay.

9 MEMBER SIEBER: Well, it looks like, when  
10 you get in this condition, you are going to stay in this  
11 alternate mode of operation for a long period of time,  
12 right?

13 MR. HEACOCK: It will take some time to get  
14 back out of that, correct.

15 MEMBER SIEBER: Yes.

16 MR. HEACOCK: The operations folks will have  
17 to --

18 MEMBER SIEBER: Hours or many hours?

19 MR. HEACOCK: It depends on the event. You  
20 know, it is really event-based.

21 MEMBER SIEBER: You've got to take care of  
22 the plant first.

23 MR. HEACOCK: Correct. As long as you have  
24 a reliable source, operations is not going to worry about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the feeds, and we are going to be designed to such that  
2 it can continue --

3 MEMBER SIEBER: I would hope so.

4 MR. HEACOCK: Yes. Allow that, the last  
5 thing to worry about being the power.

6 MEMBER-AT-LARGE STETKAR: Do you happen to  
7 know -- I will let you off the hook here on this in just  
8 a second.

9 (Laughter.)

10 One thing I was just thinking about is -- and  
11 you can tell me you don't have the design worked out,  
12 and we will let it die there. But the 4-kV winding on  
13 RAT B, does that have enough capacity to feed two PIP  
14 buses and a safety bus simultaneously, whatever loads  
15 would be on there?

16 I mean, in your scenario, because of the  
17 time, I don't want to get into figuring out how you  
18 pre-select which two PIP buses are going to be picked  
19 up by this transfer that may not be designed yet. But  
20 what amount of load, combined safety bus and PIP buses,  
21 can you actually supply through that one winding? Do  
22 you know?

23 MR. HEACOCK: Off the top of my head, no,  
24 I cannot. We are working through --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: That's good  
2 enough. Fine.

3 MR. HEACOCK: And we have procedures to make  
4 sure we don't exceed the winding, but --

5 MEMBER-AT-LARGE STETKAR: Fine, fine.

6 CHAIRMAN ABDEL-KHALIK: Let's proceed.

7 MEMBER-AT-LARGE STETKAR: Yes, we should  
8 proceed.

9 MR. HEACOCK: Is that a followup or is that  
10 just --

11 MEMBER-AT-LARGE STETKAR: Well, it more  
12 depends on the design. I mean it's --

13 MR. HEACOCK: Yes, it is design-related,  
14 but --

15 MEMBER-AT-LARGE STETKAR: However the  
16 design works.

17 MR. HEACOCK: Okay. We will also have  
18 procedures in place to make sure that we don't exceed  
19 the loading of the windings, of the RATs or the unit  
20 auxiliary transformers themselves.

21 MEMBER SIEBER: Now all the details of how  
22 you would operate the plant in these kinds of situations  
23 show up in the EOP?

24 MR. HEACOCK: Without knowing where we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at with EOPS yet --

2 MEMBER SIEBER: It should be not in all the  
3 supplements that you're making, but in the EOPs, which  
4 I presume somewhere the staff would review, and we would  
5 never see, right?

6 MR. CHAPPELL: EOPs are off normals.

7 MR. HEACOCK: Yes.

8 MR. CHAPPELL: We have abnormal operating  
9 procedures that would also address loss of power supplies.

10 MEMBER SIEBER: Yes, well, they are abnormal  
11 or EOPs.

12 MR. HEACOCK: But, typically, what I have  
13 seen in the past for 1 and 2, yes, they address how you  
14 configure your buses.

15 MEMBER SIEBER: I guess I would hold that  
16 open in my own mind because I'm really curious as to  
17 how you are going to do this.

18 MR. HEAD: But we have those issues on 1  
19 an 2 right now that are addressed by EOPs and alternate  
20 procedures.

21 MR. HEACOCK: And, then, how they are  
22 supposed to be aligned. On loss of this bus, you are  
23 supposed to check to see if you have an alternate source.  
24 If you do, you go to your alternate source, and so on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and so forth.

2 MEMBER SIEBER: Right. Okay.

3 MR. HEACOCK: Yes. There's a whole litany  
4 of steps they have to go through.

5 MR. HEAD: Loading limits.

6 MR. HEACOCK: Yes.

7 MEMBER SIEBER: Okay, thanks.

8 CHAIRMAN ABDEL-KHALIK: We're going to run  
9 over. Please proceed.

10 Do you have a question?

11 MEMBER-AT-LARGE STETKAR: Yes, I do.

12 CHAIRMAN ABDEL-KHALIK: Okay.

13 MEMBER BROWN: I had one other high-level  
14 question.

15 CHAIRMAN ABDEL-KHALIK: Let's do John's  
16 first and then we will take your question.

17 MEMBER-AT-LARGE STETKAR: Just this, again,  
18 is more curiosity. Why did you decide not to have a dead-bus  
19 transfer between the UAT and the RAT at either the  
20 non-safety or the safety buses?

21 MR. HEACOCK: Our certified design went with  
22 a non-transfer, and we just adopted that. From the  
23 standpoint now, however, we expect to change that because  
24 I don't agree with that philosophy of going -- without

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an alternate source being available, switching over to  
2 it.

3 MEMBER-AT-LARGE STETKAR: The only reason  
4 I ask that is we have recently looked at a COL application  
5 from another vendor, you know, another design center.  
6 When they went to go actually build that plant, they  
7 decided that it was probably better to have an automatic  
8 transfer, even though the original design on that plant  
9 didn't have a transfer.

10 MR. HEACOCK: Yes.

11 MEMBER-AT-LARGE STETKAR: So, I am just  
12 curious.

13 MR. HEACOCK: No, it is much better.

14 MEMBER-AT-LARGE STETKAR: I'm just curious  
15 whether there was any reason other than continuity from  
16 the --

17 MR. HEACOCK: It was what's in the words  
18 in the certified design we adopted, but the actual design,  
19 you will see that it will have a dead-bus transfer.

20 MEMBER-AT-LARGE STETKAR: That will be  
21 another departure?

22 MR. HEACOCK: Yes. Well, it won't be.

23 MR. HEAD: No. We are licensing --

24 MEMBER-AT-LARGE STETKAR: Oh, you are going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to license it this way and then --

2 MR. HEACOCK: It will be after.

3 MEMBER-AT-LARGE STETKAR: Okay.

4 MR. HEAD: He is proposing a change that  
5 we may adopt.

6 MEMBER-AT-LARGE STETKAR: Okay. I  
7 understand.

8 (Laughter.)

9 Continue. I understand. I understand.

10 CHAIRMAN ABDEL-KHALIK: Charlie, you had  
11 a question?

12 MEMBER BROWN: Real quick, what I was  
13 noticing, when I looked at this, was that there's no -- if  
14 you have a fault, a major fault, on any one input on  
15 any of the UAT A, B, and C, you have effectively eliminated  
16 your ability to supply power, do anything with the main  
17 transformer because it is a short right on the bus, if  
18 you have a major fault there. I just don't see isolation,  
19 your ability to isolate the primary of that transformer  
20 from the main power, the main generator or the rest of  
21 the feeds over to the other two UATs.

22 MR. HEACOCK: That's correct.

23 MEMBER BROWN: That means, if you have a  
24 fault there and it is a short of some kind, you're toast.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The breaker opens. The main generator breaker opens  
2 and you have shut down that all through the whole line.

3 MR. HEACOCK: Yes. This is not an unusual --

4 MEMBER BROWN: You use a switchyard input  
5 because there is no isolation of that primary side.  
6 There's no breaker on the input, is all I'm saying.

7 MR. HEACOCK: There's no breaker to the UATs,  
8 correct. If we have a fault there, it will trip the feeds  
9 back through the main -- trip the generator breakers  
10 out in the switchyard, which will, essentially you're  
11 correct, eliminate the power for all the buses.

12 The only difference being that we do have  
13 the one feed. The safety bus Charlie 3 is continuously  
14 fed from, or any of them, but our normal supply will  
15 be Charlie 3. It is going to be normally fed from a reserve  
16 auxiliary transformer. But this is a typical design for  
17 most plants.

18 What we do have --

19 MEMBER BROWN: I was thinking you need to  
20 provide -- I mean the ability to provide power, that's  
21 what they're there for. If there's one transformer major  
22 failure, it looks like you can't supply it.

23 MR. HEACOCK: Again, that is not different  
24 from any other design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay. That's fine. That's  
2 the way it is.

3 MR. HEACOCK: The difference that we do have  
4 is that we have a main generator breaker that, if we  
5 trip the turbine or generator, for whatever reason, that  
6 generator breaker will open and isolate the generator.

7 MEMBER BROWN: No, I understand that part.  
8 I can see that. It is just that is all. I'm not  
9 familiar -- I am just not used to not seeing any isolation  
10 to any main power transformers from any sources, whether  
11 they be outside or whether --

12 MR. HEACOCK: And actually, we kind of  
13 thought --

14 MEMBER BROWN: I quit. I quit.

15 MR. HEACOCK: Okay.

16 MEMBER BROWN: You told us where they all  
17 are. Whether I like it, that's irrelevant.

18 (Laughter.)

19 CHAIRMAN ABDEL-KHALIK: Please proceed.

20 MR. HEACOCK: Okay. Let's go ahead and go  
21 to the next slide, yes, No. 9.

22 One of the items we also changed was the  
23 emergency diesel generator capability increased from  
24 the DCD from 5,000 kilowatts to 7200 kilowatts. This

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is to accommodate increases in loads, more from  
2 site-specific changes that we had for our UHS, our ultimate  
3 heat sink pumps, and fans that we added and some of the  
4 HVAC loads that needed to be increased to --

5 MEMBER SIEBER: It's hot down there.

6 MR. HEACOCK: Yes. Yes, it is hot down there.

7 We do call it tropicalization.

8 The other part is that we increased the  
9 combustion turbine size from a 9-megawatt to a 20-megawatt  
10 size. That was also so that we can load more buses as  
11 we needed to from the PIPs.

12 MEMBER SIEBER: Speaking of hot down there,  
13 you had an open item related to the emergency diesel  
14 generator operation at high temperatures, which you expect.  
15 Last I saw, that was still open.

16 MR. HEACOCK: This is the question of going  
17 from the certified design to 60-degrees feed ambience?

18 MEMBER SIEBER: Yes. Yes.

19 MR. HEACOCK: Correct.

20 MEMBER SIEBER: What are you going to do  
21 about that?

22 MR. HEACOCK: Well, No. 1, we are buying  
23 a very large diesel. From a standpoint of being able  
24 to handle at higher temperatures, we have derated -- we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bought a diesel generator set that was larger in size  
2 than we need, No. 1.

3 MEMBER SIEBER: Is it larger than 7200?

4 MR. HEACOCK: Yes. Actually, at a derated  
5 value at the higher temperatures, it is 8.1 megawatts  
6 or 9100 kilowatts.

7 MEMBER SIEBER: Okay. But it will run at  
8 the higher temperatures?

9 MR. HEACOCK: It is designed, the initial  
10 design was about almost 8400 kilowatts. That was its  
11 normal temperature running it as derated based on the  
12 temperature.

13 MEMBER SIEBER: A ship engine?

14 MR. HEACOCK: It's a peel stick. It will  
15 be a pitched peel stick.

16 MEMBER SIEBER: Okay.

17 MR. HEACOCK: But it is derated due to the  
18 temperatures, correct. It is bigger than the 7200 that  
19 we need. It is actually much bigger.

20 MEMBER SIEBER: And the staff doesn't know  
21 about that yet, right?

22 MR. HEACOCK: No, because we went out for  
23 bids, and just recently got to the point where we were  
24 bid. So, based on the feedback we are getting from the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vendor, we will eventually end up changing that. That  
2 will be more or less in the future.

3 MEMBER SIEBER: Yes, in due time.

4 MR. HEACOCK: Yes.

5 MEMBER SIEBER: Okay.

6 MR. CHAPPELL: Does that address the open  
7 item, as you understand it?

8 MEMBER SIEBER: Yes. Yes.

9 MR. CHAPPELL: Okay.

10 MEMBER SIEBER: The open item is addressed  
11 by the staff to their satisfaction. I'm sure they will  
12 look at the specifications to determine that it will  
13 operate under those conditions and produce the right  
14 amount of power.

15 MR. CHAPPELL: Correct.

16 MEMBER SIEBER: Okay.

17 MR. CHAPPELL: Right.

18 MEMBER SIEBER: That is all it takes to close  
19 it, and I don't need to know any more.

20 MR. CHAPPELL: Okay.

21 MR. HEACOCK: Okay. No other questions?

22 (Laughter.)

23 With that --

24 CHAIRMAN ABDEL-KHALIK: A related open item,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1       however, came up at the last meeting in terms of operating  
2       conditions for the people. But, you know, in terms of  
3       derating the diesel generators, as you go from 50 to  
4       60 degrees C, maybe you have answered that question,  
5       and the staff is yet to evaluate your response to it.  
6       So, as far as we are concerned, that open item is still  
7       open.

8                   MR. HEACOCK: Okay. And that goes for all  
9       the equipment in the room with it, these will fall under  
10      equipment qualification requirements due to the increased  
11      temperature. So, all those will be evaluated.

12                   CHAIRMAN ABDEL-KHALIK: Right.

13                   MR. HEACOCK: For the combustion turbine  
14      generator, since we increase from a 9-megawatt to a  
15      20-megawatt, it does take a little bit more time for  
16      us to spin the unit up. So, we have actually increased  
17      the startup time from a two-minute requirement to a  
18      10-minute, basically, to less than 10 minutes. This will  
19      keep us in the requirements of the Reg Guide 1.55, SBO,  
20      to where we do not have to perform a coping analysis.  
21      This, also, of course, serves as our alternate AC source.

22                   MEMBER-AT-LARGE STETKAR: I understand that  
23      the combustion turbine will be up-to-speed in rated voltage  
24      within 10 minutes. Again, maybe I'm confused about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design. But, as I read the description, it seemed to  
2 say that, if I lose offsite power -- now we will do a  
3 clean loss of all offsite power, instantaneous; everything  
4 is gone.

5 The combustion turbines start. For station  
6 blackout, none of the diesels start. Combustion turbines  
7 start automatically. They automatically re-energize the  
8 PIP buses. The PIP buses load.

9 Now I am sitting in the control room as an  
10 operator. I verify that the PIP buses have voltage.  
11 None of my safety buses have voltage. I need to now trip  
12 loads off the PIP buses or open up PIP buses and close  
13 manually the CTG feeds to the safety buses. Is that  
14 correct?

15 MR. HEACOCK: Right.

16 MEMBER-AT-LARGE STETKAR: And I can do that  
17 in zero time?

18 MR. HEACOCK: No, the point being it is less  
19 than 10 minutes that it will come up, so that we have  
20 still enough time for the operators --

21 MEMBER-AT-LARGE STETKAR: How much less  
22 than? 9.9999 minutes would satisfy the tech spec  
23 requirements.

24 MR. HEACOCK: Part of the station blackout

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is upon recognizing you are in a SBO. The time starts  
2 at --

3 MEMBER-AT-LARGE STETKAR: I know I'm in an  
4 SBO.

5 MR. HEACOCK: Well, it is when you declare  
6 that SBO, that is somewhat of the timeframe of where  
7 you announce that you are there, and then you have the  
8 10 minutes.

9 MEMBER-AT-LARGE STETKAR: I'm not a lawyer.  
10 I'm an operator.

11 MR. HEACOCK: Yes, yes.

12 MEMBER-AT-LARGE STETKAR: I know that I'm  
13 in an SBO. The lights went out. I looked at the buses.  
14 There's no voltage. The lights are out.

15 MR. HEACOCK: What we have is to ensure that  
16 we will be able to have operations. One of our overall  
17 requirements is to make sure operations will have the  
18 time to close those breakers in, to restore power to  
19 the safety buses within 10 minutes.

20 Right now, without us having procured the  
21 combustion turbine, we do not know exactly what that  
22 startup time is going to be. Some have close to eight  
23 minutes. Some have six minutes. We are expecting to  
24 procure one that has a startup time to where we can easily

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 meet the 10-minute requirement.

2 MEMBER-AT-LARGE STETKAR: Easily?

3 MR. HEACOCK: Well --

4 MEMBER-AT-LARGE STETKAR: I'll ask the staff  
5 about this later then. Thanks.

6 MR. HEACOCK: That's something we --

7 MEMBER-AT-LARGE STETKAR: I understand. I  
8 understand the whole reason for doing this is you don't  
9 want to perform a station blackout coping analysis.

10 MR. HEACOCK: Yes, I understand.

11 MEMBER-AT-LARGE STETKAR: So, you are,  
12 basically, trading off the need to perform a coping analysis  
13 with putting --

14 MEMBER SIEBER: A combustion turbine.

15 MEMBER-AT-LARGE STETKAR: No. Putting  
16 pressure on the operators to on paper do things in a  
17 very, very short period of time.

18 MR. HEACOCK: I agree.

19 MEMBER-AT-LARGE STETKAR: Okay.

20 MR. HEACOCK: I understand your view.

21 MEMBER-AT-LARGE STETKAR: That kind of  
22 bothers me from an operational standpoint.

23 MR. HEACOCK: Believe us, it does us, too.

24 MEMBER-AT-LARGE STETKAR: Well, but, again,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I understand what you're saying, but, still, you have  
2 relaxed the start time for the combustion turbine because  
3 you need to, because you need to buy a bigger one.

4 MR. HEACOCK: Yes.

5 MEMBER-AT-LARGE STETKAR: Maybe the  
6 tradeoff is you have to do a station blackout coping  
7 analysis.

8 MR. HEACOCK: Well, and that's where it will  
9 drive us.

10 MEMBER-AT-LARGE STETKAR: That is why I want  
11 to ask the staff about that this afternoon a little bit.

12 MR. HEACOCK: If we exceed 10 minutes, yes,  
13 we will have to do a coping analysis; you're correct.

14 CHAIRMAN ABDEL-KHALIK: How much more time  
15 do you need, do you think you will need to finish your  
16 part of the presentation?

17 MR. HEACOCK: I'm just about done.

18 CHAIRMAN ABDEL-KHALIK: You're done?

19 MR. HEACOCK: I've basically got one more  
20 slide.

21 CHAIRMAN ABDEL-KHALIK: Okay.

22 MR. HEACOCK: And then I should be done.

23 CHAIRMAN ABDEL-KHALIK: Then, you've got  
24 your portion. How much more time does STP need to finish

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the presentation on Chapter 8?

2 MR. CHAPPELL: Five minutes, if we don't  
3 have more -- you know, depending on the questions.

4 (Laughter.)

5 MEMBER-AT-LARGE STETKAR: I don't have much  
6 more.

7 CHAIRMAN ABDEL-KHALIK: All right, let's  
8 proceed then. Thank you.

9 MR. HEAD: I think the rest almost is  
10 bookkeeping.

11 CHAIRMAN ABDEL-KHALIK: Yes.

12 MR. HEAD: I think we've gotten through the  
13 interesting stuff.

14 CHAIRMAN ABDEL-KHALIK: Okay.

15 MR. HEACOCK: This kind of gets into the  
16 question we had just a minute ago. Station blackout,  
17 A4S was basically added, but it was a pointer back to  
18 1 Charlie within the certified design. When the certified  
19 design was put together, the station blackout ended up  
20 in 1 Charlie.

21 We are going to be compliant with 50.63,  
22 CFR 50.62 for loss of all alternating current. With the  
23 CTG, going through with our issues with 10 minutes, we  
24 will eliminate the SBO. Again, we may end up doing that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if it gets to that point. We will get there when we find  
2 out what kind of combustion turbine we get.

3 And then, also, FSAR 19.9, 19 echo addressed  
4 some station blackout events, which is along the lines  
5 of RCIC, being able to handle an eight-hour duration.

6 If there are no questions on that, I'm through  
7 with mine.

8 MR. CHAPPELL: All right. I'll finish up  
9 some of the bookkeeping here then.

10 We have talked a little bit about the major  
11 departure in this chapter. There is another Tier 1  
12 departure that we referenced in our last session that  
13 talks about adding a fourth division of Class 1, 120-volt  
14 AC power distribution system that is fed off Division  
15 2. This is for maintenance flexibility.

16 Other changes related to Tier 1 departures  
17 are for consistency; for example, adding a condensate  
18 pump trip. We will discuss that departure in Chapter  
19 6.

20 The changes in this chapter -- of course,  
21 we have the dual unit. That note about the dual-unit  
22 design is we are looking at minimization of shared systems,  
23 and that was an important thing to consider for the  
24 electrical distribution system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           Then, we had some revised load changes as  
2 well.

3           COL license information items, there are  
4 quite a number in this chapter, a total of 31. They have  
5 been addressed by providing certain commitments in place  
6 to ensure that the appropriate programs and procedures  
7 or procurement specifications contain the requirements  
8 that are listed. We don't have any details in here, but  
9 this gives you an idea about the types of information  
10 that need to be provided to complete the application  
11 in this section.

12           The last discussion is on an ITAAC related  
13 to the testing. This was a Tier 1 departure that was  
14 mentioned in Chapter 1 and I put up here as a reminder.

15           We did say that we discuss this in Chapter 8. In reviewing  
16 the information, we have the people here that would be  
17 able to answer any questions you may have on this.

18           It is a minor change to the ITAAC in that  
19 it specifies to the extent practical for testing and  
20 also allows type testing by the manufacturer to be  
21 incorporated into pre-operational testing. It is more  
22 a result-approach to do testing of the electrical  
23 distribution system and components.

24           CHAIRMAN ABDEL-KHALIK: Are there any other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions for the applicant on Chapter 8?

2 (No response.)

3 Before we move to the staff's presentation --

4 MEMBER-AT-LARGE STETKAR: Said, let me just  
5 think about this one.

6 CHAIRMAN ABDEL-KHALIK: Oh, okay.

7 MEMBER-AT-LARGE STETKAR: Everybody is  
8 aware of the fuse coordination problems.

9 CHAIRMAN ABDEL-KHALIK: Before we move to  
10 the staff's presentation on Chapter 8, I would like to  
11 summarize the list of open items that came up during  
12 the previous discussion. If you would just go through  
13 that list, so that we would have a record of it, and  
14 the staff would have a record of it, it would be a good  
15 idea for us. Okay? So, would you please proceed with  
16 your list, and John will confirm as to whether or not  
17 this is consistent with everything that has come up during  
18 the previous discussion?

19 MR. HEAD: An open item is regarding the  
20 number of breaker coils available for closure.

21 The switchyard battery life.

22 MEMBER SIEBER: This is discharge life --

23 MR. HEAD: Discharge.

24 MEMBER SIEBER: -- as opposed to a 10-year

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 battery or --

2 MR. HEAD: What I was wondering, though,  
3 is that as important now? We discussed the CTG --

4 MEMBER-AT-LARGE STETKAR: Yes.

5 MR. HEAD: -- available in the switchyard.  
6 Okay.

7 That is all I had at this point.

8 What else, Coley, did you have?

9 MR. CHAPPELL: There was some question about  
10 what would happen if we lost the UAT. Were there any  
11 other additional items that are needed out of that  
12 discussion?

13 MEMBER-AT-LARGE STETKAR: I'm not sure  
14 because what I was hearing is that it doesn't seem that  
15 the design is far enough advanced to answer, fully answer,  
16 the questions that I had.

17 I mean the question about losing the UAT  
18 was simply an example, so that I could understand what  
19 type of switching sequence goes through in terms of feeding  
20 buses, either from the RAT or the CTG. What I heard was  
21 that the design isn't far enough advanced to answer that  
22 question. So, I'm not sure what else to say. I guess,  
23 when the design is finished, we would like to hear about  
24 that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: And specifically, the logics.  
2 The logics.

3 MEMBER-AT-LARGE STETKAR: Specifically, I  
4 would like to understand what happens. You know, take  
5 failure of an UAT as an example.

6 MR. HEACOCK: Yes.

7 MEMBER-AT-LARGE STETKAR: But I'm  
8 interested in the non-complete loss of offsite power,  
9 non-station blackout performance of the electrical system,  
10 you know, how it responds to a fault. And pick a fault  
11 like a UAT, where you do have both RATs energized, but  
12 you will, indeed, have requirements to re-energize some  
13 set of PIP buses and the safety buses.

14 I think I understand what is going on with  
15 the safety buses, but the stuff in the middle is where  
16 I am really getting confused. That could have implications  
17 on the safety buses, depending on --

18 MR. HEACOCK: Yes, how they are configured.

19 MEMBER-AT-LARGE STETKAR: -- how it is  
20 designed.

21 MR. HEACOCK: I understand.

22 MEMBER-AT-LARGE STETKAR: How that actual  
23 switching is designed.

24 We talked about the SBO coping. I understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there's no item on that. I am going to ask the staff  
2 about that, but for you there's nothing.

3 There is one, though. I would like to have  
4 confidence that, remember when we were talking about  
5 the offsite lines, I forced you to fail all six lines  
6 going north.

7 MR. HEACOCK: Yes.

8 MEMBER-AT-LARGE STETKAR: And the statement  
9 was made that you thought that, whether you call them  
10 Dow or Velasco, the ones going off to the east --

11 MR. HEACOCK: Right, right.

12 MEMBER-AT-LARGE STETKAR: -- had enough  
13 capacity to feed all of the shutdown loads for all four  
14 units. I would like confirmation on that.

15 MR. HEACOCK: Okay.

16 MEMBER-AT-LARGE STETKAR: Even if you  
17 consider the fault, you know, a beyond-design fault --

18 MR. HEACOCK: I understand your question.  
19 Yes, I understand your question.

20 MEMBER-AT-LARGE STETKAR: -- I would still  
21 like to have some confidence on it.

22 MR. CHAPPELL: I believe there may have been  
23 one more related to a specific question on reserve auxiliary  
24 transformer winding, 41.60, but winding --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER-AT-LARGE STETKAR: That, too, though,  
2 depends a little bit on the details on the design, if  
3 it only has to pick up a small set of loads. Once I heard  
4 some uncertainty about how the actual logic for that  
5 switching is going to be performed, some of the other  
6 questions become a little bit more nebulous. So, rather  
7 than saying I want an answer on something, I'm not quite  
8 sure what the question is right at the moment.

9                   MR. HEACOCK: Okay.

10                  CHAIRMAN ABDEL-KHALIK: Jack, is this  
11 consistent with your understanding of the open items?  
12 Everything is okay?

13                  MEMBER SIEBER: Yes.

14                  CHAIRMAN ABDEL-KHALIK: Okay. All right.  
15 Well, thank you very much.

16                  We will now proceed with the staff's  
17 presentation. I understand we have taken, you know, a  
18 major chunk of your time. So, what we will do, the published  
19 agenda says we will go until 12:15 and then we will take  
20 a lunch break. So, at some reasonable point close to  
21 12:15, we will take a break.

22                  MR. MUNIZ: All right. So, this is the  
23 staff's presentation on the SER prepared for Chapter  
24 8 of the STP COLA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 My name is Adrian Muniz, Chapter PM. Here  
2 with me is Amar Pal, technical reviewer that worked on  
3 the chapter, and Neil Fabrega, contractor. This is the  
4 staffing developed in the SER.

5 So, our presentation, we are going to cover  
6 the different sections in the STP COLA ranging from the  
7 offsite power systems, one site, and a station blackout.

8 We are going to focus mainly on the departures that affected  
9 Chapter 8 that are of importance. The onsite AC power  
10 system, we will be discussing more of the open item on  
11 the DCD diesel room temperature going from 50 to 60 degrees,  
12 among other things.

13 I'm going to turn it over to Amar Pal.

14 MR. PAL: Hi. My name is Amar Pal.

15 I am going to talk about this STP COL  
16 application. The COL application contains interface  
17 requirements, quality assurance items, and other  
18 information.

19 The interface requirements include having  
20 two offsite circuits coming into the plant and the voltage  
21 and the frequency and the independence of the circuits  
22 and the site of the offsite circuits, and the independence  
23 and the impedance of the main and auxiliary transformers  
24 to match the requirements, and the control tower,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instrumentation in the control tower. Those are the seven  
2 items for the interface requirements.

3 This interface requirement is addressed in  
4 ITAAC. They will be verified by ITAAC.

5 There are a total of 31 COL information items,  
6 and staff reviewed all of them. There is some concern  
7 with issues, RAI.

8 Site-specific information, offsite power  
9 systems we will discuss later on.

10 Onsite process for the electrical load, 10  
11 years, and staff is concerned about the detail of rating,  
12 whether the total load will still meet the 95 percent  
13 of the EDG continuous load. So, staff looked at that  
14 and found it acceptable.

15 SBO coping duration, the STP has an eight-hour  
16 SBO coping duration. That is based on the DC requirements.

17 Staff looked at that, whether the eight hours is enough  
18 or not, based on Reg Guide 1.155. The requirements --

19 MEMBER-AT-LARGE STETKAR: Excuse me. I  
20 thought I read in the FSAR that there is no SBO coping  
21 duration analysis.

22 MR. PAL: There is not. It wasn't talking  
23 about the duration analysis. It is the coping period,  
24 how long they have to cope, based on three factors. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is the EDG classification, EDG reliability, and the offsite  
2 power system characteristics.

3 MEMBER-AT-LARGE STETKAR: So, in that  
4 context --

5 MR. PAL: In that context, you would  
6 determine first the eight hours or four hours, that type  
7 of thing.

8 MEMBER-AT-LARGE STETKAR: Thank you.

9 MR. PAL: And then, coping method is the  
10 AC source, and 10-minute AC source coping analysis.

11 MEMBER-AT-LARGE STETKAR: Thank you.

12 MR. PAL: So, we looked at that. In Reg Guide  
13 1.155, we find that it is a four-hour coping duration  
14 with the STP situation of .975 reliability and EDG  
15 classification of A, and worst-case P-T classification  
16 gives 24 hours. So, that we felt acceptable in these  
17 things.

18 The COL identified 14 departures. Four of  
19 them are Tier 1 departures; Tier 2 start departure, one;  
20 and Tier 2, which requires NRC approval, three; and Tier  
21 2 departures, no approval required, six. We went through  
22 all these departures and raised the issues as far as  
23 necessary.

24 COL information items are definitely

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 addressed. We looked at that, and the FSAR for  
2 establishing the level of detail. So, as offsite, onsite,  
3 and SBO.

4 The next slide is the offsite power systems.

5 We had one open item. That open item is regarding the  
6 applicability of Reg Guide 1.180 for solid-state and  
7 digital relays. The staff wrote on that RAI, and in the  
8 RAI response applicant stated that they are not going  
9 to deviate from the DCD. The DCD already addressed these  
10 testing requirements for the EMI, RFI. So, staff finds  
11 that acceptable.

12 And this section could not conclude with  
13 all of the items.

14 8.2, there are four open items. Three of  
15 them got enough information that can be resolved. These  
16 are, one is the switchyard component testing requirements.  
17 So, they have included all the things which should be  
18 tested. So, we find them acceptable.

19 Then, we have an open item issue on the failure  
20 events. They had numerous events, and we have some concern  
21 about these, whether the events are analyzed properly  
22 and corrective action taken or not, and whether they  
23 had any loss of the power in the plant. We found that  
24 they did not have a loss of safe power, and they did

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 provide some corrective action taken on some transmission  
2 lines.

3 MEMBER-AT-LARGE STETKAR: Let me interrupt  
4 you briefly in that sense. I know that you are doing  
5 a review of the license for Units 3 and 4. I know that  
6 Units 1 and 2 have a license.

7 MR. PAL: Yes.

8 MEMBER-AT-LARGE STETKAR: However, with  
9 respect to the offsite power supplies, the applicant  
10 is basically taking nine currently-operating transmission  
11 lines that are connected to Units 1 and 2 and subdividing  
12 those nine, so that they have, I believe, five now that  
13 go to Units 3 and 4 with a cross-tie between the Units  
14 1 and 2, and 3 and 4 switchyard, which I view as a cross-tie.

15 MR. PAL: Uh-hum.

16 MEMBER-AT-LARGE STETKAR: And they have four  
17 lines now that go to Units 1 and 2. To what extent does  
18 the staff look at the integrated site situation with  
19 respect to offsite power supplies, now that we are going  
20 to have four operating reactors at this site?

21 MR. PAL: Staff concentrated on Units 3 and  
22 4.

23 MEMBER-AT-LARGE STETKAR: I understand that.  
24 I'm asking, to what extent have you thought about the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 integrated site?

2 MR. FABREGA: I have not looked at it.

3 MEMBER-AT-LARGE STETKAR: Okay. Thank you.

4 MR. FABREGA: We only knew about the lines  
5 that were coming to Units 3 and 4. Therefore, I  
6 concentrated on that.

7 MEMBER-AT-LARGE STETKAR: Okay.

8 MR. FABREGA: I didn't even consider the  
9 possibility or the actual changes that were going on  
10 into the other units. That, obviously, wouldn't affect  
11 the other unit possibly. Okay?

12 I cannot make conclusions about the other  
13 units. I fully understand your question, if this is going  
14 to be an integrated thing. We probably ought to look  
15 at that.

16 MEMBER-AT-LARGE STETKAR: My concern is that  
17 suppose I add now four more units to the same site with  
18 the same nine transmission lines connected to it, and  
19 for each pair of units that I add, the staff only looks  
20 within the confines of the little box that I draw around  
21 those two units. At some point, one would think that  
22 it would be useful to step back a bit and look holistically  
23 at all four units.

24 I'm sure that -- well, I will stop there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't want to speculate about anything.

2 (Laughter.)

3 MR. PAL: Sure. The only comment I could  
4 make is the NRR should look at the change, just to Units  
5 1 and 2, and what's the impact of the offsite power system  
6 situation for their units.

7 MR. WUNDER: Yes, I think NRR is getting  
8 close. But when you make any kind of a change, anything  
9 that is described in the FSAR, you have to do an analysis  
10 and you have to determine if it causes a new or different  
11 kind of accident. You've got to determine if it causes  
12 an unresolved safety issue. If they do, then they have  
13 to come to us and we have to amend the license. So, these  
14 things aren't done in a vacuum.

15 MEMBER-AT-LARGE STETKAR: Have they done  
16 that for Units 1 and 2?

17 MR. WUNDER: In this instance, I don't know.  
18 I will ask that.

19 MR. HEACOCK: It's preliminary at this point  
20 in time. We will have to go through, like he was saying,  
21 we have to go through the 50.59 process for this site  
22 and look at the changes and the effects.

23 The actual changes won't be in effect for  
24 some time, but, yes, we are looking at that ahead of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time. Otherwise, we would not have actually gone to the  
2 design that we have that we showed to ensure that we  
3 did not have a situation that really lessened the  
4 reliability of the offsite source.

5 MR. HEAD: But we are expecting not to need  
6 an amendment to do this or, if we thought that was likely  
7 at all, then we would be not doing this design. Because  
8 Units 1 and 2 have to maintain their licensing basis,  
9 design basis integrity. That is crucial in all our  
10 thinking, is 1 and 2, and the switchyard is, obviously,  
11 a significant part of that.

12 So, we have looked at it holistically, even  
13 though it is 50.59 in one set of units and a COLA in  
14 the other set.

15 MR. HEACOCK: We also have a process in place  
16 that looks at -- we call them interface evaluations.  
17 So, any effects from 3 and 4 back on 1 and 2, so we identify  
18 from there, and then we take them into the 1 and 2 process.

19 MEMBER-AT-LARGE STETKAR: The reason, I mean  
20 other than kind of a generic concern, specifically, the  
21 reason I kind of looked at this is from this perspective  
22 of Units 3 and 4 -- and I know nothing about the licensing  
23 of 1 and 2. So, from the perspective of Units 3 and 4,  
24 if I go back to that north set of tower lines, you, basically,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say that the east tower and the center tower are not  
2 independent in Units 3 and 4. The west tower is your  
3 second independent.

4 MR. HEACOCK: Right.

5 MEMBER-AT-LARGE STETKAR: That tower, as  
6 I understand it, contains two transmission lines for  
7 Units 3 and 4. The east and the center towers contain  
8 all of the Units 1 and 2 transmission lines in that corridor.

9 You lose that. Now you're single, and you are down to  
10 one transmission line from Velasco for Units 1 and 2.

11 MR. HEACOCK: On the center towers, we have  
12 one line. We do have one transmission line going up.  
13 We have three lines total.

14 MEMBER-AT-LARGE STETKAR: Well, you don't  
15 take credit for Hillje --

16 MR. HEACOCK: The Hillje, correct. Correct.

17 MEMBER-AT-LARGE STETKAR: Hillje, I'm sorry.  
18 That's on the center --

19 MR. HEACOCK: Yes, the center tower.

20 MEMBER-AT-LARGE STETKAR: -- the center  
21 tower. The center tower has got Hillje and Elm Creek.

22 MR. HEACOCK: Yes.

23 MEMBER-AT-LARGE STETKAR: And the east tower  
24 has got Elm Creek 18 and W. A. Parish on the 30 --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Right.

2 MEMBER-AT-LARGE STETKAR: And Parish and  
3 Elm Creek and Hillje 64 are Units ½ lines.

4 MR. HEACOCK: Correct. You are correct,  
5 yes.

6 MEMBER-AT-LARGE STETKAR: So, if they go  
7 out, you are down to the one Velasco 18 line to feed  
8 Units 1 and 2?

9 MR. HEACOCK: Yes.

10 MEMBER-AT-LARGE STETKAR: Okay. Which is  
11 why I am back to, how many lines can feed --

12 MR. HEACOCK: And the cross-tie. And the  
13 cross-tie between 3 and 4, and 1 and 2. So, we actually  
14 have those two.

15 MEMBER-AT-LARGE STETKAR: Yes. Okay.

16 MR. HEACOCK: So, we are not down to one.  
17 We are down to two.

18 MEMBER-AT-LARGE STETKAR: We have spent  
19 enough time on this. I think we all understand where  
20 we are.

21 CHAIRMAN ABDEL-KHALIK: Okay, please  
22 continue.

23 MR. PAL: So, the other open item talked  
24 about the communication protocols between the STP and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the transmission operator during the risk-sensitive  
2 maintenance activities. So, they gave us that protocol.  
3 So, we found that acceptable.

4 The only open item is regarding the cable  
5 testing, which are susceptible to moisture. We are working  
6 with the applicants to resolve the issue.

7 On the specific item of interest,  
8 supplemental information on the transmission lines, which  
9 in their description in the main part I think these are  
10 discussed very detailed by STP. I think I don't have  
11 much to add on these, except these main transformers  
12 are three single-phase transformers. Three single-phase  
13 transformers, each we gave 537.5; total, 1612.

14 Another thing in here before is the built-in  
15 contingency analyses, which are in the voltage level  
16 at the switchyard. If the voltage is below a certain  
17 level or not within the allowable limits, they are going  
18 to inform the STP operator to take action on that.

19 CHAIRMAN ABDEL-KHALIK: I wonder if this  
20 would be a good point to stop, and we will continue with  
21 Section 8, onsite AC power system, after lunch.

22 MR. PAL: I believe so. I believe so.

23 CHAIRMAN ABDEL-KHALIK: All right. So, at  
24 this time, we will recess for lunch. We will be back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 at 1:15.

2 (Whereupon, the foregoing matter went off  
3 the record for lunch at 12:18 p.m. and went back on the  
4 record at 1:15 p.m.)

5

6

7

8

9

10

11

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 1:15 p.m.

3 CHAIRMAN ABDEL-KHALIK: At this time, the  
4 staff will continue their presentation of Chapter 8.  
5 Please continue.

6 MR. PAL: Good afternoon.

7 We want to start with Chapter 8.3.1, Onsite  
8 AC Power System. That section, we have two open items.  
9 One of them can be closed based on the additional  
10 information.

11 We received that regarding an isolation  
12 device for I&C site PIP, and the applicant agreed to  
13 have some testing done based on vendor recommendations.  
14 So, based on that, we can close that item.

15 The open item that is still there is the  
16 diesel generator room temperature. In our original RAI,  
17 they said the coolant would be qualified for that  
18 temperature. If it can't be qualified, then that will  
19 be relocated in a separate room. But they also said that  
20 the coolant qualification will be based on Section 3.11.

21 Section 3.11 has the room temperature indicated in the  
22 DC as 50 degrees. It is not 60 degrees. So, they are  
23 going to revise that table to make the 60-degree temperature,  
24 and that's what the open items are about.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TONACCI: Excuse me a second. Does that  
2 address the open item that we had --

3 CHAIRMAN ABDEL-KHALIK: Not fully. I guess  
4 we talked about that before. It is not only the testing  
5 that has to be done at 60 degrees to verify the performance  
6 of the diesels. We talked about the capacity being sort  
7 of oversized to compensate for the increasing inlet air  
8 temperature.

9 MR. TONACCI: Right.

10 CHAIRMAN ABDEL-KHALIK: But we also had a  
11 concern about the operators.

12 MR. TONACCI: Exactly right, and that will  
13 be in Chapter 9.

14 CHAIRMAN ABDEL-KHALIK: Okay.

15 MR. TONACCI: That part, we will defer to  
16 Chapter 9.

17 CHAIRMAN ABDEL-KHALIK: Okay.

18 MR. TONACCI: But, as far as equipment, are  
19 we done with that piece of it or is there more that you  
20 want to hear?

21 MEMBER-AT-LARGE STETKAR: The machine has  
22 to be tested.

23 CHAIRMAN ABDEL-KHALIK: If they are going  
24 to qualify it to 60, then --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TONACCI: Yes. Yes, we are. Then, it  
2 should be okay.

3 CHAIRMAN ABDEL-KHALIK: But we will just  
4 wait to see your response to the question with regard  
5 to Chapter 9.

6 MR. TONACCI: Okay.

7 MR. HEAD: With regard to the operators?

8 CHAIRMAN ABDEL-KHALIK: Correct, yes.

9 MR. HEAD: Okay. Jay spoke to that some  
10 last -- Jay Phelps, the Operations Manager, spoke some  
11 to it last time we were here. So, you would be needing  
12 --

13 CHAIRMAN ABDEL-KHALIK: We will revisit it  
14 when Chapter 9 is looked at.

15 MR. HEAD: Okay. All right.

16 CHAIRMAN ABDEL-KHALIK: Just a heads-up  
17 here.

18 MR. HEAD: Okay.

19 MR. PAL: The next slide, I think STP talked  
20 about that in the things about this Departure 8.3-1,  
21 all these, 10 years, and the rating of 10 years for --

22 CHAIRMAN ABDEL-KHALIK: Hold on a second.  
23 We need to stop this noise.

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   Okay, we're back on.

2                   MR. PAL: As I said before, this Departure  
3                   18.1 was discussed extensively by the STP. So, really,  
4                   we can skip that.

5                   This rating change, voltage change, and the  
6                   rating change, and motor change. The Departure 2.12-2,  
7                   also additional division for power supply for I&C circuits  
8                   which is non-interruptible. It is an interruptible power  
9                   supply. So, we have some concern about this, what happens  
10                  to the 10 minutes for CTG to come up and losing power  
11                  for that site. But this division is not important. This  
12                  is not uninterruptible power supply. They can tolerate  
13                  the loss of power for 10 minutes. So, based on that,  
14                  we found this acceptable. It is an enhancement.

15                 Next is 8.3.2, DC Power System. Really,  
16                 there is nothing much changed on this section. There  
17                 is one open item, which is already discussed in 8.2.1  
18                 because that same item is applicable here. That is  
19                 important here, too.

20                 The next is station blackout. This ABWR  
21                 design is going to cope with some blackout with an AAC  
22                 power source, which is CTG which will be available within  
23                 10 minutes.

24                 The DCD had the requirements as well as the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Reg Guide, and the rule requires that you have to  
2 demonstrate that the CTG can be connected to the safety  
3 process within 10 minutes. The applicant made that comment.

4 They have that in the DCD also and in their writeup,  
5 that the safety process will be energized within 10 minutes.

6 MEMBER-AT-LARGE STETKAR: Let me ask you,  
7 because I asked the applicant this. How do you have any  
8 assurance, if the requirement is that the CTG shall be  
9 up-to-speed and at voltage in less than 10 minutes, and  
10 according to acceptance criteria, that means to me 9.9999  
11 minutes is acceptable, but, indeed, human beings can  
12 perform all of the required manual switching operations  
13 in .00001 minute.

14 MR. PAL: Yes, exactly the same concern we  
15 had. We had an RAI on that. Finally, we agreed that  
16 they have to do a test, an initial test, to show that  
17 this can be done. So, we are counting on the test.

18 MR. FABREGA: I think Reg Guide 1.155  
19 requires that they demonstrate by test that they can --

20 MR. PAL: Connect.

21 MR. FABREGA: -- connect within 10 minutes.

22 MEMBER-AT-LARGE STETKAR: Okay. Including  
23 all --

24 MR. PAL: Including the bus and whatever,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all the operator actions. These are not automatic. This  
2 will be done manually. So, all these things together,  
3 and not just the bus. That is the key thing here, the  
4 keyword, not just the safety bus within 10 minutes.

5 MEMBER-AT-LARGE STETKAR: Yes, you don't  
6 necessarily have to start the loads from the safety bus.

7 MR. PAL: That's right, not the load.

8 MEMBER-AT-LARGE STETKAR: But you need to  
9 have 4.16 kV on that bus.

10 MR. PAL: Yes. Exactly. Yes.

11 MEMBER-AT-LARGE STETKAR: And the  
12 implication is such that you can start loads at that  
13 time.

14 MR. PAL: Absolutely. Absolutely. So, the  
15 test is the only thing which would verify that, yes,  
16 in fact, it can be done. And that is the same concern  
17 we had. We talked about that; less than 10 minutes could  
18 be 9.99.

19 MEMBER-AT-LARGE STETKAR: I mean that's all  
20 acceptance criteria is --

21 MR. PAL: Absolutely.

22 MEMBER-AT-LARGE STETKAR: -- 9.99 is fine.

23 MR. PAL: Exactly. That's less than 10  
24 minutes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER SIEBER: I think we have to wait and  
2 see what the startup characteristics are. My experience,  
3 that is actually a pretty small combustion turbine as  
4 far as peakers, peaking units go. My experience with  
5 them is that they start up pretty fast.

6           MEMBER-AT-LARGE STETKAR: They may, Jack.  
7 I'm just a bit concerned about the fact that if, indeed,  
8 the logic automatically re-energizes the 4-kV non-safety  
9 buses, then the operators not only need to connect something  
10 that is running at voltage unloaded to a dead bus, they  
11 need to undo a bunch of things that have already been  
12 done automatically. That takes a little bit of time and  
13 thinking.

14           MEMBER SIEBER: It's not a little thought.

15           MEMBER-AT-LARGE STETKAR: That's right.

16           MEMBER SIEBER: It's the thought that takes  
17 the time.

18           MEMBER-AT-LARGE STETKAR: That takes the  
19 time. If, indeed, it was just up and running idle unloaded,  
20 and all they had to do was close the output breaker,  
21 that is the easy way to do it.

22           MEMBER BROWN: Maybe if we are talking the  
23 safety buses and the CTGs, let me bring up this one point.  
24 I mentioned this to you prior to re-engaging here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           In this 10-minute requirement, in the SER  
2 when you are talking about Departure 8.3-3, you all brought  
3 up the fact that the Division 1, Class 1E, and the rest,  
4 I guess it is Division 1, Class 1E, the bus supplies  
5 power to three groups of non-Class E, 1E, fine motor  
6 control rod drive motors. Those motors are used as backup  
7 for scram for driving in everything.

8           So, I guess you were talking about 10 minutes,  
9 but this says the priority for that bus is to have the  
10 diesel start up, and that's the first choice. That was  
11 in your SER writeup on this thing. I have forgotten how  
12 you phrased it.

13           It said, "It is important that the first  
14 available power supply or standby power be available  
15 for the motors. Therefore, a diesel-supplied bus was  
16 chosen as the first source of AC power. In a combustion  
17 turbine, supplied PIP bus is the second back-up source."

18           So, if you had loss of all power and you  
19 need the fine motor control rod drives, you don't have  
20 them if you said the CTG starts up and brings power into  
21 these buses. And you said you do not start the diesels.

22           Well, how come? That seemed to be a dichotomy,  
23 and I don't know whether I've got the flavor right. You  
24 need the fine motor control rod drives, but, yet, that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 diesel has got to start.

2 MR. HEACOCK: Yes, and it will.

3 MEMBER BROWN: But will it be started just  
4 because you scram -- presumably, if you lose all power,  
5 you scram now, correct?

6 MR. HEACOCK: Yes.

7 MEMBER BROWN: That's the way my plants were.

8 MR. HEACOCK: Don't get me into the scram.

9 Let me go straight from the loss of offsite sources.

10 The under-voltage relays on the  
11 safety-related bus will send a signal to the diesel  
12 generators in each division and start that diesel generator.

13 That is No. 1.

14 The combustion turbine is there as a backup  
15 in case the diesel generator does not start and pick  
16 up the bus. Then, you have the combustion turbine  
17 generator source to pick up that bus at a point in time  
18 after it comes up-to-speed.

19 MEMBER BROWN: Another part of your all's  
20 writeup, I've just looked at the FSAR. It says the CTG  
21 comes on first, and the diesels don't start. I mean,  
22 did I read that wrong?

23 MR. HEACOCK: Yes, I think you might have  
24 that wrong because the diesels are required --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: So, they will start under  
2 those circumstances?

3 MR. HEACOCK: Correct. Correct. They are  
4 required to --

5 MEMBER BROWN: The only time you have to  
6 connect the CTG to those Division 1E buses is if the  
7 diesels become unavailable or fail to start?

8 MR. HEACOCK: Correct. The CTG is the backup  
9 to the diesel generator.

10 MEMBER BROWN: Okay. All right. I'm fine  
11 then.

12 MR. HEACOCK: Okay.

13 MEMBER BROWN: Thank you.

14 MR. HEACOCK: Uh-hum.

15 MR. HEAD: Can I follow up, though? This  
16 question you alluded to, do we need to see as more design  
17 detail or something? Is that a follow-up item? Or what  
18 exactly --

19 MEMBER SIEBER: No, I don't think we need  
20 to see that, but I think that is the ultimate --

21 MEMBER-AT-LARGE STETKAR: I think our  
22 concern is that we want to be sure that the staff really  
23 looks at this issue carefully because the 10-minute startup  
24 requirement for the CTG, coupled with at least the possible

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confusion about how the design is actually working  
2 automatically and manually, leads to the impression that  
3 the operators may not have very much time to actually  
4 connect power to the Class 1E bus from a source that  
5 won't be overloaded when they start that first load.

6 In other words, and as I said, I'm more  
7 concerned about the fact that the CTG may be picking  
8 up things automatically that the operators need to undo  
9 before they can actually close the output breaker, and  
10 that whatever the demonstration, whatever tests or process  
11 you use to confirm that this can be done is not simply  
12 limited to the fact that, okay, the CTG is up to voltage  
13 and all the operator needs to do is close the output  
14 breaker, because that is not correct.

15 MR. PAL: Exactly. That is not correct.

16 MR. HEACOCK: Right. So, you have to shed  
17 a bus.

18 MEMBER-AT-LARGE STETKAR: You might need  
19 to shed buses.

20 MR. HEACOCK: Yes, that's the intent, to  
21 shed buses.

22 MEMBER-AT-LARGE STETKAR: That needs to be  
23 carefully considered in that time.

24 MEMBER SIEBER: The discussion really went,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we talked about where that procedure would go; decided,  
2 hopefully, that it would be in the EOPs. And it was my  
3 desire that staff look at the EOPs to see how complex  
4 that was. I don't know that we need to look at them.

5 I would feel more comfortable if I saw them, but I don't  
6 think you're obligated to give them to me because that  
7 is pretty detailed.

8 MR. HEACOCK: I'm just thinking that, as  
9 part of the --

10 MEMBER SIEBER: On the other hand, to say  
11 with certainty that this would work, you need to know  
12 the starting interval and what the procedure looks like,  
13 and some kind of human factors analysis that would say  
14 an operator could reasonably do --

15 MEMBER-AT-LARGE STETKAR: There's guidance  
16 for looking at the amount of time available to do something  
17 and the amount of time that is required to do something  
18 with some margin to compensate for operator delays or  
19 confusion, or whatever. I mean there are methods to do  
20 that that people use in the passive plant designs, for  
21 example, to look at manual initiation of safety functions.

22 That same type of process in an analytical  
23 sense would seem to apply here, where you are not quite -- I  
24 mean maybe you are certain about how long it takes the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CTG to start up and reach voltage, but there is some  
2 uncertainty about that. It isn't going to be a minute.

3 MR. HEACOCK: No. No, it's not.

4 MEMBER-AT-LARGE STETKAR: It's probably not  
5 going to be 9.9999 minutes.

6 (Laughter.)

7 MR. HEACOCK: No, it's not.

8 MEMBER-AT-LARGE STETKAR: But somewhere  
9 between there.

10 MEMBER SIEBER: It might be two or three  
11 minutes.

12 MEMBER-AT-LARGE STETKAR: It might be two  
13 or three or four or five.

14 MEMBER SIEBER: My feeling is, for the staff  
15 to say this is okay, they need to look at the starting  
16 time tests, EOPs, and some analysis --

17 MEMBER-AT-LARGE STETKAR: That's right,  
18 yes.

19 MEMBER SIEBER: -- of human factors  
20 implications as to whether they can complete the actions  
21 with reasonable accuracy in the amount of time that is  
22 allowed.

23 MS. BANERJEE: Is there an ITAAC that could  
24 be referenced?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: I don't believe we have one  
2 presently. It is the test program that basically, like  
3 we said on the RAI, that we basically committed to doing.

4 We will have to show this from a standpoint  
5 of like you're saying, from the standpoint that CTGs  
6 come up-to-speed and the operator has enough time to  
7 actually shed buses and then close the breakers to repower  
8 the bus to start, to be within that 10-minute timeframe.

9 Because we all recognize that we are up against a timeframe.  
10 We don't know what we are actually going to get. Therefore,  
11 we are going to go through this and look at this.

12 But there was not an ITAAC space that we  
13 had that in.

14 MEMBER-AT-LARGE STETKAR: Where would the  
15 staff follow up on this? Where and when? And, yes, I'm  
16 talking process.

17 MR. PAL: There is no open item on it, no  
18 open item, because we, staff, believe that all the documents  
19 require that you have to have a test done, and tests  
20 should verify that 10 minutes is achievable. Based on  
21 that comment, then, verification, staff believes that  
22 should be adequate.

23 MS. BANERJEE: Is there a confirmatory item  
24 on this?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. FABREGA: No.

2 MEMBER SIEBER: The question is, since you  
3 have offsite power from multiple sources, and you have  
4 diesel generators, is this combustion turbine required  
5 or just a really nice backup to have? If it is required,  
6 then you have to do this work. If it is just a really  
7 nice backup to have, you probably don't have to do all  
8 the work. On the other hand, it would be foolish to spend  
9 all that money and not do the work.

10 MEMBER-AT-LARGE STETKAR: Well, we have not  
11 asked, I mean I think Maitri asked the pertinent question.  
12 You have mentioned a test to demonstrate that, indeed,  
13 this would be done. Where is the commitment to perform  
14 that test documented?

15 MR. HEACOCK: I have to try to remember off  
16 the top of my head.

17 MEMBER-AT-LARGE STETKAR: She asked, is  
18 there an ITAAC? Okay, well, if there's not an ITAAC,  
19 where is the commitment to perform that test?

20 MR. HEACOCK: Yes, that's what I'm trying  
21 to remember.

22 MEMBER-AT-LARGE STETKAR: So that even the  
23 staff has it as a potential audit item, if it is the  
24 first COL audit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. BANERJEE: And a confirmatory item to  
2 the SER is necessary, right?

3 CHAIRMAN ABDEL-KHALIK: This is a CTG start  
4 test?

5 MR. TONACCI: I think the question is pretty  
6 clear: how do we make sure the operator has the time  
7 he needs to safely energize these buses?

8 MEMBER-AT-LARGE STETKAR: That's right.  
9 And if, indeed, if the staff, at least at the COL phase,  
10 is saying that you are happy that you have enough commitment  
11 from the applicant that they are going to do a test to  
12 demonstrate that capability, okay, I personally could  
13 live with that. I don't have to.

14 But I think that we would like to be  
15 comfortable that there, indeed, is an actual commitment  
16 to perform that test, so that the staff can later follow  
17 up, if it is a later followup.

18 MR. TONACCI: I agree. I think your question  
19 is a very good one. Let's go back and do some homework  
20 and correct this as an open item. We will close it,  
21 hopefully, next session.

22 MEMBER-AT-LARGE STETKAR: Good. Thank you.

23 MR. FABREGA: Can I interject something here?  
24 If they are going to meet 10 CFR 50.63, then they need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to make sure that either they have a unit CTG, an alternate  
2 AC that is capable of coming to speed with being loaded,  
3 capable of being loaded in 10 minutes, or they have to  
4 perform a coping analysis. Okay?

5 So, their commitment is to 10 CFR 50.73.  
6 So, if they do meet that commitment, then it is a moot  
7 point.

8 We can follow up, but it is only if they  
9 don't meet the 10 minutes. Then, they either have to  
10 perform a coping analysis or they need to -- or they  
11 are not meeting 10 CFR 50.63.

12 CHAIRMAN ABDEL-KHALIK: But the question  
13 is, how will the staff keep track of that commitment?  
14 That is the issue at the table right now.

15 MEMBER-AT-LARGE STETKAR: 50.63 commitment,  
16 we are still talking about that tracking issue.

17 MEMBER SIEBER: Right.

18 CHAIRMAN ABDEL-KHALIK: Let's just move  
19 forward, please.

20 MR. PAL: In this section, we have one open  
21 item. The open item is exactly to the SBO procedures.  
22 They committed to comply with that guidance, guidelines  
23 of NUMARK, which requires three procedures. One is the  
24 SBO procedure. One is the offsite power procedure. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 other one is the weather procedure. So, they are going  
2 to follow that. So, this open item can be closed.

3 The next slide is the staff findings. Staff  
4 thinks that there is sufficient information provided  
5 on the offsite power system, including interconnections  
6 and reliability and stability.

7 Finds that sufficient details about all  
8 site-specific safety-related load increase to EDG so  
9 that the maximum expected -- we talked about that. We  
10 did 95 percent of the continuous rating of the EDG.

11 We find that the safety-related buses have  
12 three supplies. One is from UAT, and one is RAT A, and  
13 the other one is RAT B. So, we have two alternate offsite  
14 power sources, but they cannot achieve as the alternate  
15 power source because of some limitations of the separation.

16 Then, we have the EDG connection and the  
17 AC source connection.

18 Two of the three divisions are normally fed  
19 from the offsite normal power source, and the power going  
20 from alternate offsite power source we discussed before.

21 Loss of transformer; one bus still gets power from the  
22 alternate power source, offsite power source.

23 The SBO, they have the AAC power source with  
24 seven days of fuel capacity. And additionally, one other

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point here, they have a battery capacity for eight hours  
2 as a backup. So, this ABWR design has two methods of  
3 coping, battery coping and AAC power source coping.

4 And on top of that, because of the two units  
5 together, they have two alternate AC power sources on  
6 the existing plans, with two on each side. You will recall  
7 only one AAC power source because you don't assume both  
8 units in the station blackout at the same time. So, that  
9 way, it is also an additional feature. We can consider  
10 that.

11 MEMBER-AT-LARGE STETKAR: You'll be sorry  
12 you mentioned that.

13 (Laughter.)

14 Does each combustion turbine have sufficient  
15 capacity to power all the safety loads -- let me not  
16 say, "all" -- the necessary safety loads on both units  
17 simultaneously? In other words, if I'm down to one  
18 combustion turbine generator, can I --

19 MR. PAL: I believe so because it is --

20 MEMBER-AT-LARGE STETKAR: I don't believe  
21 anything.

22 (Laughter.)

23 I'm going to ask the applicant to answer  
24 this one.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Basically, we have sized the  
2 CTG to be able to handle two safety divisions in the  
3 unit. You only need particularly generally just one safety  
4 division to shut down and stay shut down. So, yes, you  
5 could have one unit and one on the other unit, power  
6 at the same time.

7 MEMBER-AT-LARGE STETKAR: At the same time?

8 MR. HEACOCK: Cross-tie. We didn't get into  
9 talking about this cross-tie, but we do have a --

10 MEMBER-AT-LARGE STETKAR: Right, right.  
11 But, I mean, since the staff brought it up, I thought  
12 I would ask

13 MR. HEACOCK: Yes. That was the intent.

14 MEMBER-AT-LARGE STETKAR: So, it has got  
15 sufficient capacity for two safety divisions?

16 MR. HEACOCK: Yes.

17 MEMBER-AT-LARGE STETKAR: Two safety buses?

18 MR. HEACOCK: Yes.

19 MEMBER SIEBER: It could be one of each.

20 MEMBER-AT-LARGE STETKAR: It could be one  
21 and one; it could be two and zero. But, you know, with  
22 the common switchyard and the offsite power alignment,  
23 it is quite likely you are going to lose offsite power  
24 to both units at the same time now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEACOCK: Yes.

2 MEMBER-AT-LARGE STETKAR: You still have  
3 the six diesels.

4 MR. HEACOCK: Six diesels and then two  
5 combustion turbines.

6 MEMBER-AT-LARGE STETKAR: And one more  
7 combustion turbine. You're starting to get pretty small  
8 here, but it is another level of assurance, though --

9 MR. HEACOCK: Yes, right.

10 MEMBER-AT-LARGE STETKAR: -- that, indeed,  
11 with the size of the turbine that you have installed,  
12 you can, in real extremist --

13 MR. HEACOCK: Correct.

14 MEMBER-AT-LARGE STETKAR: -- power one bus  
15 on each. So, that's good.

16 CHAIRMAN ABDEL-KHALIK: Please continue.

17 MR. PAL: Okay. We have eight open items  
18 and six currently closed. For two, we are still working.  
19 And that's about it for staff.

20 CHAIRMAN ABDEL-KHALIK: Okay. Well, thank  
21 you.

22 Go ahead.

23 MEMBER BROWN: I have one other question.

24 CHAIRMAN ABDEL-KHALIK: Yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER BROWN: You mentioned on page 8-19,  
2 you were talking about the underground cable for Dow  
3 line 27. You brought up the issue of buried cables are  
4 presently an item of interest. You asked what programs  
5 did they have to avoid or arrest degradation of the cable  
6 insulation. Their response was that it is a cross-linked  
7 polyethylene metallic shield, and it is installed in  
8 duct banks, and that it is also qualified for submergence.

9                   Then, you went on to say you found that  
10 acceptable because it is reasonably protected against  
11 moisture, potential moisture in the underground trench,  
12 and therefore, it should be okay.

13                   Now I got the flavor that this was -- is  
14 this really submerged all the time? That is the question.

15                   Is this really going to be under water? I don't know  
16 what the water level is, the underground water level  
17 is. But in the duct bank and trench --

18                   MEMBER-AT-LARGE STETKAR: This much  
19 overgrade.

20                   (Laughter.)

21                   MR. HEACOCK: We have a very high water table.

22                   MEMBER BROWN: That is what I thought.

23                   MR. HEACOCK: And there is a very good chance  
24 it will be submerged, but the cable is designed for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 continuous submergence.

2 MEMBER BROWN: Okay. My next question  
3 is -- I'll take you on that -- but now, if it is going  
4 to be submerged, is there a standard by which you qualify  
5 these for the 40 to 60 years that it may be in operation?

6 MR. HEACOCK: This does not fall, to kind  
7 of separate, this does not fall under the plant's  
8 requirement. This is part of the transmission  
9 requirements, No. 1. This is not our cable. It is offsite.

10 And as far as the long-term viability of  
11 that, that falls on the transmissions and falls under  
12 their requirements and their standards for what they  
13 need to make sure.

14 What it is, it is submarine cable. It will  
15 have a qualified life. Off the top of my head, I don't  
16 know what that life is, although we can chat with the  
17 transmission company to find out exactly what that is.

18 MEMBER BROWN: That would be of interest,  
19 just to know what the time is. I mean I went back and  
20 read some more after I came up with the question and  
21 found I guess this is only one of a number of cables,  
22 of sources.

23 MR. HEACOCK: Yes, it is one of a number  
24 of sources. This is also a high-voltage cable, not a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 medium-voltage. The interest is really on medium-voltage  
2 within the plants themselves that are not designed for  
3 continuous submergence.

4 MEMBER BROWN: Well, yes, I understand that  
5 point.

6 MR. HEACOCK: Yes.

7 MEMBER BROWN: But even a high-volume unit,  
8 what is it, 345-kV cable?

9 MR. HEACOCK: Three hundred and  
10 forty-five-kV line.

11 MEMBER BROWN: Okay. That's nice to have  
12 under water.

13 MR. HEACOCK: Well, I'll tell you, we put  
14 them in all the places, actually.

15 MEMBER BROWN: That's fine. I just would  
16 like to know what kind of characteristics or what type  
17 of lifetime qualifications that it has got.

18 MR. HEACOCK: Okay.

19 MEMBER BROWN: Even though it is not yours,  
20 I guess.

21 MR. HEACOCK: Yes, it is not ours, but we --

22 MEMBER BROWN: You have to live if it fails.

23 MR. HEACOCK: Correct. We can talk to the  
24 transmission and find out what that is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay.

2 MEMBER-AT-LARGE STETKAR: Evan, you did say,  
3 though, it is a qualified submarine cable?

4 MR. HEACOCK: It is designed for continuous  
5 submergence, correct.

6 MEMBER SIEBER: That's different than  
7 qualified submarine cable.

8 (Laughter.)

9 MR. HEACOCK: Yes.

10 CHAIRMAN ABDEL-KHALIK: At this time, I would  
11 like to --

12 MEMBER BROWN: My submarine cables are  
13 qualified for submarines, but they are not submerged  
14 all the time.

15 (Laughter.)

16 CHAIRMAN ABDEL-KHALIK: Before we move on  
17 to Chapter 16, I would like to again go through the process  
18 with the staff of capturing all the open items that came  
19 up during their presentation.

20 MEMBER SIEBER: I would like to ask a question  
21 on Chapter 8. When I reviewed that, there was one open  
22 item that was not resolved at the time the SER was written.

23 It had to do with the reference to the code for solid-state  
24 relays and protection devices, and referred to EMI and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 RFI interference. The code that was referenced did not  
2 discuss that because it probably wasn't an issue with  
3 the old mechanical relays.

4 But having personally experienced EMI issues  
5 and RFI issues with solid-state protection systems, I  
6 would like to know how that open item was resolved.

7 MR. PAL: We talked about that in the  
8 beginning. They are staying with the DC requirements,  
9 the BWR DCD duality. They indicated that they are going  
10 to do a second test by IEEE standards, which are included  
11 in the Reg Guide 1.180. Since they are not taking any  
12 departure from the DCD, we accept that.

13 We've got it addressed already in the Chapter  
14 7, 7(a) I believe.

15 MR. HEACOCK: Let me add one other item to  
16 that. As part of our overall qualifications, like you  
17 said, Chapter 7, we did invoke an electromagnetic  
18 compatibility standard that we would have to meet for  
19 all of our safety-related devices, electronic devices,  
20 not only in the I&C process, but also the electronics  
21 for power. We are invoking that through --

22 MEMBER SIEBER: That goes into protective  
23 relaying?

24 MR. HEACOCK: Protective relaying. It will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 go for any of the safety. We are invoking that in our  
2 specifications to make sure that they follow that.

3 MEMBER SIEBER: Now, well, I guess that  
4 answers my question. From a regulatory standpoint, having  
5 had an interest in this for over 20 years, I have learned  
6 that as recently as last year there are still issues  
7 because solid-state protection relays in other devices  
8 used to protect electrical systems are so fast, that  
9 coordination sometimes becomes a problem.

10 In other words, you end up with a race of  
11 things going on, and sometimes you get locked out. Has  
12 that been an issue? Do you plan to look at it, either  
13 through design space or by testing, to make sure that  
14 that is not a possibility with the protection schemes  
15 that you set up in your switchyard and your vital buses,  
16 and so forth?

17 MR. HEACOCK: Well, there being a big  
18 difference between what we will do in the plant itself  
19 for the safety compared to what we do in the switchyard,  
20 but looking at the safety first, yes, it will be an issue.

21 We have to look at coordination of all of our devices,  
22 make sure we don't get in a relay race, that something  
23 upstream trips before the downstream devices have a chance.

24 MEMBER SIEBER: That's right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MR. HEACOCK: So, that is just practical  
2 coordination. You are correct, these things are a lot  
3 faster. But we will look at them, make sure that the  
4 coordination does exist.

5           MEMBER SIEBER: Yes, there seems to be more  
6 surprises these days than there were when I started in --

7           MR. HEACOCK: You're correct. They are very  
8 sensitive to certain harmonics. They haven't got  
9 necessarily all the harmonics worked out of them. The  
10 new ones that we are looking at will have a much better  
11 situation, but sometimes they do have some --

12          MEMBER SIEBER: Well, one other thing I would  
13 point out is that, for example, the power supply buses  
14 that feed the power to operate these devices, sometimes  
15 they are a contactor for other devices on that same bus,  
16 the contactor itself being a big inductive device, and  
17 the contacts that open and close in time will give you  
18 big spikes --

19          MR. HEACOCK: Yes.

20          MEMBER SIEBER: -- in harmonics that, for  
21 example, can reset the counters and timers to zero, and  
22 do other things like that. So, that sometimes they will  
23 lock out on their own because some relay down the road  
24 that you probably hadn't even thought of, a contactor

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 opened or closed when you weren't planning on that to  
2 happen.

3 I would think that, when you try all this  
4 stuff out, periodically, you would look at the wave shapes  
5 on the bus to make sure that you aren't getting some  
6 wild spikes on there.

7 MR. HEACOCK: You are correct, from other  
8 devices causing inductive kicks or passive kicks even --

9 MEMBER SIEBER: Right.

10 MR. HEACOCK: -- that throw your signals.

11 That will end up being generally -- I am going to say  
12 it is very generally, as when we do operate, we will  
13 look at that from the testing standpoint to make sure.

14 MEMBER SIEBER: Right.

15 MR. HEACOCK: But, specifically, sitting  
16 down and trying to look for those inductive items, those  
17 are usually hard to find. And like you're right, there's  
18 something there that --

19 MEMBER SIEBER: It's not always there.

20 MR. HEACOCK: Yes.

21 MEMBER SIEBER: But when it's there, it is  
22 bad.

23 MR. HEACOCK: And one of the items, and this  
24 goes for especially our existing units, we do put in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shorts, you know, diode-resistant-type shorts, to knock  
2 off those off the relays that do produce those typically.

3 MEMBER SIEBER: Super. That will do it.

4 MR. HEACOCK: Yes.

5 MEMBER SIEBER: Okay. Thank you.

6 MR. HEACOCK: Uh-hum.

7 CHAIRMAN ABDEL-KHALIK: Would you like to  
8 go for the open items list, so that we can confirm before  
9 we move on to --

10 MR. WUNDER: Yes, sir. At this point, I think  
11 STP, before the break, went through all the ones that  
12 applied to them.

13 CHAIRMAN ABDEL-KHALIK: Yes.

14 MR. WUNDER: So, just from this afternoon's  
15 session, we are still looking at the issue of diesel  
16 generator room having an ability which is going to be  
17 addressed in our Chapter 9 presentation. Our big issue  
18 is how is the staff confident at this point at the licensing  
19 phase that, when the plant is operational, they will,  
20 in fact, be able to meet the requirements of 50.63 and  
21 power these safety buses with the CTG within 10 minutes.

22 I'm not clear. Are we good with the submerged  
23 cable issue?

24 CHAIRMAN ABDEL-KHALIK: Yes. Yes. That's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 closed.

2 MR. WUNDER: Yes. Okay. Then, those are  
3 two remaining issues.

4 MR. HEAD: I thought we owed you the --

5 MEMBER BROWN: The qualification, yes,  
6 whatever the lifetime.

7 MR. HEAD: We will keep that one.

8 MEMBER BROWN: Yes, that is the only thing.

9 MR. HEAD: Okay.

10 MEMBER BROWN: How is it qualified, and  
11 what's the lifetime?

12 MR. HEAD: Yes.

13 CHAIRMAN ABDEL-KHALIK: Jack, John, is there  
14 anything else in addition to this?

15 MEMBER SIEBER: No.

16 MEMBER-AT-LARGE STETKAR: No.

17 CHAIRMAN ABDEL-KHALIK: Thank you.

18 MS. BANERJEE: Is there a question on staff  
19 review of all four units for the whole entire electrical  
20 system?

21 CHAIRMAN ABDEL-KHALIK: I think that is  
22 addressed as part of --

23 MS. BANERJEE: John raised that.

24 CHAIRMAN ABDEL-KHALIK: -- 50.59 that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would have to do for Units 1 and 2.

2 MR. HEACOCK: Units 1 and 2, our interface,  
3 correct, and our tie-back to regulations.

4 CHAIRMAN ABDEL-KHALIK: Right.

5 MS. BANERJEE: Okay. Thank you.

6 CHAIRMAN ABDEL-KHALIK: At this time, we  
7 will move on to Chapter 16 presentations.

8 MR. HEAD: Okay. We will go on to Chapter  
9 16 now.

10 CHAIRMAN ABDEL-KHALIK: Please proceed.

11 MR. HEAD: Okay. The standard agenda, and  
12 here are the attendees we have with us today that can  
13 help us with our presentation. We will focus on Steve  
14 Cashell, who we will say is our tech spec expert. I will  
15 turn this over to Steve.

16 MR. CASHELL: Okay. Well, thank you for  
17 inviting me, Mr. Chairman and members.

18 My name is Steve Cashell, and I have been  
19 with this project since it began with STP 3 and 4. I  
20 have a bachelor's degree in chemistry from Kenyon College.

21 Following that, I served my period in the Naval Nuclear  
22 Program as an officer, a qualified engineering officer.

23 I spent the next 32 years in licensing,  
24 operations, and compliance of operating plants, and about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the last 20 years on BWRs primarily. I have been heavily  
2 involved with tech spec work, including the writing and  
3 the project management of some of these ITS conversions  
4 that have occurred.

5 Prior to coming to this project, the previous  
6 six years, I was a BWR Owners Group Subcommittee member  
7 on both the Risk-Managed Tech Specs and the Tech Specs  
8 Issues Coordination Committee.

9 Our tech specs were developed using  
10 NUREG-1434, which is a BWR 6 tech spec, standard tech  
11 spec. So, we used Rev. 0. That is what was being written  
12 at the same time our certain design was being certified.

13 And that is for all the specs except for  
14 the containment specs, the inerting and the drywall issues.

15 For that, we followed NUREG-1433, which more closely  
16 resembled what we have.

17 The EBWR tech specs are in the full, improved  
18 standard tech spec format. The only difference is we  
19 are Rev. 0, approximately. We have made some improvements  
20 since then, and you will see what we are going to do  
21 in the future.

22 The contents, of course, are the standard  
23 use and application safety limits, limiting safety system  
24 settings, conditions for operation, surveillance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements, design features, and admin controls.

2 We have many departures, but they can be  
3 broken down into these four categories. There are six  
4 Tier 1 departures that affect the tech specs, nine Tier  
5 2 design-related departures. There are eight Tier 2,  
6 I call them, non-design-related departures. They can't  
7 be categorized as editorial. So, they are in that  
8 category.

9 And the remainder is supplement, correct,  
10 and clarify information between the tech specs and the  
11 bases, provide consistency between the tech specs and  
12 the bases, other editorial in nature.

13 All the tech spec and tech spec bases  
14 departures require prior NRC approval.

15 The Tier 1 departures that affect tech specs  
16 are as follows:

17 The MSIV closure and scram on high radiation  
18 removes the high-rad scram and isolation functions from  
19 the tech spec, from the tables.

20 Feedwater line break mitigation, we actually  
21 added feedwater line break mitigation functions to the  
22 tech specs.

23 The RCIC turbine/pump departure, that simply  
24 changes the name. It was a turbine exhaust diaphragm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure. They don't have a diaphragm in the exhaust.  
2 So, it is turbine exhaust pressure.

3 I&C power divisions, that adds new Division  
4 4, 120-volt distribution panels to the basis for 3.8.9  
5 distribution systems.

6 Hydrogen recombiner elimination, that  
7 removes a hydrogen recombiner, and it downgrades the  
8 hydrogen/oxygen monitor functions, so they get removed  
9 from the tech specs.

10 The safety-related I&C architecture, that  
11 revises a lot of the I&C nomenclature in some of the  
12 design descriptions.

13 The design-related departures mostly affect  
14 the bases of the tech specs, except for, well, the first  
15 one, containment analysis. It revised P sub A, the  
16 calculated peak containment pressure.

17 Then, the next one, the more contentious  
18 one, is the RCS total and unidentified leakage rates.

19 We have obtained the information from K6, K7 on that,  
20 but we haven't really absorbed and learned how to use  
21 their tech specs. Their tech specs aren't formatted like  
22 ours are. We are not exactly sure yet. So, we are still  
23 trying to get that for you.

24 Then, the rest of these affect the bases.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Oh, I'm sorry. ADS electrical interface, that just  
2 clarifies that there are three divisions in the control  
3 logic versus four.

4 Post-accident monitoring, this revised that  
5 list. There is a list of Reg Guide 197 Type A and Category  
6 1 instruments. Those are the ones that have to go into  
7 the tech specs.

8 This one actually changed containment  
9 wide-range pressure to wetwell pressure. That is actually  
10 the instrument that we used. And it adds a wetwell  
11 atmospheric temperature that wasn't in the table. There  
12 are two other departures that affect that table. We will  
13 go through those as we get to them.

14 Control rod drive interfaces as an alternate  
15 method to ensure full rod insertion to the bases. The  
16 rod control information and system operator information,  
17 it revises the design description. It is push button  
18 now instead of a test switch.

19 The plant medium-voltage design, the  
20 electrical folks just went through a lot of those, but  
21 it is all those design changes through the same CpG sizing.

22 8.3.3, Electrical Site-Specific Power, this  
23 revises the list of -- or the MCC nomenclature adds some  
24 MCCs to the list of required distributions portions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           And finally, the condensate and feedwater  
2 system, the DCD mentioned three feedwater pumps. We have  
3 four. So, we have four adjustable-speed rods at four  
4 points.

5           Okay, now for the eight non-design-related  
6 departures, most of these were brought about because  
7 of rule changes once the design was certified.

8           For instance, the safety limit violation,  
9 10 CFR 50.72 and 73 were changed. So, certain of the  
10 notification requirements are no longer required. So,  
11 that was removed.

12           Post-exit monitoring instrumentation, this  
13 is where we removed one item from the PAM table. It removes  
14 containment water level parameter. We still have  
15 suppression cool water level, and we have the appropriate  
16 instrumentation to monitor.

17           Unit responsibility eliminates control room  
18 SRO requirements in MODE 4. That is a cold shutdown for  
19 us.

20           The unit staff, it provides the actual plant  
21 staff time.

22           The Bases Control Program, that eliminates  
23 that term under the safety questions for the 50.59 change.

24           Reporting requirements revises annual

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reporting. It just changes the date you have to submit  
2 your annual report.

3 Working hours removes the working hour limits  
4 from tech spec, since it is now required by rule.

5 And In-Service Testing Program, it is just  
6 the ASME Section XI. We now refer to ASME Operations  
7 and Maintenance Code.

8 The COL license information items are a little  
9 more interesting. We only had one, but it is an  
10 all-encompassing item. It was to supply all the bracketed  
11 information. We have about 450 bracketed items in there,  
12 and they fall under 156-odd categories.

13 But the staff came out with the Interim Staff  
14 Guidance ISG-08 necessary content of the tech specs when  
15 a license is issued. We had three options. The first  
16 option is give us your plant-specific information. We  
17 were able to do that for almost all the items. Okay?

18 The second one was, well, if you can't do  
19 that, give us a bounding value. We had only one item  
20 we had to do that with. We think we know the correct  
21 answer here, but it is a required number of LPRMs per  
22 division to make it APRM and division-operable. So, we  
23 are living with the high number. There is a pair of analyses  
24 to get that number. Before we actually operate, we will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get that number and get it refined.

2 And then, finally, the third option was  
3 reference a program that uses an NRC-approved methodology.

4 We did that for all the allowable values in the tech  
5 specs. And in order to do that, we had to create an  
6 instrument setpoint methodology. We will talk about that  
7 on the next slide.

8 So, this is the setpoint methodology. It  
9 has, actually, a new specification to the admin section.

10 Setpoint Control Program is the title. And it identifies  
11 the methodology documents used to calculate the setpoints.

12 It relocates all the allowable values from the tech specs  
13 to the licensing control document.

14 In order to do that, we had to revise  
15 definitions in the related surveillance requirements,  
16 and the definitions for two types of functional tests,  
17 and two types of channel calibrations had to be changed.

18 In the functional tests, we have actually a requirement  
19 to verify setpoints. So, that would be a much more  
20 restrictive change in the vernacular.

21 And finally, it establishes the document  
22 that contains the required setpoint values.

23 Site-specific supplemental information,  
24 there's only two types, the bracketed information that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we supplied -- it is sort of supplemental -- and then  
2 the ultimate heat sink surveillance requirements. We  
3 changed the design of the heat sink which had a spray  
4 pond. We now have a cooling tower with cooling tower  
5 cells and fans. So, we had to add a surveillance  
6 requirement to test the cell fans, and we also changed  
7 the requirements for measuring the basin. The pumps are  
8 located below the basin. So, we actually measure down  
9 to the basin bottom now.

10 So, that is the supplemental information.

11 CHAIRMAN ABDEL-KHALIK: Where does the  
12 site-specific flood level come in?

13 MR. CASHELL: That's in Chapter 1. That is  
14 the site parameter table, I guess in Chapter 2. Is that?  
15 Chapter 2, I believe.

16 MR. HEAD: Are you talking in tech specs  
17 or in --

18 MR. CASHELL: It's not in the tech specs.

19 CHAIRMAN ABDEL-KHALIK: It is not in the  
20 tech specs. It's in Chapter 2?

21 MR. EUDY: I couldn't answer that.

22 CHAIRMAN ABDEL-KHALIK: Okay. Well, will  
23 we have an opportunity to look at that? One of the things  
24 I guess that relates to that was the fact that they have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 added doors that, presumably, remain closed and  
2 water-tight to accommodate the fact that the site flood  
3 level is somewhat higher than --

4 MR. EUDY: Right.

5 CHAIRMAN ABDEL-KHALIK: And the question  
6 I have, and I don't know whether this is the right time  
7 to ask it, is whether or not these doors remained closed  
8 and water-tight during an outage.

9 MR. HEAD: Our plans right now, that they  
10 are to remain open. They are functional doors. I believe  
11 we are still in dialog with the staff on Chapter 19 on  
12 that topic. So, there's two opportunities to discuss  
13 that.

14 CHAIRMAN ABDEL-KHALIK: We'll probably  
15 revisit this at a more appropriate time.

16 Thank you.

17 MR. CASHELL: And finally, our future plans.

18 Because we are sitting there at Rev. 0 with our tech  
19 specs, we realize that the Tech Spec Task Force Traveler  
20 Program began about when our design was certified, and  
21 there are 500 TSTFs. At least 100 of them apply to us.

22 We want to bring our tech specs up to the Rev. 3.1 level  
23 for both of the NUREGs. So, we intend to do that. We  
24 actually intend to submit that application close after

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we get our combined license.

2 We have incorporated those TSTFs, and what  
3 it incorporates, also, there are eight risk-informed  
4 initiatives. It will incorporate most of those  
5 risk-informed initiatives, and most of those have been  
6 done by this CLIIP process, this Consolidated Line Item  
7 Improvement Program.

8 So, we will wrap all that up into one  
9 application and bring the tech specs up to grade. A lot  
10 of that is bases descriptions. It is writing the specs  
11 better, so they're easier to understand, and the operators  
12 do it.

13 In the second bullet there is the risk-managed  
14 tech specs. STP 1 and 2 actually have this option, this  
15 option Initiative 4b, which allows you to have a backstop  
16 for your completion times and set your own completion  
17 times based on your PRA. We will approach that parallel  
18 with the other one. That one will probably take longer  
19 to get approved. So, we will do it as a separate submittal.

20 Now, the third bullet, we intend to have  
21 our plant-specific PRA complete prior to COL issuance  
22 in sufficient form to support these initiatives. When  
23 I say, "complete," it won't have the external events  
24 fire and seismic prior to fuel load, but it will be done

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 soon thereafter and before we operate.

2 And our PRA will be ASME. It will meet the  
3 ASME standard. It will meet Reg Guide 1.200, and it will  
4 have had its peer review done on the portions that are  
5 finished.

6 So, we believe we can accomplish all this,  
7 bring our tech specs up to the latest, greatest today's  
8 standards, and be among the very few plants that actually  
9 are fully risk-informed. Before we actually operate the  
10 plant, we hope to get these approved.

11 CHAIRMAN ABDEL-KHALIK: In the setpoint  
12 methodology, is there a reference to a specific topical  
13 that you will use for --

14 MR. CASHELL: Yes.

15 CHAIRMAN ABDEL-KHALIK: -- the detect and  
16 suppress stability?

17 MR. CASHELL: Yes, there is. There is a WCAP  
18 for that. It is --

19 CHAIRMAN ABDEL-KHALIK: But does that  
20 include the detect and suppress option 3 methodology  
21 as well?

22 MR. CASHELL: Yes. Yes, it does. That is  
23 one of the topicals we discussed this morning that will  
24 be submitted to the NRC in late June as part of the Fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Amendment, the new Fuel Amendment.

2 CHAIRMAN ABDEL-KHALIK: Okay.

3 MR. CASHELL: Okay? It will be based on the  
4 new fuel type. We actually have two topical in the  
5 setpoint methodology. It is all the tech spec allowable  
6 value-type setpoints, and then the OPRM setpoints for  
7 stability. That has its own --

8 CHAIRMAN ABDEL-KHALIK: I suspect this is  
9 one of the topical that the Committee will need to look  
10 at --

11 MR. CASHELL: Okay.

12 CHAIRMAN ABDEL-KHALIK: -- in conjunction  
13 with the Thermal-Hydraulic Subcommittee.

14 MR. CASHELL: Okay.

15 CHAIRMAN ABDEL-KHALIK: Okay.

16 MEMBER-AT-LARGE STETKAR: I have several  
17 detailed things.

18 CHAIRMAN ABDEL-KHALIK: Please, go ahead.  
19 Sure.

20 MEMBER-AT-LARGE STETKAR: You may have  
21 gathered that I am sort of detail-oriented and electrical.

22 So, I went through the tech specs for electrical stuff.

23 But I stumbled over a couple of other things that I wanted  
24 to ask you about first before the electrical.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   There's a footnote in table 3.3.4.1-1 that  
2 specifies allowable values for reactor internal pump  
3 trip timing. I noted that the allowable value for the  
4 trip timing for internal pumps A, D, F, J, B, E, and  
5 H is less than or equal to zero seconds. That is a pretty  
6 doggone tight setpoint.

7                   (Laughter.)

8                   It is hard for me to measure zero, much less  
9 less than zero. And it has been added. I mean it is  
10 something that you added to this. It is not carried over  
11 from the original DCD.

12                   So, I would like to understand how you measure  
13 that.

14                   MR. CASHELL: That was an early attempt to --

15                   MEMBER SIEBER: It's where your car quits.

16                   (Laughter.)

17                   MR. CASHELL: -- to complete the brackets  
18 while this interim step --

19                   MEMBER-AT-LARGE STETKAR: Zero is a small  
20 number.

21                   MR. CASHELL: -- was being created.

22                   MEMBER-AT-LARGE STETKAR: I notice the staff  
23 didn't ask about zero.

24                   MR. CASHELL: We took all those out in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 response to an RAI.

2 MEMBER-AT-LARGE STETKAR: Oh, did you?

3 MR. CASHELL: I would note it comes out  
4 completely, and the allowable values, it just references  
5 the new setpoint control program.

6 MEMBER-AT-LARGE STETKAR: Oh, okay.

7 MR. CASHELL: The WCAP will explain how to  
8 obtain all of that.

9 MEMBER-AT-LARGE STETKAR: I saw that in most  
10 cases, but this happened to be one case that it wasn't,  
11 and zero caught my eye. Okay.

12 Before I get to electrical stuff, there  
13 is -- this, again, is plant-specific -- this MODE 4 for  
14 south Texas is cold shutdown?

15 MR. CASHELL: Shutdown.

16 MEMBER-AT-LARGE STETKAR: Okay. There's a  
17 requirement that says, if I have no reactor cooling water  
18 or no reactor service water -- I might have the names  
19 of those systems wrong -- RCW or RSW, or no ultimate  
20 heat sink, I have to be in hot shutdown within 12 hours  
21 and cold shutdown within 36 hours. How do I get to cold  
22 shutdown if I don't have those systems?

23 This is a holdover from when I was an operator,  
24 and I was required to go to cold shutdown if I had no

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 component cooling water, and I couldn't get there. So,  
2 I am curious how you can get to a place that the tech  
3 specs are telling you to go to.

4 MR. CASHELL: You know, I guess that is one  
5 of the glitches with the way tech specs are written.  
6 What you would do if you couldn't get there in 36 hours  
7 is --

8 MEMBER-AT-LARGE STETKAR: Call the staff?

9 MR. CASHELL: Well, I was going to say you  
10 would have Tech Spec 303, but 303 only applies in MODES  
11 1, 2, and 3. So, you don't really have a spec any longer  
12 you can follow. The best you can do is continue to cool  
13 down and try to regain surface water.

14 MR. HEAD: But being inoperable doesn't  
15 really always mean they are non-functional.

16 MEMBER-AT-LARGE STETKAR: That's true.  
17 That's true. I understand that. I was just curious  
18 whether I was missing something basically.

19 MR. CASHELL: And that, actually, may be  
20 one of the specs that is corrected by these 100-odd TSTFs.  
21 I can't remember for sure.

22 MEMBER-AT-LARGE STETKAR: No, no, this is  
23 just counting up number of trains of things. So, it  
24 shouldn't be a setpoint.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CASHELL: So, it shouldn't be a setpoint.  
2 Well, some of those were actually --

3 MEMBER-AT-LARGE STETKAR: Anyway, let me  
4 get to the electrical stuff because that was more of  
5 a curiosity.

6 How am I going to do this? If I have one -- I'm  
7 going to think about offsite power here for a moment.

8 LCO 3.8.1.a.1 says, if I have one of two offsite AC power  
9 sources to one ESF bus inoperable, then I must verify  
10 that the ESF bus is powered from the other operable offsite,  
11 from the operable offsite source within 72 hours.

12 So, does that mean that, if I'm in the plant,  
13 I can actually leave that bus without any source of offsite  
14 power for 72 hours? According to this, I can. Why?

15 MR. CASHELL: Well, there's a whole series.  
16 Isn't there an A1 and A2, A3? You need all those.

17 MEMBER-AT-LARGE STETKAR: This is --

18 MR. CASHELL: The distribution  
19 specification would apply there, too.

20 MEMBER-AT-LARGE STETKAR: The distribution,  
21 yes, I will ask you later about distribution stuff.

22 MR. CASHELL: Okay.

23 MEMBER-AT-LARGE STETKAR: But I'm  
24 interpreting that correctly? The tech specs allow me

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to have both -- they can't both be inoperable, but I  
2 can have one inoperable and one disconnected for 72 hours?

3 MR. CASHELL: Well, the distribution system,  
4 Spec 1 would allow you to do that. You would have to  
5 power it from some location.

6 MEMBER-AT-LARGE STETKAR: Okay.

7 MR. CASHELL: Let me add just one other thing,  
8 just for clarification.

9 MEMBER-AT-LARGE STETKAR: Actually, the  
10 distribution systems says, with one AC electrical  
11 distribution system inoperable, restore AC power to the  
12 distribution system to operable status within 72 hours.

13 So, I tried to check these numbers.

14 MR. HEACOCK: Let me add onto the other part  
15 of the distribution, the 72-hours alignment to the other  
16 source.

17 If you go back and look at how the diesels  
18 are designed, if we lose the preferred source that we  
19 are on at the time, we are going to lose and go out on  
20 under-voltage, and we are going to start the diesels  
21 and we are going to load to the diesels. That is where  
22 you are going to be initially. You are not going to be  
23 without power. You are going to be on the diesel generator.  
24 That is where it goes first.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, to a degree, what they are basically  
2           saying is that, yes, it is probably not the best wording  
3           for 72 hours, but you have some amount of time to try  
4           to get off the diesels and then over to the alternate  
5           source by manual connection.

6           MEMBER-AT-LARGE STETKAR: That's a pretty  
7           good answer, but 72 hours still seems a long time --

8           MR. HEACOCK: I understand.

9           MEMBER-AT-LARGE STETKAR: -- to allow people  
10          to sit there.

11          MR. HEACOCK: That was the intent, though,  
12          is to follow that path.

13          MEMBER-AT-LARGE STETKAR: Well, I just  
14          wanted to make sure because I want to get to other areas  
15          where I actually had more difficulty understanding even  
16          what the tech specs were telling me.

17          MR. CASHELL: Along with that 72-hour  
18          requirement, though, is to verify that the CTG is  
19          functional.

20          MEMBER-AT-LARGE STETKAR: That's right. I  
21          will get to that in a second. I'm kind of slow. I have  
22          to work my way down from the offsite power stuff.

23          Now I have to read something very carefully,  
24          and I want to make sure I quote this correctly. This

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is from LCO 3.8.1.b.2.

2 It says, "With one required offsite circuit  
3 inoperable, the required action is declare required  
4 feature(s) with no power available from an operable offsite  
5 circuit inoperable when the redundant required feature(s)  
6 are in operable."

7 What does that mean?

8 MR. CASHELL: What that would do, that says,  
9 if you lost a function because --

10 MEMBER-AT-LARGE STETKAR: Let's say I lost  
11 the UAT.

12 MR. CASHELL: -- you lost power to it, right?

13 MEMBER-AT-LARGE STETKAR: Yes.

14 MR. CASHELL: And then, you go and look at  
15 the other function, and it's inoperable. Now what they  
16 are telling you to do is we can't rely on that train  
17 working. You already know that component is inoperable.

18 So, with this one, without the power, you just immediately  
19 declare that feature inoperable. That will drive you  
20 to the specification for the feature; for instance, a  
21 type of pump or something, and that specification will  
22 give you a much more limited completion time.

23 MR. CHAPPELL: It ensures that, if you have  
24 power feeding your defense-in-depth multiple trains,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if any of those other components are already inop at  
2 the time when you enter the specification for loss of  
3 power. It requires you to look at all of the trains  
4 available or components available to provide that function.

5 And if there are parts that are inoperable, then it drives  
6 you to declare that component inoperable within a specified  
7 timeframe.

8 MEMBER-AT-LARGE STETKAR: But I don't have  
9 to require it, I don't have to declare it inoperable  
10 if everything else on the other trains are operable?

11 MR. CASHELL: The function is operable,  
12 right.

13 MR. CHAPPELL: Right.

14 MEMBER-AT-LARGE STETKAR: That's kind of  
15 different. I will have to think about that.

16 MEMBER SIEBER: If you're the supervisor,  
17 you've got to refer that to the shift attorney.

18 MEMBER-AT-LARGE STETKAR: I was going to  
19 say I didn't get a law degree, and I had a real difficult  
20 time understanding this one as the shift supervisor.

21 But that's the way to interpret it  
22 functionally, is that I only enter that action -- that  
23 action statement applies -- for example, if I lose the  
24 UAT feed -- remember, this is for one required offsite

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 circuit, inoperable. If I lose the UAT -- so, I don't  
2 start the diesels.

3 I will lose the RAT feed to bus A3. Okay?  
4 That is one of my required offsite circuits for bus A3.  
5 Nothing happens to the plant. But as long as nothing  
6 on buses B3 and C3 is inoperable, I'm okay?

7 MR. HEAD: Right. You're only in the  
8 electrical --

9 MR. CASHELL: And then you stay in the  
10 electrical specs, in that specification --

11 MR. HEAD: Stay in the action statement --

12 MR. CASHELL: Only in the distribution  
13 systems spec.

14 MEMBER-AT-LARGE STETKAR: Yes, but the  
15 distribution system is 72 hours.

16 MR. HEAD: This aspect is pretty standard.

17 MEMBER-AT-LARGE STETKAR: Is it?

18 MR. HEAD: Yes, on 1 and 2, we have the same  
19 sort of specification, that --

20 MEMBER-AT-LARGE STETKAR: Oh, okay. I  
21 haven't looked at tech specs in a long time. The ones  
22 I've looked at were not written like this one.

23 MR. CASHELL: Well, remember how you used  
24 to have to cascade through all the specs and everything?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: Yes.

2 MR. CASHELL: What this statement does now,  
3 instead of letting you stay with the real broad timeframes,  
4 the 72 hours and all, they will force you into a two-hour  
5 completion time or an eight-hour, or something more  
6 restrictive, depending on the components that are  
7 inoperable.

8 MEMBER-AT-LARGE STETKAR: I have to think  
9 about what it is telling me, but I at least understand  
10 the philosophy.

11 Now another sort of philosophical one, again,  
12 with one required offsite circuit inoperable, and this  
13 is LCO 3.8.1.b.5. "With one required offsite circuit  
14 inoperable, restore the required offsite circuit to  
15 operable status within 14 days and one day from discovery  
16 of two divisions with no power available from an operable  
17 offsite circuit, and 15 days from discovery of failure  
18 to meet the LCO."

19 What do all of the "and's" mean? I mean  
20 I can understand restore the circuit to operable status  
21 within 14 days. That I can handle. But what are all  
22 of the "and" things?

23 MR. CASHELL: If you had separate conditions  
24 entries, it gives you all the timeframes that you have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to meet. In other words, if you entered one, and then  
2 three days later you entered it again for another circuit,  
3 then, all of a sudden, you can't just add the 14 days  
4 to each of those and carry on. You have an overall limit  
5 of that 15 days.

6 MEMBER-AT-LARGE STETKAR: What does the  
7 final "and 15 days from discovery of failure to meet  
8 the LCO" mean?

9 MR. CHAPPELL: That means, once you enter  
10 that LCO for a loss of offsite, or whatever reason you  
11 entered in, you have 15 days from that point to exit  
12 it, period. That 15 days would only apply if you had  
13 a subsequent inoperability that was concurrent.

14 MEMBER-AT-LARGE STETKAR: Okay.

15 MR. CHAPPELL: So, that way, you can't switch  
16 from one power source to another source, stay in the  
17 LCO, and extend it indefinitely.

18 MR. CASHELL: You can't use that to do  
19 maintenance forever and keep running operable the whole  
20 time.

21 MEMBER-AT-LARGE STETKAR: Okay. I'll have  
22 to think about that one, too.

23 A couple more. You will have to bear with  
24 me here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 LCO 3.8.1.c.3, if I have one required diesel  
2 generator inoperable, I must -- c.3.1 says, "Determine  
3 the operable diesel generators are not inoperable due  
4 to a common-cause failure" or c.3.2, "Perform surveillance  
5 requirement 3.8.1.2 for the operable diesel generators."

6 And similar statements apply, for example,  
7 for the DC systems where I must demonstrate that the  
8 others are not inoperable due to a common-cause failure.  
9 How do I do that?

10 MEMBER SIEBER: Surveillance.

11 MEMBER-AT-LARGE STETKAR: Well, but it says  
12 I either do that or I do the surveillance. So, I am curious  
13 about what that is that I can do without actually doing  
14 a functional surveillance, since I am given that option.

15 MR. CASHELL: If you determine what went  
16 wrong, you determine bad fuel or --

17 MEMBER-AT-LARGE STETKAR: Or a relay failed.

18 MR. CASHELL: Yes.

19 MEMBER-AT-LARGE STETKAR: I'm sorry, it's  
20 a solid-state. A part failed.

21 MR. CASHELL: Anything it could be that you  
22 immediately recognize as being common-mode failure, then  
23 declare them all inoperable. But if you don't know what  
24 the failure mode is or what really caused it, it gives

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you an option to go out; we'll just start the other one  
2 and run it through its surveillances --

3 MEMBER-AT-LARGE STETKAR: Isn't, in some  
4 sense, other than the fact that an operator may have  
5 made a human error that is unique to this particular  
6 diesel generator and burned it up, for example, isn't  
7 any type of failure a potential common-cause failure  
8 until you verify that the other equipment hasn't failed?

9 MR. CHAPPELL: That's why it is a required  
10 action.

11 MEMBER-AT-LARGE STETKAR: Well, no, the  
12 requirement says I have an option. My fallback option  
13 is I can do the test. Now that gives me pretty good assurance.

14 But, for the diesels and the DC, I can not do anything  
15 by simply declaring that the others are not susceptible  
16 to a common-cause failure.

17 And I'm curious about how I do that, how  
18 I, as an operator, you know, a shift supervisor, following  
19 these tech specs, do that.

20 MR. HEAD: But the diesel doesn't have to  
21 have failed. At that point in time, it is inoperable.

22 And if it is something that you can see and go verify  
23 on the other two units it doesn't exist, then there is  
24 no reason to start them up. But if there is some question,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if it is some buried aspect that you don't really know,  
2 then the shift supervisor on 1 and 2 right now will go  
3 start those diesels up.

4 MEMBER-AT-LARGE STETKAR: This, again, is  
5 consistent with the way 1 and 2 are written?

6 MR. HEAD: Yes, sir.

7 MEMBER-AT-LARGE STETKAR: I assumed it was.

8 MR. CASHELL: And also, that is a case where  
9 you are still going to do a common-mode failure analysis  
10 on any diesel failure, but you will do it in your corrective  
11 action program. The tech specs aren't designed really  
12 to force you to do it there.

13 MEMBER-AT-LARGE STETKAR: Well, except the  
14 tech specs are designed to make sure that I have a minimal  
15 complement of equipment --

16 MR. CASHELL: Right.

17 MEMBER-AT-LARGE STETKAR: -- available to  
18 handle accident conditions.

19 MR. CASHELL: Yes.

20 MEMBER-AT-LARGE STETKAR: But I don't want  
21 to have to wait for the people doing the corrective action  
22 program analysis in the next three or four months, or  
23 whatever.

24 Okay. One last one, two. Again, these are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 related. This is DC sources. It is LCO 3.8.4.a.

2 If one DC electrical power subsystem, either  
3 Division 1, 2, or 3, is inoperable, then I must verify  
4 that the combustion turbine generator is operable within,  
5 I must verify within 12 hours that the combustion turbine  
6 generator is operable. And the same requirement applies  
7 if I have one AC electrical distribution system inoperable.

8 The question I had is this requires that  
9 I verify operability of the combustion turbine generators.

10 It does not require that I verify operability of the  
11 diesels for the other divisions. There's no requirement  
12 to verify diesel operability.

13 Since the combustion turbine generator is  
14 the second backup for the safety divisions, I was curious  
15 why the LCO focuses on the CTG rather than the DGs.

16 MR. CASHELL: I think you've got to separate  
17 these two.

18 MEMBER SIEBER: Especially since the  
19 combustion turbines aren't --

20 MEMBER-AT-LARGE STETKAR: But the  
21 combustion turbine is in the tech specs, all through  
22 the tech specs.

23 MR. CASHELL: The CTG is not in any of the  
24 LCOs. You notice it is never required to be operable.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1       What the CTG allows you in those specs is extended  
2 completion times for all these other things. In other  
3 words, that is how you get the 72 hours rather than a  
4 shorter period of time.

5                   MEMBER-AT-LARGE STETKAR: But why is it the  
6 CTG rather than the diesels?

7                   MR. CASHELL: Well, the diesels have their  
8 own specs in LCO and, also, they already have requirements,  
9 and you are already verifying --

10                   MEMBER-AT-LARGE STETKAR: They're  
11 operable.

12                   MR. CASHELL: -- frequently that they're  
13 operable. This is the only place the CTGs are covered.

14                   MEMBER-AT-LARGE STETKAR: Oh, okay. Okay.  
15 I got it. I understand. Thank you. Thank you.

16                   MR. HEAD: I wasn't the on-shift lawyer,  
17 but we spent more time in Chapter 8 on tech specs than --

18                   MEMBER-AT-LARGE STETKAR: Well, the problem  
19 is I used to be on shift, and things that were written  
20 a lot more simply than these really taxed our ability  
21 to understand what we should do at three o'clock in the  
22 morning on Sunday, for example.

23                   MEMBER SIEBER: Did you have a shift lawyer?

24                   MEMBER-AT-LARGE STETKAR: We didn't,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unfortunately. And unfortunately, some of the people  
2 who we called, who knew absolutely what we were supposed  
3 to do, occasionally were wrong because they were not  
4 lawyers, either.

5 That is why some of these fairly convoluted  
6 tech specs are -- I don't want to say they're of concern.

7 It is just thinking about how the staff, the operating  
8 staff, would respond to these within some reasonable  
9 time, make the right decision, is a bit daunting, I think.

10 MR. CASHELL: Actually, the bases are much  
11 better today than in the old custom specs. That helps.

12 And remember, this is Rev. 0. This is when the whole  
13 concept of ITS was being developed, too. So, we are going  
14 to bring it up --

15 MEMBER-AT-LARGE STETKAR: Yes. Some of the  
16 reasons I ask these questions is, you know, I point to  
17 specific areas because I, quite honestly, couldn't figure  
18 out the philosophy. The CTG is a philosophical -- I  
19 understand that now. I at least understand the philosophy  
20 behind the other things.

21 I read the bases. The bases don't quite  
22 bring out that level of philosophy, either. So, thanks.

23 I appreciate that.

24 CHAIRMAN ABDEL-KHALIK: Okay. Are there any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other questions to STP on this chapter?

2 (No response.)

3 We will move now to the staff's presentation  
4 on Chapter 16.

5 MR. EUDY: Hello again. I'm Mike Eudy. I'm  
6 going to be presenting the Chapter 16 review by staff.

7 We appreciate South Texas' overview of the  
8 chapter. We are going to focus on a couple of particular  
9 areas.

10 I have with me Craig Harbuck, who is going  
11 to go over the technical issues, and we have some other  
12 people in the audience in case there's any specific  
13 questions, and the review team.

14 A couple of items of interest that we are  
15 going to go over. We are going to talk about staff review  
16 focus. Kind of Craig's going to give an overview of the  
17 verification process for plant-specific tech specs and  
18 their tech specs departures and site-specific tech specs  
19 COL information.

20 We are going to talk about the bracketed  
21 items which were included in COL License Information  
22 Item 61.

23 They have already given an overview of ISG-8,  
24 but Craig can probably add some more discussion to that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Then, we are going to talk about open item  
2           61. There is one open item for Chapter 16 at the moment,  
3           but, basically, there's two items within it. So, Craig  
4           is going to talk about that. It is related to LSS and  
5           the pressure-temperature limits.

6           I will turn it over to Craig.

7           MR. HARBUCK: The plant-specific tech specs  
8           consist of the generic tech specs, any approved departures  
9           from the generic tech specs, and site-specific COL  
10          information. So, to do our review, our focus is that  
11          we verify and incorporate by reference the generic tech  
12          specs and bases.

13          Then, we check to see if the departures that  
14          are proposed, the ones that affect the tech specs, we  
15          verify that they are appropriate and acceptable. Of course,  
16          all departures from the tech specs have to be approved  
17          by the staff, as per the ruling, Part 52. Then, we verify  
18          that the information they have provided as site-specific,  
19          we verify that that is appropriate and correct.

20          Next slide.

21          The guidance that was issued in ISG-8 for  
22          completing plant-specific tech specs with site-specific  
23          information has been incorporated into Revision 3 of  
24          the Standard Review Plan, Section 60.0 that just came

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 out days ago. So, I am not sure what the status of the  
2 ISG is at the moment, but that is what we are using for  
3 this review.

4 The staff shared a publicly-noticed version  
5 of ISG-8 with the ACRS, and we got no comments back.  
6 So, it has been mentioned before in the other presentation,  
7 so I am assuming everyone is familiar with it. I won't  
8 go into it any more.

9 The site-specific information that we have  
10 that is not resolved yet has to do with limiting safety  
11 system settings and RCS pressure-temperature limits.  
12 The completion of staff review of this COL information,  
13 we call this open item 16-1.

14 Next slide.

15 The applicant proposed Standard Departure  
16 60.3-100 to implement option 3 for limiting safety system  
17 settings and established an admin control tech spec for  
18 controlling instrumentation settings in a specified  
19 document outside the tech specs.

20 This approach is similar to that to be taken  
21 for the other design centers. It actually got its initial  
22 impetus, the ISG began when we started looking at the  
23 site-specific information, how they were proposed to  
24 be completed in the initial application for South Texas.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Now all the other design centers and COL applications  
2 are onboard with this approach for instrumentation.

3 Now the program specification references  
4 an NRC-approved methodology, and there has been a  
5 methodology submitted, and it is still under review.  
6 Therefore, it remains open in this chapter because staff  
7 hasn't completed that review.

8 But except for that, all the other changes  
9 to the generic tech specs that are related to completing  
10 site-specific information, or I should say the LSSS,  
11 we find it to be acceptable.

12 There is a backup slide if anyone would like  
13 to see more details about what Standard Departure 16.3-100  
14 changes, but I am not sure how we are going to provide  
15 that. I don't think we have it on the computer, unless  
16 anyone wants to see it.

17 But if there's any other questions about  
18 the status of the methodology review, Chapter 7 reviewer  
19 Dinesh Taneja is here, and he would be able to speak  
20 to that.

21 Questions?

22 (No response.)

23 Okay, next slide.

24 The other item that is included in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information that needs to be finished relates to the  
2 pressure-temperature limits report specification and  
3 the methodology for that. The Chapter 5 staff is still  
4 looking at that. I think there was a Chapter 5 presentation  
5 earlier today, and they must have mentioned the open  
6 item related to it.

7 The completion of the COL  
8 information-related PTLR and the generic tech specs is  
9 filling completion of the review of that methodology.  
10 Chapter 5 reviewer Neil Ray, and possibly George Thomas,  
11 could answer any questions about the status of that  
12 methodology review, if there is anything beyond what  
13 you discussed this morning.

14 The information that we needed in the generic  
15 tech specs is primarily referenced to the methodology  
16 report and the staff approval document, and the admin  
17 control tech spec, but there is also another place where  
18 we consider that the information, we can't conclude it  
19 is acceptable until we have confirmation that the P-T  
20 limit curves are acceptable. That would be in these two  
21 notes and two surveillances. To make it easier, I have  
22 just transcribed those onto the next slide, if we can  
23 just move to that.

24 You will see here that these modes state

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at what temperature you need to monitor your head and  
2 vessel flange temperatures and what frequency you need  
3 to do that. Those numbers are probably okay, which is  
4 what the applicant contends. They have removed the  
5 brackets, but until we have the curves, I think it is  
6 prudent just to consider those to still be pending.

7 And to translate, 27 degrees C is 81 degrees,  
8 and 38 is about 100 in English units.

9 Let's see. Also, this goes in a little bit  
10 more detail, but not much more detail, about what Standard  
11 Departure 16.3-8 accomplishes.

12 And the last slide, then, is very simple.  
13 Because of these methodology reviews, these other  
14 chapters, we can't make a final conclusion. However,  
15 we, the reviewers for Chapter 16, we have no remaining  
16 issues that would be called tech spec issues per se.

17 CHAIRMAN ABDEL-KHALIK: Any questions for  
18 the staff on Chapter 16?

19 MEMBER SIEBER: Just so I get it straight,  
20 you have listed in everybody's tech specs certain setpoints,  
21 and STP has elected to, rather than put all those setpoints  
22 in the tech specs, they will establish a separate manual,  
23 and that will include the setpoint methodology and the  
24 setpoints. And that has been done by a lot of licensees.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Beyond that, most licensees have a scaling  
2 manual. I'm not sure everybody uses the same thing for  
3 that, but there is a manual that says -- you give it  
4 to the instrument man, and here's how he calibrates the  
5 instruments. It has got the span, the proportional band,  
6 the rate, the reset, and trip points within that. So,  
7 that is how your instruments are calibrated. That is  
8 supposed to make sure that the tech spec value is valid.

9           Is there a methodology where you keep the  
10 scaling manual consistent with the document which I would  
11 call the tech spec setpoint manual? Or do you do it that  
12 way or not? Do you know how your instrument department  
13 works?

14           MR. CASHELL: Kyle, would you like to address  
15 that then?

16           MR. DITTMAN: I guess I didn't follow the  
17 question, but --

18           CHAIRMAN ABDEL-KHALIK: Please identify  
19 yourself.

20           MR. DITTMAN: Oh, I'm Kyle Dittman, I&C  
21 Supervisor.

22           MEMBER SIEBER: Let me say it very briefly.  
23 Your tech specs, when they are finished, will reference  
24 a separate manual that will include the methodology for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 establishing setpoints, and that will be a separate  
2 document from the tech specs.

3 Now, when you calibrate the instruments,  
4 you use a scaling manual which typically is derived from  
5 the setpoint manual, but it includes span, proportional  
6 band set rate, reset, and trip points. You may have an  
7 instrument that has four or five trip points on it, and  
8 you will list all those.

9 What methodology will you use to keep the  
10 scaling manual consistent with the setpoint manual?

11 MR. DITTMAN: It is all going to be controlled  
12 under a setpoint control program.

13 MEMBER SIEBER: Right.

14 MR. DITTMAN: And a setpoint control program  
15 will control how they are calibrated and what procedures.

16 Obviously, the methodology will be approved as part of  
17 the SER, and that will be part of the setpoint control  
18 program. So, it will be, basically, driven all under  
19 that one program, which will ensure that it is consistent.

20 MEMBER SIEBER: Okay. Now the operator, as  
21 he operates the plant, has to refer to two documents.

22 One of them is the tech specs itself, plus the procedures,  
23 and the setpoint manual. Is that correct?

24 MR. CASHELL: Yes. And actually, this new

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 process will probably make it easier on the I&C technician.

2 Let me read you a couple of excerpts from  
3 the setpoint control program.

4 MEMBER SIEBER: All right.

5 MR. CASHELL: "The nominal trip setpoint,  
6 thenominal value has found tolerance and has left tolerance  
7 for each tech spec. Required automatic protection  
8 instrumentation function shall be calibrated in  
9 conformance with this approved methodology" that we are  
10 going to have. Okay?

11 And it also discusses the acceptable margin  
12 that has to be in there. Okay?

13 MEMBER SIEBER: Right.

14 MR. CASHELL: Then, it talks about what a  
15 channel calibration and a functional test have to consist  
16 of. Okay? It tells a tech what to do, you know, take  
17 which values --

18 MEMBER SIEBER: Right.

19 MR. CASHELL: -- how to treat them, and  
20 everything else.

21 Then, it says the difference between the  
22 instrument channel trip setting, the as-found value,  
23 and the previously left value shall be evaluated, and  
24 all that. So, it talks about a training program, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how you evaluate that.

2 Then, finally, it says, "Setpoint control  
3 programs shall establish a document containing the current  
4 value of the specified nominal trip setpoint allowable  
5 value, as-found tolerance, as-left tolerance, for each  
6 function" and references to the calculation  
7 documentation.

8 So, what I envision is a book that has all  
9 this in it, so that the tech will now have everything  
10 he really needs to look at. He will have the history.  
11 He will have what the value is, and what the temporary  
12 values may have been.

13 MR. DITTMAN: Yes, the setpoints will be  
14 in one place. When we put in a setpoint control, on their  
15 setpoint control program, someplace they will see them.

16 But how you calibrate in the field will be driven by,  
17 you know, that will feed into the surveillance procedures,  
18 the calibration procedures.

19 So, when the techs go out and do the  
20 calibrations, like you said, the reset, the setting,  
21 the trip setpoints, all that stuff, that will be written  
22 right into the procedures. Those procedures will take  
23 into account the uncertainties from the methodology.  
24 The scaling will be done by a scaling count, but that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will feed into the procedures. So, all of that stuff  
2 will be driven by the program.

3 MEMBER SIEBER: Okay. And all of this, all  
4 these setpoints will be consistent throughout all the  
5 various types of operating procedures, including  
6 emergency and abnormal, plus the tech specs, plus the  
7 setpoint control document, plus the scaling manual? So,  
8 it is all going to have the same numbers?

9 MR. CASHELL: Yes, they have to be.

10 MEMBER SIEBER: Yes, I know it is supposed  
11 to be. I want you to tell me that it will be.

12 MR. DITTMAN: Yes, it will be. It will come,  
13 all that program and that listing setpoints.

14 MEMBER SIEBER: Okay. Thank you.

15 And I did get a document here from the licensee  
16 that explains this, which I probably will end up giving  
17 to the --

18 CHAIRMAN ABDEL-KHALIK: Charlie? Please go  
19 ahead.

20 MR. HARBUCK: That tells what the program  
21 looks like.

22 MEMBER SIEBER: Okay.

23 MR. HARBUCK: The program specification.

24 MEMBER SIEBER: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER BROWN: Can I have one question, but  
2 I don't know who is going to answer it? But in the FSAR  
3 there were a number of all the instrumentation checks,  
4 surveillance requirements, where your channel functional  
5 tests were specified to be at 92 days. Every 92 days,  
6 you had to go do this surveillance test.

7                   Staff didn't like that. You wrote an RAI.  
8 I think 16 days, 21, issue 4 -- oh, by the way, it was  
9 specified in both DCD, Rev. 4, as well as the FSAR, Rev.  
10 3.

11                   Then, RAI 1668 came along, and that one finally  
12 identified that the applicant listened to the staff and  
13 said, okay, you don't like 92; we'll change to 31. And  
14 you came into basis because we had this automatic self-test  
15 and diagnostic routine.

16                   The original basis, both in the DCD and the  
17 FSAR, said, not only do you have the diagnostics, but  
18 you also had highly-reliable components which were  
19 drift-free, virtually drift-free. Okay?

20                   Staff came back and said, oh, no, you really  
21 can't use that as a basis because you've got  
22 self-diagnostics; we really like to have reliable  
23 components and drift-free performance for these  
24 components.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   And that just raised the question to me about ,  
2                   for 31 days, is there a way you come up with the values  
3                   or the data that says 31 days is good because these are  
4                   highly-reliable? Quite frankly, I thought the argument  
5                   that we test this stuff every 30, you know, constantly,  
6                   particularly for digital equipment where we have  
7                   self-tests and self-diagnostics, I moved in my program  
8                   from weekly checks, and the Naval Nuclear approach, and  
9                   started taking daily. We just checked and checked and  
10                  checked. Finally, we found, gee, this stuff never went  
11                  out of spec. I won't say, "never," but it was a long  
12                  time.

13                   So, did you have some type of database or  
14                   some type of testing or something or was this 31 days  
15                   and this high reliability stuff just plucked out of the  
16                   air?

17                   MR. HARBUCK: I'll give a stab at answering  
18                   that, and then I will ask Dinesh Taneja to follow up.

19                   It really comes down to a lack of sufficient  
20                   information that staff is willing to make any conclusions  
21                   about the digital design, such that we can say, oh, we  
22                   can relax these frequencies.

23                   Now the 92 days was a bracketed number in  
24                   most cases.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER BROWN: Well, I understand that, but  
2           you said -- first, I was going to say, how did you come  
3           up with 92 days? But you also looked at 31, still working  
4           on the 31 days.

5           MR. HARBUCK: Okay. The 92 days comes  
6           from -- and the reason it is bracketed is because it  
7           was bracketed in Rev. 0, the standard, where there were  
8           topical reports that you could refer to, based on the  
9           analog-type systems, instrumentation systems, that used  
10          historical data to show that you could get away with  
11          testing less frequently. And that's how you got from  
12          31 to 92 days.

13          MEMBER BROWN: Even in the analog world?

14          MR. HARBUCK: The analog world. Okay?

15          Of course, the tech specs tried to adapt  
16          to the digital, the new digital systems that were being  
17          proposed, but we weren't looking at hardware at that  
18          time. We don't have necessarily experience, and we don't  
19          even know what hardware is going to be purchased, I think.  
20          I don't think that has been decided yet.

21          So, there is not an experience base to justify,  
22          yes, we can go longer. Now, in theory, you know, yes,  
23          this stuff is supposed to be checking itself all the  
24          time and it doesn't drift, and you should be able to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get away with testing less often.

2 MEMBER BROWN: Manually testing less often?

3 MR. HARBUCK: Yes, manually testing less  
4 often.

5 But our technical staff has not chosen to -- my  
6 understanding is that there is not enough evidence yet  
7 to justify relaxing those frequencies. My guess is that,  
8 eventually, those things will be relaxed.

9 MEMBER BROWN: The analog-type database or  
10 historical experience was what type of analog equipment?  
11 The backing tubes, megants, transistors?

12 MR. HARBUCK: No, it's bystables.

13 MEMBER BROWN: Integrated circuits?

14 MR. HARBUCK: Well, I'm not --

15 MEMBER BROWN: That is the type of -- a  
16 bystable is not a component. That is an assembly of  
17 components.

18 MR. HARBUCK: It's old technology, 1960s  
19 technology for the most part.

20 Can you add anything to that, Dinesh?

21 MR. TANEJA: Yes. I'm Dinesh Taneja. I'm  
22 the I&C reviewer for this application.

23 One other thing that DCD tech specs  
24 surveillance intervals were based on, I believe in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DCD they did try to take credit for the self-diagnostics --

2 MEMBER BROWN: Well, they stated that.

3 MR. TANEJA: -- and surveillance  
4 capabilities; whereas, in the COL application, STP did  
5 not actually, you know, that's one of the areas where  
6 they are not taking credit for that feature as yet.

7 So, that is the reason why the frequencies  
8 were made more frequent.

9 MEMBER BROWN: Well, the FSAR explicitly  
10 stated both of those factors, and you all said -- you  
11 went back and hit the 92 days first, and then they came  
12 back and just said we'll use 31 just because of the  
13 self-diagnostics-type stuff. The DCD quoted  
14 self-diagnostics also.

15 MR. TANEJA: I don't think they explicitly  
16 take credit for that self-diagnostics, you know, that  
17 I recall.

18 MEMBER BROWN: Well, here it says, "The  
19 frequency of 92 days is based on the specified high  
20 reliability and redundancy of devices used to implement  
21 the functions, the specified low drift, and the signal  
22 validation of tests that are automatically and  
23 continuously performed on the channels." That is right  
24 out of the FSAR, Rev. 3.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So, that is why I asked the question. I  
2 mean I don't have any problem with going to 31. I was  
3 looking for what experience base that your all's world -- I  
4 know what I had back in my programs, and I was curious  
5 as to what, based on previous meetings, what experience  
6 base you had to allow you to make those decisions. That's  
7 all.

8           MR. TANEJA: Experience with the existing  
9 operating plants was based on the actual test data from  
10 the past 20-30 years of operating experience.

11          MEMBER BROWN: In other words, how often  
12 do they have to realign, recalibrate --

13          MR. TANEJA: Exactly. Exactly. And that  
14 equipment is mostly like your analog type of instrument.

15          MEMBER BROWN: Transistorized?

16          MR. TANEJA: Transistorized, right.

17          MEMBER BROWN: Not integrated circuits? I  
18 guess the later ones might have had a few integrated  
19 circuits.

20          MR. TANEJA: Might have, but it is basically,  
21 you know, your Westinghouse 7300 and Foxboro I/A Systems,  
22 and these are, essentially, analog technology, you know,  
23 of the sixties and the seventies. Those instruments have  
24 been pretty reliable.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   What the nuclear industry has done is they  
2                   have basically done a lot of statistical analysis on  
3                   the actual surveillances that they have been performing.

4                   MEMBER BROWN: Okay.

5                   MR. TANEJA: And that became the basis for  
6                   a lot of the plants, even existing plants, extended their  
7                   surveillance durations based on that information that  
8                   they had.

9                   MEMBER BROWN: Okay. So, you are going to  
10                  be conservative and not use the 92, but shift back to  
11                  an earlier --

12                  MR. TANEJA: And, you know, we are going  
13                  to probably see -- I don't think the applicant had any  
14                  problem doing the --

15                  MEMBER BROWN: Oh, obviously. He changed  
16                  rapidly.

17                  (Laughter.)

18                  It was obvious they weren't going to argue.

19                  Okay, that's all. You've answered enough.

20                  MR. CASHELL: My understanding is, until  
21                  we choose the instruments, that we start at zero. But  
22                  our intent, when we do the upgrade, is, well, we will  
23                  get the instruments, and, ideally, these instruments  
24                  will have some operating experience in Japan and Australia

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and here. We may be able to drop in that database and  
2 revise our surveillance frequencies.

3 MR. HEAD: We've done that on 1 and 2 in  
4 a number of cases.

5 MEMBER BROWN: Okay.

6 MR. HEAD: There's a risk basis, an  
7 experience basis. So, there's programs that you can use  
8 to do that.

9 MEMBER BROWN: All right. I am done. That  
10 answered me satisfactorily.

11 CHAIRMAN ABDEL-KHALIK: Are there any  
12 follow-up items?

13 MR. HEAD: I had one. I wanted to go back  
14 to this slide and just mention the end-game, whether  
15 it is British units or -- okay?

16 CHAIRMAN ABDEL-KHALIK: Yes.

17 MR. HEAD: When we are licensed and operating  
18 in the control room, that will read Fahrenheit. But when  
19 we come back and give you, when we address that issue,  
20 we will address it from the DCD all the way down. I was  
21 going to leave you with that this will --

22 CHAIRMAN ABDEL-KHALIK: But, I mean, this  
23 is just another example of the problem I'm talking about.

24 MR. HEAD: Exactly. I understand.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: Right.

2 MR. HEAD: This points out your concern.

3 CHAIRMAN ABDEL-KHALIK: Right.

4 MEMBER SIEBER: I can do that one in my head.

5 (Laughter.)

6 MR. HEAD: Well, I understand, but should

7 I, as an operator, have to do that?

8 CHAIRMAN ABDEL-KHALIK: Okay. Thank you.

9 MR. HEAD: Sure.

10 CHAIRMAN ABDEL-KHALIK: Are there any  
11 specific follow-up items on this chapter?

12 MS. BANERJEE: The simpler tech spec that  
13 John was --

14 MEMBER-AT-LARGE STETKAR: You know, the good  
15 news is I'm not going to have to be a shift supervisor  
16 at that plant.

17 (Laughter.)

18 We will make sure they have a minor in the  
19 law.

20 MS. BANERJEE: Simple English.

21 MEMBER SIEBER: You just never know.

22 MEMBER-AT-LARGE STETKAR: No, I do.

23 (Laughter.)

24 CHAIRMAN ABDEL-KHALIK: Rather than

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 starting and stopping in the middle of the next chapter,  
2 I would like for us to take a break at this time. We  
3 will reconvene at 10 after 3:00.

4 (Whereupon, the foregoing matter went off  
5 the record at 2:57 p.m. and went back on the record at  
6 3:09 p.m.)

7 CHAIRMAN ABDEL-KHALIK: We're back in  
8 session.

9 At this time, we will go through Chapter  
10 17, and we will start with STP's presentation.

11 MR. HEAD: Thank you.

12 We will start in with Chapter 17. It is  
13 our standard agenda. And today, we have Tim Walker,  
14 Quality Manager, joining us, and Bill Stillwell will  
15 take us through the discussion on Chapter 17.

16 MR. STILLWELL: If you didn't hear earlier,  
17 my name is Bill Stillwell. I am the Supervisor of  
18 Probabilistic Risk Assessment for STP, Units 3 and 4.

19 I have been at STP approximately 21 years  
20 or 22 years, three times.

21 (Laughter.)

22 I have been doing probabilistic risk  
23 assessment since before John started probabilistic risk  
24 assessment, but only slightly.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I guess that's enough background. I know  
2 most of you.

3 The reason we are talking from a PRA  
4 perspective about Chapter 17 is because Chapter 17 includes  
5 the design reliability assurance program, and the PRA  
6 process feeds the risk information into the Chapter 17  
7 design reliability assurance program. So, it seems like  
8 a natural fit.

9 Where appropriate, I will pass off to Tim  
10 to talk about the specifics for the South Texas Project  
11 quality assurance program description.

12 Okay. Chapter 17 consisted in the DCD of  
13 three sections, well, four sections if you count zero.

14 It was quality assurance during design, which GE used  
15 to design and certify the Advanced Boiling Water Reactor.

16 It was quality assurance during the operations phase  
17 in 17.2, and then the reliability assurance program during  
18 the design phase in 17.3.

19 The STP combined license application  
20 incorporated those three sections by reference and added  
21 supplements to point to site-specific information that  
22 talks about the operational quality assurance program  
23 description and the STP design reliability assurance  
24 program for design and construction.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   We added three new chapters, 17.4S, which  
2                   is the reliability assurance program; 17.5S, which is  
3                   the South Texas Project quality assurance program guidance,  
4                   and 17.6S is how we are going to incorporate the maintenance  
5                   for 10 CFR 50.65.

6                   Good news, there are no departures in  
7                   Chapter 17.

8                   At this point, I am going to turn it over  
9                   to Tim to talk about quality oversight activities that  
10                  we have been undertaking.

11                  MR. WALKER: Good afternoon.

12                  My name is Tim Walker. I am the Manager  
13                  of Quality for South Texas Units 3 and 4. I have been  
14                  at STP for about 22 years. The last 12 years, I have  
15                  been a manager in quality, including over the operating  
16                  units and large projects, et cetera.

17                  Prior to that, I worked at Hatch and Sequoyah  
18                  during the operations and Sequoyah during the restart  
19                  phase. And before that, I was in construction at Clinton,  
20                  St. Lucie 1, and Fort St. Vrain.

21                  To head into just some of the things that  
22                  we have done as far as implementing the quality program,  
23                  of course, Toshiba had never done any safety-related  
24                  work for the U.S. markets here. So, we had to qualify

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Toshiba, and we qualified two of their facilities, the  
2 Isogo Engineering Center and the Kayhan Operations  
3 Facility, by full-scope audits.

4 We have done three audits of the Isogo  
5 Engineering Center and a number of surveillances over  
6 there over the last three years. We find they have a  
7 very comprehensive quality program and a lot of experience,  
8 just not here in the U.S.

9 We worked on and submitted the applications  
10 for, and obtained, an ASME owner certificate, the first  
11 one that has been issued by ASME in over 20 years for  
12 an owner. It was kind of a learning experience for them  
13 again, as well as for us.

14 We currently have ongoing resident oversight  
15 of reactor pressure vessel fabrication that has been  
16 ongoing for about two years now, starting with the forging  
17 fabrication at Japan Steel Works in 2008, right around  
18 the April timeframe. Now most of the components have  
19 been shipped for our Unit 3 reactor to the IHI facility  
20 in Yokohama, which is right next door to the Toshiba  
21 Isogo Engineering Center, which is convenient.

22 Japan Future Enterprises, at JFE, is  
23 producing the plate for the upper shell courses and the  
24 top head dome.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Yakin is producing specialty steel,  
2 stainless steels and incannels, for the stub tubes that  
3 go in the bottom head, as well as the things like the  
4 shroud support plate that has just recently been fabricated  
5 at Yakin.

6           Toshiba NEEMD is located at the Kayhan  
7 Facility, and they do all of the reactor internals, reactor  
8 internal pumps, the reactor supports, fine motion control  
9 rod drives, the hydraulic control units, all done at  
10 Kayhan, an NEEMD facility.

11           Over the last 12 years, we have had the good  
12 fortune, and it has mixed really well with what we are  
13 doing now in new units, to have the opportunity to provide  
14 direct oversight of a number of large projects in  
15 replacement components for our operating units. Starting  
16 about 12 years ago, we did direct oversight with residents  
17 during fabrication of our Unit 1 and Unit 2 replacement  
18 steam generators at both the Westinghouse Pensacola  
19 facility and in Spain at ENSA.

20           We also did low-pressure rotor replacement  
21 fabrication oversight in Germany at Siemens' facility.

22           That was the first time they had really ever had anybody  
23 come in and be residents there. That was a learning  
24 experience, once again, dealing in foreign culture with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the different folks that have different expectations  
2 than we do. We learned a lot from that.

3 We also did generator rotor replacement,  
4 as well as rewinds, at the Siemens' facility in North  
5 Carolina.

6 We had an unfortunate experience of having  
7 a standby diesel generator eject a piston about seven  
8 years ago. We had to take that diesel generator completely  
9 out of our site, take it to an offsite facility, do a  
10 complete teardown and a complete rebuild, including  
11 replacement of the crank shaft, all of the connecting  
12 rods, all of the pistons, all of the heads. We took every  
13 piece apart on that and put it back together. We learned  
14 a lot from doing that, too.

15 And lastly, the major project that we have  
16 had recently ongoing in Units 1 and 2 is replacing the  
17 heads for the operating units. That was done at Mitsubishi  
18 Heavy Industries in Kobe, Japan. That was before we had  
19 decided to do Units 3 and 4.

20 So, we had experience with dealing with the  
21 Japanese and many Japanese subsuppliers. We had resident  
22 inspectors in Kobe, direct STP employees, which has been  
23 a great benefit to us in learning the Japanese culture,  
24 dealing with their processes and procedures. They are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different companies, but we have learned a lot from doing  
2 that and being able to get around, and being familiar  
3 with working in Japan.

4 So, I just wanted to give you a little  
5 background on what we have been doing and why we think  
6 that we are well-suited and capable of going forward  
7 and do the oversight of the project that is coming up.

8 MR. STILLWELL: Okay, I'm going to skip slide  
9 8 temporarily and go to slide 9 to close out our quality  
10 assurance program description.

11 We added a Chapter 17.5S, which is the QA  
12 program guidance. It implements NQA-1 ASME standard.

13 It follows the NEI template 06-14A with site-specific  
14 or bracketed information provided. So, this is the  
15 implementation description for our quality assurance  
16 program description.

17 I guess right now is a good place to ask  
18 if we have questions on the quality assurance part of  
19 what is actually quality assurance Chapter 17.

20 CHAIRMAN ABDEL-KHALIK: We don't have any.

21 MR. STILLWELL: If not, we will go to the  
22 interesting part, from my perspective.

23 (Laughter.)

24 I'm sorry. Quality assurance is extremely

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 important, and that was just a joke.

2 Design reliability assurance program and  
3 the Maintenance Rule. Chapter 17.3 described the design  
4 reliability assurance program that GE implemented during  
5 certification.

6 As I mentioned, when we issued our combined  
7 operating license, we developed Chapter 17.4S, which  
8 is the STP implementation of design reliability assurance  
9 for design and construction. We also added Chapter 17.6S,  
10 which is how we are going to implement what used to be  
11 called operational reliability assurance or, actually,  
12 reliability assurance during the operation of the plant.

13 And it describes how we do the Maintenance Rule.

14 17.4S is actually implemented at South Texas  
15 now. We have an expert panel in place that has embarked  
16 on risk-ranking our structures, systems, and components  
17 as we move forward.

18 I had better follow the slides for a while.

19 As I mentioned, design reliability, our  
20 reliability assurance program in general is a lifetime  
21 program. It will be in place over the life of the plant.

22 Right now, we are doing the design portion, which is  
23 in place as we continue to design and actually construct  
24 the plant.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Prior to fuel load, we will transition to  
2 the Maintenance Rule program and other operational  
3 programs that will maintain the reliability of SSCs over  
4 the remainder life of the plant.

5           The reliability assurance program defines  
6 the criteria for PRA and deterministic identification  
7 of risk-significant SSCs. Actually, we have implemented  
8 a DRAP expert panel that is going to take PRA risk importance  
9 information from the plant-specific PRA and blend it  
10 with deterministic information from engineering,  
11 maintenance, operations, quality assurance, and come  
12 out with a risk ranking, if you will. Well, it is a risk  
13 ranking that is similar to a process we have implemented  
14 at South Texas about 10 years. It is not the same as,  
15 but it is really close. It approaches something that  
16 people like to talk about as greater quality assurance.

17           We are using a similar process in the blending  
18 and the setup of the expert panel.

19           Now I see questions starting.

20           MEMBER-AT-LARGE           STETKAR:           Yes.

21           Unfortunately, you guys are the first up who actually  
22 seem to be doing some of this.

23           MR. STILLWELL: Oh, good.

24           MEMBER-AT-LARGE STETKAR: Some of us, like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 me, need to be educated. You know, I understand  
2 Fussell-Vesely importance and risk achievement. Those  
3 things I can handle.

4 As far as the PRA input, is it true that  
5 the DRAP list contains anything with a Fussell-Vesely  
6 greater than .005 or a risk achievement greater than  
7 2 by definition, or is that --

8 MR. STILLWELL: What was done in the DCD,  
9 and what we are continuing in Section 19K, they used  
10 a Fussell-Vesely of .1 percent and a risk achievement  
11 worth of 5 to define what was risk-significant in the  
12 early certification stage.

13 MEMBER-AT-LARGE STETKAR: Okay.

14 MR. STILLWELL: We are keeping that same  
15 certification, if you will, criteria, but what we are  
16 passing to the expert panel is Fussell-Vesely greater  
17 than .005 and risk achievement greater than 2 because  
18 that is consistent with what we do for online programs,  
19 like Maintenance Rule or risk importance.

20 MEMBER-AT-LARGE STETKAR: Okay. But that --

21 MR. STILLWELL: So, we are keeping the 19K.

22 MEMBER-AT-LARGE STETKAR: You're keeping  
23 the .1 and the 5 --

24 MR. STILLWELL: And 19K.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: -- as black and  
2 white --

3 MR. STILLWELL: Black and white.

4 MEMBER-AT-LARGE STETKAR: -- in terms of  
5 if they meet that, they are on the list?

6 MR. STILLWELL: Yes, sir.

7 MEMBER-AT-LARGE STETKAR: And then,  
8 anything that satisfies these more relaxed criteria gets  
9 passed on to the expert panel?

10 MR. STILLWELL: With a strong recommendation  
11 that it be added to the list.

12 MEMBER-AT-LARGE STETKAR: But anything that  
13 does not satisfy these criteria, does the expert panel  
14 also look at that? Or this is the screen that you use?

15 MR. STILLWELL: That's the purpose of the  
16 expert panel, is to bring their experience in engineering,  
17 operations, maintenance, quality assurance, reliability  
18 assurance programs to look at systems, structures, and  
19 components that the PRA doesn't model well. Or that were  
20 excluded from the PRA for whatever reason. We didn't  
21 have the design at the time or just complexity of the  
22 model.

23 MEMBER-AT-LARGE STETKAR: I guess what I  
24 was asking is, suppose I have something that is modeled

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the PRA, and it has a Fussell-Vesely, instead of half  
2 a percent, it's got .4 percent or a risk achievement  
3 worth of 1.8.

4 MR. STILLWELL: Uh-hum.

5 MEMBER-AT-LARGE STETKAR: Does the expert  
6 panel, is the expert panel told, "Hey, look at this"  
7 or is the expert panel told, "Don't look at this"? I'm  
8 trying to understand how this screen works.

9 MR. STILLWELL: The way it works for this  
10 other program that we've got implemented at 1 and 2,  
11 we will bring in the entire list. This is the rank,  
12 Fussell-Vesely, risk achievement worth combined --

13 MEMBER-AT-LARGE STETKAR: Of everything?

14 MR. STILLWELL: Of everything. In the other  
15 program, we say these things are on the list, because  
16 our program for 1 and 2 is set; if the PRA says it is  
17 risk-significant, it is risk-significant and will never  
18 change.

19 These other things are not risk-significant.

20 However, we've got this little band thing here because,  
21 by experience, we found out that we don't like things  
22 shifting across thresholds between model updates.

23 We intend to bring everything to the expert  
24 panel in some sort of rank list on a system basis, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then, we will discuss it at the expert panel.

2 MEMBER-AT-LARGE STETKAR: But you actually  
3 haven't done it?

4 MR. STILLWELL: We're actually starting the  
5 first one next month.

6 MEMBER-AT-LARGE STETKAR: Okay. Now once  
7 the expert panel looks at something -- so I now have  
8 a pump or a set of pumps -- there are a combination of  
9 weighting and rating, or weights and ratings, that the  
10 expert panel uses. For the benefit of me, and maybe even  
11 more for some of the other Subcommittee members who may  
12 not have gone through this process, could you briefly  
13 explain how that process works? I mean it is sort of  
14 described in the FSAR, but it is sort of bullets and  
15 numbers and weights.

16 MR. STILLWELL: At a high level, when the  
17 expert panel meets and we start talking about systems  
18 or SSCs in a particular system, we basically see the  
19 PRA, set it aside, and say let's talk deterministically  
20 now. So, we have five questions that we ask that are  
21 related to the questions everyone had to go through when  
22 they set up the Maintenance Rule or the set of components  
23 and systems in the Maintenance Rule. Is it used in EOPs?  
24 Can it cause a plant trip? Is it used in low-power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 shutdown? Will its failure cause another initiating  
2 event? And I forget, off the top of my head, what the  
3 last one is.

4 But these five questions, we assigned a weight  
5 to. Some of them initially we thought were more important  
6 than others. So, EOP usage is very important. Cause  
7 another initiating event is very important.

8 Mentioned in the EOPs, but not necessarily  
9 used is kind, yes, we want to care about, but it is not  
10 that important. So, we assign qualitatively a rank to  
11 each one of the five questions.

12 MEMBER-AT-LARGE STETKAR: That's what you  
13 called the weight --

14 MR. STILLWELL: The weight.

15 MEMBER-AT-LARGE STETKAR: -- of those five  
16 questions?

17 MR. STILLWELL: And when we initially set  
18 it up, we wound up, once you did the multiplication for  
19 each of the five questions, with a rank of 100. So, we  
20 set up our deterministic criteria based on ranges of  
21 10.

22 So, if we came up with an EOP importance  
23 of 4 or 5, and no matter what the PRA said about it,  
24 deterministically, we would say that system, structure,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or component is extremely important in the EOPs; we rely  
2 on it a awful lot. So, therefore, it is risk-significant,  
3 no matter what the PRA says.

4 On the other hand, if we came up with a risk  
5 significance of 5, which I think is actually the lowest  
6 we could get, and we couldn't come up with any other  
7 reason for this thing to even be talked about, it was  
8 obviously unimportant deterministically.

9 And then we looked at the combined criteria,  
10 the PRA actually had three criteria in STP 1 and 2.  
11 Deterministically, we set up a matching three criteria.

12 We said, if it's high PRA, it's high. If it's medium  
13 PRA, it's medium. If it's high, expert panel, then it's  
14 obviously high, no matter what the PRA says. If it is  
15 medium, expert panel, it's medium if PRA is low or medium.

16 But a medium expert panel couldn't drop a high PRA down.

17 So, we always defaulted to the higher rank  
18 of whichever process got us to the final rank. That is  
19 basically the blending process we have used to bring  
20 in deterministic information and PRA information.

21 We are going to be following the same process  
22 with the DRAP expert panel. I mentioned we are actually  
23 performing our first systems risk ranking April.

24 MEMBER-AT-LARGE STETKAR: Now what I wanted

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to ask is, where are you -- I think I understand the  
2 basic process. A PRA was performed for the DCD --

3 MR. STILLWELL: Yes.

4 MEMBER-AT-LARGE STETKAR: -- which,  
5 obviously, needs modifications for plant-specific  
6 changes.

7 MR. STILLWELL: Yes.

8 MEMBER-AT-LARGE STETKAR: Are you in the  
9 process of updating that PRA now?

10 MR. STILLWELL: The PRA --

11 MEMBER-AT-LARGE STETKAR: When will it be,  
12 well, when will it be done?

13 MR. STILLWELL: It's done.

14 MEMBER-AT-LARGE STETKAR: And which PRA are  
15 you using, if you say -- oh, it's done?

16 MR. STILLWELL: It's done.

17 MEMBER-AT-LARGE STETKAR: So, that's the  
18 PRA that you are using to feed into the expert panel  
19 that you have --

20 MR. STILLWELL: Right now.

21 MEMBER-AT-LARGE STETKAR: -- constituted  
22 now. Okay.

23 MR. STILLWELL: Right now.

24 Just a little background for those that don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, we are actually building a PRA that will meet current  
2 codes and standards to support risk-informed applications,  
3 but, also, it is how we are going to comply with 50.71(h)  
4 for the operating life of the plant.

5 The PRA that came with the plant is a late  
6 1980/early 1990 vintage PRA. Having upgraded two PRAs,  
7 I don't want to do that anymore. It is easier to start  
8 with a nice, clean piece of paper and say here's my standard;  
9 here's what we've got to have. That process is ongoing.

10 The PRA that supported certification has  
11 been modified to include site-specific departures,  
12 site-specific supplements and also the departures. That  
13 is the PRA we are using to feed this initial set of  
14 risk-ranking information to the DRAP expert panel.

15 MEMBER-AT-LARGE STETKAR: One last question,  
16 to keep us moving on. You've obviously not populated  
17 the DRAP list yet, other than perhaps things that --

18 MR. STILLWELL: The PRA information --

19 MEMBER-AT-LARGE STETKAR: Yes, I was going  
20 to say the absolute PRA pass/fail. But in terms of anything  
21 that might come out of the expert panel, when will the  
22 DRAP list be populated? Prior to issuance of the COL?

23 MR. STILLWELL: Our goal is to populate the  
24 list this year.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER-AT-LARGE STETKAR: Okay.

2 MR. STILLWELL: That is our goal.

3 MEMBER-AT-LARGE STETKAR: I want to ask the  
4 staff about what they do with -- this has been a continuing  
5 concern. It is DRAP lists for a plant like yours. It  
6 is RTNSS lists for the pure passive plants. They are  
7 parallel, and we have been having difficulties in our  
8 committees understanding when those lists get populated,  
9 how they are populated, and how they are reviewed, once  
10 they are populated. So, that is the reason for this.

11 MR. STILLWELL: Our goal is to get through  
12 the systems this year.

13 MEMBER-AT-LARGE STETKAR: Okay.

14 MR. STILLWELL: At least the first time  
15 through. The reason is because we are doing detail design,  
16 and we are also starting to purchase large pieces of  
17 equipment. So, we need to get reliability information  
18 to our end of the contracts, where we think it is going  
19 to be important. So, our goal is this year. I won't  
20 say what we've done by the end of the year, but our goal  
21 is --

22 MEMBER-AT-LARGE STETKAR: I will ask the  
23 staff more about when things get checked off.

24 Thanks. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STILLWELL: And as I mentioned, DRAP  
2 feeds into the Maintenance Rule. Basically, it is the  
3 initial set of components that will be in 50.60-whatever  
4 it is. My mind just went blank.

5 CHAIRMAN ABDEL-KHALIK: Go on. That's okay.  
6 They're all numbers.

7 MR. STILLWELL: And the program has been  
8 implemented. It is in place, and we have the expert panel  
9 assembled.

10 MEMBER-AT-LARGE STETKAR: I was going to  
11 ask about one last thing.

12 MR. STILLWELL: Yes, sir.

13 MEMBER-AT-LARGE STETKAR: You said that you  
14 have already done the PRA input to the process. Did you  
15 identify any non-safety-related equipment for the DRAP  
16 list from the PRA?

17 MR. STILLWELL: There has always been  
18 non-safety-related equipment in the DRAP program for  
19 the ABWR.

20 MEMBER-AT-LARGE STETKAR: Okay.

21 MR. STILLWELL: Feedwater condensate  
22 primarily, but things like the AC independent water  
23 addition pump --

24 MEMBER-AT-LARGE STETKAR: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. STILLWELL: -- is a non-safety-related  
2 that is very important.

3 MEMBER-AT-LARGE STETKAR: Does CTG show up,  
4 just out of curiosity?

5 MR. STILLWELL: I can't imagine why the CTG  
6 would possibly show up. It's No. 1 on the list.

7 (Laughter.)

8 How can I forget that one. It's like being --

9 MEMBER-AT-LARGE STETKAR: I was just --

10 MR. STILLWELL: Yes, it's No. 1. It's at  
11 the top of the list.

12 Okay, the Maintenance Rule program, we have  
13 talked a little bit about it. NEI and the new plants  
14 worked with the NRC to identify how the Maintenance Rule  
15 was going to be implemented for the new plants.

16 We, the industry, developed NEI-07-02, which  
17 has been reviewed by the staff. I believe, but I am not  
18 sure, that there is a Safety Evaluation Report on the  
19 NEI template. If not, it has been accepted as this is  
20 how you are going to implement the Maintenance Rule.  
21 We basically adopted the NEI-07-02 template for the  
22 Maintenance Rule for operations of the ABWR.

23 I guess this is a good place to ask if anyone  
24 has any questions on the design and reliability assurance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 program implementation at South Texas.

2 (No response.)

3 If not, I will keep going.

4 The last set of slides are COLA information  
5 items. We had four COLA information items in Chapter  
6 17. The QA programs for construction and operation are  
7 covered in 17.5S. The procedures for design reliability  
8 assurance programs, 17.2 and 17.3, are discussed in 17.4S.  
9 Provision for ORAP is really the 17.6S Maintenance Rule.

10 ITAAC, the only ITAAC associated with Chapter  
11 17 is the design reliability assurance program ITAAC,  
12 summarized right here. It is inspections for scope,  
13 purpose, and objectives. It is the process we use to  
14 evaluate and prioritize SSCs. The list is  
15 risk-significant SSCs. The process for determining  
16 dominant failure modes: key assumptions and insights  
17 are considered, and site-specific ITAAC are not provided.

18 That is basically our discussion of Chapter  
19 17, unless there's other questions.

20 CHAIRMAN ABDEL-KHALIK: Are there any  
21 questions for STP on Chapter 17?

22 (No response.)

23 Okay, thank you, Mr. Stillwell.

24 MR. STILLWELL: Thank you for your time.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN ABDEL-KHALIK: We will move on to  
2 the staff's presentation.

3 MR. ANAND: Good afternoon.

4 My name is Raj Anand, and I'm the Project  
5 Manager for the Chapter 17 of the South Texas COL  
6 application.

7 I have with me Garrett Newman and Mr. Todd  
8 Hilsmeier. Garrett is the Technical Reviewer for Section  
9 17.0, 17.1, 17.2, and 17.5S, quality assurance program.  
10 Todd is a Technical Reviewer for the Section 17.3, 17.4S,  
11 related to the reliability assurance program, and 17.6,  
12 the Maintenance Rule program.

13 We thank STP for their presentation. The  
14 staff agrees with the STP presentation.

15 Chapter 17 addresses the quality assurance  
16 program during design, construction, the operation phase,  
17 as well as the reliability assurance program and the  
18 Maintenance Rule program.

19 There are no departures in Chapter 17.

20 Section 17.0, 17.1, 17.2, and 17.3  
21 acknowledge the use of the ABWR DCD.

22 Section 17.4S describes the STP reliability  
23 program for detailed design, procurement, construction,  
24 and operations. The program ensures that the design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reliability of the risk-significant systems, structures,  
2 and components is maintained over the life of the plant.

3 Section 17.5S provides the quality assurance  
4 program guidance and is based upon the industry's template  
5 NEI-06-14A for new plants.

6 Section 17.6S describes the Maintenance Rule  
7 program. This section incorporates by reference the  
8 Nuclear Energy Institute's Report No. NEI-07-42, Genetic  
9 FSAR template guidance for Maintenance Rule program for  
10 plant licensed under 10 CFR Part 52.

11 With this, I will turn it over to Garrett  
12 Newman to discuss the important features of the quality  
13 assurance program during the design, construction, and  
14 operations phase.

15 After Garrett has finished with his  
16 presentation, then I will request Todd Hilsmeier to discuss  
17 the important issues related to the DRAP.

18 Garrett, do you want to start?

19 MR. NEWMAN: Okay, thank you, Raj.

20 Good afternoon.

21 My name is Garrett Newman. I'm a Reactor  
22 Operations Engineer in the Quality and Vendor Branch  
23 2 in the Division of Construction and Inspection and  
24 Operational Programs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           A brief introduction: I've been with the  
2 agency almost four years. I came to the Office of New  
3 Reactors from Region I, where I was the local qualified  
4 reactor inspector. I served two short-term stints as  
5 a resident inspector at Susquehanna and Indian Point  
6 3.

7           As Raj and STP mentioned, Section 17.0 through  
8 17.2 incorporate those sections of the ABWR DCD. In  
9 addition, Section 17.0 addresses COL Information Item  
10 17.1, QA programs for construction and operation. In  
11 that section, they point to Section 17.5S to address  
12 that item.

13           Section 17.1 is QA during design and  
14 construction, and Section 17.2 is DRAP programs during  
15 the operations phase. Those sections also point to 17.5S  
16 for those programs.

17           The staff conducted an inspection in January  
18 of 2009 focused on STP's activities during their due  
19 diligence assessment of Toshiba to determine whether  
20 they were qualified by EBWR design for Units 3 and 4  
21 in accordance with 10 CFR Part 52, Appendix A.

22           As a followup, the staff issues an RAI because  
23 the STP was using the operational quality assurance  
24 programs for Units 1 and 2 for activities for the COL

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 application. Staff requested STP to incorporate the OQAP  
2 into Section 17.1. The STP's response included a  
3 commitment to incorporate that into 17.1. We found that  
4 response acceptance, and it is being tracked as a  
5 confirmatory item.

6 With the exception of that item, the staff  
7 found those three sections acceptable.

8 Section 17.5S is the quality assurance  
9 program guidance section. This section references the  
10 Units 3 and 4 quality assurance program description.  
11 The staff used Appendix B to 10 CFR Part 50 and NUREG-800  
12 and the SRP Section 17.5 to evaluate this section on  
13 the QAPD.

14 As mentioned before, the QAPD was based on  
15 the NEI template 06-14. This template provided a general  
16 QA program for ESP and COL applicants to be supplemented  
17 by applicant-specific information in bracketed sections.

18 The template is based on ASME NQA-1-1994 and, as endorsed,  
19 it is the method to comply with Appendix B.

20 Provision 7 of the template was submitted  
21 in July 2009. It was endorsed in December of 2009.

22 There is one open item relating to this section,  
23 and I will discuss that now. The staff issued RAI 17.5-9  
24 because Part 4 of the QAPD regulatory commitments did

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not adequately address QA-related guidance to fully comply  
2 with Appendix B. The specific items are listed here that  
3 were mentioned in the RAI.

4 Staff and the industry are working through  
5 the generic issues through an update to the template  
6 06-14, and the STP had indicated that they had planned  
7 on updating to the newer revision, once it is endorsed  
8 by the NRC, to address those issues.

9 STP responded yesterday to the RAI, and the  
10 staff has not yet completed the review of that. This  
11 is, therefore, being tracked as an open item.

12 Unless there's any questions these sections,  
13 I am going to pass it to Todd.

14 CHAIRMAN ABDEL-KHALIK: Any questions?

15 (No response.)

16 Let's move on then.

17 MR. ANAND: Thank you, Garrett.

18 Now I will request Tod Hilsmeier to discuss  
19 some important topics related to design reliability  
20 assurance program, DRAP, and the Maintenance Rule program,  
21 as discussed in Chapter 17 of the Draft Safety Evaluation  
22 Report.

23 MR. HILSMEIER: Thank you, Raj.

24 My name is Todd Hilsmeier, and I will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussing STP's RAP program and, also, the Maintenance  
2 Rule program description.

3 As a background, I got my PhD at Ohio State  
4 University, where I specialized in reliability risk  
5 analysis. I worked at Sciencetech for six years doing PRA  
6 analysis, mostly PRA modeling.

7 Then, tired of traveling, I joined the  
8 utilities for six years and specialized, worked in the  
9 PRA group, more doing applications and some modeling.

10 Then, the grass is greener on the other side.

11 It is great to work here at NRC. So, I joined NRC almost  
12 six years ago, again, working in the PRA group. So, I  
13 have about 17 years' experience in PRA.

14 The first slide I would like to talk about  
15 is FSAR Section 17.4S, which describes STP's RAP program  
16 and addresses the necessary COL information items. We  
17 will discuss a review of Section 17.4S through the following  
18 three subject areas:

19 First, we will discuss the staff's review  
20 of these essential elements of DRAP, which addresses  
21 COL Information Items 17.2 and 17.3, on how the applicant  
22 will implement a DRAP program.

23 Next, we will discuss the staff's review  
24 of the methodology for identifying the risk-significant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 SSCs. So, it also addresses COL Information Item 17.2.

2 And lastly, we will discuss the staff's review  
3 of the proposed process for integrating RAP into  
4 operational programs, which addresses COL Information  
5 Item 17.4.

6 Next slide.

7 This slide presents the staff's review of  
8 the essential elements of DRAP. The applicant described  
9 in Section 17.4S the essential elements of DRAP. The  
10 essential elements of DRAP is basically a process or  
11 a control that is applied by the applicant to ensure  
12 that the plant is designed and constructed consistent  
13 with the key assumptions and risk insights and to ensure  
14 that the risk-significant SSCs are appropriately  
15 developed, retained, and communicated to the appropriate  
16 organizations.

17 Section 17.4S described these essential  
18 elements, which include, describing at a high level,  
19 how the organizations responsible for developing and  
20 implementing DRAP activities interface to ensure that  
21 the plant is designed and constructed consistent with  
22 the key assumptions and risk insights of the PRA and  
23 deterministic analyses.

24 Also, the essential elements include how

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the design control change process provides a feedback  
2 mechanism to the risk management organization, and the  
3 quality control is used for identifying the  
4 risk-significant SSCs.

5 In developing a PRA model, it is very important  
6 that the PRA group and the design engineering group are  
7 interfacing. Because when there are design changes, those  
8 design changes need to be communicated to the PRA group,  
9 to update the PRA model and risk-significant SSCs. And  
10 if any new risk insights or key assumptions are made,  
11 that needs to be communicated to the design organization  
12 to ensure that assumptions are realistic and achievable.

13 Also, the essential elements include  
14 procedural controls for DRAP activities, record controls  
15 for DRAP activities, a corrective action process applied  
16 to DRAP activities, and, also, audit plans for DRAP  
17 activities.

18 And the applicant plans to proceduralize  
19 and start implementing the essential elements of DRAP  
20 by March 2010. As Bill Stillwell mentioned, they are  
21 already implementing these essential elements.

22 The staff will conduct an audit to verify  
23 this activity, to verify that the essential elements  
24 are properly implemented, most likely early this summer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This is Confirmatory Item 17.04-8

2 The next slide.

3 MEMBER-AT-LARGE STETKAR: Todd, that audit  
4 is simply to examine the basic elements of the program,  
5 right?

6 MR. HILSMEIER: Right. Exactly.

7 MEMBER-AT-LARGE STETKAR: Okay. Thanks.

8 MR. HILSMEIER: The next slide presents the  
9 staff's review of the methodology for identifying the  
10 risk-significant SSCs.

11 One question that is asked pretty often is,  
12 what do we do with the risk-significant SSCs? RTNSS does  
13 one thing, and RAP does another. Basically, under RAP,  
14 the risk-significant SSCs are identified because the  
15 non-safety-related risk-significant SSCs are subjected  
16 to quality assurance controls that meet the provisions  
17 of SRP 17.5, Part V. We don't mention anything about  
18 the safety-related SSCs because they are already covered  
19 under Appendix B of 10 CFR Part 50.

20 Also, the risk-significant SSCs are  
21 identified to ensure that the maintenance and testing  
22 activities address the dominant failure modes of these  
23 SSCs.

24 Lastly, the risk-significant SSCs are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 considered high safety-significant under the Maintenance  
2 Rule. What that means is these high safety-significant  
3 SSCs are given explicit reliability availability  
4 performance criteria based on the PRA reliability  
5 availability values.

6 The initial identification of the  
7 risk-significant SSCs for preparation of the STP's COLA  
8 application is provided in Appendix 19K of the FSAR.  
9 We will be discussing that table, that list of  
10 risk-significant SSCs, during a Chapter 19 presentation  
11 to ACRS.

12 MEMBER-AT-LARGE STETKAR: But that list is  
13 based on the DCD PRA of the DCD design? Is that correct?

14 MR. HILSMEIER: And modified/supplemented  
15 based on the plant-specific information and departures.

16 MEMBER-AT-LARGE STETKAR: Okay. Yes.  
17 Okay.

18 MR. HILSMEIER: So, to fully understand and  
19 appreciate the changes to a list, we need to discuss  
20 it in context with the changes to the PRA. So, we felt  
21 it's most appropriate --

22 MEMBER-AT-LARGE STETKAR: I mean, if I can  
23 understand it, the list that currently exists in Section  
24 19K of the STP COLA FSAR is a list that is derived from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the current PRA?

2 MR. STILLWELL: Let me see if I can clarify  
3 your question to give you the correct --

4 MEMBER-AT-LARGE STETKAR: I'm trying to find  
5 out where that --

6 MR. STILLWELL: You are looking at Revision  
7 3 of the COLA, the one that went in last September.

8 MEMBER-AT-LARGE STETKAR: Uh-hum.

9 MR. STILLWELL: That list was based on the  
10 PRA that was modified to support Revision 0. We have  
11 since responded to an RAI with the PRA that includes  
12 STP departures. So, an RAI response has the latest and  
13 greatest 19K list, if you will.

14 MEMBER-AT-LARGE STETKAR: No, I hear you,  
15 Bill. This is part of what we're running into, is it  
16 is difficult for our -- we haven't looked at Chapter  
17 19 yet officially of anything. But part of the problem  
18 that we are running into, whether it is RTNSS or DRAP,  
19 is there seems to be -- and this is not unique to STP;  
20 it is across the board -- this undercurrent of the real  
21 analyses and the real lists being documented in, you  
22 know, large numbers of RAI responses rather than pulled  
23 together everywhere. So, this is just kind of a  
24 forewarning that I guess we will need to look there for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this one also.

2 MR. STILLWELL: The 3 and 4 comes out before  
3 we get to Chapter 19, then it will be in Rev. 4.

4 MEMBER-AT-LARGE STETKAR: Okay. But that  
5 list -- well, we will worry about that --

6 MR. STILLWELL: But, yes, there is a  
7 consolidated list that is basically all of the information  
8 we know from the PRA.

9 MEMBER-AT-LARGE STETKAR: What I was going  
10 to ask Todd, then, is, is the last -- well, I will let  
11 you get to the last bullet. Sorry.

12 (Laughter.)

13 MEMBER SIEBER: Don't shoot him until he's --

14 MEMBER-AT-LARGE STETKAR: That's right.  
15 I've got to get you lined up on the crosshairs first.

16 (Laughter.)

17 MR. HILSMEIER: As the applicant enters the  
18 detailed design and construction phases, the list of  
19 risk-significant SSCs will be revised/updated using the  
20 criteria shown on this slide.

21 As Bill Stillwell talked about, from the  
22 PRA, SSCs may be considered risk-significant if the  
23 Fussell-Vesely is .005 or more or if the raw is greater  
24 than or equal to 2.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           And also, the expert panel is established  
2           to identify additional risk-significant SSCs based on  
3           deterministic techniques and operating experience.

4           The applicant, based on teleconference calls,  
5           the applicant plans to identify the risk-significant  
6           SSCs using the revised methodology in 2010. We plan to  
7           conduct an audit to verify this activity.

8           MEMBER-AT-LARGE STETKAR: Now my question.

9           MR. HILSMEIER: Okay.

10          MEMBER-AT-LARGE STETKAR: Where will that  
11          list be documented? Assuming that the last bullet refers  
12          to your audit of, what I will hopefully call, the final  
13          list for the COL.

14          MR. HILSMEIER: It needs to be documented  
15          in the FSAR.

16          MEMBER-AT-LARGE STETKAR: Okay.

17          MR. HILSMEIER: Because one of the -- I don't  
18          really want to say, "requirements". The RAP is a funny  
19          animal. Some people say it is required; some people say  
20          it is not required. So, I am going to use the term  
21          "requirements". Anyway, based on the staff guidance,  
22          the FSAR needs to contain a complete list of RAP SSCs.  
23          So, if that list is updated with the revised methodology,  
24          the FSAR needs to contain that list. And that is what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we will be looking for, that the final list is included  
2 in the FSAR.

3 MEMBER-AT-LARGE STETKAR: So that, if I step  
4 back from the kind of interim mechanics of the process,  
5 eventually, there will be an SER written on some revision  
6 of the FSAR that includes the final DRAP list, is that  
7 correct?

8 MR. HILSMIEIER: Correct. That's what I  
9 expect.

10 MEMBER-AT-LARGE STETKAR: Okay. What I am  
11 trying to understand is, from our perspective, because  
12 we only get involved in this process up to a certain  
13 point, that the DRAP list, the finalization of the DRAP  
14 list is not an ITAAC item that is continued post-COL.  
15 It is only subject to staff audits, that, indeed, the  
16 SER -- however that final DRAP list is negotiated, that  
17 list will be subject to a staff review and an SER. Is  
18 that --

19 MR. HILSMIEIER: Yes.

20 MEMBER-AT-LARGE STETKAR: Okay.

21 MR. HILSMIEIER: And I see that list as a  
22 live list. As the PRA changes, that list may change.

23 MEMBER-AT-LARGE STETKAR: At some point  
24 frozen in time, Rev. X of STP COL FSAR with an SER --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HILSMEIER: Right.

2 MEMBER-AT-LARGE STETKAR: -- that's stamped,  
3 that will be a frozen-in-time snapshot of what that list  
4 is?

5 MR. HILSMEIER: Yes.

6 MEMBER-AT-LARGE STETKAR: Okay. And any  
7 changes, obviously, if you change things later, that's  
8 later, but --

9 MR. HILSMEIER: Right.

10 MEMBER-AT-LARGE STETKAR: That's good.  
11 That's reassuring, actually. I am glad to hear that.

12 MR. HILSMEIER: Thank you.

13 The next --

14 MEMBER-AT-LARGE STETKAR: I hope that it  
15 actually works that way.

16 MR. HILSMEIER: Yes.

17 MEMBER-AT-LARGE STETKAR: Unfortunately,  
18 yours is the most coherent presentation that we have  
19 heard about how that list will be developed and when  
20 it will be developed and how it will be reviewed --

21 MR. HILSMEIER: Right.

22 MEMBER-AT-LARGE STETKAR: -- you know, of  
23 any of the COL applicants that we have interfaced with  
24 so far.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. HILSMEIER: RAP has a long history. The  
2 previous guidances were kind of vague in certain areas.  
3 That led to these issues.

4 One of my projects for the past year is to  
5 write an ISG to clarify what RAP is.

6 MEMBER-AT-LARGE STETKAR: Said just shut  
7 me off.

8 I just wanted to ask, I tend to look at RAP  
9 and RTNSS as entirely parallel processes. It is just  
10 an artifice of what type of machine you are dealing with.

11 If you have been working for the last year  
12 to try to pull together things under the RAP side of  
13 that process, have you been working with the RTNSS people  
14 at all, or are they just completely separate from you?

15 MR. HILSMEIER: No, we are all in the same  
16 group.

17 MEMBER-AT-LARGE STETKAR: Okay.

18 MR. HILSMEIER: And I've been working with  
19 them.

20 MEMBER-AT-LARGE STETKAR: Okay. Good.  
21 Thanks.

22 MR. HILSMEIER: In the ISG, we  
23 request/recommend -- it is a guidance, so we can't  
24 require -- but we recommend that written SSCs are included

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in RAP. It doesn't apply to STP because you're an active  
2 plant, but for like other design centers that are passive  
3 plants, the written SSCs are included in RAP. Therefore,  
4 those written SSCs also go through the RAP program.

5 MEMBER-AT-LARGE STETKAR: And, in principle,  
6 they should be in the COL FSAR?

7 MR. HILSMEIER: Yes.

8 MEMBER-AT-LARGE STETKAR: And subject to  
9 review?

10 MR. HILSMEIER: Yes.

11 MEMBER-AT-LARGE STETKAR: Okay. Thanks.

12 MR. HILSMEIER: Any other questions?

13 (No response.)

14 The next slide, please.

15 This slide presents the staff's review of  
16 the integration of RAP into operational programs. The  
17 objective of RAP during the operations phase is to ensure  
18 that the reliability/availability of risk-significant  
19 SSCs are maintained consistent with their  
20 risk-significance.

21 And the applicant proposed to integrate RAP  
22 into the following operational programs:

23 First, the Maintenance Rule program that  
24 is implemented in accordance with Regulatory Guide 1.160,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which endorses NUMARK 93-01 for the Maintenance Rule.

2           And the risk-significant SSCs will be  
3 categorized as having high safety significance. As I  
4 mentioned earlier, this means that the risk-significant  
5 SSCs are given specific reliability and availability  
6 performance criteria based on the  
7 reliability/availability of the PRA in general. There's  
8 exceptions, like if the passive SSC  
9 reliability/availability performance criteria is not  
10 practical for passive SSCs. So that we would use condition  
11 performance criteria in those cases.

12           And also, RAP is integrated into the quality  
13 assurance program for the operations phase in accordance  
14 with the quality assurance program description. And RAP  
15 is also integrated into surveillance testing and service  
16 inspection and service testing under the Maintenance  
17 Rule program.

18           And the staff concluded that the proposed  
19 process for integrating RAP into the operational programs  
20 is acceptable, based on the guidances that we review  
21 17.4 against.

22           The next slide.

23           The next slide discusses staff review of  
24 Section 17.6 on the Maintenance Rule program description.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This section incorporates by reference the generic  
2 template in NEI-07-02, which is a generic template of  
3 Section 17.6 for a COL application.

4 The staff wrote an RAI, 17.06-2, requesting  
5 the applicant to revise 17.6 to incorporate the latest  
6 NEI template guidance, which is 07-02A. NEI 07-02A meets  
7 the requirements of SRP 17.6 and has been approved by  
8 the NRC. So, this is Confirmatory Item 17.06-2. So,  
9 at this time, the staff is unable to finalize its  
10 conclusions for this section as a result of the confirmatory  
11 item.

12 MR. ANAND: In summary, the NRC staff has  
13 reviewed has reviewed the applicant's quality assurance  
14 program for the design, fabrication, construction,  
15 testing, and operation of the STP Units 3 and 4. Based  
16 upon its review, the staff has identified two open items  
17 related to risk-significant SSCs and will discuss these  
18 open items in detail during the Chapter 19 presentation  
19 to the ACRS Subcommittee.

20 The other open item is related to QAPD, and  
21 it is expected to be addressed in the next future revision  
22 of the QAPD, as a result of the latest revision to NEI  
23 template 06-14A, Revision 8.

24 Therefore, the staff is unable to finalize

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 its conclusion concerning Chapter 17, quality assurance  
2 program in accordance with the NRC requirements at this  
3 time. However, the staff has a path forward to close  
4 all these open items in Draft Safety Evaluation Report.

5 Now the staff is ready to take additional  
6 questions the Subcommittee might have.

7 CHAIRMAN ABDEL-KHALIK: Are there any  
8 questions to the staff?

9 (No response.)

10 Well, thank you very much.

11 MR. ANAND: Thanks.

12 CHAIRMAN ABDEL-KHALIK: At this time, I would  
13 like to open the phone line in case there are members --

14 MR. HEAD: I am sorry. I didn't know exactly  
15 where you were in closure. I apologize.

16 But on this last discussion on the DRAP,  
17 I would like to note the existence of the ITAAC that  
18 is a closure mechanism for the DRAP process. So, I think  
19 we will engage the staff and discuss that some more,  
20 and it may be a follow-up item that we will come back  
21 and discuss maybe in a future discussion.

22 That ITAAC exists, and I believe it is -- you  
23 know, I want to make sure that --

24 CHAIRMAN ABDEL-KHALIK: Thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER-AT-LARGE STETKAR: I think our  
2 concern, as kind of I mentioned, is that it has been  
3 very, very difficult for us, as a Committee, to understand  
4 how the DRAP list, you know, the population of the list -- I  
5 understand, theoretically, what is going to be done with  
6 the equipment, once the list is populated in terms of  
7 operational reliability assessment.

8                   Both DRAP and, in a parallel sense, the RTNSS  
9 equipment, where and when, indeed, those lists will be  
10 populated and how the process that the staff will use  
11 to review the lists, not just the theoretical process  
12 of how those lists are populated, but the actual population  
13 of those lists, and your qualification gives me somewhat  
14 continuing unease about that.

15                   MR. HEAD: Okay. Like I say, we will explore  
16 whether or not we want to follow up just exactly how  
17 that list, when that list occurs, and when it takes place  
18 within the respective review process.

19                   MEMBER-AT-LARGE STETKAR: Yes, that is the  
20 reason I was asking.

21                   CHAIRMAN ABDEL-KHALIK: Why don't we take  
22 that as a follow-up item, then, from this Chapter?

23                   MR. HEAD: All right.

24                   CHAIRMAN ABDEL-KHALIK: Okay?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Do STP Units 1 and 2 do  
2 something similar to this in the QA classification space?

3 MR. STILLWELL: Yes, it does.

4 MEMBER SIEBER: Yes, maybe you could briefly  
5 describe that because that is a piece of experience that  
6 is out there.

7 MR. STILLWELL: That's why we think we can  
8 do it.

9 MR. HEAD: Yes, between great quality  
10 assurance and the special treatment exemption, and, then,  
11 that was then transferred over into, basically, the  
12 secondary side of the plant, we have been doing this  
13 for, we think, at least 10 years. I have personally  
14 risk-ranked over 100,000 components.

15 (Laughter.)

16 So, we have been doing it, but I was really  
17 addressing the licensing process with my response. That  
18 was my --

19 MEMBER-AT-LARGE STETKAR: And that was the  
20 source of my question, too.

21 MEMBER SIEBER: Yes. Well, when that came  
22 up with Units 1 and 2, my concern was to try to establish  
23 where there was a difference in reliability between COTS  
24 equipment and the old COQA Class 1 equipment. I did look

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at some of your data and couldn't find it. I couldn't  
2 find a difference.

3 MR. STILLWELL: To date, and it has been  
4 two years since I was really actively involved in it,  
5 we have not seen any changes in failure rate, our operating  
6 experience for the components that we rank and put into  
7 the treatment process.

8 MEMBER SIEBER: Yes.

9 MR. STILLWELL: But, again, it is only 10  
10 years or five years.

11 MEMBER SIEBER: I'm not sure that every  
12 licensee could achieve that.

13 MR. TONACCI: Excuse me. This is Mark  
14 Tonacci.

15 We just got a follow-up item, but I didn't  
16 actually hear the question. It was kind of fuzzy. Can  
17 we restate what the followup is?

18 MEMBER-AT-LARGE STETKAR: I think what we  
19 would like to understand is when, related to the issuance  
20 of the COL, will the DRAP list be populated to the extent  
21 that it can be considered -- I don't want to use the  
22 word "complete" because people are going to hang on that  
23 word -- can be populated to an extent that there is  
24 agreement that there's been a comprehensive evaluation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of both safety-related and non-safety-related risk and  
2 deterministic criteria, that that process has worked,  
3 that there is a list that the applicant presents, and  
4 that list, indeed, has been reviewed by the staff.

5 Now if that is not going to be done as part  
6 of the COL Safety Evaluation, we would like to know that  
7 as soon as possible because, then, it falls over to ITAAC  
8 space, which is a completely different type of staff  
9 audit function.

10 MEMBER SIEBER: Yes, it is.

11 MEMBER-AT-LARGE STETKAR: And quite  
12 honestly, a function that we don't get involved in at  
13 all, or haven't yet.

14 (Laughter.)

15 MR. HILSMEIER: I can answer that now. We  
16 expect the list to be essentially complete before issuance  
17 of the COL.

18 MEMBER-AT-LARGE STETKAR: I heard that, and  
19 I heard what Scott had said.

20 MR. HEAD: It won't be a final list at that  
21 point. I mean --

22 MEMBER-AT-LARGE STETKAR: As I said, I want  
23 to avoid the words "complete", "100 percent", "final",  
24 but I also want to have some confidence that it is simply

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not a description of a program or some subset of things  
2 that the PRA has cranked out, but it hasn't gone through  
3 the rest of the process.

4 MR. HEAD: I think it is a good thing for  
5 us to be able to clarify. So, I appreciate it.

6 CHAIRMAN ABDEL-KHALIK: Okay. All right.

7 You got that, Mark?

8 MEMBER-AT-LARGE STETKAR: It is basically  
9 a process in making sure that we understand where we  
10 are going to be in terms of the DRAP list and its review  
11 at the COL.

12 CHAIRMAN ABDEL-KHALIK: At this time, I would  
13 like to open the phone line to provide an opportunity  
14 for members of the public who may have joined us by telephone  
15 to either make a statement or ask a question.

16 Is there anybody on the line who would like  
17 to make a statement?

18 MR. McINTYRE: Yes, I have a question.

19 CHAIRMAN ABDEL-KHALIK: Yes, sir. Please  
20 identify yourself.

21 MR. McINTYRE: This is John McIntyre from  
22 Charlotte, North Carolina.

23 There was a term used in the presentation  
24 that I was not aware of, and I'm not sure if I heard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it correctly, but it was, from what I heard, RTNSS SSC.

2 CHAIRMAN ABDEL-KHALIK: Okay. Do you want  
3 to take it, Todd?

4 MR. HILSMEIERS: Yes. RTNSS SSCs, the  
5 acronym stands for Regulatory Treatment Non-Safety  
6 Systems. It is a program that was developed for passive  
7 reactors.

8 One of the concerns with the passive reactors  
9 is that there's insufficient operating experience to  
10 show that these passive -- we believe the passive systems  
11 are reliable, but there is insufficient operating  
12 experience to show that.

13 So, we developed the RTNSS program, which  
14 ensures that the non-safety-related systems that provide  
15 the backup to the passive safety-related systems are  
16 reliable and functional. So, the RTNSS program ensures  
17 that the non-safety-related SSCs that provide like a  
18 back-up function to the passive safety-related SSCs would  
19 function reliably, that they have high reliability. So,  
20 RTNSS is geared towards improving or ensuring that those  
21 non-safety systems are reliable.

22 MEMBER-AT-LARGE STETKAR: Well, I think,  
23 Todd, one of the keys for the gentleman who is on the  
24 bridge line is that, by regulation, RTNSS does not apply

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to so-called active plants like South Texas.

2 MR. HILSMEIER: Correct.

3 MEMBER-AT-LARGE STETKAR: It is kind of an  
4 analogous set of equipment, but it applies to the passive  
5 plant designs, like AP1000 and ESBWR.

6 MR. HILSMEIER: Right.

7 MEMBER-AT-LARGE STETKAR: The only reason  
8 I brought it up in this context is, technically, it is  
9 kind of an analogous set of equipment, where it is  
10 potentially important to safety equipment, but not  
11 safety-related and additional regulatory attention is  
12 paid.

13 CHAIRMAN ABDEL-KHALIK: Mr. McIntyre, does  
14 this answer your question?

15 MR. McINTYRE: Yes, it does. Thank you for  
16 the explanation.

17 CHAIRMAN ABDEL-KHALIK: Sure.

18 Is there anybody else on the line who would  
19 like to make a statement?

20 (No response.)

21 Is there anybody else on the line who would  
22 like to ask a question?

23 (No response.)

24 All right. At this time, I guess we will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 close the lines again.

2 On the schedule, we are supposed to sort  
3 of go around and discuss amongst the Subcommittee any  
4 comments, and we have pretty much kept track of all the  
5 open items chapter by chapter. But if there are any  
6 additional comments that the Subcommittee members would  
7 like to add to that, we can do that at this time.

8 Jack?

9 MEMBER SIEBER: Well, during my review of  
10 the documents that formed the basis for this meeting,  
11 the issues that I had I have brought to both the applicant's  
12 attention and the staff's attention, and they have been  
13 dispositioned.

14 And some other issues have come up which  
15 I thought about during the review, but others brought  
16 them up before I got the opportunity. So, I thank the  
17 other members for apparently a good review job.

18 I am satisfied with the outcome of this  
19 meeting.

20 CHAIRMAN ABDEL-KHALIK: Okay, thank you.

21 John?

22 MEMBER-AT-LARGE STETKAR: No, I don't have  
23 anything, other than to say thanks a lot. I mean I thought  
24 your presentations, both the applicant and staff did

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a really good job. And I really appreciate your rapid  
2 and forthcoming feedback on all the detailed technical  
3 stuff. So, I appreciate it. Thank you very much.

4 CHAIRMAN ABDEL-KHALIK: Sam?

5 VICE CHAIRMAN ARMIJO: No, nothing.

6 CHAIRMAN ABDEL-KHALIK: Charlie?

7 MEMBER BROWN: No, nothing.

8 I do appreciate the response to one of my  
9 earlier questions. They answered it at one of the breaks.  
10 I appreciated that.

11 Good discussion. Thank you.

12 CHAIRMAN ABDEL-KHALIK: Okay.

13 Well, at this time, let me add my thanks  
14 and appreciation to both STP and the staff for doing  
15 a good job. Thank you very much.

16 The meeting is adjourned.

17 (Whereupon, at 4:15 p.m., the proceedings  
18 in the above-entitled matter were adjourned.)

19

20

21

22

23

24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



# **Presentation to the ACRS ABWR Subcommittee**

**South Texas Units 3 and 4 COL Application Review**

**Action Items from March 2, 2010, Meeting**

*March 18, 2010*

# **ACRS Action Items For Discussion**

- Part 21 Notifications and Stability Issue
- Fuel Topical Reports/Fuel Amendment
- Japanese ABWR Dose Comparisons
- Uncertainty of the Effluent Releases Predicted by the Current GALE Code



# **Part 21 Notifications and Stability Issue**

# Notifications under Part 21

- All Part 21 submittals are reviewed by NRC.
- DCIP identifies technical areas of concern and forwards to appropriate NRO branches.
- Technical branch chiefs assess applicability to applications under their review.
- Issues of general concern addressed in generic communications.
- Formal procedure for dealing with Part 21 issues in LIC-403.
- Part 21 issues associated with a certified design are to be identified upon a COLA referencing that design.

# Part 21: Stability Analysis

- 2001-23-5, GE, 8-31-2001, Potentially non-conservative stability detect and suppression trip set points
- STP3/4 which is an Option III plant is committed to confirm the accuracy of the cycle specific DIVOM (Delta CPR/Initial CPR Vs Oscillation Magnitude) curve
- STPNOC will provide an updated Stability Option III analyses including resolution of the Part 21 issues before fuel load (COM 4.4-3)



# Fuel Topical Reports/Fuel Amendment

# Fuel Topical Reports (TR)/ Fuel Amendment

- TRs are in support of STPNOC's future fuel amendment request (2013) and are not addressed part of the RCOL
- Coordination between the ABWR, Power Uprate and Thermal Hydraulic Phenomena subcommittees has begun for TRs with dual applicability for ABWRs and BWRs
- First TR is currently under staff review, expected to be finished Fall 2010.
- Subsequent TRs will be available for ACRS review and presentation as they are received from STPNOC



# Japanese ABWR Dose Comparisons

# Comparison of Estimated Annual Occupational Dose for STP and ABWR

- Only one data point is available for an individual ABWR
- Kashiwazaki-Kariwa, Units 6 & 7 (K-6/7) for 1997 to 2004
- K-6/7 = **0.49** person-mSv/MW-yr
- STP 3 & 4 = **0.82** person-mSv/MW-yr  
(Calculated assuming 85% operating capacity)

# US and Japanese BWR Occupational Dose Data

	Average Collective Dose (person-Sv)	person-mSv/MW-yr
Average Japanese Improved BWR ('93-'03) =	1.13	Unavailable
Kashiwazaki-Kariwa Units No. 6 and 7('97-'04) =	0.546	0.49
Estimated South Texas Unit 3 & 4 (per unit) † =	<b>0.909</b>	<b>0.82</b>

† Estimated STP 3 & 4 person-mSv/MW-yr based on the following assumptions:

Max Dependable Electrical Output = 1300 MWe  
 Maximum Dependable Capacity Achieved = 85% (US average 1973-2008)  
 Electrical Generation (MW-yr) = 1105  
 Estimated Annual Occupational Dose (person-mSv/yr) = 909

=> 909 (person-mSv/yr) / 1105 (MW-yr) = 0.82 person-mSv/MW-yr

**or**


=> 909 (person-mSv/yr) / 1196 (MW-yr) = 0.76 person-mSv/MW-yr  
 [if assume 92% capacity (US average 2000-2008)]

## References:

- ‡ Compiled from data contained in ISOE Asian Technical Center, ISOE Information Sheet 2, 4, 6, 8, 12, 14, 16, 18, 21, 26, 28, 29, 30, 32, and 33. Published 1995 to 2009
- \*\* Approximate value from ISOE Asian Technical Center, ISOE Information Sheet 33, Figure 2, 2009
- + Compiled from data in Table 4-1 of NUREG 0713, Volume 30
- ++ Converted to SI units from data in Table 4-1 of NUREG 0713, Volume 30
- \* Improved plants came into commercial operation in and after FY 1983 with improved design features intended for enhanced reliability, lower exposure and more efficient inspection works. (Includes Kashiwazaki-Kariwa Units No. 6 and 7 beginning in 1996 and 1997)
- † Average of Conventional and Improved BWR values

# US and Japanese BWR Occupational Dose Data

Average Collective Dose and Dose per MW-yr  
Japan and US Plants





# **Uncertainty of the Effluent Releases Predicted by the Current GALE Code**

## **Staff Answered Two Questions:**

- Are the structures and algorithms in GALE86 relevant to present designs?
- How accurate is GALE86 when used to predict effluent releases from new reactors?

# Are the structures and algorithms in GALE86 relevant to present designs?

**Yes**

- Radionuclide reactor coolant concentrations based on ANS 18.1
- New reactor designs for radioactive waste management systems are just variations of the same processes modeled in GALE86

# How accurate is GALE 86 when used to predict effluent releases from new reactors?

- GALE86 over predicts most liquid and gaseous effluents by at least a factor of 2, and in most cases an order of magnitude or more
- GALE86 predictions for H-3 and C-14 are reasonably accurate


# **Action Items from March 2, 2010, Meeting**

Discussion/Committee Questions

# South Texas Project Units 3 & 4 Presentation to ACRS Subcommittee **ACRS Follow-up Items**

Topics:


(1) Japanese Occupational Dose Experience



# Approximate dose during Outages (average from 1997 to 2002, BWR)


## Kashiwazaki-Kariwa

- K1 through K5 are BWR-5 plants
- K6 and K7 are ABWR



Summary of data provided by TEPCO, Tokyo Electric Power Company, Owner/Operator of BWR plants since 1971.

# South Texas Project Units 3 & 4 Presentation to ACRS Subcommittee Chapter 5: Reactor Coolant System and Connected Systems



# Agenda

- Introduction
- Contents of FSAR Chapter 5
  - Departure Information
  - Site-Specific Supplements
  - COL License Information Items
- ITAAC

# Attendees

Scott Head	Regulatory Affairs Manager, STP 3&4
Thomas Daley	Engineering Supervisor, STP 3&4
Bill Stillwell	PRA Supervisor, STP 3&4
Coley Chappell	Licensing, STP 3&4

# Chapter Summary and Contents

- 5.1 Reactor Coolant System and Connected Systems
- 5.2 Integrity of Reactor Coolant Pressure Boundary
- 5.3 Reactor Vessel
- 5.4 Component and Subsystem Design
- 5A (Deleted)
- 5B RHR Injection Flow And Heat Capacity Analysis  
Outlines

# STD DEP T1 2.4-3 RCIC Turbine/Pump

- Improved Monoblock Design (pump and turbine within same casing)
- System simplification removes requirements for:
  - Oil lubrication or oil cooling system (totally water lubricated)
  - Shaft seal
  - Barometric condenser
  - Steam bypass line for startup
  - Vacuum pump and associated penetration piping or isolation valves
- Meets or exceeds all safety-related performance criteria
  - Start time and flow rate
  - Low steam pressure operation

# Tier 2 Departures

## **STD DEP 5.2-2:** PSI/ISI NDE of Reactor Coolant Pressure Boundary

- Changed requirements for weld NDE from RG 1.150 to ASME Section XI, Appendix VIII

## **STD DEP 5.3-1:** Reactor Pressure Vessel Material Surveillance Program

- Clarified the number of test specimens and lead factor.
- Program is addressed in COL License Information Item 5.5.

## **STD DEP 5.4-1:** Reactor Water Cleanup System

- Flow capacity of pumps doubled: 1% of rated feedwater flow to 2%
- Pump discharge shutoff head increased: 160 m to 182 m.
- Pumps/heat exchanger design pressure increased: 10.20 to 10.65 MPaG.

## **STD DEP 5.4-2:** Reactor Internal Pump (RIP) Motor Cable Box

- Reduced size of cable box, and added plug-in type power connector.

## **STD DEP 5.4-3:** Residual Heat Removal System Interlock

- Clarified that wetwell spray is used with suppression pool cooling mode.

## Tier 2 Departures (cont)

### **STD DEP 5.4-4:** Recirculation Motor Cooling System

- Recirculation motor heat exchanger shell, tube sheet and water box material is carbon steel or stainless steel: description of connection points is deleted to permit both materials, to enhance resistance to flow accelerated corrosion (FAC).

### **STD DEP 5.4-5:** Addition of Vent Line from Reactor Water Cleanup System Spray Line to RPV Head Vent Line

- Prevents accumulation of hydrogen in the RPV Head Spray Line.

### **STD DEP 5A-1:** Delete Appendix on Compliance With RG 1.150

- Ultrasonic examination of RPV will be conducted in accordance with ASME Section XI, Appendix VIII.

### **STD DEP 5B-1:** Residual Heat Removal Flow and Heat Capacity Analysis

- Increases the heat removal capacity of the RHR heat exchangers to allow reduced outage time.

# COL License Information Items

## 5.1 Conversion of Indications

- Surveillance procedures convert drywell leakage indications into a common leakage equivalent for unidentified and identified leakage to ensure Technical Specification leakage requirements are met (FSAR Section 5.2.6.1)

## 5.2 Plant Specific ISI/PSI

- Program will be based on the 2004 Boiler and Pressure Vessel Code section XI (FSAR Section 5.2.6.2)

## 5.3 Reactor Vessel Water Level Instrumentation

- Backfill water flow to the instrument reference leg is supplied by the Control Rod Drive System to prevent formation of gas pockets in the reference leg (FSAR Section 5.2.6.3)

## 5.4 Fracture Toughness Data

- Data based on the actual RPV materials will be provided in the FSAR amendment that occurs one year after acceptance of the RPV on site (FSAR Section 5.3.4.1)

# COL License Information Items (cont)

## 5.5 Materials & Surveillance Capsule

- Program will be in accordance with “Reactor Pressure Vessel Material Surveillance Program”, Toshiba Corporation, April, 2009 (UTLR-0003, Rev. 0) (FSAR Section 5.3.4.2)

## 5.6 Plant Specific Pressure-temperature Information

- Plant specific calculations for  $RT_{NDT}$ , stress intensity factors, and pressure-temperature curves similar to those in RG 1.99 and SRP 5.3.2 will be provided in a FSAR amendment prior to receipt of fuel (FSAR Section 5.3.4.3)

## 5.7 Testing of Main Steam Isolation Valves

- Testing of MSIVs under operating conditions will be conducted during the initial test program (FSAR Section 5.4.15.1)

# COL License Information Items (cont)

## 5.8 Analysis of 8-Hour RCIC Capability

- Capability of RCIC to operate for 8 hours during a SBO event will be demonstrated during the initial test program (FSAR Section 5.4.15.2)

## 5.9 ACIWA Flow Reduction

- Hydraulic analysis will be performed to determine if a flow reduction device is needed based on actual flow rate capacities, pressure, and hose size. Analysis will be available prior to commencement of Preoperational Test Program. (FSAR Section 5.4.15.3)

## 5.10 RIP Installation & Verification During Maintenance

- Procedures address RIP installation and verification of motor bottom cover and visual monitoring for leakage during impeller-shaft and plug removal. Contingency plan assures that core and spent fuel cooling can be provided in the event of loss of coolant during RIP maintenance. (FSAR Section 5.4.15.4)

# Chapter 5: Reactor Coolant System and Connected Systems

## ITAAC

- ITAAC for the RHR system is contained in Tier 1 Subsection 2.4.1, Table 2.4.1
  - Verification of acceptable system flow rates in augmented fuel pool cooling mode of operation
  
- ITAAC for RCIC system is contained in Tier 1 Subsection 2.4.4, Table 2.4.4
  - Verification of RCIC pump performance
  - Verification of automatic start/stop functions of system

# Chapter 5

## Questions and Comments





# **Presentation to the ACRS Subcommittee**

## **SER/OI Chapter 5 “Reactor Coolant System and Connected Systems”**

*March 18, 2010*



# ACRS Subcommittee Presentation

## SER/OI Chapter 5

### Staff Review Team

- **Project Managers**
  - George Wunder
  - Tekia Govan
  
- **Technical Staff**
  - SRSB, Chief, Joseph Donoghue
  - SRSB, Lead Reviewer, George Thomas
  - SBPB, Chief, Samuel Lee
  - SBPB, Lead Reviewer, Chang-Yang Li
  - CIB2, Acting Chief, Neil Ray
  - CIB2, Lead Reviewers, Steven Downey, Timothy Steingass and Thomas Scarbrough

# Overview of Chapter 5 Review Topics of Interest

<p><b>Reactor Vessel Materials</b></p>	<p><u>COL Item 5.4</u>: COL applicant to provide fracture toughness data  <u>COL Item 5.5</u>: COL applicant to provide a description of their RVSP.</p>
<p><b>P-T Limits</b></p>	<p><u>COL Item 5.6</u>: COL applicant to provide site-specific P-T limits curve.</p>
<p><b>Preservice/Inservice Inspection</b></p>	<p><u>STD DEP VENDOR</u>: PSI/ISI Program  <u>STD DEP 5.2-2</u>: Examination Categories  <u>STD DEP 5A-1</u>: Ultrasonic Examination of RPV</p>
<p><b>Rx Coolant Pressure Boundary Leakage</b></p>	<p><u>COL Item 5.1</u>: Conversion of Indicators  <u>STD DEP 7.3-12</u>: Leak Detection and Isolation System Sump Monitoring</p>
<p><b>10 CFR 50.55 Compliance and Code Cases</b></p>	<ul style="list-style-type: none"> <li>• Updates to Codes and Standards</li> <li>• Updates to Code Cases</li> </ul>
<p><b>RCIC Turbine Design Change</b></p>	<p><u>STD DEP T1 2.4-3</u>: RCIC Turbine/PumpSTP FSAR reflects new RCIC turbine-pump design</p>

# Summary of Staff Review

- Rx Vessel Materials
- P-T Limits
- Preservice/Inservice Inspection
- Rx Coolant Pressure Boundary Leakage
- Compliance with 10 CFR Part 50 Section 50.55 and Applicable Code Cases
- RCIC Turbine Design Change

# Reactor Vessel Materials (5.3.1)

- Fracture Toughness Data
  - ABWR DCD COL Item 5.4
    - COL applicant will provide fracture toughness data based on the limiting reactor vessel materials
  - STP Response
    - fracture toughness data based on limiting RV actual materials will be provided in the first regular FSAR update that occurs 1 year after the onsite acceptance of the RV (COM 5.3-1)
  - Staff Conclusion
    - Resolution of COL item is acceptable (10 CFR 50 Appendix G)
  
- Materials and Surveillance Capsule
  - ABWR DCD COL Item 5.5
    - COL applicant will provide a description of their RVSP
  - STP Response
    - Provided a topical report containing their RVSP
    - Milestone for RVSP implementation: Prior to fuel load (FSAR Table 13.4-201)
  - Staff Conclusion
    - RVSP is “fully described” (SECY 05-0197)
    - Resolution of COL item is acceptable ( 10 CFR 50 Appendix G and H)

# Pressure-Temperature Limits (5.3.2)

- ABWR DCD COL Item 5.6
  - COL applicant will submit plant-specific P-T limits curves
- STP Response
  - Submitted a generic Pressure and Temperature Limits Report (PTLR), following guidelines of GL 96-03
  - Plant specific P/T limits will be submitted prior to receipt of fuels on site (COM 5.3-3)
- Review and approval of the PTLR tracked as OPEN ITEM

## **Preservice/Inservice Inspection and Testing of RCPB (5.2.4)**

- Section 5.2.4 addresses Preservice and Inservice Inspection and Testing of Class 1 components and piping
- STD DEP VENDOR: PSI/ISI Program
  - Design is based on ASME Section XI requirements with Toshiba responsible for RPV design accessibility to perform PSI and ISI examinations – COL Applicant is responsible for remaining component design accessibility to perform PSI/ISI examinations
  - Staff concluded that the design responsibilities to meet ASME Section XI requirements for PSI/ISI examinations were clearly designated

# Preservice/Inservice Inspection and Testing of RCPB (*cont'd*)

- **STD DEP 5.2-2: EXAMINATION CATEGORIES**
  - COL FSAR stated that PSI would extend to 100% of Class 1 pressure retaining welds and 100% of Category B-O control rod drive housing welds (if incorporated into the design). In addition, evaluations will be performed to assure accessibility to perform ISI examinations
  - The staff concluded that the departures met the requirements of ASME Section XI for scope and accessibility to perform ISI examinations, and were therefore, acceptable
  
- **STD DEP 5A-1: Ultrasonic Examination of RPV**
  - COL FSAR stated that the ultrasonic system for examination of the RPV would meet the requirements of ASME Appendix VII and VIII for qualification of personnel and equipment demonstration
  - The staff concluded that the departure met the requirements of ASME Section XI and 10 CFR 50, and is acceptable
  
- No Open Items

# Reactor Coolant Pressure Boundary Leakage Detection (5.2.5)

- The RCPB leakage detection systems are designed to detect and to the extent practical, identify the source of reactor coolant leakage.
- COL Information Item 5.1: Conversion of Indicators
  - Develop the surveillance procedures prior to fuel load to direct operator to convert instrument indicators to a common leakage equivalent.
- STD DEP 7.3-12: Leak Detection and Isolation System Sump Monitoring
  - Change the unidentified leakage TS limit from 1 gpm to 5 gpm.
  - Change the total leakage limit over 24 hours from 25 gpm to 30 gpm.
  - Add alarm limit of 2 gpm within 4 hour period to provide early warning prior to the TS limit.
  - Develop procedures prior to fuel load to respond to prolonged low-level RCS leakage.
- Open Item: Applicant to submit a commitment to complete the above procedures and make available prior to fuel load.

## **Compliance with 10 CFR 50.55a (5.2.1.1)**

- STP FSAR Section 5.2.1.1 incorporates by reference ABWR DCD Section 5.2.1.1 with no departures or supplements
- In RAI response, STP referred to ABWR DCD Tier 2 Table 1.8-21 and STP FSAR Tables 1.8-21 and 1.8-21a for Code edition/addenda to be applied
- STP FSAR Table 1.8-21a will be revised to include ASME OM Code (2004 Edition) for IST program description in support of COL application
- STP FSAR Section 5.2.1.1 acceptable with FSAR update as Confirmatory Item 5.2.1.1-1

## **Applicable Code Cases (5.2.1.2)**

- STP FSAR Section 5.2.1.2 incorporates by reference ABWR DCD Section 5.2.1.2
- STD DEP 1.8-1 states that ASME Code Cases approved in RG 1.84 (Rev. 33) might be used at STP
- Open Item 5.2.1.2-1 indicates STP needs to fully describe Inservice Inspection program, and identify Code Cases in RG 1.84 and RG 1.147 to be applied
- Open Item 5.2.1.2-2 indicates STP needs to fully describe Inservice Testing program, and identify Code Cases in RG 1.192 to be applied

## **Applicable Code Cases (5.2.1.2)**

- STP clarified use of annulled Code Cases in RAI response
- STP stated in RAI response that FSAR Table 5.2-1 will be updated to specify Code Cases listed in RG 1.84, Revision 33
- STP plan to delete superseded Code Cases from FSAR Table 5.2-1 being tracked as Confirmatory Item 5.2.1.2-5

# Reactor Core Isolation Cooling System (5.4.6)

- Standard Departure (STD DEP) T1 2.4-3, “RCIC Turbine/Pump,” from ABWR DCD
- STP FSAR reflects new RCIC turbine-pump design
- Proprietary Toshiba Technical Report UTLR-0004-P (Rev. 0, June 2009), “Application of Turbine Water Lubricated (TWL) Pump to South Texas Project Units 3 & 4 RCIC Turbine-Pump,” describes new RCIC turbine-pump design

## **RCIC Turbine-Pump Design (5.4.6)**

- Monoblock design (pump-turbine within same casing)
- No shaft seal required
- No barometric condenser required
- No oil lubrication
- No steam bypass line required for warm-up
- Less complex auxiliary systems

## **RCIC Turbine-Pump Design (5.4.6)**

- NRC staff reviewed RCIC turbine-pump topical report at STP Rockville office on April 29, 2009
- NRC staff requested STP to submit topical report as proprietary document in support of COL application
- NRC staff prepared RAIs on topical report with STP response provided on July 7, 2009
- NRC staff conducted audit to discuss RCIC turbine-pump design and RAI responses with STP personnel on November 10 and 11, 2009, at STP Rockville office

# **RCIC Turbine-Pump RAI Responses and Audit Results**

- STP indicated in RAI response that RCIC turbine-pump will be qualified using ASME Standard QME-1-2007, but topical report does not specify functional qualification provisions
- Surveillance not specified for small non-safety-related pump that assists with shaft bearing lubrication during standby conditions
- QA program for RCIC turbine-pump will satisfy 10 CFR 50, Appendix B
- RCIC turbine-pump included in IST program as described in FSAR Section 3.9.6
- Potential flow-induced vibration for RCIC turbine-pump will be addressed as specified in ABWR DCD

## **SER Open Items 05.04.06**

- Open Item 05.04.06-1
  - Audit follow-up items:
    - Revise topical report to specify functional qualification provisions for RCIC turbine pump
    - Specify surveillance testing for RCIC standby lubrication pump
- Open Item 05.04.06-2
  - RAI requests STP to submit results of pump calculations showing available NPSH margin when head loss for new ECCS suction strainer is determined

## **Chapter 5 Review Wrap Up**

Due to Open Items and Confirmatory Items, the staff is unable to finalize conclusions concerning Chapter 5, “Reactor Coolant System and Connected Systems” at this time.



# **ACRS Subcommittee Presentation SER/OI Chapter 5**


*Discussion/Committee Questions*



**STP Chapter 5 Open Item Status: March 18, 2010**

<b>OPEN ITEM</b>	<b>TITLE</b>	<b>DESCRIPTION /RESOLUTION</b>
5.2.1.2-1	Code Cases	Applicant requested to provide a full description of ISI to specify Code cases. Pending receipt and staff review.
5.2.1.2-2	Code Cases	Applicant requested to provide a full description of IST to specify Code cases. Pending receipt and staff review.
5.2.3-2	Revised Departure Report STD DEP 4.5-1	Applicant requested to submit modified Departures report to clarify impact of departure. Pending receipt and staff review.
5.2.5-5	FSAR Commitments COL Info Item 5.1 STD DEP 7.3-12	Alarm response procedures and Surveillance procedures were promised in the RAI responses, but no commitments were made in the FSAR. Pending receipt and staff review.
5.3.2-1	COL Info Item 5.6 PTLR	Topical Report to support application plant-specific PTLR issues. Currently under staff review.
5.4-2	COL Info Item 5.10 RIP	Applicant requested to provide contingency plan for RIP maintenance. Pending receipt and staff review.
5.4.6-1	RCIC STD SEP T1 2.4-3 (Proprietary section of SER)	Issues involving RCIC turbine-pump design. Staff review and audit pending.
5.4.6-2	RCIC STD SEP T1 2.4-3 (Proprietary section of SER)	NPSH calculations. Pending receipt and staff review.
5.4.7-1	Open item listed in SER	Resolved
5.4.7-8	Open item listed in SER	Resolved

# South Texas Project Units 3 & 4 Presentation to ACRS Subcommittee Chapter 8 Electric Power



# Agenda

- Contents of FSAR Chapter 8
  - Departure Information
  - Site-Specific Supplements
- COL Licensee Information Items
- ITAAC

# Attendees

Scott Head	Regulatory Affairs Manager, STP 3&4
Evans Heacock	Design Engineering Lead, STP 3&4
Richard Bense	Licensing, STP 3&4
Coley Chappell	Licensing, STP 3&4
Bill Stillwell	PRA Supervisor, STP 3&4

# Chapter 8 Contents

- 8.1 Offsite Transmission Network
- 8.2 Offsite Power System
- 8.3 Onsite Power Systems
- 8.4S Station Blackout
- 8A Miscellaneous Electrical Systems

# 8.1 Offsite Transmission Network


## COL Applicant Design Scope

Reliability of the offsite network:

- Six 345 kV transmission lines connect STP 3&4 to transmission systems of three diverse service providers connected via three rights of way.
- Loss of any double-circuit 345 kV line, loss of any two 345 kV lines, or loss of all circuits on any right-of-way does not adversely impact availability of offsite power.
- Grid stability maintained on loss of largest generation source.
- ‘Breaker-and-a-Half’ switchyard configuration provides high reliability and flexibility for maintenance.
- Failure Modes and Effects Analysis shows no single failure prevents offsite power from supporting its safety function during any postulated accident.

# 8.1 Offsite Transmission Network

## 345 kV General Arrangement



## 8.2 Offsite Power System and

## 8.3 Onsite Power System


### Plant Medium Voltage Electrical System Design (STD DEP 8.3-1)

Electrical bus voltage changed to a dual system to better accommodate motor driven feed pumps and other large loads and to be consistent with typical US practice:

- Power Generation (PG) bus increased from 6.9 kV (DCD) to 13.8 kV;
- Plant Investment Protection (PIP) bus reduced from 6.9 kV (DCD) to 4.16 kV; and
- Class 1E safety bus reduced from 6.9 kV (DCD) to 4.16 kV.

# Plant Medium Voltage Electrical System Design (STD DEP 8.3-1) (cont)

## Simplified Electrical Distribution



# Plant Medium Voltage Electrical System Design (STD DEP 8.3-1) (cont)

- Capacity of onsite power sources increased to accommodate increased site loads:
  - Emergency Diesel Generators (EDG) capacity increased from 5000 kW at 6.9 kV (DCD) to 7200 kW at 4.16 kV.
  - Combustion turbine generator (CTG) capacity increased from 9 MWe (DCD) to a minimum of 20 MWe.
- CTG maximum start time increased from 2 (DCD) to 10 minutes
  - Remains within RG 1.155 limits for Station Blackout (SBO) alternate AC source.
  - CTG can be aligned to support the other unit.
- Second 100% capacity Reserve Auxiliary Transformer (RAT) added to support electric boiler during startup.

## 8.4S Station Blackout

- Compliance with 10 CFR 50.63, “Loss of All Alternating Current Power,” addressed in Appendix 1C of the COL FSAR.
- CTG provides an alternate source of AC power to PIP buses and Class 1E buses within 10 minutes -- eliminates need for SBO coping analysis consistent with RG 1.155.
- FSAR 19.9.9 and ABWR DCD 19E address Station Blackout Events.

# Chapter 8 Tier 1 Departures

## **I&C Power Divisions (STD DEP T1 2.12-2)**

- Fourth regulating transformer and distribution panels added for Instrument and Control Power to improve maintenance and trouble shooting. (Instrument Divisions II and IV both still supplied from Division II Class 1E bus.)

## **Safety-Related I & C Architecture (STD DEP T1 3.4-1)**

- Chapter 8 nomenclature changes to conform with Chapter 7.

## **Hydrogen Recombiner Elimination (STD DEP T1 2.14-1)**

## **Feedwater Line Break Mitigation (STD DEP T1 2.4-2)**

- Condensate pump trip added to provide added assurance of conservatism in the containment response following a FWLB, but is not credited in the FWLB analysis in Chapter 6.2.

# Chapter 8 Departures (continued)

## Codes, Standards, and Regulatory Guide Edition Changes (STD DEP 1.8-1, Tier 2\*)

- IEEE 279 is replaced by IEEE 603.
- IEEE 384 is adopted.

## Dual Units at STP 3 & 4 (STP DEP 1.1-2)

- ABWR DCD is a single unit plant design
- STP 3 & 4 ensures GDC 5 is met by limiting shared systems

## Electrical Equipment Numbering (STP DEP 8.2-1)

- Electrical Equipment Numbering revised to address site-specific variations for switchyard and other auxiliary structures, routing of power circuits, bus assignments, and nomenclature variations.

# Chapter 8 Departures (continued)

## Electrical Site-Specific Power and Other Changes (STP DEP 8.3-3)

- Load Tables for Loss of Coolant Accident and Loss of Preferred Power based on load study calculations and EDG and CTG sizing calculations.

# COL License Information Items

The 31 COL License Information Items in Chapter 8 ensure that required programs, procedures, and procurement specifications are completed and implemented prior to fuel load:

- 8.1 Diesel Generator Reliability
- 8.2 Periodic Testing of Offsite Equipment
- 8.3 Procedures when Reserve or Unit Aux Transformer is Out of Service
- 8.4 Offsite Power Systems Design Bases
- 8.5 Offsite Power Systems Scope Split
- 8.6 Capacity of Auxiliary Transformers
- 8.8 Diesel Generator Design Details
- 8.10 Protective Devices for Electrical Penetration Assemblies
- 8.15 Offsite Power Supply Arrangements

# COL License Information Items (continued)

- 8.19 Load Testing of Class 1E Switchgear and Motor Control Centers
- 8.20 Administrative Controls for Bus Grounding Circuit Breakers
- 8.21 Administrative Controls for Manual Interconnections
- 8.23 Common Industrial Standards Referenced in Purchase Specifications
- 8.24 Administrative Control for Switching 125Vdc Standby Charger
- 8.25 Control of Access to Class 1E Power Equipment
- 8.26 Periodic Testing of Voltage Protection Equipment
- 8.27 Diesel Generator Parallel Test Mode
- 8.28 Periodic Testing of Diesel Generator Protective Relaying
- 8.29 Periodic Testing of Diesel Generator Synchronizing Interlocks
- 8.30 Periodic Testing of Thermal Overloads and Bypass Circuitry

# COL License Information Items (continued)

- 8.31 Periodic Inspection/Testing of Lighting System
- 8.32 Controls for Limiting Potential Hazards Into Cable Chases
- 8.33 Periodic Testing of Class 1E Equipment Protective Relaying
- 8.34 Periodic Testing of CVCF Power Supplies and EPAs
- 8.35 Periodic Testing of Class 1E Circuit Breakers
- 8.36 Periodic Testing of Electrical Systems & Equipment
- 8.38 Class 1E Battery Installation and Maintenance Requirements
- 8.39 Periodic Testing of Class 1E Batteries
- 8.40 Periodic Testing of Class 1E CVCF Power Supplies
- 8.41 Periodic Testing of Class 1E Battery Chargers
- 8.42 Periodic Testing of Class 1E Diesel Generators

# ITAAC

Incorporated by Reference with the following exception:

## **Electrical Breaker/Fuse Coordination and Low Voltage Testing (STD DEP T1 2.12-1)**

- Circuit breaker and fuse coordination changed from “closest to the fault opens first” to include “to the maximum extent possible.”
- Field testing of electrical components at “analyzed minimum voltage” replaced with manufacturer's type tests over the voltage operating range combined with onsite system preoperational and startup testing.
- Field testing of DC loads at both “minimum battery voltage and maximum charger voltage” replaced by manufacturer's type tests over the operating voltage range combined with onsite system preoperational and startup testing.

# Chapter 8

## Electric Power

### Questions and Comments





# **Presentation to the ACRS Subcommittee**

**South Texas Units 3 and 4 COL Application Review**

**SER/OI Chapter 8.0  
“Electric Power”**

March 18, 2010

## Summary of Technical Discussion Points for South Texas COL Chapter 8

<b>FSAR Section</b>		<b>Summary of Supplemental Information</b>
<b>8.1</b>	Electric Power Introduction	Departures of interest evaluated in Section 8.3.1. Tier 2* departure and open item.
<b>8.2</b>	Offsite Power Systems	Brief description of evaluation of offsite power system and COL information items. Tier 2 departure requiring prior approval discussed in Section 8.3.1. Open item 8.2-3 regarding inaccessible/underground cables.
<b>8.3.1</b>	Onsite AC Power Systems (AC)	Departures 8.3-1 (T2) and 2.2-12 (T1), and COL information items and open item 8.3.1-1 regarding diesel inlet air temperature..
<b>8.3.2</b>	Onsite DC Power Systems	Brief description of evaluation of onsite power system
<b>8.4S</b>	Station Blackout	Brief description of evaluation of Station Blackout and COL information items

## **USABWR STP COL – Review Topics of Interest**

### **Section 8.0 – Electric Power**

- COL application contains:
  - Interface Requirements
  - COL Information Items
  - Supplemental Information
  - Site specific information on the following:
    - Offsite power system
    - Onsite power system (Electrical load increases)
    - SBO coping durations
  
- COL application identified 14 departures
  
- COL review included:
  - Confirming that all COL Information Items identified in USABWR DCD are addressed
  - Determining whether the STP COL FSAR information provided sufficient level of detail for offsite power, onsite power, and SBO.

## **USABWR STP COL – Review Topics of Interest**

### **Section 8.1 – Site Specific Information**

- **Section 8.1** – Addresses staff review of applicable design bases, criteria, regulatory guides, standards, and other documents to be implemented in the design of the electrical systems that are beyond the scope of the design certification.
  
- **Specific items of interest:**
  - One Open Item regarding applicability of RG 1.180 to solid state and digital components used in safety-related system.
    - The open Item is resolved based on the additional information received from the applicant.
  - COL Information Item is adequately addressed.
  
- **Section Conclusion**
  - As result of Open Item, the staff is unable to finalize its conclusion

## **USABWR STP COL – Review Topics of Interest**

### **Section 8.2 – Offsite Power System**

- **Section 8.2** - Addresses staff review of offsite power systems includes two or more physically independent circuits. It encompasses the grid, transmission lines, switchyard components, etc. that supply electric power to safety-related and other equipment and is capable of operating independently of the onsite standby power sources.
  
- **Specific items of interest:**
  - Four Open Items
    - Three Open Items resolved based on additional information received.
    - Open Item regarding program for testing and inspection of inaccessible or underground power and control cables is not resolved.
  
  - COL License Information Items are adequately addressed

## **USABWR STP COL – Review Topics of Interest**

### **Section 8.2 – Offsite Power System (continued)**

- **Specific items of interest (Cont'd):**
  - Supplemental Information – Transmission lines, Switchyard Description, Main Power Transformer, and RATs, Failure Modes and Effect Analysis, and Grid Analysis
  - Interface Requirements
  
- **Section Conclusion**
  - As result of Open Items, the staff is unable to finalize its conclusion.

## **USABWR STP COL – Review Topics of Interest**

### **Subsection 8.3.1 – Onsite AC Power System**

- **Subsection 8.3.1** Addresses staff review of standby power sources, distribution systems, and auxiliary support systems that supply power to safety-related equipment or equipment important to safety for all normal operating and accident conditions.
  
- **Specific items of interest:**
  - Two Open Items
    - Applicant provided additional information to resolve one Open Item.
    - Open item regarding diesel room temperature increase is not resolved.
  
  - COL License Information Items are adequately addressed

## **USABWR STP COL – Review Topics of Interest**

### **Subsection 8.3.1 – Onsite AC Power System (continued)**

- **Specific items of interest (Continued):**
  - STD DEP 8.3-1 changed voltage rating of PG bus from 6.9 kV to 13.8 KV, PIP bus from 6.9 kV to 4.16 kV and Class 1E buses from 6.9 kV to 4.16 kV. Additionally EDG rating is changed from 5000 KW to 7200 KW, CTG rating is changed from 9 MW to 20 MW. An additional RAT was included.
  - STP DEP T1 2.12-2 added a fourth Class 1E I&C interruptible power supply to increase reliability and availability. It is an improvement from the DCD design.
- **Section Conclusion**
  - As result of Open Items, the staff is unable to finalize its conclusion.

## **USABWR STP COL – Review Topics of Interest**

### **Subsection 8.3.2 – Onsite DC Power System**

- **Subsection 8.3.2** Addresses staff review of the four independent Class 1E DC divisions to provide reliable power for safety-related equipment for the plant instrumentation, control, monitoring, and other vital functions needed to shut down the plant and non-Class 1E DC power systems.
  
  - **Specific items of interest:**
    - One Open Item identified in current SER.(This open item is discussed in Section 8.3.1)
      - Applicant provided additional information to close this Open Item.
    - COL License Information Items are adequately addressed.
- Section Conclusion**
- As result of one Open Item, the staff is unable to finalize its conclusion.

## **USABWR STP COL – Review Topics of Interest**

### **Section 8.4S – Station Blackout**

- **Section 8.4S** Addresses staff review of STP Units 3 and 4 conformance to the requirements of 10 CFR 50.63, and the guidelines of RG 1.155.
- **Specific items of interest:**
  - Cope SBO with AAC Power Source. In addition the ABWR is designed with an 8-hour battery to accommodate SBO without AC power
  - CTG size increased from 9 MW at 6.9 KV to at least 20 MW at 13.8 kV.
  - CTG start time increased from 2 minutes to less than 10 minutes
  - One Open Item identified in current SER
    - Applicant provided additional information to close this Open Item.
  - COL Information Items are adequately addressed.
- **Section Conclusion**
  - As result of one Open Item, the staff is unable to finalize its conclusion.

# USABWR STP COL – Staff Findings

- The STP COL FSAR provides:
  - Sufficient information about offsite power system, switchyard, interconnection entities to maintain grid reliability and stability and minimize a loss of offsite power.
  - Sufficient details about site-specific safety-related load increase to EDG so that maximum expected loads do not exceed 95 percent of the continuous rating of EDG.
  - Each medium voltage safety-related bus can be connected to normal offsite power source thru UAT, alternate offsite power source thru RAT A or RAT B, onsite power source thru EDG, and AAC power source thru CTG.
  - Two of three divisions are normally fed from an offsite normal preferred power source. The remaining division is normally fed from alternate preferred power source.
  - Regarding SBO, each STP unit has an AAC power source (CTG) with 7 days fuel capacity. Additionally, the ABWR is designed with an 8-hour battery to accommodate SBO without AC power.
  - SER with O/I identified 8 Open Items. Staff subsequently closed 7 Open Items and working with the applicant to close the remaining Open item.

# Summary

- Staff is unable to finalize its conclusions at this time.

# Questions and Answers

- Questions
- Follow-up actions

## **STP Chapter 8 Open Items**

- **OI 8.1-1** Electromagnetic and Radiofrequency Interference
  - Closed since the SER was written
- **OI 8.2-1** Switchyard battery discharge, relay, circuit breaker timing, transformer testing
  - Closed since the SER was written
- **OI 8.2-2** Transmission Line Failure Events
  - Closed since the SER was written
- **OI 8.2-3** Inaccessible/Underground cable testing program
  - Open

## **STP Chapter 8 Open Items** (cont'd)


- **OI 8.2-4** Communication protocol between STP and TSP regarding risk-sensitive maintenance
  - Closed since the SER was written
  
- **OI 8.3.1-1** Diesel room temperature increase
  - Open
  
- **OI 8.3.1-2** Inclusion of Isolation devices in I&C circuits into the periodic testing program
  - Closed since the SER was written
  
- **OI 8.4-1** Severe weather procedures
  - Closed since the SER was written

# South Texas Project Units 3 & 4

## Presentation to ACRS Subcommittee

### Chapter 16

### Technical Specifications



# Agenda

- Introduction
- Contents
  - Departure Information
  - Site-Specific Supplements
  - COL License Information Items
- Future Plans
- Conclusion

# Attendees

Scott Head	Regulatory Affairs Manager, STP 3&4
Tom Daley	Engineering Supervisor, STP 3&4
Steve Cashell	Licensing, STP 3&4
Kyle Dittman	Engineering I&C Supervisor, STP 3&4

# Chapter 16 Introduction

- The ABWR Technical Specifications were developed using NUREG-1434, “Standard Technical Specifications General Electric Plants, BWR/6,” Revision 0 for all but the containment specifications which follow NUREG-1433, “Standard Technical Specifications General Electric Plants, BWR/4,” Revision 0, to the extent practicable.
- The ABWR Technical Specifications and Bases are written in the Improved Standard Technical Specification format.

# Chapter 16 Contents

- Use and Application
- Safety Limits and Limiting Safety System Settings
- Limiting Conditions for Operation
- Surveillance Requirements
- Design Features
- Administrative Controls

# Departures

## All TS and TS Bases Departures require NRC approval

- **6** Tier 1 departures affect TS
  - STD DEPs T1-2.3-1, 2.4-2, 2.4-3, 2.12-2, 2.14-1 and 3.4-1
- **9** Tier 2 design related departures affect TS
  - STD DEPs T2 6.2-2, 7.3-12, 7.3-17, 7.5-1, 7.7-10, 7.7-18, 8.3-1, 8.3-3 and 10.4-5
- **8** Tier 2 non-design related departures (non-editorial)
  - STD DEPs 16.2-1, 16.3-78 and 16.5-1 through 16.5-6

The remainder supplement, correct or clarify information in the TS and Bases, provide consistency between the TS and Bases, or are editorial in nature

# Tier 1 Departures

- MSIV Closure and Scram on High Rad (T1 2.3-1)
  - Removes high radiation scram and isolation functions from TS
- Feedwater Line Break Mitigation (T1 2.4-2)
  - Adds new feedwater line break mitigation functions to TS
- RCIC Turbine / Pump (T1 2.4-3)
  - Revises the function name
- I&C Power Divisions (T1 2.12-2)
  - Adds new Division IV 120 v distribution panels
- Hydrogen Recombiner Elimination (STD DEP T1 2.14-1)
  - Removes hydrogen recombiner and hydrogen/oxygen monitor functions from TS
- Safety Related I&C Architecture (STD DEP T1 3.4-1)
  - Revises I&C nomenclature and design descriptions

# Tier 2 Design-related Departures

- Containment Analysis (6.2-2)
  - Revises calculated peak containment pressure (Pa)
- Leak Detection & Sump Monitoring (7.3-12)
  - Revises RCS total and unidentified leakage limits
- ADS Electrical Interface (7.3-17)
  - Revises design description – 3 Divisions of control logic vs. 4
- Post Accident Monitoring (7.5-1)
  - Revises list of RG 1.97, Type A and Category 1 instruments
  - Specifies Wetwell Pressure and adds Wetwell Atmos. temperature
- Control Rod Drive Interfaces (7.7-10)
  - Adds alternate method to ensure full rod insertion

# Tier 2 Design-related Departures

- RCIS Operator Information (7.7-18)
  - Revises design description – test switch is now a push button
- Plant Medium Voltage System Design (8.3-1)
  - Revises electrical system design information as discussed in Chapter 8
- Electrical Site Specific Power (8.3-3)
  - Revises MCC nomenclature and adds MCCs
- Condensate & Feedwater System (10.4-5)
  - Revises design description – 4 ASDs for 4 feedwater pumps

# Tier 2 Non design-related Departures

- Safety Limit Violation (16.2-1)
  - Eliminates notification requirements per 10 CFR 50.36, 50.72 and 50.73
- Post Accident Monitoring Instrumentation (16.3-78)
  - Removes “Containment Water Level” parameter as non-Type A or Category 1
- Unit Responsibility (16.5-1)
  - Eliminates control room SRO requirements in MODE 4 (Cold Shutdown) 10 CFR 50.54(m)(2)(iii)
- Unit Staff (16.5-2)
  - Provides actual plant staff titles

# Tier 2 Non-design related Departures

- TS Bases Control Program (16.5-3)
  - Eliminates term “unreviewed safety question” per 10 CFR 50.59
- Reporting Requirements (16.5-4)
  - Revises annual reporting requirements per 10 CFR 20.2206
- Working Hours (16.5-5)
  - Removes working hour limits from TS per 10 CFR 26
- Inservice Testing Program (16.5-6)
  - Revises program to reference the ASME OM Code

# COL License Information Items

Only one, all encompassing COL Item:

## 16-1 Supply the bracketed information

All bracketed items were completed in accordance with one of the three available options identified in Interim Staff Guidance ISG-08, “Necessary Content of Plant-Specific Technical Specifications When a Combined License is Issued”

- Plant-specific information
  - Most items
- Bounding value
  - One item – Required # of LPRMs per division
- Reference to a program that uses an NRC-approved methodology
  - Allowable Values - Instrument Setpoint Methodology

# Instrument Setpoint Methodology

- Adds new Specification 5.5.2.11, “Setpoint Control Program”
- Identifies methodology documents used to calculate setpoints
- Relocates Allowable Values from TS to a licensee-controlled document
- Revises Definitions and related SRs for:
  - FUNCTIONAL TESTS
  - CHANNEL CALIBRATIONS
- Establishes a document containing the required setpoint values

# Site-Specific Supplements

- ❑ Bracketed information
- ❑ Ultimate Heat Sink (UHS) Surveillance Requirements
  - ❑ Cooling tower cell fans
  - ❑ UHS basin measurements

# Chapter 16 - Future Plans

## Tech Spec Upgrade – Post COL

- ❑ Incorporate approximately 100 applicable TSTFs, including risk-informed TSTFs, to fully conform with NUREG-1433 and 1434, Rev 3.1
- ❑ Risk Managed (RMTS), including RITSTF Initiative 4b (Completion Times), using NEI 06-09, “Risk-Managed Technical Specifications (RMTS) Guidelines” and TSTF-505 (if approved)
- ❑ Plant-specific PRA to support risk informed initiatives intended to be complete\* prior to COL issuance
  - ❑ ASME PRA Standard, RG 1.200 and Peer Review

\* Fire and seismic external events to be completed prior to fuel load

# Chapter 16

## Questions and Comments





# **Presentation to the ACRS Subcommittee**

**South Texas Project Units 3 and 4 COL Application Review**

**SER/OI Chapter 16  
“Technical Specifications”**

*March 18, 2010*

## **STP COL Chapter 16 Staff Review Team**

- **Project Managers**
  - George Wunder, Lead PM, DNRL/NGE2
  - Michael Eudy, Chapter PM, DNRL/NGE2
  
- **Technical Staff Presenters**
  - Craig Harbuck, Reviewer, CTSB
  - Dinesh Taneja, Reviewer ICE2
  - George Thomas, Reviewer, SRSB
  - Steve Downey, Reviewer, CIB2

## Overview of Chapter 16 Review Topics of Interest

<b>Topics of Interest</b>	<b>Summary</b>
<b>Staff Review Focus</b>	Overview of verification process for plant-specific technical specifications (TS) <ul style="list-style-type: none"> <li>• Generic TS</li> <li>• Departures</li> <li>• Site-specific TS COL information</li> </ul>
<b>COL License Information Item 16.1</b>	Overview of resolution options for site-specific TS COL information using DC/COL-ISG-8
<b>Open Item 16-1</b>	Completion of site-specific TS COL information <ul style="list-style-type: none"> <li>• Site-specific Limiting Safety System Settings</li> <li>• Site-specific RCS Pressure-Temperature Limits</li> </ul>

## **Chapter 16 Review Focus**

1. Verify that plant-specific technical specifications (PTS) and bases incorporate by reference (IBR) the ABWR generic technical specifications (GTS) and bases
2. Verify that departures from GTS and bases are warranted and justified
3. Verify that PTS and bases incorporate acceptable site-specific COL information to complete COL License Information Item 16.1
  - DC/COL-ISG-8, “Necessary Content of Plant-Specific Technical Specifications When a Combined License Is Issued.”

## **Open Item 16-1**

### **Completion of COL Information Item 16.1**

- DC/COL-ISG-8 describes resolution of COL site-specific TS information using three options:
  1. Provide site-specific values or information;
  2. Provide useable bounding values or information; or
  3. Move the values or information to a licensee-controlled document and establish an administrative-control TS that requires determining the information using an NRC-approved methodology.
- Site-specific Limiting Safety System Settings (LSSS) (RAI 16-65 Issues 1 and 4.f)
- Site-specific RCS Pressure-Temperature (P-T) Limits (RAI 16-65 Issue 1, RAI 16-21 Issue 14, and RAI 5.3.2-1)

## **Open Item 16-1** *(continued)* **Site-specific LSSS**

- STD DEP 16.3-100 implements “Option 3” to complete the LSSS (“allowable values”) for instrumentation trip or actuation settings.
- Setpoint Control Program specification (PTS 5.5.2.11) references plant-specific methodology
  - Setpoint methodology is based on previously approved Westinghouse setpoint methodology for AP1000
  - Consistent with SCP specification developed for ESBWR GTS
- Completion of staff review of this departure is pending acceptance of instrumentation setpoint methodology for STP Units 3 and 4. (SER Section 7.1.5)

## **Open Item 16-1** *(continued)* **Site-specific RCS P-T Limits**

- STD DEP 16.3-8 deletes references to the P-T limit methodology in the bases for PTS 3.4.9 and implements “Option 1” to complete COL information in PTS 5.7.1.6 – by adding references to the P-T limit methodology and the NRC approval letter. (RAI 16-65 Issue 1)
- Removes brackets from RCS temperature values in GTS SR 3.4.9.4 and SR 3.4.9.5, and associated bases, for verifying reactor vessel flange and head flange temperatures are above limits in PTLR during cold shutdown. More frequent monitoring is specified below these values. (RAI 16-21 Issue 14)
- Completion of staff review of this departure and COL information is pending acceptance of the RCS P-T Limits Report (PTLR) for STP Units 3 and 4. (SER Section 5.3.2) (RAI 5.3.2-1, Open Item 5.3.2-1)

## Open Item 16-1 *(continued)*

### Site-specific RCS P-T Limits

SURVEILLANCE	FREQUENCY
<p>SR 3.4.9.4 -----NOTE-----            Not required to be performed until 30 minutes after            RCS temperature <math>\leq</math> [27°C] in MODE 4.            -----</p> <p>Verify reactor vessel flange and head flange            temperatures are within the limits specified in the            PTLR.</p>	30 minutes
<p>SR 3.4.9.4 -----NOTE-----            Not required to be performed until 12 hours after            RCS temperature <math>\leq</math> [38°C] in MODE 4.            -----</p> <p>Verify reactor vessel flange and head flange            temperatures are within the limits specified in the            PTLR.</p>	12 hours

## **Chapter 16 Review Wrap Up**

Chapter 16 staff reviewers have no outstanding technical issues related to PTS and bases. However, due to open items in other chapters involving information necessary for resolving Open Item 16-1 (STD DEPs 16.3-100 and 16.3-8), the staff is unable to finalize conclusions relating to Chapter 16 “Technical Specifications” at this time.



# **Overview of STP RCOL Chapter 16 – “Technical Specifications”**

Discussion/Committee Questions



STP Chapter 16 Open Item Status: 3/18/10


<b>OPEN ITEM</b>	<b>TITLE</b>	<b>DESCRIPTION /RESOLUTION</b>
<b>16-1 a</b>	Instrument setpoint methodology	Tied to acceptance review in SER section 7.1.5 which is pending
<b>16-1 b</b>	RCS P-T Limits	Tied to acceptance review in SER section 5.3.2 which is pending

# South Texas Project Units 3 & 4

## Presentation to ACRS Subcommittee

### Chapter 17

### Quality Assurance



# Agenda

- Introduction
- Contents of FSAR Chapter 17
  - Departure Information
  - COL License Information Items
  - Site-Specific Supplements
- ITAAC
- Conclusion

# Attendees

Scott Head	Regulatory Affairs Manager, STP 3&4
Tim Walker	Quality Manager, STP 3&4
Bill Stillwell	PRA Supervisor, STP 3&4
Evans Heacock	Design Engineering Lead, STP 3&4
Jim Agles	Licensing, STP 3&4

# Chapter Contents/Summary

- **17.0 Introduction:**  
 Incorporated by reference with a supplement pointing to Section 17.5S for the information required by COL Information item 17.1 concerning the STP 3&4 Quality Assurance Program Description (QAPD).
- **17.1 Quality Assurance During Design and Construction:**  
 Incorporated by reference with a supplement pointing to Section 17.5S for a description of the STP 3&4 QAPD.
- **17.2 Quality Assurance During Operations Phase:**  
 Incorporated by reference with a supplement pointing to Section 17.5S for a description of the STP 3&4 QAPD.
- **17.3 Reliability Assurance Program During Design Phase:**  
 Incorporated by reference with supplements to point to Section 17.4S and 17.6S for the information required by COL Information Items 17.2, 17.3, and 17.4 related to the STP 3&4 Design Reliability Assurance Program (DRAP).

# Chapter Contents/Summary (cont)

- **17.4S Reliability Assurance Program**

Provides a DRAP program based on Standard Review Plan (SRP) Section 17.4.

- **17.5S Quality Assurance Program Guidance**

References a separate document titled “STP 3 & 4 Quality Assurance Program Description,” based on the industry template, Nuclear Energy Institute (NEI) 06-14A “Quality Assurance Program Description (QAPD).”

- **17.6S Maintenance Rule Program**

Incorporates by reference NEI 07-02, "Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52."

# Departures

There are no departures in Chapter 17.

# Quality Oversight Activities

- Qualified Toshiba facilities by full scope audits
- Obtained first ASME Owner's Certificate in 20 years
- Reactor Pressure Vessel Fabrication
  - JSW, IHI, JFE, Yakin, Toshiba NEEMD
- STPNOC large component fabrication oversight
  - STP 1&2 Quality Oversight experience includes Replacement Steam Generators, LP Rotors, Generator Rotors, Standby Diesel Generator repair, Replacement Reactor Vessel Head

# 17.4S Reliability Assurance Program

- Undertaken for the life of the plant to ensure the reliability assumed by the probabilistic risk assessment (PRA) for risk significant systems, structures and components (SSC) is actually achieved in practice.
- Defines the criteria for PRA and deterministic identification of risk significant SSCs.
- Establishes the DRAP organization/qualifications including membership of an Expert Panel to implement the program.
- Establishes the interface with the Maintenance Rule Program (17.6S) to maintain plant reliability during plant operations.
- Program has been implemented and expert panel members identified.

# 17.5S QA Program Guidance

- Maintained as a separate document titled “STP 3 & 4 Quality Assurance Program Description.”
- STP 3&4 QAPD is based on American Society of Mechanical Engineers (ASME) NQA-1-1994, “Quality Assurance Program Requirements for Nuclear Facilities.”
- Nuclear Energy Institute (NEI) prepared an industry template, NEI 06-14A “Quality Assurance Program Description (QAPD),” for an ASME NQA-1-1994 based program.
- STP 3&4 QAPD is based on NEI 06-14A with site specific [bracketed] information provided.

# 17.6S Maintenance Rule

- Nuclear Energy Institute Report No. NEI 07-02, "Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52" provides the Maintenance Rule Program for STP 3 & 4.
- NEI 07-02 is incorporated by reference with site-specific supplements added where called for.

# COL Information Items

- 17.1 QA Programs For Construction and Operation:** The information requested is provided by a separate QAPD as referenced by Section 17.5S. The QAPD is based on the industry template, Nuclear Energy Institute (NEI) 06-14A “Quality Assurance Program Description (QAPD).”
- 17.2 Policy and Implementation Procedures for D-RAP:** Information provided as described in 17.4S.10 including the QAPD and the DRAP program described in Section 17.4S.
- 17.3 D-RAP Organization:** Information provided as described in 17.4S.10. The Organizational elements associated with DRAP and RAP during the Operations phase is provided in 17.4S.1.1.
- 17.4 Provision for O-RAP:** Information provided as described in 17.4S.10. The provisions for Reliability Assurance during Operations are described in Section 17.4S Reliability Assurance Program and 17.6S Maintenance Rule.

# ITAAC

## Tier 1 ITAAC Table 3.6 Design Reliability Assurance Program

- **Inspections of the Reliability Assurance Program will be conducted to verify:**
  - Scope, Purpose, and Objectives
  - Process used to evaluate and prioritize SSCs
  - List of Risk Significant SSCs
  - Process for determining dominant failure modes (Risk significant SSCs)
  - Key assumptions and insights considered
  
- **Site specific ITAAC are not provided.**

# Chapter 17 Quality Assurance

## Questions and Comments





# **Presentation to the ACRS Subcommittee**

**South Texas Units 3 and 4 COL Application Review**

**SER/OI Chapter 17  
“Quality Assurance”**

March 18, 2010

# **STP COL Chapter 17 Staff Review Team**

- **Project Managers**
  - George Wunder, Lead PM, DNRL/NGE2
  - Raj Anand, Chapter PM, DNRL/NGE2
  
- **Technical Staff Presenters**
  - Garrett Newman, DCIP/CQVB
  - Todd Hilsmeier, DSRA/SPRA

## Summary of Technical Discussion for South Texas COL Chapter 17

<b>FSAR Section</b>		<b>Summary of Supplemental Information</b>
<b>17.0</b>	Introduction	<ul style="list-style-type: none"> <li>• This section incorporates by reference Section 17.0 of the ABWR DCD</li> <li>• This section addresses COL License Information Item:               <ul style="list-style-type: none"> <li>- 17.1 QA Programs for Construction and Operation</li> </ul> </li> </ul>
<b>17.1</b>	Quality Assurance during Design and Construction	<ul style="list-style-type: none"> <li>• This section incorporates by reference Section 17.1 of the ABWR DCD</li> </ul>
<b>17.2</b>	Quality Assurance during Operation Phase	<ul style="list-style-type: none"> <li>• This section incorporates by reference Section 17.2 of the ABWR DCD</li> </ul>
<b>17.5S</b>	Quality Assurance Program Guidance	<ul style="list-style-type: none"> <li>• Referenced STP 3 and 4 QA Program is based on NEI 06-14</li> </ul>
<b>17.3</b>	Reliability Assurance Program During Design Phase	<ul style="list-style-type: none"> <li>• This section incorporates by reference Section 17.3 of the ABWR DCD</li> <li>• Provides supplemental information stating that COL License Information Items 17.2, 17.3, and 17.4 are addressed in FSAR Section 17.4S</li> </ul>
<b>17.4S</b>	Reliability Assurance Program	<ul style="list-style-type: none"> <li>• This section addresses COL License Information Items:               <ul style="list-style-type: none"> <li>- 17.2 Policy and Implementation Procedures for D-RAP</li> <li>- 17.3 D-RAP Organization</li> <li>- 17.4 Provision for Operation RAP</li> </ul> </li> </ul>
<b>17.6S</b>	Maintenance Rule Program	<ul style="list-style-type: none"> <li>• This section incorporates by reference NEI 07-02, “Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52”</li> </ul>

## **Sections 17.0, 17.1, and 17.2**

- FSAR Sections 17.0, 17.1 and 17.2 incorporate by reference Chapters 17.0, 17.1, and 17.2 of the ABWR DCD and provide reference to Section 17.5S of the FSAR to address the following COL Information Item:
  - 17.1 QA Programs For Construction and Operation
- STPNOC committed to incorporate by reference the OQAP into FSAR Section 17.1 (Confirmatory Item 01-9 - Result of January 2009 QA Implementation Inspection)
- The staff's review confirmed that the applicant has addressed the relevant information, and with exception to Confirmatory Item 01-9, no outstanding information is expected to be addressed in the COL FSAR related to these sections

## **Section 17.5S - Quality Assurance Program Guidance**

- Section 17.5S provides reference to “STP 3 & 4 Quality Assurance Program Description” submitted to the NRC as a separate document
- STPNOC submitted “STP 3 & 4 Quality Assurance Program Description,” Revision 2, on September 30, 2009
- Based on NEI 06-14, Rev. 7 – Approved December 2009
  - RAI issued to STP to address applicant-specific issues

## **Section 17.5S - Quality Assurance Program Guidance**

### **RAI / Open Item 17.5-9**

- STPNOC QAPD, Part IV, Regulatory Commitments mirrors NEI 06-14, Revision 7, but does not address applicant-specific items in the NRC SER, dated, Nov. 3, 2009.
- Staff requested clarification how quality assurance-related regulatory and industry guidance are met in Part IV of the QAPD.
  - RG 1.28 records and retention times
  - RG 1.33 proposed alternative acceptability
  - Consistency between this section and FSAR Table 1.9S
  - NQA-1-1994 commitment clarification

## **Section 17.4S – Reliability Assurance Program**

- FSAR Section 17.4S addresses COL License Information Items 17.2, 17.3, and 17.4 through the discussion of the following:
  - Essential Elements of D-RAP
  - Methodology for Identifying Risk-Significant SSCs
  - Integration of RAP into Operational Programs

## **Section 17.4S – Reliability Assurance Program**

### **Essential Elements of D-RAP**

- Applicant describes in FSAR Section 17.4S the essential elements of the site-specific D-RAP. The essential elements of D-RAP include organizational interfaces, design control, procedure controls, record controls, corrective action process, and audit plans
- Applicant plans to proceduralize and implement these essential elements by March 2010
- Staff will conduct an audit to verify this D-RAP activity (Confirmatory Item 17.04-8)

## **Section 17.4S – Reliability Assurance Program**

### **Methodology for Identifying Risk-Significant (RS) SSCs**

- The initial identification of site-specific RS SSCs in preparation of the COL application is provided in FSAR Appendix 19K and will be discussed during the Chapter 19 presentation to ACRS
- Applicant's methodology for identifying site-specific RS SSCs prior to entering the detailed design, procurement, fabrication, and construction phase:
  - PRA ( $FV \geq 0.005$ ,  $RAW \geq 2.0$ )
  - Establish and utilize an expert panel to augment PRA techniques in the risk ranking of SSCs using deterministic techniques and operating experience
- Applicant plans to implement this methodology and update the list of site-specific RS SSCs in 2010
- Staff will conduct an audit to verify this D-RAP activity (Confirmatory Item 17.04-7)

## **Section 17.4S – Reliability Assurance Program**

### **Integration of RAP into Operational Programs**

- Applicant proposes a process in FSAR Section 17.4S for meeting the objectives of the RAP during plant operation by integrating the RAP into the maintenance rule, quality assurance, surveillance testing, inservice inspection, inservice testing, and maintenance programs
- Staff concludes that this proposed process meets the guidance in Item E of SECY-95-132 and SRP Section 17.4 and is acceptable

## **Section 17.6S – Maintenance Rule Program**

- FSAR Section 17.6S incorporates by reference NEI 07-02, “Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52”
- Applicant will revise FSAR Section 17.6S to adopt the NEI 07-02A guidance (Confirmatory Item 17.06-2)
- Staff is unable to finalize conclusions for FSAR Section 17.6S as a result of the identified confirmatory item

# Chapter 17 Open items

Open Items	Current status of Open Items
<p><b>17.5-9</b> Requested clarification of how quality-related regulatory and industry guidance are met in Part IV of the QAPD.</p>	<p>The applicant has not responded yet. NEI 06-14, Rev. 8 is expected to address the generic issues.</p>
<p><b>17.04-9</b> (Identify the SSCs associated with risk-significant common cause failures of the HPCF, RHR, RBCW, and RSW systems)</p> <p><b>17.04-10</b> (Clarify the risk significance of the CWS pump circuit breakers)</p>	<p>These open items are related to the list of risk-significant SSCs in FSAR Appendix 19K and will be discussed as part of the Chapter 19 presentation to ACRS</p>
<p><b>17.04-11</b> (Integrate the “medium” risk category into the “high” risk category in FSAR Section 17.4S.1.4)</p>	<p>Has since been closed and is now confirmatory</p>

# Chapter 17 Open items

Open Items	Current status of Open Items
<p><b>17.5-9</b> Requested clarification of how quality-related regulatory and industry guidance are met in Part IV of the QAPD.</p>	<p>The applicant has not responded yet. NEI 06-14, Rev. 8 is expected to address the generic issues.</p>
<p><b>17.04-9</b> (Identify the SSCs associated with risk-significant common cause failures of the HPCF, RHR, RBCW, and RSW systems)</p> <p><b>17.04-10</b> (Clarify the risk significance of the CWS pump circuit breakers)</p>	<p>These open items are related to the list of risk-significant SSCs in FSAR Appendix 19K and will be discussed as part of the Chapter 19 presentation to ACRS</p>
<p><b>17.04-11</b> (Integrate the “medium” risk category into the “high” risk category in FSAR Section 17.4S.1.4)</p>	<p>Has since been closed and is now confirmatory</p>

# Backup Slides

## Reliability Assurance Program (RAP)

- Purpose of RAP is to ensure:
  - The reactor is designed, constructed, and operated consistent with the risk insights and key assumptions
  - The RAP SSCs do not degrade to an unacceptable level of reliability, availability, or condition during plant operations
  - The frequency of transients that challenge these SSCs is minimized
  - These SSCs will function reliably when challenged
- RAP is implemented in two stages:
  - Design-reliability assurance program (D-RAP) prior to fuel load
  - Use of operational programs to meet the objectives of RAP during operations phase

# Backup Slides

## Design Reliability Assurance Program

- D-RAP implementation includes:
  - Establishing and applying the essential elements of D-RAP.  
These are controls/processes that ensure the risk insights and key assumptions are consistent with the designed and constructed plant, and that the list of RAP SSCs is appropriately developed, maintained, and communicated to the appropriate organizations
  - Subjecting the non-safety-related RS SSCs to QA controls (Part V, "Nonsafety Related SSC Quality Controls," of SRP Section 17.5)

# Backup Slides

## Design Reliability Assurance Program

- **DC Applicant's Responsibilities:**
  - Describe the details of the D-RAP (e.g., scope, purpose, objectives, framework, and phases of D-RAP)
  - Establish and apply the essential elements of D-RAP during DC design activities
  - Determine the RAP SSCs (within the scope of the DC) using a combination of probabilistic, deterministic, and other methods of analysis
  - For the non-safety-related RAP SSCs, implement QA controls during DC design activities
  - Propose an D-RAP ITAAC
- **COL Applicant's Responsibilities:**
  - Establish and apply the essential elements of D-RAP during COL design activities
  - Determine the RAP SSCs in the COL's D-RAP by introducing plant-specific information
  - For the non-safety-related RAP SSCs, implement QA controls during COL design activities
  - Propose a process for integrating RAP into operational programs
- **COL Holder's Responsibilities:**
  - Apply the essential elements of D-RAP during COL design and construction activities (which includes updating the list of RAP SSCs as changes are made to the plant-specific design and PRA)
  - For the non-safety-related RAP SSCs, implement QA controls during design and construction activities
  - Complete the D-RAP ITAAC
  - Integrates RAP into operational programs (e.g., maintenance rule, quality assurance, surveillance testing, inservice inspection, inservice testing, and maintenance programs)