



Entergy Nuclear Operations, Inc.
Vermont Yankee
320 Governor Hunt Road
Vernon, VT 05354
Tel 802 257 7711

James M. DeVincentis
Licensing Manager

May 21, 2010

BVY 10-029

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

SUBJECT: Core Operating Limits Report for Cycle 28
Vermont Yankee Nuclear Power Station
Docket No. 50-271
License No. DPR-28

Dear Sir or Madam:

In accordance with Section 6.6.C of the Vermont Yankee Technical Specifications, enclosed is the Core Operating Limits Report for Cycle 28. This report presents the cycle-specific operating limits for Cycle 28 of the Vermont Yankee Nuclear Power Station.

There are no regulatory commitments being made in this submittal.

Should you have any questions concerning this transmittal, please contact me at (802) 451-3150.

Sincerely,

A handwritten signature in cursive script, appearing to read "JMD DeVincentis".

[JMD/JTM]

Attachment 1 – Vermont Yankee Nuclear Power Station - Cycle 28 - Vermont Yankee
Core Operating Limits Report

cc listing (next page)

ADD1
NRR

cc: Mr. Samuel J. Collins
Regional Administrator, Region 1
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. James S. Kim, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O-8C2A
Washington, DC 20555

USNRC Resident Inspector
Entergy Nuclear Vermont Yankee, LLC
320 Governor Hunt Road
Vernon, Vermont 05354

Mr. David O'Brien, Commissioner
VT Department of Public Service
112 State Street – Drawer 20
Montpelier, Vermont 05620-2601

BVY 10-029

Docket No. 50-271

Attachment 1

Vermont Yankee Nuclear Power Station

Cycle 28

Core Operating Limits Report

Vermont Yankee Nuclear Power Station

Cycle 28

Core Operating Limits Report

Revision 0

May 2010

Prepared	<u>DENNIS L. PEARSON / Dennis L. Pearson</u>	<u>5/17/2010</u>
	Responsible Engineer (Print/Sign)	Date
Reviewed	<u>NASSER NIK / Nasser Nik</u>	<u>5/17/2010</u>
	Fuels and Analysis (Print/Sign)	Date
Approved	<u>Ed Lindner / E Lindner</u>	<u>5/17/2010</u>
	Supervisor, Reactor Engineering (Print/Sign)	Date
Approved	<u>Norm Roderich / Norm Roderich</u>	<u>5/19/2010</u>
	Onsite Safety Review Committee (Print/Sign)	Date
Approved	<u>Christopher J. Wamsler / Chris Wamsler</u>	<u>5/19/2010</u>
	General Manager, Plant Operations (Print/Sign)	Date

REVISION RECORD

<u>Cycle</u>	<u>Revision</u>	<u>Date</u>	<u>Description</u>
28	0	05/2010	Cycle 28 revision

ABSTRACT

This report presents Cycle 28 specific operating limits at current license thermal power (1912 thermal megawatts) for the operation of the Vermont Yankee Nuclear Power Station as specified in Technical Specification 6.6.C. The limits included in the report are average planar linear heat generation rate, linear heat generation rate, minimum critical power ratio, and thermal-hydraulic stability exclusion region.

The requirement of Technical Specifications Table 3.2.5 pertaining to the rod block monitor (RBM) setpoint equation maximum value of N for single loop and dual loop operation are included in this report.

TABLE OF CONTENTS

	<u>Page</u>
LIST OF TABLES	ii
LIST OF FIGURES	ii
1.0 INTRODUCTION	1
2.0 CORE OPERATING LIMITS	2
2.1 Average Planar Linear Heat Generation Rate Limits (APLHGR).....	2
2.2 Minimum Critical Power Ratio (MCPR) Limits	2
2.3 Linear Heat Generation Rate (LHGR) Limits	4
2.4 Thermal-Hydraulic Stability Exclusion Region.....	5
2.5 Power/Flow Map.....	7
2.6 Single Loop Operation.....	7
2.7 Rod Block Monitoring.....	8
3.0 REFERENCES	16

TABLE OF CONTENTS (Continued)

LIST OF TABLES

<u>Number</u>	<u>Title</u>	<u>Page</u>
Table 2.1-1	MAPLHGR Limits for Bundle Types: GNF2-P10DG2B403-14G6.0-100T2-150-T6-3259 GNF2-P10DG2B404-14GZ-100T2-150-T6-3260 GNF2-P10DG2B403-11G6.0-100T2-150-T6-3261 GNF2-P10DG2B404-18GZ-100T2-150-T6-3262.....	9
Table 2.1-2	MAPLHGR Limits for Bundle Types: GNF2-P10DG2B387-15GZ-100T2-150-T6-2977-LUA GE14-P10DNAB383-17G6.0-100T-150-T6-2865 GE14-P10DNAB422-14GZ-100T-150-T6-2965 GE14-P10DNAB388-15GZ-100T-150-T6-2968 GE14-P10DNAB388-15GZ-100T-150-T6-2969 GE14-P10DNAB421-16GZ-100T-150-T6-3084 GE14-P10DNAB420-16GZ-100T-150-T6-3085 GE14-P10DNAB388-15G6.0-100T-150-T6-3086 GE14-P10DNAB388-16GZ-100T-150-T6-3087	9
Table 2.2-1	Rated MCPR Operating Limits (OLMCPR).....	10
Table 2.2-2	RBM Setpoint	10

LIST OF FIGURES

<u>Number</u>	<u>Title</u>	<u>Page</u>
2.2-1	Power Dependent K (P) / MCPR (P) Limits.....	11
2.2-2	Flow Dependent MCPR Operating Limit MCPR (F).....	12
2.3-1	Power Dependent LHGRFAC (P) Multiplier.....	13
2.3-2	LHGR Flow Factor LHGRFAC (F).....	14
2.4-1	Limits of Power/Flow Operation	15

1.0 INTRODUCTION

This report provides the cycle-specific limits for operation of the Vermont Yankee Nuclear Power Station in Cycle 28. It includes the limits for the average planar linear heat generation rate, linear heat generation rate, minimum critical power ratio, and thermal-hydraulic stability exclusion region. If any of these limits are exceeded, action will be taken as defined in the Technical Specifications.

As specified in Technical Specifications Table 3.2.5, the rod block monitor (RBM) setpoint equation maximum value of N for single and dual loop operation are included in this report.

This Core Operating Limits Report for Cycle 28 has been prepared in accordance with the requirements of Technical Specifications 6.6.C. The core operating limits have been developed using the NRC-approved methodologies listed in References 3.1 through 3.4. The methodologies are also listed in Technical Specification 6.6.C. The bases for these limits are in References 3.5 through 3.8. The GNF2 MCPR operating limits include Compensatory Measures to bound the effects of potentially bent GNF2 spacer flow wings as described in Reference 3.6.

As documented in the Vermont Yankee Extended Power Uprate (EPU) Safety Evaluation and resulting License Condition (Reference 3.10), when operating at thermal power greater than 1593 megawatts thermal, the safety limit minimum critical power ratio (SLMCPR) shall be established by adding 0.02 to the cycle-specific SLMCPR value calculated by the NRC approved methodologies documented in General Electric Licensing Topical Report NEDE-24011-P-A, "General Electric Standard Application for Reactor Fuel," as amended and documented in the Core Operating Limits Report. The 0.02 penalty is not applied to the single loop SLMCPR, because the plant is limited to the conditions specified in Section 2.6 while in single loop operation. The reload licensing analysis is consistent with the SLMCPR in Technical Specification 1.1.A (1.09 dual loop and 1.10 single loop) and includes the imposed license condition on the dual loop value (Reference 3.6).

2.0 CORE OPERATING LIMITS

The Cycle 28 operating limits have been defined using NRC-approved methodologies. Cycle 28 must be operated within the bounds of these limits and all others specified in the Technical Specifications.

2.1. Average Planar Linear Heat Generation Rate Limits (APLHGR) (T.S. 3.11.A)

APLHGR is applicable to a specific planar height and is equal to the sum of the linear heat generation rate (LHGR) for all of the fuel rods in the specific bundle at the specific height divided by the number of fuel rods in the fuel bundle at the height.

The maximum APLHGR (MAPLHGR) limit is a function of reactor power, core flow, fuel type, and average planar exposure. The cycle dependent limits are developed using NRC approved methodology described in References 3.1, 3.3 and 3.11. The MAPLHGR limit ensures that the peak clad temperature during a LOCA will not exceed the limits as specified in 10CFR50.46 (b) (1) and that the fuel design analysis criteria defined in References 3.1, 3.3 and 3.11 will be met.

Tables 2.1-1 and 2.1-2 provide a limiting composite of MAPLHGR values for each fuel type, which envelope the lattice MAPLHGR values employed by the process computer (Reference 3.6). When hand calculations are required, these MAPLHGR values are used for all lattices in the bundle.

For single recirculation loop operation, the limiting values shall be the values from these Tables listed under the heading "Single Loop Operation." These values are obtained by multiplying the values for two loop operation by 0.82 (References 3.6 and 3.9).

The power and flow dependent LHGR limits (LHGRFAC multipliers) in Figure 2.3-1 and 2.3-2 are sufficient to provide adequate protection for off-rated conditions for a LOCA. Therefore, the power and flow dependent MAPFAC multipliers are set to 1.

2.2. Minimum Critical Power Ratio (MCPR) Limits (T.S. 3.11.C)

MCPR is the smallest Critical Power Ratio (CPR) that exists in the core for each type of fuel and shall be equal to, or greater than the Operating Limit MCPR (OLMCPR), which is a function of Core Thermal Power, Core Flow, Fuel Type, and Scram Time (Tau).

The rated Operating Limit MCPR at steady-state rated power and increased core flow operating conditions is derived from the cycle specific fuel cladding integrity Safety Limit MCPR and the delta CPR, as determined from the most limiting transient event. The rated OLMCPR will ensure that the Safety Limit MCPR is not exceeded during any abnormal operational occurrence (AOO) (Reference 3.6).

The rated OLMCPR for two loop and single loop operation is documented in Table 2.2-1 and is dependent on scram time (Tau) surveillance data at position 36 (Reference 3.5).

Determination of Tau:

- i. First, τ_{ave} shall be determined:

$$\tau_{ave} = \frac{\sum_{i=1}^n N_i \tau_i}{\sum_{i=1}^n N_i}$$

where:

n = number of scram time tests thus far this cycle,

N_i = number of active rods measured in surveillance i , and

τ_i = average scram time to position 36 dropout of all rods measured in surveillance i .

- ii. Second, τ_B shall be determined:

$$\tau_B = \mu + 1.65 \sqrt{\left(\frac{N_1}{\sum_{i=1}^n N_i} \right) \sigma}$$

where:

$\mu = 0.830$ = mean of the distribution for average scram insertion time to position 36 dropout used in the ODYN Option B analysis.

$\sigma = 0.019$ = standard deviation of the distribution for average scram insertion time to position 36 dropout used in the ODYN Option B analysis.

N_1 = number of active rods measured during the first surveillance test at BOC.

- iii. Third, determine the OLMCPR, as follows:

If $\tau_{ave} \leq \tau_B$, then $OLMCPR_{Option B}$ from Table 2.2.1 may be used.

If $\tau_{ave} > \tau_B$, then a new OLMCPR shall be calculated:

$$OLMCPR_{New} = OLMCPR_{Option B} + \frac{\tau_{ave} - \tau_B}{\tau_A - \tau_B} (OLMCPR_{Option A} - OLMCPR_{Option B})$$

where:

$OLMCPR_{\text{Option A}}$ = Option A OLMCPR from Table 2.2.1 based on Option A analysis using full core scram times listed in Technical Specifications.

$OLMCPR_{\text{Option B}}$ = Option B OLMCPR from Table 2.2.1 based on Option B analysis described in Reference 3.1.

$\tau_A = 1.096$ seconds = Technical Specification core average scram time to drop-out of position 36.

The OLMCPR is the greater of the flow and power dependent MCPR operating limits, MCPR (F) and MCPR (P).

$$OLMCPR = \text{MAX} (MCPR (P), MCPR (F))$$

The flow dependent MCPR operating limit, MCPR (F), is provided in Figure 2.2-2.

For core thermal powers less than 25%, the power dependent MCPR operating limit, MCPR (P), is provided in Figure 2.2-1. For core thermal powers equal to or greater than 25%, MCPR (P) is the product of the rated OLMCPR presented in Table 2.2-1 and the K (P) factor presented in Figure 2.2-1.

Cycle exposure dependent limits are provided through the end of rated exposure point, which is expected to be the maximum exposure attainable at full power during ICF operation. Coastdown operation is allowable down to 40% rated CTP per Reference 3.1.

For single recirculation loop operation, the MCPR limits at rated flow shall be the values from Table 2.2-1 listed under the heading, "Single Loop Operation." The single loop values are obtained by adding 0.01 to the two loop operation values (TS 1.1.A.1).

2.3. Linear Heat Generation Rate (LHGR) Limits (T.S. 3.11.B)

LHGR is the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length. By maintaining the operating LHGR below the applicable LHGR limit, it is assured that all thermal-mechanical design basis and licensing limits for the fuel will be satisfied.

The maximum LHGR limit is a function of reactor power, core flow, fuel and rod type, and fuel rod nodal exposure. The limit is developed using NRC approved methodology described in Reference 3.1 to ensure the cladding will not exceed its yield stress and that the fuel thermal-mechanical design criteria will not be violated during any postulated transient events.

During reactor power operation, the LHGR of any rod in any fuel bundle at any axial location shall not exceed the rated power and rated core flow limits (LHGR_{std}) for each fuel and rod type as a function of fuel rod nodal exposure listed in Reference 3.7.

The LHGR limits for the fuel pin axial locations with no gadolinium and maximum gadolinium concentration listed in Reference 3.7 are expected to operate near the LHGR limits.

There are also fuel pins with axial locations that have gadolinium concentrations that are less than the maximum concentration anywhere in the bundle. The LHGR limits for these axial locations range uniformly between the case of no gadolinium and the most limiting gadolinium concentration.

For other than rated power and flow conditions (below 23% core thermal power thermal limit calculation is not required), the applicable limiting LHGR values for each fuel type is the smaller of the power and flow dependent LHGR limits multiplied by the applicable power and flow adjustment factor or the LHGR limit multiplied by 0.82 when in single loop operation.

$$\text{LHGR limit} = \text{MIN} (\text{LHGR} (P), \text{LHGR} (F)).$$

Power-dependent LHGR limit, LHGR (P), is the product of the LHGR power dependent LHGR limit adjustment factor, LHGRFAC (P), shown in Figure 2.3-1 and the LHGR_{std}.

$$\text{LHGR} (P) = \text{LHGRFAC} (P) \times \text{LHGR}_{\text{std}}$$

The flow-dependent LHGR limit, LHGR (F), is the product of the LHGR flow dependent LHGR limit adjustment factor, LHGRFAC (F), shown in Figure 2.3-2 and the LHGR_{std}.

$$\text{LHGR} (F) = \text{LHGRFAC} (F) \times \text{LHGR}_{\text{std}}$$

2.4. Thermal-Hydraulic Stability Exclusion Region (T.S. 3.6.J)

The predominant oscillation mode is core-wide based on decay ratios at the most limiting point on the power/flow map. Normal plant operation is not allowed inside the bounds of the exclusion region defined in Figure 2.4-1. Operation inside of the exclusion region may result in a thermal-hydraulic oscillation. Intentional operation within the buffer region is not allowed unless the Stability Monitor is operable. Otherwise, the buffer region is considered part of the exclusion region (Reference 3.6).

The coordinates of the Exclusion Region are as follows:

Point	Power (%)	Flow (%)
A	57.9	41.7
B	37.5	31.3

The Modified Shape Function equation used to generate the Exclusion Region boundary is as follows:

$$P = P_B \left(\frac{P_A}{P_B} \right)^{\left[\frac{W - W_B}{W_A - W_B} \right]}$$

where,

- P = a core thermal power value on the Exclusion Region boundary (% of rated),
- W = the core flow rate corresponding to power, P, on the Exclusion Region boundary (% of rated),
- P_A = core thermal power at State Point A (% of rated),
- P_B = core thermal power at State Point B (% of rated),
- W_A = core flow rate at State Point A (% of rated),
- W_B = core flow rate at State Point B (% of rated),

The range of validity of the fit is: 31.3% ≤ %Flow ≤ 41.7%

The coordinates of the Buffer Region are as follows:

Point	Power (%)	Flow (%)
C	63.8	49.1
D	32.5	31.3

The Modified Shape Function equation used to generate the Buffer Region boundary is as follows:

$$P = P_D \left(\frac{P_C}{P_D} \right)^{\left[\frac{W - W_D}{W_C - W_D} \right]}$$

where,

- P = a core thermal power value on the Buffer Zone boundary (% of rated),
- W = the core flow rate corresponding to power, P, on the Buffer Zone boundary (% of rated),
- P_C = core thermal power at State Point C (% of rated),
- P_D = core thermal power at State Point D (% of rated),
- W_C = core flow rate at State Point C (% of rated),
- W_D = core flow rate at State Point D (% of rated),

The range of validity of the fit is: 31.3% ≤ %Flow ≤ 49.1%.

2.5. Power/Flow Map

Power operation, with respect to Core Thermal Power/Total Core Flow combinations, is allowed within the outlined area of Figure 2.4-1. This area is bounded by the following lines:

- **Minimum Pump Speed Line;** This line approximates operation at minimum pump speed. Plant start-up is performed with the recirculation pumps operating at approximately 20% speed. Reactor power level will approximately follow this line during the normal control rod withdrawal sequence.
- **Minimum Power Line;** This line approximates the interlock that requires recirc pump speed to be at a minimum in terms of feedwater flow. This interlock ensures NPSH requirements for jet pumps and recirculation pumps are met.
- **Natural Circulation Line;** The operating state the reactor follows along this line for the normal control rod withdrawal sequence in the absence of recirculation pump operation.
- **Exclusion Region;** The exclusion region is a power/flow region where an instability can occur. The boundary for the exclusion region is established through use of an analysis procedure which is demonstrated to be conservative relative to expected operating conditions.
- **Buffer Region Boundary;** The Buffer Region is determined by adjusting the endpoints of the Exclusion Region to meet a 0.65 decay ratio OR increasing the flow on the highest rod line by 5% and decreasing power on the natural circulation line by 5% if more limiting than the 0.65 decay ratio intercepts.
- **Rated Power Line and MELLLA Boundary;** These lines provide the upper power limit and operating domain assumed in plant safety analyses.
- **ICF Boundary;** This line represents the highest allowable analyzed core flow. The analysis in Reference 3.4 supports the maximum attainable core flow being 107% of rated core flow.

2.6. Single Loop Operation

SLO was not analyzed for operation in the MELLLA region. The power/flow operating condition for Single Loop Operation (SLO) is core power less than 1239 MWth (64.80%CTP), core flow less than 26.35 M#/hr (54.9%) and maximum rod line less than 90% (References 3.2 and 3.3)

2.7. Rod Block Monitoring

The Rod Block Monitor (RBM) control rod block functions are no longer credited in the Rod Withdrawal Error (RWE) Analysis and as such, do not affect the MCPR Operating Limit. The RBM setpoints are based on providing operational flexibility in the MELLLA region (TS Bases 3.2). The rod block monitor (RBM) setpoint equation maximum value of N for single loop and dual loop operation are listed in Table 2.2-2.

Table 2.1-1

MAPLHGR Limits for Bundle Types:

GNF2-P10DG2B403-14G6.0-100T2-150-T6-3259
 GNF2-P10DG2B404-14GZ-100T2-150-T6-3260
 GNF2-P10DG2B403-11G6.0-100T2-150-T6-3261
 GNF2-P10DG2B404-18GZ-100T2-150-T6-3262

Average Planar Exposure (GWd/ST)	MAPLHGR (kW/ft)	
	Two Loop Operation	Single Loop Operation ¹
0	13.78	11.30
17.52	13.78	11.30
60.78	7.50	6.15
63.50	6.69	5.49

Table 2.1-2

MAPLHGR Limits for Bundle Types:

GNF2-P10DG2B387-15GZ-100T2-150-T6-2977-LUA
 GE14-P10DNAB383-17G6.0-100T-150-T6-2865
 GE14-P10DNAB422-14GZ-100T-150-T6-2965
 GE14-P10DNAB388-15GZ-100T-150-T6-2968
 GE14-P10DNAB388-15GZ-100T-150-T6-2969
 GE14-P10DNAB421-16GZ-100T-150-T6-3084
 GE14-P10DNAB420-16GZ-100T-150-T6-3085
 GE14-P10DNAB388-15G6.0-100T-150-T6-3086
 GE14-P10DNAB388-16GZ-100T-150-T6-3087

Average Planar Exposure (GWd/ST)	MAPLHGR (kW/ft)	
	Two Loop Operation	Single Loop Operation ¹
0	12.82	10.51
19.12	12.82	10.51
57.61	8.00	6.56
63.50	5.00	4.10

Technical Specification References: 3.6.G.1a and 3.11.A.

¹ MAPLHGR for single loop operation is obtained by multiplying MAPLHGR for two loop operation by 0.82.

Table 2.2-1

Rated MCPR Operating Limits (OLMCPR)

<u>Option/Fuel Type</u>	<u>Cycle Exposure Range</u>	<u>Two Loop Operation²</u>	<u>Single Loop Operation¹</u>
Option A/GE14	0 to 8,900 MWd/St	1.45	1.46
	Beyond 8,900 MWd/St	1.59	1.60
Option A/GNF2 ³	0 to 8,900 MWd/St	1.47	1.48
	Beyond 8,900 MWd/St	1.59	1.60
Option B/GE14	0 to 8,900 MWd/St	1.40	1.41
	Beyond 8,900 MWd/St	1.42	1.43
Option B/GNF2 ³	0 to 8,900 MWd/St	1.40	1.41
	Beyond 8,900 MWd/St	1.49	1.50

Source: References 3.6.

- 1 The MCPR operating limit is increased by 0.01 for single loop operation.
- 2 The two loop MCPR operating limits bound ICF operation throughout the cycle.
- 3 The GNF2 MCPR operating limits include Compensatory Measures to bound the effects of potentially bent GNF2 spacer flow wings (Reference 3.6).

Table 2.2-2
RBM Setpoint⁴

Dual Loop Operation Maximum Value of "N" in RBM Setpoint Equation – 62.
Single Loop Operation Maximum Value of "N" in RBM Setpoint Equation – 68.


Source: Reference 3.8

Technical Specification References: Table 3.2.5.

- 4 The Rod Block Monitor (RBM) trip setpoints are determined by the equation shown in Table 3.2.5 of the Technical Specifications.

Figure 2.2-1

Power Dependent K (P) / MCPR (P) Limits
(Technical Specification Reference 3.11.C)



Operating Limit MCPR(P) = K(P) * Operating Limit MCPR(100)

For P < 23%, No Thermal Limits Required

P-Bypass = 25% Rated Power

MCPR(P) limits are based on a 1.09 SLMCPR

MCPR(P) for <25%P, >60°F

POWER	LIMIT
23.0	2.70
25.0	2.58

EQUATIONS

For 23% ≤ P < 25%:

$$MCPR(P) = 2.58 + 6.00E-02(25.0 - P)$$

MCPR(P) for <25%P, ≤60°F

POWER	LIMIT
23.0	2.24
25.0	2.15

EQUATIONS

For 23% ≤ P < 25%:

$$MCPR(P) = 2.15 + 4.50E-02(25.0 - P)$$

K(P) for ≥25%P

POWER	LIMIT
25.0	1.55
45.0	1.28
100.0	1.00

EQUATIONS

For 25% ≤ P < 45%:


$$MCPR(P) = 1.28 + 1.35E-02(45.0 - P)$$

For 45% ≤ P < 100%:

$$MCPR(P) = 1.00 + 5.09E-03(100.0 - P)$$

Figure 2.2-2

Flow Dependent MCPR Operating Limit MCPR (F)
 (Technical Specification Reference 3.11.C)



MCPR(F) limits are based on a 1.09 SLMCPR

Max Runout Flow = 109.5%


FLOW	LIMIT
30.0	1.60
86.3	1.25
109.5	1.25

EQUATIONS

For $30\% \leq F \leq 109.5\%$: $MCPR(F) = \text{MAX}(1.25, -0.622 * F / 100 + 1.7865)$

Figure 2.3-1

Power Dependent LHGRFAC (P) Multiplier
(Technical Specification Reference 3.11.B)



LHGR(P) = LHGRFAC(P) * LHGRstd
 For P < 23%, No Thermal Limits Required
 P-Bypass = 25% Rated Power

LHGRFAC(P) for <25%P, >60°F

POWER	LIMIT
23.0	0.560
25.0	0.568

EQUATIONS

For 23% ≤ P < 25%: $LHGRFAC(P) = 0.568 + 4.00E-03(P - 25.0)$

LHGRFAC(P) for <25%P, ≤60°F

POWER	LIMIT
23.0	0.598
25.0	0.608

EQUATIONS

For 23% ≤ P < 25%: $LHGRFAC(P) = 0.608 + 5.00E-03(P - 25.0)$

LHGRFAC(P) for ≥25%P


POWER	LIMIT
25.0	0.608
100.0	1.000

EQUATIONS

For 25% ≤ P < 100%: $LHGRFAC(P) = 1.000 + 5.23E-03(P - 100.0)$

Figure 2.3-2

LHGR Flow Factor LHGRFAC (F)
 (Technical Specification Reference 3.11.B)



$LHGR(F) = LHGRFAC(F) * LHGRstd$

Max Runout Flow = 109.5%

FLOW	LIMIT
30.0	0.54
82.6	1.00
109.5	1.00

EQUATIONS

For $30\% \leq F \leq 109.5\%$: $LHGRFAC(F) = \text{MIN}(1.00, \{A(F)*F/100+B(F)\})$


$A(F) = 0.874$

$B(F) = 0.278$

Figure 2.4-1

Limits of Power/Flow Operation
(Technical Specification Reference 3.6.J)

CYCLE 28 POWER/FLOW MAP



3.0 REFERENCES

- 3.1. Report, General Electric, General Electric Standard Application for Reactor Fuel (GESTAR II), NEDE-24011-P-A-16, October 2007 (Proprietary).
- 3.2. Report, GE, Vermont Yankee Nuclear Power Station APRM/RBM/Technical Specifications/Maximum Extended Load Line Limit Analysis (ARTS/MELLLA), NEDC-33089P, March 2003 (Proprietary).
- 3.3. Report, GE, Entergy Nuclear Operation Incorporated Vermont Yankee Nuclear Power Station Extended Power Uprate – Task T0407 – ECCS-LOCA SAFER/GESTR, GE-NE-0000-0015-5477-01, September 2004 (Proprietary)
- 3.4. Report, GE, Vermont Yankee Nuclear Power Station Increased Core Flow Analysis, NEDC-32791P, February 1999 (Proprietary).
- 3.5. Letter, Global Nuclear Fuels, William H. Hetzel (GNF) to Dave Mannai (VYNPC), Vermont Yankee Option B Licensing Basis, WHV: 2001-023, November 9, 2001.
- 3.6. Report, Global Nuclear Fuels, Supplemental Reload Licensing Report for Vermont Yankee Nuclear Power Station Reload 27 Cycle 28, 0000-0100-8140-SRLR, Rev. 2, May 2010 (ECH-NE-10-00006).
- 3.7. Report, Global Nuclear Fuels, Fuel Bundle Information Report for Vermont Yankee Nuclear Power Station Reload 27 Cycle 28, 0000-0100-8140-FBIR, Rev. 0, February 2010 (Proprietary) (ECH-NE-10-00008).
- 3.8. VYDC 2003-015, ARTS/MELLLA Implementation.
- 3.9. Report, GE, Vermont Yankee Nuclear Power Station Single Loop Operation, NEDO-30060, February 1983.
- 3.10. Entergy Nuclear Vermont Yankee, LLC and Entergy Nuclear Operations, Inc. Docket No. 50-271 Vermont Yankee Nuclear Power Station Amendment to Facility Operating License Amendment No. 229 License No. DPR-28, Extended Power Uprate Amendment, March 2006.
- 3.11. Report, GEH, Vermont Yankee Nuclear Power Station GNF2 ECCS-LOCA Evaluation, 0000-0100-8613-R0, December 2009 (ECH-NE-10-00001)