

ArevaEPRDCPEm Resource

From: Tesfaye, Getachew
Sent: Wednesday, May 26, 2010 12:31 PM
To: 'usepr@areva.com'
Cc: Tabatabai, Sarah; Karas, Rebecca; Patel, Jay; Miernicki, Michael; Colaccino, Joseph; ArevaEPRDCPEm Resource
Subject: U.S. EPR Design Certification Application RAI No. 400(4708), FSAR Ch. 3, OPEN ITEM
Attachments: RAI_400_RGS1_4708.doc

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on May 5, 2010, and on March 26, 2010, you informed us that the RAI is clear and no further clarification is needed. As a result, no change is made to the draft RAI. The question in this RAI is an OPEN ITEM in the safety evaluation report for Chapter 3, Group 1 sections in Phases 2 and 3 reviews. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,
Getachew Tesfaye
Sr. Project Manager
NRO/DNRL/NARP
(301) 415-3361

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 1461

Mail Envelope Properties (0A64B42AAA8FD4418CE1EB5240A6FED1134506A734)

Subject: U.S. EPR Design Certification Application RAI No. 400(4708), FSAR Ch. 3,
OPEN ITEM
Sent Date: 5/26/2010 12:31:25 PM
Received Date: 5/26/2010 12:31:27 PM
From: Tesfaye, Getachew

Created By: Getachew.Tesfaye@nrc.gov

Recipients:

"Tabatabai, Sarah" <Sarah.Tabatabai@nrc.gov>
Tracking Status: None
"Karas, Rebecca" <Rebecca.Karas@nrc.gov>
Tracking Status: None
"Patel, Jay" <Jay.Patel@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	916	5/26/2010 12:31:27 PM
RAI_400_RGS1_4708.doc		30202

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 400 (4708), Revision 1

5/26/2010

U. S. EPR Standard Design Certification

AREVA NP Inc.

Docket No. 52-020

SRP Section: 03.07.04 - Seismic Instrumentation

Application Section: 3.7.4

QUESTIONS for Geosciences and Geotechnical Engineering Branch 1 (RGS1)

03.07.04-7

OPEN ITEM

ITAAC Item 2.1, listed in FSAR Tier 1, Table 2.4.7-1 states that analyses are to be performed to determine that the location of the SMS equipment as described in FSAR Tier 1, Section 2.1. However, the staff reviewed FSAR Tier 1, Section 2.1 and was not able to find the description of the SMS locations. Please specify the correct FSAR Tier 1 Section which provides the location of the SMS equipment.