



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 146
License No. DPR-26

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated November 30, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:

9002070176 900130
PDR ADOCK 05000247
P PDC

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 146, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Robert A. Capra

Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: January 30, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 146

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Revise Appendix A as follows:

Remove Page

3.3-3

Insert Page

3.3-3

- e. Deleted
 - f. One refueling water storage tank low-level alarm may be inoperable for up to 7 days provided the other low-level alarm is operable.
3. When RCS temperature is less than or equal to 295^oF, the requirements of Table 3.1.A-2 regarding the number of safety injection (SI) pumps allowed to be energized shall be adhered to.

B. CONTAINMENT COOLING AND IODINE REMOVAL SYSTEMS

1. The reactor shall not be made critical unless the following conditions are met:
- a. The spray additive tank contains not less than 4000 gallons of solution with a sodium hydroxide concentration of not less than 30% by weight.
 - b. The five fan cooler-charcoal filter units and the two spray pumps, with their associated valves and piping, are operable.
2. During power operation, the requirements of 3.3.B.1 may be modified to allow any one of the following components to be inoperable. If the system is not restored to meet the requirements of 3.3.B.1 within the time period specified, the reactor shall be placed in the hot shutdown condition utilizing normal operating procedures. If the requirements of 3.3.B.1 are not satisfied within an additional 48 hours, the reactor shall be placed in the cold shutdown condition utilizing normal operating procedures.
- a. One fan cooler unit may be inoperable during normal reactor operation for a period not to exceed 7 days provided both containment spray pumps are operable.
 - b. One containment spray pump may be inoperable during normal reactor operation, for a period not to exceed 72 hours, provided the five fan cooler units and the remaining containment spray pump are operable.
 - c. Any valve required for the functioning of the system during and following accident conditions may be inoperable provided it is restored to operable status within 7 days or 24 hours for the fan cooler or containment spray systems respectively, and all valves in the system that provide the duplicate function are operable.