



DAVE BAXTER
Vice President
Oconee Nuclear Station

Duke Energy
ON01VP / 7800 Rochester Highway
Seneca, SC 29672

864-873-4460
864-873-4208 fax
dabaxter@dukeenergy.com

May 26, 2010

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Duke Energy Carolinas, LLC (Duke)
Oconee Nuclear Station, Unit 2
Docket Number 50-270
Relief Request 09-ON-003

On March 20, 2009 Duke Energy submitted Relief Request 09-ON-003 (ADAMS ML090830726) pursuant to 10 CFR 50.55a(a)(3)(i), requesting NRC approval to use alternatives to the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI inservice inspection (ISI) requirements for the Oconee Nuclear Station, Unit 1, 2, & 3. This alternative approach is to support application of full structural weld overlays on several welds in the Reactor Coolant System for all three Oconee units.

On October 16, 2009 the NRC granted verbal approval for the portion of Relief Request 09-ON-003 applicable to the Unit 1 Letdown nozzle welds. By letter dated March 31, 2010 (ADAMS ML100880286), the NRC provided written approval for all three Oconee Units. The request committed to provide a report to summarize the results of ultrasonic examinations of the weld overlays within 14 days of completion of those examinations. In accordance with that commitment, the summary report for Unit 2 is attached.

If you have any questions or require additional information, please contact Randy Todd at (864)-873-3418.

Sincerely,

Dave Baxter
Site Vice President
Oconee Nuclear Station

Attachment

A047
NRC

Nuclear Regulatory Commission
May 26, 2010
Page 2

XC with Attachment:

Luis Reyes
Region II Administrator
U.S. Nuclear Regulatory Commission
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

John Stang
Project Manager (ONS)
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Rockville, MD 20852-2738

XC w/o Attachment:

Andy Sabisch
NRC Senior Resident Inspector
Oconee Nuclear Station

Susan Jenkins, Section Manager,
Division of Waste Management
Bureau of Land and Waste Management
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201

Attachment

**Summary of Weld Overlay Ultrasonic Examination for Letdown Line Drain Nozzle-to-Safe End
and Safe End-to-Elbow Welds at Oconee Nuclear Station, Unit 2**



Ultrasonic Examination Procedure

SI-UT-145, Revision 0, *Procedure for Manual Phased Array Ultrasonic Examination of Weld Overlaid Similar and Dissimilar Metal Piping Welds*, EPRI-WOL-PA-1, was used for examination of the Letdown Line Drain Nozzle weld overlay (WOL). This procedure, and the examiner who applied the procedure, are qualified through the PDI Program at the EPRI NDE Center.

Letdown Drain Nozzle Weld Overlay Examination

Component Identification: Letdown Drain Weld Overlay 2-51A-0035-01-136V

Examination Date: 05/12/10

Examination Time: 1144 to 1210

Weld Overlay Regions Examined: Overlay, Nozzle-to-Safe End Dissimilar Metal (DM) Weld #2-PIB1-11 / Base Material (Outer 25%) and Safe End-to-Elbow Weld #2-51A-0035-01-15A / Base Material (Outer 25%)

Axial Examination Angles: 0° through 85°

Circumferential Examination Angles: 0° through 85°

Examination Summary: No suspected flaw indications were observed during the examinations. The examination gain was adjusted to maintain the procedure-specified baseline noise level from 5% to 20% of full screen height. The examination coverage achieved of the Code-required volumes during the examinations is provided below:

- Coverage of Weld Overlay 2-51A-0035-01-136V Material: 100%
- Coverage of Outer 25% of Nozzle-to-Safe End DM Weld #2-PIB1-11 & Adjacent Base Material: 100%
- Coverage of Safe End-to-Elbow Weld #2-51A-0035-01-15A & Outer 25% Adjacent Base Material: 93%