


# **Loss-of-Coolant Accident Phenomena Identification and Ranking Table Licensing Technical Report**

**Wendell Wagner, Senior Safety Analyst**

**June 2, 2010**



**U.S. Nuclear Regulatory Commission  
Pre-Application Meeting  
Rockville, MD**



# Requirements and Interfaces

- 10 CFR 50.46, *Acceptance Criteria for Emergency Core Cooling Systems for Light-Water Nuclear Power Reactors*
- SECY-08-189, *Advanced Reactor Design Policy*
- Regulatory Guide 1.203, *Transient and Accident Analysis Methods*
- NuScale Level B Software Quality Assurance Process & Procedures

# Report Outline

- General Information
- Postulated Accident Scenario Description
- PIRT Process
- Discussion of Phenomena and Ranking Rationales
- Conclusions
- Appendix A – PIRT Panel Biographies

# Purpose and Scope

- Independent assessment of the relative importance of phenomena that may occur in the NuScale module during postulated loss-of-coolant accidents (LOCAs)
- Support development of detailed evaluation models for analysis of LOCAs

# References

1. **US NRC.** Regulatory Guide 1.203, *Transient and Accident Analysis Methods*. US NRC, 2005.
2. **US NRC.** 10 CFR 50.46, *Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors*. US NRC.
3. **US NRC.** SECY-08-189, *Advanced Reactor Design Policy*, US NRC, 2008.
4. **NuScale Power.** *Customer Requirements Document (Draft)*, NuScale Power, 2008.
5. **NuScale Power.** NP-RF-03RP-003, *NuScale Preliminary Loss-Of-Coolant-Accident Phenomena Identification and Ranking Table (PIRT)*, NuScale Power, 2010.
6. **Information Systems Laboratories.** *RELAP5 MOD3.3 Code Manual, Volume 4: Models and Correlations*, ISL, 2006.
7. **Saha, D., Cleveland, J.** *Natural Circulation in Nuclear Reactor System*, Science and Technology of Nuclear Installations, 2008.

# Plant Description

- Based on Rev. A module design
- Key differences between Rev A. and Rev. B (current) designs
  - 1.63 m height core
  - Minor ECCS timing
  - Steam generator tube number and dimensions
- Design changes are not anticipated to change phenomena ranking

# Scenario Description

- LOCA variation in NuScale design restricted by limited number of penetrations of primary system pressure boundary
  - Breaks in penetrations that would exceed normal makeup capacity
- Leads to limited set of LOCA scenarios
- Panel selected inadvertent actuation of an RVV as scenario that would cover the vast majority of phenomena to be expected in any LOCA
- Sample RELAP5/3.3 calculations developed to help inform panel deliberations

# Process

- Step 1 – Issues
- Step 2 – Objectives
- Step 3 – Hardware and scenario
- Step 4 – Evaluation criteria
- Step 5 – Knowledge base
- Step 6 – Identify phenomena
- Step 7 – Important ranking
- Step 8 – Knowledge level ranking



# Panelists

- Dr. Graham Wallis, Chair
- Dr. Lawrence E. Hochreiter
- Dr. Mujid S. Kazimi
- Mr. Brent Boyack
- Dr. Kord S. Smith
- Dr. José N. Reyes
- Dr. Kent B. Welter, Facilitator
- Dr. Eric P. Young, Assistant

# Important Level and Knowledge Rankings

## Importance Rank

Inactive (I)

Low (L)

Medium (M)

High (H)

## Definition

Phenomenon not present or negligible

Small influence on primary figure of merit

Moderate influence on primary figure of merit

Significant influence on primary figure of merit

## Knowledge Level

1

Very limited knowledge, uncertainty cannot be characterized

2

Partially known, large uncertainty


3

Known, moderate uncertainty

4

Well known, small uncertainty

# Scenario Periods



# Phenomena-specific Systems, Components, and Processes

Core	Primary System	Containment Heat Removal System	Decay Heat Removal System
<ul style="list-style-type: none"> <li>• Fuel rods</li> <li>• Subchannel Coolant flow</li> <li>• Core-wide flow</li> <li>• Control rods / guide tubes</li> <li>• Reflector / core barrel / baffle</li> </ul>	<ul style="list-style-type: none"> <li>• Downcomer</li> <li>• Hot Leg Riser</li> <li>• Lower plenum</li> <li>• Upper plenum</li> <li>• Pressurizer</li> <li>• Cold Leg (steam generator annulus)</li> <li>• Break</li> </ul>	<ul style="list-style-type: none"> <li>• Containment</li> <li>• Sump recirculation valves</li> <li>• Containment cooling pool</li> <li>• Reactor vent valves</li> <li>• Concrete / stainless steel liner of containment cooling pool</li> </ul>	<ul style="list-style-type: none"> <li>• Containment cooling Pool (During sparger venting)</li> <li>• Sump screen and piping</li> <li>• Steam generator tubes</li> <li>• Sparger and piping</li> <li>• Feedwater accumulators</li> <li>• Instrumentation</li> </ul>

# Figures of Merit


Period	Figure of Merit	Description
1	Critical heat flux (CHF)	<p>Thermal limit of a phenomenon where a phase change occurs during heating (such as bubbles forming on a metal surface used to heat water), which suddenly decreases the efficiency of heat transfer, thus causing a localized temperature increase of the heating surface.</p> <p>Also called a departure from nucleate boiling (DNB), the CHF limit for the fuel cladding is an important figure of merit for assessing reactor safety.</p>
2	Core collapsed liquid level and CHF	<p>Single-phase collapsed liquid level is measured in relation to the top of the heated fuel region.</p> <p>CHF is important for any heated surface within the core region and is described for the previous period.</p>
3	Core coolability	<p>Conditional configuration described by the ability to supply sufficient coolant to prevent fuel temperatures that would result in fuel damage.</p>

# Summary of Results

	<b>Phase 1 (Initial Blowdown)</b>	<b>Phase 2 (RVV Actuation)</b>	<b>Phase 3 (Long-Term Cooling)</b>
High Importance (H)	⌚ Subchannel/coolant flow	⌚ Break ⌚ Reactor vent valves	⌚ Concrete / stainless steel liner of CCP
Medium Importance (M)	⌚ Fuel rods ⌚ Core-wide flow ⌚ Hot Leg Riser ⌚ Lower plenum ⌚ Upper plenum ⌚ Pressurizer ⌚ Cold Leg (SG annulus) ⌚ Break	⌚ Fuel rods ⌚ Subchannel / Coolant Flow ⌚ Core-wide flow ⌚ Hot Leg Riser ⌚ Lower plenum ⌚ Pressurizer ⌚ Containment	⌚ Break ⌚ Containment ⌚ Sump recirculation valves ⌚ Containment cooling pool ⌚ Reactor vent valves
Low Importance (L)	⌚ Control rods / guide tubes ⌚ Reflector/core barrel/baffle ⌚ Downcomer ⌚ Containment ⌚ Containment cooling pool while sparger venting	⌚ Control rods / guide tubes ⌚ Reflector/core barrel/baffle ⌚ Downcomer ⌚ Upper plenum ⌚ Cold Leg (SG annulus) ⌚ Containment cooling pool	⌚ Fuel rods ⌚ Subchannel / coolant flow ⌚ Core-wide flow ⌚ Control rods/guide tubes ⌚ Reflector/core barrel/baffle ⌚ Downcomer ⌚ Hot Leg Riser ⌚ Lower plenum ⌚ Upper Plenum ⌚ Pressurizer ⌚ Cold leg (SG annulus)

# Conclusions

- Approximately 160 phenomena related to figures of merit identified
- 54 (~34%) specified as highly important for at least one period of SBLOCA
- No phenomenon identified ranked highly important for all three periods of SBLOCA
- Knowledge levels for these 54 highly-ranked phenomena ranged from 2 (partially known) to 4 (fully known), with the large majority ranked as fairly well known
- 16 phenomena of high importance were assigned knowledge level of 2
- Majority of high-importance, low-knowledge phenomena associated with core subchannel flow and Hot Leg Riser



# NUSCALE POWER

201 NW 3rd Street  
Corvallis, OR 97330  
541-207-3931  
[nuscalepower.com](http://nuscalepower.com)

