

AP1000DCDFileNPEm Resource

From: Loza, Paul G. [lozapg@westinghouse.com]
Sent: Tuesday, June 01, 2010 1:44 PM
To: Buckberg, Perry
Cc: Mulhollem, Luke G.; Butler, Rhonda; Brehm, Jason A.
Subject: Acknowledgement of OI-SRP 9.1.3-SBPA-13 R2

Perry,

I acknowledge receipt for Westinghouse of OI-SRP 9.1.3-SBPA-13 R2.

Thanks,

Paul

From: Buckberg, Perry [mailto:Perry.Buckberg@nrc.gov]
Sent: Tuesday, June 01, 2010 11:53 AM
To: Loza, Paul G.
Cc: Jaffe, David; McKenna, Eileen; Butler, Rhonda; Oddo, John; Brehm, Jason A.; Sanders, Mitchell P.; Lath, Arunabh; Mulhollem, Luke G.; Melton, Michael A
Subject: AP1000 OI-SRP 9.1.3-SBPA-13

Paul,

After reviewing the Westinghouse 5/19/10 response to OI-SRP 9.1.3-SBPA-13 R1, the staff has one last concern that a revised response could resolve. Below is OI-SRP 9.1.3-SBPA-13 Revision 2.

Thanks,

Perry Buckberg

Senior Project Manager
Nuclear Regulatory Commission
Office of New Reactors
phone: (301)415-1383
fax: (301)415-5397
perry.buckberg@nrc.gov

OI-SRP 9.1.3-SBPA-13 R2

The information presented in DCD Table 9.1-2, "Spent Fuel Pool Cooling and Purification System Design Parameters," is not supported by the discussion in DCD Section 9.1.3.1.3.2, "Full Core Off-Load." A statement is needed in Section 9.1.3.1.3.2 that discusses that with a full core offload, with only one of the SFS cooling trains and one RNS train in operation, the maximum fuel pool temperature is less than 140°F.

Hearing Identifier: AP1000_DCD_Review
Email Number: 387

Mail Envelope Properties (27265BDD489F164BAB98F1FFF63719725098134C)

Subject: Acknowledgement of OI-SRP 9.1.3-SBPA-13 R2
Sent Date: 6/1/2010 1:43:33 PM
Received Date: 6/1/2010 1:43:35 PM
From: Loza, Paul G.

Created By: lozapg@westinghouse.com

Recipients:

"Mulhollem, Luke G." <MulholLG@westinghouse.com>
Tracking Status: None
"Butler, Rhonda" <Rhonda.Butler@nrc.gov>
Tracking Status: None
"Brehm, Jason A." <brehmja@westinghouse.com>
Tracking Status: None
"Buckberg, Perry" <Perry.Buckberg@nrc.gov>
Tracking Status: None

Post Office: SWEC9985.w-intra.net

Files	Size	Date & Time
MESSAGE	1293	6/1/2010 1:43:35 PM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: