

From: Goodwin, Cameron
Sent: Wednesday, June 02, 2010 3:13 PM
To: 'ken.nicely@exeloncorp.com'
Subject: LaSalle AST

Per UFSAR Section 9.5.4.1.1 (Rev. 18), the usable diesel fuel volume required to support each Division 1 and 2 diesel generator continuous operation at rated load for 7 days is 32,200 gallons. Division 1 diesels will now be loaded above the continuous rating due to the load increase needed for the AST amendment. Provide a detailed discussion addressing how the EDG 7 day fuel supply requirement is satisfied as a result of this AST amendment.

Thank you,

Cameron

Mrs. Cameron Goodwin
Division of Operating Reactor Licensing
LaSalle Project Manager
Phone: (301)415-3719
Email: Cameron.Goodwin@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: LaSalle AST
Sent Date: 6/2/2010 3:12:02 PM
Received Date: 6/2/2010 3:13:00 PM
From: Goodwin, Cameron

Created By: Cameron.Goodwin@nrc.gov

Recipients:
ken.nicely@exeloncorp.com ('ken.nicely@exeloncorp.com')
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	10343	6/2/2010

Options
Expiration Date:
Priority: oImportanceNormal
ReplyRequested: True

Return Notification: False

Sensitivity: olNormal

Recipients received: