

AP1000DCDFileNPEm Resource

From: Loza, Paul G. [lozapg@westinghouse.com]
Sent: Tuesday, June 01, 2010 5:30 PM
To: Clark, Phyllis
Cc: Lindgren, Donald A.
Subject: Acknowledgement of RAI-SRP3.12-EMB1-09

Hi Phyllis,

I acknowledge receipt for Westinghouse of RAI-SRP3.12-EMB1-09, as follows:

TR-115, Rev.2 states that the HRHF exceeds the CSDRS for frequencies above about 15 HZ. The representative piping package consideration is based on high frequency participation as indicated in Section 6.3.1 of TR-115. The staff noted that the floor response spectra exceedances are in the region for frequencies around 6-12 Hz as shown in Figures 6.3.2.2.-1 thru 6.3.2.2-3. The analysis only addressed high frequency packages. However, Westinghouse fails to address all other piping and components packages related to the floor response spectra exceedances for frequencies around 6-12 Hz. The staff is requesting Westinghouse address all other piping packages for the floor response spectra exceedances around 6-12 Hz.

TR-115, Rev. 2 does not address support load increase due to the response spectra exceedance. The staff is requesting Westinghouse to address this issue.

Thanks,

Paul Loza

Hearing Identifier: AP1000_DCD_Review
Email Number: 399

Mail Envelope Properties (27265BDD489F164BAB98F1FFF6371972509816D8)

Subject: Acknowledgement of RAI-SRP3.12-EMB1-09
Sent Date: 6/1/2010 5:29:59 PM
Received Date: 6/1/2010 5:30:02 PM
From: Loza, Paul G.

Created By: lozapg@westinghouse.com

Recipients:
"Lindgren, Donald A." <lindg1da@westinghouse.com>
Tracking Status: None
"Clark, Phyllis" <Phyllis.Clark@nrc.gov>
Tracking Status: None

Post Office: SWEC9985.w-intra.net

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 1037 | 6/1/2010 5:30:02 PM |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: