

15

Power Reactor	Event Number: 43958
Facility: MCGUIRE Region: 2 State: NC Unit: [1] [2] [ ] RX Type: [1] W-4-LP,[2] W-4-LP NRC Notified By: TONY COOK HQ OPS Officer: HOWIE CROUCH	Notification Date: 02/04/2008 Notification Time: 11:44 [ET] Event Date: 02/04/2008 Event Time: 09:15 [EST] Last Update Date: 02/04/2008
Emergency Class: NON EMERGENCY 10 CFR Section: 50.72(b)(2)(xi) - OFFSITE NOTIFICATION	Person (Organization): BRIAN BONSER (R2 )

Unit	SCRAM Code	RX CRIT	Initial PWR	Initial RX Mode	Current PWR	Current RX Mode
1	N	Y	100	Power Operation	100	Power Operation
2	N	Y	100	Power Operation	100	Power Operation

**Event Text**

OFFSITE NOTIFICATION TO THE NORTH CAROLINA DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES

"A leak in the final holdup pond has resulted in a release of treated wastewater to the environment. North Carolina Department of Environment and Natural Resources [has] been notified."

The volume of the leak was approximately 100,000 gallons and the leak was to groundwater. The licensee has sampled the wastewater for tritium and determined that the activity was below reporting limits.

The licensee has notified the NRC Resident Inspector.

D-15