

Official Transcript of Proceedings  
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards  
Subcommittee on AP1000 - Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, February 3, 2010

Work Order No.: NRC-044

Pages 1-190

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 SUBCOMMITTEE ON AP1000 - OPEN SESSION

7 + + + + +

8 WEDNESDAY, FEBRUARY 3, 2010

9 + + + + +

10 ROCKVILLE, MARYLAND

11 The Subcommittee met at the Nuclear  
12 Regulatory Commission, Two White Flint North, Room  
13 T2B1, 11545 Rockville Pike, at 10:00 a.m., Harold Ray,  
14 Chairman, presiding.

15 SUBCOMMITTEE MEMBERS:

16 HAROLD B. RAY, Chair

17 SAID ABDEL-KHALIK

18 J. SAM ARMIJO

19 SANJOY BANERJEE

20 DENNIS C. BLEY

21 MARIO V. BONACA

22 CHARLES H. BROWN, JR.

23 MICHAEL T. RYAN

24 WILLIAM J. SHACK

25 JOHN W. STETKAR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## 1 CONSULTANTS TO THE SUBCOMMITTEE:

2 THOMAS S. KRESS

3 GRAHAM B. WALLIS

4  
5 NRC STAFF:

6 PETER WEN, Designated Federal Official

7 WEIDONG WANT

8 STEPHANIE COFFIN

9 DON HABIB

10 GENE HSII

11 MICHELLE HART

12 MARK CARUSO

13 MALCOLM PATTERSON

## 14 ALSO PRESENT:

15 EDDIE GRANT

16 WES SPARKMAN

17 ED CUMMINS

18 AMY AUGHTMAN

19 MARK WILLIAMS

20 ROB SISK

21 BOB HIRMANPOUR

22 BOB PRUNTY

23 JILL MONAHAN

24 TERRY SCHULTZ (via telephone)

25 DALE WISEMAN

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## TABLE OF CONTENTS

	<u>AGENDA ITEM</u>	<u>PAGE</u>
1		
2		
3	Opening Remarks and Objectives, Harold Ray	4
4	COL Chapter 13 - applicant	8
5	COL Chapter 13 - staff	14
6	COL Chapter 15 - applicant OPEN	22
7	COL Chapter 15 - staff OPEN	51
8	RTNSS Presentation OPEN	63
9	RCP Issues	
10	Discussion of Action Items	130
11	Upcoming ACRS Interactions	183
12	Committee Discussion	189
13	Adjourn	
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## P R O C E E D I N G S

Time: 9:59 a.m.

CHAIRMAN RAY: The meeting will now come to order. This is the second day of a two-day meeting of the AP1000 Reactor Subcommittee, a standing subcommittee that advises the Committee on reactor safeguard.

I am Harold Ray, Chairman of the Subcommittee. ACRS members in attendance are Mario Bonaca, Dennis Bley. We have John Stetkar, Sam Armijo, Bill Shack, and Charles Brown and Mike Ryan. We will be joined by Said Abdel-Khalik a little later in the morning, and perhaps one or two others.

We also have at the table with us ACRS Consultants Tom Kress and Graham Wallis. We have in the audience Professor -- doggone it, I did have it. I apologize. I am going to get this sooner or later.

MEMBER SHACK: He just came in.

CHAIRMAN RAY: Stovadimovic from Berkeley. He will be observing us and joining us at the table in a subsequent meeting. Also present: Peter Wen is the Designated Federal Official for this meeting, and he is joined by ACRS staff member Weidong Wang.

The purpose of this subcommittee meeting over this second day will be to continue with reviews and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussions concerning design control document 17 of  
2 the AP1000 Pressurized Water Reactor and standard  
3 contents of the Reference Combined Operating License  
4 Application. I emphasize those words, Standard  
5 Contents of the Reference Combined Operating License  
6 Application, because the site-specific contents will  
7 not be part of the agenda today.

8 We had a two-day AP1000 Subcommittee meetings in  
9 July, October and November of last year. Except for  
10 DCD Sections 3.7, 3.8 and Chapter 6, this February  
11 meeting will complete the initial reviews for the SER  
12 with open items for both the DCD and the Combined  
13 License reviews.

14 For that reason, I want to be particularly  
15 careful at the end of today's agenda to go over the  
16 action items. Weidong will provide us those. I guess  
17 Eileen from the staff may be the source, but in any  
18 event, we want to go over that to make sure that this  
19 initial review we have all the members' action items  
20 that remain open identified accurately.

21 During today's meeting we will hear  
22 presentations from the NRC staff, Westinghouse,  
23 Southern Nuclear Operating Company and NuStart. We  
24 have received no written comments or requests for time  
25 to make oral statements from members of the public

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regarding today's meeting.

2 We have a revised agenda as a result of one  
3 carryover item to today's agenda from yesterday that  
4 we weren't able to complete, despite the fact that we  
5 went until six o'clock. That item is -- I trust  
6 everyone has access to the revised agenda that we will  
7 be following today. It is Item 6.

8 That portion of the meeting will be closed, as  
9 indicated on the agenda, and the rules for a closed  
10 meeting I described yesterday, but they are that only  
11 NRC staff, applicants, and those who are contractually  
12 obligated to confidentiality with the applicants can  
13 attend during closed sessions of the meeting.

14 As I say, the agenda currently shows just that  
15 one item that is being taken up right after lunch as  
16 Closed Session.

17 All right. Well, in any event, agendas will  
18 continue to be revised as the need develops, I guess,  
19 and this last one acknowledges that we start at ten.

20  
21 I am told that our deferred start time was a  
22 benefit to at least one of our members who has not  
23 otherwise been able to get here on time. So I guess  
24 it was a good idea, but things have changed in a  
25 century since I lived here. It would have shut the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 town down back then, but it didn't seem to have that  
2 big an impact, the weather.

3 So the Subcommittee will gather information,  
4 analyze relevant issues of the facts, and formalize  
5 proposed positions and actions as appropriate for  
6 deliberation by the full Committee. Rules for  
7 participation in today's meeting have been announced  
8 as part of the notice of the meeting previously  
9 published in the Federal Register.

10 A transcript of the meeting is being kept and  
11 will be made available as stated in the Federal  
12 Register Notice. Therefore, we request that  
13 participants in this meeting use the microphones  
14 located here in the meeting room when addressing the  
15 Subcommittee. Participants should first identify  
16 themselves and speak with sufficient clarity and  
17 volume so that they may be readily heard.

18 With that, I believe we are ready to proceed.  
19 Eddie, you got the gavel, or who is in charge here of  
20 this segment?

21 MR. GRANT: I have the mouse, but Wes  
22 Sparkman with Southern Nuclear, I believe, is up.

23 CHAIRMAN RAY: All right. Very good.

24 MR. SPARKMAN: Good morning. Wes  
25 Sparkman. I am with Southern Nuclear, Vogtle 3&4

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Project. To my right is Bob Hirmanpour, and to my  
2 left is Eddie Grant. We also have Mark Williams from  
3 Westinghouse off to the right to help us out with any  
4 questions that the ACRS might have.

5 We are covering Chapter 13, again the standard  
6 portions: 13.1, organizational structure of  
7 applicant, plant specific, and we are not intending to  
8 go into any detail on that. We do intend to cover  
9 briefly 13.2, which is training; 13.4, operational  
10 programs; and 13.5, plant procedures. Next slide.

11 The DCD is incorporated by reference. There is  
12 only one standard departure taken, and that is for  
13 section numbering, which I believe you all probably  
14 have seen in previous chapters.

15 There are additional supplemental information  
16 items that are included in Chapter 13 beyond what is  
17 in the DCD and, because of that, some of the numbering  
18 has to change. Therefore, we have taken a departure.

19 The majority of the FSAR Chapter 13 is, as  
20 I said before, is plant specific, primarily  
21 organizational structure, things like that. The major  
22 supplemental information has to do with operational  
23 programs milestones, which are included in Table 13.4-  
24 201, and then COLD items. Next slide.

25 There are three standard COL items that we want

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to discuss this morning briefly. The first is 13.2-1,  
2 which is the training program for plant personnel.

3 FSAR Section 13.2 provides the training program  
4 description, and we are incorporating NEI 06-13A. I  
5 don't know if you have had a chance to look at that,  
6 but that defines what needs to be in our training  
7 program.

8 With respect to operational programs, COL item  
9 13.4-1, again we discussed earlier, or I said just a  
10 minute ago that FSAR Table 13.4-201 lists the  
11 operational programs that are required by the NRC  
12 regulations. If you look at that table, there is a  
13 column that describes what regulation requires that  
14 particular program, and then implementation  
15 milestones, either by regulation or by license  
16 condition.

17 MEMBER STETKAR: Can I ask you a question  
18 about the training programs?

19 MR. SPARKMAN: Sure.

20 MEMBER STETKAR: In 13.2, there is a  
21 statement that says operators involved in the human  
22 factors engineering verification and validation  
23 program receive additional specific training for the  
24 task of performing V&V.

25 That training and milestones are not listed in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the table. So I don't have any information about the  
2 schedule for either the training or the V&V process.  
3 Do you have any information about that training?

4 MR. SPARKMAN: In terms of schedule, I  
5 don't know that a specific schedule has been developed  
6 yet. I know that, like for instance, with the  
7 simulator, some people that are going to be involved  
8 with respect to validating the simulator will have  
9 some training prior to that. Eddie, do you have any  
10 specifics?

11 MEMBER STETKAR: This is in particular for  
12 the human factors engineering, which should be done  
13 well before the simulator is, in fact, constructed.

14 MR. GRANT: Yes.

15 MEMBER STETKAR: So I am a bit concerned  
16 about when that training will be performed.

17 MR. CUMMINS: Yes. This is Ed Cummins.  
18 First of all, the V&V is in the scope of Westinghouse.  
19 So we are doing the V&V of human factors. We have  
20 written a procedure, and actually we are redoing it  
21 with the staff right as we speak, because it is part  
22 of one of the design acceptance criteria that we are  
23 trying to close.

24 The training is done for operating crews  
25 who come from customers. The customers provide

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operating crews, and we give them a short amount of  
2 training on the AP1000 specific and the control room  
3 methods. Then we use them as test subjects, and we  
4 have three or four crews go through, and we measure, I  
5 think the procedure says, three times for each even,  
6 and then you record information of errors or  
7 improvements as you go through.

8 That whole process is just about getting  
9 ready to start. It is in the next few months that we  
10 are going to start that process.

11 MEMBER STETKAR: Do you have arrangements  
12 in place to get operating crews from Southern?

13 MR. CUMMINS: We do. We are still  
14 refining the details on it a little bit, but yes.

15 MEMBER STETKAR: Okay, that helps.  
16 Thanks.

17 MEMBER BLEY: And the DAC will be closed  
18 as part of the design cert?

19 MR. CUMMINS: The V&V DAC will not be, but  
20 the planning of the V&V DAC will be.

21 CHAIRMAN RAY: Ed, when you said it is  
22 within Westinghouse scope, did you mean to say it is  
23 part of a DCD or just that it is work that is being  
24 done by Westinghouse for its COL licensing customers?

25 MR. CUMMINS: I think the V&V DAC will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 remain a DAC, because it is an extensive program. So  
2 it is Westinghouse's responsibility to close that DAC  
3 and get whatever inspection, the process that occurs  
4 from the staff, to close the V&V DAC on human factors.

5 The responsibility is really between us  
6 and our customers, I suppose, but they would expect to  
7 get a control room that has been verified.

8 CHAIRMAN RAY: I am just trying to figure  
9 out whether the requirements that are being met are  
10 part of the COL and part of the DCD.

11 MR. CUMMINS: It isn't part of the  
12 certified design or part of the COL. It will be part  
13 of a post-inspection, a DAC inspection.

14 CHAIRMAN RAY: Which are DAC. The DAC are  
15 in the COL, though.

16 MR. GRANT: The answer is yes. The work  
17 will be done by Westinghouse. It will be closed on  
18 the docket of the particular license.

19 CHAIRMAN RAY: That is the answer I was  
20 trying to get to. In the COL license?

21 MR. GRANT: It will come from Vogtle to  
22 say here is the closure package for the DAC.

23 CHAIRMAN RAY: Right. And whether you get  
24 it from Westinghouse or somebody else is your  
25 business.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GRANT: Irrelevant.

2 CHAIRMAN RAY: Okay. Go ahead.

3 MR. SPARKMAN: All right. I think we have  
4 covered operational programs, and 13.5-1 of plant  
5 procedures: FSAR 13.5 describes a variety of  
6 different procedures, administrative, other procedures  
7 used to conduct routine operating, abnormal, and  
8 emergency activities in a safe manner. We have a  
9 discussion of that in Chapter 13.5, and we will be  
10 producing those procedures as they become necessary,  
11 if you have any other questions about the procedures.

12 All the open items are plant specific.  
13 There are no standard open items associated with  
14 Chapter 13.

15 CHAIRMAN RAY: Okay, good. Terse, to the  
16 point. Any questions from any members or consultants?

17 MEMBER ARMIJO: We are not going to  
18 discuss anything about 13-6, Security, in this  
19 meeting?

20 CHAIRMAN RAY: That was my understanding,  
21 but--

22 MR. GRANT: Eddie Grant with NuStart. We  
23 don't actually have an SER for those two sections yet.

24 There is a short section, but it is basically an open  
25 item that says the SER on those topics comes later.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: I think you told us  
2 yesterday we would be discussing that at a subsequent  
3 meeting. Is that right?

4 MS. COFFIN: Yes. the first time this  
5 Subcommittee will see the security views for the  
6 AP1000 COL applicants will be in our Phase 5 for the  
7 Vogtle --

8 CHAIRMAN RAY: It will be site specific.

9 MS. COFFIN: It will be site specific.

10 CHAIRMAN RAY: All right. Now Amy  
11 approached me yesterday and said that there was a  
12 response to Member Stetkar's question that was  
13 available for review. Is this a good time to look at  
14 it?

15 MR. GRANT: Certainly.

16 MS. AUGHTMAN: Well, if we could hold  
17 until Chapter 15.

18 CHAIRMAN RAY: All right, Chapter 15 it  
19 is. Fine. Thank you.

20 MR. GRANT: Thank you.

21 CHAIRMAN RAY: Okay, staff.

22 MS. McGOVERN: Good morning. I am Denise  
23 McGovern, the Chapter 13 Project Manager for the  
24 AP1000 Combined Operating License applications. With  
25 me today from the Division of Construction Inspection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Programs is Jim Kellum, the lead reviewer for Sections  
2 13.1, 13.2, and 13.5. He is with the Operator  
3 Licensing and Human Performance Branch. He will be  
4 going over the standard content for 13.2, training,  
5 and 13.5, plant procedures. Then I will cover 13.4,  
6 Operational Programs.

7 CHAIRMAN RAY: Very good.

8 MR. KELLUM: As Denise had said, my name  
9 is Jim Kellum. I am from NRO, and I am here to talk  
10 about the Chapter 13, Sections 1, 2 and 5. I have  
11 actually presented this information previously to this  
12 committee several months ago for another one, and I am  
13 not going to really provide any additional or  
14 different information than what was provided at the  
15 previous time we presented this.

16 CHAIRMAN RAY: Feel free to just whiz  
17 right through it then.

18 MR. KELLUM: Thank you. Like I said, we  
19 are talking about Sections 13.1, 13.2 and 13.5. 13.1  
20 is the organizational structure of the applicant, and  
21 that is going to be plant specific, and what we have  
22 seen from the COLs that have been submitted, they all  
23 provide a table that outlines the personnel, the  
24 qualifications, etcetera, and in accordance with the  
25 ANSI 3.1, which is the selection, training, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 qualification of plant personnel and the subsequent  
2 Reg Guide 1.8.

3 So moving on to Section 13.2, which is  
4 training, that is incorporated by reference, and 13.2  
5 -- Largely, what that will follow, it also  
6 incorporates by reference NEI 06-13A Rev. 1, which is  
7 the template for an industry training program.

8 Now that template -- or the Rev. 1 change  
9 -- I don't know if you saw Rev 0, Rev. 1. the big  
10 change in Rev 1 was Rev 1 adds the cold license  
11 process. That was one thing that was lacking from the  
12 original revision.

13 So there is an Appendix A that discusses  
14 all the cold licensing, since, obviously, nobody has  
15 been licensed on this type plant before, and it goes  
16 through the qualifications that are going to be  
17 required for ROs, SROs, etcetera, and experience  
18 requirements and so forth.

19 06-13A: In that description, it  
20 incorporates all the things from 10 CFR 120, the  
21 personnel that are required for plant operation, and  
22 not just operators. It lists numerous positions that  
23 training is required, not only the ROs, SROs, STAs,  
24 but also things like chem techs, rad techs,  
25 engineering training. All that isn't covered in 06-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 13A.

2 In addition, it also covers things like  
3 general employee training and so forth, fire  
4 protection training. That is all encompassed in 06-  
5 13, and it is all based on -- or requires the  
6 systematic approach to training, and it also  
7 incorporates OE, TMI action plans. All that is  
8 incorporated into 06-13A.

9 So it is a complete template for a  
10 training program and, if an applicant follows that,  
11 then it will meet the requirements that we are looking  
12 for in that training program.

13 On to 13.5-1: Again, that is plant  
14 procedures, and as the applicant had said, that is  
15 going to consist of administrative and operating  
16 procedures. The operating procedures that are laid  
17 out in the standard review plan 0800, 13.5.1.1 and  
18 2.1.

19 It talks about normal ops procedures,  
20 abnormal ops, EOPs, alarm procedures, etcetera,  
21 etcetera. What we are seeing is in the applications  
22 it is including all those procedures as well as the  
23 administrative procedures where the standard review  
24 plan for that, 13.5.2.1 has Category A, Category B,  
25 administrative procedures.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Those Category A procedures are things  
2 like controls such as control of procedures, temporary  
3 mods, those type things, and Category B is  
4 administrative like the shift supervisor night orders  
5 and turnover procedures, etcetera. So all those admin  
6 procedures, all those operating procedures are all  
7 listed in the COL that are the criteria from the  
8 standard review plan, NUREG-0800.

9           MEMBER BLEY: When you actually have the  
10 procedures -- you may have them -- have you thought  
11 about the extent to which you are going to examine the  
12 EOPs that are based on the -- the automated ones that  
13 come with the --

14           MR. KELLUM: You mean the generic? Are  
15 you talking about the ones from the vendor? Oh, okay,  
16 you are talking about the computer based procedures?

17           MEMBER BLEY: Yes, that were a part of  
18 this.

19           MR. KELLUM: That inspection program  
20 hasn't been written yet, but one thing we put in the  
21 SER for that is that review of procedures will be part  
22 of the procedures construction program. As far as for  
23 the time when the procedures are required, the  
24 standard review plan says that the procedures will be  
25 available in adequate time, not only to train the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operators but also to be in use in preparation for  
2 developing NRC administrator exams, etcetera.

3 MEMBER BLEY: So it has got to be like at  
4 least a year before?

5 MR. KELLUM: Yes, even more so.

6 MEMBER BLEY: But you will be writing that  
7 inspection procedure. Somebody will be writing it?

8 MR. KELLUM: Yes. Thanks.

9 MR. WILLIAMS: Hi. I am Mark Williams  
10 with Westinghouse. Just to help address your inquiry  
11 a little bit more with respect to the status of the  
12 emergency operating procedures and the abnormal  
13 operating procedures, we are preparing those. In  
14 fact, we have revisions of the EOPs now developed, and  
15 we are going to ensure that we have those developed to  
16 support the integrated systems validation testing,  
17 which will occur -- right now it is scheduled to occur  
18 in fall of 2011.

19 So we actually have revisions of those  
20 particular developed now, and we get the input from  
21 the customers from the other group and CO and  
22 applicants who review these procedures and provide  
23 comments on them, which we incorporate into subsequent  
24 revisions.

25 MEMBER BLEY: One thing I don't remember

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from our visit up there. In the control room with the  
2 automated procedures, will the EOPs be incorporated in  
3 the computer version for the operators?

4 MR. WILLIAMS; Mark Williams from  
5 Westinghouse. Yes. The computer has a procedure  
6 system right now for the combined operating license  
7 applicants in the U.S. It includes all the EOPs and  
8 all the AOPs. So they are both included in the  
9 computerized procedure system.

10 MEMBER BLEY: Thanks.

11 CHAIRMAN RAY: You had one other section?

12 MS. McGOVERN: We do have one other  
13 section. 13.4 is incorporated by reference for the  
14 AP1000 DCD. The standard content is the table of  
15 operational programs required by NRC regulations, as  
16 outlined in Reg Guide 1.206 and SECY paper guidance  
17 05-0197.

18 There is no site-specific content. The  
19 programs are site-specific, but the table is standard.

20 The table addresses what operational  
21 programs are required and their implementation  
22 milestones. Operational program implementation not  
23 addressed in regulation: That is when the milestone  
24 is not addressed in regulation, it is covered by  
25 license condition 3, and the timing of information

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 related to operational programs for inspection  
2 activities is license condition 6. Again, that is  
3 when it is not prescribed in the regulation when that  
4 milestone is.

5 This is an example from staff's SER of how  
6 we cross-reference the table given to us in the SAR.  
7 The one thing that is different, what we did is we  
8 covered where the programs are actually -- Where it  
9 says SER Section(s), that is where the programs  
10 themselves are reviewed, so that you can cross-  
11 reference where the program is, and then which NRC  
12 staff group reviewed the SER section that contained  
13 the program.

14 That's it.

15 MEMBER BLEY: Jim, I would like to ask  
16 you another question, going back to the Tier 1  
17 documents that have all the DAC. That said a number  
18 of those are being deleted in the current revision.

19 When you folks reviewed that, do you just  
20 look at the new material and including no DAC with it  
21 or do you take those DAC and play those against the  
22 new material to see how they have been satisfied?

23 MS. KELLUM: I am not sure I follow your  
24 question.

25 MEMBER BLEY: In some of the human factors

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 area and in some of the operator areas, there were  
2 DAC, and some of those are being cleared as part of  
3 Rev 17, in general for everybody. What I am wondering  
4 is --

5 MR. KELLUM: All the training stuff is  
6 tiered, too.

7 MEMBER BLEY: Yes, okay. I thought you  
8 were talking about some of the others, too. Never  
9 mind. I will ask somebody else. Thanks. I will drop  
10 that.

11 CHAIRMAN RAY: Any other questions? Thank  
12 you. All right. So we have made up a half-hour  
13 already. That is a good sign, and we are ready to  
14 take up Chapter 15, beginning with the applicant.

15 Before you begin, Rob, if we have time  
16 before lunch, are you prepared to close the meeting  
17 and do the gas accumulation?

18 MR. SISK: Yes, sir. Our people are in  
19 the cafeteria right now. I just need 10 minutes to  
20 let them know when to come up.

21 CHAIRMAN RAY: That is fine. Said won't  
22 be with us until eleven o'clock at least. So I am  
23 just trying to look ahead.

24 MR. SISK: Do you want to plan for around  
25 eleven?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Well, I don't want to  
2 constrain the time for this segment; something like  
3 that, yes.

4 MR. GRANT: Thirty minutes will not  
5 constrain the time for this presentation, unless you  
6 guys have a lot of questions about not much  
7 information.

8 CHAIRMAN RAY: All right, fine. Proceed.

9 MS. AUGHTMAN: All right. So Amy Aughtman  
10 again from Southern, and with me here to cover 15 is  
11 Eddie Grant, and additionally we've got some  
12 Westinghouse support, if necessary. Hopefully, this  
13 should be pretty quick. Eddie.

14 MR. GRANT: All right. The usual list of  
15 standard -- or actually, the topics for Chapter 15,  
16 the usual information there. You will see that none  
17 of those are in blue, because as it indicates here, we  
18 basically incorporate by reference the DCD. We have  
19 taken no standard departures. Almost all of the  
20 information is IDR. There is no supplemental  
21 information that is standard.

22 There are no standard COL items for this  
23 particular topic, except that recently Westinghouse  
24 did identify a new COL item in response to one of  
25 their RAIs. That was identified as an open item in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our SER. However, as we have heard already yesterday  
2 from Westinghouse, they are reconsidering their  
3 original response, and it looks like there is likely  
4 to be an ITAAC in lieu of this COL item. So we are  
5 holding off on our response on it until we find out  
6 exactly what that response is going to say.

7 We anticipate an ITAAC and that the COLD  
8 item will go away, which will take care of our open  
9 item.

10 The open item 15.4-1 was a simple  
11 administration item to reinsert a reference to a  
12 Generic Letter related to boron dilution. We have  
13 removed it, because we thought all the information was  
14 covered by the DCD. Turns out the staff references  
15 that in 13.5 in relation to some of the procedures and  
16 asked us to put that back into the table in Chapter 1.

17 So we have reinserted that reference, again no  
18 technical information there, just a cross-reference.

19 That pretty much covers it. Any  
20 questions?

21 CHAIRMAN RAY: Well, we you predicted,  
22 this is something where the meat of the subject is  
23 expected to be in the DCD and not the COL.

24 MR. GRANT: Absolutely. Safety analysis  
25 is not something the applicant does a lot of.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Any questions or comments  
2 on the part of the members?

3 MR. SISK: Mr. Chairman, just as a follow-  
4 up from yesterday's meeting in regard to the  
5 uncertainties on the instrumentation, we did follow up  
6 over the night. We could either discuss that now or  
7 later on, if you would like to hear a little bit about  
8 the data on the uncertainty in the calorimetrics and  
9 the transmitter.

10 CHAIRMAN RAY: Well, Said will need to be  
11 here for that, and so he is currently meeting with the  
12 Chairman. So I expect him back here around eleven  
13 o'clock.

14 Now -- Yes, go ahead, John. I am not  
15 trying to fill time, but just go ahead.

16 MEMBER STETKAR: I can fill time. Eddie,  
17 did I understand you to say that concerns about the --  
18 Let me ask it a different way.

19 How does the site specific accident  
20 analysis account for dose to second-unit operators or  
21 effect on second-unit operators from an accident at  
22 one unit? Let's say Unit 3 versus Unit 4, which would  
23 be a site-specific unit configuration pathway  
24 analysis. that is not covered by the DCD, is it?

25 MR. GRANT: That is correct. It is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 covered by the DCD.

2 MEMBER STETKAR: Does that come under the  
3 auspices of the Chapter 15 analyses?

4 MR. GRANT: Not really. There is an  
5 aspect of it. The site-specific piece that we didn't  
6 talk about in Chapter 15 that we do provide some  
7 supplemental information for is to confirm that the  
8 chi over q dose dispersion factors are within or  
9 bounded by the generic dispersion factors, and we have  
10 all done that. We made sure -- We asked them to  
11 revise them, in fact, a time or two so that we made  
12 sure that we were all bounded, but we are bounded, and  
13 that is confirmed.

14 So when you look at the accident analysis  
15 for Unit 4, for instance, and the effect on the Unit 4  
16 operators, there is actually a bounding analysis for  
17 the effect on the Unit 3 operators, because they are  
18 further away.

19 So we cover that in Chapter 6, actually,  
20 not Chapter 15, which is where we cover control room  
21 habitability and the events there. We did have a  
22 section on that in our FSARs that addressed the dual  
23 unit impacts due to both toxic chemicals and, of  
24 course, accident analysis to indicate that second unit  
25 is acceptable or has acceptable doses.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Thanks.

2 MEMBER SHACK: Just a quick question from  
3 yesterday. There was discussion of chi over q. As I  
4 read through the literature, the chi over q values  
5 seem to be roaming around, and then there was some  
6 statement yesterday about changing chi over q back to  
7 what was the DCD 15 value.

8 Will the 17 have a value that will be  
9 bounding for all these sites?

10 MR. CUMMINS: This is Ed Cummins. This  
11 was related to this impaction thing that basically the  
12 staff didn't think that we had enough time to justify  
13 that. Then there was a period o f--

14 MEMBER SHACK: I was looking forward to  
15 Dr. Powers' comments on that impaction.

16 MR. CUMMINS: So we decided that time was  
17 more important. So we have them in 15. We tried to  
18 take advantage of impaction in Rev. 16 and 17. We put  
19 it back to Rev. 15.

20 Does any site have some issues with that?

21 There are at least one site, the TVA site, where they  
22 have to do something, and I think it is probably not  
23 appropriate for me to say what they plan to do,  
24 because that is a site-specific thing. They can buy  
25 land or other things that would achieve an acceptable

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 solution.

2 MEMBER SHACK: So even with your new  
3 ventilation system for the control habitability, you  
4 are still going to need that chi over q value, the way  
5 you have it set up in 15?

6 MR. CUMMINS: Well, there are different  
7 chi over qs for the control room and the off-site  
8 dose, and one is more local, and one is more global.  
9 So they are unrelated.

10 For the control room, all of the sites are  
11 acceptable. For the site boundary, it depends on the  
12 distance to the boundary and, obviously, the weather  
13 conditions.

14 MS. COFFIN: Dr. Shack, in our Chapter 15  
15 for Bellefonte, we discussed Bellefonte's exemption  
16 request and how they approached this issue for that  
17 particular site.

18 MEMBER SHACK: I was more concerned about  
19 it in terms of the habitability, since that is going  
20 to affect everybody.

21 MR. GRANT: As he said, we are bounded for  
22 the control room.

23 CHAIRMAN RAY: Anything else on Chapter 15  
24 Standard Content? Hearing nothing, Amy, now do you  
25 want to respond on Chapter 9?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. AUGHTMAN: Yes, sir. If everyone is  
2 agreeable, Member Stetkar, we have a response prepared  
3 for your questions regarding Chapter 9 yesterday.  
4 Bear with us a minute as we pull that up.

5 I guess, just to quickly recap the  
6 question from yesterday, it is with respect to the  
7 FSAR table 9.5-201. So with me to help address that  
8 is Bob Hirmanpour and, if necessary Bob Prunty from  
9 Bechtel.

10 We went back and looked at some of the  
11 details on the questions that you raised yesterday,  
12 and we pulled a few slides together to try to help  
13 illustrate how everything fits together and is  
14 organized.

15 So we pulled the relevant excerpts from  
16 the guidance document, from the Branch Technical  
17 Position, and then we will show the DCD table and how  
18 that was set up, and then our FSAR table, and then  
19 where the resolution actually is for that.

20 MEMBER STETKAR: Okay, good.

21 MS. AUGHTMAN: So I am going to let Bob  
22 Hirmanpour step you through.

23 MR. HIRMANPOUR: Good morning. Bob  
24 Hirmanpour from NuStart Energy.

25 If I understood, actually, you had two

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions: Why is that response standard, if you are  
2 referring to plant specific items; and second, what is  
3 the analysis behind the justification?

4 MEMBER STETKAR: Yes, the justification  
5 for credibility. Right.

6 MR. HIRMANPOUR: Basically, the Branch  
7 Technical Position, CMEP 9.51, and that is the old  
8 BTP. That is the actual wording that is in the BTP.  
9 What is important on here is two things.

10 First of all, shared systems; second of  
11 all is man-made, man-made events. They are looking at  
12 the reasonable probability of occurring and affecting  
13 two units, as far as that is important to know that,  
14 because then the provider responded and used a word  
15 like unlikely. So go to the next slide.

16 So basically, what Westinghouse did, they  
17 tried to address the BTP and the DCD and a couple of  
18 the items, including 15 and 22. What they provided is  
19 that there are some site-specific elements that may  
20 impact that, because we are looking at external  
21 events. We are looking at fires with the industrial  
22 event or a jungle.

23 So what they provided is the remarks  
24 column that says this is going to be a site-specific  
25 basis. So, basically, you have to go to individual

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 FSAR to see how their site is set up. Go to the next  
2 slide.

3 Basically, what we did, we tried to  
4 provide that response. So we duplicated the DCD  
5 entry, and we provided a response here. We had  
6 provided references to the Section 2.2 and 3.5. Those  
7 are the sections of the FSAR that covers 2.2 mainly,  
8 the fires, including man-made fires. Could be an  
9 accident jungle.

10 It depends again on the site location.  
11 Some sites, they talk about the forest. Some site may  
12 talk about barges and airplanes. So it depends where  
13 you are located and your site boundaries and the  
14 potential accidents that could happen in that area.  
15 Those are covered in Section 2.2 and 3.5.

16 Overall, we had concluded that the  
17 response is probably going to be the same for all the  
18 plants, regardless of their situation. So we made  
19 that section of the FSAR a standard response.

20 Now if any site -- Again, when they  
21 prepared their COLA, they have to look at the standard  
22 content and, if they cannot meet those requirements,  
23 then they have to change that, and so far we haven't  
24 seen anything that says it is otherwise.

25 MEMBER BROWN: Can you go back to that?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Why do your quotes, the remarks, differ from the table  
2 itself and --

3 MR. HIRMANPOUR: From the DCD?

4 MEMBER BROWN: Yes, the different  
5 subsection, with 2.2.3 as opposed to -- I don't know  
6 if that means anything or not. It is just that you had  
7 different information here than you had in the FSAR.  
8 That is all.

9 MR. HIRMANPOUR: FSAR has the section 2.2  
10 that covers a range of fires, and some of them may be  
11 potential man-made. Some of them not so. I'll  
12 provide a couple of examples to show you how actually  
13 we are cover the fire aspect of it and impact on the  
14 fire protection system, but those are plant-specific,  
15 but we will give you some of those examples.

16 MS. AUGHTMAN: I think his question is  
17 probably that in the SER --

18 MEMBER BROWN: The excerpt is different  
19 from what is in the SER.

20 MS. AUGHTMAN: -- it refers to 2.2.3.

21 MEMBER BROWN: Yes. I didn't know whether  
22 there was some difference. That's all.

23 MS. AUGHTMAN: And for the Vogle  
24 application, we ended up having to truncate that last  
25 little subsection, because there's some ESP

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 references, and to make sure we included the broader  
2 section of relevant information.

3 MR. GRANT: In order to make sure that  
4 that stayed standard, we probably should have gone  
5 back to Bellefonte and truncated at 3 as well. I  
6 would admit to that as being an oversight on my part,  
7 but we will see if we can correct that so that it is  
8 indeed standard across the board.

9 MR. HIRMANPOUR: Did we answer the  
10 question of standard, as far as where we can find the  
11 information?

12 MEMBER STETKAR: I am following you where  
13 I can conceivably find the information.

14 MR. HIRMANPOUR: Okay. And again now, we  
15 have a couple of slides just specific examples.

16 MS. AUGHTMAN: Yes. So this is just one  
17 example of a section that would cover this type of  
18 event. In the FSAR 2.2.3.3.2, we have a fire due to  
19 an accident in an offsite industrial storage facility.  
20 So we are touching on site-specific information here,  
21 but I thought it would help to illustrate how the  
22 standard content was addressed in Chapter 9.

23 At Vogtle, in particular, we have a  
24 combustion turbine plant located adjacent to our site,  
25 and so we have performed an evaluation on Plant Wilson

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and did determine that it would not have an impact on  
2 the control room habitability or cause thermal damage  
3 to safety related structures at Units 3 and 4.

4 Now that evaluation was actually done for  
5 Units 1 and 2, but we basically extrapolated that  
6 evaluation for 3 and 4, because those units are  
7 located further from the Plant Wilson than even 1 and  
8 2 are.

9 So that is why we make the statement -- I  
10 just want to go back -- that we don't believe that  
11 those events are credible.

12 MEMBER STETKAR: Well, that is one example  
13 of one event that is very specific to the Vogtle site.

14 I don't see a similar evaluation of other events that  
15 might be specific to the Vogtle site or a generic  
16 evaluation of generic events that might be applicable  
17 to any site.

18 In my life, I have come across a site that  
19 had a very large natural gas pipeline routed near it,  
20 and it is pretty difficult to justify that a large gas  
21 explosion could not affect multiple units at the site.

22 Again a very site-specific configuration.

23 MS. AUGHTMAN: Right.

24 MEMBER STETKAR: And in fact, quite a bit  
25 of analysis had to be done to justify some frequency

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of impact from those explosions. So just a blanket  
2 statement in a standard COL table that applies to all  
3 COL applicants that any event is incredible sounds --

4 MS. AUGHTMAN: That is what I want to  
5 clarify.

6 MEMBER STETKAR: -- sounds a little bit of  
7 a stretch.

8 MS. AUGHTMAN: That is why I would like to  
9 clarify. When we did define standard content, it was  
10 basically if the reference COL applicant plus one or  
11 more other COL applicants could say the same thing,  
12 then we designated it as standard.

13 So if a site could not say these words,  
14 that if they, in fact, had an event, like you are  
15 suggesting, that would say they would need to add  
16 additional information here, they would then come in  
17 and annotate that piece of the table as site-specific.

18 But they have the ability to change --

19 MEMBER BLEY: I guess this might be more  
20 for the staff than for you. It just strikes me, too,  
21 that things that are standard content ought to be  
22 things that can be shown to be true in a general way.

23 That they are true at two or three sites  
24 doesn't in any way imply they are true everywhere, and  
25 once it is in the standard content, it gets easier for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the next reviewer not to look hard enough to see if it  
2 is really true at this site. So it is a little  
3 disturbing to see it as standard content, I guess. So  
4 I agree with Mr. Stetkar.

5 MR. HIRMANPOUR: Let me add one more  
6 thing. Remember, I said conclusion standard. Again,  
7 we do refer to site-specific. You have to go to site  
8 specifics, and those sections also talk about external  
9 hazards, and each site has already done an external  
10 hazard analysis that supports those statements.

11 So each site went back, and we had cases  
12 we have pipelines, gas pipelines, close to the sites.

13 So we did extensive review of those external hazard  
14 analyses, and also that was factored into the PRA.

15 MEMBER STETKAR: Are those -- Okay, but  
16 this isn't PRA. This is -- Are those analyses to  
17 justify the frequency and consequences which are,  
18 obviously, PRA terms documented in the respective  
19 sections of those COL FSARs. So I could go to that  
20 section.

21 For example, you showed a qualitative  
22 analysis for Plant Wilson -- potential fires at Plant  
23 Wilson's effect on Units 3 and 4, a qualitative  
24 analysis, but some justification. For other sites  
25 where perhaps a more detailed quantitative analysis

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was required to justify this incredibility, are those  
2 analyses documented in the appropriate sections of  
3 either -- let's just say Section 2 or Section 3 of the  
4 FSAR?

5 MR. HIRMANPOUR: I will have to ask Vogle  
6 for specifics.

7 MEMBER STETKAR: Because, see, the  
8 criteria say a reasonable probability, which is  
9 obviously a somewhat nebulous term. So stating that  
10 something is not credible is also a somewhat nebulous  
11 term. So we are talking about comparative frequencies  
12 here. It could be very site-specific and could indeed  
13 require some analysis and review.

14 MR. HIRMANPOUR: Also, the reasonable  
15 probability has to do with the event itself occurring  
16 and the effect.

17 MEMBER STETKAR: That is right. I said  
18 frequency and consequences.

19 MR. HIRMANPOUR: By default, the AP1000  
20 doesn't have shared systems. So this is less  
21 applicable in the AP1000 world than some of the older  
22 plants that may have a common instrument air system or  
23 something.

24 MEMBER STETKAR: Sure. Sure, that is  
25 true. That is true. You are not susceptible to as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 many of those types of events.

2 MR. HIRMANPOUR: Right.

3 MR. PRUNTY: This is Bob Prunty with  
4 Bechtel, representing Southern Nuclear. Let me start  
5 by saying that the reason that we referenced 2.2 is  
6 because 2.2 is where the discussion of all of these  
7 sorts of events comes.

8 In the instance that you brought about  
9 pipelines, pipelines are mentioned in 2.2. The  
10 nearest pipeline at Vogtle happens to be greater than  
11 10 miles away. It is not evaluated as any potential  
12 impact to the plant based on the regulatory guidance  
13 right now. So that was not further evaluated in the  
14 consequences section.

15 For 2.2.3, we have a close proximity of an  
16 oil burning plant, and just to make it clear, the Unit  
17 1 and 2 evaluation of that that we referenced is a  
18 very formalized calc. It looks at smoke particulate  
19 and heat flux and all sorts of things. We were able  
20 to utilize that calculation and make it applicable.  
21 That is the qualitative piece.

22 We didn't just qualitatively say, well,  
23 since it is this far away, it must be a problem. We  
24 looked at how that calc was treated with the existing  
25 units and the conclusions they drew, and then we said

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we are further away; therefore, that calc is  
2 applicable to us, but it was not just a qualitative  
3 basis.

4 That was true for analyzing all the off-  
5 site related events, railcars, truck accidents, any of  
6 that sort of thing, and where there were criteria met  
7 like being with inside five miles and transportation  
8 accidents, there were quantitative calculations done,  
9 but they are all addressed individually in individual  
10 subsections within 2.2. So there is not --

11 MEMBER STETKAR: Sure. No, I understand.

12 MR. PRUNTY: -- a blanket statement. It  
13 depends on the existing plant and what threats there  
14 may be to that particular plant. But we used  
15 quantitative calculation methods for all the things  
16 that were inside the selection criteria of either five  
17 miles or 10 miles or whatever it happened to be.

18 MEMBER STETKAR: That is really good. I  
19 am glad to hear that.

20 MR. PRUNTY: This was just picked out as  
21 just one example of that kind of statement. Granted,  
22 it did not use the word credible, but it said it would  
23 have no impact, and we used that phrase, no impact, in  
24 other venues as we were talking about the different  
25 events.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR:     I am not necessarily  
2 looking for a six-significant figure frequency  
3 analysis, but I am looking for some technical  
4 justification. It sounds like that is well in hand  
5 for Plant Vogtle.

6           I am still a bit concerned about all of  
7 that analysis being folded over into justification of  
8 a standard COL item to simply say it is not credible.

9           MR. GRANT:     It does not. Let me address  
10 that. Eddie Grant again with NuStart.

11           It sounds like there might be a little bit  
12 of confusion about what standard means. It is not  
13 like the DCD. The DCD is generic information that is  
14 absolutely applicable across the board unless you have  
15 taken a departure. So it applies to all the AP1000s.

16           A piece of information identified as  
17 standard in a particular COL does not mean that  
18 applies to all seven of the AP1000 COLs. That means  
19 it is standard information being reviewed as standard  
20 on the reference COLA and, if it is so designated in  
21 an S-COLA as standard, it will get the same review or  
22 it won't need to be reviewed again. But it is up to  
23 each S-COLA to verify the information is indeed  
24 standard for their S-COLA, and it is up to the staff,  
25 as we heard suggested, to confirm that the standard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information was standard in the R-COLA and that, if it  
2 is not standard, if it is designated as site-specific,  
3 as Amy indicated it could be, instead of a departure -  
4 - You don't have to take a departure from standard  
5 information in an S-COL. You only have to identify it  
6 as site-specific.

7 That keys to the staff to do a site-  
8 specific review on that piece of information. So it  
9 is different than the DCD being generically  
10 applicable. It means it is standard and gets a  
11 standard review such that, if it is standard in an S-  
12 COLA, it doesn't need to be reviewed again.

13 CHAIRMAN RAY: Well, Eddie, that is very  
14 helpful. You must agree, though, that it is  
15 sophisticated.

16 MR. GRANT: It is. It is, and I apologize  
17 that we haven't made that clear in the past.

18 MEMBER STETKAR: I would ask the staff, is  
19 that -- It seems it makes the staff's life rather  
20 difficult, because the staff then has to examine in  
21 every S-COLA every item that is marked standard and  
22 essentially ask themselves is there anything that I  
23 know about this site that would make this non-standard  
24 for this site that has not been designated as site-  
25 specific.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           There's all of those double negatives  
2 thinking about omission.

3           MR. GRANT: Actually, it is the other way  
4 around. They need to confirm that they do a review on  
5 all the information that is site-specific, and confirm  
6 that each piece of standard information was indeed  
7 standard in the reference COLA.

8           CHAIRMAN RAY: You are both saying the  
9 same thing. Let the staff respond to John.

10          MS. COFFIN: I guess I would like to make  
11 two points. One is that the subsection 2.2 and 3.5  
12 that refer to this table, each COL has their own site-  
13 specific analysis, and the staff will review and  
14 evaluate those conclusions in Chapter 2 of our safety  
15 evaluation report.

16          So there is no generic analyses. At  
17 least, I am not aware of any generic analyses that  
18 covers them. So each site will be evaluated in terms  
19 of its manmade hazards. That is part of our standard  
20 review plan. That is standard.

21          I think simply this conclusion for this  
22 set of groups happens to have come to the same happy  
23 conclusion, but the analysis that supports it are all  
24 site-specific, and they are evaluated by the staff on  
25 a site-specific basis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That helps, and as long  
2 as the reviews are being done on a site-specific basis  
3 for essentially the scope of analyses that would feed  
4 into this conclusion, then this simple conclusion out  
5 of context is probably covered.

6 MS. COFFIN: Right. The second point that  
7 I wanted to talk about is, as the staff is looking at  
8 a site-specific COL, one of our primary review  
9 activities is to not just accept standard content at  
10 face value, but to rigorously ask ourselves a  
11 question: Are there any site-specific things that we  
12 should question the applicability of this being  
13 standard?

14 MEMBER STETKAR: But that is -- You have  
15 to admit, that is different and difficult to do,  
16 especially -- You spend a lot of effort.

17 MS. COFFIN: It is not trivial, but I  
18 would like to give credit to the applicants. I think  
19 they do a very good job in terms of defining what is  
20 standard and what is site-specific, and there were  
21 times where we didn't agree, and we came to some  
22 resolution.

23 MEMBER STETKAR: I think what Dennis and I  
24 are saying is that, if these two particular entries  
25 labeled 15 and 22 in this particular table had a site-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specific annotation in the lefthand column rather than  
2 just a blanket standard annotation for the whole  
3 table, it would seem to make everyone's life a lot  
4 easier.

5 If indeed every site could justify that  
6 it was not credible based on their own plant's site-  
7 specific analyses, well, so be it. If they couldn't,  
8 well, it is a flag that is raised to reviewers that  
9 you really need to think about those things.

10 All that being said, if indeed the staff  
11 feels comfortable with doing a review of what I call  
12 the input analyses in Chapter 2 and Chapter 3, and you  
13 feel those are fairly complete, then the simple  
14 conclusion summary table was sort of a moot point.

15 MEMBER SHACK: Every topical report is  
16 sort of like this. You come to a generic conclusion,  
17 but you have to verify it in every case. To me, this  
18 isn't really any different from that. They can make  
19 that statement, but it really still has to be  
20 verified.

21 CHAIRMAN RAY: Well, that is an  
22 interesting parallel, Bill. You may be right.  
23 Somehow a topical report and this seem a little  
24 different to me, but maybe you are right.

25 It does make you wonder, well, what is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 being accomplished by standard content review, and I  
2 just have to think about that a little bit.

3 MEMBER STETKAR: Yes. You know, this is -  
4 - Said is here. So we can stop. Let me just finish  
5 the thought.

6 I know myself, when we were given the  
7 FSAR, the Bellefonte FSAR and the SER, I basically  
8 ignored anything that had BLN in the lefthand column,  
9 and concentrated on anything that had STD or SUP in  
10 the lefthand column.

11 I will tell you that, if I was given the  
12 site-specific FSAR, I would probably not pay much  
13 attention to things that are called STD and SUP,  
14 simply because we have theoretically gone through all  
15 of that. That is just natural human nature.

16 So that comes back to this issue of how  
17 thoroughly and what type of thought process do I use  
18 as a reviewer to think about things that we have  
19 previously reviewed and have accepted as standard, and  
20 now might be different, subtly different for some  
21 specific site, but might not have been captured  
22 perhaps by the applicant.

23 CHAIRMAN RAY: Well, John, would you like  
24 to identify this for some further discussion?

25 MEMBER STETKAR: I don't think so, Harold.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I think that the staff's response regarding their  
2 review of the site-specific -- let me call it hazards  
3 analysis in Chapter 2 and Chapter 3 will probably  
4 cover it, regardless of how this particular table is  
5 annotated. I think I am pretty well satisfied that  
6 the basic technical issues will be covered during the  
7 reviews, and any significant site-specific differences  
8 will be identified through the reviews of those other  
9 sections.

10 CHAIRMAN RAY: Dennis, you and Sam also  
11 shared this concern.

12 MEMBER BLEY: I am pretty close to John,  
13 but just two things. I have to admit, the word  
14 incredible grates on me whenever I run across it, and  
15 I see a subtle difference from what Bill said.

16 In truth, yes, you have to check  
17 everything. I agree, but in most of those topical  
18 reports we kind of think something has been built that  
19 bounds a general situation, but we have to look and  
20 make sure we are not surprised.

21 Here we had a bunch of statements which we  
22 just outright know don't apply everywhere. I think  
23 that is the difference, and having them there is -- I  
24 agree, as long as the review is looking in detail, we  
25 are covered. But it just seems odd to me to call

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things standard content when we know they are not  
2 going to apply a lot of other places.

3 CHAIRMAN RAY: Yes, and I think the way  
4 you put it, which was just because it is true of the  
5 first three plants in a series, to make that standard  
6 content on that basis does seem to create kind of a  
7 bias that doesn't need to be there. I am not sure  
8 what purpose it serves.

9 MEMBER ARMIJO: I think it is just  
10 needlessly confusing. I don't see why you have to go  
11 through all this.

12 CHAIRMAN RAY: Again, I will ask, we don't  
13 -- to make something to bring us back to this later,  
14 if you want. But otherwise, we will move on.

15 MR. GRANT: I would suggest that you will  
16 get several opportunities to discuss that very topic  
17 with each S-COLA that comes through, because you will  
18 get exactly the situation that you described. You  
19 will be asked to review the site-specific content at  
20 that point and overlook the standard, because it has  
21 already been covered.

22 CHAIRMAN RAY: Well, precisely, we will be  
23 asked again.

24 MEMBER BLEY: I guess we won't. That is  
25 the other hazard of putting too much stuff in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 standard.

2 CHAIRMAN RAY: Anybody else have anything  
3 more on this? Okay, you want to share your other  
4 slides, Amy?

5 MS. AUGHTMAN: I think these covered it.

6 CHAIRMAN RAY: Okay, fine. Rob, are you  
7 ready?

8 MR. SISK: We are.

9 ACTING CHAIRMAN HARRIS: We had two items  
10 you have proposed to discuss.

11 MS. COFFIN: We have a Chapter 15 from the  
12 staff presentation to make.

13 CHAIRMAN RAY: All right. There's too  
14 many discussions. Excuse me. Stephanie.

15 MS. COFFIN: The staff has a presentation  
16 to make on Chapter 15.

17 CHAIRMAN RAY: Yes, I understood that.  
18 Excuse me, Rob. Staff would like to proceed, even  
19 though we had projected this as the time to answer  
20 those questions. That is okay. Go ahead, Stephanie.  
21 I ask you to just stand down for another few minutes.

22

23 MR. SISK: That is fine.

24 MR. HABIB: Thank you. This is the staff  
25 presentation for the staff review of Chapter 15 of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COLA. It covers the standard material. The technical  
2 reviewers: Beside me, Gene Hsii and Michelle Hart,  
3 and also Jay Lee was a member of the review team.

4 My name is Don Habib. I am the project  
5 manager. Previous project manager was Joe Sebrosky,  
6 who is also here today.

7 This is an outline of the Chapter 15 in  
8 the FSAR and the SER that we prepared. The numbering  
9 of the sections in the SER generally follows what was  
10 in the FSAR from 15.0 through 15.8 and the two  
11 appendices.

12 In addition, the staff added a 15.9. 15.9  
13 doesn't have a corresponding section in the FSAR, and  
14 that 15.9 basically includes the radiological analysis  
15 of the design basis accidents. They were put in 15.9  
16 basically to keep them all in one place.

17 So with that, I will turn it over to the  
18 staff. Well, the three things that we will cover: In  
19 15.0, the calorimetric uncertainty methodology; 15.4,  
20 inadvertent boron dilution; and 15.9, dual unit  
21 analysis. Those are the three items marked in yellow.

22 CHAIRMAN RAY: Okay.

23 MR. HSII: My name is Gene Hsii. The  
24 Chapter 15.0 Accident Analysis, the FSAR incorporated  
25 by reference the supplement to Section 15 of Revision

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 17 DCD.

2 As we talked about it yesterday, during  
3 the AP1000 DCD review, we had a question about the  
4 calorimetric uncertainty of one percent, and  
5 Westinghouse proposed to make it a COL item. That  
6 will be COL item 15.0-1 for the gratification of the  
7 calorimetric uncertainty of one percent.

8 In the FSAR this issue not addressed. So  
9 we identified that as an open item, 15.0-1. We also  
10 identified a COL open item 15.0-2 on the same issue,  
11 except we talk about the particular information should  
12 be provided to address this issue.

13 We got a letter from Southern Nuclear. It  
14 is dated January 22 of this year. It indicated that  
15 Westinghouse is planning to revise the response to the  
16 RAI, and so we have not received the RAI response yet  
17 -- the revised RAI response yet. So this item still  
18 remains open.

19 CHAIRMAN RAY: Understood.

20 MR. HSII: Next one. This one, the  
21 Generic Letter 85-05, is related to the problem that  
22 was an event issue. This issue was reviewed and  
23 approved during the design certification review except  
24 we identified an issue at that time, issue tied to a  
25 emergency operating procedure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In Table 1.9-204, Generic Communication  
2 Assessment, this is all the items related to written  
3 and Generic Letters in the Revision 0 of Table 1.9-  
4 204. This Generic Letter 85-05 was listed there, but  
5 in Revision 1 that item was removed. So we had an  
6 open item, said put it back; tie it to -- cross-  
7 reference to COL item 13.5-1.

8 We got a letter from Southern Nuclear on  
9 January 22nd. They indicate they will put it back to  
10 the table for other issues.

11 CHAIRMAN RAY: Okay.

12 MS. HART: This is Michelle Hart. I am  
13 with the Siting and Accident Consequences Branch. As  
14 you had discussed earlier with the COL applicants, in  
15 Chapter 15 it is incorporated by reference, and the  
16 chi over qs are shown to be less than the chi over qs  
17 in the DCD. So there is not a lot of content to that.

18 However, for Bellefonte, because they were a special  
19 case, we have this separate section, 15.9, in our SER.

20 Included in that, we included the standard  
21 supplemental item in Chapter 6.4, which is the dual  
22 unit analysis which was asked about earlier.

23 The standard content is basically that  
24 qualitative argument, to a certain degree, that if you  
25 can handle the accident at your own unit in your

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 control room, you can handle an accident at a nearby  
2 AP1000 unit. Because this was Bellefonte, there was  
3 no other units on the site.

4 So it just talks about AP1000 units, and we agree with  
5 that assessment.

6 CHAIRMAN RAY: So this is standard content  
7 applicable to dual unit sites.

8 MS. HART: That is correct. That is  
9 correct. If there is another unit on the site, the  
10 applicant would be expected to discuss the current  
11 units, like for Vogtle Unit 1 and 2. They would have  
12 to discuss Vogtle 1 and 2.

13 CHAIRMAN RAY: That is site-specific then.

14 MS. HART: Right. But the standard  
15 content if you have two AP1000 units.

16 CONSULTANT WALLIS: Can we over this issue  
17 again of not credible events? There is no possible  
18 common cause that could lead to simultaneous accident?  
19 There is no possible, imaginable common cause?

20 MS. HART: Well, that is not the same  
21 thing as credible.

22 CONSULTANT WALLIS: It is

23 MEMBER ARMIJO: Common control room.

24 CONSULTANT WALLIS: Well, maybe we can  
25 talk forever about what you mean by credible. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean it has a very low probability. Credible, to me,  
2 means you can imagine it happening.

3 MS. HART: Right.

4 CONSULTANT WALLIS: To you, it means it  
5 has a very low probability, that is incredible?

6 MS. HART: That is correct.

7 CONSULTANT WALLIS: Then so it becomes a  
8 very personal thing about how improbable it needs to  
9 be to be incredible.

10 MS. HART: That is correct.

11 CONSULTANT WALLIS: Which is a little  
12 unfortunate. Okay, no more.

13 CHAIRMAN RAY: Okay. This is the standard  
14 content edition to cover dual unit sites then.  
15 Anything else you wanted to say?

16 MS. HART: I have nothing further.

17 CHAIRMAN RAY: Okay. Stephanie, is that  
18 it?

19 MS. COFFIN: Yes, sir. Thank you.

20 CHAIRMAN RAY: All right. Now I was  
21 premature before, but I think it is time now that we  
22 can address two items. We will address them as the  
23 Chapter -- Wait a minute. It is the instrument table.

24 MR. SISK: The instrumentation, yes, sir.

25 CHAIRMAN RAY: And then we will have a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 closed meeting to discuss -- I think we will have time  
2 before lunch -- gas intrusion.

3 MR. SISK: We will do the instrument table  
4 first and the gas intrusion before lunch, you say?

5 CHAIRMAN RAY: Yes. We will close the  
6 meeting, do the gas intrusion, and then go to lunch.  
7 When we return, then it will be -- resume open  
8 meeting.

9 MR. SISK: To answer the question on the  
10 instrumentation table, I want to introduce Mark  
11 Williams. He was discussing a little bit earlier this  
12 morning on a couple of topics, but he is going to  
13 basically respond to the questions regarding the  
14 uncertainties and how some of that is being managed in  
15 the calorimetrics.

16 MR. WILLIAMS: Good morning. My name is  
17 Mark Williams. I am with Westinghouse, and I am just  
18 going to sort of relay my understanding of what the  
19 issues are.

20 These issues are relating to the  
21 calorimetric instrument uncertainty versus the NIS  
22 trip uncertainty. There was a table which had three  
23 values, three parameters, in it. All those parameters  
24 were related to calorimetric uncertainty.

25 With respect to calorimetric uncertainty,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we include in the calorimetric uncertainty instrument  
2 drift and rack uncertainty to accommodate an entire  
3 cycle. So that is rolled up, and that is included in  
4 the calorimetric uncertainty for the power, the  
5 secondary power calorimetric.

6 The NIS trip -- that uncertainty is  
7 separate and independent from that. They are not  
8 related. So the NIS trip uncertainty also includes  
9 instrument drift and rack uncertainty, but it includes  
10 the instrument drift and rack uncertainty that is  
11 independent of what is included in the calorimetric  
12 calculation.

13 We have a process by which, on a daily  
14 basis, we take the secondary calorimetric, and we  
15 adjust the NIS power indication with gain, so they are  
16 within acceptance criteria. So there is effect.

17 There is no dependent effect between the  
18 calorimetric uncertainty and the NIS power trip --  
19 power range trip uncertainty. That is accounted for  
20 in the process of ensuring on a daily basis that we  
21 equilibrate this secondary calorimetric with the NIS  
22 reading by adjusting with gain.

23 MEMBER ABDEL-KHALIK: Excuse me. The  
24 table, as written, has the two percent calorimetric  
25 uncertainty, and in it, it listed that. What you are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 telling me is that two percent actually incorporates  
2 within it not just the uncertainties in the  
3 instrumentation used to measure feedwater flow,  
4 etcetera, to be able to do the secondary energy  
5 balance, but it also incorporates the instrument drift  
6 in it associated with the NI instrumentation. Is that  
7 correct?

8 MR. WILLIAMS: It incorporates the  
9 instrumentation and the drift associated with the  
10 secondary calorimetric --

11 MEMBER ABDEL-KHALIK: With the secondary  
12 calorimetric.

13 MR. WILLIAMS: -- and also the NIS power  
14 range trip uncertainty incorporates the instrument  
15 drift and rack uncertainties associated with it.

16 MEMBER ABDEL-KHALIK: So if that is the  
17 case, why are these listed in this table as  
18 independent variables?

19 MR. WILLIAMS: I am not sure.

20 MEMBER ABDEL-KHALIK: If the instrument  
21 drift on the NI instrumentation is incorporated within  
22 the two percent, why is it listed separately as .4  
23 percent?

24 MR. WILLIAMS: That .4 percent actually  
25 relates to the uncertainty associated with the power

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 range trip, and there is a portion of the uncertainty  
2 that is not accommodated in the calorimetric  
3 uncertainty that needs to be accommodated in the power  
4 range trip uncertainty.

5 MEMBER ABDEL-KHALIK: I guess I would have  
6 to look at the detail and see what part needs to be  
7 separated out.

8 MR. WILLIAMS; Yes. They are independent,  
9 basically. Essentially, on a daily basis we evaluate  
10 the calorimetric power. We compare that to the  
11 nuclear power, the NIS power as measured by the power  
12 channels, and then we adjust with the gain to make  
13 sure they match. So that eliminates dependency  
14 between those two uncertainties, effectively.

15 It is not unusual in power plant practices  
16 to take a secondary calorimetric and to make no  
17 adjustment on NIS, because the drift -- there has been  
18 no impact due to instrument drift or change in the 24-  
19 hour period within which was the last time that you  
20 did the secondary calorimetric calc.

21 So the point I am trying to make is that  
22 they are not dependent on each other. So to include  
23 the .4 with the calorimetric uncertainty is not --  
24 Basically, it would be rolling up two different  
25 numbers that are calculated for two different bases.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: So let's just sort  
2 of clarify things. Whether we are talking about two  
3 percent or one percent, what does the two percent  
4 include?

5 MR. WILLIAMS: The two percent would  
6 include all of the uncertainty associated with the  
7 feedwater mass flow rate measurement, any type of rack  
8 or instrument drift associated with the measurement  
9 and the instrumentation for that, blowdown measurement  
10 error, all of the variables, the rolled up variables  
11 that would go into calculating secondary calorimetric  
12 power, and the drift associated with those.

13 Once a day we measure secondary  
14 calorimetric power and make sure it matches within  
15 acceptance criteria to the NIS power. The NIS power  
16 range trip has an uncertainty associated with it that  
17 is specific to the NIS measurement process. So its  
18 uncertainty is rolled up in there, and that  
19 uncertainty is accounted for in the uncertainty  
20 associated with the trip, the trip setpoint, the high  
21 powered trip setpoint.

22 MEMBER ABDEL-KHALIK: Right.

23 MR. WILLIAMS: So they are kind of  
24 separate things.

25 MEMBER ABDEL-KHALIK: Separate things. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the question then remains: When one is doing LOCA  
2 analysis, if they are really separate, why aren't we  
3 concerned about the energy instrument drift over and  
4 above the uncertainty in the energy balance  
5 measurement?

6 MS. MONAHAN: Hi. This is Jill Monahan.  
7 The NI -- the instrumentation in the table that you  
8 are looking at is for the high neutron flux setpoint,  
9 which is not credited in the LOCA analyses. We do not  
10 trip on that. We only use the initial power  
11 uncertainty and initial -- the one percent or two  
12 percent. The high neutron flux setpoint, which is the  
13 total of 118 percent, is only credited in the non-LOCA  
14 analyses.

15 MEMBER ABDEL-KHALIK: That doesn't make  
16 sense, does it? All we are concerned about is what is  
17 the real -- what do we think the real reactor power is  
18 when the event takes place; and if that difference  
19 between the real reactor power and what the measured  
20 reactor power is, that is caused by error in the  
21 energy balance, which is the one percent or the two  
22 percent, plus any drift in the instrumentation during  
23 that 24-hour period when you sort of match the two?

24 MS. MONAHAN: And that is all included in  
25 the secondary power calorimetric, which is the one or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 two percent initial power.

2 MR. WILLIAMS: Correct.

3 MR. MONAHAN: The table specifically is  
4 looking at the reactor trip setpoint for high neutron  
5 flux.

6 MR. WILLIAMS: Just for the high neutron  
7 flux.

8 MR. CUMMINS: This is Ed Cummins. And  
9 that trip setpoint is not changed daily. That trip is  
10 every 18 hours.

11 MEMBER ABDEL-KHALIK: I understand, 118  
12 percent is 118 percent. Right.

13 MR. CUMMINS: So you get -- It is, I  
14 think, at least logical that you might have a drift of  
15 .4 percent for 18 months of drift, and a drift of a  
16 small fraction of one percent, because the drift is a  
17 small part of the calorimetric error in a daily  
18 situation.

19 MR. ABDEL-KHALIK: I will have to think  
20 through this again, but I think we can stop at this  
21 time. Thank you.

22 CHAIRMAN RAY: Any other members have any  
23 comments or questions? Yes, Rob?

24 MR. SISK: I was just going to say, we've  
25 gone as far as we can on this, and we do apologize. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 understand the table can be a bit confusing. We would  
2 be glad to follow up on any additional questions.

3 We can go to the gas accumulation when you  
4 are ready.

5 CHAIRMAN RAY: All right. Well, then we  
6 will want to close the meeting for that purpose. So  
7 we will do that in anticipation that we can get it  
8 done, the gas accumulation discussion, prior to Noon.

9 Is that all right with you, Stephanie? All right.

10 (Whereupon, the Open Meeting went off the  
11 record at 11:20 a.m., and the Subcommittee moved to  
12 Closed Session.)

13 - - -  
14  
15

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

## A F T E R N O O N   S E S S I O N

Time: 12:57 p.m.

CHAIRMAN RAY: Back on the record. It looks to me like there is a P&P meeting that is running long or something, is my guess as to what has happened. In any event, we can't -- Although we are ahead on the agenda, I think we are going to use up time talking about action items later today.

We are open for the rest of the day, I believe. Rob, you want your guys to be able to talk, don't you?

MR. SISK: Yes, sir.

CHAIRMAN RAY: Anyway. So I just wanted to say that, by the agenda, we are running ahead, but I think we are going to need the time to talk about the comprehensive review of the action items here at this milestone that we have reached. So I would like to proceed then, please, whoever is in charge of this presentation. yes?

MR. SISK: I was just going to say, if I could, could I just do a quick call to check on the phone.

CHAIRMAN RAY: So you can see if your guys can hear us and we can hear them. Go ahead.

MR. SISK: Terry Schultz, are you on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 line? Matt Evans, Terry Schultz? Is the line open  
2 yet?

3 CHAIRMAN RAY: Well, you know as much as I  
4 do. Rob, you know how to check on that. Peter will  
5 go check on it.

6 I think we should begin. Go ahead.

7 MR. CARUSO: Good afternoon.

8 CHAIRMAN RAY: Good afternoon.

9 MR. CARUSO: My name is mark Caruso. I am  
10 in NRO in the PRA Group, and with me is Malcolm  
11 Patterson. He is also in the PRRA Group. We are here  
12 to talk to you about regulatory treatment of non-  
13 safety systems.

14 We are going to start out giving you a  
15 sort of general background on it, some of the history,  
16 a discussion of the process that is used, and a little  
17 bit about how that process was applied in the original  
18 design certification for the AP1000. Then after I  
19 finish that, Malcolm is going to go and talk about  
20 RTNSS as applied to the most recent amendment for the  
21 AP1000.

22 As far as history goes, in a nutshell,  
23 RTNSS is really -- It is related to passive designs  
24 only, and back in the Nineties when AP600 was in here,  
25 there were a number of concerns about the uncertainty

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the performance of the passive systems, uncertainty  
2 regarding new systems and lack of operating  
3 experience, initiating event frequencies, failure  
4 rates of squib valves, and these sorts of things.

5 In the passive designs, the active systems  
6 are really non-safety systems, but there are systems  
7 there that look a lot like the original safety systems  
8 in many respects, and there was concern that these  
9 systems were important, more important than non-safety  
10 systems in original designs and, because of the  
11 uncertainty and concern about the passive systems,  
12 that there should be some treatment of these systems.

13 So I am going to go to the next slide. So  
14 what I thought was I realized the committee knows a  
15 lot about passive systems and passive designs, and  
16 there is no intent here to make this into some sort of  
17 review tutorial on passive systems. But since this is  
18 intimately related to passive systems --

19 CHAIRMAN RAY: Excuse me just a second,  
20 Mark, and let me see if we can establish this  
21 communication link. Doesn't sound like it.

22 Rob, do you want to do your check again,  
23 or Ed?

24 MR. CUMMINS: Terry or Matt, are you  
25 there?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCHULTZ: Terry is here.

2 MR. CUMMINS: Who else is there? We can  
3 proceed.

4 CHAIRMAN RAY: Sorry. Go ahead and  
5 restart on this slide, please.

6 MR. CARUSO: Okay. It will be useful to  
7 talk about a couple of aspects of the passive system  
8 plant designs that really sort of make up the driving  
9 force for RTNSS.

10 As you know, passive systems provide the  
11 primary safety functions in the passive designs,  
12 reactor water make-up, core cooling, containment  
13 cooling. They don't use mode of power. They don't  
14 use pumps. They use natural forces and some dc power  
15 to perform their functions.

16 These are the safety related systems.  
17 These are the systems that replace the ones we all  
18 know and love, the pumped injection, long term  
19 recirculation, pumped recirculation, the fan coolers,  
20 those systems.

21 As I mentioned, because there is  
22 uncertainty, they are new, they haven't been tried,  
23 there is in some respects no operating experience, the  
24 active systems in these designs perform back-up  
25 functions to the passive and, therefore, the staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 raised a policy issue back in the Nineties that there  
2 should be some sort of treatment, that they should not  
3 be treated like non-safety systems in our original  
4 designs, that we should do something.

5 So there were a number of policy  
6 discussions, policy papers written, and the Commission  
7 finally issued an SRM that established a policy, the  
8 NRC's policy on RTNSS. Go to the next slide.

9 So active systems: The active systems in  
10 the passive design -- they are not credited in the  
11 accident analysis. They are only included if they make  
12 it worse. They are, for the most part, designated as  
13 non-safety systems.

14 They, in many respects, play a more  
15 important role than active systems in current designs,  
16 although there are a number of non-safety systems in  
17 current designs that are important to risk, as we  
18 know. But they do provide -- They provide defense-in-  
19 depth for some of the safety functions. There are  
20 systems that can inject water into the core. There is  
21 AC power that can provide back-up for other functions.

22 These systems, in many cases, will respond  
23 first in an accident, and they can avoid challenges to  
24 the passive systems. And because they can do these  
25 functions and perform these functions, they may, in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fact, be very risk-significant.

2 So because of this, the Commission and the  
3 industry agree that there should be some regulatory  
4 oversight of some of these non-safety systems, and the  
5 NRC staff and the industry, through the Electric Power  
6 Research group, established a process for deciding  
7 what non-safety systems should be scoped into this  
8 program -- basically, what non-safety systems should  
9 have treatment, and what should the treatment be. And  
10 that is pretty much it. What is in scope, and how do  
11 they get treated?

12 So the first step, as I said, is to  
13 identify what those non-safety systems are that  
14 deserve treatment, and then to essentially look at  
15 their importance. They invented the term  
16 reliability/availability mission for each SSC, which  
17 really is defined as performance requirements, the  
18 requirements on availability, requirements on the  
19 reliability for the SSC. They used that information  
20 as the basis for deciding how important is this SSC,  
21 and that importance then dictated what the treatment  
22 would be.

23 Now the various types of treatment that  
24 are sort of being used and available are tech spec  
25 controls, availability controls, which is a new idea,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a new concept in new reactors whereby a tech spec-like  
2 document has been prepared, looks very much like tech  
3 specs, has limiting conditions for availability.

4 It has action statements. It has  
5 surveillance requirements. It is just not -- doesn't  
6 have the toughness and the teeth that tech specs have,  
7 doesn't require plant shutdowns. It basically says  
8 this equipment should be available, one train, two  
9 trains, whatever. It has LCOs on availability, and  
10 has actions for what happens, what you should do if  
11 you don't have -- if it becomes unavailable, and it  
12 has surveillance requirements to help you evaluate  
13 whether or not it is available.

14 In addition, there are design  
15 considerations, and this mostly comes into play for  
16 non-safety systems that may be aggravating initiating  
17 events, whereas what is turning out to be the approach  
18 for both the ESBWR and AP1000 is, for those cases, to  
19 go in and make them better, to increase their mean  
20 time to failure, that sort of thing.

21 MEMBER STETKAR: Let me ask you about the  
22 design issue, because I don't think any of your later  
23 slides speaks to that, do they?

24 MR. CARUSO: Well, I am going to say a  
25 little bit about that. The design considerations in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 RTNSS -- there's basically, I think, a desire to have  
2 some of the most important non-safety systems, systems  
3 that can directly serve as defense-in-depth for the  
4 passive, to be redundant, to have a certain  
5 redundancy.

6 MEMBER STETKAR: Let me kind of cut to the  
7 chase. In terms of redundancy, in terms of numbers of  
8 pumps and pipes and valves, I understand that. The  
9 thing that I was thinking about were design  
10 considerations such as seismic design, for example.

11 In the designs I have looked at, the RTNSS  
12 systems -- Unless there is a seismic two over one type  
13 of concern, the RTNSS are basically non-seismic  
14 design. Therefore, they are not qualified for a  
15 seismic event, across the board, unless they can  
16 interfere with a safety system.

17 The same is true, in general, for  
18 environmental qualification. For example, cabinets or  
19 control panels in the main control room, if they are  
20 designated safety related, need to be environmentally  
21 qualified, but other panels and cabinets that support  
22 operator responses, if they are not safety related,  
23 may be RTNSS, but are not environmentally qualified.

24 So those are the types of design  
25 considerations, not necessarily the hardware layout.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CARUSO: On the next slide I am going  
2 to talk about the criteria that are used to scope  
3 things into RTNSS, and there is really only one  
4 criteria there that has some design requirements  
5 associated with it, and that is pretty much the way  
6 the Commission laid it out.

7 You are right. When you get to design, it  
8 is minimal. There is a few very specific requirements  
9 that have to do with design, and they really only  
10 apply to this particular category. So I will get to  
11 that in a second.

12 The last treatment option is the  
13 reliability assurance program, which I am sure you are  
14 all familiar with. It is discussed in Section 17.4 of  
15 the FSAR. I am sure you have all been briefed on -- I  
16 know you have been briefed on the ESBWR reliability  
17 assurance program.

18 It is basically a program whereby -- It is  
19 sort of an expanded maintenance-like program, in a  
20 sense. You look at all your components, safety  
21 related and non-safety related, and you apply a risk  
22 informed ranking type of process to decide what gets  
23 scoped in this program, similar what is done in the  
24 maintenance rule, high significant, low safety  
25 significant, that sort of thing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           Then it allows you to apply all your  
2 operational programs, parts of them, to these SSCs,  
3 not just maintenance: design controls, procurement,  
4 QA. The program has requirements on helping you  
5 figure out what levels of these things should I apply,  
6 and what kind of testing.

7           I think maybe you heard some about the  
8 IST. IST is applied yesterday. So that is really  
9 what the reliability assurance program is. It is a  
10 program to identify what is really important in the  
11 plant, both non-safety and safety, from a risk  
12 perspective, and then decide in all the areas what  
13 kinds of treatment should those SSCs get.

14           MEMBER STETKAR: Mark, since you mentioned  
15 IST, it still -- I went over my notes last night. It  
16 still wasn't clear to me. I think in our discussions  
17 yesterday, it seemed that the IST requirements are  
18 still being interpreted as strictly applicable to  
19 safety related valves, since the question came up in  
20 terms of motor operated valves and power operated  
21 valves.

22           I was really curious what sort of process  
23 is in vogue to elevate RTNSS motor operated valves and  
24 power operated valves to that list of equipment that  
25 are subject to formal IST requirements.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CARUSO: Well, as far as RTNSS goes,  
2 scoping RTNSS components -- and it could include  
3 valves -- if you scope them into -- If you basically  
4 say all my RTNSS SSCs are going to go in the  
5 reliability assurance program, which is, in fact, what  
6 is happening, then you are going to get more of a risk  
7 informed treatment. You are going to get them ranked.  
8 You are going to get the treatment applied to it.

9 Now it is true that the normal IST program  
10 that is required in 50.55(a), whatever, is still based  
11 on safety related considerations. There is a risk  
12 informed IST program that is voluntary, and for the  
13 new reactors I think there may be only one COL who is  
14 proposing to get risk informed applications along with  
15 their combined license. Other ones are basically  
16 going to get their license first and then come back  
17 and look at what they want, QA, IST, whatever.

18 So there is a risk informed process.

19 MEMBER STETKAR: But in general, the way  
20 that is applied in practice is to extend the test  
21 intervals for my set of predefined equipment. It is  
22 not to add equipment to that list. I haven't ever  
23 seen --

24 MR. CARUSO: No. The scoping could scope  
25 non-safety in there. The scoping rules are not -- It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is not limited to safety related equipment.

2 MEMBER STETKAR: That's right in  
3 principle. In practice, I am saying is the way people  
4 tend to apply risk informed testing programs is to  
5 extend the test intervals for equipment that are on a  
6 pre-defined list.

7 MEMBER SHACK: It is more their incentive.

8 MEMBER STETKAR: That's right. That is  
9 their incentive. We are talking about application  
10 after the license is issued.

11 MEMBER SHACK: In practice, you might  
12 include.

13 MR. CARUSO: And I have probably told you  
14 as much as I know about risk informed IST. So I can't  
15 --

16 MEMBER STETKAR: I guess what I am asking  
17 about is, as part of this process of defining RTNSS  
18 equipment that's supposed to be subject to increased  
19 scrutiny, there is no formal process that says thou  
20 shalt add, you know, X equipment down to some level of  
21 risk significance from your D-RAP list, for example.

22 I am asking that. I am not aware of it.

23 MR. CARUSO: Well, I think that the  
24 reliability assurance program will have you -- You  
25 know, if valves come in there, it will have you look

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at applying ISG in some shape or form to those valves.

2 Now it may not be the same level of treatment that  
3 you would get from safety-related, but I think the  
4 program forces you to go through the process of  
5 addressing that.

6 The program doesn't specifically say how.

7 It just says, you know, what we have approved as --  
8 You have a program that has you do these things. You  
9 evaluate what kinds of design controls, what I need  
10 for this stuff, what kinds of QA, and it has criteria  
11 in there on doing that.

12 We haven't actually seen it done yet,  
13 because it doesn't actually get done until farther  
14 down in the licensing process with the COL. We  
15 haven't seen it in the design certification readings.

16 MEMBER BONACA: But if you get this  
17 ranking, for example, up to the article section stage  
18 or after that, could it be in the same component that  
19 folds under accepting QA requirement at Plant A is not  
20 required to have the same treatment in Plant B?

21 MR. CARUSO: Could be.

22 MEMBER BONACA: Could be.

23 MR. CARUSO: Because we are not -- You  
24 know, we are not -- They are not proposing all of the  
25 details of the program. It is more at a higher level.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: I am kind of struggling  
2 with that, because right now -- until now it has been  
3 very clear, you have a safety related component --  
4 category requirements.

5 MR. CARUSO: Well, safety related, no.  
6 They are going to get the same treatment for safety  
7 related. The stuff that gets in here gets non-safety  
8 related.

9 MEMBER BONACA: Okay.

10 CHAIRMAN RAY: Excuse me, Mark. Those who  
11 are on the line, please mute your end of the  
12 communication.

13 MR. CUMMINS: Terry, you need to mute your  
14 line.

15 MR. SCHULTZ: Sorry.

16 CHAIRMAN RAY: This is what is called  
17 multi-tasking. All right, Mark, you may resume.

18 MR. CARUSO: We are sort of getting into  
19 another very interesting topic here that we could  
20 probably spend the whole meeting on, but how about if  
21 we get back to it.

22 CHAIRMAN RAY: Not until Mario's question  
23 is answered.

24 MR. CARUSO: Okay.

25 MEMBER BONACA: No, he did. I understand

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now in part. I am still left with some questions  
2 regarding a component that, again, may have a  
3 different classification in two different plants, just  
4 because you have a management group that makes the  
5 call one way or the other, and we have inconsistent  
6 treatment among the design, the same design.

7 MR. PATTERSON: I can only speak to the  
8 AP1000 that I have reviewed, but we expect that the  
9 treatment will be identical at all AP1000 licensees.  
10 They have all adopted the D-RAP list. The components  
11 that are identified as being within the scope of the  
12 RTNSS program are already identified by Westinghouse,  
13 and all of the applicants have said that is our list  
14 and we will measure them that way, and they have 18  
15 different issues, just like the figure related to a  
16 program. Simply a different level of quality being  
17 expected.

18 MEMBER BONACA: That is the way it should  
19 be.

20 MR. SCHULTZ: This is Terry Schultz from  
21 Westinghouse. I think I have something I could add to  
22 this question about in-service testing.

23 CHAIRMAN RAY: Go ahead.

24 MR. SCHULTZ: I think that the way the  
25 RTNSS program is set up for AP1000, there is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operability checks that are built into the short term  
2 availability control program. Periodically, the  
3 components need to be -- The key components in the  
4 various RTNSS systems that are in that program need to  
5 be -- show that the pumps start or any valves that  
6 have to move will change position, and that that is  
7 considered to be sufficient for their risk importance,  
8 and that we do not think we need to put those valves  
9 into the in-service testing program.

10 CHAIRMAN RAY: Okay. Any questions at  
11 this point? All right, thank you. Again, please  
12 return your line to Mute until you need to speak to us  
13 again. Thank you.

14 MR. CARUSO: The next slide here lists the  
15 criteria, the categories, criteria that are used to  
16 scope SSCs into the RTNSS program. The first one is  
17 pretty straightforward: Any non-safety system that is  
18 used, relied upon to meet the ATWS or SBO rules is  
19 scoped in.

20 The second two criteria relate to -- In  
21 the passive designs generally the safety systems will  
22 perform all the safety functions for 72 hours  
23 following the accident with, presumably -- or by  
24 design very little intervention by the operators.  
25 After 72 hours, it may be necessary to support those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 functions with non-safety systems.

2 That is where this criteria comes from,  
3 looking at what safety systems need support from non-  
4 safety systems in that period between 72 hours after  
5 the accident and seven days.

6 So the applicant looks at his safety  
7 functions, looks at how they are being accomplished,  
8 are there non-safety systems that are needed such as  
9 being able to -- you know, refilling tanks with non-  
10 safety systems or providing for heat removal in the  
11 control room, providing heat removal in other rooms.

12 They identify anything non-safety that  
13 they need for that, and it is scoped in. This is the  
14 criteria where the Commission has said there are going  
15 to be a few specific design requirements associated  
16 with this equipment, and the main one is seismic, that  
17 this equipment needs to be at least seismic Category 2.

18 The rationale is that the equipment  
19 doesn't need to function during the earthquake, but it  
20 needs to be available after the earthquake and not in  
21 a state that I have got to do some fixing.

22 The buildings have to -- You know, if  
23 you've got HVAC and you need HVAC, you need piping  
24 systems and they are on the wall attached to the walls  
25 of the building, the building better not crumble. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 building -- That equipment better be available to turn  
2 on after the accident. That is what seismic Category  
3 2 is.

4 In some instances --

5 CHAIRMAN RAY: What defines seismic  
6 Category 2, again?

7 MR. PATTERSON: I would summarize it as  
8 saying something that is seismic Category 2 will  
9 survive the earthquake and not fail in such a way that  
10 it interferes with any safety related component.

11 CHAIRMAN RAY: Well, that is the first  
12 time I have ever heard that definition for seismic  
13 Category 2, but I am not disputing it. I would have  
14 to go back and look. Does anybody here know?

15 MR. CUMMINS: This is Ed Cummins. I would  
16 use exactly the same definition, and then when you  
17 come to the staff and say, well, how do you design  
18 something to seismic Category 2, they say design it to  
19 seismic Category 1, the loads. So it ends up being --  
20 But the difference between 2 and 1 is that in Category  
21 1 it must function. In Category 2 it must be intact,  
22 but the design method turns out to be the same.

23 MEMBER BLEY: And intact just means it  
24 doesn't fall down.

25 MR. CUMMINS: It didn't fall down and hit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 something, and in the case of these things, the  
2 intention is that, if it is a tank and it is seismic  
3 Category 2, it still has its fuel or water in it. It  
4 didn't fail. It didn't have to be a pump over it. It  
5 doesn't have to pump, for example.

6 CHAIRMAN RAY: Well, it has to remain  
7 operable is what I heard.

8 MR. CUMMINS: Which is not typical for --  
9 The word operable in seismic Category 2 don't normally  
10 match.

11 CHAIRMAN RAY: That is correct.

12 MEMBER STETKAR: I am still a bit confused  
13 about that, because if I look at the AP1000 DCD  
14 seismic -- whatever it is called here -- qualification  
15 -- seismic classification table -- there is a table  
16 3.2-3 in the DCD.

17 If I look at, for example, the fuel oil  
18 storage tanks for the ancillary dc generators, they  
19 are indeed seismic Category 2, consistent with what I  
20 just heard. If I look at the engines themselves and  
21 any equipment attached to the engines, they are non-  
22 seismic. So I am not quite sure how that is  
23 consistent.

24 MR. CUMMINS: Ed Cummins again. All this  
25 came about in the AP600 time frame based on some kind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of negotiation between the applicants and our  
2 customers and the staff. In cases where you have a  
3 piece of equipment that was fungible -- you have some  
4 of them in your warehouse, and the kind of diesels  
5 these are, are in the back of firetrucks.

6 So we originally started with not  
7 providing them at all in the plant and said, whenever  
8 we need them, we will deliver them there, and they  
9 will start pumping. That sort of got -- In the  
10 negotiation that got compromised to say, no, you have  
11 to actually deliver them and mount them in your thing,  
12 but if they were to fail in the earthquake, bring your  
13 next one out. It is replaceable by people doing minor  
14 amounts of work. It is a portable piece of equipment.

15 So portable pieces of equipment, at least  
16 in our negotiation, were allowed to be non-seismic,  
17 because you could get another one.

18 CHAIRMAN RAY: Anything else?

19 MR. PATTERSON: I should point out, this  
20 issue would not have been revisited, because it was  
21 not amended from the certified design.

22 MEMBER STETKAR: I am trying to understand  
23 RTNSS also in a more generic sense, because I am  
24 assuming that the general understanding of RTNSS as it  
25 applies to AP1000 should be somewhat consistent with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the general understanding of RTNSS as it applies to  
2 any of the other new plants, regardless of what was  
3 previously negotiated.

4 MR. CUMMINS: This is Ed Cummins again.  
5 Well, the AP600 was the one who defined it in the  
6 beginning, and if you took that philosophy, you would  
7 say all the other ones should be like it. At least,  
8 if you were me, you would say that. We set the  
9 standard initially.

10 MEMBER STETKAR: Right. I guess the  
11 reason I asked, in particular on the seismic, is I saw  
12 this as an inconsistency in the AP1000 seismic  
13 qualification. I picked the ancillary diesels,  
14 because they are the easiest to look at, where the  
15 fuel tanks are seismic Category 2, but anything else  
16 related to the system is non-seismically qualified. I  
17 haven't really looked at the others.

18 MR. CARUSO: Well, if you went and looked  
19 at the ESBWR ancillary diesels, you would find that  
20 they are seismic-2, because they are not being trucked  
21 in.

22 MEMBER STETKAR: So they are more  
23 consistent with --

24 MR. CUMMINS: They are more stationary,  
25 and as you said, the issue has to do with portability

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as opposed to sort of stationary.

2 MEMBER STETKAR: Is that true for valves  
3 welded in pipes in the plant also?

4 MR. CARUSO: Valves welded in pipes are  
5 pretty stationary. One other example I do remember  
6 with AP1000 is I think they utilize fans, portable  
7 fans, to remove heat from some of the rooms, and they  
8 have them stored in a building, and I think in that  
9 particular case that building design was allowed to be  
10 National Building Code; because they said, okay, well,  
11 even if the building id damaged some, I can still go  
12 in there and get these fans out. That was another  
13 sort of negotiated --

14 MEMBER STETKAR: Have you ever seen  
15 seismic damage?

16 MR. CARUSO: No.

17 MEMBER STETKAR: Talk to the folks in  
18 Haiti. Now National Building Code is a lot better.

19 MR. CARUSO: They have this one example  
20 with the National Building Code, and ESBWR came in,  
21 and they wanted to have all kinds of stuff in  
22 buildings with National Building Code, and that didn't  
23 happen, because the kind of stuff they were talking  
24 about was HVAC connected to the building and pipes  
25 connected to the building, and we said, no, I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think so.

2 MR. PATTERSON: I would also like to point  
3 out that the part of the building in which the  
4 ancillary equipment is located is seismic Category 2,  
5 even though it is a non-safety building.

6 MR. CUMMINS: This is Ed Cummins. And in  
7 fact, the fans are not located -- They are located in  
8 a seismic Category 1 building. The little temporary  
9 fans we store in the nuclear island.

10 MR. CARUSO: Yes, I have not -- I am not  
11 the AP1000 RTNSS reviewer. I wasn't the reviewer back  
12 in 1997. So I should probably keep my mouth shut when  
13 you talk about AP1000. I will just talk about RTNSS  
14 in general, keep my mouth shut. This is our AP1000  
15 review. I did the RTNSS review for the ESBWR.

16 MEMBER SHACK: The 95-132 statement is a  
17 little more general than yours. It says SSC functions  
18 relied upon to dissolve long term safety and to  
19 address seismic events, which would seem to me to  
20 bring a few more things into scope.

21 MR. CARUSO: Theoretically, but I don't  
22 think anything has been brought in for either AP1000  
23 or ESBWR.

24 MEMBER STETKAR: Mark or Malcolm, I am  
25 always searching for specific examples to try to make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 me understand this a little bit better. So I had to  
2 search for another one quickly here.

3 Component cooling water pumps are included  
4 in the AP1000 D-RAP as RTNSS equipment. Component  
5 cooling water pumps are non-seismically qualified  
6 equipment.

7 They seem to be -- They are usually welded  
8 or bolted into piping systems, and it strikes me that  
9 they are probably not on trucks to bring into the  
10 plant to hook in parallel. So explain to me why  
11 component cooling water pumps are not --

12 MR. CARUSO: Because the criteria that  
13 scopes them in is not the long term safety criteria,  
14 and there is no -- If the criteria that scopes them  
15 into RTNSS is it is important from the PRA sensitivity  
16 study, there is no requirement for it to be -- If it  
17 is seismic, that equipment doesn't -- There is no  
18 seismic requirement attached to it in RTNSS space.

19 MEMBER STETKAR: Question: Has the AP1000  
20 done a seismic PRA?

21 MR. CUMMINS: We use the margins.

22 MEMBER STETKAR: Okay. So we don't know  
23 the seismic contribution to risk or the relative  
24 contribution from seismic failures of these pumps to  
25 risk.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: Ed Cummins. Could I try  
2 this for a minute? What was seismic and what was not  
3 seismic in RTNSS was related to the post-71 hours.  
4 Why was it stipulated to the post-72 hours? Well,  
5 originally everybody had kind of agreed with URD and  
6 said 72 hours was sufficient. Then there was some  
7 operating experience, including the hurricane in  
8 Florida, where it wasn't clear that support could be  
9 brought from off-site within 72 hours.

10 So the staff wanted to change 72 hours to  
11 seven days. So what we agreed to do was to change 72  
12 hours to seven days by using equipment that would be  
13 there still in seven days. That is, the component  
14 cooling water pump, as an example, is not used in the  
15 period from 72 hours to seven days, and the equipment  
16 that you want to use or need to use for plant safety  
17 between 72 hours and seven days -- since the cause of  
18 ability to get to the site might have been an  
19 earthquake, you had to have it survivable from the  
20 earthquake. That was the theory.

21 So those equipment that we would use  
22 between 72 hours and seven days should survive an  
23 earthquake, or if not, you have another one there that  
24 you can lift up and put in there.

25 MEMBER BLEY: Not to be too dense, if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't need it in that period of time, why did it end  
2 up being RTNSS?

3 MR. CUMMINS: I think Terry can say this  
4 better. In certain plant events like mid-loop  
5 operation, for example, it has a contribution to  
6 safety, which is important from a probabilistic.

7 That is not when you are having the  
8 earthquake, but it has a reason to be important in  
9 some plant conditions.

10 MEMBER BLEY: So the things that would  
11 limit access to the site were things that drove you to  
12 --

13 MR. CUMMINS: To seismic level.

14 MEMBER STETKAR: A re spent fuel pool  
15 cooling strictly post-72 hours or is that --

16 MR. CUMMINS: The provision of water to  
17 the spent fuel pool so that it can boil up is part of  
18 the 72-hours to seven days.

19 MEMBER STETKAR: But that is provided by  
20 things like fire systems. Is that right?

21 MR. CUMMINS: We have a big tank of water,  
22 and we pump a little bit of it into the spent fuel and  
23 a little bit onto the containment cooling.

24 CHAIRMAN RAY: Okay.

25 MR. CARUSO: But you are right, John.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 When they do do a seismic PRA, that could --

2 MEMBER STETKAR: I am just trying to --  
3 You know, I am antagonistic, and I bring up all of  
4 these specific examples, but I am actually trying to  
5 just get a better handle on --

6 MEMBER SHACK: What is in RTNSS that  
7 includes seismic events.

8 MR. CARUSO: That was the point I was  
9 going to make. The next criteria is you do a  
10 sensitivity study with the PRA. You take the non-  
11 safety systems out from the PRRA, and you look at what  
12 core damage frequency and what LRF I get. If I can  
13 meet the safety goals without any non-safety systems,  
14 then I scope nothing in from that criteria.

15 If I don't, then I start to put safety  
16 systems back in and look at how important are they to  
17 meeting the safety goals.

18 CONSULTANT KRESS: Don't you have to have  
19 a site to determine safety goals?

20 MR. CARUSO: Well, you are doing a Level 2  
21 PRA.

22 CONSULTANT KRESS: How do you do that for  
23 a design certified design, is what I am asking?

24 MR. PATTERSON: Well, if you do a Level 1  
25 PRA --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. CARUSO: No, he is talking LRF.

2 MR. PATTERSON: Right.

3 MR. CARUSO: Large release frequency. It  
4 is not a Level 3, based on Level 3.

5 CONSULTANT KRESS: You just substitute LRF  
6 as a surrogate for safety? What value do you use?

7 MR. CARUSO: Ten to the minus six.

8 MEMBER SHACK: LRF?

9 CONSULTANT KRESS: LRF.

10 MEMBER SHACK: Now ask him what an LRF is.

11 CONSULTANT KRESS: What if you have four  
12 of these plants? You use one-fourth,  $10^{-6}$ ?

13 MR. PATTERSON: Each plant would measured  
14 individually.

15 CONSULTANT KRESS: Okay, but that seems  
16 strange to me. Quite a containment performance goals.  
17 Is that an LRF?

18 MR. CARUSO: Conditional containment  
19 failure probability goal? It is 10 percent, 0.1.

20 CONSULTANT KRESS: Is that redundant to an  
21 LRF?

22 MR. CARUSO: I think in some respects it  
23 is.

24 CONSULTANT KRESS; Just checking.

25 MR. CARUSO: So in that case, they do the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 focus PRA sensitivity studies, and identify any non-  
2 safety equipment that can be relied on or can cause  
3 them to meet the goals.

4 With respect to PRA, they also look at the  
5 impact of non-safety systems on initiating event  
6 frequencies, and I need to say something about this  
7 bullet here before I hear loud noises from over on  
8 that side of the room.

9 It says here that anything that could  
10 cause an initiating event to significantly affect CDF  
11 or LRF would be scoped in. They really -- The  
12 criteria is sort of broken up into a set of screening  
13 tests: You know, does a non-safety system impact any  
14 -- is it factored into the calculation or  
15 determination of any initiating event frequency? And  
16 if it is no, then it is immediately screened out.

17 Then the second criteria is does it  
18 increase the initiating event frequency? If it does,  
19 you get a necessary condition to keep it in. then you  
20 look at, well, does that increase -- how does that  
21 increase affect CDF and Large Release Frequency?

22 In the RTNSS report for the AP1000, the  
23 criteria actually needs to be 10 percent increase in  
24 CDF -- 10 percent of CDF, contribution of 10 percent  
25 to CDF or LRF to be scoped in. However, the reason I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have one percent on this slide is in the evaluation  
2 they essentially used a de facto one percent. They  
3 found that, for the most part, they were getting for  
4 the non-safety SSCs that were affecting initiating  
5 event frequencies, they were getting .2, .1 percent  
6 contributions.

7 In one case, they got a 1.4 percent  
8 contribution to CDF and a 7.5 percent contribution to  
9 LRF, and they decided that that was big, and they  
10 would put it in anyway. So in the actual evaluation,  
11 they were somewhat concerned and scoped in SSCs that  
12 didn't meet their published criteria. So this one  
13 percent represents what was actually done as opposed  
14 to what the stated criteria is in the WCAP report.

15 The equipment that is relied upon to meet  
16 the containment performance goals -- and those goals  
17 are the conditional containment failure probability,  
18 .1; and also a deterministic goal which is to maintain  
19 structural integrity ASME service level C, I believe,  
20 of the containment for 24 hours.

21 The last criteria is that applicants are  
22 required to do a systems interaction evaluation, and  
23 they use a process, I believe, that was outlined in  
24 the Generic Letter sometime ago. Systems interaction  
25 was an unresolved safety issue for a number of years,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and it was resolved with defining a process to  
2 devaluate, you know, are there system interactions  
3 that can impact safety systems.

4 Here, it is looking at either an  
5 interaction from a non-safety system or, in effect,  
6 the passive systems is primarily what you are looking  
7 at. If you needed to add something in to solve that  
8 problem or make that interaction go away, a non-safety  
9 piece of equipment, that would be scoped in.

10 So those are the criteria that are used to  
11 decide what SSCs will get some sort of treatment.

12 Now what I said in the beginning was, once  
13 you define the SSCs, you try to decide what treatment  
14 should they get, and you basically identify their  
15 importance. If the SSC is something that is in the  
16 PRA, you have the PRA to help you look at its  
17 importance, your importance measures, your  
18 assumptions of reliability and availability. If it is  
19 not in the PRA, then you need to do some sort of  
20 judgment.

21 The Commission's guidance and the policy  
22 is not real well defined here in terms of how you map  
23 these reliability/availability missions to treatment.

24 It basically says you should do a graded  
25 approach. It is really important, you know. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 should give it more important treatment.

2 Now in one case there is sort of a very  
3 distinct criteria, and that is scoping something into  
4 tech specs. Here it is pretty well defined. If, in  
5 fact, -- and this has been the practice of both AP1000  
6 and the ESBWR. If in fact, the piece of equipment  
7 came from the criteria that involves whether or not  
8 you meet the safety goals, if that piece of equipment  
9 is the one that gets you over the hump, it goes in  
10 tech specs. That has been what is happening.

11 That is based on -- There is a regulatory  
12 criteria here. If you look in 50.36(d), the criteria  
13 for what goes in tech specs, there is criteria 4 that  
14 says anything that has been shown to be risk  
15 significant or important in operating experience, it  
16 should be in tech specs. That is essentially the  
17 regulatory foundation of that particular treatment  
18 decision.

19 Other than that, for the most part,  
20 everything else is being pretty much treated with the  
21 availability controls. So it is really in two groups.

22 It is either in tech specs or to the availability  
23 controls, the D-RAP program and, as I said, in these  
24 particular cases of some of the SCCs that affect  
25 initiating event frequency, they will go back and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 improve the design for tolerant, digital feedwater  
2 controllers, that sort of thing.

3 So the last slide I have here is just a  
4 summary of what in the original design certification,  
5 not the amendment -- what was -- a listing of the  
6 equipment, the major pieces of equipment that were  
7 scoped into RTNSS and the category that put them in  
8 there. I wasn't planning to go through all of this,  
9 but I, just for completeness, wanted to include that.

10 So if there's no questions for me, Malcolm  
11 is now going to talk about how RTNSS was treated for  
12 the AP1000 amendment.

13 CONSULTANT KRESS: I have a question on  
14 the previous slide. Why was one percent chosen as  
15 being significantly affect CDF and LRF?

16 MR. CARUSO: Well, it was actually -- Ten  
17 percent was actually chosen. One percent was used.

18 CONSULTANT KRESS: Okay. I'll buy that  
19 then. What CDF are you talking about?

20 MR. CARUSO: Ten to the minus four.

21 CONSULTANT KRESS: Ten to the minus four?

22 Thank you.

23 CHAIRMAN RAY: Okay, Malcolm.

24 MR. PATTERSON: I am Malcolm Patterson. I  
25 am in the Office of New Reactors in the PRA Branch. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was responsible for the review of the AP1000  
2 amendment, which focused primarily on changes to the  
3 D-RAP. There were not many. There were a few design  
4 changes that resulted in the addition of components.

5 There were a number of components that, as  
6 a result of design changes or a refinement of the PRA,  
7 dropped below the setpoint for being included, but  
8 Westinghouse retained all of those rather than  
9 creating an argument over small numbers.

10 What we did get involved in, in our  
11 review, was the criteria that they characterized these  
12 components. Sometimes common cause failure remained  
13 an important reason for keeping an item on the D-RAP,  
14 and Westinghouse, because the basic event important  
15 for a given compliance had dropped below the threshold  
16 we were using of a raw of 2 or higher, they said,  
17 okay, we are keeping this on the list because the  
18 expert panel says whether it should stay on the list.

19 While that is a good reason, in our view,  
20 it was still an issue that common cause failure would  
21 have put it on the list, and so we wanted to make sure  
22 that sometime in the future someone doing a design  
23 change would understand all the reasons why something  
24 was in the RTNSS program or was on the D-RAP. Go to  
25 the next slide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I wanted to talk briefly about the  
2 reliability assurance program, because in the case of  
3 AP1000 essentially everything that has been scoped  
4 into the reliability assurance program is either  
5 safety related or it is in the RTNSS program. If it  
6 is non-safety related, it is RTNSS. If it safety  
7 related, it is already covered under the Appendix B QA  
8 program.

9 We made sure that anything that was in the  
10 RTNSS program was included in the reliability  
11 assurance program. Up to the time of COL, we were  
12 primarily concerned about the design controls from  
13 Westinghouse. Once a license is granted, however,  
14 this shifts to a concern over the COL applicants' QA  
15 program and the RTNSS QA program.

16 The reliability assurance program is  
17 broken into two stages. They are divided by fuel  
18 load. Prior to fuel load, it is called the D-RAP, and  
19 after fuel load it doesn't have a name as a program.  
20 It comprises operational phase reliability assurance  
21 activities.

22 The reason we don't have a program is it  
23 would be redundant. We already have maintenance rule,  
24 IST, ISI, various programs in place, the QA program,  
25 that provide all the assurance we need to make sure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that these components are maintained as reliable  
2 throughout the plant's operating life, as they were  
3 assumed to be when we did the PRRA and the  
4 certification of the initial design. Next slide,  
5 please.

6 So we were looking at changes in the  
7 program, either the Westinghouse program or the COL  
8 applicant's program, and changes in scope. As I said,  
9 the changes in scope were primarily due to minor  
10 design changes. For example, the addition of a remote  
11 DAS station, so that manual actuation of containment  
12 isolation valves could be performed outside of the  
13 control room. This was added, because it was one of  
14 the ATWS criteria. There were -- Next slide, please.

15 There were no changes to the programmatic  
16 requirements. They, basically, as I said before, the  
17 same 18 points that you will see in Appendix B QA  
18 program, just slightly modified requirements for  
19 stringency. Next slide.

20 Some of the other items -- some  
21 containment isolation valves were added, check valves  
22 in the normal heat removal system, and some non-1E  
23 alternating current buses. Next slide, please.

24 In the COL stage, there have been no  
25 deviations from the DC program. We did make sure that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there was a plant-specific QA program treating the  
2 RTNSS added to each COL's FSAR in Section 17.5 where  
3 the entire QA program is addressed.

4 That was all I prepared on this. If there  
5 is anything else you would like to know about the DC  
6 or COL applicants as far as their RTNSS programs?

7 CHAIRMAN RAY: Well, when you talk about  
8 changes, you are talking about changes associated with  
9 the amendment to the CD?

10 MR. PATTERSON: Yes.

11 CHAIRMAN RAY: You are talking about COL  
12 changes -- what are we talking about?

13 MR. PATTERSON: Well, originally the COLs  
14 had said we are incorporating the Westinghouse D-RAP  
15 by reference. Unfortunately, that was Westinghouse's  
16 QA program, and the licensee has to have  
17 responsibility for their QA program. So it was  
18 necessary to get them to amend their initial  
19 applications so that the COL made it clear that it was  
20 a COL-specific QA program that was being used to  
21 address RTNSS.

22 CHAIRMAN RAY: You are talking about  
23 changes from the initial application as a part of the  
24 review process?

25 MR. PATTERSON: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Not change from something  
2 else?

3 MR. PATTERSON: Right. Well, it was a  
4 change from the DC. The DC didn't address the QA  
5 program that the COLs were going to have to apply in  
6 the future.

7 CHAIRMAN RAY: Okay. But it is change in  
8 a different sense. In any event, I understand what  
9 you are saying.

10 Okay, any questions on RTNSS? We have had  
11 a lengthy review of the generic as well as the  
12 specific application.

13 Anything, John, that you want to add to  
14 our list, to-do list here associated with your  
15 queries?

16 MEMBER STETKAR: No. I need time to think  
17 more carefully about the rationale of all of this  
18 process. So i can't think of anything specific,  
19 Harold.

20 CHAIRMAN RAY: Okay. Well, the specific  
21 thing that came to my mind is I need to think, I  
22 guess, about the seismic Category 2 and what the heck  
23 it means.

24 MEMBER STETKAR: That is the one that  
25 bothers me the most, quite honestly, in terms of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 apparent -- I don't want to say -- apparent is too  
2 strong -- possible inconsistencies in terms of the  
3 criteria that used to populate the D-RAP list versus  
4 criteria that are used to, for example, apply seismic  
5 Category 2 design requirements to things. That, and  
6 to a lesser extent, environmental qualification.

7 I really need to think more carefully,  
8 because I think that there seems to be some very  
9 subtle distinctions being made -- let me put it that  
10 way -- about those decisions. It is not clear to me  
11 how they are made and how consistently they are  
12 applied, and what I am looking for is kind of a  
13 consistent process across all the new reactors. We  
14 are only talking about two designs right at the  
15 moment.

16 MR. CARUSO: I think it would be helpful  
17 to read the staff evaluations of RTNSS. I know for a  
18 fact in the ESBWR, because I was sort of the overall  
19 coordinator of it -- I am not a structural person, but  
20 the SER -- The review of the seismic Category 2 and  
21 how it was defined was very detailed, and there was a  
22 number of questions about loads and calculations, and  
23 it is really in depth. I think that might be helpful  
24 to go look at that, because I think that is where the  
25 rubber met the road, was in those technical reviews.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: Weidong, I think this is  
2 not a matter for Westinghouse at this point, but we  
3 need to somehow understand better as a committee what  
4 seismic Category 2 means in the context of RTNSS.

5 Okay. With that then, we are at the point  
6 where it is two o'clock. It seems prudent for us to  
7 proceed with what are called in the agenda for today  
8 RCP issues. Is that possible?

9 MS. MCKENNA: Yes, certainly.  
10 Westinghouse, you are prepared on the reactor coolant  
11 pump?

12 MR. SISK: Yes. Just a few minutes. We  
13 can put the presentation up, and we are prepared to  
14 talk about reactor coolant pump.

15 CHAIRMAN RAY: All right. Then we will  
16 take a break after that.

17 MR. SISK: Okay.

18 MR. CUMMINS: This is Ed Cummins. while  
19 we are waiting, I think it is only in the context of a  
20 subset of RTNSS, this post-72 hours, where you get  
21 into this seismic Category 2 issue.

22 CHAIRMAN RAY: It may be, Ed.

23 MEMBER STETKAR: I think, Ed, a little bit  
24 of what I am concerned about is, if you had done a  
25 real seismic risk assessment, you might find that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 seismically qualifying some of those RTNSS systems  
2 could help the seismic risk considerably.

3 So in terms of quantitative contribution  
4 to risk, one of those categories, had their been a  
5 real seismic risk analysis done, one of those  
6 categories might have led you to different decisions.

7 Absent that, it is not clear.

8 MEMBER BLEY: Harold, there is one thing I  
9 haven't quite wrapped my head around yet, and that is  
10 how these negotiations that occurred on AP600 on RTNSS  
11 and seismic have been, can be, ought to be translated  
12 into consistent policy. I haven't seen that gap  
13 crossed anywhere.

14 That doesn't apply here so much as that is  
15 a more generic issue for the staff.

16 CHAIRMAN RAY: Yes. We are mindful, of  
17 course, that AP1000 has been certified, and I think  
18 what was referred to the AP600 context was things that  
19 happened prior to that time.

20 MEMBER BLEY: Which set up the AP1000.

21 CHAIRMAN RAY: Correct. Our interest is  
22 in trying to make sure we understand that background.

23 MEMBER BLEY: How it ended up, if that is  
24 where we want to be in the end, and how that  
25 translates to the next one.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER STETKAR: I think the caution is  
2 that they were saying, well, right at the moment, we  
3 have AP1000 which is, in fact, a certified design, and  
4 ESBWR which is in the process of being certified.

5           Well, okay, I think what Dennis' concern  
6 and mine is also is that, if we can formalize that  
7 process a bit more, thinking into the future, perhaps  
8 there would be a third passive design proposed at  
9 sometime, and understanding that process a little bit  
10 better and the criteria that are used would be helpful  
11 rather than kind of renegotiating it as each new  
12 design comes in and we think about things a little bit  
13 differently.

14           CHAIRMAN RAY: Okay, fair enough. I was  
15 just trying to put it in the category that it is not  
16 on Westinghouse's to-do list at the moment. It has  
17 got to be something we begin at least with our own  
18 understanding of how we got where we are, so that we  
19 can draw from that any generic conclusions or at least  
20 the direction that we want to take.

21           So, Weidong, we will incorporate this last  
22 little bit of discussion in the same desire to  
23 understand seismic Category 2 better, given that  
24 Dennis' point is that let's bear in mind that that  
25 emerged from a whole set of negotiations over a long

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 period of time, and we probably need to understand  
2 that as a starting point anyway.

3           Okay, Reactor Coolant Pump Flywheel --  
4 what an interesting subject. Dale, we are looking  
5 forward to this, I think.

6           MR. SISK: Mr. Chairman, I was just going  
7 to suggest, we are ready, but I do want to caution  
8 that we are going to try to keep this presentation as  
9 nonproprietary. There are potential for us to go into  
10 a point where we may have to defer.

11           We certainly want to answer the questions,  
12 but we may defer those to a later point. I have asked  
13 Dale to just highlight when we start to step into a  
14 proprietary issue. Otherwise, we are looking forward  
15 to the discussion.

16           CHAIRMAN RAY: That is fair enough. So  
17 don't hesitate to tell us. We will have to go into  
18 closed session if we want to pursue a particular line,  
19 but at least from my standpoint -- I speak just for  
20 myself -- this is a matter of trying to learn from an  
21 experience, more than it is to question where you are  
22 today in terms of the design of this thing, but to  
23 look at it from the standpoint of what the experience  
24 should be able to tell us about all kinds of things  
25 that we get involved in when certifying design. So go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ahead, with that background.

2 MR. WISEMAN: I am Dale Wiseman from  
3 Westinghouse to talk about the flywheel, and really  
4 try to summarize all the changes that we have made  
5 between DCD, Rev. 15 and Rev 17. The particular  
6 questions were on materials and inspection  
7 requirements. That also leads us into a summary of  
8 our inertia changes, which we have talked about  
9 somewhat in the past, and our flywheel missile  
10 analysis summary.

11 MEMBER ARMIJO: Before you go too far,  
12 could you -- The original intent was to get a longer  
13 coastdown on your pump. I think that was why you  
14 increased the mass of that flywheel. At least, that  
15 is what I got out of some of your documents.

16 What were you trying to achieve as far as  
17 extending the coastdown of the pump by making a more  
18 massive flywheel?

19 MR. WISEMAN: When you say more massive,  
20 you mean --

21 MEMBER ARMIJO: Heavier.

22 MR. WISEMAN: -- between DCD's 15 and  
23 Seventeen?

24 MEMBER ARMIJO: Correct. Yes.

25 MR. WISEMAN: I will get into that, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basically it is the fact that, as we went through  
2 detail design and learned more about the losses inside  
3 the pump, we needed more inertia to meet the coastdown  
4 requirement that was in the design spec, to start  
5 with.

6 So it was essentially adding inertia to  
7 meet the design requirement in the pump.

8 MEMBER ARMIJO: Could you put that in  
9 units of time, like minutes?

10 MR. CUMMINS: This is Ed Cummins. It is  
11 flow. What we want is a flow curve which matches the  
12 power decay for the curve when you trip. So if the  
13 flow was somehow behind the power, then your power to  
14 flow would mismatch, and you would have core problems.

15 So we want a flow close down-curve on loss of AC  
16 which matches the power curve of a trip. That is  
17 concept.

18 MEMBER ARMIJO: Okay. That is what you  
19 were doing with this?

20 MR. CUMMINS: That is what the inertia is  
21 for.

22 MEMBER ARMIJO: Okay.

23 MEMBER BONACA: Suppose you have minimum  
24 DMB before.

25 MR. CUMMINS: Sure.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: Do you have a volume for  
2 it?

3 MR. WISEMAN: Yes. The limiting event  
4 that really drives the inertia or the coastdown  
5 requirements is for complete loss of flow, and that is  
6 part goes into the -- The ultimate is to meet the DMBR  
7 margins, and that -- In the complete loss of flow,  
8 that all critical part happens three to four seconds  
9 after you lose your flow. So the critical part of the  
10 coastdown is in the first six to eight seconds, to  
11 give you a time frame.

12 MEMBER ARMIJO: Okay.

13 CHAIRMAN RAY: But we got -- All of us  
14 have little things that we want to get to, but I keep  
15 asking myself, why is this a change in the certified  
16 design, and why isn't this just part of the  
17 implementation of the certified design? So answer  
18 that as you go along here, would you. What is it that  
19 you had to change in the certified design in order to  
20 achieve what I think we all understand to be the  
21 requirements that you are trying to meet?

22 MR. WISEMAN: Okay. Just to start to  
23 orient everyone, there are two flywheels in the AP1000  
24 reactor coolant pump, the upper flywheel assembly  
25 between the upper radial bearing and the impeller, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then the lower flywheel assembly that is located in  
2 between the upper and lower truss bearing.

3 MEMBER ARMIJO: One is bigger. I am just  
4 looking at the sketch there.

5 MR. WISEMAN: They are both the same  
6 diameter. The upper is longer.

7 MEMBER ARMIJO: Okay.

8 MR. WISEMAN: This summarizes the change,  
9 really, from DCD Rev 15 to 17 in the flywheel design.

10 The DCD Rev 15 was based on a depleted uranium alloy  
11 flywheel using depleted uranium for the heavy metal in  
12 the flywheel.

13 This was a carryover from AP600. This was  
14 the original design on AP600, and it has -- The  
15 depleted uranium was enclosed in an alloy 690  
16 enclosure, but the uranium itself was the structural  
17 component of that design.

18 In Rev 17 -- and I have a slide discussing  
19 the reasons we made all these changes following here.

20 So this is just to show you the two designs. We went  
21 to the -- We got rid of the depleted uranium for  
22 various reasons, which we will discuss, went to heavy  
23 tungsten alloy insert, as you see.

24 There is an inner hub that is shrunk onto  
25 the shaft. The tungsten alloy inserts are then shrunk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 between the hub and this outer retaining ring. So the  
2 retaining ring and the inner hub become the structural  
3 components. The tungsten alloy or the heavy metal, in  
4 this case, is no longer a structural component in this  
5 design.

6 MEMBER ARMIJO: They are segmented.  
7 Right?

8 MR. WISEMAN: They are segmented.

9 MEMBER ARMIJO: So they are just held by  
10 the retaining ring against the hub.

11 MR. WISEMAN: Onto the hub. That is  
12 correct. Here are the flywheel materials as they  
13 evolved from DCD 15 through 17, and actually one step  
14 beyond Rev 17.

15 We include in a response to some RAIs on  
16 the reactor coolant pump materials. Back in May 2009  
17 we included a change to the retainer ring beyond the  
18 Rev 17 design. But the shaft is stated as 403  
19 stainless steel. The inner hub is also 403 stainless,  
20 and as you can see here, from 15 to 17 the actual  
21 heavy metal has gone from depleted uranium to tungsten  
22 alloy.

23 The retaining ring was initially 18 nickel  
24 maraging steel. That has recently been changed to  
25 this chromium, 18 manganese material, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enclosure, which is not a structural part but is to  
2 seal all those internal components from the reactor  
3 coolant, was originally alloy 690 and was changed to  
4 alloy 625.

5 MEMBER ARMIJO: Why were those changes  
6 made, both for the enclosure and the retainer ring?

7 MR. WISEMAN: Can you wait two slides,  
8 because I go through all the reasons here.

9 MEMBER ARMIJO: Sure.

10 MEMBER ABDEL-KHALIK: Is there a  
11 difference in the thermal expansion coefficient  
12 between --

13 MEMBER ARMIJO: Yes, big differences.

14 MEMBER ABDEL-KHALIK: -- the tungsten and  
15 the material of the inner hub?

16 MR. WISEMAN: The tungsten, yes. there is  
17 some difference. It is not huge, but there is some  
18 difference, yes.

19 MEMBER ABDEL-KHALIK: Can you translate  
20 that into a change in radial dimension as you go from  
21 cold shutdown to hot standby?

22 MR. WISEMAN: No, I can't. I can't off  
23 the top of my head tell you how much difference that  
24 makes. But one of the changes to the enclosure was to  
25 better match thermal coefficient expansion

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 coefficients going from the 690 to the 625. So that  
2 has all been part of the design effort.

3 MR. CUMMINS: This is Ed Cummins. Dale,  
4 the operating temperature of the inertia is not  
5 reactor cooling system operating temperature. It is  
6 something lower than that.

7 MR. WISEMAN: Well, that is true. The  
8 flywheel normally operates in the 300 degree range,  
9 but there is still -- Right. There is still an  
10 effect of the heatup, certainly. Yes.

11 MEMBER ABDEL-KHALIK: Was that part of the  
12 analysis, figuring out what the thermal stresses  
13 associated with the change in the differential  
14 expansion?

15 MR. WISEMAN: Yes.

16 MEMBER ABDEL-KHALIK: What is the  
17 contribution of that, during the heat up?

18 MR. WISEMAN: I can't tell you. I don't  
19 know that detail of the analysis. We could find that  
20 out. I can't tell you.

21 MEMBER ARMIJO: There is a report that the  
22 staff provided us, a Curtiss-Wright report that was  
23 done, that has a lot of that information on thermal  
24 expansions and the stresses and all of that.

25 MR. WISEMAN; Yes. That Curtiss-Wright

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 report has both the structural and the thermal effects  
2 and the resulting stresses.

3 So as to the reasons for some of these  
4 material -- for all these material changes: In the  
5 change from depleted uranium to heavy tungsten, the  
6 real driver here was the fact that it was determined  
7 that our losses in the pump were significantly higher  
8 than we had originally anticipated. So we needed to  
9 add inertia.

10 MEMBER ARMIJO: Was that the result of a  
11 test pump or some experiments or just --

12 MR. WISEMAN; No. At that time, it was  
13 the result of more detailed calculation and reviews  
14 that revealed some losses that weren't adequately  
15 accounted for.

16 So the most efficient way to get inertia  
17 is to increase the diameter of the flywheel, but if we  
18 increased the diameter of the depleted uranium, since  
19 it was a structural component, we were getting  
20 stresses that were exceeding the allowables in the  
21 uranium.

22 If we made the flywheels longer to get  
23 sufficient inertia, we ran out of space we have for  
24 the pump. So at that point it was determined we  
25 needed to find a different material, and the tungsten

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 alloy has almost exactly the same density as the  
2 depleted uranium, and it has many advantages over the  
3 depleted uranium also. Some are listed here.

4 By the time we were working on AP1000, the  
5 depleted uranium vendors had pretty much disappeared  
6 compared to when we started on AP600, and the fact  
7 that the tungsten alloy has ASTM specs and you don't  
8 have to have permits to handle it, and it is not an  
9 environmental issue. So there were lots of things  
10 that said it is time to move away from depleted  
11 uranium.

12 At the same time, looking at the  
13 configuration, it was determined it would be better to  
14 not have the heavy metal as the structural component.

15 So that is when the made the configuration change to  
16 add the inner hub and the retaining ring, and the  
17 tungsten alloy essentially sits in between the two.

18 The flywheel enclosure changed from 90 to  
19 625, as I mentioned earlier. There were really two  
20 reasons driving that. The 625 has a lower coefficient  
21 of thermal expansion which better matched the  
22 components inside the enclosure. it also has a higher  
23 yield strength, and it is really easier to weld. So  
24 that was the driver to go to 625.

25 The retaining ring --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER ARMIJO: Before you go on, did you  
2 consider the 625 and the 690 equivalent from a  
3 standpoint of possible stress corrosion cracking  
4 problems in the coolant environment?

5           MR. WISEMAN: To my knowledge, there  
6 wasn't much difference between the two in that regard.  
7 That was not indicated as a strong driver by EMD.  
8 They were both considered to be--

9           MEMBER ARMIJO: Are there test data or  
10 experimental data that kind of justifies that belief?

11          MR. WISEMAN: I don't know for sure. I  
12 know that we have used some 625 in some of our fuel  
13 assembly nozzles without any --

14          MEMBER ARMIJO: Maybe Bill knows, but I  
15 have seen a lot of test data on 690.

16          MEMBER SHACK: Well, there is a whole lot  
17 less, but I mean, the 625 performance has been fairly  
18 good. It is much more limited, but I don't know that  
19 -- I can't recall problems with it. People use it  
20 when you need high strength alloys, and it has worked  
21 reasonably well.

22          MEMBER ARMIJO: Yes. It seems, 690, we  
23 know so much more about.

24          MEMBER SHACK: Yes. You certainly have a  
25 lot more data on 690. No question about it, but again

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this is at 300. You know, you are down in  
2 temperature.

3 MEMBER ARMIJO: Yes. Some of the analyses  
4 in the -- and I don't know if these are in the  
5 Curtiss-Wright report -- go up to 400 and in some  
6 cases even a little bit higher. So I don't know what  
7 the actual -- That may be the mean operating  
8 temperature. What would your sustained highest  
9 operating temperature be? Is it really 300?

10 MR. WISEMAN: The nominal is in the 300,  
11 low 300 range. there is some gradient through the  
12 flywheel.

13 MEMBER SHACK: I mean, you take a steam  
14 generator from 600 to 550, and you buy one heck of a  
15 lot. So going from 550 down to 400, I would suspect  
16 it.

17 MEMBER ARMIJO: You're right.

18 MR. WISEMAN: So the retaining ring change  
19 -- When we first added the retaining ring, we were  
20 using the 18 nickel maraging steel because of the  
21 desire to have the highest high strength, and there  
22 was a flywheel mock-up done. It was a full diameter,  
23 but not as long as the actual mock-up. It was done  
24 really for manufacturing -- confirming manufacturing  
25 procedures and assembly procedures and to be able to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 demonstrate that it could be balanced.

2 In the course of that program, we had the  
3 retainer ring crack, and the subsequent investigation  
4 revealed that during the machining processes there was  
5 some water introduced into the assembly, and as a  
6 result we had hydrogen-assisted stress corrosion  
7 cracking.

8 Initially, Curtiss-Wright went back  
9 through their manufacturing procedures to eliminate  
10 moisture, but no one was really comfortable with that  
11 risk moving forward. So we started looking at a  
12 material change for the retainer ring.

13 This is the material change we included in  
14 a response to an RAI in May of 2009 to the staff. It  
15 was an RAI that was related to materials in the  
16 reactor coolant pump. That is when we included this  
17 change.

18 The change was to an 18 chrome-18  
19 manganese material, which was a material that was  
20 developed for retaining ring applications in  
21 generators, essentially for the same kind of reasons,  
22 the cracking in the existing material.

23 This material has been shown not to be  
24 susceptible to corrosion or hydrogen-assisted stress  
25 corrosion cracking. Its drawback is that it doesn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have the strength of the 18 nickel maraging. So it  
2 means that in the -- Since we are limited in overall  
3 space, we needed a little thicker retainer ring, takes  
4 a little bit off of the tungsten alloy mass.

5 MEMBER ARMIJO: How much do you know about  
6 this? How much actual experience is there with this  
7 18 chrome-18 manganese? This is very unusual  
8 stainless steel. People don't normally add that much  
9 manganese to stainless steel.

10 I did do a little bit of reading on the  
11 change for the generator problem, the cracking of the  
12 generator problem. It is not clear to me what the  
13 real root cause is. Maybe it is hydrogen  
14 embrittlement, but in your application it should be  
15 dry.

16 If it is manufactured properly, as long as  
17 those outer containers keep the coolant out of it, it  
18 should be dry, but in the event it doesn't, small  
19 leaks or something in your enclosure, yo know, you've  
20 got -- for these kinds -- and it is a high stress on  
21 that component. You've got -- I just wonder if you  
22 have done any testing to demonstrate that this stuff  
23 won't crack in a kind of a violent manner in the event  
24 you get a leak in these enclosures.

25 I don't know how often you would inspect

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those enclosures to make sure they weren't leaking.

2 Would you ever know?

3 My question is: What do you know about  
4 this material with respect to a stress corrosion  
5 cracking susceptibility or hydrogen embrittlement  
6 susceptibility in the environment that might occur if  
7 those enclosures had any kind of leaks?

8 MR. WISEMAN: My understanding is there  
9 has been testing. There has been some testing done as  
10 far as looking at susceptibility to stress corrosion  
11 cracking.

12 MEMBER ARMIJO: Was that done by  
13 Westinghouse or for this?

14 MR. WISEMAN: No, it wasn't done for this  
15 particular application.

16 MEMBER ARMIJO: For the environment that  
17 you are going to be in. That is really -- You know,  
18 stress corrosion cracking is so specific to the  
19 environment. If somebody has done some fluoride  
20 stress corrosion cracking test somewhere else, doesn't  
21 mean that it will in your environment.

22 So you said you don't have any data like  
23 that?

24 MR. WISEMAN: I personally don't have any  
25 of that data. Curtiss-Wright has indicated that they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have some test data. We could look into getting that.

2 MEMBER ARMIJO: I would sure like to see  
3 it, if it is available.

4 MR. WISEMAN: This slide summarizes our  
5 inertia changes that we have talked about in the past.

6 So in DCD 15 we had a rotating inertia of 16,500  
7 pounds per square foot, and it was between Rev 15 and  
8 Rev 17 that we determined that we needed sufficient --  
9 quite a bit more inertia.

10 This is the 15 to 17 change. Going back  
11 to how this changes the licensing, there was a -- or  
12 there still is an ITAAC in Rev 15 that was to show  
13 that you had a certain amount of inertia, 16,500 or  
14 greater.

15 As we got into looking at the -- reviewing  
16 our losses and learning more about our losses, it  
17 became obvious that that ITAAC wasn't really  
18 sufficient.

19 CHAIRMAN RAY: Well, but, Dale, that is  
20 what I was saying in the beginning. To me, maybe one  
21 of the lessons here is that the ITAAC should have said  
22 you need to show that you have sufficient inertia.

23 I sit here wondering why are we going  
24 through all of this detail which, clearly, you would  
25 expect you guys would go through, but why are we going

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through it?

2 If the ITAAC, in the first place, had said  
3 not 16,500 but sufficient inertia to demonstrate that  
4 you will match the flow required, well, why wouldn't  
5 that have been okay? Now that is a rhetorical  
6 question you maybe don't want to answer, but that is  
7 what I am wondering anyway.

8 MR. WISEMAN: Well, that is essentially  
9 what we changed the ITAAC to in Rev 17. It said that  
10 you had to --

11 CHAIRMAN RAY: You are not going to come  
12 back in here and tell us about the next dadgum change  
13 you make, huh, I suppose?

14 MR. WISEMAN: Only if I am asked.

15 CHAIRMAN RAY: Well, I am being a little  
16 facetious here, but really, this is a lot of detail,  
17 but it is the kind of thing I would expect to have  
18 happen as you go forward. I just don't know why we  
19 don't specify what the performance requirement is.

20 MEMBER ARMIJO: I wasn't so interested in  
21 the fact that the ITAAC was improperly written as it  
22 was a change in a material, which I am always  
23 suspicious about, to a material that is a rather  
24 unusual structural member and, if it comes apart, it  
25 is going to give you a bad day.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have looked at your other analysis and  
2 your other slides, and I agree. You've got plenty of  
3 margin getting past the casing, but it is still not --  
4 It wouldn't be good in use for the plant.

5 So I just was trying to find out if you  
6 had really considered and run test programs, something  
7 to check the environmental -- the performance in a  
8 deteriorated environment. If it was perfectly dry in  
9 there and that 625 couldn't leak or you can inspect it  
10 periodically, show that it wasn't leaking, you know, I  
11 don't have any problem. It is just another material.

12 But this is a very unusual material.

13 CHAIRMAN RAY: Well, I wasn't meaning to  
14 say that the only thing you needed to know about it in  
15 the certification was the inertia requirement because,  
16 clearly, the failure modes and effects are important.

17 I don't think the reliability, as  
18 important as that is -- and I was deeply involved in a  
19 plant in Colorado that failed because of the  
20 circulators not being reliable. So I know how  
21 important it is to you all, but -- Anyway, I have  
22 said enough. Go ahead.

23 MR. WISEMAN: Okay. So the -- As I  
24 mentioned, the space for the tungsten heavy alloy was  
25 reduced slightly when we went to the new retaining

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ring material. So the inertia, as you can see here,  
2 decreased slightly. We still have margin in our  
3 coastdown curve to what is required to meet our  
4 minimum DMB requirements.

5 As far as inspection, there are -- We  
6 essentially impose during fabrication the inspection  
7 requirements from NB-2500. This is along the  
8 guidelines of Reg Guide 1.14. We take exception to  
9 some of those, because this is not a steel plate  
10 flywheel, but we are trying to live to the spirit of  
11 that Reg Guide by imposing the 2500. So the inner hub  
12 has an ultrasonic exam, mag particle, and after final  
13 machining a liquid penetrant examination of the inside  
14 surface.

15 The retainer ring has a PT, a UT, and then  
16 again after the final machining the outside surface is  
17 examined.

18 The enclosure: Again, it is a non-  
19 structural member but, obviously, the integrity of the  
20 welds is important. We do a dye penetrant of the  
21 welds, and there is a helium leak test performed on  
22 the flywheel enclosure after it is assembled.

23 There is mechanical testing of the inner  
24 hub and retainer ring material, and essentially there  
25 are no in-service inspection requirements. The key to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that is the fact that our flywheel missiles -- if  
2 there would be a flywheel missile, it would be  
3 contained within the pressure boundary and would not  
4 penetrate the pressure boundary.

5 In-service inspection of the flywheel  
6 would require a pump disassembly and a flywheel  
7 disassembly, really, to get to the structural parts.

8 CHAIRMAN RAY: Basically, you have to be  
9 able to survive a failure of the flywheel, try to  
10 avoid it, but if you can survive it, then that is the  
11 only way you can get by without in-service inspection,  
12 which has all these drawbacks.

13 MEMBER ABDEL-KHALIK: Is it proprietary to  
14 talk about the specific tungsten alloy that you are  
15 using?

16 MR. WISEMAN: It is in ASTM.

17 MEMBER ABDEL-KHALIK: How brittle is this  
18 tungsten alloy?

19 MR. WISEMAN: I think the fracture  
20 toughness requirements is like 35. It is -- I would  
21 say it is on the brittle side.

22 MEMBER ARMIJO: It is segmented. So it is  
23 not a structural member. These are a bunch of segments  
24 that are put around.

25 MEMBER SHACK: Just chunks.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER ARMIJO:     They are just chunks,  
2     right.  So they are not doing any structural --

3                   MEMBER ABDEL-KHALIK:        The fracture  
4     toughness you would worry about is the retaining ring,  
5     yes.

6                   CHAIRMAN RAY:  They may have missed it.  I  
7     think -- Are we going to talk about that analysis,  
8     because that, to me, is the only thing that is  
9     important to hear.  If the retaining ring fails, then  
10    what?

11                  MR. WISEMAN:  That was my next slide.  I  
12    think in your handout -- Just before I forget, I think  
13    there as a mistake here on the retainer ring for DCD  
14    17.  As you can see up here, it is AMS 6519.  I think  
15    your handouts may say ASTM.  So that was -- We didn't  
16    get that corrected in the handouts.

17                  So the flywheel missile analyses -- and  
18    these reports on this missile analysis and the stress  
19    analysis of the flywheel have been submitted to the  
20    staff, and it is basically following the procedure of  
21    what they look at in turbine disc fractures, and it is  
22    Hagg and Sankey semi-empirical method which looks at  
23    two different stages of penetration, the first  
24    inelastic impact and transfer of momentum, and then  
25    dissipation of the rest of the energy of the missile

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in plastic tensile strain.

2 So in these calculations we take a pretty  
3 conservative approach in ignoring anything with the  
4 enclosure or the retaining ring. Assume the retaining  
5 ring has failed, obviously.

6 For the pressure boundary components that  
7 we look at, take the minimum ASME material properties  
8 assumed that at the design temperature. So it is a  
9 higher temperature than it would be normally  
10 operating. We assume all the heavy alloy segments  
11 impact the pressure boundary.

12 The upper flywheel essentially impacts the  
13 stator closure and the thermal barrier material, and  
14 if you look at the upper region there, there's several  
15 --

16 CHAIRMAN RAY: Can you go back to this  
17 picture for a second?

18 MR. WISEMAN: You can see, there's several  
19 lengths of -- This is the material over here, and we  
20 take a conservative thickness that doesn't even -- if  
21 you look at this ring in here, it is probably the  
22 thinnest material. What is actually used in the  
23 analysis goes back to this where we have a little step  
24 change there.

25 So just to say that it is a -- We tried to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 take very conservative assumptions into what the  
2 pressure boundary thickness is when we do these.

3 The margins that we have -- When we talk  
4 about margins, what we are saying here is margin is  
5 the energy required to fail the pressure boundary, to  
6 penetrate the pressure boundary divided by the energy  
7 that is in one of these missile fragments.

8 CHAIRMAN RAY: And we talked about this  
9 last time you were here, and I can't remember the  
10 answer. My bigger concern is creating a path from a  
11 rad coolant system through the cooling service water,  
12 whatever it is referred to as the cooling supply to  
13 the pump.

14 Now as I recall, you said that wasn't  
15 possible, not credible.

16 MR. WISEMAN: No.

17 CHAIRMAN RAY: Loss of Coolant Accident, I  
18 don't worry about so much as I do pressurizing the  
19 cooling system with reactor coolant.

20 MR. WISEMAN: The missile would come off  
21 here, which would stop short of hitting the heat  
22 exchanger, and I guess I am not sure what your concern  
23 is beyond the heat exchanger.

24 CHAIRMAN RAY: Well, that you would get a  
25 path that would -- Instead of just loss of coolant to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the containment, you would get a pathway into the heat  
2 exchanger and thereby into the cooling water system.  
3 In other words, it would rupture but not only the rad  
4 coolant pressure boundary but the heat exchanger. Not  
5 possible?

6 MR. WISEMAN: I don't see how. The heat  
7 exchanger -- This piping is all -- This is the high  
8 pressure piping, and the tubes in the heat exchanger  
9 are the high pressure reactor coolant pressure  
10 boundary here, but the flywheel will be contained back  
11 in -- Any fragment would be contained back here.

12 CHAIRMAN RAY: That is what I seem to  
13 recall, was you said it was not a credible -- There is  
14 no missile that can penetrate to the heat exchanger  
15 cooling coils.

16 MR. WISEMAN: No. No, you can't get to  
17 the heat exchanger tubes. You can, obviously, block  
18 the cooling flow to the heat exchanger, but--

19 CHAIRMAN RAY: I am really just worrying  
20 about the one thing that I mentioned, which was that  
21 there is no credible missile impact on the heat  
22 exchanger.

23 MR. WISEMAN: No, because the heat  
24 exchanger is all outside the pressure boundary of the  
25 pump central here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER BLEY:     If that is what you are  
2 worried about, Harold, I don't know what that heat  
3 exchanger looks like internally, but this thing  
4 probably goes through some pretty violent shaking if  
5 this should happen. So you might break some of those  
6 tubes, and then you would have the situation maybe.

7           CHAIRMAN RAY:    I don't know.

8           MEMBER BLEY:     You still wouldn't.

9           CHAIRMAN RAY:     That is a different  
10 question of what dynamic effects.

11          MEMBER ARMIJO:     Let's just say  
12 hypothetically one of these things failed. It would  
13 bring your pump to an immediate stop, and what  
14 accident analysis have you done that addresses the  
15 consequences of that event? What kind of event is it?  
16 Is it one of those infrequent?

17          MR. WISEMAN:     It would be like a locked  
18 rotor event.

19          MR. CUMMINS:     Ed Cummins. Probably it is  
20 a Class B accident, and it is basically a seizing of  
21 one of the pumps. So it absolutely stops, and that is  
22 the worse thing you can do, which won't happen here.

23          MEMBER ARMIJO:    You still have the other  
24 pump going on that generator, and you've got three  
25 other pumps cooling.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CUMMINS: Three other pumps, but you  
2 get a trip, and it is a challenging accident.

3 MEMBER ARMIJO: And you've had a bad day.

4 CHAIRMAN RAY: I would worry about the  
5 attachments to the steam generator, but that is also  
6 beyond our scope here. That much rotating mass all of  
7 a sudden stopping -- geez, I don't know what it would  
8 do to the attachments, but it would be a mess.

9 MR. WISEMAN: That is part of our  
10 analysis, yes.

11 MEMBER ARMIJO: You know, this is -- I  
12 got interested in it because of the change of the  
13 materials at this stage of the game and the fact that  
14 this retaining ring, which I think is the key issue,  
15 is an unusual material, that it is not well tested,  
16 and although the safety analysis on the penetration of  
17 the shell - you've got plenty of margin there.

18 I just seem to think that there is -- with  
19 a new material, unless you test it, you've got some -  
20 -I have some concerns, but it is not in the sense of a  
21 safety concern, but I would test it.

22 CHAIRMAN RAY: Is that it, dale?

23 MR. WISEMAN: Yes, other than just to say  
24 that the minimum margins that we are showing for our  
25 current design are like 1.8, a factor of two for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 penetrating the pressure boundary.

2 CHAIRMAN RAY: Yes, like I said,  
3 penetrating the pressure boundary is one thing. The  
4 dynamic effects of seizing the rotors and other --  
5 After the break, we will take up and devote the rest  
6 of -- most of the rest of today anyway, there's two  
7 other items to talk about, to our action item list.

8 This is one item that is on there from my  
9 standpoint. I am satisfied by this presentation. The  
10 other members speak for themselves. So we, I think,  
11 have addressed the concern that I had. So appreciate  
12 it, Rob.

13 MR. SISK: Glad we could solve an issue.

14 CHAIRMAN RAY: I am only speaking for  
15 myself at this point.

16 In any event, we will take a break,  
17 please, until three o'clock, at which time we will  
18 take up, with Eileen's help, the list of action items.

19 I remind everybody that at this point we  
20 are down to -- on both the COL and the DCD, down to  
21 the point where we only have for the initial pass 3.7,  
22 3.8, and Chapter 6 of the DCD itself to go, which is  
23 not to say we are done, but we will be working a good  
24 deal off the action item list after this. That is why  
25 it is important to get it straight. Three o'clock,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 please.

2 (Whereupon, the foregoing matter went off  
3 the record at 2:46 p.m. and went back on the record at  
4 3:00 p.m.)

5 CHAIRMAN RAY: Okay, thank you. We are  
6 going to resume here now. The next event is going to  
7 be real sausage making, and I need my sausage maker  
8 over here. Where is Weidong? So I have to fill time  
9 until he shows up, I guess.

10 In any event, this is the fourth two-day  
11 meeting that we have had to date, and Mike Lee  
12 originally and now Weidong is responsible for keeping  
13 this list that we have in front of us here for the  
14 ACRS staff.

15 WE match it with the list that Eileen  
16 keeps, which is perhaps a little bit longer list, and  
17 I think that is really what we are looking at here, is  
18 Eileen's list. But in any event, they are compared to  
19 try and make sure that we are keeping track of the  
20 items that are raised during subcommittee meetings.

21 At this point or perhaps after the final  
22 increment of initial review, we will want to  
23 deliberate at the full Committee about whether we  
24 simply continue on from that point as final SERs are  
25 developed or whether we have something we want to say

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as a full Committee as a result of this review.

2 So in order to get ourselves in the  
3 position to do that, we need to go through this action  
4 item list and try and make sure that it accurately  
5 reflects what we believe, and we aren't sending people  
6 off to chase wild goose chases after things that we  
7 are really not needing to pursue further.

8 So anyway, what we see here in front of us  
9 in this table I would like to go through now with you  
10 and see if there are inputs that anyone wishes to  
11 make, either by saying that is the wrong issue or that  
12 is not what I said or we ought to add something to it,  
13 or we have heard enough, we don't need to pursue this  
14 any further, in which case there will be a little  
15 applause in the back which we can ignore.

16 So unless anybody has anything they would  
17 like to add to what I have said, I would like to spend  
18 whatever time it takes. I think we have enough time  
19 now to go through these items here. Like I say, they  
20 reflect input by NRO which Eileen is responsible for,  
21 as well as initially Mike Lee and subsequently  
22 Weidong. I have had a little bit of input to them as  
23 minutes for the meetings have been prepared.

24 Okay. With that, let's see how it works.

25 Item 1: The action item is to get more discussion of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how generic issues are addressed since Rev 15. An  
2 example given there is GSI-191.

3 Again, let me say one more time, the  
4 wording here may be way off base, given that this goes  
5 way back to July, and maybe we are smarter now or we  
6 have a better idea of what it is that is the question  
7 we are trying to get answered. So we want to try and  
8 fix that now, if that is appropriate.

9 So Item 1: Anybody have any comment they  
10 want to make? Do they think we have learned what we  
11 need to about how generic issues are being addressed?

12 We heard about 191 here today. We were told that it  
13 will be resolved for AP1000 as part of this amendment  
14 process. Anybody want to hear anymore about how  
15 generic issues have been addressed since Rev 15?

16 Eileen, is there any reason to keep this  
17 item on the list?

18 MS. MCKENNA: I don't think so. I think  
19 we've -- My view is we were kind of touching on this  
20 by examples, by GSI-191. That is a case. Obviously,  
21 the gas intrusion, the Generic Letter; that is a  
22 case.

23 This really was dealing with those more  
24 recent kinds of events, because up to time of  
25 certification, of course, all generic issues and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Generic Letters and bulletins have been discussed. So  
2 this was really focusing on anything new that really  
3 needed to be handled. I think we are handling them.

4 CHAIRMAN RAY: Does anybody object to  
5 taking it off the list? Okay, done.

6 Item 2: We just this afternoon had a  
7 discussion about non-condensable gases. Are we done,  
8 do you think?

9 MEMBER ABDEL-KHALIK: No. I think the  
10 discussion that was presented today was very good. It  
11 is a work in progress, but I think we need to hear the  
12 full story.

13 CHAIRMAN RAY: All right. Do you want to  
14 change this in any way or do you think the wording  
15 here is fine?

16 MEMBER ABDEL-KHALIK: This is fine.

17 CHAIRMAN RAY: All right.

18 MR. SISK: Just a clarification. What I  
19 am hearing is that we have given you the in-process.  
20 You would like for us to come back at the end and give  
21 you kind of a report on what we finalized. Is that  
22 what I am hearing?

23 MEMBER ABDEL-KHALIK: I think that would  
24 be a reasonable interpretation. I think the issue  
25 that came up was, well, have you done the heat-up

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis, for example. Assuming that the entire line  
2 is voided, what the consequences of that would be.

3 If it turns out that the consequences are  
4 tolerable, then maybe the issue would go away, but  
5 nothing that has been presented so far would tell me  
6 that the issue has gone away. In fact, the material  
7 reinforces the fact that this is an important issue  
8 that needs to be resolved.

9 MR. SISK: No problem. Just wanted to be  
10 clear. Thank you.

11 CHAIRMAN RAY: All right. Then we will  
12 reword the --

13 CONSULTANT WALLIS: There is really no way  
14 to fix it, too. I mean, there is really no way you  
15 can do something with that piping arrangement.

16 MEMBER ARMIJO: Can't engineer that  
17 problem away. Yes.

18 CHAIRMAN RAY: We will change the action  
19 which reflects what occurred today to reflect what  
20 Said just said in some way, something about at the  
21 conclusion of the ongoing analysis, we would like a  
22 report, and so on.

23 Item 3: RTD relocation. Is there any  
24 impact on the dead band for rod control? Are there  
25 any upper half -- or are they at the upper half or top

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the hot leg?

2 I recall this discussion. My name is on  
3 here. So that reflects that I was --

4 MS. MCKENNA: Mr. Chairman, I will just  
5 comment. What we try to do is go back in some cases  
6 and look at the transcript and our notes to see which  
7 members we thought raised these issues. Again,  
8 sometimes somebody raised it once, and then later in  
9 wrap-up somebody else raised a similar issue. So I  
10 won't swear that we have 100 percent, but we did our  
11 best.

12 We focused on the ones where we thought  
13 there was still something open. You will see, in some  
14 cases we didn't fill it in yet, but that was the  
15 intent, was to try to reflect which member we thought  
16 had --

17 CHAIRMAN RAY: We don't take it as an  
18 accusation. Anyway, the idea is that it was closed at  
19 the October meeting. That is my recollection also,  
20 but if there is anything we further we want to pursue  
21 -- I think you had the main lead on questioning this.

22 All right, let's consider it to be closed  
23 and take it off.

24 Flywheel design, something we just heard  
25 more about: Sam, do you want to hear more yet?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER ARMIJO: Well, this is just free  
2 advice to Westinghouse. I just think that material  
3 for that retainer ring hasn't been adequately tested.

4                   At least, I haven't seen the data, and it could cause  
5 you a lot of grief.

6                   CHAIRMAN RAY: Well, you did ask for some  
7 information about that testing, didn't you?

8                   MEMBER ARMIJO: Yes. Maybe Curtiss-  
9 Wright, and they have got test data, but I kind of  
10 suspect they don't. But if they have it, it would be  
11 great to see it.

12                   The other thing is all the possible things  
13 that could -- A pump failure like that could cause all  
14 sorts of other problems. I just don't know if they  
15 have really been thought through.

16                   CHAIRMAN RAY: It was my understanding  
17 from what Dale said that pump seizure, basically --  
18 use Ed's term -- is analyzed, an analyzed condition.

19                   MR. CUMMINS: Chapter 15, condition 4.

20                   MEMBER ARMIJO: That may be the case and,  
21 if that is the case, then I don't have a problem with  
22 that.

23                   MEMBER BONACA: Some fuel in DMB is  
24 allowed.

25                   CHAIRMAN RAY: Sir?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: And some fuel in DMB is  
2 allowed.

3 CHAIRMAN RAY: All right. I am only  
4 concerned that there is some gap in the analysis, but  
5 if it is an analyzed event --

6 MEMBER ARMIJO: If the staff is in  
7 agreement with that, I don't have a problem.

8 CHAIRMAN RAY: Anybody want to keep this  
9 on the list for any reason?

10 CONSULTANT KRESS: I would still like to  
11 see how it is treated in the PRA, the frequency. I am  
12 not sure we have a good value for the frequency of  
13 seizure, the failure in this category.

14 CHAIRMAN RAY: Okay. Anybody -- Eileen or  
15 Westinghouse either -- have any comment on what Tom  
16 said?

17 MR. SISK: Just a clarification. What you  
18 are asking for is for the flywheel failure in PRA or  
19 are you looking for locked rotor in PRA?

20 CONSULTANT KRESS: Locked rotor.

21 CHAIRMAN RAY: All right. Well, let's  
22 narrow it down then just to that as an issue. Either  
23 make a new action item out of it or revise it  
24 accordingly, because I think we got a pretty thorough  
25 presentation today of things that were previously

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 outstanding, including my concern about the external  
2 heat exchanger.

3 MEMBER ARMIJO: Harold, I would still like  
4 to get whatever data that Westinghouse has on the  
5 corrosion testing of that retainer ring material.  
6 What do they know about it?

7 CHAIRMAN RAY: Yes, I meant to mention  
8 that, if I didn't, as still a request.

9 The pressurizer, Item 5, we believe, has  
10 been covered. That was a change in the shape. We had  
11 a presentation that had to do with the chugging  
12 behavior and how there was minimal impact on that. So  
13 we consider that to be gone unless somebody wants  
14 something more.

15 6, Flow Skirt: Talked about that today --  
16 excuse me, I mean yesterday at this meeting. There  
17 are some specific questions here about that subject.  
18 Said, would you disposition that?

19 MEMBER ABDEL-KHALIK: I still have  
20 questions about this. I guess the questions were sort  
21 of posed regarding the dynamic similarity of the 1/7th  
22 scale experiments. You have the geometric similarity  
23 but not dynamic similarity, and I didn't see any  
24 information that would reassure me that the process by  
25 which you do the experiment at a Reynolds number that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is 35 times lower than normal, you compare the  
2 experiments against the numerical model, and even if  
3 you get perfect agreement, that you have any  
4 confidence in using that numerical model then to  
5 predict what happens at the actual Reynolds number,  
6 which is 35 times higher.

7 The question was asked as to whether or  
8 not the possibility of looking at running the  
9 experiments with a different fluid, high pressure air  
10 instead of water, to try to push the Reynolds number a  
11 little closer to the actual value, and I think the  
12 gentleman from Westinghouse said he will look at that.

13 CHAIRMAN RAY: Is this a safety issue or -  
14 - My lay or view of this thing was that the flow skirt  
15 was mainly being driven by the fuel design  
16 requirements as opposed to a safety issue. So I am  
17 trying to separate those here, so we don't inflate  
18 them.

19 MEMBER ABDEL-KHALIK: I think, from my  
20 perspective, that this impacts the core and the flow  
21 distributions, and there are a lot of things that  
22 happen --

23 CONSULTANT KRESS: It affects the plant  
24 temperature in the hot channel.

25 MEMBER ABDEL-KHALIK: Right. -- that sort

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of can follow out of that.

2 MS. RISK: I was going to say, there are  
3 clearly some -- what is the word I am looking for? --  
4 potential impacts, but the purpose of this issue is  
5 really a fuel performance issue. There really isn't a  
6 direct safety concern. What is really driving this  
7 was industry efforts to drive rod threading to zero in  
8 the Zero By Ten program that MPO had initiated.

9 So I understand that there could be a  
10 connection that could be drawn, but they are really  
11 handled within the design -- the accidents in the  
12 design capabilities of the plant, and what we are  
13 talking about is an effort to move away from fuel  
14 leakers, not a safety concern.

15 MEMBER ABDEL-KHALIK: Nevertheless, this  
16 has a direct impact on how you prepare the input to  
17 your VIPERW code, and that has an impact on the core  
18 thermal hydraulic design, and we would just like to  
19 find out what the assumptions used in setting up the  
20 input for VIPER are, and the fact that they are  
21 actually supported by either the experimental data or  
22 numerical methods that are supported by experimental  
23 data.

24 CONSULTANT WALLIS: This failing issue is  
25 generic. I mean, LOFT and PUMA and APEX and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 everything -- there is almost no experiment at full  
2 scale.

3 MEMBER ABDEL-KHALIK: I understand.

4 MR. CUMMINS: Ed Cummins. Just to be  
5 certain that we say what we think about the safety  
6 issue, we claim the cross-flow -- The safety issue  
7 happens higher in the core, and the cross-flow  
8 mitigates it. So in our opinion, it is not a safety  
9 issue.

10 That doesn't mean we can't bring it back  
11 to talk about it, but --

12 CHAIRMAN RAY: Well, I want to be as  
13 precise as we can, Ed, about what it is that we need  
14 more discussion of, because at the end of the day, I  
15 have to worry about how much time we are spending on  
16 various issues as well as what impact it is having on  
17 you and the staff.

18 So I guess, Said, could I ask if you could  
19 maybe write a simple statement of what you would like  
20 to see happen next here?

21 MEMBER ABDEL-KHALIK: I guess we never  
22 heard anything about lower plenum anomaly, and this  
23 derives from what the inlet core flow distribution is,  
24 what the geometry is in the lower plenum, what one  
25 expects as far as the conditions in the lower plenum.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           If there are data or analyses that would  
2 explain what is going on, I think that would be very  
3 helpful.

4           MR. SISK: Let me rephrase what I heard in  
5 the three-way communication process then. Rather than  
6 focusing on flow skirt, in and of itself, would it be  
7 more beneficial then to come in with a brief  
8 discussion on the lower plenum anomaly?

9           MEMBER ABDEL-KHALIK: Lower plenum and  
10 core inlet flow distribution. Right.

11          CHAIRMAN RAY: All right. The flow skirt  
12 then simply becomes an entry point, I guess, for the  
13 discussion that you are still -- we want to have. It  
14 isn't a consequence of the flow skirt, is it?

15          MEMBER ARMIJO: No.

16          CHAIRMAN RAY: All right. Let's revise 6,  
17 and again I would like to keep it as focused as  
18 possible to the specific things that Said is asking  
19 for, and not just groping for further discussion.

20          Okay, Sam, on Item 7 are we satisfied? I  
21 think this was yours.

22          MEMBER ARMIJO: No, I didn't ask about  
23 exothermic, I know. I wouldn't ask that.

24          CHAIRMAN RAY: Well, I just read the first  
25 part, zinc injection, which you did have an interest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in zinc injection, as I recall.

2 MEMBER ARMIJO: That is in good shape. I  
3 don't have any problem.

4 CHAIRMAN RAY: All right, Tom.

5 CONSULTANT KRESS: That one was mine, and  
6 they discussed the potential for this and satisfied me  
7 to the point it is closed.

8 CHAIRMAN RAY: Okay.

9 CONSULTANT KRESS: There was also a  
10 question on whether or not it affects the departure  
11 from nuclear boiling as a coating, but I think they  
12 also addressed that one. I would say it is closed.

13 CHAIRMAN RAY: Okay, good. Item 8, PTLR  
14 process, need to clarify how this is captured in the  
15 tech specs, and other examples. This is indicated as  
16 having been closed at the October meeting. I don't  
17 recall who head that as an item of interest or  
18 inquiry, but if there is no exception, we will leave  
19 it closed as indicated.

20 Turbine overspeed protection: This I do  
21 own up for. We discussed it at the October meeting  
22 and, as it says here, open question on intercept valve  
23 test frequency and method of testing for overspeed.

24 Let me direct a question to Westinghouse.  
25 Do you have something in train to give us anymore

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information on that or do we need to reframe the  
2 question or where do we stand on that?

3 MR. CUMMINS: Ed Cummins. We have  
4 answered a couple of questions to the staff related to  
5 overspeed and how we test it. We would be happy to  
6 have a short presentation on it.

7 CHAIRMAN RAY: But my recollection, Ed,  
8 was that there was a change or a reduction or an  
9 increase in the interval of the intercept valve  
10 testing on the grounds that the standard testing  
11 frequency was unnecessary. I will say it that way.  
12 And it got into a discussion that I didn't think was  
13 very satisfying at the time.

14 I would just like to take a look at that.  
15 I understand as a plant operator how you don't like  
16 to have to do this test. Done it a lot myself, and I  
17 just want to make sure we are not -- that we are  
18 giving appropriate attention to that, because I do  
19 think turbine missiles are a risk.

20 MEMBER BROWN: Don't -- When you are  
21 finished.

22 CHAIRMAN RAY: I am finished.

23 MEMBER BROWN: Okay. I wasn't here for  
24 the october meeting. I was in Tokyo. So I have no  
25 idea what went on then, but I did have an interest in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this one because of what I had initially read on the  
2 overspeed control, the digital -- the I&C.

3 I got the paper which described this. I  
4 am going to ask you all what happened. I got the  
5 paper. I read the paper, which said that they now  
6 have a totally independent, different type of  
7 overspeed trip.

8 They've got the normal speed control and  
9 trip, and then you've got a diverse set with another  
10 set of sensors and another set of electronics,  
11 including a different software. They are still  
12 digital, but it is a different set of software.

13 So I wanted to confirm that, in fact,  
14 those DCD changes -- and you proposed that you would  
15 change the DCD to do some things. I see that noted  
16 here.

17 CHAIRMAN RAY: Yes. Let's keep that on  
18 the list. Let's not try and solve it now.

19 MEMBER BROWN: Oh, no, that is fine. I  
20 don't want to solve it. I just wanted to make sure  
21 that was the case.

22 The other interest I had was the testing,  
23 and I didn't know whether you had --

24 MR. CUMMINS: Just one sentence. We have  
25 addressed this diversity, and it is in the DC. We

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have not addressed the valve frequency. We have that  
2 yet to do.

3 CHAIRMAN RAY: I understand. I am going  
4 to keep the diversity on the list as well, because  
5 Charlie is the guy who we need to satisfy on this. I  
6 can't speak for him in that regard.

7 MEMBER STETKAR: As part of the testing  
8 frequency, the question I raised yesterday, I guess it  
9 was -- and again, I wasn't here in October either.

10 So I didn't have the benefit of those  
11 discussions, but it is linked to the testing  
12 frequency, because they use the turbine missile  
13 analysis to justify the testing frequency to verify  
14 the reliability of the main turbine stop valves and  
15 control valves and the intercept reheat stop valves.

16 I have some real questions about that  
17 basic turbine missile -- the overspeed failure  
18 analysis --let's call it that -- the frequency input  
19 to the overall turbine missile analysis.

20 CHAIRMAN RAY: Do you want to add to this?

21 MEMBER STETKAR: Well, yes. I mean, we  
22 can link it to this one in terms of Westinghouse  
23 preparing some material. The two specific concerns  
24 that I have: Number one is their use of the available  
25 operating experience data from -- I think it was nine

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Japanese units -- to justify the frequency of both  
2 challenges to the turbine overspeed and the  
3 reliability of, in this particular case, the main  
4 turbine stop and control valves. So it is how they  
5 used the available operating experience to justify  
6 both the challenge frequency and the failure rate for  
7 the valves.

8 The second question was: The analysis is  
9 based completely on a design overspeed condition which  
10 they assume is going to challenge the rotor, the  
11 discs. They do not evaluate a -- did I say design  
12 overspeed? If I did, I misspoke. A destructive  
13 overspeed is what they quantify.

14 There are two other overspeed conditions,  
15 the design overspeed and intermediate overspeed, and  
16 they said we don't need to evaluate those, because the  
17 conditional probability of the discs coming apart is  
18 so low that it is insignificant.

19 Using their data, it would have to be less  
20 than  $10^{-3}$  for a design overspeed. Otherwise, they  
21 would double the frequency that they calculate.

22 So I would like to see what those  
23 conditional probabilities are for each of the  
24 overspeed conditions. That is probably a simple  
25 answer, because I am sure they have it somewhere.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They just weren't reported in the turbine missile  
2 frequency analysis.

3 CHAIRMAN RAY: Item 12 looks like a better  
4 place.

5 MEMBER STETKAR: Well, it just has that  
6 one crossed off, and that is why I thought --

7 CHAIRMAN RAY: It was discussed at the  
8 October meeting, but -- Eileen and Weidong?

9 MS. MCKENNA: I think it was crossed off  
10 because of the dual unit versus the single unit.

11 CHAIRMAN RAY: Okay. John has a different  
12 set of concerns here. You just heard them. If you  
13 need him to help you word the action item, why let's  
14 do that offline.

15 MS. MCKENNA: And expand it to maybe two  
16 items or something.

17 CHAIRMAN RAY: Okay, however you want to  
18 handle it, but the issue is, I think, sufficiently  
19 different than 9, which is what Charlie and I were  
20 talking about, that it ought to be highlighted. Well,  
21 I just put it in place in 12 or make it a new item,  
22 whatever.

23 I think of it in the context of 12,  
24 because that is where --

25 MEMBER STETKAR: I brought it into the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 turbine valve testing frequency, because they used  
2 that turbine missile frequency analysis, or the  
3 turbine trip failure analysis, if you want to call  
4 that, to justify the testing frequencies. That is how  
5 they backed out the testing frequencies to make sure  
6 that they still satisfied the  $10^{-5}$  failure to trip.

7 CHAIRMAN RAY: Okay. Whichever seems  
8 appropriate, a new item or link it to 12, as you see  
9 fit, but John's question needs to be followed up on.

10 MEMBER BROWN: One other point that might  
11 help on the diversity issue. From the paper and the  
12 other stuff that I was able to find, it looked like  
13 the independence on the functions, the centers and  
14 everything looked fairly reasonable.

15 The thing I couldn't find was power supply  
16 independence between the two systems. I was hoping  
17 they were, but I did not see an explicit -- or I  
18 didn't find it, let's put it that way. So I would  
19 like that, if somebody can find that out.

20 CHAIRMAN RAY: If anybody thinks I am  
21 pushing along here, we've got 45 items to go through,  
22 and we are on Item 10. So I am trying to do what we  
23 can here without running us into the evening.

24 Item 10: Elbow taps for RCS flow  
25 measurements is Sanjoy's item. Eileen, can you tell

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 us anything about that?

2 MS. MCKENNA: I am going to ask  
3 Westinghouse to. We don't have a whole lot of  
4 information in-house on this issue. So I think we  
5 were looking to get some background information.

6 CHAIRMAN RAY: So as far as you are  
7 concerned, that is still something to come?  
8 Westinghouse want to say anything, or not?

9 MR. SISK: We will treat it as open. We  
10 did have a brief discussion on that a little bit. I  
11 think it was either at the October or -- I think it  
12 was the October, but we could certainly bring that in,  
13 treat it as open, and close that out.

14 CHAIRMAN RAY: Okay. Like I say, I am  
15 trying to get these things treated properly and then  
16 closed, not coming back to them over and over again.

17 Okay, aircraft impact: I should ask the  
18 staff, that being Eileen, what is the outlook here?  
19 Is this going to come in the shield building, or what?

20 MS. MCKENNA: There is, obviously, a  
21 relationship to that shield building, because the  
22 design of the shield building does provide a degree of  
23 resistance to the aircraft impact. So we need to --

24 CHAIRMAN RAY: I don't know what  
25 inspection results -- what are those words meant to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean?

2 MS. McKENNA: Well, I think at the time  
3 that this item went on the list, the plan was to kind  
4 of approach aircraft impact primarily from inspection.

5 I think that has shifted a little bit to be more of  
6 performing a review. So we maybe need to clean up  
7 wording here and just say the committee is interested  
8 in the results of the staff's evaluation of aircraft  
9 impact.

10 CHAIRMAN RAY: When would we get that  
11 normally?

12 MS. McKENNA: Well, I will tell you, since  
13 we need to get the shield building, and they are  
14 revising their assessment of the rule requirements and  
15 the guidance based on what they have to do to the  
16 building, and that is coming in March, I believe, the  
17 last we heard, and then the staff would be able to do  
18 its review.

19 So it is going to be a little while.

20 CHAIRMAN RAY: Say it again.

21 MR. SISK: It wasn't us.

22 MS. McKENNA: Wasn't me.

23 MR. SISK: But, I think, perhaps to add  
24 some clarity to that, we just finished our peer review  
25 for AIA on the new design, and the pathway that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 going forward right now, as Eileen was pointing out,  
2 we are going to providing a revised language for 19(f)  
3 and the write-up as a part of the new shield building.

4 But the actual staff inspection is separate and  
5 outside of the licensing process, and is likely to  
6 take place this summer.

7 Sometime after, I think, the new design  
8 goes in, we would be glad to either discuss or work  
9 with the staff on whatever is needed in that area.

10 CHAIRMAN RAY: Okay. The word inspection  
11 makes sense now. It is broader than the shield  
12 building. You were talking about --

13 MS. McKENNA: Yes.

14 CHAIRMAN RAY: And you think, Rob, that  
15 there is a time sometime later this year when that  
16 will have been done and we could hear about it?

17 MR. CUMMINS: Done is --

18 CHAIRMAN RAY: We got the word done. We  
19 could hear about it?

20 MR. CUMMINS: We are done with the design  
21 today, and would be willing to make a presentation  
22 anytime. If you wanted the staff to do -- Their  
23 schedule for doing a review of it is -- They have  
24 concluded, I think, that they don't need to do a  
25 review even within the design cert scope. So it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sort of slipping, and whether we want the staff to  
2 have reviewed it or not, I think we need to discuss  
3 with them.

4 MR. SISK: And, Eileen, maybe we should  
5 confirm. I think we actually had a discussion on the  
6 agenda with the ACRS for shield building later this  
7 year.

8 MS. MCKENNA: Well, I think we were  
9 proposing -- we'll get to this next agenda topic --  
10 that in March we would have an informational briefing  
11 from Westinghouse on where we are with the shield  
12 building, kind of come up to speed and you've got your  
13 consultant engaged. You have a ways to go, obviously,  
14 to catch up perhaps with the staff's interaction, and  
15 possibly that we could cover this topic at that same  
16 time. Something to talk about, think about.

17 CHAIRMAN RAY: Possibly. All right, yes.  
18 Think about it. In any event, I can't say we are  
19 done with it, and we need to have some plan for  
20 addressing it.

21 MEMBER ARMIJO: Do you just want to call  
22 it an aircraft impact assessment, period?

23 CHAIRMAN RAY: Perhaps. I think the word  
24 inspection got inserted in there, because at the time  
25 there was this expectation that there would be an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 inspection that would be -- but it doesn't make a lot  
2 of sense to me.

3 Okay, Item 12 we have talked about. It  
4 will either pick up what John had discussed or it will  
5 remain closed, and a new item will be established, but  
6 in any event, just the issue of dual unit sites, I  
7 think, is adequately addressed already.

8 BLN hydrology issue and QA aspects:  
9 Obviously, this came up in the context of TVA and is  
10 site-specific. Do we need to carry this here now for  
11 any reason?

12 MS. McKENNA: We considered it closed, but  
13 if you want to take them off the list until --

14 CHAIRMAN RAY: Yes. I think, ultimately,  
15 we probably want to take things off the list so that  
16 we don't waste people's time with things that are  
17 closed, and maybe they decide they are not closed  
18 after all.

19 I guess that applies to 14 also.

20 Fifteen: 199, Eastern Tennessee seismic  
21 zone. Again, that is not relevant to what we are  
22 doing now, is it, or is it? In other words, should we  
23 be addressing this as part of our present activities  
24 or wait until we have a site-specific?

25 MR. RYAN: Do you want to take it off?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR: I think we have to wait  
2 until you have site-specific for Vogtle.

3                   CHAIRMAN RAY: Everybody agree with that?  
4 All right.

5                   MS. MCKENNA: What do you want me to do  
6 with this one?

7                   CHAIRMAN RAY: Well, yes. I would say,  
8 Mike thinks we ought to take it off, but in any case,  
9 we shouldn't be burdening ourselves with it right now.

10                  MR. RYAN: Do you want to -- I mean,  
11 inactive and just leave it there, if you want.

12                  MEMBER STETKAR: We have to wait until we  
13 get the site-specific parts of the Vogtle COL  
14 presentation.

15                  CHAIRMAN RAY: Same for 16 or not?

16                  MEMBER STETKAR: Yes. That would be also a  
17 site-specific flooding susceptibility.

18                  CHAIRMAN RAY: Okay, 17 is one Said and I  
19 chatted about a bit ago. Anymore you want to say  
20 about it?

21                  MEMBER ABDEL-KHALIK: You know, the only  
22 thing that remains in my mind is any ITAACs related to  
23 the piping layout to address the non-condensable gas  
24 issue, but I guess that just can be combined with your  
25 resolution of the non-condensable gas.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: You are on 17, on testing?

2 MEMBER ABDEL-KHALIK: Right.

3 MS. McKENNA: We can write that into the  
4 statement of the non-condensable issue.

5 MEMBER ABDEL-KHALIK: Right.

6 CHAIRMAN RAY: So you are satisfied  
7 otherwise, and so we can consider this --

8 MEMBER ABDEL-KHALIK: That was the source  
9 of that issue.

10 CHAIRMAN RAY: Okay. Take it off then,  
11 and consider it to be a part of what we discussed  
12 earlier.

13 Eighteen is closed. I think we are  
14 managing the workload now satisfactorily.

15 Radiation significance definition: Let's  
16 see, closed with respect to AP1000. Anybody have any  
17 specific recollection if there is anymore to be done  
18 there? I don't.

19 Okay, 20. So that is gone. Nineteen is  
20 gone. Twenty, digital I&C failure rates were  
21 addressed in the PRA and whether there were any  
22 improvements made in the design, insights from PRA.  
23 So, John, you and Charlie and Dennis are going to  
24 talk about that. I understand, but you are the  
25 members. Tom, what do you want?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           CONSULTANT KRESS: They talked about this.  
2           They didn't -- The failure rates were based on  
3           knowledge about the hardware, and it is hard to get a  
4           computer failure -- or a software failure rate. I  
5           think that is the best you can do.

6           CHAIRMAN RAY: Okay.

7           MEMBER STETKAR: For AP1000, I would  
8           agree. It is a broader generic issue in the area of  
9           modeling digital I&C systems.

10          CHAIRMAN RAY: Take it off.

11          Twenty-one, I don't think we need to keep  
12          it around. It is more in the way of an admonition.

13          MEMBER ABDEL-KHALIK: It still remains.

14          CHAIRMAN RAY: Well, sure. I am trying to  
15          narrow this down to action items so we know how many  
16          of them we've got to schedule into the future. Same  
17          for 22.

18          MEMBER BROWN: What did you say on 21?

19          CHAIRMAN RAY: I thought of it as an  
20          admonition rather than as an action item.

21          MEMBER BLEY: We already have action items  
22          related to specifics.

23          CHAIRMAN RAY: And so I put 22 in the same  
24          category. This says to be discussed at the February  
25          meeting. I think we have evolved from this point to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the process that we have here now. It got a little  
2 mixed up yesterday and today because of the fact that  
3 Sanjoy was only here yesterday and needed to address  
4 items that he has an interest in then.

5 Twenty-three --

6 MEMBER BROWN: What are we doing with 21  
7 and 22? Are they going to go off?

8 CHAIRMAN RAY: Take them off, yes, because  
9 again we are trying to schedule stuff that needs to be  
10 done.

11 MEMBER BROWN: All right.

12 CHAIRMAN RAY: Twenty-two is said to be  
13 closed. Again, it is more in the way of a generic  
14 process related discussion we were having at the time.

15 So it got picked up.

16 Twenty-four -- Anything you want to say  
17 more, Eileen, that needs to be said?

18 MS. MCKENNA: I think this is just  
19 something we put down, and we did talk about this in  
20 the November full Committee meeting of how we are  
21 transitioning, and I think that, obviously, we are  
22 hoping to finish that transition very shortly. So  
23 that we hope that issue will be behind us.

24 CHAIRMAN RAY: I would call it muddling  
25 through.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER BROWN: I guess I have one question  
2 on how -- We have had a number of subcommittee  
3 meetings, and I guess I am looking for how do you --  
4 this process issue. How do we close out the entire  
5 thing with the full Committee after -- I mean, you can  
6 never address this in the one and a half hour  
7 allocation that we normally have. Is it a two-day,  
8 full -- Has that been decided?

9           CHAIRMAN RAY: Let me tell you what I  
10 think, and then if the boss here or somebody else  
11 wants to change it, he can. I think right now we  
12 would look at discussing whether to write a letter on  
13 the DCD amendment first, and we would not do that  
14 until after we have completed the initial review,  
15 which is still a meeting or so away.

16           Whether we write a letter on the standard  
17 content portion of the combined license, I am  
18 doubtful. I think we wait until we see the site-  
19 specific and write a letter then, unless there is  
20 something that really troubles us.

21           So right now I think our main focus is on  
22 is there anything we want to say, and are we ready to  
23 say it, on the DCDA, the Rev 17 of the design change.

24           MEMBER BROWN: Now how do you get that all  
25 19 chapters presented to the full Committee? We have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had pretty good participation recently.

2 CHAIRMAN RAY: Well, that is something we  
3 will have to work on.

4 MEMBER BROWN: Okay. We haven't really  
5 walked through that? That is an answer.

6 CHAIRMAN RAY: Yes. I don't want to try  
7 and engineer that here.

8 MEMBER BROWN: That just occurred to me as  
9 we were --

10 CHAIRMAN RAY: But on the subject of 24,  
11 is there anybody who feels like we need to carry an  
12 action item on this transition process? Like I say,  
13 for a minute I couldn't explain it. We are just going  
14 to muddle through, and that is about what it boils  
15 down to.

16 At some point we will say we have a  
17 concern or we've got to write a letter, because even  
18 if we don't have concerns, we are done. That time  
19 hasn't come yet.

20 Okay, 25, human factors engineering:  
21 Anybody want to comment on that? Dennis, you often  
22 have --

23 MEMBER BLEY: No. I think we see where it  
24 is headed, and the things we are most interested in  
25 aren't going to happen until later. So, no

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: You want to drop it?

2 MEMBER BLEY: I am willing to drop it,  
3 yes.

4 CHAIRMAN RAY: Okay, you are the guy.

5 MEMBER BLEY: We will see it some other  
6 time.

7 CHAIRMAN RAY: Twenty-six, waste  
8 management: Dr. Ryan?

9 MEMBER RYAN: Sir.

10 CHAIRMAN RAY: What would you like to do  
11 with 26?

12 MEMBER RYAN: I thought that was in the  
13 COL.

14 CHAIRMAN RAY: Keep it there?

15 MEMBER RYAN: Yes, I think so.

16 CHAIRMAN RAY: All right.

17 MEMBER RYAN: It is not a big issue.

18 CHAIRMAN RAY: All right. Twenty-seven,  
19 PRA audit results: What do you PRA guys want to do?  
20 Are we done?

21 MEMBER BLEY: Well, they sent us the audit  
22 results. I have looked through them. Same issues we  
23 have had elsewhere. I don't want to keep that one,  
24 but I would like a briefing, because I don't find it  
25 anywhere, for the PRRA for the COL.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Everything in there says nothing matters,  
2 and we haven't changed the base PRA, and we've got a  
3 lot of changes to the plant, and I haven't seen any  
4 basis for saying that in aggregate those make no  
5 difference except a sentence that essentially says  
6 that in Chapter 19 for the COL.

7 MEMBER ARMIJO: Wasn't that addressed in  
8 the audit?

9 MEMBER BLEY: The audit was of the AP1000  
10 PRA.

11 MEMBER ARMIJO: Oh, okay.

12 MS. MCKENNA: I might also note that I  
13 have given to Weidong an updated list of the technical  
14 reports, and there was a revision to one of those. It  
15 was the PRA requantification. So you may want to take  
16 a look at that document. I know there was interest in  
17 that. I think it was TR-102, as I recall. It came  
18 in, in December. So, yes, you may want to take a  
19 look.

20 MEMBER BLEY: It is a recal.

21 MS. MCKENNA: Yes.

22 CHAIRMAN RAY: Okay, Weidong, keep 27.  
23 Say it is under review.

24 MR. WANG: Okay.

25 CHAIRMAN RAY: Twenty-eight: Pipe break

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hazard report. We had discussion about that this  
2 time. There has been -- It was quite a bit of back  
3 and forth. Westinghouse, you want to say anything  
4 about this action, which is provide report when  
5 completed? How would you describe it?

6 MR. CUMMINS: It is being deferred until  
7 after design cert.

8 CHAIRMAN RAY: So I guess, since Sanjoy is  
9 not here -- I am trying to think and talk at the same  
10 time. I am trying to figure out if there is any  
11 action item that is associated with the COL, but I  
12 don't think so. So as far as I am concerned, there is  
13 no reason to continue to carry this as an action item.

14 Since you are talking about striping, what  
15 do you want to do with 29?

16 MEMBER ARMIJO: I am not Mr. Banerjee. I  
17 don't remember what his issue was.

18 CONSULTANT KRESS: They were going through  
19 instrument piping to see what sort of thermal stresses  
20 you would get from the striping, and they had a  
21 criteria for going around looking where that would be.

22 I think Banerjee wanted more information on just what  
23 those criteria were. I don't know if he ever got it  
24 or not.

25 MR. SISK: We haven't talked about this,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but we would be glad to present something in the March  
2 time frame, as noted on the paper, to follow up on it.

3 CHAIRMAN RAY: Thank you.

4 MEMBER ARMIJO: Part of a fatigue issue.

5 MEMBER SHACK: This is the whole fatigue  
6 design thing. The same with wet stems. I am not sure  
7 why that is in there.

8 CHAIRMAN RAY: You want to take it out?

9 MEMBER SHACK: To my mind, the analysis is  
10 the least of the concerns. I mean, it is identifying  
11 exactly what you want to analyze in the first place.  
12 I am fairly confident they can analyze it. It is  
13 finding the driving forces that is the tricky part of  
14 the fatigue.

15 CHAIRMAN RAY: So should we take out 30 or  
16 you want to change it?

17 MEMBER SHACK: Take out 30. You know, 29,  
18 you could make it broader. It is striping. It is  
19 thermal fatigue. It is all those issues for  
20 everything except the sort of standard design cert --

21 MEMBER ARMIJO: Screening criteria for  
22 thermal fatigue.

23 MEMBER SHACK: It is the hard part of the  
24 fatigue that is of interest.

25 CHAIRMAN RAY: Okay, take out 30. Leave

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 31. Thirty-two: There is still discussion among  
2 members of the subcommittee, I think.

3 MR. SISK: I think I misunderstood what  
4 you said. We are going to leave 29 and take 30 out?

5 CHAIRMAN RAY: Yes.

6 MR. SISK: Thank you.

7 CHAIRMAN RAY: And we are going to leave  
8 31 as is.

9 Thirty-two, I was starting to say, I  
10 believe that that is under discussion now.

11 MEMBER BROWN: Right now when we left the  
12 meeting on the 19th, I had not had an opportunity to  
13 see the WCAPS that were relative to the I&C  
14 architecture, and we had an abbreviated presentation  
15 which illuminated some stuff, which helped a lot when  
16 I read the WCAP

17 I found at least one item in there  
18 relative to the SER that I need to consult with John  
19 and Dennis and George, which we are going to do, and  
20 determine whether there is any other -- I got to see  
21 if they --

22 MEMBER STETKAR: My sense is, for this  
23 meeting, we should leave it on the list.

24 MEMBER BROWN: We ought to leave it on the  
25 list.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RAY: That is all I wanted to do,  
2 is just leave it on the list.

3 MEMBER BROWN: It should not be ghosted or  
4 grayed or whatever.

5 MS. McKENNA: I think it was, because at  
6 the time this was coming at the full committee where I  
7 know you presented your kind of four criteria, if you  
8 will, on what you were looking for in terms of  
9 function.

10 MEMBER BROWN: This was an earlier --

11 MS. McKENNA: Yes, before the subcommittee  
12 meeting, and so that is why I grayed it out, but  
13 obviously, if we need to add a different item or a  
14 more specific item, we would be happy to do that.

15 MEMBER BROWN: Well, there is at least a  
16 half a dozen to a dozen open items for you all, but  
17 depending on how they are resolved --

18 CHAIRMAN RAY: Let's not -- Let's just  
19 leave it as is, but keep it. Keep it open.

20 MS. McKENNA: I will un-gray it.

21 CHAIRMAN RAY: Thank you. You can say  
22 ongoing review by ACRS or something. We may or may  
23 not ask for something more from staff or Westinghouse.

24 Okay, 33: Site?

25 MEMBER ABDEL-KHALIK: I think we heard

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enough about ASTRUM. I am not sure if anybody else  
2 wants to hear about the seismic analysis.

3 CONSULTANT WALLIS: Well, Sanjoy was still  
4 talking about it when he left.

5 MEMBER STETKAR: Talking about what?

6 CONSULTANT WALLIS: He was wondering how  
7 they managed to get such a huge change, such a big  
8 margin. there was some concern about that. I think  
9 you better ask Sanjoy whether he --

10 MR. WANG: We will have a newer action  
11 item for this meeting. I mean for February.

12 CHAIRMAN RAY: yes, I think that is right.  
13 S a result of the discussion, Weidong will have an  
14 action item that will try and capture the point that  
15 Sanjoy has.

16 MEMBER ARMIJO: That was an ASTRUM-  
17 specific thing. This originally was we would like to  
18 see the methods changes that have gone on instead of a  
19 general -- ASTRUM was one piece of that.

20 MS. MCKENNA: And we did kind of look  
21 through and see what -- you know, within the design  
22 changes and ASTRUM and some of the seismic areas.  
23 There were changes from -- I will probably get it  
24 wrong, whether it was time history, response after or  
25 whatever. You will hear about those when we come back

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on those Chapter 3 areas, but we didn't see a whole  
2 lot of other methodology changes that were going on.

3 MEMBER ARMIJO: Right. So that is covered  
4 except or the understanding of how ASTRUM is -- how it  
5 really works.

6 CHAIRMAN RAY: Yes. Well, or maybe  
7 another way to say this: How did its use result in  
8 such a big change, increase in margin? that is not  
9 meant to reflect some suspicion. It is only a matter  
10 of professional interest, so we understand, if we are  
11 cutting off a tail or if we are doing something else,  
12 what is going on. That is all.

13 I know Sanjoy also had concerns that were  
14 discussed, over my head, about whether it was suitable  
15 for application to AP1000 for a bunch of reasons, but  
16 in any event, it will be kept open, as Weidong said.

17 Thirty-four: Dennis?

18 MEMBER BLEY: I would still like to know  
19 this.

20 MEMBER BROWN: I just want to interject  
21 one thing on the back, and I may have said it before.

22 When I read a number of the DACs acceptance criteria  
23 for some fairly critical items was that a report will  
24 be issued, and everybody is happy.

25 So there was absolutely no idea what the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 criteria would be relative to the satisfaction of  
2 those. So the whole issue of how do you deal with DAC  
3 in the digital I&C world is still -- It is still a  
4 generic --

5 CHAIRMAN RAY: This is human factors-  
6 specific here.

7 MEMBER BROWN: Oh, okay.

8 CHAIRMAN RAY: Now wait a minute, Charlie.  
9 I am saying you got a broader issue, which I think is  
10 fair.

11 MEMBER BROWN: Well, I think we have  
12 discussed that before in terms of how that was -- I  
13 know you have made the comment, and I know John has as  
14 well.

15 MEMBER BLEY: I think what I meant by  
16 this, and it would apply to Charlie's, at least for  
17 some of the DAC that are being eliminated by Rev 17,  
18 it would be really nice to see something from either  
19 Westinghouse or staff, or both, explaining why that  
20 DAC is no longer there, how it was fulfilled, and it  
21 would deal with what Charlie is saying.

22 It is, yeah, okay, so that report was  
23 issued; what did you do to be convinced that  
24 everything is the way it ought to be? So that level  
25 of -- and not everyone of them, maybe a few, so we can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get a flavor that the review is digging in and that it  
2 is not just, as Charlie said, a report has been  
3 submitted.

4 CHAIRMAN RAY: All right. Dennis, could  
5 you reword the comments disposition entry here? This  
6 just simply says final SER should document DAC  
7 closure. I don't think that is a correct statement of  
8 what you would like to see happen. This is just on  
9 HFE, right?

10 MEMBER BLEY: Yes, that was the first  
11 thing I said.

12 CHAIRMAN RAY: Could you just give Weidong  
13 something that better states what it is you think we  
14 need to do and see here?

15 MEMBER BLEY: Sure.

16 CHAIRMAN RAY: Then to Charlie's point  
17 about DAC generally, I think it is a serious question.  
18 I just hate to add it to the action list here for  
19 AP1000 unless we know exactly what the question is we  
20 are trying to get an answer to, if it is a generic  
21 issue. Bill, help me on this. Isn't this still a  
22 generic issue between us and the staff?

23 MEMBER SHACK: Yes. I had a question for  
24 Eileen on that, because this HFE is the first one that  
25 we have actually seen where there has been a closure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of a DAC. I guess my question was: Was it fulfilled  
2 by essentially going through the DAC and Rev 15 and  
3 assessing that the product they provided addressed  
4 those DAC or was it really a different process where  
5 you just sort of started over from scratch?

6 MS. MCKENNA: No, I am not the Chapter 18  
7 reviewer, but my sense is that it was kind of taking -  
8 - since they were all the implementation plan  
9 documents that had been developed that were what  
10 formed the basis of the DAC, and that the staff then  
11 goes through and says, okay, did these things that  
12 they were supposed to develop this and implement that  
13 -- did that occur.

14 So I think the answer is yes, but I think  
15 I would --

16 MEMBER BLEY: I think not, because we had  
17 a fellow here talking about that some months ago, and  
18 I think we asked him that, and he said, no, they sat  
19 down and reviewed it and decided there were no DAC  
20 needed to be in Rev 17, that they didn't actually play  
21 it against the DAC from 15. I am pretty sure that is  
22 in the transcript.

23 MR. CUMMINS: I think you can get both  
24 answers, but what happened in reality is the staff  
25 inspected us based on the DAC that was in Rev 15, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we negotiated a series of deliverables that met the  
2 requirement of the DAC as written, and we provided  
3 those deliverables, and they reviewed, and they are  
4 coming to -- They haven't yet accepted them, but they  
5 are coming to accept them, and then they will be  
6 closed.

7 So in the case of HFE, all of the DAC will  
8 be closed. So there will only be a V&V ITAAC left.  
9 In the case of I&C, two of the DAC will be closed.

10 So there will still be a third open DAC.  
11 And the two that we are starting to write them up as  
12 part of RAIs, and they are reference documents being  
13 put into Chapter 7, and it says, you know, we provided  
14 these 15 reference documents for the staff to review,  
15 and the staff found them acceptable, or whatever it  
16 says.

17 It is definitely -- They read what the DAC  
18 said we were supposed to do, and then we said we think  
19 the answer to this is this, and back and forth a few  
20 times, joint agreement, then review that. So it was a  
21 very -- Yes?

22 MEMBER BROWN: If you look at the DCD --  
23 and I am agreeing with you, sort of, in that it does  
24 reference the WCAPS for particularly 16.675, I think  
25 the number is, which works. Okay? If you go through

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that it is a much better picture.

2 There are some points where it doesn't  
3 necessarily work in all circumstances, I don't think,  
4 and I have --

5 CHAIRMAN RAY: I've got a feeling we are  
6 working an issue here when I'm --

7 MEMBER BROWN: No, no, let me finish. I'm  
8 slow, okay? My brain is too old.

9 They talk about DAC-1, 2 and 3, and you  
10 said two of them were closed out, and there is still  
11 one open, and the staff echoed that. But when you  
12 look at -- and I've forgotten what the categorization  
13 of DAC-1, 2 and 3 were. It was the third one that  
14 wasn't finished.

15 I guess I still don't understand totally  
16 what resolved 1 and 2 and 3, and how 3 is going to --  
17 That is all I am looking for, is how did we get that  
18 result, so we can look at it, and then either agree or  
19 disagree.

20 MS. MCKENNA: That is probably a similar  
21 action, if you will, than what we have for human  
22 factors in terms of being able to document in our  
23 safety evaluation what was closed and why it was  
24 closed.

25 MEMBER BROWN: I don't want to try to have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to go grovel through 300 pages of stuff to try to  
2 figure out where the pieces of the puzzle fit  
3 together. I will never get there.

4 MEMBER SHACK: Why don't you make sure  
5 that this action item is clear enough as an action  
6 with the action we expected.

7 CHAIRMAN RAY: That was fine. I  
8 understand.

9 MR. CUMMINS: For I&C DAC 1 and 2, for  
10 each of those there is a list of, I'll say, ten-ish  
11 documents that Westinghouse produced for each of them.

12 Those were reviewed by the staff, and they are  
13 assessing them still. And for DAC 3, I&C DAC,  
14 Westinghouse has prepared a proposal for what list of  
15 15 documents we should produce in the future to close  
16 that, and that is starting to be discussed with the  
17 staff, and how we document that. We are thinking we  
18 might document that in 14.3, make that list in there.

19 CHAIRMAN RAY: All right, enough on this.  
20 Let's have two action items, one on human factors,  
21 one on I&C. You guys write up what the heck it should  
22 say, but I think it is clear enough that we want --

23 MEMBER BROWN: Staff needs to tell us.

24 CHAIRMAN RAY: All right. Where in the  
25 heck am I? I've gotten lost here in DAC. Thirty-

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 five. Okay, now we've got a series of GSI 191 things.  
2 Hopefully, we can simply say, well, we are going to  
3 hear about that in due course at the right time.

4 MS. MCKENNA: In fact, that was a  
5 recommendation from Weidong, that we just put those  
6 altogether as staff needs to come and talk to you  
7 about GSI 191 and talk about a lot of things.

8 CHAIRMAN RAY: Okay, but in order to make  
9 that discussion, when it occurs, as productive as  
10 possible, I don't think we want to lose sight of the  
11 points that were captured here from the earlier  
12 meeting. So when you put them together, Sam is going  
13 to say --

14 MEMBER ARMIJO: Let me say what my concern  
15 was, and I think partly it was part of Sanjoy's, is  
16 that it was the chemical -- the prototypicality of the  
17 chemical environments used in the fuel assembly tests.

18 They were basically physical blockage  
19 tests with no real -- and if you read the transcripts,  
20 I kept going back to what is the temperature  
21 dependence; is the chemistry taken into account, the  
22 boric acid, the aluminum and all the other stuff that  
23 could be in there.

24 I think Sanjoy has added in aluminum. I  
25 started out with boric acid, but these chemical

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 prototypicality of the environment, including  
2 temperature, for those tests; and has it been done or  
3 not?

4 CHAIRMAN RAY: Go ahead, I'm sorry.

5 MEMBER ARMIJO: And that's it. So that is  
6 kind of a subset of the statistical analysis.

7 CHAIRMAN RAY: I just don't want to  
8 compress all of this down and then have to reinvent  
9 these issues later. So I don't mind combining them,  
10 Eileen, into a single thing having to do with GSI-191.

11 I just don't want to lose what Sam just said. In my  
12 case, it was --

13 MEMBER ARMIJO: I can write something.

14 MS. McKENNA: Yes. It sounds like we  
15 didn't quite -- These are really cryptic shorthand.

16 CHAIRMAN RAY: They are very cryptic.  
17 That is right. In my case, you know what concrete  
18 scouring is in terms of a concern, which was we don't  
19 assume that there is a lot of scoured concrete debris  
20 created by loss of coolant accident, and I was asking,  
21 well, why.

22 Graham, on 39, had a --

23 CONSULTANT WALLIS: That is GSI-191.

24 CHAIRMAN RAY: Right, exactly.

25 HDPE criteria for loads and supports --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what the heck?

2 MEMBER SHACK: Is there high density  
3 polyethylene piping somewhere?

4 MS. McKENNA: Yes. May have gotten the  
5 wrong member there.

6 MEMBER SHACK: Where are we using high  
7 density polyethylene piping?

8 CHAIRMAN RAY: Well, it is buried piping,  
9 and the question, I guess, had to do -- but I can't  
10 dredge it up out of my memory now -- had to do with --

11 MS. McKENNA: Well, there were a number of  
12 questions about the joints and how --

13 CHAIRMAN RAY: That's right, yes.

14 MS. McKENNA: -- the thing was supported  
15 when it is buried, and I guess there is something, a  
16 code case maybe, coming on, and we had some --

17 CHAIRMAN RAY: Okay, let's not try and  
18 solve it here. Let's just say I don't believe we have  
19 a basis for closing it. It is coming back to me  
20 vaguely now.

21 MEMBER RYAN: There is a lot of current  
22 experience with buried piping.

23 CHAIRMAN RAY: That's right, bad  
24 experience.

25 MEMBER ARMIJO: This is probably an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 improvement. I would like to know more about it.

2 CHAIRMAN RAY: So we will keep that.

3 RCBT test frequency -- Reactor trip  
4 circuit breaker test frequency is what that must mean.

5 Anybody have any basis for year OI? Is that one,  
6 John, that you were asking about? Sounds like a  
7 question you would ask.

8 MEMBER STETKAR: Which one?

9 CHAIRMAN RAY: Forty-one.

10 MEMBER STETKAR: No.

11 MR. CUMMINS: We have responded to an RAI  
12 from the staff that says we will do it. I don't  
13 remember, but it less than yearly, and I think it is  
14 one division per month or -- Anyway, we have responded  
15 back with a position, and I think the staff and we  
16 need to get on the same page there.

17 CHAIRMAN RAY: Okay.

18 MEMBER RYAN: Harold, if you want to  
19 shorten your list by one, I will take 40 and write up  
20 something for Weidong, if you want.

21 CHAIRMAN RAY: All right. Cyber security:  
22 This says there is a topical report provided. Is  
23 that a basic of closing this item or is it under  
24 review or who is interested?

25 MEMBER BROWN: I don't want that one right

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now, because I didn't have that until somehow I think  
2 somebody turned it over to me, but I am not quite sure  
3 of the status, whether I own that. Do I own that?

4 CHAIRMAN RAY: Eileen, I am going to look  
5 to you to decide.

6 MEMBER BROWN: I told George I wasn't  
7 going to do it. He is the one that's been doing it.  
8 So you ought to talk to him.

9 CHAIRMAN RAY: All right, you and George,  
10 would you? You sat right next to him.

11 MEMBER BROWN: Well, I don't know. they  
12 have rearranged me now.

13 CHAIRMAN RAY: We will leave it on the  
14 list.

15 MEMBER ARMIJO: You better talk fast.

16 CHAIRMAN RAY: The next, 43, is yours high  
17 speed links.

18 MEMBER BROWN: The high speed links are  
19 discussed in topical report. There is an outstanding  
20 SER open item that the staff has. That will be an  
21 interesting one. That is the one I commented to you  
22 in my notes to you, that that would be an interesting  
23 resolution, because it was -- the platform was  
24 approved with high speed links.

25 CHAIRMAN RAY: So it is under review?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Yes, but the staff is  
2 taking issue. It is going to be interesting.

3 CHAIRMAN RAY: Forty-four is closed today.

4 MEMBER BROWN: I am not sure we would all  
5 agree with it.

6 CHAIRMAN RAY: Forty-five -- I am not sure  
7 what --

8 MS. McKENNA: This is the fire induced  
9 circuit -- We kind of touched on it a little bit, I  
10 know, somewhat in the Chapter 9 discussions about  
11 separation and whether --

12 CHAIRMAN RAY: Where do you guys stand on  
13 this, Eileen? Can you tell me right off the top of  
14 your head?

15 MS. McKENNA: Staff had concluded that the  
16 analysis that had been done was acceptable in terms of  
17 essentially assuming that, because of the separation  
18 of the trains, that all the equipment in a particular  
19 fire area is just lost, and is not clearly concerned  
20 about the adverse interaction kind of things, which  
21 was what, I think, drove a lot of the issue in the  
22 first place.

23 I think this was Maynard's question from  
24 the last meeting.

25 CHAIRMAN RAY: Does this have anything to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do with a large fire event?

2 MS. McKENNA: No. Strictly the hot short  
3 kind of actuation.

4 CHAIRMAN RAY: Okay. Well, we are going  
5 to have to drop it, since I can't come up with  
6 anything.

7 MEMBER STETKAR: The real key is, as long  
8 as they are following the guidance in 1.189 and they  
9 comply with it, that guidance addresses this issue.

10 MR. CUMMINS: I think the staff looked at  
11 the report, and I think that the staff was basically  
12 okay with the report, but I don't think there was any  
13 issue between us and the staff.

14 MEMBER STETKAR: I think it was more of a  
15 concern if you go to the risk informed approach as far  
16 as scope and numbers and that sort of stuff.

17 MR. WANG: That item was closed down?

18 CHAIRMAN RAY: Yes. That last one, yes.  
19 I don't want to keep everybody here to try and come up  
20 with a list from this meeting. I need -- We have to  
21 look at the transcript and so on and so forth. It is  
22 just too difficult to do it sitting here now. But  
23 there will be a few items presumably that everybody  
24 has fresh in their minds about now that will be added  
25 to the list.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We have deleted more items, I am sure,  
2 than we have added, but at the end of the day we will  
3 have to look at the list and decide, okay, do we want  
4 to request additional presentations on any of these  
5 topics, and we will pass that word to the staff and  
6 ultimately to Westinghouse, if you are involved.

7 the last item for us, I think, today, to  
8 discuss are upcoming interactions as they stand  
9 presently. So, Eileen, did you want to make this  
10 presentation?

11 MS. McKENNA: I think Stephanie was going  
12 to cover that topic.

13 CHAIRMAN RAY: All right.

14 MS. COFFIN: We have a short presentation.

15 CHAIRMAN RAY: All right, Stephanie.  
16 While she is getting set, is she going to talk about  
17 the February meeting?

18 MS. McKENNA: The next meeting, yes.

19 CHAIRMAN RAY: Then there is the March  
20 meeting that you talk about.

21 MS. McKENNA: That is the next meeting.

22 CHAIRMAN RAY: Excuse me, I'm sorry.  
23 There is a February meeting later this month, but it  
24 is not on AP1000. That is what confused me. I  
25 apologize. The March meeting is the next meeting of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this subcommittee. That is correct. It has been a  
2 long day.

3 MS. COFFIN: So we are about to enter into  
4 what we call our Phase 5 ACRS interactions on the  
5 design cert amendment. Phase II and III are nearly  
6 complete with the issue of 18 and 19 SER with open  
7 item chapters issued and presented to the committee,  
8 and Chapters 3.7 and 3.6 are scheduled. They are  
9 under evaluation.

10 So as we are moving into preparing our  
11 advanced Final Safety Evaluation Report, we do plan to  
12 issue them on a chapter by chapter basis.

13 CHAIRMAN RAY: Excuse me, Stephanie. I am  
14 asking myself sa I am following you here, are we  
15 talking about standard content only or --

16 MS. COFFIN: This is the design cert. I  
17 am on the design cert.

18 CHAIRMAN RAY: Design cert. Of course,  
19 you are. I am sorry. Because you are sitting there,  
20 I keep thinking.

21 MS. COFFIN: We tag team. All the open  
22 items will be resolved before we issue the chapter to  
23 the ACRS and to the applicant, but there will very  
24 likely be confirmatory items remaining where they need  
25 to -- We will see a DCD mark-up, but they need to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actually provide the proper revision appropriate and  
2 close it out. So you will see some confirmatory items  
3 in those chapters.

4 Also, because of timing and other issues,  
5 there are going to be some review areas in Phase V  
6 that you have not previously seen presented for this  
7 design cert; for example, aircraft impact analysis and  
8 security reviews. We do expect multiple meetings with  
9 you throughout the calendar year.

10 This is essentially the same slide, but it  
11 is for the reference COL. So you are going to be --  
12 We are going to be issuing the advance final SER ,  
13 again on a chapter by chapter basis, for Vogtle. This  
14 is our reference COL now, and that is the first one  
15 you are going to see.

16 Same story, all open items will be  
17 resolved prior to chapter issuance. Some confirmatory  
18 items may remain, and again there will be some new  
19 review areas that you haven't seen before, loss of  
20 large areas due to fires, explosions, fitness for  
21 duty.

22 The presentation format will be similar to  
23 how we have been conducting them since last July. We  
24 will be presenting the chapters at the same meeting,  
25 but we will have separate presentations for the design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cert and for the reference COL presentations.

2 The applicants will present. The staff  
3 will present. The focus of our presentations will be  
4 on the key review areas and, of course, how we close  
5 open items, and we will issue them at least 30 days  
6 prior to the meeting.

7 IN terms of subsequent COLs, we would like  
8 to offer an information briefing on specific topics of  
9 interest related to Summer and Levy. The topics will  
10 be coming from Chapter 2, 8 and 13 and other site-  
11 specific topics that may be of interest to the ACRS.

12 So we are welcoming any particular areas  
13 that you are interested in, and we are targeting April  
14 for that informational briefing.

15 CHAIRMAN RAY: Well, April -- now that is  
16 -- I am trying to remember what you said previously.  
17 That means you are going to begin introducing the S-  
18 COLAs before we are entirely done with the R-COLA  
19 review. Is that correct?

20 MS. COFFIN: We are offering that as a  
21 suggestion to get early engagement on some maybe more  
22 complicated site-specific issues.

23 CHAIRMAN RAY: Well, as long as we  
24 prioritize what we are doing, because I think that the  
25 first aim has to be to try and get the highest

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 priority done first and not have it be drug our  
2 because we are starting to do other things as well.

3 MS. COFFIN: I understand. The reason why  
4 we offer this is that the subsequent COLs, we don't  
5 issue an SER with open items. So we go directly to  
6 the advanced final SER with no open items. So we wold  
7 like to -- So there is a risk of not engaging you  
8 early enough for the subsequent COLs, because of that  
9 revised process for the subsequent COLs.

10 CHAIRMAN RAY: Well, I understand. The  
11 other risk, though, is that we delay getting the DCDA  
12 and this R-COLA done --

13 MS. COFFIN: Oh, we would never let that  
14 happen. I understand. So we will just keep dialoguing  
15 through Weidong and work that out, but as of today we  
16 are targeting April to do this kind of briefing. But  
17 if it turns out it is not in the best interest, then  
18 we can change.

19 This is the last slide, upcoming topics.  
20 In March there is going to be a presentation by  
21 Westinghouse on the shield building, and then in April  
22 again the information briefing for Summer and Levy,  
23 and we are targeting to present the Advanced final SER  
24 on the four chapters that I have listed there for the  
25 design cert amendment and for Vogtle, our reference

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COL.

2 CHAIRMAN RAY: Well, okay. As you heard  
3 me say to Charlie, I think, we are going to have to  
4 decide if at the end of this -- the end of the March  
5 meeting, whether there is anything we want to say to  
6 you at that time about the DCD. Of course, that will  
7 be a full Committee decision based on whatever the  
8 subcommittee decides to recommend.

9 So I have no idea whether that will result  
10 in a letter then or not.

11 MR. CUMMINS: So a comment: The airplane  
12 crash fits with the shield building. It depends on  
13 how you want the staff. The staff won't comment on  
14 the airplane crash yet, but if you are in the same  
15 mode in the airplane crash as in the shield building,  
16 it is a logical thing to do together, I guess. The  
17 thing that resists the airplane crash is the shield  
18 building.

19 MEMBER SHACK: The staff isn't going to  
20 talk about the shield building either in March.

21 MS. COFFIN: No, we will not.

22 CHAIRMAN RAY: We are going to have to  
23 talk to the staff about what works best for them as  
24 well. I am just saying that at some point I believe  
25 we will have to -- we will have to stop and think,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 okay, is there anything now that we should say to you  
2 or do we just want to keep on down this -- trucking  
3 down this road.

4 MS. COFFIN: Right.

5 CHAIRMAN RAY: I have no -- I can't tell  
6 you right now how that is likely to come out.

7 MS. COFFIN: I understand.

8 CHAIRMAN RAY: Poll everybody and see if  
9 there is a feeling that there is a need to communicate  
10 with you.

11 MS. COFFIN: That's it.

12 CHAIRMAN RAY: Any questions for  
13 Stephanie? All right.

14 Well, I will tell the subcommittee members  
15 that the calendar that Sherry produces reflects,  
16 obviously, a discussion of more detail with the staff  
17 as to when we should anticipate having meetings. We  
18 have to, most of us, look further than April in  
19 deciding if we can support meetings and when they are  
20 likely to be held.

21 So that will be coming shortly after the  
22 full committee meeting, an update of the outlook. Any  
23 comments or questions from anyone?

24 Now I will correctly, I think, say we will  
25 adjourn.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Are you going to send around  
2 electronic versions of all the presentations, so I can  
3 discard all the paper?

4 MR. WANG: If you request, yes.

5 MEMBER ARMIJO: Put them all on a CD for  
6 me.

7 MR. WANG: Sure.

8 CHAIRMAN RAY: We have three different  
9 modes among the members, electronic, CD and paper. I  
10 know you would like to have just one of the three, but  
11 it turns out that some of us deal in one or the other.

12 MEMBER BROWN: Until my DSL line, which is  
13 presently running at 10 kilobytes per second -- I  
14 would like a CD. I can't even download an e-mail,  
15 much less anything else, right now.

16 CHAIRMAN RAY: Thank you. We are going to  
17 adjourn and go off the record.

18 (Whereupon, the foregoing matter went off  
19 the record at 4:17 p.m.)

20

21

22

23

24

25

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



*Bellefonte 3&4*

*Lee Nuclear 1&2*

*Summer 2&3*

***Vogtle 3&4***

*Harris 2&3*

*Levy 1&2*

*Turkey Point 6&7*

# **AP1000 Reference Combined License Application Presentation to ACRS Chapter 13 Standard Topics**

**February 3, 2010**

# R-COLA Chapter 13: Standard Topics

## Conduct of Operations

**13.1 Organizational Structure of Applicant**

**13.2 Training**

**13.3 Emergency Planning**

**13.4 Operational Programs**

**13.5 Plant Procedures**

**13.6 Security**

**13.7 Fitness for Duty**

# R-COLA Chapter 13: Major Topics

## DCD incorporated by reference

- The only Standard Departure taken is to section numbering (STD DEP 1.1-1)

## Majority of FSAR Chapter 13 information is Plant Specific (e.g., Organization)

## Major supplemental information

- Operational Programs milestones (Table 13.4-201)
- Addressing COL items (next slide)

# R-COLA Chapter 13: COL Items

## COL 13.2-1 Training Program for Plant Personnel

- FSAR Section 13.2 provided training program description
- Incorporated NEI 06-13A

## COL 13.4-1 Operational Programs

- Provided FSAR Table 13.4-201, operational programs required by the NRC regulations
- The table provides listing of programs, regulatory requirements and implementation milestone

# R-COLA Chapter 13: COL Items

## COL 13.5-1 Plant Procedures

- FSAR 13.5 describes administrative and other procedures used to conduct the routine operating, abnormal, and emergency activities in a safe manner.

# R-COLA Chapter 13: Open Items

**All chapter 13 Open Items are Plant Specific**



**AP1000  
DCWG**



*Bellefonte 3&4*  
2/3/2010

*Lee Nuclear 1&2*

*Summer 2&3*

*Vogtle 3&4*

*Harris 2&3*

*Levy 1&2*

*Turkey Point 6&7*



# **Presentation to the ACRS Subcommittee**

## **AP1000 Combined License Application Review**

### **Chapter 13 Sections 13.4 Operational Programs**

February 3, 2010

# Staff Review Team

- Project Manager
  - Denise McGovern, PM, AP-1000 COL, Chapter 13

# Overview of COL FSAR Standard Content

## Chapter 13 Sections 13.4

<b>FSAR Section</b>	<b>IBR?</b>	<b>COL Standard Content</b>	<b>Required Site-Specific Content</b>
13.4 Operational Programs	Yes	Table – Operational Programs Required by NRC Regulations	None

# **STD COL 13.4-1**

## **Operational Programs Required by NRC Regulations**

### **Table 13.4-201**

- Addressed operational programs and implementation
- Operational program implementation not addressed in regulation – License Condition 3
- Timing of information related to operational programs to support NRC inspection activities – License Condition 6

# Standard Content

## Table 13.4-201 (SER Example)

Operational Program	Implementation Milestone(s)	Implementation Requirement(s)	SER Section(s)
1. Inservice Inspection Program	Prior to commercial service.	10 CFR 50.55a(g); ASME XI IWA-2430(b)	5.2.4, 5.4.2, 6.6
2. Inservice Testing Program	After generator online on nuclear heat.	10 CFR 50.55a(f), ASME OM Code	3.9.6, 5.2.4
3. Environmental Qualification Program	Prior to initial fuel load.	License Condition	3.11



# **Presentation to the ACRS Subcommittee**

## **AP1000 Combined License Application Review**

### **Chapter 13 Sections 13.1, 13.2 & 13.5 Conduct of Operations**

February 3, 2010

# Staff Review Team

- Technical Staff
  - Michael Junge, Chief, COLP
  - Jim Kellum, Lead Reviewer, COLP
- Project Manager
  - Denise McGovern, PM, AP-1000 COL, Chapter 13

# Overview of COL FSAR Standard Content

## Chapter 13, Conduct of Operations

### Sections 13.1, 13.2 & 13.5

FSAR Section	IBR?	COL Standard Content	Required Site-Specific Content
13.1 Organizational Structure of Applicant	Yes	None	Organizational Structure
13.2 Training	Yes	NEI 06-13A Rev.1	
13.5 Plant Procedures	Yes	Addressing Plant Procedures	

# STD COL 13.2-1

## Licensed Operators and Non-Licensed Plant Staff Training

NEI 06-13A Revision 1 - Template for an Industry Training Program

- Provides the description of the training programs for plant personnel, including the requalification program for licensed operators.

# STD COL 13.5-1

## Plant Procedures

COL applicants referencing the AP1000 will address:

- Administrative Procedures
- Operating Procedures

# **ACRS Subcommittee Presentation SER Chapter 13**

*Discussion/Committee Questions*



*Bellefonte 3&4*

*Lee Nuclear 1&2*

*Summer 2&3*

*Vogtle 3&4*

*Harris 2&3*

*Levy 1&2*

*Turkey Point 6&7*



**AP1000 Reference  
Combined License Application  
Presentation to ACRS  
Chapter 15 Selected Topics**

**February 2, 2010**

NuStart Energy Development, LLC - All Rights Reserved

# R-COLA Chapter 15: Standard Topics

## Accident Analyses

### 15.0 General Information

### 15.1 Increase in Heat Removal from the Primary System

### 15.2 Decrease in Heat Removal by the Secondary System

### 15.3 Decrease in Reactor Coolant System Flow Rate

### 15.4 Reactivity and Power Distribution Anomalies

### 15.5 Increase in Reactor Coolant Inventory

### 15.6 Decrease in Reactor Coolant Inventory

### 15.7 Radioactive Release from a Subsystem or Component

### 15.8 Anticipated Transient Without Scram

### 15A Evaluation Models and Parameters for Analysis of Radiological Consequences of Accidents

### 15B Removal of Airborne Activity from the Containment Atmosphere Following a LOCA



## **R-COLA Chapter 15: Major Topics**

- **DCD incorporated by reference**
  - No Standard Departures taken
- **Majority of FSAR Chapter 15 information is IBR of DCD**
- **Standard supplemental information**
  - None



# R-COLA Chapter 15: COL Items

**No Standard COL Items**

*Bellefonte 3&4*

*Lee Nuclear 1&2*

*Summer 2&3*

*Vogle 3&4*

*Harris 2&3*

*Levy 1&2*

*Turkey Point 6&7*



# R-COLA Chapter 15: Open Items

**OI 15.0-1 Calorimetric Power Uncertainty (STD COL 15.0-1)**

**OI 15.4-1 Re-insert Reference to GL 85-05 re Boron Dilution  
(Chapter 1 administrative item)**



Bellefonte 3&4    Lee Nuclear 1&2    Summer 2&3    Vogtle 3&4    Harris 2&3    Levy 1&2    Turkey Point 6&7

# **AP1000 Reference Combined License Application Follow-up Information to ACRS FSAR Chapter 9 – Table 9.5-201**

February 3, 2010

## BTP CMEB 9.5-1 C.1.b wording:

*Fires involving facilities shared between units and fires due to man-made site-related events that have a reasonable probability of occurring and affecting more than one reactor unit (such as an aircraft crash) should be considered.*

## Applicable DCD Table excerpt:

<b>Table 9.5.1-1 (Sheet 2 of 33)</b> <b>AP1000 FIRE PROTECTION PROGRAM COMPLIANCE WITH BTP CMEB 9.5-1</b>			
<b>BTP CMEB 9.5-1 Guideline</b>	<b>Paragraph</b>	<b>Comp</b>	<b>Remarks</b>
15. Fires due to man-made site-related events that have a reasonable probability of occurring and affecting more than one reactor unit should be considered.	C.1.b	WA	To be evaluated on a site-specific basis. Plant siting decisions are expected to preclude the need to consider such events.

## Applicable FSAR Table excerpt:

<b>TABLE 9.5-201 (Sheet 3 of 7)</b> <b>AP1000 FIRE PROTECTION PROGRAM COMPLIANCE WITH BTP</b> <b>CMEB 9.5-1</b>			
<b>BTP CMEB 9.5-1</b> <b>Guideline</b>	<b>Paragra</b> <b>ph</b>	<b>Comp</b>	<b>Remarks</b>
<b>Fire Protection Analysis</b>			
15. Fires due to man-made site-related events that have a reasonable probability of occurring and affecting more than one reactor unit should be considered	C.1.b	C	Comply <b>Subsections 2.2</b> and <b>3.5</b> establish that these events are not credible

## From FSAR

### 2.2.3.3.2 Fire Due to an Accident at Offsite Industrial Storage Facility

*Units 3 and 4 are located at a farther distance from Plant Wilson than Units 1 and 2. Drawing from the conclusion based on the previous evaluation of Units 1 and 2, any industrial fire due to diesel oil or miscellaneous oils stored at Plant Wilson **would not** have an impact on control room habitability or **cause thermal damage to safety-related structures at Units 3 and 4.***



# **Presentation to the ACRS Subcommittee**

**AP1000 Combined License Application Review  
Standard Content for**

**Chapter 15  
Accident Analyses**

February 3, 2010

# Staff Review Team

- **Technical Staff**
  - **Yi-Hsiung (Gene) Hsui**, Reactor Systems, Nuclear Performance & Code Review Branch
  - **Jay Lee**, Siting and Accident Consequences Branch
  - **Michelle Hart**, Siting and Accident Consequences Branch
- **Project Management**
  - **Donald Habib**, Chapter 15, AP1000 Standard Content COL
  - **Joseph Sebrosky**, AP1000 Standard Content COL

# Overview of AP1000 Standard Content

## Chapter 15 - Accident Analysis

FSAR Section	IBR?	COL Standard Content	Required Site-Specific Content
15.0 Accident Analysis	Yes	<b>Calorimetric uncertainty methodology (open item)</b>	None
15.1 Increase in Heat Removal from the Primary System	Yes	None	None
15.2 Decrease in Heat Removal by the Secondary System	Yes	None	None
15.3 Decrease in Reactor Coolant System Flow Rate	Yes	None	None
15.4 Reactivity and Power Distribution Anomalies	Yes	<b>Inadvertent boron dilution, Generic Letter 85-05, (open item)</b>	None
15.5 Increase in Reactor Coolant Inventory	Yes	None	None
15.6 Decrease in Reactor Coolant Inventory	Yes	None	Atmospheric dispersion factors
15.7 Radioactive Release from a Subsystem or Component	Yes	None	Liquid release
15.8 Anticipated Transients without Scram	Yes	None	None
Appendix 15A Evaluation Models and Parameters for Analysis of Radiological Consequences of Accidents	Yes	None	Atmospheric dispersion factors
Appendix 15B Removal of Airborne Activity from the Containment Atmosphere Following a LOCA	Yes	None	None
Radiological Consequences of Accidents	Yes	<b>Dual unit analysis</b>	

# 15.0 Accident Analysis

- COL FSAR Section 15.0 incorporates by reference with no departures or supplements Section 15.0 of Revision 17 of the AP1000 DCD
- In response to RAI-SRP15.0-SRSB-02 pertaining to assumed 1% initial power uncertainty in safety analysis, Westinghouse proposed COL Information Item 15.0-1 (to be included in AP1000 DCD, Rev. 18).
  - Following selection of actual plant operating instrumentation and calculation of instrumentation uncertainties of operating plant parameters prior to fuel loads, COL holder will calculate primary power calorimetric uncertainty, using an NRC acceptable method, and confirm it is bounded by the safety analysis uncertainty.
- Staff identifies Open Item 15.0-2 for implementation of COL Info Item 15.0-1
  - Submit information to support 1% power measurement uncertainty
    - A reference to NRC approval of the main feedwater and power measurement methodology, instrumentation, and associated uncertainties, or
    - A detailed description of analyses of main feedwater flow and power measurement uncertainties.

# Generic Letter 85-05, Inadvertent Boron Dilution Event

- GL 85-05 urges each licensee to ensure its plants have adequate protection against boron dilution events
- GL 85-05 was resolved based on analyses of inadvertent boron dilution events, terminated by automatic functions, or operator action with sufficient time available (NUREG-1793, DCD SER)
- COL Item 13.5-1 requires development of emergency operating procedures
- BLN COL FSAR, Table 1.9-204, “Generic Communications Assessment,” listed Bulletins and GLs
- GL 85-05 was included in Table 1.9-204, Rev. 0, but removed in Rev. 1
- Staff identified Open item 15.4-1
  - Reinsert a reference to GL 85-05 in Table 1.9-204 to provide a cross reference to COL information item 13.5-1

# STD SUP 6.4-1

## Dual Unit Analysis for Control Room Habitability

- The standard response stated that:

Radiological dose to the control room operators at an adjacent AP1000 unit due to a radiological release from another unit is bounded by the dose to control room operators on the affected unit. Simultaneous accidents at multiple units at a common site are not considered to be a credible event.

- The staff agrees with the standard response to STD 6.4-1



# **Presentation to the ACRS AP1000 Subcommittee**

AP1000 Design Certification Amendment  
Application Review

## **Regulatory Treatment of Non-Safety Systems**

February 3, 2010

Mark Caruso  
Malcolm Patterson

# Purpose

- Review the history of regulatory treatment of non-safety systems (RTNSS).
- Explain the scope of RTNSS.
- Describe the staff's review of RTNSS in the AP1000 design certification amendment application.
- Answer the subcommittee's questions.



# Review of Passive Plant Designs

- Passive systems perform primary safety functions:
  - reactor water make-up
  - core cooling
  - containment cooling
- Passive systems use natural forces and DC power to perform their safety function and are designated safety-related
- Uncertainties in passive system reliability not completely addressed by testing and design enhancements



# Review of Passive Plant Designs

- Active systems:
  - not credited in design basis accident analysis
  - generally designated as non-safety systems

Some key active systems in passive plant designs:

- provide defense-in-depth for some safety functions
  - reduce challenges to passive systems
  - support passive systems 72 hours post-accident
  - may be risk-significant
- Commission and industry agreed that some regulatory oversight of some non-safety systems may be appropriate



# Process

- Identify non-safety SSCs that deserve regulatory treatment
- Determine Reliability/Availability Mission for each SSC
- Determine appropriate treatment for each SSC
  - technical specification controls
  - availability controls
  - design considerations
  - reliability assurance program

# RTNSS SSC Selection Criteria

## Non-safety-related SSCs:

- relied upon to meet ATWS and SBO rules
- relied upon for core cooling, containment heat removal, or control room habitability more than 72 hours after accident
- provide diagnostic information more than 72 hours after accident
- relied upon to meet Commission's safety goals
- that cause initiating event that significantly affect CDF or LRF ( $> 1\%$ )
- relied on to meet containment performance goals
- (added to the design) to prevent significant adverse interaction between active and passive systems



# Reliability Assurance Program

- includes elements for design control and quality assurance
- staff review per Standard Review Plan 17.4
- design reliability assurance program (D-RAP) until initial fuel load
- operational-phase reliability assurance activities (OPRAAs) after initial fuel load

## Staff review of RTNSS limited to

- DCA changes
  - in program
  - in scope
- COL
  - deviations
  - plant-specific items

# DCA Changes

## Program

- no changes (18 QA requirements)

## Scope

- nothing deleted (rationale changes)
- a few additions

# DCD Changes (continued)

## Items added

- remote DAS cabinet
- 6900 Vac buses
- check valves in the RNS
- containment isolation valves (letdown)

# COLA Changes

- no deviations
- scope incorporated by reference
- QA programs are licensee's responsibility described in FSAR Section 17.5, "Quality Assurance Program Description—New License Applicants"



# Questions?

---

# AP1000 RCP Flywheel

Dale Wiseman


February 3, 2010

# Purpose

---

- Provide Information Regarding AP1000 Reactor Coolant Pump Flywheel
  - Materials
  - Inspection Requirements

AP1000 RCP  
CONFIGURATION FOR  
PROTOTYPE TEST  
APRIL 15, 2009




# AP1000 RCP Outline


Upper Flywheel Assembly

Lower Flywheel Assembly

# Flywheel Configurations



DCD Revision 15  
Depleted Uranium Alloy  
Enclosure



DCD Revision 17  
Inner Hub  
Heavy Tungsten Alloy  
Outer Retainer Ring  
Enclosure Plates and Shell

# Flywheel Materials

	Shaft	Inner Hub	Flywheel	Retainer Ring	Enclosure
DCD Rev 15	403 SST	N/A	Depleted Uranium Alloy U-2Mo	N/A	Alloy 690
DCD Rev 17	403 SST	403 SST	Tungsten Heavy Alloy	18 Ni Maraging Steel	Alloy 625
Post DCD R17 (RAI 5/09)	403 SST	403 SST	Tungsten Heavy Alloy	18Cr-18Mn	Alloy 625

# Flywheel Materials Specifications

	Shaft	Inner Hub	Flywheel	Retainer Ring	Enclosure
DCD Rev 15	ASTM 336 – Gr F6	N/A	Design Spec Specified	N/A	ASTM B168 and B564
DCD Rev 17	ASTM 336 – Gr F6	ASTM 336 – Gr F6	ASTM B777 Class 4	AMS 6519	ASTM B443 and B564
Post DCD R17 (RAI 5/09)	ASTM 336 – Gr F6	ASTM 336 – Gr F6	ASTM B777 Class 4	ASTM A289	ASTM B443 and B564

# Discussion of Material Changes

---

- **High Density Flywheel Material Change – Depleted Uranium to Tungsten Heavy Alloy**
  - Increase in Required Inertia - As the RCP Design was Finalized, Friction Losses Increased Due to Increased Power Requirements, Detailed Loss Calculations, etc.
  - Depleted Uranium was Structural Component – Increase in Inertia Required Increase in Diameter Which Resulted in High Stress Levels
  - Evaluated Alternate Materials – Tungsten Heavy Alloy
    - Advantages of Tungsten Heavy Alloy – Multiple Suppliers, Known Material Properties/Fracture Toughness (ASTM), Volumetric Examinations Standard, No Environmental/Health Issues, Owning/Handling Not Regulated
  - DCD Revision 17 Flywheel Configuration Changed Such that High Density Material is Not a Structural Part
    - Retainer Ring Holds Tungsten Heavy Alloy Segments, Only Structural Components are Ring and Inner Hub

# Discussion of Material Changes (Con.)

---

- Flywheel Enclosure
  - Change from Alloy 690 to Alloy 625
  - Advantages of Alloy 625 – Lower Coefficient of Thermal Expansion (Reduces Stresses in Enclosure); Higher Yield Strength; Easier to Weld
- Retainer Ring
  - DCD Revision 17 – 18 Ni Maraging Steel for High Strength
    - Flywheel Mockup for Manufacturability and Demonstrate Balancing
      - Cracked Retainer Ring
      - Hydrogen Embrittlement/Stress Corrosion Cracking
  - Retainer Ring Material Change Included in Response to RCP RAI in May 2009
    - Ring Changed to 18Cr-18Mn
    - Material Developed for Retainer Ring Applications in Generators Because of Cracking in the Materials in Use (18Mn-5Cr)
    - Not Susceptible to Corrosion or Hydrogen Assisted Stress Corrosion Cracking
    - Lower Strength Requires Thicker Retainer Ring, Reduces Tungsten Alloy Mass

# Summary of Inertia Changes

	Rotating Inertia (lb-ft <sup>2</sup> )	Reason for Change
DCD Rev 15	16,500	
DCD Rev 17	23,510	Detailed Design- Additional Losses
Post DCD R17 (RAI 5/09)	23,110	Change in Retainer Ring Reduced Tungsten Volume/Mass

- Flow Coastdown Requirements in Design Spec Have Not Changed
- Calculated Pump Coastdown Flows Have Always Been Higher Than Those Used in the Safety Analyses

# Flywheel Inspection/Testing Requirements

---

- Each Structural Component Inspected Prior to Final Assembly According to Requirements In Section III, NB-2500 of ASME Code
  - Inner Hub
    - Ultrasonic Examination
    - Magnetic Particle Examination
    - Liquid Penetrant Examination of Inside Surface After Finishing Operations
  - Retainer Ring
    - Liquid Penetrant Examination
    - Ultrasonic Examination
    - Liquid Penetrant Examination of Outside Surface After Finishing Operations
  - Enclosure (Non-Structural)
    - Dye Penetrant of Welds
    - Enclosure Leak Tested
- Impact Testing – Inner Hub and Retainer Ring Material
- No In-Service Inspection Required
  - Postulated Flywheel Missiles are Contained Within the Pressure Boundary
  - In-Service Inspection of the Flywheel Would Require Pump Removal, Disassembly, and Removal of Flywheel Enclosures
  - High Radiation Exposure

# Flywheel Missile Analyses

---

- Follows Procedure Used for Turbine Disk Fractures (Hagg and Sankey, “The Containment of Disk Burst Fragments by Cylindrical Shells”)
  - Stage 1 – Inelastic Impact and Transfer of Momentum to the Pressure Boundary (PB)
  - Stage 2 – Dissipation of Energy in Plastic Tensile Strain in the PB
  - Calculation Assumptions
    - Ignore the Retainer Ring and Enclosure Components
    - Minimum ASME Material Strength Properties @ Design Temperature
    - All Heavy Alloy Segments Impact the PB
    - Upper Flywheel – Check Penetration Through Thermal Barrier and Stator Closure
    - Lower Flywheel – Check Penetration Through Stator Lower Flange
  - DCD Rev 17 Minimum Margin is 1.8 for Upper Flywheel Stage 2
  - Minimum Margin for Flywheel Design Change in Retainer Ring Material (May 2009 RAI Response) Increased to 2.0 for Upper Flywheel Stage 2 Due to Small Changes in Tungsten Alloy Segments and Pressure Boundary



# **AP1000 Design Center Upcoming Interactions with the ACRS**

Eileen McKenna, Branch Chief (AP1000 Projects)  
Stephanie Coffin, Branch Chief (AP1000 Projects)  
February 2 - 3, 2010

# Phase 5 ACRS Interactions - DCA

- Westinghouse Design Certification Amendment Review
  - Phases 2 and 3 nearly complete
  - 18 of 19 SER with open items chapters issued and presented
  - Chapters 3.7/3.8 and 6 schedules are under evaluation
- Staff will be issuing the Advanced Final Safety Evaluation Report (AFSER) on a chapter-by-chapter basis
- All open items will be resolved prior to chapter issuance. Some confirmatory items may remain.
- Some review areas have not previously been presented to the ACRS for this design center (e.g., security reviews, aircraft impact analysis)
- Expect multiple meetings with ACRS AP1000 subcommittee through the calendar year

# Phase 5 ACRS Interactions - RCOL

- AP1000 COL Standard Content Review
  - Phases 2 and 3 nearly complete
  - 18 of 19 SER with open items chapters issued; most presented
  - Chapters 3.7/3.8 and 6 schedules are under evaluation
- Staff will be issuing the Advanced Final Safety Evaluation Report (AFSER) on a chapter-by-chapter basis
- All open items will be resolved prior to chapter issuance. Some confirmatory items may remain.
- Some review areas have not previously been presented to the ACRS for this design center (e.g., security reviews, loss of large areas due to fires/explosions)
- Expect multiple meetings with ACRS AP1000 subcommittee through the calendar year

# Presentation Format

- DCA and RCOL chapters will be presented at the same meeting with separate presentations for the DCA and RCOL
- DCA and COL applicants and NRC staff presentations
- Focus of staff presentations will be on key review areas and closure of open items
- Chapters to be presented will be issued at least 30 days prior to meeting

# ACRS Interactions - SCOLs

- Informational briefings on specific topics of interest related to the Summer and Levy County COL reviews
- Topics from chapters 2 (site characteristics), 8 (electrical), and 13 (emergency preparedness), and other site-specific topics that may be of interest to the ACRS
- Feedback on review topics of particular interest to ACRS members welcomed
- Targeting April 2010

# Upcoming Topics

- March 2010
  - Shield Building
  
- April 2010
  - Informational briefings for Summer and Levy
  - AFSER briefings on AFSER for DCA and RCOL
    - Chapter 2 (site characteristics)
    - Chapter 4 (reactor)
    - Chapter 11 (radioactive waste management)
    - Chapter 12 (radiation protection)