



College of Engineering  
Department of Nuclear & Radiological Engineering  
University of Florida Training Reactor

202 Nuclear Science Bldg.  
PO Box 118300  
Gainesville, FL 32611-8300  
352-392-1401 x306  
352-392-3380 Fax  
haghighat@ufl.edu

June 1, 2010

Document Control Desk  
U.S, Nuclear Regulatory Commission  
Washington, DC 20555  
Attn: Mr. Duane Hardesty

Dear Mr. Hardesty,

Subject: University of Florida Training Reactor (UFTR) License Renewal (TAC NO. ME 1586),  
DOCKET NO. 50-83

Enclosed is a document provide bases for Chapter 5 for renewal of Facility Operating License No. R-56 for the University of Florida Training Reactor (UFTR).

If you need further information, please do not hesitate to contact me at [haghighat@ufl.edu](mailto:haghighat@ufl.edu) or (352) 392-1401 x306.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on June 1, 2010

Sincerely,

Alireza Haghighat, PhD  
FP&L Endowed Chair Professor  
Director of UFTR

Cc Jack Donohue, NRC  
Gabriel Ghita, UF  
David Hintenlang, Interim Chair  
Brian Shea, UFTR Manager  
Glenn Sjoden, RSRS Chair  
UFTR – NRC file



**Lisa L. Purvis**  
Commission # DD608673  
Expires November 3, 2010  
Bonded Troy Pain - Insurance, Inc. 889-886-7919

*Alachua County, Florida*  
*June 1, 2010*  
*Lisa L. Purvis*

A020  
NRR

## **Bases for Section 5 (titled 'Design Features') of the UFTR's Technical Specifications**

The UFTR uses an Argonaut design, which offers significant safety and security features. On the safety, the residual heat in the fuel is very low, thereby resulting in a unique shut down mechanism in the form of dumping of the coolant/moderation water. On the security, besides a secure confinement building and separation of the reactor cell from the other offices and labs of the reactor building, the reactor core is placed under ~50 tons of concrete, and the fuel is dispersed in an aluminum plate with aluminum cladding.

The primary cooling system is designed such that the reactor core is kept at low pressures and temperatures. This is achieved by the proper arrangement of the fuel bundles in a fuel box, which results in prevention of occurrence of local boiling at the maximum power; i.e., the combinations of coolant flow-rate, inlet coolant temperature, and the maximum operating power, keeps the system away from the Onset of Nuclear Boiling (ONB). The secondary cooling system provides the necessary mechanisms for the removal of heat from the primary cooling system and the isolation of the primary coolant from the environment and public. Aforementioned features further contribute to the safety margins of the UFTR.

Finally, the fuel storage facilities of the UFTR have been designed for maintaining a highly subcritical condition even under a flooding event.