

EPRI

ELECTRIC POWER
RESEARCH INSTITUTE

Assessment of Mitigation Effectiveness under HWC/NMCA from Core Shroud Reinspection Data

Raj Pathania

Bob Carter

EPRI

EPRI-NRC Technical Exchange Meeting

May 25-26, 2010

Objectives

- *Objectives: To evaluate the effectiveness of IGSCC mitigation in BWR internals by MHWC, NMCA and OLNC and to provide the technical basis for inspection relief*
- Evaluation of core shroud reinspection data
 - Normal Water Chemistry (NWC) plants
 - Hydrogen Water Chemistry (MHWC) plants
 - Noble Metal Chemical Addition (NMCA) plants
 - Online Noble Metal Chemical Addition (OLNC) plant


Approach

- Compiled UT inspection data for indications in core shroud circumferential welds
 - Nine Plants - NWC
 - Four Plants - MHWC
 - Four Plants - NMCA
 - One Plant - OLNC
- Determined Crack Growth Rates (CGRs) for length and depth direction of each indication between inspection periods
- Inspection intervals varied from 1 to 4 years for NWC and 2 to 10 years for mitigated plants
- Indications showing negative or zero CGRs were treated as non-growing cracks
- Developed cumulative frequency distributions for measured CGRs
- Compared measured CGRs with bounding CGRs for NWC and HWC used in BWRVIP-14-A
- Compared CGR distributions in NWC versus MHWC, NMCA and OLNC plants


HWC Availability for MHWC, NMCA and OLNC Plants

Mitigation	Plant	Time-Weighted H ₂ Availability %
M-HWC	A	79.8
	B	89.8
	C	90.9
	D	92.2
NMCA	E	92.9
	F	97.9 / 99.1
	G	95.6
	H	97.2
OLNC	I	97.9


Length CGR Distribution (+/- Data) NWC vs. MHCW




Length CGR Distribution (+/- Data) NWC vs. NMCA




Length CGR Distribution (+/- Data) NWC vs. OLNC




Length CGR Distribution (+/- Data) NWC vs. MHWC/NMCA/OLNC for All Plants




Depth CGR Distribution (+/- Data) NWC vs. MHW




Depth CGR Distribution (+/- Data) NWC vs. NMCA



Depth CGR Distribution (+/- Data) NWC vs. OLNC




Depth CGR Distribution (+/- Data) NWC vs. MHW/C/NMCA/OLNC for All Plants




Summary

- Data reflects a decrease in deepening CGR for MHWC/NMCA/OLNC when compared to NWC
 - **BWRVIP-14-A approved deepening disposition rate bounds 96% of MHWC/NMCA/ OLNC deepening rates**
 - **55% showed no deepening**
- Data reflects a decrease in lengthening CGR for MHWC/NMCA/OLNC when compared to NWC
 - **Approved lengthening rate bounds 88% of MHWC/NMCA/OLNC lengthening rates**
 - **40% showed no lengthening**

Deepening Disposition rate:
 1.1×10^{-5} in/hr (2.4 mm/y)




Lengthening Disposition rate:
 5×10^{-5} in/hr (11.1 mm/y)



Mitigation Effectiveness in MHWC/NMCA/OLNC Plants - Conclusions

- Analysis of re-inspection data of core shrouds of eight MHWC/NMCA/OLNC mitigated plants strongly supports the effectiveness of mitigation compared to the NWC plants
- Effects of the decreasing residual stress fields may also play a role in decreased deepening rates
- These results were published in a revision to BWRVIP-174 in 2009
- The study will be updated again in 2011 with data from additional MHWC/NMCA/OLNC plants



BWR reinspection data provide strong evidence that NMCA, OLNC and MHWC are effective in mitigating IGSCC and support extended reinspection intervals



BWRVIP Strategy for Optimizing Inspection of Reactor Vessel Internals

Background

- BWRVIP Inspection & Evaluation (I&E) Guidelines were developed using the available inspection data, operating experience and industry knowledge on degradation mechanisms at the time the reports were published
 - Initial guidelines were largely based on safety considerations and did not consider the extent of degradation issues in the fleet or the potential benefit of mitigation (e.g. HWC)
- Post-implementation of I&E Guidelines
 - Large amount of inspection data has now been generated which provides insight on component degradation and mitigation effectiveness
 - Widespread implementation of HWC / NMCA
 - BWRVIP R&D efforts have improved industry knowledge on degradation mechanisms
 - NDE improvements both in UT and VT

Objective

- BWRVIP intends to re-visit the I&E Guidelines and to optimize the inspection programs based on:
 - Latest field inspection data and fleet operating experience
 - SCC mitigation associated with HWC / NMCA
 - Current NDE capabilities
 - Component repairs
 - In-situ crack growth rate studies
 - Structural analyses

Priority of Components

#	I&E Guideline	Priority
1	Core Spray (BWRVIP-18R1)	High
2	Jet Pump (BWRVIP-41R2)	
3	Shroud (BWRVIP-76)	
4	Shroud Support (BWRVIP-38)	
5	CRD Guide Tubes (BWRVIP47-A)	
6	Vessel ID Brackets (BWRVIP-48-A)	Medium
7	Top Guide Rims / Pins (BWRVIP26-A)	
8	SLC / Core DP Piping (BWRVIP-27-A)	
9	LPCI Coupling (BWRVIP-42-A)	
10	Access Hole Cover (BWRVIP-180)	
11	Jet Pump Beam (BWRVIP-138 R1)	
12	Top Guide Grid Beam (BWRVIP-183)	Low
13	Core Plate Bolts (BWRVIP-25)	
14	Steam Dryer (BWRVIP-139-A)	
15	Bottom Head Drain Piping (BWRVIP-205)	

Summary

- I&E Guideline Inspection Optimization Roadmap completed
- Priority of components defined
- Component specific evaluations of high priority components to be conducted in 2010-2012
- Briefings with NRC anticipated to review preliminary results and obtain feedback



Together...Shaping the Future of Electricity