

**From:** ken.nicely@exeloncorp.com  
**Sent:** Thursday, June 10, 2010 10:29 AM  
**To:** Goodwin, Cameron  
**Subject:** RE: LaSalle AST  
**Attachments:** AST Question.pdf

Cameron,

The attached information addresses the question related to the usable diesel fuel volume.

Thanks,  
Ken Nicely

---

**From:** Goodwin, Cameron [mailto:Cameron.Goodwin@nrc.gov]  
**Sent:** Wednesday, June 02, 2010 2:13 PM  
**To:** Nicely, Ken:(GenCo-Nuc)  
**Subject:** LaSalle AST

Per UFSAR Section 9.5.4.1.1 (Rev. 18), the usable diesel fuel volume required to support each Division 1 and 2 diesel generator continuous operation at rated load for 7 days is 32,200 gallons. Division 1 diesels will now be loaded above the continuous rating due to the load increase needed for the AST amendment. Provide a detailed discussion addressing how the EDG 7 day fuel supply requirement is satisfied as a result of this AST amendment.

Thank you,

Cameron

**Mrs. Cameron Goodwin**  
Division of Operating Reactor Licensing  
LaSalle Project Manager  
Phone: (301)415-3719  
Email: [Cameron.Goodwin@nrc.gov](mailto:Cameron.Goodwin@nrc.gov)

\*\*\*\*\* This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. \*\*\*\*\*

---

**E-mail Properties**

Mail Envelope Properties (BB85B9582429394AAD8F2969B2FD7C976F6FAD)

Subject: RE: LaSalle AST  
Sent Date: 6/10/2010 10:29:09 AM  
Received Date: 6/10/2010 10:29:09 AM  
From: ken.nicely@exeloncorp.com

Created By: ken.nicely@exeloncorp.com

Recipients:  
Cameron.Goodwin@nrc.gov (Goodwin, Cameron)  
Tracking Status: None

Post Office:  
cccmsxch18.energy.power.corp

Files	Size	Date & Time
MESSAGE	81168	6/10/2010
AST Question.pdf	61288	

Options  
Expiration Date:  
Priority: olImportanceNormal  
ReplyRequested: True  
Return Notification: False

Sensitivity: olNormal  
Recipients received: