12/12/05 Facility: VC Summer Date of Examination: Examination Prepared By (Circle): **NRC** Facility Written / Operating Test Written / Operating Test DUTLING

	Written / Operating rest Writte	en / Operating rest
Target Date*	Task Description (Reference)	Chief Examiner's Initials
-180	Examination administration date confirmed (C.1.a; C.2.a and b)	ED 7/12/05
-120	2. NRC examiners and facility contact assigned (C.1.d; C.2.e)	De 7/12/05
-120	3. Facility contact briefed on security and other requirements (C.2.c)	Ed 1/11/es
-120	4. Corporate notification letter sent (C.2.d)	@N 7/13/05
[-90]	[5. Reference material due (C.1.e; C.3.c; Attachment 2)]	@ 8/10/05
{-75}	6. Integrated examination outline(s) due, including Forms ES-201-2, ES-ES-301-1, ES-301-2, ES-301-5, ES-D-1's, ES-401-1/2, ES-401-3, ES-401-4, as applicable (C.1.e and f; C.3.d)	
{-70}	{7. Examination outline(s) reviewed by NRC and feedback provided to licensee (C.2.h; C.3.e)}	facility N/A-
{-45}	8. Proposed examinations (including written, walk-through JPMs, and scenarios, as applicable), supporting documentation (including Fo ES-301-3, ES-301-4, ES-301-5, ES-301-6, and ES-401-6), and ref materials due (C.1.e, f, g and h; C.3.d)	rms ~/A
-30	9. Preliminary license applications (NRC Form 398's) due (C.1.I; C.2. ES-202)	.g; @ 11/14/05
-14	10. Final license applications due and Form ES-201-4 prepared (C.1.I ES-202)	199
-14	11. Examination approved by NRC supervisor for facility licensee revie (C.2.h; C.3.f)	
-14	12. Examinations reviewed with facility licensee (C.1.j; C.2.f and h; C.3	3.g) (
-7	13. Written examinations and operating tests approved by NRC super (C.2.i; C.3.h)	visor 12/6/05
-7	14. Final applications reviewed; 1 or 2 (if >10) applications audited to qualifications / eligibility; and examination approval and waiver lett (C.2.i; Attachment 4; ES-202, C.2.e; ES-204)	ers sent
-7	15. Proctoring/written exam administration guidelines reviewed with facility licensee (C.3.k)	(Eg) 11/30/05
-7	16. Approved scenarios, job performance measures, and questions distributed to NRC examiners (C.3.i)	ON 12/8/05

<sup>\*</sup> Target dates are generally based on facility-prepared examinations and are keyed to the examination date identified in the corporate notification letter. They are for planning purposes and may be adjusted on a case-bycase basis in coordination with the facility licensee. [Applies only] {Does not apply} to examinations prepared by the NRC.

# **Examination Outline Quality Checklist**

Form ES-201-2

Facility	V.C. Summer 2005 - 361 Date of Examination:	12/	12/8	>5
			Initials	3
Item	Task Description	а	b*	c#
1. W	a. Verify that the outline(s) fit(s) the appropriate model, in accordance with ES-401.	0	MA	B
R	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all K/A categories are appropriately sampled.	C	NA	8
T	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	0	MA	
E N	d. Assess whether the justifications for deselected or rejected K/A statements are appropriate.	0	M/A	8
2. S	<ul> <li>Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, technical specifications, and major transients.</li> </ul>	a	NA	Ø
I M U L A T	b. Assess whether there are enough scenario sets (and spares) to test the projected number and mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity, and ensure that each applicant can be tested using at least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s), and that scenarios will not be repeated on subsequent days.	a	N/A	Ø.
O R	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.	C	~/ <sub>A</sub>	(F)
3. W / T	<ul> <li>a. Verify that the systems walk-through outline meets the criteria specified on Form ES-301-2: <ol> <li>the outline(s) contain(s) the required number of control room and in-plant tasks distributed among the safety functions as specified on the form</li> <li>task repetition from the last two NRC examinations is within the limits specified on the form</li> <li>no tasks are duplicated from the applicants' audit test(s)</li> <li>the number of new or modified tasks meets or exceeds the minimums specified on the form</li> <li>the number of alternate path, low-power, emergency, and RCA tasks meet the criteria on the form.</li> </ol> </li> </ul>	c	MA	Ø
	b. Verify that the administrative outline meets the criteria specified on Form ES-301-1:  (1) the tasks are distributed among the topics as specified on the form  (2) at least one task is new or significantly modified  (3) no more than one task is repeated from the last two NRC licensing examinations	C	N/A	B
	Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on subsequent days.	0	MA	0
4.	a. Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam sections.	0	NA	100
G	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	0	NA	00
E N	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	1	MA	(B)
E	d. Check for duplication and overlap among exam sections.	0	NA	8
R	e. Check the entire exam for balance of coverage.	10	MA	8
l C	f. Assess whether the exam fits the appropriate job level (RO or SRO).	1	NIA	(3)
c. NR	thor C Chief Examiner (#)  Printed Name/Signafure    MARK A. CHITTY   MARK			ate 107/05 1/A 1005
d. NR	C Supervisor Edwin Leit, Jef ladwen gra, if		-//	
Note:	# Independent NRC reviewer initial items in Column "c"; chief examiner concurrence rec	quired.		



# ES-201

# **Examination Outline Quality Checklist**

Form ES-201-2

Facility:	VC Summer Date of Examinati	on: 0	1/10/2	2006					
Item	Task Description		Initial						
1.	a. Verify that the outline(s) fit(s) the appropriate model, in accordance with ES-401.	a	b*	c#					
W R I	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all K/A categories are appropriately sampled.	C	+	@					
T T	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	C	/ N/A	@					
E N	d. Assess whether the justifications for deselected or rejected K/A statements are appropriate	. 0	N/A	@2					
2. S	Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, technical specifications, and major transients.		N/A	60					
MULATO	b. Assess whether there are enough scenario sets (and spares) to test the projected number a mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity, and ensure that each applicant can be tested using a least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s), and that scenarios will not be repeated on subsequent days.	ı	N/A	<b>Ø</b>					
O R	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.	e C	N/A	<b>₩</b>					
3. W / T	<ul> <li>a. Verify that the systems walk-through outline meets the criteria specified on Form ES-301-2:</li> <li>(1) the outline(s) contain(s) the required number of control room and in-plant tasks distribut among the safety functions as specified on the form</li> <li>(2) task repetition from the last two NRC examinations is within the limits specified on the form</li> <li>(3) no tasks are duplicated from the applicants' audit test(s)</li> <li>(4) the number of new or modified tasks meets or exceeds the minimums specified on the form</li> <li>(5) the number of alternate path, low-power, emergency, and RCA tasks meet the criteria of the form.</li> </ul>	ted C	N/A	@					
	b. Verify that the administrative outline meets the criteria specified on Form ES-301-1: (1) the tasks are distributed among the topics as specified on the form (2) at least one task is new or significantly modified (3) no more than one task is repeated from the last two NRC licensing examinations	C	N/A	<b>@</b>					
	c. Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on subsequent days.	2	N/A	<b>W</b>					
4. G	Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam sections.	C	N/A						
G E	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	C	- N/A	@					
N E	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	- 4-	N/A	8D					
R A	d. Check for duplication and overlap among exam sections.	L	11//	B					
L	e. Check the entire exam for balance of coverage.	U	N/A	(D)					
	f. Assess whether the exam fits the appropriate job level (RO or SRO).		N/A	<b>B</b>					
- Auth	Printed Name/Signature  Mork Chitty		Date						
a. Auu	. Author Mark Chitty / Man Chitty								
b. Facil	facility Reviewer (*)  N/A  / N/A								
c. NRC	Chief Examiner (#) Steven Rose / Sales		16/0	,6					
d. NRC	Supervisor James H. Moorman, III		6-06	, <u>0</u>					
Note:	# Independent NRC reviewer initial items in Column "c"; chief examiner concurrence	required.							

### 1. Pre-Examination

### 2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of <u>12-11/65</u>. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. Dong Watson	Senior Instructor- Bulgant	Songley O Notate	10/27/05	Dunka CHUtate	1/31/06
2. Michael J. Johnson	Control Room Supervisor 95	Milly / John	10/28/05	May July	- 4130 106_
3. Jan Nobil	Sinvesto Oknopor Supervison	ton fell (	_ <u>1= 31 6</u> 5		
4. Albort K. Koun, In	Operator Training Supopular	ARM	ulei/as	MKM	1/26/06
5. Warda P. MORRIS	Celera J	wanda P. Marrie	11-7-05	Wanda P. Morris	1-36-02
6. KARL O. SEASE	Les NUCLEAR ENOTRICTOR	Klos	ulrilos	her Sen	1131/06
7. JOHR BROKE	SIMULATOR LEAKLINEER	Chi Borela	15/14/05	- KARRON	W01/30/0/
8. Glenn A. MEntire		Muchala	4/14/0	JANA MAR	1/26/06
9. W.H. Turkett	Sa. Process Control Horle of	Waters	11/16/0	5 WA Theeles	1/30/06
10. W.R. Quick.	Supervisor, Initial training Pains	William Rawin	11/28/05	William & July	6/26/06
11 S.a. Silbertson	SUPER PSECE / SIPES	L. A. GILBERTSON	12/3/05	La Sillertson	n 1-26-06
12. GERALD T. LINOLER	ONLINE OPS Scheduling Sup.	J. Lindh	12/6/05	Durk	1-31-0-
13. Michael Simpson	Shift Supervisor	my	12/6/08	man	1/26/05
14. GEORGE LIPPARD	MGR. DIEXATIONS	THE Wand	12/7/05	Sest dell for 6A	"X 1 2 11 . 1
15. Gary Moffatt	Man Nuclear Training	Dan Coffett	12-8-05	12 Jan Mollrett	1-30-06
NOTES:		- 9 · W	*	Vintelein	

## 1. <u>Pre-Examination</u>

I acknowledge that I have acquired specialized knowledge about the NRC licensing examinations scheduled for the week(s) of 2/12/v5 as of the date of my signature. I agree that I will not knowingly divulge any information about these examinations to any persons who have not been authorized by the NRC chief examiner. I understand that I am not to instruct, evaluate, or provide performance feedback to those applicants scheduled to be administered these licensing examinations from this date until completion of examination administration, except as specifically noted below and authorized by the NRC (e.g., acting as a simulator booth operator or communicator is acceptable if the individual does not select the training content or provide direct or indirect feedback). Furthermore, I am aware of the physical security measures and requirements (as documented in the facility licensee's procedures) and understand that violation of the conditions of this agreement may result in cancellation of the examinations and/or an enforcement action against me or the facility licensee. I will immediately report to facility management or the NRC chief examiner any indications or suggestions that examination security may have been compromised.

### 2. Post-Examination

To the best of my knowledge, I did not divulge to any unauthorized persons any information concerning the NRC licensing examinations administered during the week(s) of 12/14/05. From the date that I entered into this security agreement until the completion of examination administration, I did not instruct, evaluate, or provide performance feedback to those applicants who were administered these licensing examinations, except as specifically noted below and authorized by the NRC.

PRINTED NAME	JOB TITLE / RESPONSIBILITY	SIGNATURE (1)	DATE	SIGNATURE (2)	DATE NOTE
1. Riley R. Johnson	NUC INST.	Religh Tohum	11/28/05	Riley R. J	There 1/30/00
2. LARRY R.WACONTO	« Nuc Trest.	Mulen	1/29/05	7 alidaen	1/20/08
3. Hit Crider	NUC Frist	Stutit Comes	12/12/08	bookinge	1/26/06
4. JEFF ALCHIE	5,000/1	Marche	12/12/0	- Hely Sand	2/22/00
5. LR CARTIN	Sr. Engr - DE	El Sant	12/15/0	I /Lak link	2/22/06
6. Robert RAY	Ops Supervisor	700	1/ 4/06	May	1/30/06
7. M Kranendone	SRO .	- 100 AG 1 - L	1-4-06	MILA	2.22.6
8. Hickory J. Johnson	- Op's Example (CRS)	Mally for	- 70 1/30/D	6	
9					٧.
10					
11					
12	200 0-0 000 000 000 000 000 000 000 000		·		
13					
14					
15	\$100 MIN SECTION SECTI				
NOTES:					

Facility:	V.C. Sum	mer	12/12/05							
Examination Level (circle	one):	(RO) <del>SRO</del>	Operating Test Number:	2005-301						
Administrative Topic (see Note)	Type Code*		Describe activity to be performed							
Conduct of Operations	(N)		RO Only – Perform RCS leak rate calculation with plant in Mode 4 per STP-114.002 (K/A G2.1.7; 3.7/4.4)							
Conduct of Operations	(N)		Calculate the Maximum allowable head venting time per EOP-18.2 Step 17 and Attachment 2. (K/A G2.1.25; 2.8/3.1)							
Equipment Control	(N)	RO Only – Construct a tagout for SFP HEX 'A' (Construct without the use of pre-written tagouts or computerized tagging system) (K/A G2.2.13; 2.8/3.1)								
Radiation Control	(N)	Perform a Shieldir	ng Calculation (K/A G2.3.2; 2.5/2.9)							
Emergency Plan		N/A								
	NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.									
* Type Codes & Criteria:	(N)ew o	from bank ( $\leq$ 3 for F or (M)odified from bacus 2 exams ( $\leq$ 1; rai								

Facility: V.6  Examination Level (circle	C. Summer	Date of Examination: 12/12/05  Operating Test Number: 2005-301
Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations	(N)	SRO Only – Determine Overtime Availability. (K/A G2.1.4; 3.4)
Conduct of Operations	(N)	Calculate the Maximum allowable head venting time per EOP-18.2 Step and Attachment 2. (K/A G2.1.25; 2.8/3.1)
Equipment Control	(D)	SRO Only – Review work package for SFP HEX 'A'; JPA-001 (K/A G2.2.13; 3.6/3.8)
Radiation Control	(N)	Perform a Shielding Calculation (K/A G2.3.2; 2.5/2.9)
Emergency Plan	(D)	SRO Only – Classification of an Emergency Event
NOTE: All itama (5 tatal)		d for CDOs. DO applicants require only 4 itams uplace they are retaking

NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.

\* Type Codes & Criteria:

(C)ontrol room

(D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes)

(N)ew or (M)odified from bank ( $\geq 1$ )

(P)revious 2 exams (≤ 1; randomly selected)

(S)imulator

	12/15/05_ 5-301
Type Code*	Safety Function
(N) (S) (A)	6
(D) (S) (A)	3
(M) (S) (A)	1
(N) (S)	2
(D) (S)	8
(D) (S) (A)	4S
(N) (S) (A) (L)	4P
(N) (S) (L)	. 7
(M) (E) (L)	4\$
(D) (E) (R)	8
(D)	6
	Type Code*  (N) (S) (A)  (D) (S) (A)  (M) (S) (A)  (N) (S)  (D) (S)  (D) (S) (A)  (N) (S) (A)  (N) (S) (A)  (N) (S) (L)  (M) (E) (L)  (D) (E) (R)

Facility: V.C. Summer  Exam Level (circle one): RO / SRO-1 (SRO-U)	Date of Examinat Operating Test N		
Control Room Systems <sup>®</sup> (8 for RO; 7 for SRO-I; 2	or 3 for SRO-U)		
System / JPM Title		Type Code*	Safety Function
a. Start and load Diesel Generator "A" from the conthe test start mode per SOP-306.16A. (The D/0 uncontrollably pickup load requiring an emerge (K/A 062A1.01; 3.4/3.8)	G will	(N) (S) (A)	6
b. JPSF-059, Alternate Isolation of Rutured S/G ('038EA1.32; 4.6/4.7)	C' MSIV) (K/A	(D) (S) (A)	3
c. JPSF-012, Dropped Rod Recovery. When Rod to ~ 30 step position, the rod stops moving (stu-ROD CNTRL BANK SEL switch is taken to mar 403.5, another rod within the same group drops manual trip. (K/A 003AA1.02; 3.6/3.4)	ck). When the nual per AOP-	(M) (S) (A)	1
d.			
e.			
f			
g.			
h.			
In-Plant Systems <sup>®</sup> (3 for RO; 3 for SRO-I; 3 or 2 fo	r SRO-U)		
i. JPP-055, Locally Start the Turbine Driven Emerg Feedwater Pump per FEP-4.0 Enclosure F and flow. (K/A 061A2.04; 3.4/3.8)		(M) (E) (L)	48
j. JPPF-166B, Establish Chilled Water Alternate C Charging Pumps. (K/A 026AA1.07; 2.9/3.0)	ooling to	(D) (E) (R)	8
k.			
@ All control room (and in-plant) systems mus functions; in-plant systems and functions m room.			,
* Type Codes Crit	teria for RO/SRO-	-I / SRO-U	

Facility:	VC SUMMER	Date of Examination: /2//2/os Operating	ري Test ۱ و	Vumbe	-301 r:		
		1. General Criteria		Initial	s		
			a	b*	c#		
a.		onforms with the previously approved outline; changes are consistent with tts (e.g., 10 CFR 55.45, operational importance, safety function distribution).	60	N/A	1		
b.	There is no day-to-da during this examinati	@	MA	Ø			
C.	The operating test sh	all not duplicate items from the applicants' audit test(s). (see Section D.1.a.)	0	MA	1		
d.	Overlap with the writt acceptable limits.	ten examination and between different parts of the operating test is within	<b>®</b>	N/A	a		
e.			$\mathscr{B}$	NA	Ø		
acceptable limits.  e. It appears that the operating test will differentiate between competent and less-than-competent applicants at the designated license level.  2. Walk-Through Criteria  a. Each JPM includes the following, as applicable:							
а.	<ul> <li>a. Each JPM includes the following, as applicable: <ul> <li>initial conditions</li> <li>initiating cues</li> <li>references and tools, including associated procedures</li> <li>reasonable and validated time limits (average time allowed for completion) and specific designation if deemed to be time-critical by the facility licensee</li> <li>operationally important specific performance criteria that include: <ul> <li>detailed expected actions with exact criteria and nomenclature</li> <li>system response and other examiner cues</li> <li>statements describing important observations to be made by the applicant</li> </ul> </li> </ul></li></ul>						
b.	outlines (Forms ES-3)	ges from the previously approved systems and administrative walk-through 01-1 and 2) have not caused the test to deviate from any of the acceptance tribution, bank use, repetition from the last 2 NRC examinations) specified form ES-201-2.	Ø	<b>%</b>	•		
		3. Simulator Criteria					
The ass	<b>®</b>	N/A	A				
a. Aut b. Fac c. NR	chor cility Reviewer(*) C Chief Examiner (#) C Supervisor	Printed Name / Signature	Date				

Facility	V.C. Surmer Date of Exam: Scenario Numbers: 1 / 2	/ 3 Operating Test N	lo.: 2	عون <sup>-</sup> -	301			
acinty	QUALITATIVE ATTRIBUTES			Initials				
			а	b*	c#			
1.	The initial conditions are realistic, in that some equipment and/or instrumentation of service, but it does not cue the operators into expected events.	on may be out		M/A	<b>D</b>			
2.	The scenarios consist mostly of related events.		0	N/A	@			
3. Each event description consists of  • the point in the scenario when it is to be initiated  • the malfunction(s) that are entered to initiate the event  • the symptoms/cues that will be visible to the crew  • the expected operator actions (by shift position)  • the event termination point (if applicable)								
4.	No more than one non-mechanistic failure (e.g., pipe break) is incorporated intwithout a credible preceding incident such as a seismic event.	to the scenario	0	N/A	@			
5.	The events are valid with regard to physics and thermodynamics.		0	~/A	Ser			
6.	Sequencing and timing of events is reasonable, and allows the examination te complete evaluation results commensurate with the scenario objectives.	am to obtain	0	N/A	CON			
7.	If time compression techniques are used, the scenario summary clearly so indicates.  Operators have sufficient time to carry out expected activities without undue time constraints.  Cues are given.							
8.	The simulator modeling is not altered.		0	MA	(8)			
9.	The scenarios have been validated. Pursuant to 10 CFR 55.46(d), any open performance deficiencies or deviations from the referenced plant have been to ensure that functional fidelity is maintained while running the planned scenario.	valuated	l	N/A	8			
10.	"It to the desire at least one pay or significantly modified scenario							
11.	All individual operator competencies can be evaluated, as verified using Form (submit the form along with the simulator scenarios).	n ES-301-6	0	11/1	0			
12.	Each applicant will be significantly involved in the minimum number of transic specified on Form ES-301-5 (submit the form with the simulator scenarios).	ents and events	C	M/A	0			
13.	The level of difficulty is appropriate to support licensing decisions for each cre	ew position.	10	MA	00			
	Target Quantitative Attributes (Per Scenario; See Section D.5.d)	Actual Attributes	<u> </u>	<u> </u>	<u> </u>			
1.	Total malfunctions (5–8)	6 16 16	0	NA				
2.	Malfunctions after EOP entry (1–2)	21211	0		(8)			
3.	Abnormal events (2–4)	51314	0	NA	0			
4.	Major transients (1–2)	/ ///	10	N/A	463			
5.	EOPs entered/requiring substantive actions (1–2)	21212	10	NA	/ 4			
6	EOP contingencies requiring substantive actions (0–2)	01010	10					
7.	Critical tasks (2–3)	3,2,3	1	NA	8			

Facility: VC Summer Date of Exam:12/12/05									Operating Test No.:2005-301			est )1					
A P P	E V		Scenarios														
	E V E N T		1			2			3			4		T O		M I	
LICANT	T		CREW OSITIO		CREV	V PO	SITION	CREV	V POS	ITION	CREV	V POS	ITION	T A		N I M	
N T	Y P E	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C.	B O P			Ü M(*)	) U
RO	RX NOR		5				1							1 2	1	1	0
SRO-I SRO-U	1/C		1,3				2,3,9							5	4	4	2
3n0-0	MAJ TS		8				7			union de la constantina della				0	0	2	1 2
RÔ	RX													0*	1	1	0
SRO-I	NOR I/C			5 26		4,5,								1 7	1	1	1 2
SRO-U	MAJ			2,6, 7,9 8		8								2	2	2	1
	TS			O										0	0	2	2
RO	RX	5			SAME AND SAME OF SAME									1	1	1	0
SRO-I	NOR I/C	5			1									2 12	1 4	1 4	1 2
SRO-U	1,0	1,2, 3,6, 7,9			2,3, 4,5, 8,9	All and								12			-
	MAJ	8			7				- 793			794 5 A S		2	2	2	1
	TS	1,2, 3,4			2,4, 5				11 -					7	0	2	2
RO	RX														1	1	0
SRO-I	NOR I/C														4	1	1 2
SRO-U	MAJ														2	2	1
	TS														0	2	2

# Instructions:

- 1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must do one scenario, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position.
- 2. Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (\*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
- 3. Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

Facility: \	VC Summ	ner					Date	of Ex	am:12/	12/05				Ope No.:	ratir 200	ig T 5-3(	est 01
A P	E V							Sc	enario	S	·						
APPLICART	E V E N T		1			2			3	711 16 16 16 16 16 16 16 16 16 16 16 16 1		4		T O T		M I	
CA	'   T	PC	CREW	N	CREV	V PO	SITION	CREV	V POS	ITION	CREV	W POS	ITION	T A L		N I M	
N T	Y P E	S R	A	ВО	S R	A T	B O P	S R	A T	ВО	S R	A T C	B O P	-		U M(*)	)
	E	Ö	Ċ	Р	Ö	Ċ	Р	0	Ċ	Р	0	С	Р		R		U
<u>ro</u>	RX		5											1	1	1	0
SRO-I	NOR I/C		3 1,3				2,3,9			a degra de				2 5	1	4	1 2
SRO-U	MAJ TS		8				7							2	2	2	1 2
	RX		141.75											U	Ŭ	_	2
<u>60</u>	NOR			5				-25						0* 1	1	1	0
SRO-I SRO-U	I/C			2,6, 7,9		4,5,								7	4	4	2
SHO-0	MAJ			8		8 7							1.000	2	2	2	1
	TS	10, 55 10, 53 10, 53	11.0							100				0	0	2	2
RO	RX	5				100								1	1	1	0
SRO-I	NOR I/C	5 1.2.												2 12	1	1 4	1 2
(SRO-U)		1,2, 3,6, 7,9											1,154				
	MAJ TS	8 1,2,												2 7	2	2	1
		3,4															
RO	RX NOR				1									0	1	1	0
SRO-I	1/C	111 2 11			23		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		100 m	edia.				6	4	4	2
0110-07	MAJ				4,5, 8,9	1,31 (		100					SE SE	4	-		_
	TS				7 2,4, 5	-, 10		200					- 80	3	0	2	2
	•				5						10000						

- Instructions:

  1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must do one scenario, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position.
- Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (\*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis. 2.
- Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns. 3.

Facility: \	VC Sumn	ner		*			Date	of Ex	am:12/	12/05				Ope No.:	ratir 200	ig T 5-30	est )1
A P	E V							Sc	enario	S							
P	E V E N T		1			2			3	•		4		T		M	
APPLICANT	'   T	P	CREW OSITIO	N	CRE	N PO	SITION	CREV	W POS	ITION	CREV	V POS	ITION	T A L	ŀ	N I M	
N T	Y P E	S R O	A T C	B O P	S R O	A T C	B O P	SRO	A T C	B O P	SRO	A T C	B O P		ı	Ŭ M(*)	) U
RO	RX		5						N. S. C.					1	1	1	0
SRO-I	NOR I/C		3 1,3				1 2,3,9							2 5	1 4	1 4	1 2
SRO-U	MAJ		8				7							2	2	2	1
	TS													0	0	2	2
RO	RX	5						er e tante	200					1	1	1	0
SRO-I	NOR	5		120,000	1			Territoria de la composición dela composición de la composición de la composición dela composición dela composición dela composición dela composición de la composición de la composición dela composición						2	1	12	1
SRO-U	I/C	1,2, 3,6, 7,9			2,3, 4,5, 8,9									12	4	4	2
	MAJ	8			7									2	2	2	1
	TS	1,2, 3,4			2,4, 5									7	0	2	2
RO	RX	9.5	70.00												1	1	0
SRO-I	NOR I/C											September 1			1	1	1
SRO-U																4	2
	MAJ TS							alia Na			a territoria				2	2	1 2
RO	RX NOR			11776 S.M. 2176 S.M.	100.00										1	1	0
SRO-I	I/C						110								4	4	2
SRO-U	MAJ														2	2	1
	TS								1.68 M 1.18 M						0	2	2

## Instructions:

- 1. Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must do one scenario, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position.
- 2. Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (\*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
- 3. Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

Facility: VC Summer	Da	te of E	xaı	mir	nation	: 12/12	2/0	5		Operat	ing	ј Те	st No.:	2005-	30	1
							ΑF	PPL	ICAN	ΓS						
	∥	O (1)( RO-I RO-U	3)(	5)		RO (2)( SRO-I SRO-U				RO SRO-I RO-U	(2)	(3)	🗆 S	RO SRO-I SRO-U	(4)	
Competencies	SC	ENAF	RIO		S	CENA	RIC	)	S	CENA	RIC		SC	ENAF	10	·
	1	2	3	4	1	2	3	4	1	2	3	4	1	2	3	4
Interpret/Diagnose Events and Conditions	1,3, 7,8	2,3, 6,7, 9			2,6, 7,8, 9	4,5, 6,7, 8,10			1,2, 3,4, 6,7, 8	2,3, 4,5, 6,7, 8,9, 10			2,6, 7,8, 9	2,3, 4,5, 6,7, 8,9, 10		
Comply With and Use Procedures (1)	1,3, 5,7, 8	1,2, 5,6, 7,9			2,5, 6,7, 8	4,5, 6,7, 8			1,2, 3,6, 7,8 5	1,2, 4,5, 6,7, 8,9			2,5, 6,7, 8	1,2, 4,5, 6,7, 8,9		
Operate Control Boards (2)	1,3, 4,5, 7,8	1,2, 3,5, 6,7, 9			2,5, 6,7, 8,9	4,5, 6,7, 8							2,5, 6,7, 7,8, 9			
Communicate and Interact	1,3, 4,5, 7,8	1,2, 3,6, 7,9			2,5, 6,7, 8,9	4,5, 6,7, 8,10			1,2, 3,4, 6,7, 8,9	1,2, 3,4, 5,6, 7,8, 9,10			2,5, 6,7, 8,9	1,2, 3,4, 5,6, 7,8, 9,10		
Demonstrate Supervisory Ability (3)									1,2, 3,5, 6,7, 8,9	1,2, 3,4, 5,6, 7,8, 9,10				1,2, 3,4, 5,6, 7,8, 9,10		
Comply With and Use Tech. Specs. (3)									1,2, 3,4	2,4, 5				2,4, 5		

### Notes:

Includes Technical Specification compliance for an RO. Optional for an SRO-U.

(1) (2) (3) Only applicable to SROs.

# Instructions:

Check the applicants' license type and enter one or more event numbers that will allow the examiners to evaluate every applicable competency for every applicant.

Facility: VC Summer	Da	te of E	xam	nina <sup>.</sup>	tion:	12/1	2/0	5	(	Operat	ting	j Te	est No.:	2005	-30	1
							ΑF	PPL	ICAN	ΓS						
	□ S	RO BRO-I BRO-U	(1)		_ S	RO SRO-I SRO-U	J	1		RO SRO-I SRO-U				RO BRO-I BRO-U	1	
Competencies	SC	ENAF	RIO		SC	CENA	RIC		S	CENA	RIC	)	SC	CENAF	310	
	1	2	3 4	4	1	2	3	4	1	2	3	4	1	2	3	4
Interpret/Diagnose Events and Conditions	1,2, 3,4, 6,7, 8	4,5, 6,7, 8,10														
Comply With and Use Procedures (1)	1,2 <sup>5</sup> , 3,6, 7,8	4,5, 6,7, 8														
Operate Control Boards (2)	3/	4,5, 6,7, 8														
Communicate and Interact	1,2, <sup>5</sup> 3,4, 6,7, 8,9	4,5, 6,7, 8,10														
Demonstrate Supervisory Ability (3)	1,2, 3,5, 6,7, 8,9															
Comply With and Use Tech. Specs. (3)	1,2, 3,4															
Notes: (1) Includes Technical Spe (2) Optional for an SRO-U. (3) Only applicable to SRO		n comp	lianc	e for	an F	RO.										

# Instructions:

Check the applicants' license type and enter one or more event numbers that will allow the examiners to evaluate every applicable competency for every applicant.

Facility:	VC SUMMER	Date of Exam:	01/1	0/06	Exam	Level:	RO 🗹 S	RO 🗌
							Initial	
	Item Description					а	b*	c#
1.	Questions and answers are technically accurate and	applicable to	he facili	ty.		C	NA	<b>@</b>
2.	<ul><li>a. NRC K/As are referenced for all questions.</li><li>b. Facility learning objectives are referenced</li></ul>					e	rs/A	<b>®</b>
. 3.	SRO questions are appropriate in accordance with S	ection D.2.d o	f ES-401			MA	NIA	N/A
4.	The sampling process was random and systematic (I were repeated from the last 2 NRC licensing exams,							<b>D</b>
5.	Question duplication from the license screening/audit as indicated below (check the item that applies) and the audit exam was systematically and randomly of the audit exam was completed before the license the examinations were developed independently; the licensee certifies that there is no duplication; of other (explain)	appears appro developed; or exam was sta or	priate:			C	ri/a	<i>@</i>
6.	Bank use meets limits (no more than 75 percent from the bank, at least 10 percent new, and the rest new or modified); enter the actual RO / SRO-only question distribution(s) at right.	Bank 29/39%		dified	New 24132%	C	n/a	æ
7.	Between 50 and 60 percent of the questions on the Fexam are written at the comprehension/ analysis level the SRO exam may exceed 60 percent if the random selected K/As support the higher cognitive levels; enthe actual RO / SRO question distribution(s) at right.	l; 			C/A	C	~/4	<b>©</b>
8.	References/handouts provided do not give away ansor aid in the elimination of distractors.	wers	-			C	NA	<b>®</b>
9.	Question content conforms with specific K/A stateme examination outline and is appropriate for the tier to v deviations are justified.					e	MA	<b>@</b>
10.	Question psychometric quality and format meet the g	uidelines in E	S Appen	dix B.		C	MA	0
11.	The exam contains the required number of one-point the total is correct and agrees with the value on the co		ce items	,		l	MA	8
c. NRC (	in any A d	Nose / Moormak/	Jeson Dedevelo	/, CA			Da 0 <u>i/0</u> 110	ite 6/06 6/06

+ PROGRAM OFFICE CONTACTED ON 1/5/06 AND 1/6/06.

-	4	^	4
-	_/	n	1
ᆫ		v	- 1

# Written Examination Quality Checklist

Form ES-401-6

Facility:	VC SUMMEN Date	of Exam:	01/1	10/0	S Exam	Level:	RO 🗌 S	RO 👍
							Initial	
	Item Description					а	b*	c#
1.	Questions and answers are technically accurate and app	licable to t	he facili	ty.		C	MA	80
2.	<ul><li>a. NRC K/As are referenced for all questions.</li><li>b. Facility learning objectives are referenced as a</li></ul>	vailable.				C	N/A	œ.
3.	SRO questions are appropriate in accordance with Section	on <u>D.2.d of</u>	ES-401	1		e	N/A	@
4.	The sampling process was random and systematic (If mowere repeated from the last 2 NRC licensing exams, cons	ore than 4 F	RO or 2	SRO qu				6
5.	Question duplication from the license screening/audit exa as indicated below (check the item that applies) and appreture audit exam was systematically and randomly deverthe audit exam was completed before the license examinations were developed independently; or the licensee certifies that there is no duplication; or other (explain)	am was cor ears appropeloped; or	ntrolled priate:			C	NA	Ø.
6.	Bank use meets limits (no more than 75 percent from the bank, at least 10 percent new, and the rest new or modified); enter the actual RO / SRO-only question distribution(s) at right.	Bank 4 1/6/,	ļ	dified	New 16 164%	C	n/A	<b>@</b>
7.	Between 50 and 60 percent of the questions on the RO exam are written at the comprehension/ analysis level; the SRO exam may exceed 60 percent if the randomly selected K/As support the higher cognitive levels; enter the actual RO / SRO question distribution(s) at right.	Mem			C/A	C	NA	8
8.	References/handouts provided do not give away answers or aid in the elimination of distractors.	} 				C	MA	Ø.
9.	Question content conforms with specific K/A statements i examination outline and is appropriate for the tier to which deviations are justified.					C	NIA	₽
10.	Question psychometric quality and format meet the guide	lines in ES	Appen	dix B.		C	NA	<i>Q</i> .
11.	The exam contains the required number of one-point, mu the total is correct and agrees with the value on the cover		e items:	;		C	NA	Ø
c. NRC C	y Reviewer (*) Chief Examiner (#)  **TEVEN D. Re.**	N/A se/ rman, co	Muh Sea	1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	horse aminations.		Da 6//0. //6	. / .

CRAFT RO EXAM

S-4	01, R	lev. 9						W	ritten	Exa	minat	ion l	Revi	ew W	orksheet Form ES-401-
Q#	1. LOK	2. LOD	3	3. Psycl	hometr	ic Flaws	S	4.	Job Cont	tent Fl	aws	5. C	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward		SRO Only	U/E/S	Explanation
				 [F	Refer to	o Sectio	n D of E	ES-401	and App	endix		nstruct idition:		mation	regarding each of the following concepts.]
1.	Ë	nter the	level of	knowle	edge (l	₋OK) of	each qu	uestion	as eithe	r (F)uı	ndamen	tal or (	H)ighe	r cognit	tive level.
2.	Е	nter the	level of	difficul	Ity (LO	D) of ea	ch ques	stion us	sing a 1 -	- 5 (ea	asy – dif	ficult) r	ating s	scale (q	uestions in the 2 – 4 range are acceptable).
3.	С	heck th	e appro	priate b	ox if a	psycho	metric f	law is i	identified:	:					
	•		The ste The an The dis One or	em or d swer cl stractor more d	listract hoices s are r distract	ors cont are a co not credi tors is (a	tain cue ollectior ible; sin are) par	s (i.e., n of uni gle imp tially co	clues, sp related tro plausible orrect (e.	ecific ue/fals distra	determi se stater ctors sh	ners, p nents. ould be	ohrasin e repai	ig, leng red, mo	information is needed, or too much needless information). th, etc).  ore than one is unacceptable. ated assumptions that are not contradicted by stem).
4.	C	heck th	The qu The qu The qu	estion estion estion	is not I require contair	inked to s the re as data	the job call of k with an	requir (nowle unreal	dge that i	s too of ac	specific curacy o	for the	close nsister	d refere it units	out, as written, is not operational in content). ence test mode (i.e., it is not required to be known from memory). (e.g., panel meter in percent with question in gallons).
5.	<u>C</u> ur	heck qu naccept	estions able).	that ar	e samp	oled for	conform	nance	with the a	pprov	ed K/A	and th	ose tha	at are d	lesignated SRO-only (K/A and license level mismatches are
6.	В	ased or	the rev	iewer's	judgm	ent, is t	he ques	stion as	s written	(U)nsa	atisfacto	ry (req	uiring	repair o	or replacement), in need of (E)ditorial enhancement, or (S)atisfactory?
7.	At	t a mini	num, ex	oplain a	ıny "U"	ratings	(e.g., h	ow the	Appendi	x B ps	ychome	tric at	ributes	are no	ot being met).
1	F	1										Х		U	001A2.03: Question does not test the K/A. The question does not have malfunction that has to be mitigated. LOD too low for this K/A in that there is no malfunction and the operator just needs to know that this condition is expected and no action is required.
ľ	H	2												S	Question replaced. The new question is satisfactory. The question tes at the C/A level with a LOD=2.

Q#	1.	2.		3. Psyc	chometr	ric Flaws	3	4.	Job Cont	tent Fl	aws	5. C	ther	6.	7.
Z#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A		U/E/S	Explanation
2	Н	2	×			х						х		U	002A4.08: Distractors A and B are not credible in that with a break of the high pressure tap (i.e. an SBLOCA) that continued plant operation would not be affected. The stem does not need to state that all RCPs are running at 90% power, that is a given for this power level. Suggest changing the stem to have the high pressure tap become clogged or modify the question to have a low pressure tap become clogged and ask what the indications would be. The question does not test the K/A in that the question asks what will happen with the plant vs the ability to operate and/or monitor the safety parameter display.
	Н	3											2	s	Question replaced. The new question is satisfactory. The question test at the C/A level with a LOD=3.
3	Η	3	x			X						^		E S	003A4.01: Distractors A and B are essentially the same since a decrease in #1 seal D/P can only be caused by low RCS pressure or #1 seal failure. The stem should only state what is available to the operators, to state that the standpipe is verified high, how is this done? In the stem change "seal return flow" to "seal leakoff flow"," at VC Summer seal return flow is called seal leak off flow. In the stem state which annunciators have alarmed, this adds operational validity.  Question has been corrected. SAT
4	F	4				Х								E S	003AK1.17: This question is testing the GFE knowledge of Rx Physics but is dead on the K/A. Suggest changing distractor B to be the opposite of answer A.  Question has been corrected. SAT
5	:	2										X			004G2.4.49: The conditions established in this question do not REQUIRE immediate operator action which is required to be tested by the K/A. The question test what the system will do without operator action vice the required operator action.
11234	,														Question has been replaced. New question is satisfactory. The new question tests at the memory level with a LOD=2. SAT
6	Н	3	X												005AA2.03: Stem needs to be changed to state that the rods did not move when bank D vs "any Rod Bank". The AOP for stuck rods does not allow going to any other banks other than the one the stuck rod is in.  Question has been corrected. SAT

(	1. . ∟OK	2. LOD	3	B. Psyc	hometr	ic Flaw	s	4.	Job Con	tent Fl	aws		ər	6.	7.
٠	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia		Back- ward		SRO Only	U/E/S	Explanation
7	F	2												s	005K6.03: No reference material provided for verification of the correct answer.
8	Н	3	X				X							E S	006K4.11: The wording in the stem, "Which ONE of the following is correct?" needs to be changed. Having the wording this way makes distractor B also correct, since the distractor B statement is true. "Whone of the following explains why the SI signal could not be reset?" Question has been corrected. SAT
9	Н	3					X							<u>=</u>	007A2.05: Distractor A is partially correct in that, the alarm is expect for the PRT conditions.  Question has been corrected. SAT
10	F	2					X			111000000000000000000000000000000000000				Ē	007EK1.05: Change distractors so all cover the same amount of time Supporting information found states that SR should not energize until least 15 minutes after a trip, therefore, change answer C to 15-17 minutes, and distractor D to 20-22 minutes.  Question has been corrected. SAT
11	Н	2									The second secon		į	J	007K1.01: There are two correct answers. Both B and C can be considered correct based on the facility reference material. The reference material states that the PRT rupture disc is set to release a 86-100 psig with a nominal release of 91 psig. This information make two of the answer choices arguably correct with B being the best answice C as marked.
														S	Question has been corrected. The stem has been modified to state to maximum pressure that could be reached in the PRT.
12	H	3	X											E .	008A3.06: Suggest modifying the question to get a better K/A match. the stem the CCW dicharge pressure to 40 psig and the amps are increasing (pump impeller binding). This will make distractor A correct and ensure that the question tests the automatic actions as required the K/A.  Question has been corrected. SAT
13	Н	2										<	Į	j	008AG2.4.49: Question does not test the K/A. The question does no test any aspects of operation of system components or controls.
	н	2												<b>S</b>	008AG2.4.4: K/A was changed. New question was developed for thi K/A. The new question is Satisfactory. The question tests at the C/J level with a LOD=2.

Q#	1. LOK	2. LOD	3	. Psycl	nomet	ric Flaw	s	4.	Job Cont	ent Fl	aws	5. C	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
14		2	X			×								U S	010G2.4.4: Distractors C and D are not credible. The detailed instrument readings provided in the stem (i.e. all pressure instruments reading and trending the same) makes C and D distractors implausible. Suggest changing the stem to state that one of the PZR pressure instruments is indicating a failed high channel. Adding this information to the stem adds credibility to distractors C and D and makes the question a C/A vs Mem.  Question has been replaced. The new question is Satisfactory. The question tests at the C/A level with a LOD=2.
15	F	2	x	The state of the s										E S	011EK2.02: Stem provides teaching. Reword the stem to read that EOP-1.0 is in progress. "WOOF is the reason for RCP trip criteria under the above conditions?" With a Large Break LOCA, the RCS will depressurize to less than 1400 psig which is RCP trip criteria for the distractor D reason. Change the stem to state that a MS line break has occurred.  Question has been corrected. SAT
		2										X		U S	012A4.03: Question does not match the K/A. The question does not address any aspects associated with RPS channels being blocked or bypassed.  Question has been replaced. New question from a previous NRC exam
															(year 2000). The new question is Satisfactory. The question tests at the memory level with a LOD=2.
17	F .	2				X								E S	012K2.01: Distractor D is not credible in that the loss of one power supply would result in the loss of P-6. Suggest changing distractor D to read "A low power rod block, C-1, signal with no change in reactor power." Could not find supporting reference material to verify the answer as correct.  Question has been corrected. SAT
18	F	1										X		U	013K1.06: Question does not test the K/A. The question tests the operation characteristics of an MOV. The question LOD is too low to be included on a license operator exam, this is more of an NLO fundamentals question.
	F	2												S	Question has been replaced. The new question is satisfactory. The question tests at the memory level with a LOD=2.

	1.	2.	3	B. Psyc	home	tric Flav	vs	4.	Job Cont	tent Fl	aws	5. 0	Other	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus		T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only		Explanation
19	H	2	X				X							E S	015AK1.02: Conflicting information in the stem. The stem states that power is at 35% which makes distractor B correct. The stem also states that P-8 is not lit, indicating that power is above 38%, which makes A the correct answer. The applicant is forced to make a decision that one of these two pieces of information is incorrect. Nothing else in the stem indicates that which piece of information is correct, therefore, either can be argued as correct.  Question has been corrected. SAT
20	F	2				X								E S	017K1.01: Distractor C is not credible. Remove the word "second" from distractor C. I believe this question is at the memory level, not C/A as labeled.  Question has been corrected. SAT
21	F	2												s	022A1.04
22	H	3				х								E S	022AA1.08: Distractor C is not plausible. Suggest changing to read "VCT rate of level decrease would remain unchanged from preevent." Question has been corrected. SAT
23	F	2	х											E S	022K3.02: Add to the stem to solicit the reason why the parameter changes.  Question has been corrected. SAT
24	F	2	x											E	024AG2.4.6: Stem lacks credibility, in that, why are the PORV block valves shut? How would they have been shut under these conditions? Need to provide reference material that supports the correct answer.
	н	2												s	Question has been modified. The question now tests at the C/A level with a LOD=2. The question is Satisfactory.
25	F	2				X								E S	025AG2.1.32: Distractor D is not credible. The loss of CCW flow to the HX would never affect the SI flow path. Suggest replacing this distractor with something about heat added to the system from the RHR pump could cause boiling on the CCW side of the RHR HX. Question has been corrected. SAT

.

Q#	1. LOK	2. LOD	3	3. Psyc	homet	tric Flaw	/S	4.	Job Con	tent Fl	aws	5. C	ther	6.	7.
Q#	(F/H)		Stem Focus		T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward		SRO Only	U/E/S	Explanation
26	H	3	X		,		X							U S	026AA1.01: The question stem is confusing. Has the RCP A CCW TEMP HI annunciator been in for 5 days without the plant fixing the problem? Not sure it can be said that the CCW HX outlet temperature will decrease due to lower flow. The lower flow through the cooled components would cause the CCW HX inlet temp to be higher. Suggesthis question be replaced.  Question replaced. Question now tests at the memory level with a LOD=3. SAT
27	Н	3	х		···									E S	026K2.02: Stem needs to state "Under the above conditions when the RWST LO-LO level annunciator is received which one of the following correctly describes the affect on valves MVG-3004?" Question has been corrected. SAT
28	F H	2		7 7 10 7 10 10 10 10 10 10 10 10 10 10 10 10 10								X		U S	026K3.02: Question does not match the K/A. Question asks about los of the RWST suction source to the SI pumps. K/A requires testing for the loss of the Containment Spray System affect on the recirculation SPRAY system.  026K3.01: K/A was changed. Question was developed for this K/A. T Question is Satisfactory. The Question tests at the C/A level with a LOD=2.
29	Н	3	Х											E S	027AK1.02: Add to the stem "associated with the above events?"  Question has been corrected. SAT
30	Н	3					X		,					E S	064K6.08: Distractor D can be considered partially correct. The EDG will run for an additional 30 at full load (per the reference material), however, 60 minutes of run time may be possible if the EDG is not fully loaded. A better distractor would be to have the crew immediately secure the EDG or perform actions to reduce the EDG load to increase the run time.  Question has been corrected. SAT
31	F	3				Х	-							E S	034A1.02: No reference provided for verification of correct answer or plausibility of distractors. T.S. basis has a different reason for minimur level in the refueling canal.  Question has been corrected. SAT

Q#	1. LOK	2. LOD	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fl	aws	5. C	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
32	H	3										X		U	035K6.02: The question does not test the K/A. The K/A is the effect of a loss or malfunction OF A PORV on the Steam Generating System. This question has no malfunction of a PORV but rather an instrument that fails and has no effect on the PORV. NO correct answer is annotated.
	Н	2											-	S	Conditions in the stem have been changed to establish a K/A match. The LOD of the question has decreased to a LOD=2. Question is now SAT.
33	H	2				X								E S	038EK3.08: Distractor A is not credible. RCPs are never secured due to subcooling decreasing below 50F. Subcooling has not even decreased below 50F, the lowest it will go is 52F even when the target temperature is reached. Suggest changing the reason for distractors A and B. Question has been corrected. SAT
34	H	2	X		· marketina and · ·		X						X	U	039A1.10: Procedure transition knowledge may be argued as SRO only. I think the crew will enter AOP-112.2 first without going to AOP-101.1. However, this transition aspect of the question is not needed to match the K/A. There are some partially correct answers depending on the time frame. Eventually the plant will be shut down per the AOP and activity level will decrease. With continued operation eventually activity equilibrium will be reached and activity level will stabilize. These assumptions that need to be made, make other distractors partially correct.
	Н	2												S	Question has been replaced. The new question is satisfactory. The question tests at the C/A level with a LOD=2.
35	F	1												Ú	040AK2.02: Level of difficulty is too low to provide any discriminatory value.
	Н	2				•								S	Question replaced. The new question tests at the C/A level with a LOD=2. SAT
36	H	3	X											E S	045K5.17: This is primarily GFE knowledge. Stem modification necessary to ensure that power change is significant enough to cause the desired effect.  Question has been corrected. SAT
37	Н	3					х							E S	051AA1.04: Reference material contradicts the answer. Rewording of the distractors may be helpful.  Question has been corrected. SAT

Q#	1. LOK	2. LOD	3	. Psyc	home	tric Flaw	/S	4.	Job Cont	tent Fl	aws	5. O	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward		SRO Only	U/E/S	Explanation
38	Н	2				х								E S	054AK3.01: Suggest rewording one of the distractor to have the trip breakers open so that the answer is not the only one that has this.  Question has been corrected. SAT
39	H	2	x											U S	055EA2.05: Stem is not credible. The facility would not take a battery OOS for maintenance at 100% power, this is a 2 hour T.S. Material reference is a total loss of all AC power, however the B EDG is not addressed therefore, you have to assume it started. Are the DC trains cross connectable? I do not think that the loss of one of the batteries makes the other battery discharge twice as fast.  Question has been replaced. New question is satisfactory. The new
40	Н	3					Х							E	question tests at the memory level with a LOD=2. SAT  056G2.1.28: Wording of distractor C should be changed to state "starts only A." Currently it is a subset of distractor D. This is not a memory level question as stated, since it requires multiple pieces of information to answer.  Question has been corrected. SAT
41	H	3					х							E S	057AG2.4.4: Currently this question provides information that aids in the answering of Question #39, K/A 055EA2.05. Suggest removing the voltage values from the distractors B and C. Question has been corrected. SAT
42	Н	3 2					х								058AA2.01: There are two correct answers. Both A and B are correct for the conditions in the stem.  Question has been corrected. Question now test at a LOD=2. SAT
43	F	2													059G2.1.23: Question is marked as C/A but question test at the memory level.
44	Н	3	·			Х									061K5.03: Suggest changing distractors C and D to add more credibility. Mark this question as C/A, currently it is not marked. Question has been corrected. SAT
45	Н	3										,		s	062A2.06: Misspelling in distractor B.

O#	1.	2.	3	B. Psyc	homet	ric Flaw	/S	4.	Job Con	tent FI	aws	5. C	Other	6.	7. •
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia		Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
46	F	3				x								E	062A3.04: Distractor A does not seem plausible, change distractor a read "It should light immediately and indicates charged capacitors." Could not definitively identify from the reference material provided the structure of the correct answer. Need the facility to determine.
														S*	Question has been corrected. Still need the facility to verify answer.
47	F	2												s	062AA1.07: If need this question can be modified by changing the answer to be a low CST level within 60 second of an ESFAS actuat
48	F	2	х			х								E S	063K4.01: Distractor A is not credible since the physical connection does not exist. Suggest changing "1DA2X" to "1DB2Y." Add to the assume no operator action.  Question has been corrected. SAT
49	H	1												U	064K6.07: The LOD of this question is too low and therefore, provid no discriminating value. This is due mostly to the wording of the co answer. The answer needs to be reworded to be not so obvious. It would also help to change at least one of the distractors to include another air related choice.
	Н	2												s	Question has been corrected. LOD=2. SAT
50	Н	2										x		U	065AK3.04: The question does not match the K/A. The K/A tests the reason the question only tests what happens.
	F	2												S	Question has been corrected. The question stem was changed to include the reason. Question now tests at the memory level with a LOD= 2. SAT
51	F	2												s	071K3.05: Distractors should be reworded to be more consistent wi each other.
52	Н	3				х								E S	072K4.03: Some work needed to increase plausibility of the distract and to make the distractors more uniform and balanced. Question has been corrected. SAT

Q#	1. LOK	2. LOD	3	3. Psyc	homet	ric Flav	/S	4.	Job Con	tent Fl	aws	5. C	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only		Explanation
53	F	3	Х			х								E S	073K5.03: Need correct annunciator nomenclature in the stem. Change to the stem to read "primary reason." Distractor C is not credible. Change distractor C to read: "Surveys are used to determine the extent of the failed fuel." This is actually done through RCS sampling. The question is currently marked as C/A but tests at the memory level. This question can be considered modified vs bank. Question has been corrected. SAT
54	H F	3										Х		U S	075K2.03: Question does not match the K/A. The question test Component Cooling Water power supplies, the K/A requires testing Circ Water System Service Water Pump power supplies.  Question has been replaced with a satisfactory question that meets the K/A. This question now test at the memory level with a LOD=3. SAT.
55	H	3	X											U	076A1.02: Question stem does not follow the procedures and plant functions. There is no procedure guidance that directs having to establish flow through the idle RBCU in the A train only training guidance. At step 4 of EOP-17.0, as long as there is flow in at least one train, which the stem states there is, no additional action is needed by the crew in this area.
														s	Question has been corrected. SAT
56	Н	3	x									X		U	076A3.02: Question does not really meet the K/A in that the K/A require testing the ability to monitor automatic actions and there are no automatic actions that occur. Currently the stem provides too definate a cue to the correct answer in stating that A train SW is inoperable. The information is not pertinent therefore, remove it and state that the train has been returned to service following maintenance.  Question has been corrected. SAT
57	Н	2	х									Х		E	078K4.01: The question does not test the K/A in that the questions test the automatic function but not the interlock that which provides for the manual/automatic transfer of control. This question can be easily corrected by modifying the stem to state that the operator has taken the 'A' IA Comp switch to NORMAL-AFTER-STOP when the breaker trips. This will defeat the auto start function and the compressors must be manually started. The stem should have the switch positions in all cap Question has been corrected. SAT

Q#	1. LOK	2. LOD	3	. Psyc	homet	ric Flaw	/S	4.	Job Cont	ent Fl	aws	5. C	ther	6.	7. ·
Q# 	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link		#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
58	F	2				x								E S	103K3.02: The answer is not credible in that with the plant in Mode 4 the facility would not allow removing the equipment hatch to inspect the Oring. Removing the equipment hatch alone is a loss of containment integrity.  Question has been corrected. SAT
59	F	3	X											E S	G2.1.1: The stem should state that the plant has stabilized at 200F. The question is marked as a C? But tests at the Memory level.  Question has been corrected. SAT
60	F	1	x			x			·					U	G2.1.17: The question difficulty level is too low. Stem focus is needed to ensure that the communications required are IAW facility procedures. The distractors are not credible, A is the only distractor that lists the S/G pressures and trends.
	F	2												S	G2.1.3: K/A was changed. New question was developed for this K/A. The new question is Satisfactory. The question tests at the memory level with a LOD=2.
61	F	2	X				X							U	G2.1.29: The stem should state that this is being performed as part of a "Routine system lineup verification." Currently there are two correct answers, distractor B is correct in that this is an acceptable way per SAP-153.
	Н	2												S	Question has been corrected. The question now tests at the C/A level with a LOD=2. SAT
62	F	3	X				X		·						G2.2.11: Stem should be modified to state IAW SAP-139. Distractor B is partially correct since the 30 day approval is within 90 days. Add "to occur anytime" to each of the distractors. This question can be easily modified to create better distractors.  Question has been corrected. SAT
63	Н	3					X								G2.2.25: Distractors need to be changed to be more consistent with the wording in the TS bases and avoid being partially correct. Question is currently marked as a Memory level question but tests at the C/A level. Question has been corrected. SAT
64	F	2												S	G2.2.28
65	Н	3	×	-										E S	G2.3.1: Add to the stem "approval/notification" vice "approval."  Question has been corrected. SAT

Q#	1. LOK	2. LOD	3	. Psyc	homet	ric Flaw	/S	4.	Job Con	tent Fl	aws	5. C	Other	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
66	Н	4												s	G2.3.10
67	Н	2					X							E S	G2.4.15: Distractor C is partially correct in that the reference material does not state to not to cool down at the max rate if communications are not available. The reference material states that a slower rate is acceptable based on available communications therefore, since the stem does not provide amplifying information, C can be considered as correct. Question has been corrected. SAT
68	F	2			11								х	U	G2.4.32: This question requires a knowledge level beyond that of the RO with the determination that EAL thresholds have been exceeded.
	Н	2												s	G2.4.2: K/A was changed. The new question is Satisfactory. The question tests at the C/A level with a LOD=2.
69	Н		×				X							U	W/E04EA2.1: The stem does not represent a logical sequence of the progression through EOP-1.0. Why would the crew be positioning valves in Attachment 3 when the transition is made to EOP-15. EOP-15 can not be entered until EOP-1.0 is completed. If this is a LOCA outside containment the crew would most likely have transitioned to EOP-2.5 at step 23 of EOP-1.0 (I would think the crew would have transitioned to EOP-2.5 at this step answer D). Why are only one Charging pump and one RHR pump running? Was there a problem with the SI actuation? K/A statement wording is incorrect.
	Н	2												S	Question replaced. The new question is satisfactory. The question test at the C/A level with a LOD=2.
70	F	3	X											E S	W/E07EK3.2: Redundant information in the stem, remove "assuming the crew made the correct decision" from the stem. In answer B, change "verifying" to "verifying/establishing." K/A statement wording is incorrect.  Question has been corrected. SAT
71	Ļ	2				X								U S	W/E09EG2.4.49: Distractors C and D are not plausible. Distractor C is not a reference page action for EOP-1.3 or any other EOP, therefore it is not plausible. The is no information in the stem that would indicate distractor D as a reasonable choice, therefore distractor D is not plausible.  Question has been corrected. SAT
72	Н	2												s	W/E10EK2.2: K/A statement wording is incorrect.

Q#	1.	2. LOD	3	. Psyc	homet	ric Flaw	/S	4.	Job Con	tent Fl	aws	5. C	ther	6.	7.
Q#	LOK . (F/H)	(1-5)	Stem Focus		T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward		SRO Only		Explanation
73	H	3				Х								E S	W/E12EK2.1: Distractors A, B and C lack some credibility in verifying adequate core flow and wide range S/G level. Modify these distractors to include SI termination criteria from EOP-1.  Question has been corrected. SAT
74	Н	4												s	W/E13EK2.2
75	Н	3	X					-						E S	W/E15EK3.3: Not enough information in the stem to definitively state that there is a leak vs a pump trip. Need to provide a time line for increase sump level rise or provide RBCU flow readings.  Corrections have been made to the stem. The information added to the stem allows the applicant to figure out that the RB sump should not be increasing. Question is SAT.
														-	

<u></u>	1.	2.	3	. Psycl	homet	ric Flaw	rs	4.	Job Cont	ent Fl	aws	5. C	ther	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link			Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
1	Н	2	х				Х							E S	002A2.04: Change the stem to state that RWST level has decreased below 18% to ensure the transition is required. Currently with the RCS @ 18%, at this moment in time, a procedure transition is not required so distractor A could be argued as correct.  Question has been corrected. SAT
2	Н	2	X									х		E	003A2.03: In the stem add IAW AOP-117.1. Stronger tie to the K/A (use procedures to correct/control/mitigate) if add "Initiate a reactor plant shut down per GOP-4."
	Н	3												S	Question replaced. New question is Satisfactory. The question tests at the C/A level with a LOD=3.
3	H	3	X	,			X							U	005G2.1.27: Distractor B is correct, per reference material page 22. In order for C to be the correct answer the time needs to be changed to 0400 hrs the next day (RHRS designed to cool the RCS to less than 140F 24hrs after the RCS is at 350F, not from post trip). In the stem the crew would not perform a controlled S/D with a LOCA, should also state that the RHRS is in service.
	F	2												s	Question replaced. New question is Satisfactory. The question tests at the memory level with a LOD=2.
4	Н	2												S	007A2.03: Minor wording changes to the distractors to include procedure and titles.
5	Н	2	X			X								E S	007EA2.01: Currently question marks B as correct, I believe that D is correct. The stem needs to provide information as to which procedure is in effect in order to make distractors A and C credible. Re-word distractor C to be consistent with distractor A.  Question has been corrected. SAT.

Q#	1.	2.	3	. Psyc	home	tric Flaw	/S	4.	Job Con	tent Fl	aws	5. C	ther	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus		T/F	Cred. Dist.	Partial	Job- Link	Minutia		Back- ward		SRO Only		Explanation
6	Н	2				×							х	U	008A2.04: Currently not SRO in that only system knowledge is required to answer the question. Need to add some procedures to go to so the question has some SRO value. Distractors C and D are not plausible in that excessive RCP seal leakoff would be the cause of the CCW radiation problems.
	Н	2		447										s	Question replaced. New question is Satisfactory. The question tests at the C/A level with a LOD=2.
7	F	3	х											E	009EG2.4.30: Stem need to be changed in order to have a correct answer. Currently there is no correct answer. Distractor A is a 1 hour notification per 10CFR50.72(a)(3) not 10CFR50.72(b)(1). None of the events listed require a 1 hour notification per 10CFR50.72(b)(1). Suggest the stem be changed to state per EPP-002 vice per 10CFR50.72(b)(1).
		2												s	Question has been corrected LOD=2. SAT
8	Н	3	x				X	,				X		U	022AG2.4.49: Stem needs to be consistent with procedures. With an ATWT in progress the crew would be driving rods in therefore, power would not maintain at pre-event values. An RCS leak in excess charging is a SBLOCA. The answer B is not IAW AOP-106, per AOP 106 the crew would borate through the bender unless they can not get the BA XFER PP running due to not resetting the lock outs. The question can better address the K/A if actions are listed in the distractors.
	Н	2												S	Question replaced. New question is Satisfactory. The question tests at the C/A level with a LOD=2.
9	F	2												s	032AA2.08
10	Н	2												s	035G2.4.31: Could not write a question at the SRO level for this K/A. K/A randomly reselected.
11	Н	2												s	054AA2.03
12	н	2											х	U	068G2.1.30: Question does not test at the SRO level. This K/A is not conducive to testing the SRO knowledge level.
	Н	2												s	New K/A was randomly selected 068G2.1.20. New question was generated and is Satisfactory. The new question tests at the C/A level with a LOD=2.

Q#	1. LOK	2. LOD	3	. Psyc	homet	ric Flaw	/s	4.	Job Conf	tent Fl	aws	5. O	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
13	F	3												s	103G2.1.30
14	F	2												s	G2.1.13
15	Н	1											Х	U	G2.1.34: Question does not test at the SRO level. LOD is too low
	Н	3												s	Question has been corrected. The question noe tests at the C/A with a LOD=3. SAT
16	F	3		,										s	G2.2.20: Question taken from Licensee exam bank. Insufficient references provided by the Licensee for question verification. Licensel will verify answer and distractors.
17	F	2												s	G2.2.7
18	F	3												s	G2.3.2
19	F	2												S	G2.4.33: Question taken from Licensee exam bank. Insufficient references provided by the Licensee for question verification. Lic will verify answer and distractors.
20	Н	2				Х								E	G2.4.38: Distractors A and C are not plausible. Procedures do no reference the Fairfield Pump Facility as an evacuation assembly a
														s	Question has been corrected. SAT
21	Н	2 .												s	W/E02EG2.4.6
22	Н	3				X								E	W/E05EA2.1: Distractor D is not plausible. EOP-16 does not dire transitions and EOP-15 is only entered from the Safety Function 5 tree.
						:									Question has been correct. SAT
23	Н	3												S	W/E09EA2.2: Minor wording changes to make distractors similar i appearance.
24	Н	3												S	W/E12EG2.4.4: Minor wording changes to make distractors similar appearance.
25	F	2											***************************************	s	W/E13EG2.2.25



### ES-401, Rev. 9 Written Examination Review Worksheet Form ES-401-9 2. 3. Psychometric Flaws 4. Job Content Flaws 5. Other 6. 7. LOD Q# LOK (F/H) (1-5)Stem Cues T/F Cred. Partial Job-#/ Q= SRO U/E/S Minutia Back-Explanation Focus Dist. Link units | ward K/A Only Instructions [Refer to Section D of ES-401 and Appendix B for additional information regarding each of the following concepts.] 1. Enter the level of knowledge (LOK) of each question as either (F)undamental or (H)igher cognitive level. 2. Enter the level of difficulty (LOD) of each question using a 1 – 5 (easy – difficult) rating scale (questions in the 2 – 4 range are acceptable). 3. Check the appropriate box if a psychometric flaw is identified: The stem lacks sufficient focus to elicit the correct answer (e.g., unclear intent, more information is needed, or too much needless information). The stem or distractors contain cues (i.e., clues, specific determiners, phrasing, length, etc). The answer choices are a collection of unrelated true/false statements. The distractors are not credible; single implausible distractors should be repaired, more than one is unacceptable. One or more distractors is (are) partially correct (e.g., if the applicant can make unstated assumptions that are not contradicted by stem). 4. Check the appropriate box if a job content error is identified: The question is not linked to the job requirements (i.e., the question has a valid K/A but, as written, is not operational in content). The question requires the recall of knowledge that is too specific for the closed reference test mode (i.e., it is not required to be known from memory). The question contains data with an unrealistic level of accuracy or inconsistent units (e.g., panel meter in percent with question in gallons). The question requires reverse logic or application compared to the job requirements. Check questions that are sampled for conformance with the approved K/A and those that are designated SRO-only (K/A and license level mismatches are 5. unacceptable). 6. Based on the reviewer's judgment, is the question as written (U)nsatisfactory (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)atisfactory? 7. At a minimum, explain any "U" ratings (e.g., how the Appendix B psychometric attributes are not being met), Н 001A2.03: 2 002A4.08: Need to add additional annunciator (XCP-621 Point 1-5) to the stem. Need to add that generator MW are not changing to the stem. This is required to ensure only one correct answer. Comment Incorporated. Need to add that one bistable light is lit and that no other bistable lights are illuminated. This is required to ensure only one correct answer. Comment Incorporated. 003A4.01:

	1.	2.		3. Psyc	hometr	ic Flaws	3	4.	Job Coni	ent Fl	aws	5. O	ther	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
4	F	4													003AK1.17: Need to indicate in the stem that the effect required to be evaluated is in the area of the dropped rod. Too difficult to determine the effect on the entire core.  Comment Incorporated.
5	F	2													004G2.4.49: Need to add wording to the stem that the TCV-144 valve is in its normal 100% power position to ensure the applicants know that the conditions in the stem are not due to this valve being mispositioned. Also need to add to distractors C and D that TCV-144 needs to be manually open to provide more cooling.  Comments Incorporated.
6	Н	3		-											005AA2.03: Requested changing Answer D to the action that is taken to ensure that the shutdown margin is maintained.  Comment Incorporated. Changed answer D to state that a 30 gpm boration is initiated until the plant is in MODE 3.  Requested that the stem annotate that Rods B8 and K6 are in Control Bank D.  Comment Incorporated.
7	F	2				٠									005K6.03: Incorrect nomenclature for valve in distractor B.  Corrected the valve nomenclature.
8	Н	3													006K4.11:
9	Н	3													007A2.05: Corrections needed to the stem to ensure that the conditions present would unmistakenly cause water to go to the PRT. Crew should be in GOP-6 instead of SOP-115. Requested RCS temperature in the stem to be increased to 305.  Comment Incorporated. Stem was modified to state that the GOP-6 was in progress .vs. SOP-115 to swap to the protected train. Removed unneeded information from the stem that supported sop-115. Changed RCS temperature to 305 .vs. 300.
10	F	2													007EK1.05: Requested distractor time frames be changed to better reflect when SR comes on scale, since Sr may come on scale earlier that 15 minutes.  Comment Incorporated. Distractor time frames changed.
11	Н	2													007K1.01:

п	<del></del>	·	 	Y	<u> </u>	Т		 		 	
12	Н	3									008A3.06: Requested changing the CCW pump discharge pressure from 40 psig to 45 psig to show that the auto start of the standby pump has yet to occur .vs. has failed to occur. Requested adding "subsequent and/or current status" to the stem.  Comment Incorporated. Changed the stem to reflect that CCW pump discharge pressure is 45 psig and decreasing added "subsequent and/or current status" to the stem.  Requested removing bulleted statement from the stem about CCW low flow on the essential load. This is not a pertinant condition needed in the stem and indicates that the essential and non-essential CCW headers are/were cross-connected.  Comment Incorporated.
13	Н	2									008AG2.4.49:
14	Н	2						-			010G2.4.4: Requested rearranging the bulleted information to show more of a time line of the events other than just the status. Comment Incorporated.
15	F	2									011EK2.02:
16	F	2									012A4.03: Nomenclature in the answer needs to be corrected.  Comment Incorporated. Changed "MSIV isolation signal" to "Main Steam Isolation signal."
17	F	2									012K2.01:
18	F	2									013K1.06:
19	Н	2									015AK1.02: Nomenclature for P-8 is not correct. Suggested changing the wording of distractor C to be consistent with answer A. Comment Incorporated.
20	F	2									017K1.01:
21	F	2									022A1.04: Need to change that sump was pumped to the "waste holup tank" .vs. "floor drain tank in the stem.  Comment Incorporated
22	H	3						•			022AA1.08: Requested changing VCT level in the stem from 50% to 38% to be consistent with normal makeup levels.  Comment Incorporated.
23	F	2							_		022K3.02: Nomenclature change required in the stem. Comment Incorporated. Changed "Containment Fan Cooler Unit" to "Reactor Building Cooling Unit"

24	Н	2								024AG2.4.6: Stated that the stem is hard to read.  Comment Incorporated. The stem was split into sections for easier reading.  Under the current conditions, the breaker for the PORV would not need to be opened to satisfy TS. Requested removing the reference to the PORV beaker in the stem.  Comment Incorporated.
25	F	2								025AG2.1.32:
26	F	3					- 1			026AA1.01: LOD too high for knowing the temperature for the charging pump oil cooler is above the limit, this value is usually checked in the field. Suggest changing to the Spent Fuel Pool limit has been exceeded. Comment incorporated. Stem was changed to have the SFP limit being exceeded.
27	Н	3						-		026K2.02: Answer A is correct answer for power loss on A train .vs. D as annotated.  Comment Incorporated. Question corrected to annotate A as the correct answer.
28	Н	2								026K3.02: Events in the stem should be sequenced to show a time line. Requested that "actually providing cooling" be stressed in the stem Comment Incorporated.
29	Н	3	х							027AK1.02: Requested that distractors indicate that the parameter change is from its initial steady sate value.  Comment Incorporated. Added "from its steady state value" to each distractor.
30	Н	3								064K6.08: There are two possible answers to this question. Distractors need to be modified in order for there to be only one correct answer. Comment Incorporated. Added time estimates to distractors C and D for credibility and ensuring only one correct answer.
31	F	3								034A1.02: Distractor A could also be considered correct due to procedure specification of limit of 461' 6" and trying not to exceed this value.  Comment Incorporated. Changed limit in distractor A to 461' 3.5", which is the low level alarm setpoint.
32	H	2								035K6.02: Distractor A is the correct answer. Distractor B is not correct since the reactor trip will not cause the B/S to reset to allow shutting the PORV. The reactor trips and P-12 is received in conjunction to causing to PORV closing.  Comment Incorporated. Distractor A has been annotated as the correct answer.

33	Н	2						 R0 mi C0 dis	88EK3.08: VC Summer station does not perform depressurization of CS at the same time as performing the cooldown associated with the itigation of a SGTR.  comment Incorporated. Removed the information in the stem and stractors that stated that an RCS depressurization was also in ogress.
34	Н	2				-		du	39A1.10: Requested format change to a fill in the blank type question le amount of repeat material in each distractor.
35	Н	2						04	0AK2.02:
36	Н	3						04	5K5.17:
37	Н	3						the Co	in 1AA1.04: Requested information be added in the stem to eliminated a complication due to feedwater preheating affects.  In the stem that feedwater temperature and the stem to eliminate and the stem that feedwater temperature and the stem that the stem that feedwater temperature and the stemperature and the stemp
38	Н	2						05	4AK3.01:
39	Н	2							SEA2.05: Typo in the answer. Comment Incorporated. Changed "VCD" to "VDC".
40	Н	3						Re	6G2.1.28: Nomenclature change needed, "DST" should be "DAST". emove 11' 0" level to sate "HI-HI" level alarm. This is more cognizable to the Control Room then actual level.
41	H	3						Mi	7AG2.4.4: Needs Minor word changes. inor word changes made to the stem. Changed "are" to "is"; and leet" to "mitigate"
42	Н	2						the	8AA2.01: Need to add additional annunciator that is received under e conditions specified in the stem due to where voltage is sensed.  Somment Incorporated. Added "INV 1/2 AC INPUT LOSS" to the stem.
43	F	2						sol	9G2.1.23: Need to add wording to the stem to specify the question is liciting the MINIMUM actions required.
44	Н	3							1K5.03: Requested adding the noun name for IFV-3536 to the stem.

m	· ·		 	 	 	 	 	·
45	Н	3						062A2.06: Stem is too wordy. Requested splitting the stem in to sections for easier reading.  Comment Incorporated. Stem wording rearranged for easier reading, adding clarity to the stem.
46	F	3						062A3.04: Requested that "Step 2.1" be changed to "Step III.N.2.1" in stem. Distractors should state "within 10 seconds" .vs. "within 5 to 10 seconds" since light will light within 10 seconds, but not immediately. Comment Incorporated.
47	F	2						062AA1.07: Requested wording change to the stem to be consistent with the wording that the applicants are use to seeing for this type of question.  Comment Incorporated.
48	F	2						063K4.01:
49	Н	2						064K6.07:
50	F	2						065AK3.04:
51	F	2						071K3.05: Requested format change to fill in the blank since many of the same words were in each distractor.  Comment incorporated. Changed the stem to reflect fill in the blank format. Moved distractor wording into the stem and shorted the distractors appropriately.
52	Н	3						072K4.03: Request adding the nomenclature for RM-G17A annunciator to the stem.  Comment Incorporated.
53	F	3						073K5.03: Requested changing "Radiation Protection" to "Health Physics" in the stem.  Comment Incorporated.
54	F	3						075K2.03:
55	Н	3						076A1.02: This question addresses a situation in the plant that is not in plant procedures to mitigate. Request the question be re-written. Question was replaced. The facility lesson plans addressed this as a possibility with the suggested mitigation strategy. The facility was unclear as to why this was addressed in the lesson plans.
56	Н	3						076A3.02: Need to state in the stem that a procedure violation has occurred to support the initial conditions of having both A and C SW pumps racked up at the same time on the same train. Comment Incorporated.

T	Т-	1	T	Г	т	1	<del></del>	 	 	 Т		
57	Н	2					ļ					078K4.01:
58	F	2										103K3.02:
59	F	3										G2.1.1: Remove "ACA" from the stem since this is not normally used as a designation for "Area of Continuous Attention." Comment Incoporated.
60	F	2									·	G2.1.3: Requested change 30 minutes to 15 minutes in the stem. Comment Incorporated.
61	Н	2										G2.1.29: Requested that "Routine System Lineup Verification" not be capitalized.  Comment Incorporated.
62	F	3										G2.2.11: Need to annotate in distractor B and D the qualified reviewer is a member of the plant management staff.  Comment Incorporated.
63	Н	3										G2.2.25:
64	F	2										G2.2.28
65	Н	3										G2.3.1:
66	Н	4					2.2	-				G2.3.10: The applicants are not required to know the DAC-hour airborn exposure equivalents.  Agreed to provide the applicants with a conversion on the formula sheet reference.  Need to state in the stem that the shielding will remain installed.  Comment Incorporated.
67	Н	2										G2.4.15: Requested distractor A be changed to state that max ccoldown has to be stopped if head voiding occurs. Requested stopping criteria be added to Answer B. Requested that distractor D be changed since it is not credible.  Comment Incorporated. Stopping criteria added to answer B. Distractor A reworded to state that cooldown must be stopped if head voiding occurs. Distractor D changed to state the TS limit of 100 F/hr cooldown limit must not be exceeded until local communications are established.
68	Н	2										G2.4.32:
69	Н	2										W/E04EA2.1: Need to annotate that Pressurizer pressure is decreasing .vs. stable to ensure proper procedural path through EOP-1.0. Comment Incorporated.
70	F	3										W/E07EK3.2:

71	F	2		·					S	W/E09EG2.4.49: LOD too high. Applicants are not required to know the procedure reference pages from memory. The applicants are unlikely to know that the loss of RCS subcooling in EOP-1.3 is SI initiation criteria. Compromised with the facility to change the SI initiating parameter of Pressurizer level being below the limit also be added to the stem. Facility agreed to this change since the PZR level is a parameter that is more recognizable for SI initiation.
72	H	2							s	W/E10EK2.2:
73	Н	3			,					W/E12EK2.1: Facility comment that the applicant will not distinguish between SI termination criteria under normal LOCA conditions and that of an Uncontrolled Depressurization of ALL Steam Generators. Facility requested that the question be changed.  Comment NOT Incorporated. The NRC believes that the applicants should know that with an uncontrolled depressurization of ALL Steam Generators that the existence of a "secondary heat sink" is NOT required for SI flow reduction. Facility stated that they will verify this with operations management.  Facility had no further comments to dispute having this question on the test.
74	Н	4								W/E13EK2.2
75	Н	3								W/E15EK3.3:

FACILITY COMMENTS SRD TEST

ES-401, Rev. 9

2

Form ES-401-9

Q#	1. LOK	2. LOD	3	. Psyc	homet	ric Flaw	s	4.	Job Cont	ent Fla	aws	5. C	ther	6.	7.
Q#	(F/H)	(1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
1	Н	2													002A2.04:
2	H	ვ													003A2.03: Stem should solicit that the sequence of events is required. The distractors need to reflect more of the sequence of events needed from AOP-17.1. Currently distractor C can also be considered correct in that stopping 2 RCPs is not prohibited.  Comment Incorporated. The stem was reworded to solicit the sequence of events. The distractors were modified to contain more of the events from AOP-17.1.
3	F	2				,									005G2.1.27:
4	Н	2													007A2.03: In the stem, RCS temperature should be lower than 180F with a solid PZR, suggest 140F. Stem should state that ALL PORV's are in AUTO. Distractor A should state that the controlling channel has failed instead of just stating the B/S has failed. Comments Incorporated.
5	Н	2													007EA2.01: Stem needs to be clarified to state that both MFWPs were running when they tripped. State in the stem that one of the trip breakers failed to open to add credibility to the power level still being above 5%. Distractors C and D should state that the transition is from EOP-1.0. Stem should also state that the crew is performing the immediate actions of EOP-1.0.  Comments Incorporated. Discussions with the facility resulted in also changed the stem to a higher power level to ensure a more warranted transition to EOP-13.0.
6	Н	2													008A2.04: The annunciator listed as bullet #1 would not be received under these conditions and annunciator LTDN/SL WTR HX FLO LO TEMP HI would. Stem should state that all associated automatic actions have occurred, this will ensure that distractor A is incorrect. Requested that the distractors be rearranged to be consistant with the sequence of events in the SOP.  Comments Incorporated.
7	F	2													009EG2.4.30:

	1.	2.	3	. Psyc	homet	ric Flaw	/S	4.	Job Cont	tent Fla	aws	5. C	ther	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia	#/ units	Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
8	Н	2													022AG2.4.49: Request words to be added to the stem to indicate that the problem is definitely with the CCP.  Comment Incorporated. Added to the stem that the CCP amps and flow are "fluctuating" and the pressure is "oscillating."
9	F	2													032AA2.08: Distractors C and D should state "detector" .vs. "monitor." Comment Incorporated. Stem needs to state that SR monitor N33 is out-of-service, this ensures that action must be taken. Comment Incorporated.
10	Н	2				*									035G2.4.20: In the stem "actions" should be changed to "sets of actions (not all inclusive)."  Comment Incorporated.
11	Н	2	•												054AA2.03: Stem should state that SG levels are decreasing. The stem does not need to designate the ARP, this adds confusion. Request that distractor be worded to indicate that the pumps should have a start signal .vs. should have started. This will prevent confusion in thinking that there may be a problem with the pumps. Comments Incorporated.
12	Н	2	·												068G2.1.30: Distractors B and C should reference RM-L5 .vs. RM-L9. Request that the word "second" be emphasized in the stem. Comments Incorporated. The word "second" in the stem was underlined.
13	F	3													103G2.1.30: Corrections needed to the air lock door nomenclature.  Comment Incorporated. Nomenclature for the doors corrected.
14	F	2						,							G2.1.13:
15	Н	3													G2.1.34: LOD is too high. Stem and distractors were reworded to decrease the level of difficulty to a level that was acceptable to the facility. RCS temperature decreased to 200F in the stem so a mode change has not occurred. Distractor worded to stop the heatup to prevent non-compliance.
16	F	3													G2.2.20: LOD is too high. Discussions with the facility on the LOD resulted in changing distractor C to make it less attractive. This resulted in an acceptable LOD for the facility.

	1.	2.	3	. Psyc	homet	ric Flaw	/S	4.	Job Con	tent Fi	aws	5. C	ther	6.	7.
Q#	LOK (F/H)	LOD (1-5)	Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job- Link	Minutia		Back- ward	Q= K/A	SRO Only	U/E/S	Explanation
17	F	2													G2.2.7:
18	F	3													G2.3.2: The wind directions in distractors B and D are too close to the correct direction. Request that they be changed from "South-Southeast." Comment Incorporated. The wind direction in distractors B and D changed to "West-Southwest."
19	F	2													G2.4.33: Requested that 96 hours be added to the stem to place to correct frame of reference for the applicants.  Comment Incorporated.
20	F	2													G2.4.38:
21	Н	2													W/E02EG2.4.6: Facility not content with the wording of the distractors.  Discussions lead to rewording the distractors for clarification.
22	Н	3													W/E05EA2.1:
23	Н	3													W/E09EA2.2:
24	н	3													W/E12EG2.4.4:
25	F	2													W/E13EG2.2.25:

Fac	cility: VC Summen Date of Exam: 1/10/06		Exam Le	evel R	2/SRO								
				Initials									
	Item Description		а	b	С								
1.	Clean answer sheets copied before grading		<b>(</b>	NA	pob								
2.	Answer key changes and question deletions justified and documented		@	NA	psb								
3.	Applicants' scores checked for addition errors (reviewers spot check > 25% of examinations)		(a)	WA	psb								
4.	Grading for all borderline cases (80 +/- 2% overall and 70 c 80, as applicable, +/- 4% on the SRO-only) reviewed in details.		(Gr	WA	psp								
5.	All other failing examinations checked to ensure that grade are justified	S	(G)	WA	fort								
6.	Performance on missed questions checked for training deficiencies and wording problems; evaluate validity of questions missed by half or more of the applicants		@	NA	psh								
	Printed Name / Signature		7 10 10001	D	ate								
a.	Grader Steven D. Pasi / Stools	~	Politica Constantina Constanti	57	8/06								
b.	Facility Reviewer(*)	******		<del> </del>									
c. 1	NRC Chief Examiner (*) Russep 5. BALOW / ISA			5)4	y/or								
d.	NRC Supervisor (*) James H. Moorman and James	411	L	<u>5/</u> 8	106								
(*)	The facility reviewer's signature is not applicable for examir NRC; two independent NRC reviews are required.	atio	ns grade	ed by th									

	Post-Examination Check Sheet									
Fac	cility: V.C. Summer Date of Examination: 12/	12-12/16/05 & 1/10/06								
Tas	sk Description	Date Complete								
1.	Facility written exam comments or graded exams received and verified complete	1/26/06								
2.	Facility written exam comments reviewed and incorporated and NRC grading completed, if necessary	5/08/06								
3.	Operating tests graded by NRC examiners	5/11/06								
4.	NRC chief examiner review of operating test and written exam grading completed	5/11/06								
5.	Responsible supervisor review completed	5/12/06								
6.	Management (licensing official) review completed	5/12/06								
7.	License and denial letters mailed	5/12/06								
8.	Facility notified of results	5/12/06								
9.	Examination report issued (refer to NRC MC 0612)	6/19/06								
10.	Reference material returned after final resolution of any appeals	NIA								