



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 165
License No. DPR-26

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated September 29, 1992, as supplemented by letters dated February 19, 1993, June 10, 1993, and July 19, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:


9309290357 930922
PDR ADOCK 05000247
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 165, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented at the next outage of sufficient duration to effect the plant modification.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 22, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 165

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Revise Appendix A as follows:

Remove Page
Table 3.5-1 (page 1 of 1)

Insert Page
Table 3.5-1 (page 1 of 1)

Table 3.5-1

Engineered Safety Features Initiation Instrument Setting Limits

No.	Functional Unit	Channel	Setting Limits
1.	High Containment Pressure (Hi Level)	Safety Injection	≤ 2.0 psig
2.	High Containment Pressure (Hi-Hi Level)	a. Containment Spray b. Steam Line Isolation	≤ 30 psig
3.	Pressurizer Low Pressure	Safety Injection	≥ 1829 psig
4.	High Differential Pressure Between Steam Lines	Safety Injection	≤ 150 psi
5.	High Steam Flow in 2/4 Steam Lines Coincident with Low T_{avg} or Low Steam Line Pressure	a. Safety Injection b. Steam Line Isolation	$\leq 40\%$ of full steam flow at zero load $\leq 40\%$ of full steam flow at 20% load $\leq 110\%$ of full steam flow at full load $\geq 540^{\circ}\text{F } T_{avg}$ ≥ 600 psig steam line pressure
6.	Steam Generator Water Level (Low-Low)	Auxiliary Feedwater	$\geq 5\%$ of narrow range instrument span each steam generator
7.	Station Blackout (Undervoltage)	Auxiliary Feedwater	$\geq 40\%$ nominal voltage
8a.	480V Emergency Bus Undervoltage (Loss of Voltage)	-----	220V + 100V, -20V 3 sec \pm 1 sec
8b.	480V Emergency Bus Undervoltage (Degraded Voltage)	-----	421V \pm 6V 180 sec \pm 30 sec (no SI) 10 sec \pm 2 sec (coincident SI)