



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 185
License No. DPR-26

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated December 8, 1995, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:

9512150018 951208
PDR ADOCK 05000247
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 185, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented immediately.

FOR THE NUCLEAR REGULATORY COMMISSION



Ledyard B. Marsh, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 8, 1995

ATTACHMENT TO LICENSE AMENDMENT NO. 185

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Revise Appendix A as follows:

Remove Pages

3.1.A-4

Insert Pages

3.1.A-4

5. Power Operated Relief Valves (PORVs)/Block Valves (for operation above 350°F)

- a. Whenever the reactor coolant system is above 350°F, the PORVs and their associated block valves shall be operable with the block valves either open or closed.
- b. If a PORV becomes inoperable when above 350°F, its associated block valve shall be maintained in the closed position.
- c. If a PORV block valve becomes inoperable when above 350°F, the block valve shall be closed and deenergized.
- d. If the requirements of Specification 3.1.A.5.b or 3.1.A.5.c above cannot be satisfied, compliance shall be established within four (4) hours, or the reactor shall be placed in the hot shutdown condition within the next six (6) hours and subsequently cooled below 350°F.
- e. With regard to the use of the PORVs/Block Valves as a reactor coolant system vent, the requirements of Specification 3.16 shall be adhered to.

6. Pressurizer Heaters

- a. Whenever the reactor coolant system is above 350°F, the pressurizer shall be operable with at least 150kW of pressurizer heaters.
- b. If the requirements of Specification 3.1.A.6.a cannot be met, restore the required pressurizer heater capacity to operable status within 72 hours or the reactor shall be placed in the hot shutdown condition within the next six (6) hours and subsequently cooled to below 350°F.