



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

DOCKET NO. 50-247

INDIAN POINT NUCLEAR GENERATING UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 197
License No. DPR-26

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consolidated Edison Company of New York, Inc. (the licensee) dated June 6, 1997, as supplemented by letter dated September 25, 1997, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-26 is hereby amended to read as follows:

9808040206 980729
PDR ADOCK 05000247
P PDR

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.197 are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



S. Singh Bajwa, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 29, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 197

FACILITY OPERATING LICENSE NO. DPR-26

DOCKET NO. 50-247

Revise Appendix A as follows:

Remove Pages

5.2-2

Table 4.1-2 page 1 of 2

Insert Pages

5.2-2

Table 4.1-2 page 1 of 2

C. CONTAINMENT SYSTEMS

1. The containment vessel has an internal spray system which is capable of providing a distributed borated water spray of at least 2200 gpm⁽³⁾.
2. The containment vessel has an internal air recirculation system which includes five fan-cooler units (centrifugal fans and water cooled heat exchangers), with a total heat removal capability of at least 308.5 MBtu/hr under conditions following a loss-of-coolant accident and at service water temperature of 95°F.⁽⁴⁾ All of the fan cooler units are equipped with activated charcoal filters to remove volatile iodine following an accident.

References

- (1) UFSAR Section 5.1.2.2
- (2) UFSAR Section 5.1.4
- (3) UFSAR Section 6.3
- (4) UFSAR Section 6.4

Table 4.1-2

Frequencies for Sampling Tests

	Check	Frequency	Maximum Time Between Tests	
1.	Reactor Coolant Samples	Gross Activity (1) Radiochemical(2) E Determination Tritium Activity F, Cl & O ₂	5 days/week (1) Monthly Semi-annually (3) Weekly (1) Weekly	3 days 45 days 30 weeks 10 days 10 days
2.	Reactor Coolant Boron	Boron Concentration	Twice/week	5 days
3.	Refueling Water Storage Tank Water Sample	Boron Concentration	Monthly	45 days
4.	Boric Acid Tank	Boron Concentration	Twice/week	5 days
5.	DELETED			
6.	DELETED			
7.	Accumulator	Boron Concentration	Monthly	45 days
8.	Spent Fuel Pit	Boron Concentration	Monthly	45 days
9.	Secondary Coolant	Iodine-131	Weekly (4)	10 days
10.	Containment Iodine- Particulate Monitor or Gas Monitor	Iodine-131 and Particulate Activity or Gross Gaseous Activity	Continuous When Above Cold Shutdown(5)	NA