

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
573rd Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, June 10, 2010

Work Order No.: NRC-298

Pages 1-205

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 573rd MEETING

5 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

6 (ACRS)

7 + + + + +

8 THURSDAY

9 JUNE 10, 2010

10 + + + + +

11 ROCKVILLE, MARYLAND

12 + + + + +

13 The Advisory Committee convened at the
14 Nuclear Regulatory Commission, Two White Flint North,
15 Room T2B1, 11545 Rockville Pike, at 8:30 a.m., Dr.
16 Said Abdel-Khalik, Chair, presiding.

17 COMMITTEE MEMBERS PRESENT:

18 SAID ABDEL-KHALIK, Chair

19 J. SAM ARMIJO, Vice Chair

20 SANJOY BANERJEE

21 DENNIS C. BLEY

22 MARIO V. BONACA

23 MICHAEL CORRADINI

24 DANA A. POWERS

25 HAROLD B. RAY

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COMMITTEE MEMBERS PRESENT: (cont.)

2 MICHAEL T. RYAN

3 WILLIAM J. SHACK

4 JOHN D. SIEBER

5 JOHN W. STETKAR

6
7 NRC STAFF PRESENT:

8 DEREK WIDMAYER, Designated Federal Official

9 ED ROACH

10 JEAN-CLAUDE DEHMEL

11 HOSUNG AHN

12 TOM NICHOLSON

13 RICHARD RAIONE

14 CHARLES ADER

15 DONALD DUBE

16 SUNIL WEERAKKODY

17 MICHAEL SCOTT

18 JOHN LEHNING

19 WILLIAM RULAND

20 STEPHEN SMITH

21 TIM COLLINS

C-O-N-T-E-N-T-S

1		
2	7) Opening Remarks b the ACRS Chairman	4
3	8) Proposed Interim Staff Guidance (ISG)	5
4	DC/COL ISG-013 Assessing the	
5	Consequences of an Accidental Release	
6	of Radioactive Materials from Waste	
7	Tanks and Proposed DC/COL ISG-014	
8	Assessing Groundwater Flow and	
9	Transport of Accidental Radionuclide	
10	Releases	
11	9) Status of Risk-Informing Guidance for	74
12	New Reactors	
13	10) Generic Safety Issue (GSI) -191	137
14	Assessment of Debris Accumulation	
15	on PWR Sump Performance	
16	11) Future ACRS Activities/Report of the	(CLOSED)
17	Planning and Procedures Subcommittee	
18		
19		
20		
21		
22		
23		
24		
25		

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:27 a.m.

CHAIR ABDEL-KHALIK: On the record. The meeting will now come to order. This is the second day of the 573rd Meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: (1) Proposed Interim Staff Guidance ISG-013, Assessing the Consequences of an Accidental Release of Radioactive Materials from Waste Tanks and Proposed DC/COL-ISG-014, Assessing Groundwater Flow and Transport of Accidental Radionuclide Releases; (2) Status of Risk-Informing Guidance for New Reactors; (3) Generic Safety Issue (GSI)-191, Assessment of Debris Accumulation on PWR Sump Performance; (4) Future ACRS Activities/Report of the Planning and Procedures Subcommittee; (5) Reconciliation of ACRS Comments and Recommendations; and (6) Preparation of ACRS Reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Derek Widmayer is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests for time to make oral statements from members

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the public regarding today's sessions. There will
2 be a phone bridge line. To preclude interruption of
3 the meeting, the phone will be placed in a listen-in
4 mode during the presentations and Committee
5 discussions.

6 A transcript of portions of the meeting is
7 being kept and it's requested that the speakers use
8 one of the microphones, identify themselves and speak
9 with sufficient clarity and volume so that they can be
10 readily heard.

11 At this time we will go to Item No. 8 on
12 the agenda which deals with ISG-013 and 014 and Dr.
13 Ryan will lead us through that discussion.

14 Dr. Ryan.

15 MEMBER RYAN: Mr. Chairman, we had a very
16 productive subcommittee meeting a few weeks ago on
17 ISG-013 and 014. And one important area that we dealt
18 with was the function of these ISGs and their intended
19 purpose for license review activities versus the
20 current issue of groundwater contamination at some
21 power plant facilities. So we've separated those two
22 issues and recognize that these two are really
23 intended for a license review activity on the
24 particular topics and I'm sure the staff will fill us
25 in on those details.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But I thought I'd preface our meeting
2 today by keeping that issue separate which we will
3 take up at a later time. But that's not the purpose
4 or function of these two ISGs.

5 Without further ado, I guess I will turn
6 to you, Jean Claude, or Ed. To Ed Roach of NRO.

7 MR. ROACH: Good morning. My name is Ed
8 Roach. I'm the branch chief for the Health Physics
9 Branch of New Reactors, Division of Construction and
10 Inspection. And I'd like to thank the Committee for
11 asking us to appear today and presenting these topics.

12 Again, as Dr. Ryan said, these are based
13 on our lessons learned from the recent COL and
14 certified design reviews we've conducted and where
15 we've identified clarification that was necessary
16 within the guidance for the standard review plan what
17 was reviewed in March of 2007. So these will apply
18 once approved or once finalized to those reviews that
19 come in after that point. So these are lessons
20 learned. And this is how we feel is the best method
21 to present this information where it gets full
22 transparency, review and incorporated into the SRP at
23 a later time. Thank you.

24 MEMBER RYAN: Okay. Jean-Claude, are you
25 up?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEHMEL: Yes. Thank you. My name is
2 Jean-Claude Dehmel and I'm a health physicist for NRO.

3 And basically this presentation we split. I will
4 cover ISG-013 for the first five slides and then
5 Hosung will present the remaining of the slides on
6 ISG-014 as well as conclude the presentation.

7 The purpose of both ISGs is to expand
8 existing guidance by providing additional
9 clarification and technical guidance on the
10 information already contained in the SRP Reg. Guide
11 2.206 and based on experience that we've had in
12 reviewing currently in-house applications. I'll give
13 you a few examples of some of the issues that we've
14 come across with that respect.

15 But basically the purpose of both ISGs
16 starting with ISG_013 is provide expanded guidance on
17 the justification of selecting specific tanks that are
18 assumed to fail; evaluate the kind of tank, the tank
19 location and the facility design features that may be
20 used in mitigating the impact of a release; some of
21 the process associated with the radiological
22 assessment in assessing the radiological impact of the
23 failed tank; and also for the purpose of additional
24 guidance on the assignment of tech spec for maximum
25 radioactivity inventory in tank. That is for tanks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that either failed the acceptance criteria and whether
2 or not additional design features should be
3 implemented as part of the design. For example, the
4 addition of steel liners in a cubicle housing tank.

5 The focus of ISG-014 and the guidance on
6 that, the proposed revised guidance on that, focuses
7 on the radiological consequences analysis namely for
8 the transport of radioactivity from the tank to the
9 point of exposure as well as providing further
10 guidance on the kind of site hydrogeologic features
11 that can be used to characterize and quantify the
12 movement of radioactivity to the point of exposures.

13 Why are these ISGs needed? Well, because
14 there is again as Ed noted earlier, there are
15 inconsistent guidance within the SRPs, namely Section
16 11.2 describing the liquid waste management system,
17 BTP 11-6 which essentially forms the basis for
18 analyzing and evaluating the consequence of a radwaste
19 tank failure as well as the interface requirement in
20 Section 2.4.12 and 2.4.13 with having to do with
21 groundwater movement as well as again assessing
22 radiological consequences of radwaste tank failures in
23 the context of applying site-specific features.

24 CHAIR ABDEL-KHALIK: Could you give us
25 more detail as to the manner in which the current

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guidance is internally inconsistent?

2 MR. DEHMEL: Yes, I have a slide, but
3 basically -- Let me go over those now basically then.

4 This related to the site's experience in reviewing
5 specific applications to date. For example, what has
6 been experienced has been with the kind of assumptions
7 and credits that the applicant has used in applying
8 certain design features and mitigating the impact of a
9 radiological release. The kind of assumption used
10 with respect to the release mechanism and the duration
11 of a release, whether or not it was a prompt release
12 or it was essentially a slow release.

13 For example, in the context of the BTP and
14 SRP the premise is that it's an abrupt and sudden
15 release of radioactivity. Well, some applicants
16 essentially have assumed protracted release meaning
17 that the tank ruptures and the liquid stays there for
18 months and then slowly slips out of the cubicle or
19 radwaste building into the groundwater and then
20 ultimately impacts an offsite dose.

21 MEMBER CORRADINI: So it's the
22 assumptions. The inconsistencies could be
23 characterized as the assumptions one has to make to do
24 a calculation.

25 MR. DEHMEL: Yes. Basically, our intent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is -- or the intent of the guidance has always been
2 this will be a prompt release, a prompt failure of the
3 tank with the near immediate induction of the
4 radioactivity in ground or surface water. Some
5 applicants have looked at this and said, well, we have
6 a tank located in a cubicle. The cubicle has X feet
7 of concrete and so forth and therefore some
8 assumptions were made with respect to slow seepage of
9 the radioactivity through flow joints as well as
10 cracks into the environment.

11 CHAIR ABDEL-KHALIK: What would be the
12 mechanism for sort of prompt release resulting from
13 instantaneous failure of the tank? Are there
14 sufficient loadings or pressure rises in the tank that
15 would result in prompt failure of a tank?

16 MR. DEHMEL: Not that I can think of right
17 now. The assumption in the analysis is that you have
18 to make that simple assumption that you have a prompt
19 release of radioactivity into the environment. In
20 other words, unless there are certain features, for
21 example, a steel liner that would be built into a
22 cubicle or a room housing a tank and such that the
23 height of the liner would be adequate such that it
24 would contain the entire volume of a spill tank, the
25 assumption and the guidance right now assumes a prompt

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 failure.

2 So we kind of overlook the fact that in
3 real term or in a real world if you had a failure of a
4 tank, it would not be a prompt release. It would be a
5 slow release going to the environment. But for the
6 purpose of the analysis, the purpose of the SRP, the
7 purpose of the BTP 11-6, the assumption is a prompt
8 release of radioactivity.

9 MEMBER STETKAR: I'm not familiar with the
10 guidance, but there are ways that human errors, for
11 example, could actually release the contents of a tank
12 pretty quickly, not as quickly as a catastrophic
13 failure of the tank itself but release pretty large
14 volume of --

15 MEMBER RYAN: Faster than a slow seepage.

16 MEMBER STETKAR: Yes, faster than slow
17 seepage. That's right. So if this is a surrogate for
18 those types of things if they could occur, that's one
19 way without thinking of catastrophic structure
20 failures.

21 MR. DEHMEL: Yes, because it would be very
22 unlikely that you would have a kind of failure in the
23 building like this that would essentially open up the
24 basement so to speak and allow the tank to --

25 MEMBER BLEY: Without a driving force.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEHMEL: Right.

2 CHAIR ABDEL-KHALIK: So this is a bounding
3 calculation that is known to overestimate the dose but
4 is essentially the guidance given to the applicant.

5 MR. DEHMEL: Exactly.

6 MR. ROACH: This is Ed Roach. And just to
7 elaborate a little bit. This analysis was originally
8 contained in the previous version of the SRP in
9 Chapter 15.7.3 which required the analysis of this.
10 At the time, it was the quickest way to convey the
11 activity to the receptor and the mass of failure and
12 there have been examples of where tanks have collapsed
13 due to blocking off the vents or the forklifts or
14 equipment damaging. They haven't resulted in
15 significant releases to the offsite, but those have
16 occurred in the actual industry.

17 MR. DEHMEL: The other observations we
18 know are in the application, there have been some
19 questions about the kind of source term development
20 that the applicant proposed as well as the
21 distribution of radionuclide. In some cases, some
22 radionuclides, the proposed radionuclides, listed have
23 been somewhat comprehensive. In our cases, there has
24 not been. In other cases, it considered only very
25 long-lived radionuclide. In other cases, it did not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consider all potentially environmentally mobile
2 radionuclides such as Tc-99 and Iodine-129 and so on.

3 So in light of that, we felt it was kind
4 of necessary to expand the guidance as to the
5 selection of radionuclides and the radionuclide
6 distributions as well as -- The other thing that we're
7 adding to the guidance is the graded approach with
8 respect to the kind of tanks and the kind of
9 radioactive inventory one might expect.

10 For example, you can look at -- There are
11 two extremes. One set of tanks or a kind of system
12 that would have relatively low volumes, meaning volume
13 inventory, gallons or liters in a tank, but high
14 concentration versus tanks that have very high
15 inventories volume but low concentration. So now
16 we're essentially forcing the staff and the applicant
17 to consider those two extremes and determine which one
18 will be the most limiting.

19 The other couple issues that I have
20 identified are the point of compliance. Where is the
21 point of compliance in this case? Where is the end
22 user or the most likely dose receptor? Is it at the
23 EAV? Is that a point of use where the water
24 essentially be contaminated, for example, in surface
25 water or stream where that water essentially is being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 used as a supply to a water supply system or water
2 distribution system? Or was it simply a well located
3 at some distant location offsite?

4 And the other thing that we looked at also
5 is the point of compliance, whether or not it includes
6 water. Right now, the guidance the way it is written,
7 the implication, it's only drinking water. Even
8 though there are some footnotes that talk about
9 indirect use of water such as water irrigation for
10 crops and pastures as well as the watering of
11 livestock. So we've expanded the guidance and
12 essentially take that information from a simple
13 footnote to the main body of the guidance both in the
14 SRP Section 11.2 as well as the Branch Technical
15 Position 11-6.

16 So in those instances we would -- the
17 thinking is we would not apply the effluent
18 concentration limits of Part 20 Appendix B Table 2
19 concentration, but a dose limit.

20 MEMBER CORRADINI: I don't think I
21 appreciate what you just said. Can you say it again?
22 I recognize 10 CFR 20 which is a concentration. So
23 now you're saying that you would not do that. You
24 would do what?

25 MR. DEHMEL: No, we are expanding the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guidance to retain the guidance --

2 MEMBER CORRADINI: The concentration.

3 MR. DEHMEL: The concentration itself, the
4 acceptance criteria, that focused on the effluent
5 concentration limits of Part 20 Appendix B Table 2
6 concentrations.

7 MEMBER CORRADINI: Right.

8 MR. DEHMEL: And we're expanding it to
9 actually address or recognize the fact that there may
10 be instances where there would be no consumption of
11 surface or groundwater at a site, but that the impact
12 could occur by this water being used for indirect use
13 such as watering livestock and so on.

14 MEMBER CORRADINI: Right.

15 MR. DEHMEL: So for those kind of
16 scenarios the SRP acceptance criteria adopts the 100
17 millirem per year dose of Part 20 under Part 20.1301.

18 MEMBER RYAN: Jean-Claude, I think to
19 maybe just simplify it for some of the members if you
20 have a water source that's used indirectly for crop
21 irrigation or food crop irrigation for animals.

22 MEMBER CORRADINI: Right.

23 MEMBER RYAN: There's a possibility that
24 you could reconcentrate some of the radioactivity back
25 up a food chain back to human beings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Right.

2 MEMBER RYAN: So I think this is kind of
3 closing the loop on is there any possibility for
4 reconcentration pathways versus direct drinking
5 pathways.

6 MEMBER CORRADINI: And the reconcentration
7 pathways would use this dose limit.

8 MEMBER RYAN: Would you use the Appendix B
9 as the starting point for the effluent or some
10 calculated number and then a pathway analysis I guess
11 would be the appropriate tool with that
12 reconcentration.

13 MEMBER CORRADINI: A pathway analysis that
14 looks at this. Okay.

15 MEMBER RYAN: Does that help?

16 MEMBER CORRADINI: Yes. Got it. Thank
17 you.

18 MEMBER RYAN: Yes.

19 MR. DEHMEL: The pathway analysis now,
20 obviously this would have be to site-specific.

21 MEMBER RYAN: Sure. Of course.

22 MR. DEHMEL: So you can see that it
23 presents kind of different challenges, one for design
24 certification application as well as one for a COL
25 applicant with site-specific incident.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: And I think the whole
2 purpose in the ISG is to recognize that a
3 reconcentration pathway needs some attention as well
4 as a different pathway.

5 MEMBER CORRADINI: Sure.

6 MR. DEHMEL: Because right now you'll see
7 if you look at the guidance it's only buried in the
8 footnotes. We felt that it was important to elevate
9 this to an equal level.

10 MEMBER CORRADINI: Okay. Thank you.

11 MR. DEHMEL: So going over the regulatory
12 basis, these are the three major aspects. One thing
13 we should understand is that there's nothing in the
14 regulation right now that says that one shall evaluate
15 the radiological impact of a failed radwaste tank.
16 It's not contained in the regulations, only in the
17 regulatory guidance, namely Reg Guide 1.206 which is
18 the standard form, as I understand it, for the
19 preparation of COL applications FSARs as well the SRP
20 Section 11.2 and the Branch Technical Position 11-6.

21 The first four items identified on this
22 slide, namely Parts 52.79, 52.34(a), 50.36(a) and GDC
23 60 and 61, the focus there is on ensuring that there
24 is adequate equipment to treat and process located
25 waste as well as control releases, control and monitor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effluent releases under normal operation anticipated
2 operational occurrences. There is nothing in there
3 that actually addresses itself to a failure of a
4 radwaste tank.

5 Part 100.20(c)(3) addresses to the
6 hydrogeologic site characteristics and how this
7 information would be used in the context of the
8 analysis with respect to 2.4.12 and 2.4.13 where, for
9 example, site-specific information would have to be
10 used to assess the consequences in a site-specific
11 application while you can see for DCD the simplest
12 step approach may be used in making some very simple
13 assumptions without having to rely on a site-specific
14 information.

15 The regulatory guidance, again the focus
16 and this is what the focus of the ISGs, are to revise
17 and expand the guidance and eliminate some of the
18 clarifications. But I think the first two items that
19 we talk about is SRP 11.2 and BTP 11-6, SRP Section
20 2.4.12 and 2.4.13 on groundwater flow and transport.

21 Reg. Guide 1.143 addresses itself to
22 minimum requirement for the design features and
23 operation characteristics of the liquid waste
24 management system again for the purpose of treating,
25 storing and providing measures to release radioactive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 material in a controlled fashion. And Reg Guide 1.113
2 and NUREG/CR -3332 and NUREG/CR-6805 address
3 themselves to the radiological assessment of releases
4 as well as modeling and movement and the transport of
5 radioactivity in ground and surface water.

6 MEMBER BANERJEE: What's the vintage of
7 that NUREG-6805?

8 MR. DEHMEL: NUREG-3332; '83/'84,
9 something, mid-80s, something like this.

10 MEMBER BANERJEE: And the dispersion
11 modeling is about the same?

12 MR. DEHMEL: No, 6805 is a more recent. I
13 think it's 2004. I think we have it somewhere in a
14 prior presentation.

15 MEMBER BANERJEE: 6805 is 2004.

16 MR. DEHMEL: I think it's more recent.

17 MEMBER BANERJEE: 3332 is --

18 MR. AHN: That describes how we develop
19 the conceptual site model and how we apply the ground
20 or transport process on the consequence analysis. So
21 it's quite general but not specific to this chapter,
22 FSAR chapter 2.4.12 and 2.4.13. That's why we
23 developed some kind of model on this area.

24 MEMBER BANERJEE: So the conceptual site
25 model takes into account dispersion calculations and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things.

2 MR. AHN: No. When we usually say
3 groundwater modeling, we have a two-step approach. We
4 use two-step approach. First, we need to develop the
5 conceptual site model. Then if we need it, we need to
6 analyze the transport process using either the
7 analytical equation or numerical equation.

8 So what is the conceptual site model? The
9 conceptual site model is just the qualitative
10 description of the futures of the hydrogeology or
11 groundwater flow and transport processes. So it's a
12 quite simplified conceptual process of how groundwater
13 flow and how transport occurred from the groundwater.
14 That's the conceptual site model.

15 MEMBER BANERJEE: So that must be in some
16 way related to the onsite hydrogeological
17 characterization, right?

18 MR. AHN: True. Yes.

19 MEMBER BANERJEE: So does that require
20 that you do some sort of exploratory experiments to
21 look at transport using tracers or something?

22 MR. AHN: Yes. When we analyze
23 radiological consequence in groundwater, it's really a
24 complicated process involved in a lot of different
25 physical processes in groundwater. And do we need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that at the beginning? It'd depending on the site
2 situation. So what we proposed on our guidance is
3 that at the beginning first us a simple, very
4 conservative bounding approach to check the Part 20
5 compliance. And if the site doesn't meet that
6 compliance, we made other more progressive detailed
7 model to validate the groundwater.

8 MEMBER RYAN: I would just like to add a
9 couple sentences. It might help Sanjoy. It was
10 published in 2003.

11 MEMBER BANERJEE: Right.

12 MEMBER RYAN: I'll give you three
13 sentences of the abstract. The report describes the
14 strategy that embodies a systematic, comprehensive
15 approach to hydrogeologic conceptualization model
16 development and predictive uncertainty analysis. The
17 strategy is comprehensive in that it considers all
18 stages of the model building and accounts jointly for
19 uncertainties that arise at each of them. So I think
20 it's intended to be a pretty comprehensive modeling
21 exercise with uncertainty analysis.

22 Dr. Nicholson is here who authored it. So
23 if you have any detailed questions --

24 MR. AHN: My understanding is that that
25 guidance it may be applicable to the unit where there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 may be some actual contamination happened. But in
2 this case ESP and COL we don't have any actual
3 contamination. So we just use high conceptual and
4 simply approach for them. If site does not meet, then
5 we made other more detailed methods. That's the basic
6 idea about that.

7 MEMBER BANERJEE: You'll be going into
8 this in detail in your second part, right?

9 MR. AHN: I expect that we will be going
10 into this.

11 MEMBER BANERJEE: So we can hold the
12 questions. But I'd be quite interested to understand
13 how you take into account, say, the ion exchange
14 capability of soil because this has always been a very
15 difficult problem you get.

16 MR. AHN: That's true. We'll discuss
17 that.

18 MEMBER BANERJEE: Okay.

19 MR. DEHMEL: For the record, just to
20 clarify what I said earlier, the NUREG CR 3332 was
21 published in September of 1983 and NUREG CR 6805 was
22 in July of 2003 just to make sure that's correct.

23 VICE CHAIR ARMIJO: I'd have to ask just a
24 quick question. You talk about this reconcentration
25 mechanism through the food chain. What is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concentration -- Let's say you've contaminated the
2 groundwater. A big tank leaks. The radwaste tanks
3 leaks. Somehow that liquid goes through the soil,
4 eventually gets into the groundwater. Depending on
5 time and other things, it gets diluted. How do you
6 get the starting point, starting concentrations, of
7 radionuclides to start the reconcentration step?

8 MR. DEHMEL: The start of the radioactive
9 inventory is basically the applicant has to make a
10 case that (1) the system has been properly selected
11 for the purpose of this analyzed tank, the tank
12 inventory, the nature of the radioactivity. In other
13 words, where does the process fluid that essentially
14 ends up in that tank comes from and what are the
15 characteristics of the radionuclide concentration or
16 radionuclide distribution that are expected or that
17 are assumed for the analysis. That is the starting
18 point.

19 Then we actually look at whether or not
20 those concentrations, those radionuclides
21 distributions, are adequate or make sense with respect
22 to what's expected of the plant.

23 VICE CHAIR ARMIJO: I guess I was just
24 following on Dr. Banerjee's question in that you fail
25 a tank. A lot of stuff comes out. It goes through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the soil. Some of it's trapped. Ion exchange and
2 other mechanisms. If some eventually reaches the
3 groundwater depending on time and other things,
4 there's a dilution effect.

5 MR. DEHMEL: Yes.

6 VICE CHAIR ARMIJO: Eventually some of
7 that gets into an irrigation system. Cows start
8 eating it and you try and determine if you're meeting
9 your --

10 MR. DEHMEL: Acceptance criteria.

11 VICE CHAIR ARMIJO: Yes, your acceptance
12 criteria. I'm just wondering how do you treat that.
13 Is it really that mechanistic? Do you really go
14 through all those steps? Or do you take some really
15 bounding --

16 MR. DEHMEL: Yes. Basically and --

17 MR. AHN: I'll explain that process
18 briefly. In conceptual site model, we should describe
19 the transport process through unsaturated -- then
20 saturated -- flow. However, when we make the simple
21 bounding analysis, we just assume that the ruptured
22 tank volume content will instantly reach to the
23 groundwater table that it transports. So when we --

24 VICE CHAIR ARMIJO: You don't allow for
25 dilution then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. AHN: We consider the dilution, yes.

2 VICE CHAIR ARMIJO: Okay. But you don't -
3 - But pretty much instantaneously that water without
4 trapping by soil --

5 MR. AHN: On -- we assume that this
6 instantly go to the groundwater. Then we just assume
7 and analyze the transport in the groundwater flow.
8 That's what we normally use.

9 VICE CHAIR ARMIJO: Okay.

10 MR. DEHMEL: Yes. The dilution indicator
11 and retardation are essentially taking into account.

12 VICE CHAIR ARMIJO: But it all gets to the
13 groundwater.

14 MR. DEHMEL: Yes. The assumption is that
15 we don't take credit for any kind of filtration that
16 may occur in a building so to speak. In other words,
17 there is an inventory X amount of gallons, X
18 concentration, for these specific radionuclides.
19 That's assumed to instantaneously find its way into
20 groundwater.

21 VICE CHAIR ARMIJO: Okay.

22 MR. DEHMEL: From that point on, it's
23 modeled with respect to dilution, dispersion,
24 retardation, that may actually occur in groundwater
25 too and what happens in the environment. For example,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if it goes on to -- If it's crop irrigation and so
2 on, the time it takes from the crop to grow to the
3 time the crop is processed to the time it's eaten and
4 so on. All of these points are taken into
5 consideration to the model.

6 MEMBER RYAN: East of the Mississippi,
7 Sam, that's not a bad assumption because time in the
8 vadose zone is relatively short east of the
9 Mississippi. If you get out west where you have
10 really big unsaturated zones, then maybe you might
11 want to think a little bit differently about it.

12 VICE CHAIR ARMIJO: Okay. But I just
13 wanted to know. It's very, very quick. Instantaneous.

14 MEMBER RYAN: Yes.

15 VICE CHAIR ARMIJO: Take that volume of
16 water and you put it into the groundwater.

17 MEMBER RYAN: Yes.

18 VICE CHAIR ARMIJO: Okay.

19 MEMBER BANERJEE: But you take ion
20 exchange into account, right?

21 MEMBER RYAN: Yes. And then all the
22 processes. What I heard them say, once it gets to the
23 saturated zone, all the processes are accounted.

24 MR. DEHMEL: Including retardation which
25 essentially is one component of ion exchange.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: But the problem that --

2 MEMBER SIEBER: It's a filtration type
3 delay. And the other one is ion exchange in
4 carbonated trash that may exist.

5 MEMBER BANERJEE: The difficulty that I
6 have with this is as you know you get a front moving,
7 the breakthrough waves that come with the ion exchange
8 process. How do you take that into account? Because
9 in an ion exchange column, this is a major problem to
10 predict this. Now if you know how to do this for
11 groundwater and we can't do it in an ion exchange
12 column, it's sort of an interesting --

13 MEMBER CORRADINI: He's looking for help.

14 MEMBER BANERJEE: Yes. How do you do it?

15 MR. AHN: That part technically is
16 possible. But practically where are most of the
17 traveling occurred? That's the way the vadose zone
18 but it's actually the saturated zone. So when we use
19 kind of a bounding conservative analysis, we just
20 assumed that the ruptured containment directly go to
21 the groundwater.

22 In reality, there are a lot of different
23 layers of transportation on vadose zone. First, after
24 tank was ruptured, it should penetrate the base mat of
25 the tank. That's one six feet of concrete. And after

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, we have like three or four feet of the
2 foundation layer. So we should realize the actual
3 transportation process through that and through the
4 vadose zone. But when we make the conservative
5 bounding analysis we found that everything make a big
6 hole and the containment directly with the water
7 table. Then that's the starting point of our
8 analysis.

9 MEMBER BANERJEE: Okay. That clarifies
10 certainly the early stage of this. The later stage,
11 the potential that you can get a concentration wave
12 move through the system because of that.

13 MR. AHN: That's what we considered.

14 MEMBER BANERJEE: Yes. And that could
15 actually give rise to a period where you have a fairly
16 high concentration which is coming up because of the
17 concentration wave.

18 MR. AHN: Yes, that's what we compared and
19 --

20 MEMBER BANERJEE: Yes. That's what I'm
21 asking for help. How do you do that because it seems
22 rather hard to do.

23 MR. AHN: Yes. There are several
24 different ways we can handle that issue. We can use
25 the simple analytical equation to estimate the front

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 movement or we can use detailed numerical model to
2 estimate that process. But most of the case during
3 the planning stage we don't use a transport modeling.

4 But we use just simple analytical equation to
5 estimate the transport process.

6 MEMBER BANERJEE: Then you need some
7 exchange parameters in there, right?

8 MR. AHN: Yes.

9 MEMBER BANERJEE: And you measured those
10 for that site or how do you do that?

11 MR. AHN: No. We just assumed the
12 exchange rate and --

13 MEMBER SIEBER: Prototype.

14 MR. AHN: Yes. For transport parameters
15 some of them we make instant measurement. But some we
16 use just a bounding barrier and check the Part 20
17 compliance and if the site meets Part 20 compliance
18 then we say that --

19 MEMBER BANERJEE: You have some parameters
20 for bentonite or whatever.

21 MR. AHN: Oh, yes. For material we should
22 have that parameter.

23 MEMBER BANERJEE: So you've got that.

24 MR. AHN: Yes.

25 MEMBER RYAN: Sanjoy, the other part from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the radiological prospective is probably ten or less
2 radionuclides that are dosimetrically significant and
3 mobile.

4 MEMBER BANERJEE: Right.

5 MEMBER RYAN: So the playing field of what
6 you really have to focus on is fairly narrow and
7 focuses on relatively mobile radionuclides.

8 MEMBER SIEBER: Right.

9 MEMBER RYAN: That are dosimetrically
10 significant that will drive the --

11 MEMBER BANERJEE: What are these ten or
12 give a couple anyway.

13 MEMBER RYAN: Cesium-137, strontium-90.

14 MEMBER BANERJEE: Okay.

15 MEMBER RYAN: You know those are two.

16 MEMBER POWERS: But don't you usually get
17 into troubles with those that are polyvariant and can
18 become colloidal.

19 MEMBER RYAN: Maybe Dr. Nicholson could
20 because he's studied this.

21 DR. NICHOLSON: Yes. My name is Tom
22 Nicholson. I'm with the Office of Research. To
23 answer your question, sir, that's part of the
24 characterization process to understand the
25 hydrogeologic units and the metals that are there and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how they interact. And the property you're looking
2 for is called a retardation factor. So the
3 retardation factor you could develop those on a site-
4 specific basis if you choose to and that's why you
5 often will collect core samples, go back to the lab
6 and then by looking at the chemical nature.

7 And the other gentleman was mentioning
8 colloidal transport. You think of those transport
9 processes for that specific site. So you look at the
10 question of whether it's a fractured rock, whether
11 it's a porous media, the metal that's contained. All
12 of that is part of the characterization process. And
13 that's all described in NUREG/CR 6805. You're looking
14 at alternative conceptual models of how complex or how
15 simple you want to represent the transport mechanisms
16 and you relate it to the chemicals, in this case
17 radionuclides that are moving through those
18 hydrogeologic units.

19 MR. DEHMEL: For your information, in the
20 back of ISG-013 there's a list that we've included,
21 Attachment A that essentially provides a more specific
22 guidance on the kind of separated radionuclides that
23 should be considered as a minimum in the analysis.

24 MR. AHN: Presented by the --

25 MR. DEHMEL: Tritium is in there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Strontium-90, cesium-137, traditional cobalts, nickel-
2 63, iodine-129 and others.

3 MR. AHN: Other than that, we are adopted
4 kind of the hierarchical approach to determine which
5 transport parameter are critical on that site. Then
6 based on that information we made a onsite transport
7 parameter. That has to get our onsite measurement
8 process. It's all depending on site-specific.

9 MEMBER BANERJEE: So that's under this 10
10 CFR 100 -- the characterization of the site. You
11 measured some of these parameters.

12 MEMBER SIEBER: Yes, hydrogeologic.

13 MR. AHN: Yes.

14 DR. NICHOLSON: Yes.

15 MR. DEHMEL: Okay. And then as a matter
16 of clarification just to make sure that it is
17 understood because we have gotten some comments as to
18 what was meant by the SRP acceptance criteria. The
19 SRP acceptance criteria really used as a measure, as a
20 gauge, to assess the acceptability of the radwaste
21 tank failure. It's not used for the purpose of
22 complying with the specific requirements of Part 20
23 either with the effluent concentration limits or for
24 person complying with the dose limit to 100 millirem
25 per year for members of the public.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So what the guidance has done is basically
2 look at kind of logical acceptance criteria and then
3 adopted those for the purpose of assessing the
4 consequence of a radwaste tank failure. So that's a
5 kind of important distinction.

6 With respect to this slide, this
7 identifies in essence the core elements of the
8 revision of the guidance and explains the
9 clarification with respect to ISG-013. So the focus
10 has been on or is on identifying and selecting the
11 proper type of tanks and identifying the failure
12 mechanisms such as simply an assumed failure of a tank
13 or as was mentioned earlier an operator error that
14 essentially causes the release of radioactive liquid
15 into a cubicle or into a room.

16 CHAIR ABDEL-KHALIK: Now, you indicated
17 earlier that you look at small tanks where you have
18 fairly high concentrations, large tanks where you have
19 reasonably diluted material. To me it would seem like
20 probably the worst case scenario is not one extreme or
21 the other. It's probably somewhere in between. How
22 do you determine that without analyzing everything?

23 MR. DEHMEL: Well, it depends. For
24 example, if you have a tank that's inside a building,
25 a radwaste tank, where you have high concentrations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of, say, 10,000, 20,000, 30,000 gallons of water, then
2 you can look at the other tanks that are in the liquid
3 waste management system or radwaste storage building
4 and actually identify based on the original material
5 that has been processed for the system and the end
6 point what are the radionuclides or what is the origin
7 of the source of radioactivity.

8 With respect to tanks that have -- So for
9 tanks that are in there, you're right in the sense
10 that that tank would be essentially the limiting tank
11 and there will be no other tank. Therefore other
12 tanks where you have large volume and low
13 concentration, in some instances you have tanks that
14 are located outdoors. And there the release mechanism
15 is not to a groundwater body, but to a surface water
16 body. So that's why we're expanding the guidance to
17 consider those two situations where now you have
18 different release mechanisms.

19 So you can see that the radionuclides for
20 a surface release to a surface water body you might
21 consider a broader suite of radionuclides than you
22 would for groundwater because for groundwater you
23 could essentially exclude radioactive decay to start
24 with, a significant number of radionuclides because
25 they simply won't make it to the outside dose receptor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 before an outdoor tank and a surface release pathway.

2 Then the suite of radionuclides would have to be by
3 definition a lot more comprehensive because there the
4 transfer mechanism is going to be fairly rapid and
5 taking credit for decay would be questionable in some
6 instances.

7 That's why we are essentially trying to
8 bucket those two extremes. So you could conceivably
9 look at for example a BWR site where you would have
10 two analyses, one for the condensate storage tank
11 outside and then another analysis for a radwaste tank
12 inside the radwaste building.

13 CHAIR ABDEL-KHALIK: Okay.

14 MR. AHN: On that issue, on ISG-014, we
15 describe that the determination of tank failure
16 sequences is critical. It's based on the consequence
17 at the receptor point. That's what was described on
18 our finding.

19 MR. DEHMEL: All right. And continuing
20 on, looking at the kind of credit that may be assumed
21 for passive and durable mitigating design feature, for
22 example, right now the guidance exclude the use of
23 coating essentially as being a design feature that one
24 might apply for mitigating the release of releases.
25 So the application of a steel liner built into a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cubicle or room to a height that would contain the
2 entire volume of a tank that's a credible design
3 feature that would be used for mitigating the impact.

4 The kind of assumptions and the level of
5 conservatism that may be applied in the analysis,
6 development of radioactive source by specific tanks,
7 radioactive transporting of ground or surface water,
8 the release pathways and offsite exposure scenarios,
9 again here for example differentiate the two between a
10 groundwater where you have or surface water where you
11 have direct consumption of water versus when you have
12 an indirect consumption of water. No drinking water
13 pathway where the water is used to irrigate crops,
14 pastures or water livestock.

15 And then the aspect of addressing and
16 setting up tanks specification of maximum
17 radioactivity concentration levels for a system or an
18 analysis either the tank or the site that fails to
19 comply with the SPR acceptance criteria.

20 And then finally the last one is for the
21 staff on how to prepare the specific language in the
22 SER based on the review of the analysis of the
23 applicant's information and how one would essentially
24 conclude that the analysis and the information
25 presented in the FSAR is acceptable for those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different case conditions.

2 And I'm going to pass it over to Hosung on
3 ISG-014.

4 MR. AHN: From this side, I will briefly
5 what kind of process we used in FSAR 2.4.12 and
6 2.4.13, radionuclide transport and consequence
7 analysis in there. And obviously the major objective
8 of this consequence analysis in 2.4.13 or even FSAR
9 11.2 is to check the Part 20 compliance and determine
10 whether the site is suitable in terms of the
11 radiological contamination or not. That's the major
12 objective of this analysis.

13 In general, we already discussed that
14 radiological groundwater transport process estimation
15 is quite complicated and need a lot of onsite data.
16 So most of the FSAR section describes very detailed on
17 this process and it needs a lot of time and effort in
18 preparing that FSAR and also for the step it takes a
19 lot of time and effort to review that FSAR and
20 determine the safety determination of the radioactive
21 contamination.

22 So we proposed this kind of structure the
23 hierarchical approach so that at the beginning we used
24 the very simple bounding calculation of radiological
25 contamination and the check Part 20 compliance. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if they meet they may start an analysis. Or if they
2 don't meet then we may adopt a more detailed and more
3 realistic transport mechanism and check the Part 20
4 compliance.

5 And at the end if they don't meet the Part
6 20 compliance what we can do. We can suggest a
7 technical specification to limit the tank volume or
8 tank -- or we can suggest the mitigation design
9 feature. So that's the kind of consequence analysis
10 process we are looking for.

11 MEMBER CORRADINI: So can I get back to
12 your -- So just from your logic standpoint of your
13 last box, you allow it to be no. Is it really never a
14 no? I mean it seems to me that since this is coming
15 in with a new application they're going to have to do
16 something. Whether they do a better calculation or a
17 better design modification so that it complies, is
18 that the essence of this?

19 MR. AHN: Yes, that's the essence. So
20 even before doing the consequence analysis we're
21 supposed to look at whether that proposed plant
22 mitigation design feature on radwaste system or not
23 and if they meet them then we skip that.

24 MEMBER CORRADINI: I understand. So just
25 from a standpoint of just good practice and operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants, are there analogues out there or benchmarks
2 of plants that are currently designed that meet all
3 this without going through the analysis so if I have a
4 series of design rules or design arrangements I'm
5 pretty well assured that I'm going to meet this? Do
6 you know what I'm asking?

7 MR. AHN: I think the units some of them
8 they already make this kind of analysis and they said
9 that the site is safe, plenty safe, on this. They
10 haven't similar approaches before.

11 MEMBER CORRADINI: Okay.

12 MR. DEHMEL: These requirements are not
13 new. They've been in for a while.

14 MEMBER CORRADINI: Right.

15 MR. DEHMEL: So all the plants that are
16 operating if you were to go to the FSARs you will find
17 the analysis either in chapter 11.2 or most likely in
18 15.7.3 where this was -- where these analyses were
19 initially required or situated in the guidance both in
20 Reg Guide 1.70 as well as in the SRP.

21 MEMBER CORRADINI: Maybe then I should ask
22 the question this way. Is the fact that you've added
23 an indirect pathway concern going to change anything
24 or are you just closing a potential loophole that
25 probably won't change how the design is done?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEHMEL: What we are doing with the
2 indirect pathways, the indirect pathway was always
3 identified in the guidance. But it did include the
4 level of detail, the level of -- the consideration in
5 structuring the analysis the way it has been done for
6 releases to groundwater. So what we're doing
7 essentially is providing additional guidance.

8 So if a plant had a situation where they
9 have an indirect exposure pathway at that particular
10 time that requirement is identified and flagged in the
11 SRP as well as in the guidance. And therefore they
12 had to address it. At that point, how this was
13 addressed was essentially depended upon what kind of
14 information was included in the application at the
15 time and the staff's evaluation of that for that
16 analysis submitted by the applicant.

17 MEMBER CORRADINI: It's not your
18 anticipation that this will change how a design is
19 done. This is essentially making sure that this
20 indirect pathway does not create an issue that may
21 have been missed. Do you see what I'm asking?

22 MR. DEHMEL: Well, I can't speak what has
23 been missed because you're asking would I have
24 reviewed all the prior applications and the answer is
25 no. I'm working on only new applications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: But in the subsets that
2 you have looked at.

3 MR. WIDMAYER: Dr. Corradini, I think what
4 would happen is that they adjust the tech spec on the
5 concentration in the tank. You would anticipate it
6 would change the design.

7 MEMBER CORRADINI: Okay.

8 MEMBER SIEBER: Either effect it or
9 regulate it.

10 MR. DEHMEL: And one option would be to
11 change the design.

12 MEMBER SHACK: People choose generally to
13 add mitigating features or to go to more sophisticated
14 calculations.

15 MEMBER CORRADINI: I bet I know.

16 MR. AHN: It could be both, yes. In terms
17 of --

18 MEMBER SIEBER: Red pencil lead.

19 MR. AHN: In terms of the groundwater
20 transport analysis first we identify what is the most
21 critical conceptual site model or pathway. That's
22 what we needed to identify then. We also need to
23 identify what would be the alternate possible pathway.
24 So in extreme case of pathway, it could be changed to
25 a different direction. So we look at all different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potentials on that and what would be the most critical
2 pathway and what would be the consequence of that
3 pathway. That's what we analyzed for that.

4 MEMBER CORRADINI: Okay. Thank you.

5 CHAIR ABDEL-KHALIK: That doesn't answer
6 Dr. Shack's question though.

7 MEMBER SHACK: But I know it.

8 MR. RAIONE: This is Richard Raione. I'm
9 the Chief of the Hydrologic Engineering Branch. In
10 terms of NRO there is on DCD ESBWR that presents
11 design mitigating features up front and real high tech
12 things such as double walls, spill prevention
13 countermeasures, plans, you know, berms that contain
14 100 percent the spill. And it would be advantageous
15 if perhaps in the other design centers the vendors
16 look at that type of up front environmental protection
17 to help mitigate anything happening with the
18 groundwater.

19 MEMBER SHACK: Okay. But the answer is
20 that not everybody has done that.

21 MR. RAIONE: That's correct. Only one
22 design center at this point and of course North Anna
23 the ESBWR is out. So at this point it's Fermi.

24 VICE CHAIR ARMIJO: Yes. It just seems
25 that that's something you can inspect, something you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can maintain, where these calculations could change
2 over time. Rules could change. Phenomena could be
3 discovered. And that would go through all of this
4 stuff all over again.

5 MR. DEHMEL: Well, if a design --

6 VICE CHAIR ARMIJO: I don't know what --
7 I'm talking practicality. You know, how would you
8 spend your money. Putting it into a mitigating design
9 feature or doing a lot of characterization and an
10 analysis and everything else that still may be subject
11 to challenge later on as you --

12 MR. DEHMEL: If I understand your
13 question, I think if you're talking about a change in
14 procedure or a change in a design that may occur and
15 be implemented after the application has been approved
16 when a plant is starting to operate, there are
17 procedures and requirements in the regulation that
18 forces at that point the operator, the licensee, to
19 actually look at whether or not those changes
20 introduce safety issues that essentially either need
21 to be revised or evaluated against a prior criteria
22 that were contained in the prior version of in this
23 case the final safety analysis evaluation report,
24 analysis report.

25 So there's a process by which if, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 example, the liquid waste management system is changed
2 and a new kind of tank is introduced or the driving of
3 the equipment or components is different, they would
4 have to go back and look at all the prior analysis
5 that supported the initial design and conclude that
6 the changes do not alter the prior conclusions and the
7 prior results of the analysis.

8 VICE CHAIR ARMIJO: No, I understand that.

9 MR. AHN: So let's jump to the next page.

10 CHAIR ABDEL-KHALIK: Yes.

11 MR. AHN: On ISG-014 it's quite extensive
12 getting into how we collect onsite data and how we
13 analyze the groundwater flow and transport. And we
14 can summarize that ISG scope in here. First, we
15 clarify the review area and the review interface in
16 SRP 2.4.12 and 2.4.13. We found while we are
17 reviewing ESB and the COL application that there are
18 some inconsistency between current SRP and RG 1.206
19 especially on the review area and interface. We
20 clarified that issue ISG-014.

21 Second, we reconciled the difference
22 between SRP 2.4.13 and SRP 11.2 and Branch Technical
23 Position 11-6, clarifying the conservatism in defining
24 a base hydrologic condition. That base hydrologic
25 condition means what is the gradient of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 groundwater we used in transport analysis, what kind
2 of flow rate we should use in surface water
3 contamination -- so we clarified that issue on the
4 ISG.

5 MEMBER BANERJEE: Is this done --
6 construction might change the groundwater pattern
7 somewhat, right?

8 MR. AHN: That's true and we analyzed --
9 we postulate what -- I mean we used the FSAR
10 construction information. But if they change the
11 construction from the license condition, they should
12 reanalyze this.

13 MEMBER BANERJEE: And is this only based
14 on analysis or is there something done post-
15 construction to verify that?

16 MR. AHN: Yes. When we simulate
17 groundwater flow and transport in the consequence
18 analysis we analyzed based on the future construction
19 and operation condition. So when we use the model, we
20 calibrated and verified the model on the current
21 condition. Then the prediction is purely future
22 condition --

23 MEMBER BANERJEE: And then it is verified
24 after the construction.

25 MR. AHN: There is no -- I don't think we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 verify it. We are talking only about the licensing
2 issue.

3 MEMBER BANERJEE: Right.

4 MR. AHN: So in the future if they change
5 the condition they should reanalyze this.

6 MEMBER BANERJEE: So you feel that your
7 model can take into -- So you've characterized the
8 site let's say. I'm trying to get the process clear
9 in my mind. You characterize the site before, let's
10 say, presubstantial construction. Now you have a
11 predictive model which takes into account the
12 effective construction which may or may not be
13 significant. I have no way to know. How do you know
14 at the end that your predictive model is right?

15 MR. AHN: It's based on model calibration
16 at the verification process.

17 MEMBER BANERJEE: Has there been then some
18 verification showing that these models are --

19 MR. AHN: I think it's critical -- It is
20 impossible because there was no previous history on
21 the tank rupture scenario.

22 MEMBER BANERJEE: I'm only talking about
23 groundwater for right now, not the --

24 MEMBER SHACK: He wants to inject some
25 tracers and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes.

2 MEMBER CORRADINI: He's looking for an
3 experiment.

4 MEMBER SHACK: You're pretty transparent.

5 MEMBER BANERJEE: I'm pretty transparent.

6 MEMBER SIEBER: We never did that.

7 MEMBER RYAN: I would say the tendency,
8 Sanjoy, just from my own experience is to use a
9 conservative assumption that kind of maximizes the
10 transport of the radionuclides of interest to some
11 point of interest and then the dose is assessed. And
12 if that dose is compliant the need for more detail and
13 experimentally driven modeling isn't necessary. If
14 there's a question that a conservative assumption
15 that's conservative but reasonable gets you to some
16 point where you're really concerned about the dose
17 then you kind of have to go back and revisit.

18 MEMBER BANERJEE: I was sort of looking at
19 the little cartoon in the previous slide I think.

20 MEMBER RYAN: Yes.

21 MEMBER BANERJEE: If you go back to that.
22 Then I see the more complex transported area with the
23 question mark. So that's what I want to know.

24 MEMBER SHACK: He has a big question mark.

25 MEMBER BANERJEE: Not a big. Small

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question mark.

2 MEMBER CORRADINI: Yes. Right.

3 MR. ROACH: This is Ed Roach. Again as
4 you move into the combined operating license scenario,
5 many of the applicants have committed to establishing
6 an operational program under the radiation protection
7 program addressing the groundwater protection program
8 and it's part of their licensing. It's in their FSAR.
9 It's NEI --

10 MEMBER BANERJEE: But that sounds better
11 to me.

12 MR. ROACH: NEI 08-08a and as part of that
13 operational program there is an activity or an area
14 where they have go back and evaluate their conceptual
15 site modeling impact of construction on that
16 conceptual site model that was developed as they
17 ascertained the groundwater situation. And as part of
18 that our intent at this point is to include that as
19 part of our inspections and operational programs will
20 need to go to the sites that are being --

21 MEMBER RYAN: Ed, correct me if I'm wrong.
22 But I think that program would tend to include things
23 like just simple water level measurements and where
24 are the flows, where are the directions and all that
25 kind of basic hydrologic behavior.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ROACH: That also is --

2 MEMBER RYAN: You know, on which you can
3 then superimpose a transport model.

4 MEMBER SIEBER: You limit the amount that
5 you can store in the tank and you start processing it
6 where there are levels of concentration.

7 MEMBER RYAN: Yes.

8 MEMBER SIEBER: There's all kinds of steps
9 that you could take.

10 MEMBER RYAN: One thing to keep in mind
11 which I'm sure you realize is this is a very large
12 construction. So when you begin to take the step out
13 and rebuild it again you are going to change whatever
14 you've found at the beginning.

15 MEMBER SIEBER: That's where we used to
16 call it pencil-pushing. But more sophisticated
17 analytical techniques type device.

18 MR. AHN: So one clarification of the
19 limitation of this ISG-014 is that it's covered only
20 at the planning stage and for the operating it should
21 have used different strategy.

22 So, first, we specified that we should
23 give credit for the mitigation if the applicant has
24 already mitigative design features so that it can skip
25 the radwaste contaminant consequence analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And the next one we proposed practical
2 guidance to meet the requirement of onsite
3 hydrogeology measurements specified in 10 CFR Part
4 100.20. Part 100.20 is very broad and it just
5 requires in it onsite hydrogeology characterization to
6 analyze the radiological consequence analysis.
7 However it doesn't specify any of the extent of the
8 measurement or frequency of the sampling. So we tried
9 to clarify that kind of issue in ISG-014.

10 The next one is the --

11 CHAIR ABDEL-KHALIK: So what have people
12 been doing prior to this point, prior to this
13 practical guidance?

14 MR. AHN: This guidance will apply only
15 the COL or ESP after this was offered. So previously
16 we analyzed -- I mean we reviewed case by case. But
17 it's quite similar of which we used.

18 CHAIR ABDEL-KHALIK: I'm trying to get to
19 the point of where does this practical guidance come
20 from?

21 MR. AHN: It's based on our experience of
22 reviewing ESP and the COL. And some of the ESP or COL
23 application, they already follow this direction. And
24 some may not. So for example on one COL site we issue
25 almost RAIs on hydrogeology area, but almost 60

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 percent of those RAIs come from this FSAR 2.4.12 and
2 2.4.13 groundwater area. So what our intention is we
3 need some kind of a clear guidance on this onsite
4 measurement. That's what we addressed.

5 MEMBER RYAN: Said, excuse me, the sites
6 that have an existing reactor or two are obviously
7 going to be better schooled than sites that are
8 starting with a new clean site. So I think you'll see
9 a wide range of people who are better prepared to add
10 a unit than start with new units in terms of this
11 geohydrologic question. So it's probably a wide range
12 of sophistication in how they're addressing this
13 question at this point.

14 VICE CHAIR ARMIJO: But operating plants
15 by and large do all of this stuff already or most of
16 it.

17 MEMBER RYAN: Well, it gets you to one
18 level or another but across the --

19 VICE CHAIR ARMIJO: Is the answer no or
20 yes?

21 MEMBER RYAN: -- tritium questions that
22 have occurred over the last few years have gotten
23 people awake to these kinds of issues. That's for
24 sure.

25 MR. DEHMEL: All plants that are operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have had to address the existing requirements, not
2 what's in ISG-013 or 014, the existing requirement.

3 MEMBER RYAN: Yes.

4 MR. DEHMEL: In Reg Guide 1.70 as well as
5 the SRP as it was structured then in the applications.

6 New plants, new applications have also had to address
7 this requirement, these requirements, under the
8 current guidance. Plants that will be submitting
9 application after ISG-013 and 014 are finalized and
10 formalized will have to meet the new requirement. So
11 there are some existing requirements and some guidance
12 as we're discussing in here where in a way we're kind
13 of addressing a delta.

14 It's not we're starting from scratch.
15 Right? I mean keep that in mind. We're not
16 essentially starting from scratch with no guidance
17 whatsoever. What we're trying to do is we recognize
18 the existing guidance as -- It's not clear. It's not
19 complete in some instances. It used to be elaborated
20 upon. But it's for the purpose of knowing what the
21 applicant needs to do and also for the staff to review
22 the obligations and actually come up with the right
23 conclusions in the SERs.

24 MEMBER SHACK: Are there any new
25 requirements here or did you just do it all before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through RAIs?

2 MR. AHN: Yes, I think that's --

3 MR. DEHMEL: That's right. We've done a
4 lot of stuff to RAIs. But the challenge for the staff
5 is that when we initiate an RAI the immediate response
6 from the applicant is well, I don't see this in the
7 SRP. I don't see this in the reg guide. So that's
8 why there's a need to expand the guidance so it's
9 clear. Everybody understands that we've expanded on
10 the guidance and we've expanded on what the
11 interpretation of the guidance means and how it's
12 going to be concluded in a safety evaluation report.
13 That's the purpose.

14 MR. AHN: Actually, that question is
15 similar to what NEI or industry asked, commented, on.

16 MEMBER SHACK: I'm sure they did.

17 MR. AHN: This is not -- There is no new
18 requirement. But most of this ISG just clarification
19 or reconcile of the existing guidance. That's what I
20 can say.

21 MR. RAIONE: This is Richard Raione.
22 Another thing to answer your question is it was kind
23 of interesting. But when an applicant provides the
24 conceptual site model you want your plausible
25 groundwater pathways to be consistent with that. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you don't want to pick a receptor point for instance
2 that's up gradient. In one case we actually had that
3 provided to us and the applicant because hey, look at
4 that short distance. We're trying to be conservative.

5 But you still need to reflect current and
6 predicted conditions. So one thing the guidance does
7 I think is provide a lot more information on how
8 important the conceptual site model is, what are your
9 release scenarios in the future?

10 And if you've got a quarry adjacent to
11 your site and it's pumping, what if that quarry quits
12 pumping? What does that do to the groundwater flow
13 directions, etc.? So that part I think will be quite
14 useful because we were getting too many discrepancies
15 and nothing -- it was just well intentioned but there
16 were -- If you've got a primary groundwater flow to
17 the east, why would you model the exposure to the
18 west? It wasn't consistent. So this will help.

19 MR. AHN: Let's keep on going. The next
20 item is we provide guidance in developing the
21 conceptual site model and the groundwater flow models.

22 Especially for groundwater flow model, it's not a
23 requirement. But the onsite hydrogeology is
24 completed. The groundwater model is the only way to
25 predict future condition after construction. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sometimes applicant needs to develop groundwater flow
2 model. But that's quite expensive and time consuming
3 and a lot of activity needed.

4 So what is the approach stopping of this
5 modeling and analysis? That could be one of the
6 critical issues in 2.4.12 and 2.4.13. That's why we
7 developed that kind of guidance in here.

8 MEMBER BANERJEE: And you have some
9 standard approved models that you would accept an
10 applicant using properly of course.

11 MR. AHN: In fact, there are a lot of
12 industry guidance or --

13 MEMBER BANERJEE: You have specific
14 approved models.

15 MR. AHN: We have specific for these
16 2.4.12 and 2.4.13. That's why we developed this.

17 MEMBER CORRADINI: I didn't understand the
18 answer to his question. Can you repeat?

19 MEMBER RYAN: Hosung, I think Sanjoy is
20 asking what specific modeling tool do you recommend.
21 Do you recommend any specific?

22 MEMBER BANERJEE: Or have approved.

23 MEMBER RYAN: Or have approved. They
24 haven't backed up Mod flow/mod path. You can use what
25 you want, but you have to meet the thinking in 6805.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. AHN: In general, most case they use
2 the Mod flow/mod path with some simple model. But in
3 our guidance we do not specify which model the
4 applicant should use or which one is accepted. We
5 just use generally described what kind of calibration
6 criteria is acceptable or how they modify. We
7 generally described that.

8 MEMBER BANERJEE: So you have sort of
9 specified the criteria for acceptability.

10 MR. AHN: True. Yes.

11 MEMBER BANERJEE: But there are -- I guess
12 this is a little different from other things. But the
13 applicants don't submit to you models which you then
14 review and --

15 VICE CHAIR ARMIJO: Licensing topical
16 reports.

17 MEMBER BANERJEE: Yes, there are no
18 topicals.

19 MEMBER CORRADINI: That's what I was
20 waiting for.

21 MEMBER RYAN: Just to pick on 6805 a
22 little bit, there is a chapter Mathematical
23 Conceptualization and Quantitative Exploration of
24 Hypothesis. So I think the structure of how to do the
25 assessment is certainly laid out in 6805. But the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specific calculational -- was not.

2 MEMBER BANERJEE: So is the acceptability
3 criteria laid out more or less?

4 MEMBER RYAN: Yes, I think it is.

5 MEMBER BANERJEE: Yes.

6 MEMBER RYAN: Is that a fair assessment?

7 DR. NICHOLSON: This is Tom Nicholson,
8 Office of Research. 6805 goes to the process of how
9 you first develop a unique site conception model.
10 Okay. That describes the hydrogeology in detail and
11 also asks for alternatives. And then once you have
12 the conceptual model defined and its suite of
13 alternatives then you ask the question what numerical
14 code or analytic solution would best represent the
15 conceptual model and alternatives that I have
16 formulated.

17 Now these generally are available. The
18 U.S. Geological Survey has developed models and other
19 groups. You choose that model and here's the tough
20 part. The parameter estimation. You have to have
21 site-specific values to put into those models. Then
22 the question is how do I make sure that that numerical
23 model or analytic model is appropriate. That's when
24 you get into your calibration of the model against
25 measurements. Monitoring is extremely crucial. What

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are the water levels? How does groundwater recharge
2 affect that site? Are there perch water systems? A
3 variety of questions that are unique to that site.

4 MEMBER CORRADINI: And that requires them
5 to have monitoring ahead of time I assume.

6 DR. NICHOLSON: Yes.

7 MEMBER CORRADINI: So that I guess is
8 going to go to one of your dashes down there that
9 there's I'll call it tunable parameters that are going
10 to have to be site-determined.

11 DR. NICHOLSON: Right. And so you go
12 through this and each site is different and so
13 therefore you cannot use a so-called list of
14 acceptable. You go through this process because you
15 want to make sure that your models reflect as best as
16 possible those site-specific features. And you're
17 correct. You do it prior to construction and then
18 what you would anticipate following construction. And
19 that's why these monitoring programs are so crucial.

20 MEMBER BANERJEE: And these is post-
21 construction monitoring.

22 MEMBER SIEBER: Yes.

23 DR. NICHOLSON: Yes.

24 MR. AHN: So, as Dr. Nicholson said,
25 everything is depending on the onsite condition and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how we determine the acceptability of the consequence
2 analysis and modeling is really depending on meeting
3 Part 20 compliance or not for this particular case.

4 And last one, as I described in previous
5 slide, we recommend a hierarchical approach for
6 consequence analysis or determining the specifics for
7 transport parameter sampling or groundwater modeling.

8 So that's what we proposed on ISG. Next.

9 And the final resolution, we already got
10 comment from industry through NEI and their comments
11 are quite extensive but it's quite constructive. So
12 once we go through -- After this HRS and if we have
13 some comment, we will finalize our ISG-013 and -014
14 based on those comments. We all update our SRP
15 section 2.4.12 and 2.4.13 and 11.2 based on this ISG
16 in the future.

17 And the current -- this ISG, the base
18 guidance will be applicable to all COL and ESP license
19 applications submitted after the issuance of this
20 guidance. So that's all I need to tell you. Are
21 there any questions?

22 CHAIR ABDEL-KHALIK: The site-specific
23 parameters that were referred to earlier are these
24 time-invariant over a 40 year period?

25 MR. AHN: There are two different source -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 - two different kind of data. One is the static
2 hydrogeologic data including the hydrogeologic
3 transport parameter or flow parameter. That's the
4 static data and we collect that data.

5 The other part is the transient data like
6 what would be the water level and the gradient of the
7 groundwater flow and that will impact on the transport
8 process. So we should have -- We should collect data
9 on that. Then how we credit it in the future is based
10 on either modeling or based on the variance of the
11 data. We can predict the future condition. That's
12 what it normally is.

13 MEMBER RYAN: I think to me the point that
14 you're asking is that the construction will impact the
15 hydrogeology.

16 MEMBER SIEBER: At the surface.

17 MEMBER RYAN: At the surface. And the
18 near surface.

19 MR. AHN: Yes.

20 MEMBER RYAN: I mean maybe the top 40 or
21 50 feet. Who knows? I mean some reconstructions are
22 going on right now of base soils and so on.

23 MR. AHN: Yes.

24 MEMBER RYAN: So local to the plant itself
25 you'll see a change. But as you go to, say, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 property boundary and then beyond I view that you're
2 adding an infinitely dilute radionuclide load into an
3 existing view of hydrological systems. So the trick
4 is how you get the near site hydrology to match up to
5 a more not really regional but more far-afield
6 geohydrology for the adjacent areas to the site. Does
7 that help your question?

8 CHAIR ABDEL-KHALIK: I understand, but if
9 you go down to the transport processes themselves, the
10 governing transport parameters, are these time-
11 invariant?

12 VICE CHAIR ARMIJO: The geology is
13 invariant.

14 MEMBER RYAN: I would say yes. In the
15 further away field, the answer is yes.

16 MR. AHN: One critical transport parameter
17 we recorded is distribution coefficient or the so-
18 called K value. That's depending on the pH of the
19 contaminant or temperature or different geochemical
20 property. And sometimes it may be time dependent or
21 depending on the contamination. So how we analyze
22 that during the planning situation, we used a very
23 conservative parameter of this based on measured data
24 as well as the radiation values and we used the
25 conservative bounding analysis to check the Part 20

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 compliance.

2 And you mentioned how we incorporate the -
3 - frame the structure on groundwater contamination.
4 We use groundwater modeling approach to predict that
5 future impact. For example, for some sites, they
6 proposed the retaining wall around the plant so that
7 they can prevent the groundwater flow or seepage. We
8 analyzed that situation through groundwater modeling.
9 So we account that.

10 MR. DEHMEL: One point that we mentioned
11 earlier and that essentially I think we ought to bring
12 up now in light of the design questioning which I
13 think is important and relevant. But remember that
14 this is an analysis at one point in time.

15 CHAIR ABDEL-KHALIK: In time.

16 MR. DEHMEL: Right. So we recognize that.
17 But if you look at the SRP 2.4.12, 2.4.13, to some
18 extent BTP 11-6, there's a focus on the level of
19 conservatism, the nature and the assumptions that are
20 there to essentially capture these uncertainties.

21 And, for example, let me read to you some
22 of the verbiage that currently used in 2.4.13 that
23 would essentially be used to capture these
24 uncertainties. For example, it says, conservative
25 assumptions such as the most adverse contamination,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 extreme event or the most severe natural phenomenon.

2 So we're trying to essentially provide
3 guidance to ourselves and the applicant trying to say,
4 what do we mean by this and to what extent can we
5 apply these kind of extreme conservative assumptions
6 in trying to capture these uncertainties that we just
7 can't -- that we just don't know at this point?

8 And so there is some value in applying
9 some conservative assumption. The question is to what
10 degree, to what extent, do we carry this to an extreme
11 which no longer makes sense. So I think that the
12 points that you are raising are obviously very valid.

13 But we understand them and the idea was put our arms,
14 a bracket, around this and trying to say, okay, yes,
15 we have to instill some degree of conservatism of the
16 analysis and here is the envelope, so to speak, of
17 what would be considered acceptable. But anything
18 above and beyond that is not credible or essentially
19 sets up for a failure, automatic failure. You can
20 never demonstrate compliance with the acceptance
21 criteria.

22 So although we do understand some of the
23 information presented in the application in 2.4.12 and
24 2.4.13, that is the information the applicant
25 provides. That by definition is not a complete and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concise history of the hydrogeological characteristics
2 and future hydrogeological characteristics of the
3 site.

4 So in trying to, essentially, bracket
5 this, we require the applicant to apply some degree of
6 conservatism. The question is what should be the
7 envelope for that.

8 CHAIR ABDEL-KHALIK: I'm trying to get to
9 the point whether future monitoring would allow you
10 to determine whether or not you indeed were
11 conservative in the very beginning and how would you
12 go about doing that?

13 DR. NICHOLSON: That's a very good point
14 and the question is you're basically asking the
15 question how valid are the models that you're making
16 that you're making future predictions on. And so
17 therefore the monitoring becomes extremely important.

18 There are three things that the OECD/NEA
19 has talked about, features, events and processes. So
20 the question is when you did your characterization and
21 your modeling did you adequately represent those
22 features, events and processes. You brought earlier
23 the time-dependent and independent. That's why we ask
24 for its seasonal understanding of flow because
25 obviously during different times of the year you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different groundwater flow conditions.

2 The relationship between groundwater and
3 surface water is also extremely important. And when
4 you construct a site, you often will make changes.
5 You often will lower the groundwater table that was
6 much higher prior to construction. That has to be
7 brought into the modeling and then you have to say,
8 yes, in fact if you put in slurry walls or whatever
9 the design feature that may make a permanent change to
10 the -- and the flow conditions and that's why
11 monitoring is so important to understand those, as Dr.
12 Ryan says, the site-specific nature of the groundwater
13 in comparison to the more regional setting.

14 And we get information from a variety of
15 sources. The USGS provides very good information to
16 us when we ask what is the regional setting. And then
17 the site-specific obviously that's the licensee's
18 responsibility.

19 CHAIR ABDEL-KHALIK: Thank you.

20 MEMBER BANERJEE: But I guess if I
21 understood the point, let's say things like the pH and
22 so on change over a period of time. So it's not just
23 the groundwater flows. But the KV values and so on,
24 these will change as well. And clearly you are trying
25 to bound this in some way in your initial analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So you probably tried to take the worst cases and see
2 what happens and do some sensitivity analysis. But
3 what I think Said was asking is there in the
4 monitoring program something which would allow you to
5 validate this as time goes on.

6 DR. NICHOLSON: Yes. Water quality is a
7 big part of groundwater monitoring. For instance,
8 I've been involved with the Indian Point facility up
9 there when they had releases of strontium-90 and
10 tritium. It was extremely important that the water
11 quality reflect not just water levels, the pressure
12 transducers, but also dissolved oxygen, pH,
13 temperature, all those major ions and cations and to
14 understand. And then what is the possibility that
15 they may change depending upon changes to the
16 groundwater flow conditions. And so, yes, that is
17 part of the monitoring program.

18 MR. AHN: I have one comment on
19 monitoring. At the early stage of developing this
20 guidance, we consult with our OGC on whether we should
21 include that kind of a groundwater monitoring in this
22 guidance or not and they said, well, if they meet the
23 Part 20 compliance that requirement may not meet it in
24 here. But that is already addressed on NEI 08-08
25 requirement. So that's that part.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in practicality we have been reviewing
2 four years P and 15 COL applications so far. We're
3 still reviewing COL applications.

4 Are there any sites that does not meet
5 Part 20 compliance. There is one site. Bellefonte is
6 some special case. But all other sites they meet Part
7 20 compliance at the receptor point. So we believe
8 that the contamination in groundwater from the
9 accident scenario may not critical. But still we need
10 to define -- we need to characterize the onsite
11 hydrogeology. So that's what we're addressing.

12 MEMBER BANERJEE: Going back to this
13 point, I think we go back to even my original question
14 about the computation and numerical methods and
15 models. If I understand with Bellefonte there was a
16 model used initially anyway to do the calculations and
17 NRC had some staff with some disagreement with it and
18 so on.

19 And how does your guidance now preclude
20 that happening? Are you giving some guidance which
21 will --

22 MR. AHN: I don't know the detail on the
23 Bellefonte site issues. So I cannot comment on that.

24 But I think --

25 MEMBER BANERJEE: Something was used which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was not acceptable in some way. That's the impression
2 I had, though we were not told the details. And maybe
3 Mike knows this in more detail.

4 MR. RAIONE: This is Richard Raione. The
5 Bellafonte review for Section 2.4 hasn't started yet
6 because we had a QA audit. We had to remove the NOVs.

7 That review hasn't been scheduled yet. So I guess
8 it's coming down in the near future.

9 From recollection here, the primary topic
10 of interest with Bellefonte was their PMF. It's a
11 large resource system. I forgot now. Forty-two dams,
12 etc. To clarify on potential for 2.4.13 topics with
13 Bellefonte, we don't have enough information to
14 perform the analysis. The potential here would be
15 though that some of the domestic wells offsite to
16 Bellefonte theoretically could be impacts. So we're
17 going to have to look at that very closely.

18 Most of these sites as you know are large
19 acreage sites. These tanks are located ten feet from
20 the property boundary. That affords some natural
21 barrier as it were. Bellefonte will have to be looked
22 at very closely.

23 The reason this guidance, to answer your
24 question I think better, will help fine-tune
25 Bellefonte's internal analysis. I had mentioned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 earlier there was some confusion with some of these
2 applications in terms of what's really required. How
3 is the conceptual site model consistent in terms of
4 looking at plausible groundwater pathways where it can
5 be more than one as you can imagine depending upon the
6 different hydrologic settings.

7 We're not necessarily just looking at
8 groundwater either. You could start off with an
9 instantaneous injection to the uppermost aquifer and,
10 of course, that could end up recharging a service
11 water feature.

12 So I think this guidance will most like
13 streamline the review process as it relates to
14 Bellefonte. And it will also highlight to the
15 applicant what if there are some problems. What are
16 some things we need to look in at up front besides
17 tech specs? Perhaps site mitigating features up
18 front.

19 I kind of marvel. You know the petroleum
20 industry has underground storage tanks. They did
21 cathodic protection when they went to a more of an
22 above-ground storage tank perspective, double wall
23 tanks, etc. There are some things here I think that
24 would be quite beneficial in an ESBWR-type of setting
25 where hopefully perhaps some of these other vendors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will look at the other four design centers within NRO
2 and start looking at this thing.

3 VICE CHAIR ARMIJO: Yes. To that point, I
4 really want to make sure I understand. In this chart,
5 it shows that if you put in mitigating design
6 features, double-wall tanks, berms, other things, does
7 it really save you a lot of analytical work and
8 characterization work or whatever?

9 But what else does it -- What else do you
10 have to do in order to get credit for those things?
11 Is there some inspection program you have to do
12 periodically or -- I'm just trying to understand the
13 benefit at least to the --

14 MEMBER BANERJEE: There seems a box.

15 VICE CHAIR ARMIJO: It looks like a yes to
16 the end which sounds great but.

17 MR. DEHMEL: To answer the question, for
18 the ESBWR, the installation of liner has been
19 introduced as an ITAAC in the design. So it is
20 captured in Chapter 1 of the application.

21 VICE CHAIR ARMIJO: Okay. It turns into
22 something that you inspect later.

23 MR. DEHMEL: Yes, it turns into something
24 that you have to actually confirm that it's installed.

25 VICE CHAIR ARMIJO: But the design is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bona fide solution and you don't have to go through
2 the conservative equations and transport calculations
3 and --

4 MEMBER RYAN: Yes. I think if I recall,
5 Sam, in the radwaste chapter they made, the applicant
6 made, that point as well. That's why they did it
7 because it did short-circuit them to this is a
8 solution for this potential risk.

9 MR. SACHS: Yes. That then --

10 MEMBER RYAN: I was going to say we're
11 really coming close to another schedule item. So I
12 want to just in the next couple minutes wrap up.

13 VICE CHAIR ARMIJO: That's all I wanted.
14 That was my only question.

15 MEMBER RYAN: For any final questions.

16 MR. AHN: I think one critical comment on
17 the mitigation design feature. That's mainly on the
18 DCD decision and even though the site mitigation
19 design feature they should have done some left-hand
20 side onsite characterization including the
21 hydrogeologic parameter or certain conception with the
22 SP requirement.

23 VICE CHAIR ARMIJO: Yes. I understand
24 that. But I just want to know that -- My personal
25 view is mitigating design features are the way to go.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But if there's no benefit from a regulatory
2 standpoint or cost standpoint, nobody will do it. It
3 looks like there's some benefit.

4 MR. DEHMEL: Yes.

5 MEMBER RYAN: Okay. Any other questions
6 or comments?

7 (No response.)

8 Gentlemen, thank you very much for an
9 informative presentation and your other points as
10 well. I think we're scheduled to consider letter-
11 writing on this topic at 4:30 p.m.

12 With that, Mr. Chairman, I'll turn it back
13 to you.

14 CHAIR ABDEL-KHALIK: Thank you. Perfect
15 timing. At this time, we are scheduled for a break.
16 We'll take a break until 10:15 a.m. I would like to
17 warn you however that in the intervening time there
18 may be a fire alert and if the fire alert were --
19 We're off the record.

20 (Whereupon, at 9:56 a.m. the above-
21 entitled matter went off the record and resumed at
22 10:58 a.m.)

23 CHAIR ABDEL-KHALIK: On the record. We're
24 back in session. At this time we'll go to Item No. 9
25 on the agenda, Status of Risk-Informing Guidance for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 New Reactors. As you know, this item was originally
2 scheduled for 10:15 a.m. until 12:00 noon. Since we
3 lost 45 minutes from that time we will go until 12:30
4 p.m. with your presentation.

5 MEMBER STETKAR: Great.

6 CHAIR ABDEL-KHALIK: So Mr. Stetkar will
7 lead us through this presentation. John.

8 MEMBER STETKAR: Thank you, Mr. Chairman.

9 And to make the introductions as brief as
10 possible, let me just alert the Committee that what
11 you're going to hear this morning has recently changed
12 in terms of its potential priority for the Commission.

13 So although this is still a briefing meeting, we may
14 be asked to write a letter regarding this. So just
15 keep that in mind.

16 With that introduction, I'll turn it over
17 to Charlie Ader who will give us a little more
18 background.

19 MR. ADER: Yes, this is Charles Ader with
20 the Office of New Reactors.

21 As John said, when we talked to you last,
22 we felt, the staff, this would be a policy decision
23 for the Commission. As it evolved through the
24 process, there was a view that we were aligned enough
25 with Commission guidance that we would make this just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an information paper and that's what you have in front
2 of you is an information paper that talked about three
3 options that staff considered, status quo option, a
4 change in risk metrics and then the option we're
5 recommending to modify guidance to try to maintain,
6 reasonably maintain, the level of safety of the
7 enhanced designs.

8 Further reflection, and this has been
9 evolving just over the last month from going from a
10 policy paper to an information paper. Further
11 reflection, the decision was made that this is
12 something that the Commission really would want to
13 weigh in on and we're going to turn it back into a
14 policy paper.

15 The options, the paper that was concurred
16 upon by office directors and regional administrators
17 was actually a policy paper and it had three options
18 which are now just this is what staff considered. So
19 those will go back to the options.

20 The paper will not have any additional
21 substance to it. It will be reformatting. There were
22 some editorial changes that will go back. And I
23 apologize to the Committee because I know they like to
24 see the document that will be going to the Commission.

25 Given the nature of the policy issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here, I am assuming that the Commission is going to
2 want to write a letter on this because the Committee
3 has been very active in safety goal and this type of
4 policy. So we can talk at the end, but we're prepared
5 to support the Committee for whatever they would need
6 to generate a letter.

7 And with that, I'm going to turn it over
8 in the interest of time to Don Dube and Sunil on the
9 evolution of our thinking from when you last heard
10 from staff.

11 MR. DUBE: Thank you, Charlie. I'm Don
12 Dube, Office of New Reactors and my friend and
13 colleague, Sunil Weerakkody, from NRR. The meeting
14 purpose Charlie has pretty gone over it. So I'll skip
15 through here pretty quickly, but it's to provide you a
16 briefing on the status of this Commission paper.

17 I'll skip the agenda. This is a repeat
18 slide from probably a year ago. But just to refresh
19 everyone's memory, there's a number of risk-informed
20 initiatives for new reactors. Definitely risk-managed
21 tech specs, the US APWR for example and the COL
22 applicant, Luminant for Comanche Peak 3 and 4,
23 expressed interest in risk-informed completion times,
24 and a surveillance frequency control program. There
25 are other initiatives. Electric Power Research

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Institute has a working group interested in risk-
2 informed, in-service inspection of piping and we hear
3 through the grapevine interest in perhaps special
4 treatment requirements or 5069. That's what's
5 driving, has been driving, this effort for the last
6 year or so.

7 When we reviewed these applications, it
8 raised questions regarding what risk metric acceptance
9 guidelines should we use. Should we use the same for
10 new reactors as current reactors? Should they be
11 different? And then upon second thought also what
12 about the impact on the reactor oversight process? So
13 those are the two main themes that we'll discuss over
14 the next hour or so.

15 There has been a lot of stakeholder
16 engagement. I'm not going to go through every bullet.

17 But last week we had our third public meeting on the
18 topic and while the options and the approach have
19 evolved, I mean we've tried to stay engaged to the
20 extent possible.

21 We had a briefing before the full ACRS a
22 year ago and then the Subcommittee on Reliability and
23 PRA in June of 2009. There were views from industry
24 and the Union of Concerned Scientists. And we also
25 had presentations at some of the public fora such as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Regulatory Information Conference and American
2 Nuclear Society annual meeting. So we have tried to
3 keep stakeholders engaged throughout the process even
4 though it's been a long process so far.

5 This is a key slide because it discusses
6 how the staff's views have evolved and when I say
7 staff I'm talking at the widest possible level. If
8 you look at the transmittal letter to the ACRS staff,
9 you'll see that it was concurred upon by the major
10 offices, NRR, NRO, kind of unofficially Office of
11 Research, but also most importantly all four region
12 administrators and their staff. So that took some
13 effort.

14 But I think there's a pretty wide
15 consensus on the proposed approach. And maybe that's
16 why it is a little bit of a general approach, but
17 nevertheless I give a lot of credit to my colleague,
18 Sunil, for bringing together wide variation of
19 opinions sometime in reaching this consensus. So
20 there was definitely no early staff consensus on the
21 approach.

22 Initially, we were concerned with Reg
23 Guide 1.174 and some of these potential options. You
24 may recall the relative versus absolute change in core
25 damage frequency, large release frequency. But most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 recently certainly in the last six months or so
2 perhaps less concern with the numerical guidelines and
3 more on, I'll use this quote straight from some of the
4 Commission documents and rulemaking language ensuring
5 that the level of enhanced safety believed to be
6 achieved with this design will be reasonably
7 maintained. You can find language to this effect in
8 the rulemaking, for example, on the advanced boiling
9 water reactor rule language and somewhat similar
10 language in some of the other certified designs.

11 And also to a large extent implementation
12 of what is called in the rulemaking 50.59 like process
13 for new reactors. There is as you're aware 50.59 for
14 operating reactors and a process for making changes in
15 tests at facilities and for new reactors it's codified
16 within the rule for each of the certified design and
17 it is called a 50.59 like process. And it mirrors
18 very closely 50.59 for operating reactors, although it
19 has two additional aspects related to ensuring that
20 there's no substantial increase in the frequency or
21 consequences of ex-vessel severe accidents. So that
22 is something that is already in the rules for the
23 certified designs.

24 And so the staff's views have evolved to
25 perhaps working with this 50.59 like process perhaps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to broaden it, to incorporate some of the concerns
2 about maintaining an enhanced level of safety. So
3 there is staff consensus at a high level as I said
4 across the agency including all the regions.

5 The next three/four slides I'll try to go
6 through and make up some time. Fortunately I
7 highlighted in red the really appropriate phrases that
8 implement or that address the staff's concern. This
9 is taken from a Commission paper 20 years ago now.
10 The Commission stated and I'm going to just read the
11 red quote here, preservation of the severe accident,
12 human factors and operating experience insights that
13 are part of the certified design. That's the
14 Commission's concern in a nutshell.

15 And similar language in the Statements of
16 Consideration and again we're just using the ABWR as
17 an example, but you could find similar language in the
18 other designs. And again I'm not going to read the
19 entire paragraph. All of these quotes are in the
20 draft paper. But I'll highlight the red here which
21 says, in adopting a rule that the safety enhancement
22 should not be eroded significantly by exemption
23 request, the Commission recognizes and expects that
24 this will required careful analysis and sound
25 judgment, especially considering the uncertainties in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the PRA and the lack of a precise, quantified
2 definition of the enhancement. But again very similar
3 language, probably a few different words but
4 maintaining the enhanced level of safety, not eroding
5 significantly this enhanced level of safety.

6 Similar language again just continuing in
7 the statement of consideration for the ABWR, again
8 I'll just read the first sentence more or less, the
9 Commission on its part also has a reasonable
10 expectation that vendors and utilities will cooperate
11 with the Commission in assuring that that level of
12 enhanced safety believed to be achieved with this
13 design will be reasonably maintained for the period of
14 certification including renewal.

15 And so those thoughts there in those three
16 slides is how the staff's views have evolved perhaps
17 not so much on the numerical risk acceptance
18 guidelines, although it is important. But more so
19 perhaps on finally coming to a definition, if you
20 will, of what it means to maintain the enhanced level
21 of safety. And in a sense that would be part of the
22 charter I think going forward would be what does it
23 mean to maintain this enhanced level of safety putting
24 it in the form of changes to a reg guide or reg guides
25 and we haven't thought of the exact process yet. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one can envision either amending, supplementing Reg
2 Guide 1174 or a parallel reg guide or working with
3 some documents, the industry documents in particular,
4 that the staff necessarily endorses in its own reg
5 guides anyhow. So there's a number of avenues this
6 could eventually take.

7 Just a refresher, I mean there are a
8 number of current regulatory guides for risk-informed
9 initiatives. I won't go through them all because some
10 of these were discussed a year ago. But the Reg Guide
11 1.174 is sort of the umbrella reg guide and then there
12 are specific reg guides for risk-informed in-service
13 testing, inspection and what have you.

14 And a key principle, Reg Guide 1.174, is
15 that when proposed changes result in an increase in
16 core damage frequency or risk, the increases should be
17 small and consistent with the intent of the
18 Commission's Safety Goal Policy Statement.

19 Again emphasizing Reg Guide 1.174 and I've
20 highlighted again the key words. There are five
21 principles for risk-informed decisions and only one of
22 them really is related to changes in core damage
23 frequency or risks that are small. I mean the
24 proposed change must meet regulations unless it's
25 specifically an exemption request, consistent with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 defense-in-depth philosophy, maintain safety margins,
2 small increase in risk and that performance
3 measurements strategies for monitoring performance.
4 So those are five key principles and the numerical
5 metrics if you will of a small increase is only one of
6 the five.

7 You've seen these two graphs on multiple
8 occasions. This is from Reg Guide 1.174 to refresh
9 your memory that these are guidelines, not go/no go
10 acceptance criteria. But changes are defined based on
11 a baseline core damage frequency and a change in core
12 damage frequency and depending on where that
13 hypothetical change lies generally Region I area no
14 changes would be allowed. Region II are considered
15 small changes. One would track cumulative impacts.
16 And Region III are very small changes. And there's
17 more flexibility with regard to when these changes
18 would be allowed based on some baseline core damage
19 frequency.

20 It's obviously a logarithmic scale. My
21 understanding is that most applicants for risk-
22 informed efforts generally have been in the very small
23 region. So it's pretty rare to be in Region II. And
24 there's a parallel graph for large early release
25 frequency, but the baseline values and the X axis and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the change in LERF are one order magnitude different
2 from the Y axis, I mean, from the core damage
3 frequency plot.

4 Again, in Reg Guide 1.174, the risk
5 acceptance guidelines pretty much said all this. Rely
6 on a baseline as well as a change. Increases should
7 be limited to small increments. And the thresholds to
8 some extent related to backfit regulatory analysis
9 guidelines but certainly related to, tied strongly,
10 to the Commission Safety Goal Policy Statement.

11 So what brought us --

12 MEMBER STETKAR: Don, it might be worth
13 that you go back to that last slide, just highlight
14 that last subbullet on the basis because that probably
15 has --

16 MR. DUBE: Change in -- right here?

17 MEMBER STETKAR: Yes. That probably has a
18 bit of bearing on what we're discussing here.

19 MR. DUBE: Good point. Certainly when the
20 current generation of plants that generally have core
21 damage frequencies, I'm just going to use a round
22 number, in 10^{-5} range, some higher, some lower. But I
23 think median value around there. When one starts
24 setting thresholds out to the 10^{-6} and recall even 10^{-7}
25 level of change in core damage frequency, some argue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we're considering the uncertainties in PRA.

2 One is at the threshold in terms of the
3 resolution of the PRA models. I mean there are
4 sequences and contributions that are left out of the
5 model that are more than the deltas that one is
6 talking about. And so one will hear as part of the
7 various arguments for against absolute versus relative
8 change that in sense that also kind of sets what is
9 believed to be this, you know, why these graphs are
10 cut off where they are. Thank you.

11 MEMBER STETKAR: Thanks. That helps.

12 MEMBER CORRADINI: That I am -- I'm left.
13 I don't get it yet. So can you say it a different
14 way? Are you saying that if I'm at 10^{-5} and I --

15 MR. DUBE: One's baseline is here, yes.

16 MEMBER CORRADINI: Right. And I suggest a
17 change and do an analysis and find that the delta of
18 that analysis is 10^{-7} I really don't believe 10^{-7}
19 because I could be an order of magnitude off on 10^{-7}
20 delta. Is that what you --

21 MR. DUBE: Kind of. I mean --

22 MEMBER CORRADINI: I'm just trying to --

23 MR. DUBE: Right. Yes, we're talking
24 about a one percent change and these values are
25 typically unknown to factors of three core damage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency.

2 MEMBER SIEBER: Or more.

3 MEMBER CORRADINI: Generous.

4 MEMBER STETKAR: Well, and just the
5 resolution of the model, the level of detail in the
6 model might -- You might be missing things from the
7 model that if they were included would have a larger
8 effect on the thing that you supposedly met.

9 MEMBER CORRADINI: I understand. Okay.
10 So you don't even talk about the upper left -- the
11 upper right one. I'm kind of more interested in the
12 lower left one where I would expect the uncertainties
13 are even bigger relative to --

14 MR. DUBE: Yes.

15 MEMBER CORRADINI: Does the same thing --

16 MR. DUBE: I'll increase the uncertainty
17 for Dr. Shack's interest to an order of magnitude or
18 even more.

19 MEMBER CORRADINI: Okay. Fine. Thank
20 you.

21 MEMBER STETKAR: Recognizing that most
22 folks don't have a full scope Level 2 PRA anyway. So
23 the things that you're measuring for large early
24 release frequency are even more of a surrogate for
25 reality in that space.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DUBE: Okay.

2 CHAIR ABDEL-KHALIK: Are you implying that
3 if some new reactor designer comes with a CDF with 10^{-7}
4 we shouldn't believe that?

5 MR. DUBE: No, I don't believe I'm saying
6 that. It's just that --

7 MEMBER POWERS: There is no --

8 MEMBER STETKAR: I just wanted Don to
9 highlight that point because it relevant to that exact
10 type question.

11 MEMBER POWERS: There is no reactor
12 currently proposed that can be located on any site in
13 the United States that would have a 10^{-7} CDF.

14 CHAIR ABDEL-KHALIK: Because of seismic.

15 MEMBER POWERS: Sure. A 10^{-7} seismic event
16 is an astronomical event.

17 MEMBER RAY: Darn right.

18 MEMBER BLEY: Don, can I take you back to
19 -- You became with an explanation of this change and
20 focus to retaining the enhanced safety of the new
21 plants. And then you started getting into more
22 specific things. Two questions. One, the specific
23 things you've gotten into I don't think have changed
24 because of that, have they? The ones you've already
25 talked about.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DUBE: In what sense?

2 MEMBER BLEY: Has that change in focus on
3 preserving the enhanced safety of new reactors
4 affected any of the criteria you've talked about?

5 MR. DUBE: No.

6 MEMBER BLEY: Since you introduced that
7 concept?

8 MR. DUBE: No.

9 MEMBER BLEY: If we come to any where
10 that's induced a change shine a light on them. Second
11 question --

12 MEMBER RAY: Before you go to your second,
13 should they have made a change which I think is really
14 what you're asking? Should there have been a change
15 in the thing you talked about so far as a result of
16 the changed focus or are you raising that as a
17 question implicitly?

18 MR. DUBE: I -- Go ahead.

19 MR. WEERAKKODY: If I understand the
20 question correctly, I think you're asking a
21 fundamental question as to why we are here today which
22 is --

23 MEMBER RAY: That's what I thought.

24 MR. WEERAKKODY: Because it has
25 significant policy kind of implications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Right.

2 MR. WEERAKKODY: We've been asking that
3 same question from ourselves.

4 MEMBER BLEY: May those are two different
5 questions that they both are related to. With that
6 change in philosophy, it shouldn't have changed any of
7 the criteria you're talking about. Mine was has it
8 changed any.

9 MR. WEERAKKODY: It has not.

10 MEMBER BLEY: My second question is has
11 that concept of that change in focus been introduced
12 in any public session so far and have you had comments
13 on it?

14 MR. DUBE: Yes, we had a -- The draft
15 Commission paper was issues on May 12th I think. And
16 we had a public meeting last week on it.

17 MEMBER BLEY: Okay. Any comments on that
18 change in focus?

19 MR. DUBE: If I can be generous I was
20 amazed that when we went around the room and I
21 specifically looked at the wide view of stakeholders
22 there was no general opposition including Dr. Ed Lyman
23 from the UCS if I can put words in his mouth. He did
24 not have any fundamental concern with the approach
25 proposed --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: And none from industry?

2 MR. DUBE: -- by the staff.

3 MEMBER BLEY: Okay. Go ahead. I'm sorry.

4 I just wanted to know why you told us all that in the
5 beginning.

6 MR. ADER: Don, if I can add, there was
7 some views that the current guidance has enough safety
8 nets in it that would prevent a significant
9 degradation in the level of safety that's been
10 certified. I think that's something what our proposal
11 is. We need to test that and explore that.

12 The chart Don has on his slide that he has up on the
13 screen now shows a hypothetical that I could envision
14 you could have a change of a relative large nature
15 that would be off the graph. We need to modify it.

16 So the answer is, no, we haven't modified
17 1.174 yet, but a proposal is if the Commission agrees
18 with us we would be moving forward to look at those
19 documents with this concept of --

20 MEMBER BLEY: To see if it leads to
21 changes.

22 MR. ADER: Right.

23 MR. DUBE: Right.

24 MEMBER BLEY: I just wanted the context.
25 So that helps me.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DUBE: There was a very excellent
2 suggestion and I'd like to give credit to the person
3 who brought it up, but again I think it may have been
4 Rick Wachowiak from GE who said one aspect that one
5 might do is to come with a wide spectrum of possible
6 changes that one would see at a plant over its
7 lifetime, you know, power uprate change to the --

8 MEMBER BLEY: Specific examples of
9 changes.

10 MR. DUBE: Yes. Change to the steam
11 system, power conversion system, feedwater system and
12 test the existing guidance out there to see if there
13 are gaps.

14 This next slide I'm pushing Dr. Powers'
15 10^{-7} limit here. So pretend that there's a new small
16 reactor on --

17 MEMBER POWERS: This particular line
18 you're saying that the design is a CDF. It's a
19 hypothetical thing, but it certainly excluded the
20 site. Now your next statement that 7×10^{-8} is a
21 significant increase, I cannot understand at all.

22 MR. DUBE: I didn't say significant.

23 MEMBER POWERS: I can't even tell whether
24 it's law.

25 MEMBER CORRADINI: That's a lawyerly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 answer.

2 VICE CHAIR ARMIJO: He didn't say it was
3 wrong. He just said it was an increase, 70 percent
4 increase.

5 MEMBER POWERS: Well, the point is that
6 back at the beginning the Commission was careful to
7 point out that you need to consider the uncertainties
8 in the CDF and you've echoed them here. And so
9 there's no way to put 7×10^{-8} in any kind of context
10 at all. It's just a number until I know what the
11 uncertainty on that CDF is up there.

12 MEMBER CORRADINI: Can I ask Dana a
13 question? Because you said something in the previous
14 discussion that I thought we had -- that it was kind
15 of a -- that once you put a new design on a site
16 regardless of site in the U.S. seismic will tend to
17 create a lower bound on the CDF. That's what I --

18 MEMBER POWERS: It is pretty hard to get
19 below 10^{-6} as a round number.

20 MEMBER CORRADINI: Okay.

21 MEMBER POWERS: Because the problem is the
22 uncertainties in the magnitude of the earthquake are
23 so large by the time you get down to that probably
24 that you're probably talking about a magnitude eight
25 to nine earthquake which it's never designed for at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that probability. So it's very difficult to get below
2 10^{-6} on any real site.

3 MR. DUBE: Yes. Your point is well taken
4 and I won't disagree. There are large uncertainties.

5 But let's just say hypothetically that the baseline
6 internal events with core damage frequency is 10^{-7} and
7 there are three/four new reactor designs where there
8 is around the case. And they may propose a change to
9 the feedwater system that would isolate feedwater for
10 --

11 MEMBER POWERS: And I can't possibly
12 evaluate those things because until they come in and
13 tell me my CDF is 1×10^{-7} plus or minus three times,
14 ten times, I can't tell whether 7×10^{-8} is -- that's
15 probably in the grass for 1×10^{-7} . I think just the
16 omission uncertainty on that is probably at a factor
17 of three.

18 MR. DUBE: I'm going to beg to differ in a
19 few aspects in a sense that sometimes one can measure
20 a delta CDF just as well as the baseline CDF in the
21 sense that you may have a change that affects one or
22 two real dominant sequences and you don't have to
23 evaluate 30 or 40 initiating events and thousands of
24 sequences and tens of thousands of cut-sets to quickly
25 draw the conclusion that I may not have a major

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mitigating system for a number of very key initiating
2 events and reach the conclusion that for particular
3 risk-significant sequences: Station Black, loss of
4 feedwater at a Boiling Water Reactor, that some
5 changes even though there's uncertainty on the
6 baseline or a number of sequences could have a large
7 relative impact.

8 MEMBER POWERS: 10^{-7} core damage frequency.

9 See, you don't have risk-significant sequences
10 because significance then has to be related on an
11 absolute scale and at 10^{-7} it's not risk significant
12 period.

13 MR. DUBE: Okay.

14 MEMBER RAY: Dana, maybe I don't
15 understand but if nevertheless you're trying to
16 preserve what you sold the first time isn't it
17 significant in that context?

18 MEMBER POWERS: Yes. I mean if you're
19 doing that but if you're saying --

20 MEMBER RAY: Because that's what I'm most
21 focused on is you sold me something and now you
22 changed it.

23 MEMBER POWERS: Yes, you're the buyer and
24 I'm the outside observer. So I don't care what you
25 paid for it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: I'm not the one who paid for
2 it. I'm somebody who lives down the road, you know.

3 MEMBER POWERS: Well, it could be you pay
4 for it in a strange sense.

5 MEMBER RAY: So I mean I think that's what
6 he's saying that makes sense to me.

7 MEMBER STETKAR: Because somebody who
8 lives down the road can't do anything about that
9 seismic. But they can be concerned that you might be
10 changing the way that you operate the plant or
11 maintain the plan or things like that that --

12 MEMBER RAY: You sold me one thing and now
13 you're giving me something else.

14 MEMBER STETKAR: -- could be eroding my
15 confidence in your safety.

16 MEMBER POWERS: But if he tells me that I
17 have 10^{-7} core damage frequency and he jacks it all the
18 way up to 2×10^{-7} he has not changed my risk at all.
19 Zero change in my risk.

20 MEMBER RAY: Okay. I mean I accept that.
21 But, nevertheless, at some point you get into a
22 public domain in which you sold something and now
23 you're changing it. And I think the words that we
24 started out with because they're understandable by
25 people in the public. I'm going to preserve what I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sold and licensed here period.

2 MR. DUBE: All of this discussion is
3 extremely valuable and that is the reason why again
4 this is a hypothetical example and this is where we
5 were a year ago. And this is the reason why the
6 proposed approach is to basically get away from making
7 changes to this set of graphs and emphasizing more the
8 preservative level of safety and not worried about 10^{-7}
9 or 10^{-8} or 10^{-9} or whatever threshold one might set for
10 the new reactors.

11 MEMBER POWERS: The question I will ask
12 you is as they shuffle the deck a little bit and, yes,
13 you lose a little on the cod but you gain it back on
14 the mackerel on things and it's all in the noise.
15 Have I cost you anything?

16 MEMBER RAY: No, but I guess the question
17 is, Dana, can I be sure that you're not blowing smoke
18 in my ear when you do that.

19 MEMBER POWERS: Well, you know if I was
20 doing it I'm blowing smoke in your ear.

21 MEMBER RAY: Is it credible? And I think
22 that's part of what we have to look at.

23 MEMBER POWERS: You have to look at it in
24 detail. You just can't tell from the numbers.

25 MEMBER RAY: I'm not quibbling about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I was only trying to say at least that perspective of
2 we sold you something and we're going to preserve
3 through its life in terms that are meaningful to you
4 as the guy down the road. That's what I'm looking at.

5 That's all. I'm not trying to argue with your point
6 at all.

7 MEMBER POWERS: I mean the concern I have
8 is, okay, this guy has given up a little bit to
9 operational convenience and reduced the worker
10 exposures for some reason on one thing and says, okay,
11 I'll give it back for you on the quality of my digital
12 control system or something like that. And, yes,
13 overall when I calculate the number it changes from 1
14 $\times 10^{-7}$ to 2×10^{-7} , numbers that I don't believe either
15 one of them. So I don't think we've lost anything
16 here.

17 MEMBER RAY: You know, it's a fair point.

18 MEMBER STETKAR: Let's see if we get Don
19 through because we do need to get to the main points.

20 MR. DUBE: Okay. Sunil will cover the
21 next one because this related to the Agency's response
22 to either incidents or conditions. So I'll let Sunil
23 take over for this part.

24 MR. WEERAKKODY: Thank you very much. My
25 name is Sunil Weerakkody. I'm the Deputy Director Fire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Protection, NRR. On this effort I am speaking on
2 behalf of Fred Brown. He's the Division Director in
3 charge of the Reactor Oversight Program. But I'm
4 really glad to be here on something other than fire
5 like Mr. Shack said. I spent a lot of time with you
6 last year and you helped us out on fire stuff. So
7 don't plan to come back here for awhile.

8 But having said that, let me come to the
9 example that's in front of you and what I want to
10 convey here is first after I give you a 30 second
11 summary of what MD 8.3 is. MD 8.3 is NRC's management
12 directive that we would like to follow to the letter
13 if we can when an incident or event happens in one of
14 our plants and what it tells the staff basically, this
15 particular management directive directs the staff in
16 terms of what type of test points the agency should
17 have for particular events.

18 And if you look at the first word there
19 after the one in pink, IIT, okay, that's the highest
20 level. I don't think and anybody in the audience --

21 MEMBER POWERS: Tell me what IIT stands
22 for.

23 MR. WEERAKKODY: IIT that is Incident
24 Investigation Team. We have done that at TMI and I
25 don't think -- Fred, have you ever done that IIT after

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that? I don't think so.

2 PARTICIPANT: Yes, there were a couple.
3 We haven't done one for quite a while though.

4 MR. WEERAKKODY: It's very infrequent and
5 we get to those if we have a site area emergency or if
6 we have a situation where one of the safety limits of
7 the tech specs are reached or we have a very complex
8 event that the agency doesn't really understand. I
9 don't have the exact wording here. But that's another
10 criteria.

11 Other than that, when we decide whether we
12 are going to do an augmented inspection or a special
13 inspection or no additional inspection it's determined
14 primarily by the conditional core damage probability.

15 And what graph shows is if a steam generator tube
16 rupture happens in one of our current operating
17 reactors the type of range we would end up with and as
18 you can see we'll be looking at AIT. And this will be
19 a time where just like BP when the public will be
20 watching us, how we're responding in commensurate with
21 their understanding of the significance of the event.

22 So if we have a steam generator tube rupture, we will
23 go forward with the AIT.

24 But as you can see on the new -- for a new
25 plant, we are likely to end up in the range that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see there which could range from in some cases for no
2 additional inspection or a special inspection. To
3 preempt some of the hard questions I might get, I'm
4 not here to tell you that this is right or wrong.
5 There's only one thought I want to leave with you and
6 that is does the Commission or does the staff have an
7 issue that needs to be carefully deliberated with
8 significant enrollment of the stakeholders.

9 MEMBER RAY: Yes. The same event at a
10 current plant would result in a different response
11 than at a new plant. Does that make sense?

12 MR. WEERAKKODY: Right. So one of the
13 members might say, hey, so what's the problem? Another
14 member might say, it is a big problem. I'm going to
15 agree with both of them.

16 But you understand my point. I think at
17 some point in time before the NRC staff expends a lot
18 of energy to bring the organization to discuss this
19 issue and come to a solution that is good for all
20 that's the question. Should we be talking about this
21 or should we be in a mode where we just don't do
22 anything and when something happens on a reactive mode
23 address these procedures. That's all I have to say on
24 that slide. Is the next one mine?

25 MR. DUBE: Are there any questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: I would just not on tube
2 rupture but on loss of offsite power my reaction is a
3 new reactor in a place that has a loss of offsite
4 power is safer than one that doesn't and perhaps that
5 was part of the basis on which you located or picked
6 that.

7 MR. WEERAKKODY: I agree with you, sir.

8 MEMBER POWERS: But you agree with
9 everybody.

10 The point you make is a sound one that I
11 like. I like your logic there. But on the steam
12 generator tube rupture the logic breaks down.

13 MEMBER RAY: I didn't pick that one.

14 MEMBER POWERS: I noticed you didn't. Now
15 I'm asking you to tell me about the steam generator
16 tube rupture.

17 MEMBER RAY: Yes. That's a failure of a
18 piece of important equipment.

19 MEMBER POWERS: Loss of defense-in-depth.

20 MEMBER RAY: Right. Yes indeed. And so
21 we should deliberate later and not slow down John's.

22 MEMBER POWERS: We tell these guys they
23 only get half the time. So we have lots to discuss.

24 MR. WEERAKKODY: And I will not take even
25 half of that time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: But we had our own
2 incident response that cut into their time. Let's see
3 if we can go on through.

4 MR. WEERAKKODY: Thank you.

5 MEMBER POWERS: But that is, by the way, a
6 very, very important slide that just got turned off.

7 MEMBER RAY: Yes, it is.

8 MR. WEERAKKODY: He created it. I'm
9 presenting it. Thank you, Don.

10 MEMBER POWERS: And you agreed with him,
11 right?

12 MR. WEERAKKODY: I agreed with him.

13 MEMBER BLEY: And if I understand what you
14 guys told me about 20 minutes ago if the Commission
15 gives you the go-ahead to examine this issue, this is
16 one of those issues that you'll delve into.

17 MR. WEERAKKODY: That's right. There are
18 applicable issues that in the ROP area my boss here
19 has that needs to be revisited and this is just one of
20 them.

21 MR. DUBE: So the next half dozen slides -
22 - Go ahead.

23 CHAIR ABDEL-KHALIK: Let's go back to the
24 previous slide. I do understand the difference
25 between the conditional core damage probability for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 steam generator tube rupture in current reactor versus
2 new reactor.

3 But what if the procedure for handling
4 steam generator tub rupture from both cases? What if
5 you're directly venting to the atmosphere? That's how
6 we depressurize the primary, for example, by directly
7 venting to the atmosphere in a new reactor design
8 during the steam generator tube rupture. Would this
9 picture remain the same?

10 MR. DUBE: It might change because, this
11 is a -- given a tube rupture and no other failures
12 this is a range of values that I found for conditional
13 core damage probability. If there were subsequent
14 failures this could shift to the right. I mean the
15 actual event could shift to the right because you're
16 getting closer to having a core damage event. It's
17 like an accident sequence precursor analysis.

18 CHAIR ABDEL-KHALIK: But that's a design
19 characteristic. Design-specific thing. How to
20 response. How to depressurize the primary by venting
21 through the second. We know that ahead of time.

22 MR. WEERAKKODY: Are you saying that this
23 is normal planned event at the plant?

24 CHAIR ABDEL-KHALIK: No, I'm not saying
25 that. I'm saying that this is part of the emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operating procedures.

2 MR. WEERAKKODY: Okay.

3 CHAIR ABDEL-KHALIK: That in the event of
4 a steam generator tube rupture in some plant design
5 this is how we depressurize the primary by venting --

6 MR. DUBE: Yes. We're not questioning
7 that I don't think.

8 MR. WEERAKKODY: No, we wouldn't question
9 the EOP. But I think to the extent I understand the
10 fact that there has been an event such as a steam
11 generator tube rupture in the respect that they're
12 following the EOP you would get into the question of
13 what should be the analysis test response.

14 MEMBER POWERS: See, the problem you're
15 having here, Said, is that there's a long plot. You
16 need a conditional probability of violating 10 CFR
17 Part 100.23. Okay. And you need a conditional
18 probability of radionuclide release up here. And then
19 what you would see is in the case of your venting
20 thing that you would probably move the new Rx SGTR.
21 It might even go to the right of current Rx SGTRs.

22 CHAIR ABDEL-KHALIK: That's where my
23 concern is.

24 MEMBER POWERS: Yes. It's just the wrong
25 units up there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: I think that's the point is
2 you're talking about with offsite dose consequences
3 would you still ignore it. The answer is hell, no.
4 You wouldn't.

5 CHAIR ABDEL-KHALIK: That's right.

6 MEMBER POWERS: There's presumably a third
7 dimension that comes out here which has some metric on
8 radionuclides release which you don't have on this
9 slide.

10 MEMBER RAY: Yes.

11 MR. DUBE: Good thoughts. To keep on
12 schedule because John keeps waving me forward.

13 MEMBER STETKAR: We've got to get to the
14 show.

15 MR. DUBE: Yes. So there's really
16 basically three approaches. You may recall a year ago
17 we had option 1 and 1a and 2 and 2a and 3 and it got
18 to the point where it couldn't be handled and the
19 decision was made across the agency that really it
20 came down to three fundamental options. One is to
21 treat new reactors exact same as current reactors.
22 Not even change a single guideline. The other extreme
23 would be make changes to the numerical acceptance
24 guidelines and ROP thresholds and sort of in between.

25 So I'll quickly go through the two extreme

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 examples and then the approach that the staff is
2 proposing. And so the first is no changes to the
3 current regulatory guidance or status quo. So it
4 provides incentive to build reactors with enhanced
5 severe accident safety features. If they all fall to
6 the left side of this graph, then so be it. Just a
7 hyperbole.

8 And applicants and licensees who invest in
9 and maintain additional safety features would have
10 more flexibility. They'll have more flexibility for
11 their four train system to take one train out of
12 system at any time, keep it out for maintenance, still
13 have three trains available. So they would have more
14 flexibility with regard to risk-managed tech specs,
15 various operational flexibilities, online maintenance
16 and what have you.

17 The staff concluded that this approach did
18 not meet the expectations in that the approach may not
19 prevent significant decrease in the enhanced safety
20 through changes to the licensing basis and particular
21 plant operations over the plant life. I mean without
22 examining the full spectrum of possible changes and
23 doing little exercises we're not sure that -- We're
24 not going to say that it doesn't, but it may not
25 maintain this enhanced level of safety.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And, in particular, my colleagues in NRR
2 and DIRS, the approach may not provide for meaningful
3 oversight that supports NRC's response and inspection.

4 Sunil showed this example and went through this.

5 This is just one of several examples that
6 we went through and in the interest of time we didn't
7 go through them all. But there are a number of issues
8 in the significance determination process where
9 significant equipment could be out of service for or
10 found to be in a degraded state retroactively for
11 significant periods of time and the response would
12 remain in green band if you will. And again, in the
13 interest of time, we won't go into all those details.

14 MR. ADER: Don, if I could. I just wanted
15 to mention. The paper we originally had as a policy
16 paper this was option one and the words and the
17 rationale are going to be pretty much the same. It's
18 just going to be repackaged as an option. So the next
19 one you'll hear will be another option and then the
20 recommended option.

21 MR. DUBE: Right. Option three, I'm
22 skipping to the screen, would be to modify the risk-
23 informed guidance to include a new lower risk metric
24 for the ROP and changes to the licensing basis. And
25 we already talked about with the red X on the graph

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and the concerns regarding that. It would support the
2 Commission's expectations that new plants have
3 enhanced safety and advanced reactors have enhanced
4 margins of safety. But the staff believes the
5 approach actually goes beyond the Commission's
6 expectations by effectively requiring this continued
7 maintenance of enhanced margin of safety.

8 It's a delicate balance where the
9 Commission has stated in several policy papers that
10 they expect new reactors to be safer. But they also
11 carefully use words such as not mandating or
12 requiring. So we've been walking this fence here for
13 the last year and a half or so. But I guess in effect
14 we feel that it goes beyond the Commission's
15 expectations.

16 And it may be inconsistent with the
17 Commission's Safety Goal Policy Statement and
18 certainly the statement on the regulation of advanced
19 reactors in 2008 that -- this is from actually not the
20 language but some of the background discussion -- the
21 policy statement does not state that advanced reactor
22 design must be safer than the current generation of
23 reactors.

24 CHAIR ABDEL-KHALIK: I guess I'm trying to
25 understand your delicate treatment of the word

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 require. And if I look at slide no. nine your read
2 statement said the safety enhancement should not be
3 eroded. I mean the verb should, isn't that a
4 requirement, should not be eroded?

5 MR. WEERAKKODY: It is not. In the
6 regulatory language, first off, the word shall is the
7 requirement as opposed to the word should. Should is
8 not a requirement. Shall is.

9 And the second thing what you're looking
10 at is --

11 CHAIR ABDEL-KHALIK: So if they had said
12 the safety enhancement shall not be eroded, then you
13 would have interpreted it differently?

14 (Simultaneous speaking.)

15 MR. WEERAKKODY: I'll say that it's a
16 caveat. Now this is -- You're not looking at the rule
17 language. You're looking at the statement of
18 consideration supporting the rule. In terms of the
19 hierarchy, it's one step below. So if the rule said
20 shall, that's a requirement.

21 CHAIR ABDEL-KHALIK: Okay.

22 MR. ADER: Sunil, if I can. With the new
23 designs, as you know, they're certified by rule. So
24 there is a rule for that design. This statement was
25 explaining the change process to what would be the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rule. And the Commission said they would not approve
2 exemptions that resulted in a significant decrease.
3 So an applicant could come in, reference one of the
4 certified designs, request an exemption and this
5 statement in relation to exemption requests.

6 The other slide Don had then talked about
7 the Tier II information, the stuff that the licensees
8 could change under a 50.59 like process. And that's
9 where they said they expect the industry will
10 cooperate and maintain the level of safety that they'd
11 come in and sold to the public.

12 CHAIR ABDEL-KHALIK: Okay.

13 MR. DUBE: Thank. Good questions. We
14 have struggled with this.

15 So I guess I'm on the fourth subbullet.
16 It would create a -- This is the extreme example of
17 changing numerical guidelines. It would create a
18 risk-informed framework that in effect is inconsistent
19 with the underlying technical basis for the current
20 threshold that are derived from the Commission Safety
21 Goals and implemented in Reg Guide 1.174. These are
22 the Commission Safety Goals, the quantitative health
23 objectives and then surrogates where one demonstrates,
24 for example, that if one had generally speaking a
25 baseline to the -4 core damage frequency that that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would meet the latent cancer fatality objective as a
2 surrogate. Or if one had 10^{-5} large early release
3 frequency generally speaking with some margin one
4 would have a reasonable assurance that one would meet
5 the early fatality aspect of the quantitative health
6 objective.

7 We significantly decreased these
8 thresholds. It wouldn't affect being consistent with
9 the technical basis for the Commission's Safety Goal
10 Policy Statement which is implemented in Reg Guide
11 1.174. It took us awhile to come around to thinking
12 this thought process. But I think that's how we --

13 MEMBER POWERS: In this particular option
14 on the numerical guidelines, have you thought about
15 exploiting the lovely words that appear in 1.174 of
16 increased management attention?

17 MR. DUBE: Yes. Exactly.

18 MEMBER POWERS: You can leave the goals
19 alone, but you can change the threshold for increased
20 management attention.

21 MR. DUBE: Exactly. I have a paper that I
22 didn't distribute which would show how to implement this
23 and maybe you got a hold of it. No, that is actually
24 one of the things that -- implementing aspects that is
25 down the road. But that's one of the things that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're considering. Thank you.

2 And the last bullet is very important I
3 think. You could have unintended consequences in that
4 new reactors with enhanced safety features would have
5 less operational flexibility than the current fleet of
6 reactors. You can envision I'll call them just Plant
7 A and Plant B. Plant A is a current generation plant,
8 two or three trains of safety injection and so forth.

9 Plant B is the new reactor, significantly lower
10 baseline risk, four trains of safety injection, four
11 trains of aux feedwater, four emergency diesels and a
12 backup Station Blackout. And if one had strict
13 numerical guidelines the older plant would be able to
14 implement risk-managed tech specs and the newer plant
15 with more safety features, more trains, could actually
16 be more restricted and could have less operational
17 flexibility if one weren't careful.

18 CHAIR ABDEL-KHALIK: Not if those limits
19 are absolute.

20 MR. DUBE: Yes, even if they're absolute.

21 CHAIR ABDEL-KHALIK: I can see where that
22 would be the case if those limits are relative
23 values. But if they were absolute values, I just
24 don't see it.

25 MR. WEERAKKODY: Do you mean absolute

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 values that are different from new reactors?

2 CHAIR ABDEL-KHALIK: Delta. The deltas
3 are specified as absolute values rather than
4 fractional values of the base CDF.

5 MEMBER SIEBER: Right.

6 MR. DUBE: Well, it would all come down to
7 where you drew those thresholds, but.

8 MEMBER POWERS: I'm sure I see that.

9 MR. DUBE: Yes.

10 MEMBER POWERS: It seems to me that when
11 you get down to these lower numbers that if you change
12 the numerical guidelines in any way that you would
13 interfere on what it calls operational flexibility.

14 CHAIR ABDEL-KHALIK: Not if I set those
15 limits as absolute values of delta.

16 (Simultaneous speaking.)

17 MEMBER RAY: -- same for each.

18 CHAIR ABDEL-KHALIK: Right.

19 MEMBER RAY: Rather than a -- But you
20 don't want to do that.

21 CHAIR ABDEL-KHALIK: -- but that's what --
22 You modify the risk-informed guidance to include the
23 new lower risk metric. That didn't say that these are
24 relative changes, right?

25 MR. DUBE: It's general.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: Right. But the
2 intent is to use absolute values of delta.

3 MEMBER SHACK: But if the absolute value
4 of delta is 10^{-8} or 10^{-7} .

5 CHAIR ABDEL-KHALIK: Then you would be far
6 more restrictive on reactors with higher ones.

7 MEMBER SIEBER: Can even -- higher.

8 MR. ADER: Just to clarify. The changes
9 we're talking about here is four new reactors. We
10 were not looking at going back and changing --

11 CHAIR ABDEL-KHALIK: I understand.

12 MR. ADER: -- current operating reactors.

13 MR. DUBE: And the challenge is that not
14 all new reactors are the same. We do have some of the
15 more evolutionary designs. I'll just name them
16 because they're straightforward, EPR and APWR, which
17 have active systems like the current generation but
18 more of them. But they tend to have core damage
19 frequencies more towards the bottom of the range of
20 the current fleet. And then one has the passive
21 designs, ESBWR, AP1000 and others that are being
22 proposed which are an order of magnitude of more even
23 below that. And if one had an absolute threshold we
24 can't design it I don't believe to encompass this wide
25 range of variation even within the new reactors

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because they do span a wide range certainly for
2 internal events core damage frequency. And a lot of
3 these --

4 And I understand there is a flaw on
5 seismic core damage frequency. But a lot of the kinds
6 of programs that you have usually the deltas are going
7 to -- the impact on seismic is neutral and a lot of
8 the deltas really you're using the baseline internal
9 events, maybe fire to some extent. And so to come up
10 with a threshold that can span this wide range -- we
11 thought about it for a year -- it would be tough.

12 VICE CHAIR ARMIJO: Okay.

13 MR. DUBE: Which comes to you know it's
14 like Goldilocks, too hard, too soft, just right or too
15 hot, too cold, just right. A approach selected by the
16 staff or selected by the staff identified specific
17 changes to the risk-informed guidance for changes to
18 the licensing basis that prevent a significant
19 decrease in the level of safety. Now that's a lot of
20 words, but it really comes down to defining for once
21 what does that mean, what does the Commission mean, by
22 preventing a significant decrease in level of safety.
23 It may be quantitative. It may be qualitative.

24 And then in the ROP aspect identifying
25 specific changes to the risk-informed guidance for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ROP to provide for meaningful regulatory oversight.

2 And then the next couple slides we'll try
3 to get a little more specific. I only have a few more
4 slides. So if you can hold on maybe we'll have quite
5 a bit of time for discussion.

6 For changes to the licensing basis, it's
7 evaluated how to modify the guidance to prevent this
8 significant decrease in a level of safety. Whether
9 one might supplement the CDF and LERF acceptance
10 guidelines, we haven't thought about it. Maybe
11 there's a speed limit aspect which is you know if a
12 plant has a core damage frequency baseline of mid 10^{-7}
13 range. We wouldn't worry about small changes above
14 that. But there's some level at which the staff would
15 start getting nervous. And to use what Dr. Powers
16 said exactly in Reg Guide 1.174 enhanced management
17 oversight may be appropriate. That's one possible
18 avenue that's an implementation detail.

19 Whatever approach we would utilize
20 takeover involvement. So if the Commission said go
21 with this option right tomorrow, you know the work is
22 still ahead of us. Much more work than we've done to
23 date quite frankly.

24 But involvement in the evaluation and
25 development of detailed changes, one thing that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 suggested at the public meeting last week which I
2 thought was an excellent example was come up with some
3 number of changes that are possible over the life of
4 the plant and exercise the current guidance and see if
5 there are gaps that need to be filled. A very good
6 example. Perhaps having a tabletop exercise, multi-
7 day workshop with some of the SRAs from the region and
8 industry and other stakeholders.

9 Evaluate the proposed changes to the
10 guidance. Ensure that the changes don't create
11 unintended consequences. As creating disincentives
12 for safety designs. If we are restrictive then why?
13 To what benefit is it to the vendors to have extremely
14 safer designs but have less operational flexibility
15 doesn't make a lot of sense.

16 But there's also concern about if one is
17 not careful and I didn't show you an example in the
18 interest of time. But one could go through a
19 significance determination process, show where a
20 passive feature could be in a degraded state for a
21 significant period of time and based on change of core
22 damage probability still remain a green. So one would
23 want to make sure that whatever approach we have would
24 not allow the degradation of passive safety system
25 performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And then these rules in Section VIII.B.5.c
2 of the Design Certification Rules as I mentioned
3 before talk about ensuring that there's no substantial
4 increase in the probability of consequences of ex-
5 vessel core damage events. Perhaps we could work that
6 into this overall process going forward.

7 I'll hand it over to Sunil for ROPs a
8 little more discussion.

9 MR. WEERAKKODY: Yes. I spoke about
10 Management Directive 8.3 Incident Investigation
11 before. This is you could say the second big aspect,
12 in fact a very important aspect, where this agency has
13 made significant strides in using this information in
14 our reactor oversight process. What you're going to
15 see over the next couple of slides is a following.

16 Before we come into this Committee and
17 developing the paper, we had a number of meetings with
18 the regional management, the RAs and the deputies, the
19 office director of NRO, the office director of NRR.
20 The focus of this discussion was in the event the
21 Commission tells us go do good. In other words, go
22 look at these procedures, these guidelines, and look
23 at the kind of things we need to do to tweak them for
24 our new reactors. If that's what the Commission
25 wishes us to do, then there will be certain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 considerations that the agency -- when I say the
2 agency, the RS, DRS, office directors -- would
3 consider.

4 Now one of the things I want to point out
5 before I go bullet by bullet except for the first one
6 all of the other ones start with the word evaluate.
7 Because we understand -- I think the key there is we
8 understand that to get to a point that is good for all
9 of us that we should evaluate a number of things
10 before making up our minds.

11 The first item there, utilize stakeholder
12 involvement in the evaluation and development of
13 changes to the guidance, this is the definite one. We
14 do plan if the Commission approves that we go forward
15 with these procedures and guidance documents we plan
16 to keep our internal and external stakeholders
17 engaged. That's definitely going to happen.

18 The next one, evaluate the criteria for
19 plant placement in the action matrix to assess..., I'm
20 not going to read that sentence. I kind of run out of
21 wind. But let me just speak to it. What we do in our
22 oversight process is that we look at the inspection
23 findings that are coming out of plants and their
24 significance.

25 And also we look at what we call the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 performance indicators. You know these could be
2 things like the number of trips, their system
3 availabilities. For each plant, we look at for a
4 given time period what those numbers are and based on
5 those we put them in action matrix in that order of
6 performance.

7 So the idea here is we want to go and see
8 for the new reactors whether anything has to be
9 tweaked in the thresholds, the different way the
10 plants could get into the action matrix and how the
11 agency responds. So that's what that means.

12 The third bullet, evaluate the merits of
13 developing additional criteria, for example
14 deterministic, change in risk, to support NRC's
15 response to findings and performance trends. And one
16 of the things, again you may already know this. But
17 if you don't just to refresh as compared to the
18 licensing area where you look at 1.174 you see the CD
19 and delta CDF, delta LERF. But then there's a bunch
20 of other criteria, the defense-in-depth, safety margin
21 and a couple others I can't remember.

22 But when you go to ROP what you find is
23 it's more numerical driven relatively. Okay. So
24 given that when you have -- I think this kind of goes
25 to some of the points that Dr. Powers mentioned. When

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the numbers are very, very low for plants whose PRA,
2 one could say, has some level of academic, meaning you
3 don't have a lot of operational experience and could
4 be high uncertainties you have to evaluate whether in
5 lieu of, in addition to, the numerical criteria
6 whether we should be a little more relying on the
7 deterministic.

8 Again, I emphasize the word evaluate just
9 to show that it may be necessary. It may be not. But
10 it's in play.

11 Evaluate any potential ROP changes to
12 avoid unintended consequences such as creating
13 disincentives... I'm not going to spend a lot of time
14 on that, but this basically emphasizes that in the
15 minds of the RAs and the office directors we find that
16 it is very important that when we have tweaked these
17 we've got to be real cognizant of the fact that if a
18 licensee expends investments to design a new reactor
19 they should get something back for it.

20 Consider a need to risk-weight or
21 otherwise weight findings associated with passive
22 systems to reflect the difficulty of recognizing the
23 degradation of passive systems. Again, I might need a
24 little bit of help from Don on this one, but my
25 understanding on this one is in new reactors you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some components that are of different nature which
2 could lead to sequences that we don't know yet. So
3 there should be a consideration for that when we
4 revisit our ROP.

5 And the next bullet is a very important
6 one. Continue to independently assess licensee
7 performance in the areas of safety culture since
8 safety culture addresses common underlying factors
9 that affect plant safety. You know I can recall when
10 we scheduled like a one hour meeting with the four
11 regional administrators and the two office directors.

12 You know one thought hey, you've got all of these
13 things currently in the ROP that are called cross-
14 cutting, you know, things like human performance,
15 things like safety-conscious work environment. That
16 has some relevance to what we call today, you know,
17 loosely I'm using the word safety culture here.

18 So the important thing that was pointed
19 out is it is a leading common cause type indicator.
20 So when we move forward on evaluating this guidance,
21 we want to continue to independently assess. Again,
22 these are not done deals. We want to look at that up
23 closely.

24 Evaluate maintaining or changing the
25 current thresholds for green, white, yellow, red risk-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant findings and performance indicators.
2 Again, the word I want to emphasize is evaluate
3 because if I speak to three different people outside
4 the agency they will have three very good ideas. So
5 what needs to be done is and Don pointed this out and
6 one of the external stakeholders pointed out there
7 needs to be some discussions, some examples, some
8 settings to see does the current criteria give us
9 sufficient for meaningful engagement or do we need to
10 make changes?

11 And the other point is this is more of a
12 broader point, one of the things that in the ROP we do
13 is we always keep an eye on an ongoing basis is there
14 a need to revisit them. Are there gaps? So when we
15 take on a deliberative attempt to tweak or modify the
16 existing guidance for new reactors we might find
17 things that are applicable and relevant and useful to
18 our operating reactor. So that's another thing that
19 we would need to keep an eye.

20 So those are the fundamental things that
21 the agency's senior management thinks that we should
22 take under serious consideration in the event our
23 bosses on the 18th floor and the 17th floor says go
24 forward and tweak or modify the guidance.

25 MR. DUBE: Thanks. I only have two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slides. So I'll wrap up in 30 seconds. We're not
2 going to go through the backup slides.

3 So we mentioned light water reactor risk
4 profiles generally have lower or new water light water
5 reactors generally have lower risk profiles. The
6 original, the early, staff concerns were with risk
7 metrics. So that's why the title for some of these
8 discussions was risk metrics for new reactors. But
9 it's evolved to be more of a concern with assuring the
10 enhanced level of the accident capability, perhaps how
11 we implement this 50.59 like process. And we're
12 prepared to engage stakeholders.

13 And real quickly, the steps would be to
14 issue the final Commission paper, engage stakeholders
15 regarding specific changes, proceed with evaluation of
16 applications for risk-informed initiatives which are
17 coming and will be coming real quickly once a couple
18 of plants get their COLs. And then a parallel effort,
19 maybe more extended, because there was more time and
20 maybe different sets of issues. But it's a parallel
21 effort to address ROP issues.

22 That's it.

23 CHAIR ABDEL-KHALIK: If you go to slide
24 21, would you agree that this is just a punt?

25 MR. DUBE: That is a polite way of putting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it, yes.

2 MEMBER CORRADINI: I thought you were
3 going to go back to Goldilocks. But I was waiting for
4 you would characterize it.

5 MR. ADER: No, people have made that
6 comment. It looks like we're just kicking this can
7 down the road because when we were here last year we
8 were talking about should it be LRF or LERF. And
9 there was still a lot of work. The devil's in the
10 details. But until we had alignment on what the
11 guiding principle we're trying to accomplish I don't
12 think we would have made the progress that we hoped to
13 make in the future if the Commission agrees with it
14 because there was status quo.

15 A lot of people came at it from the point
16 of view, well, we need to change the metrics. We need
17 to make them lower was kind of the initial reaction by
18 a lot of individuals. Others were status quo. You
19 have the safety goals. You should treat them alike
20 until we have alignment. So it doesn't seem like a
21 lot of progress. It seems like we put off a lot of
22 the tough issues. But until we have alignment of what
23 that principle was, what we were really trying to
24 accomplish, I think we would have expended more staff
25 effort working to different ends and we would have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 been arguing over LRF, LERF, without having agreement
2 of what we were trying to accomplish.

3 MR. DUBE: And added to that, I mean if
4 one were to go with the middle option, Option 2 if you
5 will, it means definitely not status quo. I mean
6 there will be changes and not significant changes to
7 the risk metrics. So we wouldn't be changing those
8 couple graphs necessarily for new reactors, wouldn't
9 use large release frequency or some other hybrid
10 metric. But we would rely more on defining what it
11 means to preserve the enhanced level of safety,
12 maintaining the enhanced level of safety, identifying
13 specific reg guides where there are gaps, identifying
14 where there might be new reg guides and changes to the
15 ROP.

16 MEMBER CORRADINI: So can I press the
17 point that Said had.

18 MR. DUBE: Go ahead, Mike.

19 MEMBER CORRADINI: So actually Sunil used
20 the words. You pointed to verbs. So I look at all
21 the verbs as whether we're going to think, we're doing
22 to do, or we're going to cogitate a little bit like
23 just sit around. So I see a lot of thinking. The
24 doing part is to develop guidance and the utilized
25 stakeholders. So are you going to go back? You used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the example of one of the stakeholders giving the
2 suggestion of actually consciously suggesting a lot of
3 surrogate changes in evaluating. If I'm sitting at 10^{-6}
4 for the CDF or 10^{-7} for the LERF, what the sphere is
5 of influence of all these changes?

6 So is that going to be a definite do?
7 Because that to me actually seems like a very
8 reasonable way to just start the process.

9 MR. DUBE: I mean I don't know if I would
10 use the word definite. But it's an excellent idea.

11 MEMBER CORRADINI: Okay. And then what
12 are you thinking about -- That's the third bullet.
13 What are you thinking about under the sixth bullet?
14 That's what I didn't catch about develop guidance to
15 implement design certification rules?

16 MR. DUBE: I don't have it before me, but
17 it's actually in 10 CFR Part 52. For each certified
18 design, it's actually codified in rule and VIII.B.5.c
19 states those exact words that I mentioned before. No
20 substantial increase in the probability or
21 consequences of ex-vessel severe accidents. No one
22 has defined that yet.

23 MEMBER CORRADINI: And that's what you're
24 going to do.

25 MR. DUBE: Well, it could be part of -- In

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a larger framework, yes, it could be part of the
2 effort.

3 MR. ADER: There are actually two efforts
4 and the one Don mentioned is unique for Part 52 that
5 it has that change process for those features that
6 were added for ex-vessel severe accidents.

7 MEMBER CORRADINI: Don't make it worse.

8 MR. ADER: Don't make it worse. No
9 significant. And they realize with the uncertainty I
10 think they put a significant decrease.

11 MR. DUBE: Substantial decrease.

12 MR. ADER: Substantial decrease. But
13 there's the other 50.59 like change process that
14 applicants and licensees can take departures. It
15 reads much like 50.59 and if you look at the current
16 guidance that's been endorsed, NEI guidance, they have
17 examples of frequencies of accidents. That process
18 needs to be defined as well. And there's a working
19 group that's already starting up.

20 MEMBER CORRADINI: Okay.

21 MR. ADER: NEI I think is looking at their
22 document to see if they need to supplement the -- And
23 I don't remember the number of NEI document that's the
24 50.59 guidance. But they need to supplement it for
25 50.59 like process for Part 52 given the lower risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 numbers.

2 My concern is there could be changes. If
3 we don't look at it, there's a potential that changes
4 could be evaluated that we can take a departure and it
5 would never even come into staff to look at for a
6 license amendment. So it's something that I believe
7 needs to be looked at.

8 MEMBER CORRADINI: Okay. Thank you.

9 MEMBER RAY: Does safety-related versus
10 important-to-safety play any role in your thinking
11 about this?

12 MR. DUBE: Not necessarily, no. Because
13 with the passive plans you have kind of an in-between
14 regulatory treatment of non-safety systems which is
15 kind of in-between safety-related and non-safety.
16 It's really --

17 MEMBER RAY: Well, that's something that
18 we stumble over often and we're told stay away from
19 things because it's not safety-related.

20 MR. DUBE: No.

21 MEMBER RAY: It does seem to play a role.

22 MR. DUBE: I don't get hung up on that
23 personally.

24 CHAIR ABDEL-KHALIK: I'm just still
25 struggling, trying to find out what on this slide that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 goes beyond what's in the SRM on SECY 93-077 and/or
2 the statement of consideration for the ABWR design
3 certification. What's new here?

4 MR. DUBE: The bottom bullet.

5 MR. ADER: Don, if I can.

6 MR. DUBE: Yes, go ahead.

7 MR. ADER: What we're trying to do is
8 implement those statements, make them come true, I
9 think. I think where there's a concern of the staff
10 that the current guidance as written would not
11 necessarily maintain the level of enhanced safety that
12 these new plants are providing. Some will argue that
13 we're not going to go out and take out a fourth train.

14 And I don't think people are going to do that either
15 and some of it's tiered to one. So you're not going
16 to change it unless you go by rule.

17 But the current guidance as a lot of us
18 read it could allow some changes that would have a
19 significant, maybe it's an internal event CDF change
20 that would pass under the radar screen with current
21 guidance as written.

22 MEMBER SIEBER: And then it could dribble
23 down to the current --

24 MEMBER RAY: You say somebody's not going
25 to go out and take out a fourth train. Clearly,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's true, but you know when you're managing a
2 plant, you can treat it as an installed spare, too.
3 So it makes a big, big difference whether you've got
4 spares in the warehouse and people to run in and put
5 them in place on a weekend. Or you say when it's out
6 of service it's out of service. I'll go buy another
7 one. So it does make a difference.

8 You can't assume because it's there it's
9 going to be in service because there's a cross to
10 keeping it in service.

11 MEMBER POWERS: The whole design
12 philosophy, the EPR, is to be able to take that fourth
13 train and treat it as there was an installed spare.

14 MEMBER RAY: I know, Dana, and that's why
15 I like the words in the early slides in which we said,
16 if you're selling a safer plant, then we're going to
17 make sure you keep it a safer plant. But it doesn't
18 happen by itself. It doesn't happen just because you
19 put it there.

20 MR. ADER: So what I see on the slide you
21 referred to earlier is staff going and looking at the
22 various guidance documents 1.174 to see if they will
23 make the Commission's expectations, at least, help
24 make them come true, and do we have a risk-informed
25 regulatory process that will bring things in for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enhanced attention by the NRC or at least bring them
2 in for a review so we can try to again maintain that
3 enhanced -- I use the words reasonably maintain or not
4 have a significant decrease in the level of safety
5 performance that these plants seem to exhibit.

6 MEMBER RAY: Let me try one more time on
7 my thing that you don't get hung up over because I'm
8 glad you don't -- wish I didn't. But in trying to
9 think through requirements or assumptions about
10 operability do you assume there are any constraints on
11 the important-to-safety stuff that will keep it in
12 service?

13 MR. DUBE: Well, many of the plants -- We
14 didn't show an example here, but some of the plants
15 have investment protection --

16 MEMBER RAY: Right.

17 MR. DUBE: I don't know the word allowed
18 outage time but unavailability. And we actually used
19 one of our SPAR models of a particular new reactor and
20 exercised a number of hypothetical what-ifs to see if
21 we could get ourselves -- one could get themselves in
22 a situation of having some of these non-safety but
23 important-to-safety extended period of time and push
24 some of the 10^{-6} delta core damage probability limits
25 and we couldn't come close with reasonable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 combinations of equipment out of service.

2 Now granted this was a couple of day
3 effort with one plant model and only a dozen or so
4 combinations. But it gave us some encouragement that
5 perhaps you know we have controls or if there are
6 gaps, there's not a heck of a lot of them. But what
7 we need to do is more fully exercise these what-ifs,
8 you know, possible examples of changes that might be
9 made over a plant lifetime to make sure that there are
10 no gaps.

11 MEMBER RAY: Thank you.

12 MEMBER STETKAR: Anything else?

13 MEMBER SHACK: Just one other thing. You
14 know, when you're looking at some of these plant
15 changes, I think you want to look at some of these
16 requests, too. I mean suppose an ESBWR did come in
17 and ask for a risk-informed tech spec. What would it
18 look like? Or you obviously just hit up all against
19 back stops. So there is a mechanism there for that.

20 MR. DUBE: Right.

21 MEMBER STETKAR: Don, Sunil, thanks for
22 the presentation. Thanks for accelerating it, too.
23 You did well.

24 MR. DUBE: Thank you.

25 MEMBER STETKAR: To fit the time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 constraints. There's obviously a lot of interest
2 among the Committee members.

3 Regarding whether we write a letter or
4 not, I guess that's something that we need to
5 deliberate probably later this afternoon.

6 CHAIR ABDEL-KHALIK: If it were to happen,
7 I suspect it would be in the July time frame.

8 MEMBER STETKAR: Yes. You're planning on
9 sending this up in August, right?

10 MR. ADER: As an information paper, we
11 would have probably started sending it up next week.

12 MEMBER STETKAR: Right.

13 MR. ADER: But recognizing that you would
14 probably want to write a letter we're anticipating
15 that, we're hoping that, the August time frame, late
16 July/August, we could send up the paper with whatever
17 comments that the Committee has.

18 MEMBER BLEY: I guess we need our own
19 discussion about that. I'm a little hard pressed to
20 think of what we'd say.

21 MEMBER STETKAR: Yes. Let's have that
22 discussion, but later.

23 (Simultaneous speaking.)

24 MR. ADER: Recognize that granted some of
25 the devil is going to be in the details. And we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 revise 1.174 or supplement it those documents would be
2 coming back.

3 MEMBER STETKAR: That's true, although I
4 think the Committee's -- I don't want to put words in
5 the Committee's mouth. I think we need to discuss it
6 internally because there's obviously a lot of
7 interest. There's probably diverse opinions. So we
8 need to deliberate a little bit about this internally.

9 And with that, Mr. Chairman, I will turn
10 it back to you either 24 and half minutes later or
11 five and a half minutes early.

12 (Simultaneous speaking.)

13 CHAIR ABDEL-KHALIK: Thank you. We are in
14 recess until 1:00 p.m. when we go to Item No. 10 on
15 the agenda. So unfortunately we have a reduced lunch
16 time window. Off the record.

17 (Whereupon, at 12:21 p.m., the above-
18 entitled matter went off the record and resumed at
19 12:59 p.m.)

20 CHAIR ABDEL-KHALIK: On the record. We
21 are back in session. At this time, we'll consider
22 item no. 10 on the agenda, Generic Safety Issue GSI-
23 191 and Dr. Banerjee will lead us through this
24 discussion.

25 Dr. Banerjee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Thank you. Most of the
2 members, of course, know about Generic Issue GSI-191,
3 Assessment of Debris Accumulation on PWR Sump
4 Performance. Last time we were briefed on this, I
5 think was I asked Mike about it was October 2008. And
6 we wrote a letter at that time.

7 And just to summarize very briefly before
8 handing this over to Mike, what we wrote in our letter
9 I think is still fairly germane. I'll give you the
10 main points.

11 (1) The first point was that significant
12 progress had been made towards resolving GSI-191.

13 (2) That all licensees at that time had
14 installed significantly larger sump screens and some
15 had undertaken further action such as changing fibrous
16 insulation and chemical buffers. That has, of course,
17 advanced.

18 (3) Nearly all licensees had conducted
19 some form of head loss testing for their new screen
20 systems. The staff had developed adequate guidance to
21 support its review of these tests.

22 (4) The fourth was the prototypicality of
23 these tests was something that the guidance was
24 addressing.

25 (5) That there had been an adequate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guidance developed to support chemical-reaction
2 effects.

3 (6) Programs had been put in place to
4 determine the amount of debris and chemical products
5 that passed through the sump screens as well as the
6 effects on core cooling. However, guidance should be
7 developed to ensure that these tests cover a wide
8 enough range of conditions to support the staff's
9 review of in-vessel downstream effects.

10 (7) That the staff had proposed a
11 systematic process which actually amounted to a
12 framework to close out GSI-191.

13 So that was essentially our letter and its
14 major conclusions. Since that time many things have
15 happened and Mike Scott will brief us about this. No
16 letter is needed. So I'm going to leave it in your
17 capable hands, Mike, to tell us what to do.

18 I have also given each member a copy of
19 the SRM that was put out on May 17th which has five
20 points which I think Mike will probably refer to or do
21 during his talk. If not, I have them listed and we
22 can go over it.

23 MR. SCOTT: It's certainly on my mind.

24 MEMBER BANERJEE: All right. Go ahead.

25 MR. SCOTT: Good afternoon. I'm pleased

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 today to brief on the status of Generic Safety Issue
2 191. I'd like to be able to report to you today that
3 everything is on schedule just as we said it was in
4 late October of 2008 when we met with you last.
5 Instead I'll tell you where it really is which is not
6 exactly where we wanted to be at this time.

7 Our purpose today is to provide
8 background, status, path forward and key messages for
9 this issue. Dr. Banerjee mentioned that we did not
10 request a letter. Of course, it would be up to the
11 Committee if you thought a letter would be appropriate
12 at this time. The staff is working on the SRM that
13 you referred to. So we are considering path forward
14 and recommendations to the Commission. So we are not
15 specifically asking for a letter at this time.

16 Background. Just briefly, of course, we
17 opened GSI-191 to address the sump performance issue.

18 Generic Letter 2004-02 was the document that
19 requested licensees to perform detailed evaluations of
20 their strainer performance getting away from previous
21 assumptions that were nonmechanistic and having to do
22 with the sump could survive a 50 percent blockage.
23 And Generic Letter 2004-02 was said go forth and
24 evaluate what your performance would be based on a
25 mechanistic evaluation of how much debris could get to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the sump. And that's what licensees started doing at
2 that time.

3 There was great emphasis at the time
4 Generic Letter 2004-02 was issued and subsequent to
5 that to get the strainers larger. It was widely
6 considered that the strainers needed to be a larger
7 size. This was discussed with the ACRS at that time
8 and all parties involved I believe concurred that the
9 right thing to do was to make the strainers larger
10 soon. And that choice was made with recognition that
11 the evaluations intended to show that the strainers
12 were of adequate size would be going on at the same
13 time that the strainer modifications were going on.
14 And obviously that has potential detriments for issues
15 resolution because they can find that the strainers
16 were not in and of themselves enough to resolve this
17 issue.

18 And we could and in fact did find
19 significant questions and concerns about the practices
20 that the licensees used to do the testing which has
21 led to some round and round discussions with the staff
22 which I'll talk about. But I think everybody agreed
23 at the time that it was appropriate to go ahead and
24 make the strainers larger recognizing that potential
25 impact.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And so the licensees indeed made their
2 strainers much larger and as the slide says one to two
3 orders of magnitude and the largest strainers are on
4 the order of about 6,000 or more, 7,000 square feet of
5 surface area. So very, very large. And those who
6 have dealt with this issue before are of course very
7 familiar with what I'm talking about.

8 Since 2007 as Dr. Banerjee indicated we
9 issued review guidance in early 2008 regarding various
10 aspects of the strainer problem that had not
11 previously been addressed in the staff's guidance and
12 safety evaluations and those were with regard to head
13 loss testing practices, coatings and chemical effects.

14 The testing has posed a set of challenges
15 that I think most of you are pretty familiar with.
16 Unfortunately of course you can't test this system in
17 the plant with debris in it obviously. So you have to
18 do it at a remote vendor facility. And the vendor
19 facilities are taking a section of strainer, a mock-up
20 of the strainer basically, putting it in a test tank
21 and sending debris to it. There are so many aspects
22 of this issue that weigh upon how much debris actually
23 gets to the strainer and you're trying to model it in
24 a remote facility. You can imagine that it leads to
25 lots of questions and it did.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So we asked RAIs in the dozens of the
2 licensees and their vendors regarding their test
3 practices and that started really mostly in 2008,
4 although we had interacted with them in 2007 and
5 earlier. The final RAI or the final supplemental
6 response to the generic letter were due to us at the
7 beginning of 2008. So that's where we got heavily
8 into this review of the test practices which led to
9 additional questions and additional interactions with
10 the licensees.

11 Also in 2008, the staff came to the ACRS
12 regarding in-vessel effects after its review of WCAP-
13 16793 which is a topical report speaking to in-vessel
14 effects and ACRS asked a number of great questions to
15 the staff that led us to go back and reconsider our
16 own precepts about in-vessel effects which led us to
17 ask additional questions of the industry which they
18 responded to and that discussion goes on today as I
19 will talk about in a few minutes.

20 Another subject that has come up was with
21 regard to assumptions about zone-of-influence. Zone-
22 of-influence is the volume around a hypothesized break
23 within which insulation would expect to be disturbed,
24 knocked off the pipe and be available to transport to
25 the sump. The staff's safety evaluation in 2004

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 contained guidance for this subject. The licensees
2 who -- Some licensees attempted to credit a much
3 smaller ZOI which has had effects that I will talk
4 about on this slide.

5 Basically, licensees with a significant
6 amount of fibrous and particulate insulation sponsored
7 reports and testing done by Westinghouse and a lab to
8 attempt to justify with jet impingement testing a
9 greatly reduced zone-of-influence. Those reports were
10 referenced in the licensee's submittals, though were
11 not submitted to the NRC staff for review.

12 Nevertheless we asked to look at them and
13 we did that in 2008 and 2009 and identified a number
14 of questions and issues associated with the jet
15 impingement testing that was done. We spent a lot of
16 time interacting to attempt to resolve those
17 questions. We basically said towards the end of 2009
18 that we need to put this thing to resolution either --
19 you know basically Owners' Group come in and make your
20 best case why we should accept these reduced zones of
21 influence. And just parenthetically the reduced zones
22 of influence would reduce the volume potentially
23 affected by the break by over 90 percent. So we're
24 not talking a small effect. And the staff considered
25 therefore there needed to be a pretty high standard of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evidence that this zone-of-influence testing was
2 adequate and we had a lot of questions about whether
3 it really was adequate.

4 VICE CHAIR ARMIJO: Well, I just wanted to
5 get clear. Was the reduced zone of influence based on
6 a reduced break size? Was that their thing or was it
7 a pressure thing?

8 MR. SCOTT: They actually had a nozzle
9 test rig and they put a sample of insulation at the
10 out -- of the rig and it had I believe a blow-out
11 plug. So it was a jet impingement test that was
12 intended to --

13 VICE CHAIR ARMIJO: Just straight jet
14 impingement test. So for a given break size the zone
15 of influence --

16 MR. SCOTT: Would be much potentially.
17 They attempted to justify that -- The staff had in
18 2004 read the safety evaluation that said, based on
19 the information that we have available now previously
20 jet impingement testing, this is a conservative
21 reasonable zone of influence for this and it's
22 material specific. Some materials are much more
23 resistant to this than others.

24 So we had those -- Those numbers were
25 available to licensees, but there was a belief in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 industry that those numbers were unduly conservative.

2 So they sponsored additional testing to attempt to
3 show that the numbers were in fact overly
4 conservative.

5 VICE CHAIR ARMIJO: Okay.

6 MR. SCOTT: And the results they came up
7 with indeed reduced the zone of influence by again,
8 the volume, by over 90 percent since it's a spherical
9 assumption that's made here. And we asked questions
10 about that jet impingement testing. And I can't get
11 into too much detail about it today because it is
12 proprietary. Suffice it to say we asked and I think
13 this fourth bullet here speaks to that. They found a
14 design error, the vendor did, with the test loop and
15 we ended up concluding because of the design error and
16 the various unsolved questions that we had about the
17 testing that we could not accept the reduced zone of
18 influence that was proposed.

19 MEMBER BANERJEE: Let me say that if you
20 want we can at some point close the meeting because if
21 you want to understand the details of why the staff
22 came to that conclusion which I know about and which I
23 agree with.

24 CHAIR ABDEL-KHALIK: Is Mike prepared to -

25 -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: I have various staff here that
2 are indeed prepared to address that in detail if you
3 wish to take the time to do that today.

4 MEMBER CORRADINI: But I guess I want to
5 ask a general question before we close down. So it's
6 not pipe size. It's more the methodology of how the
7 test was done in reference. So is it fair to say that
8 the zone of influence that you were expecting to use
9 in these to estimate the debris inventory going in is
10 definitely conservative and the experiments that were
11 done by this group were clearly not conservative. But
12 it was unclear how they properly scaled. Is that --
13 What was the reason to reject the test?

14 MEMBER BANERJEE: That's the question. If
15 you want to answer, I think --

16 MEMBER CORRADINI: That requires a closed
17 session?

18 MEMBER BANERJEE: We might need to close
19 the session.

20 MR. SCOTT: There were specific issues
21 that we had with the test configuration and the way
22 the test was done and issues such as how you scale --

23 MEMBER CORRADINI: Okay.

24 MR. SCOTT: -- the testing up to the plant
25 size. There were various specific technical questions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that I think probably we need to discuss in a closed
2 meeting.

3 MEMBER CORRADINI: But is it fair to say
4 though that the original zone of influence calculation
5 that licensees are using to estimate their debris
6 volume they have to deal with is definitely
7 conservative?

8 MR. SCOTT: And you're speaking here of
9 the safety evaluation zones of influence, right?

10 MEMBER CORRADINI: Well, whatever they
11 used to determine their debris volume for the GSI --

12 MEMBER BANERJEE: The original guidance.

13 MEMBER CORRADINI: The original guidance.

14 MR. SCOTT: We believe the original
15 guidance is adequately conservative. I don't want to
16 say because I don't necessarily believe it to be the
17 case that it is, for example, grossly conservative or
18 highly conservative. There is various data. It's not
19 crystal clear as to just how conservative it is.

20 MEMBER CORRADINI: Has that data been --
21 Well.

22 MEMBER BANERJEE: We've looked at it,
23 Mike.

24 MEMBER CORRADINI: Okay.

25 MEMBER BANERJEE: We've looked at it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We've written on it.

2 MEMBER CORRADINI: Okay.

3 MR. SCOTT: Yes, that was in 2004.

4 MEMBER CORRADINI: And so the Committee
5 feels at that time that adequate is the proper
6 characterization of adequately conservative.

7 CHAIR ABDEL-KHALIK: If we are to go into
8 a closed session, I would prefer that we do it towards
9 the end of the presentation.

10 MEMBER BANERJEE: To you, Mr. Chairman.

11 CHAIR ABDEL-KHALIK: Thank you. So let's
12 proceed.

13 MR. SCOTT: Okay. I think we got most of
14 the way through this. We sent a letter to the Owners'
15 Group in early 2010 that said we don't accept this
16 testing and they are attempting to come in to talk to
17 us about a new test protocol and also a new analytical
18 method to use the test results to calculate zone of
19 influence. That will be a likely extended discussion
20 before we could get to the point of accepting that.

21 MEMBER POWERS: Mike, since the screens
22 are by and large installed and larger based on the
23 guidance debris, what is motivating the industry to
24 keep hammering away on this testing?

25 MR. SCOTT: The plants that have higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 amounts of fibrous material I believe would conclude
2 that they will struggle to show adequate strainer
3 performance even with larger strainers based on the
4 assumptions, the ZOIs, that we put out in 2004. There
5 is wide variance in the industry about the plant
6 configuration. Some of them started this problem with
7 virtually no fibrous insulation and they're done or
8 effectively done.

9 MEMBER POWERS: Yes.

10 MR. SCOTT: And others started with just
11 the opposite with a large load and honestly where we
12 are today is that we are down to less than half, as
13 I'll talk about, the plants remain unresolved. But
14 those by and large are the plants that are challenged
15 by having a larger amount of this material in their
16 plant.

17 MEMBER POWERS: I understand.

18 MEMBER RAY: Before you move on, I know
19 we're talking zone of influence. But you have
20 mentioned material here a couple of times. And the
21 slide does, too. Is concrete scouring included in
22 this testing or in the scope of what we're talking
23 about?

24 MR. SCOTT: I'm going to ask for staff to
25 speak to that because I don't want to misstate this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 John Lehning of the NRC staff.

2 MR. LEHNING: This scouring of concrete is
3 not something that's included in the source terms that
4 the plants are using, the operating reactors are
5 using. And the reason is that we don't think that
6 that source term is a very large and we have been
7 using conservative values for particulate for coating
8 and for other materials that are in the plant
9 condition. And we believe that those values of
10 conservatism and those values are very significant
11 compared to the amount of concrete particulate that
12 might get destroyed.

13 MEMBER RAY: Thank you.

14 MR. SCOTT: And, John, that's addressed in
15 our safety evaluation. Is it not?

16 MR. LEHNING: I don't believe that
17 concrete particulate is specifically called out in the
18 safety evaluation at all. That was a judgment that we
19 made in coming up with the safety evaluation guidance.
20 But I don't believe it's in the safety evaluation.

21 MR. SCOTT: Okay. Thank you.

22 MEMBER CORRADINI: Are we allowed to
23 discuss in open session the number of plants that are
24 on this borderline that you discussed because of the
25 zone of influence?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: Sure.

2 MEMBER CORRADINI: That kind of follows up
3 Dana's.

4 MR. SCOTT: That's public information.
5 There are 69 PWRs and as one of my later slides says
6 the staff considered 39 of the 69 to be effectively
7 complete. And I say effectively because of this in-
8 vessel issue which we'll talk about. But barring that
9 issue, 39 of 69 are done. Of the remaining 30,
10 probably and I'm not precisely sure here, but in the
11 vicinity of 15 or 20 have credited either this reduced
12 zone of influence or have credited debris settlement
13 that is in the test room allowed debris to settle out.

14 And that leads to additional questions. So it's one
15 or the other or both of those things. So the bulk of
16 the ones that remain have one of these issues going on
17 with them.

18 MEMBER CORRADINI: And the order of
19 magnitude of -- Well, I guess I want to get an idea.
20 Is there a metric to decide how close they are to a
21 concern? I mean the NPSH I assume is the final
22 metric. But in terms of zone of influence or debris
23 and debris at the target location are they far and
24 away? Because you mentioned that the zone of
25 influence change was a 90 percent change which is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fairly order of magnitude change? So are we talking
2 factors of two? Factors of ten?

3 MR. SCOTT: Factors of two on the head
4 loss?

5 MEMBER CORRADINI: Yes. That gets them
6 into difficulty. That's what I'm trying to --

7 MR. SCOTT: I kind of hesitate to try to
8 characterize that. You have a situation --

9 MEMBER CORRADINI: Is it all over the
10 map? Is that a fair way to --

11 MR. SCOTT: It is all over the map and
12 again we're talking about a case where there is
13 limited modeling because of the complexity and variety
14 of issues involved here.

15 MEMBER CORRADINI: Okay. Fine.

16 MR. SCOTT: So it's difficult to say, for
17 example, the impact of an additional pound of
18 insulation getting to the sump on the head loss. It's
19 very difficult to predict. So I'm a little reluctant
20 to try to characterize that.

21 MEMBER CORRADINI: Okay. That's fine.

22 MR. SCOTT: John Lehning, do you want to
23 add something? It looks like you're up there.

24 MR. LEHNING: No, no. I think you said
25 that right. I was going to say it really varies from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plant to plant. In some cases, extra debris may not
2 have a huge impact. In some case, small amounts of
3 debris to cover the strainer completely could have a
4 really significant impact. And so we can't give a
5 really specific answer to that question.

6 MR. SCOTT: Okay. Moving on --

7 MEMBER BANERJEE: Mike, when we come
8 towards the end and show you the process for closure.
9 They have a slide where I think you'll see that the
10 process is fairly robust, I mean.

11 MEMBER CORRADINI: I understand. I
12 remember that we reviewed that before.

13 MEMBER BANERJEE: Yes.

14 MEMBER CORRADINI: Dr. Shack said
15 something. So if I measured in terms of a percentage
16 of open area available is that another measure or?
17 I'm looking for a metric that kind of encapsulates all
18 of this.

19 MR. SCOTT: I believe that with the safety
20 evaluation assumptions that the plants that we're
21 talking about here will not have any open area on
22 their strainer. Now that doesn't mean they have
23 unacceptable head loss. They can have a full
24 filtering bed of debris and still have acceptable heat
25 loss depending on the plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. But the reason
2 they're getting near the ragged edge is because they
3 essentially have debris everywhere on their screens.

4 MR. SCOTT: I think that most of the
5 plants in this situation certainly if they use the
6 safety evaluation assumptions which again some view to
7 be overly conservative I believe that the result they
8 would obtain would be a fully covered strainer.

9 MEMBER CORRADINI: Okay. Thank you.

10 MEMBER POWERS: Mike, at the last meeting,
11 we learned that even being close to the limit on that
12 positive suction head was not necessarily a good
13 thing. Have you factor -- When you decide on the
14 acceptance criteria for the net positive suction head
15 allowable, have you factored in the wearing of rotor
16 blades?

17 MR. SCOTT: I don't know the answer to
18 that off the cuff. Does staff have an answer to that?

19 MR. RULAND: Dr. Powers, please repeat the
20 question.

21 MEMBER POWERS: It will be a struggle for
22 me to do that. Last month, we were discussing credit
23 for overpressure and we learned that when pumps
24 operate with what is -- the manufacturer declares
25 adequate net positive suction head but are close to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that limit that they get a wearing of the impeller
2 that of course degrades the performance over
3 sufficient periods of time. And I'm just wondering
4 when you set your acceptance criteria for having
5 adequate net positive suction head do you take into
6 account this impeller wearing effect in setting that
7 acceptance criteria?

8 MEMBER BANERJEE: Do you understand the
9 point, Mike?

10 MR. SCOTT: Yes, I understand the
11 question. I don't have the answer to it.

12 MR. DURHAM: We'll see if --

13 MR. SCOTT: It looks like one of our staff
14 members, Steven Smith, is going to come up and provide
15 an answer.

16 MR. SMITH: Yes. We compared only against
17 the required net positive suction head. I've been in
18 some of the meetings where some of the other NRR folks
19 have discussed the potential wearing that can occur
20 with up to maybe 1.6 times required. We only compare
21 against the manufacturer's net positive suction head
22 which would be basically one time. So we don't take
23 that into account.

24 MEMBER POWERS: Having learned about this
25 stuff should we?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SMITH: I think this is something new
2 that we have to consider.

3 MEMBER POWERS: Yes.

4 MR. SMITH: This problem was before we
5 knew about this phenomenon.

6 MEMBER POWERS: I understand.

7 MR. SMITH: So we haven't incorporated it
8 into our guidance.

9 MEMBER POWERS: It seems like I would put
10 that on my to-look-at list.

11 MEMBER BLEY: And that would include
12 coordination with the other folks we met with because
13 as I recall they had on their ticket to try to
14 investigate the length of time it might take to get to
15 any substantial damage or degradation under those
16 conditions. So I think if you guys would work
17 together that would be --

18 MR. RULAND: Since -- This is Bill Ruland,
19 Division Director from DSS. Both of these
20 organizations work for me.

21 So we will do whatever coordination we
22 need to do. Without belaboring the point of getting
23 to discussion about the erosion rates and those kinds
24 of things, we'll factor that in.

25 MR. SCOTT: It's a fair question to ask.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Something to bear in mind here is that there are many
2 subparts of determining acceptable performance for
3 this issue and there is a viewpoint in the industry
4 that the staff expects conservatism in each and every
5 one of them and I'll talk about that a little bit.
6 But what we try to do here because we know the
7 difficulty of this issue is to reach a holistic
8 conclusion and this would be potentially an input to
9 that review.

10 MEMBER POWERS: I suspect, I'm just
11 guessing, those plants that you think are resolved
12 will be resolved even in the 1.6 kind of criterion.
13 Those that are in trouble will be in trouble even at
14 the 1.0 criterion.

15 MEMBER BANERJEE: I suspect, Dana, that
16 you -- That is correct. Those who make it probably
17 make it.

18 MEMBER POWERS: Big time.

19 MEMBER BANERJEE: Big time. Those who
20 don't, don't make it big time. So I think this is --

21 MEMBER SHACK: Binary decision-making.

22 MEMBER BANERJEE: All right. Let's go on,
23 Mike.

24 MEMBER CORRADINI: Can I just ask one
25 other thing since I think Dana's point is well taken

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here. Is there anything on the staff's side to look
2 at the zone of influence and decision if adequately
3 conservative is potentially highly conservative or
4 analyzed in that regard in terms of source term of
5 debris?

6 MR. SCOTT: One of the actions that's the
7 Staff Requirements Memorandum put on our plate was to
8 -- Let me get the words exactly right here.
9 Determining the realistic zone of influence and the
10 need for additional testing.

11 MEMBER CORRADINI: Okay.

12 MR. SCOTT: So there is actually -- You
13 could resolve that in a couple of ways. One is to let
14 the industry do it which they are working on. And the
15 other is to sponsor it ourselves.

16 MEMBER CORRADINI: Okay.

17 MR. SCOTT: I believe that either way
18 that's a significant amount of time involved to get to
19 the endpoint on that, if we're going to change the
20 ones we have now. I believe the staff would support
21 the following view.

22 We don't believe when the final answer is
23 obtained that we're going to see a much smaller ZOI
24 than we have now. That's just our view based on what
25 we know about the current situation and what we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 observed from observing the testing and reviewing the
2 analysis that the industry has proposed. Our belief
3 is that we're not going to end up with a 90 percent
4 smaller volume or anything close to it. But that's
5 not a final.

6 MEMBER POWERS: I mean because it is a
7 spherical zone of influence it doesn't take much
8 smaller to change loading by quite a bit.

9 MEMBER CORRADINI: Yes. That's what I --

10 MR. SCOTT: I understand that, recognize
11 that. We don't believe they're going to end up being
12 a lot smaller than they are now. But that's to be
13 validated.

14 MEMBER BANERJEE: Mike, ACRS looked at
15 this in a fair bit of detail and there is a lot of
16 documentation available. And if anything they went
17 the other way. And there is a lot of stuff around
18 which I can make available to you. This was before I
19 was on the Committee.

20 MEMBER CORRADINI: Right.

21 MEMBER BANERJEE: My predecessors took a
22 very close look at this.

23 MEMBER CORRADINI: To the extent though
24 that I think the staff is looking at or deciding to
25 have the applicants look at essentially what Dana said

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that was learned from the BWR community I think to
2 look at this to see how far you are from -- it's still
3 worthwhile to at least review.

4 MEMBER BANERJEE: But again look at the
5 evidence. If anything it's the other way
6 unfortunately.

7 MR. SCOTT: And that's sort of a similar
8 perspective to our own.

9 MEMBER CORRADINI: So one other question.
10 The plants that -- the 39 versus the 30 to use that -
11 - mainly got it by replacing insulation or mainly got
12 it by increasing area or some combination of the two.

13 MR. SCOTT: I would say it would be most
14 accurate to say some combination of the two. Those
15 plants that started out with low amounts of fibrous
16 insulations which means high amounts of reflective
17 metal insulation had a relatively easy time with this
18 issue. Some plants recognizing the challenges posed
19 by the high amounts of fiber have made or are going to
20 make the changes to RMI.

21 However, it is also correct to state that
22 some plants that have a fairly significant amount of
23 fibrous insulation have shown adequate strainer
24 performance. There are a number of different strainer
25 designs out there. There are many different sizes of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strainers. The plant configurations are very
2 different one to another. This is an extremely plant-
3 specific issue.

4 MEMBER CORRADINI: Yes.

5 MR. SCOTT: So it's difficult to get to
6 one.

7 MEMBER CORRADINI: So it's not fair to say
8 -- Then it wouldn't be fair to say that going more to
9 RMI type, the non fibrous insulation, is a way out of
10 this from a practical modification standpoint.

11 MR. SCOTT: I think that modification by
12 removing fibrous insulation and replacing it with
13 reflective metal is a way out of this problem.

14 MEMBER CORRADINI: Okay.

15 MR. SCOTT: That entails cost obviously.
16 Financial cost. And exposure to cost that were spoken
17 to at the April 15th Commission brief and are
18 reflected in this Staff Requirements Memorandum that
19 we are to take a look at.

20 MEMBER CORRADINI: Thank you.

21 MR. SCOTT: We don't, of course, direct
22 any particular solution.

23 MEMBER CORRADINI: Sure.

24 MR. SCOTT: We simply say you need to show
25 adequate performance and with an adequate test and an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 adequate method of evaluating it and once you have
2 your methods down then your results tell you what you
3 need to do. And there are sometimes options and
4 removing insulation is not the only option, although
5 for some plants it may be the only real practical one.

6 But I don't want to leave you with the
7 idea that you can't succeed at this issue unless you
8 get rid of all your fibrous insulation because there
9 are plants that have succeeded while not removing much
10 or all fibrous insulation.

11 Okay. The next issue in-vessel effects.
12 I talked a little bit about this before. We had
13 Revision 0 actually submitted in 2007. ACRS had
14 concerns with it. Staff asked questions about
15 Revision 0. And that ended up sending in, the Owners'
16 Group sent in Revision 1 for our review of this
17 topical report.

18 And we had questions about that. And so
19 we sent those out to the industry and they have
20 subsequently responded. We pushed them to do
21 additional testing. A limited amount of testing had
22 been done and this is sort of similar to the strainer
23 testing in that obviously you can't test in the plant.

24 So you take a mock-up of a fuel assembly. You put it
25 in a test rig. And you run debris up against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basically the way the debris would come in through the
2 ECCS system into the test rig and evaluate the head
3 loss against criteria for the fuel for the vendor fuel
4 types.

5 So there has been a substantial amount of
6 testing. Now the testing -- And again we're going to
7 verge here on proprietary. So I may have to say
8 separate discussion here. But I'll go as far as I can
9 here.

10 There are two vendors of fuel in the
11 United State for PWRs, Westinghouse and AREVA. And
12 the testing initially focused on Westinghouse fuel and
13 there was an assumption I think on the part of the
14 Owners' Group and even on the staff's part that the
15 vendor fuels would behave the same way or very
16 similarly and that based on the test results that were
17 obtained for AREVA in 2010, early 2010, that did not
18 turn out to be the case. So that's the latest hurdle
19 that has been put in the way of resolution of this
20 issue.

21 Most parties believe that the difference
22 in behavior between fuel types is related to the
23 design of the fuel. But there are enough
24 uncertainties about that especially given the fact
25 that the two fuel types were not tested in the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 facility that the staff strongly advised the Owners'
2 Group to run what we call a cross test. Take one
3 guy's assembly and put it in the other guy's test rig
4 and see what happens.

5 One of the vendors has agreed to do that.
6 The other has not. And we are currently discussing
7 at a management level that situation.

8 CHAIR ABDEL-KHALIK: Discussing is a good
9 idea.

10 MR. SCOTT: Discussing it in a management
11 level.

12 CHAIR ABDEL-KHALIK: No.

13 MEMBER CORRADINI: Because that's a
14 foregone conclusion.

15 CHAIR ABDEL-KHALIK: The cross testing.
16 This is not a joke.

17 MR. SCOTT: I understand.

18 CHAIR ABDEL-KHALIK: Is that a good idea?
19 Can you assure the integrity of these experiments
20 when self-interest is involved?

21 MR. RULAND: Typically when these tests
22 are performed, when they were originally performed,
23 the NRC staff observed these tests. And it would be
24 the intention of the NRC staff to observe any cross
25 test that would be performed. So we'd be taking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whatever precaution. We believe we're independent and
2 we've demonstrated that in the past. And so what
3 observations we make will be the observations we make
4 about the tests.

5 VICE CHAIR ARMIJO: Are you convinced that
6 the reproducibility is established in the test? Let's
7 say one was satisfactory. One was not. That the
8 satisfactory one was done more than a few times would
9 give you reproducible results. I'm not so sure.

10 MR. SCOTT: There were a number of tests
11 done for each of the vendors. So, yes, we are --

12 VICE CHAIR ARMIJO: So you have real
13 confidence that they really are behaving differently
14 either because of the test setup or the design of the
15 fuel or some combination of that. But there are
16 really two different results that were kind of
17 unexpected.

18 MR. SCOTT: Well, let me go back a little
19 further and this will address your question further.
20 As I think Bill Ruland said, we have closely
21 evaluated, observed, the test rigs which are
22 substantially identical. We tasked the Owners' Group
23 with coming in with an evaluation of the differences
24 between the test rigs, again, from the perspective of
25 identifying whether it is in fact a design issue which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they claim, they the Owners' Group, or whether there's
2 a possibility that there is a test issue impacting
3 this.

4 And they came in with a few minor
5 differences and we've considered those. We believe as
6 they believe that it is likely a design difference.
7 But we are not --

8 VICE CHAIR ARMIJO: A fuel design
9 difference.

10 MR. SCOTT: Yes. I'm sorry. Yes. A fuel
11 design difference. But we would like to reduce the
12 uncertainties involved with that by running this cross
13 test to in fair part take the question off the table
14 as to whether there is an undetected, an unknown
15 unknown difference between the test rigs that's
16 causing this impact. We don't think that's what it
17 is. But we want to eliminate it as a source of
18 uncertainty.

19 VICE CHAIR ARMIJO: Will we ever review
20 this at this level of detail the kind of fuel testing
21 that's done?

22 MEMBER BANERJEE: Of course.

23 MR. SCOTT: Yes, we will be coming before
24 you I believe in -- the last time I heard it was
25 October-ish of this year, again, assuming that this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issue gets resolved and we can go forward with the
2 safety evaluation. We do have a draft safety
3 evaluation, but it has open items in it awaiting
4 resolution of this question, particularly this
5 question.

6 We're not fully comfortable with where
7 this is. Again, the data shows one thing, but we want
8 to be largely confident that there's no test issue
9 here, test configuration issue. So assuming that the
10 Owners' Group eventually manages to work around to
11 agreeing and the vendors involved to agree to run the
12 test, then we will I believe taking a look at the test
13 plan and we'll be observing the test and we've already
14 observed the test rigs. We believe they're very
15 similar.

16 MEMBER BANERJEE: Again, if you want more
17 details at the end we can close the meeting and they
18 can tell you more about that.

19 VICE CHAIR ARMIJO: Yes. I would like to
20 find out.

21 MR. SCOTT: Okay. So our goal is to have
22 a safety evaluation out in 2010. The current timeline
23 makes that's very challenging because we're coming to
24 you with a draft safety evaluation out in the fall
25 sometime and then there needs to be time for your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review and your letter. So trying to get all this
2 done by the end of the year because of what's
3 transpired will be very challenging. But that's still
4 our goal.

5 MEMBER BANERJEE: There are always
6 surprises.

7 MR. SCOTT: Yes. And that's the nature of
8 this and look at the bottom bullet of this slide.
9 There it is. Every time we turn around there are
10 surprises.

11 So why is this issue so -- Why is it still
12 around a decade after, over a decade from, when GSI-
13 191 issued? Why are we still here? This slide speaks
14 to some of that.

15 There are numerous phenomena involved. We
16 talked about some of them, the debris generation
17 itself, zone of influence assumptions, how you
18 characterize the debris, how do you treat latent
19 debris, you know, the debris that's in the plant and
20 not necessarily in the insulation on the piping, how
21 is it transported. I talked about some licensees have
22 attempted to credit settlement of debris in the test
23 flume, but then the burden is on them to show that
24 that settlement is representative of what would
25 actually happen in the plant. And that's proven

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 challenging.

2 Strainer head loss and vortexing. There
3 are various calculations involved there in the testing
4 itself. Chemical effects that we talked about with
5 the Committee a number of times. I think we believe
6 we have a handle on that now and despite our
7 expectation a couple years ago the chemical effects
8 would be the long pole in the tent so to speak. GSI-
9 191 we don't currently see that as the case.
10 Licensees know how to evaluate it and they are
11 evaluating it. And then there's the in-vessel effects
12 issue.

13 It's also a problem and I referred to this
14 earlier because there are no reliable models for some
15 aspects of the problem. It would be very useful to us
16 to have models. We have attempted to develop some
17 over the years, but we have not had substantial
18 success in developing models because of the complexity
19 of this issue. It makes it very difficult to predict
20 what any delta in the conditions is going to have as
21 an impact on the problems.

22 A little bit goes a long way. That's
23 bullet number three. Small amounts of certain
24 materials make a big difference potentially to the
25 strainer performance. You have a slowly increasing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 head loss and add a little more debris and you
2 continue to see a slowly increasing head loss. And
3 then you get your filtering bed and the head loss goes
4 way up. And that point is difficult to predict.

5 And the last bullet that I mentioned
6 before and that Dr. Banerjee referred to is that we've
7 had all kinds of surprises. Our initial expectation
8 in a number of aspects of this problem have not been
9 born out. And that has caused us to have to come up
10 with plan B and plan C and so on.

11 MEMBER POWERS: I presume that you would
12 be suspicious of massively parallel computer
13 calculations of this particular --

14 MR. SCOTT: Well, that would certainly
15 need a lot of validation.

16 Because there's not a good track record
17 with that in the past. But if you have something in
18 mind.

19 MEMBER POWERS: Yes. The ability to test
20 facilely.

21 MR. SCOTT: Dr. Banerjee mentioned we had
22 a simple graphic here on our review and closure
23 process. And here's the good news. This process
24 works and the previous processes did not. I mentioned
25 that in 2008 we got the supposedly final supplemental

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 responses, reviewed them, had a number of issues with
2 them, issued RAIs and the licensee responses came back
3 and we looked at them and in many cases they did not
4 answer the question that was asked. And in fair part
5 we attribute that to the degree of difficulty of the
6 technical issue involved here.

7 So we came up with, okay, this isn't
8 working. Now what are we going to do? So we
9 basically came up with what we call the interactive
10 review process and the interactive review process is
11 somewhat resource intensive. But it basically
12 required the licensee and the staff to sit down over
13 the draft RAI responses and review them in detail and
14 carefully record any issues that exist with those
15 draft responses. So then when the licensee sends in
16 the final responses there's a high confidence factor
17 that the staff will find them acceptable.

18 We've done that. It works. It results in
19 challenging all-day phone calls or even more than one
20 day, day and a half calls, and face-to-face meetings.

21 It is bringing these plants to closure one at a time.

22 And again closure with an asterisk because of the in-
23 vessel effects issue.

24 The other somewhat different approach that
25 we have taken to try to reach closure here we refer to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on this slide as Integration Review Team. The
2 industry has stated at various times that the staff is
3 piling conservatism on conservatism in its review of
4 this issue. I talked about all the various review
5 areas. Debris generation, debris transport, heat loss
6 and vortexing, NPSH, every one of those areas has a
7 staff reviewer who does a detailed review of it. We
8 have put a rather large level of detail into our
9 review here because of the factors that I talked about
10 on the previous slide.

11 So the assertion has been made that you
12 staff people you want them to be conservative in each
13 and every area. And if they're conservative in each
14 and every area, then the end result is hugely
15 conservative. And this was the assertion that was
16 made in the April Commission brief.

17 Over a year ago, I think actually two
18 years ago, we recognized the potential for that to
19 occur and so we instituted this IRT or Integration
20 Review Team. And what that involves is after the
21 staff has done their detailed reviews and generated
22 proposed RAIs, then the IRT which is made up of three
23 senior level people here on the staff not directly
24 involved in the reviews, but nevertheless
25 knowledgeable about the sump issue, sit down as a team

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and review the staff's inputs in each of the areas
2 that I talked about of which there are actually a
3 total of about a dozen. And then the IRT weighs
4 whether given the conservatisms and the potential
5 nonconservatisms and uncertainties whether the
6 licensee has shown that its strainer performance is
7 adequate. And then it was intended to take the
8 excessive conservatism piece off the table.

9 This process also has worked, although it
10 has limitations. It works well when the licensee
11 reduces the number of open questions or unresolved
12 RAIs to a very small number such that it is clear to
13 this objective team that overall the strainer
14 performance evaluation is conservative and therefore
15 the strainer performance can be relied on. In those
16 situations, it works. It has worked again and again.

17 We have considered plants done with this even though
18 there are some potential nonconservatisms or
19 uncertainties in their resolution.

20 On the other hand, if a licensee has 35 or
21 40 questions about their strainer performance and the
22 staff would not be asking these questions if we didn't
23 think they were potentially significant, it is very
24 difficult for the staff to then balance those 35 or 40
25 against the 35 or 40 conservatisms and conclude, yes,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they're done. Remember no model here. So it's very
2 difficult to make that balancing act if they have a
3 lot of questions.

4 We use as shown in this graphic the
5 processes in concert. We use the interactive review
6 process to reduce the number of open issues to a small
7 number and hopefully small and less significant and
8 then we can use the IRT to say, yes, there's done.
9 And this process does work. And it has worked. That
10 doesn't mean however if the plant has a large amount
11 of fibrous insulation that this is an automatic path
12 to resolution with the plant in its existing
13 condition.

14 Recent developments. As we talked about,
15 we briefed the Commission on GSI-191 on April 15th of
16 this year. Licensee -- there were three stakeholder
17 people Licensees were two of the three and the
18 stakeholders came in basically and said to the
19 Commission that their view is that GSI-191 is no
20 longer a safety issue and that the staff is in pushing
21 for near-term closure of this issue with consideration
22 of, for example, our rejection of the ZOI reduction
23 reports that are push for closure would result in --
24 well, the statement was made -- replacement of
25 effectively all the fibrous insulation at some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these plants. Now, we don't necessarily believe that
2 to be the case, although some plants might indeed need
3 to take it all out. And as a result there would be a
4 large radiation exposure to plant personnel. Those
5 statements were made to the Commission. And the
6 Commission has subsequently asked us to evaluate those
7 and we are doing that.

8 Another activity that occurred or another
9 proposal that came in right about the same time as
10 that Commission brief was a proposal that the staff
11 allow application of leak-before-break to sump
12 performance evaluations. And I'll talk about that
13 specifically in an upcoming slide.

14 So we got the staff requirements
15 memorandum that I believe Dr. Banerjee said he
16 provided to all of you. We are tasked to report to
17 the Commission by August 27th of this year on a number
18 of aspects and approaches to closure including the
19 realistic ZOI that we already talked about, the
20 application of GDC-4 which we will talk about, how we
21 resolve in-vessel effects, to what extent we can risk-
22 inform the resolution and that discussion includes the
23 proposed 10 CFR 50.46(a) rule, alternative regulatory
24 treatment of in-vessel effects which we have
25 interpreted to mean the potential for carrying that as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a separate issue and resolving it separately from
2 strainer performance.

3 MEMBER CORRADINI: Can you say that again?

4 I didn't understand that phrase. So what do you
5 interpret that to mean again? I'm sorry.

6 MR. SCOTT: Alternative regulatory -- In
7 other words, split this out as a separate issue.

8 MEMBER CORRADINI: Okay.

9 MR. SCOTT: I'm sorry.

10 MEMBER BANERJEE: In other words, close
11 off.

12 MEMBER CORRADINI: Declare a victory and
13 then declare a new problem.

14 MEMBER POWERS: And start over.

15 MEMBER SIEBER: Right.

16 MR. RULAND: Hopefully we wouldn't have to
17 start over.

18 MEMBER BANERJEE: I don't think the staff
19 is going to go for that. Carry on.

20 MEMBER CORRADINI: I just wanted to
21 understand what it meant.

22 MR. SCOTT: That's our interpretation.

23 MEMBER CORRADINI: Okay.

24 MR. SCOTT: And then I already talked
25 about the dose impact. Again, assertions were made

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that a large dose would be incurred to remove
2 insulation on the assumption that you have to remove
3 it all. So we've been tasked to evaluate that as
4 well.

5 We are developing requested information
6 and we'll be obviously making a recommendation to the
7 Commission in late August. So that's what we're all
8 about right now.

9 The other thing that's actually not
10 mentioned in here is that the staff requirements
11 memorandum says continue working the plant specific
12 issue resolution process that we're already doing. So
13 while we're working on this -- While a fair number of
14 the staff are working this SECY paper to provide the
15 options and the recommendations to the Commission, the
16 others are continuing to work with the plants and we
17 are continuing to achieve closure of them one at a
18 time.

19 MEMBER BANERJEE: Are you going to say
20 something about the last error in the SRM, first, with
21 regard to the BWRs but of course that's not all that
22 important? But that cryptic statement should consult
23 with CRGR as appropriate to assure compliance with the
24 backfit requirements. What does that mean in your
25 view exactly?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: That was an expression of
2 sensitivity to whether we have gone beyond the point
3 where we should be consulting with CRGR before we
4 pursue our current path on issue resolution. In other
5 words, the CRGR was consulted back in 2004 for the
6 generic letter. Have we gone beyond that because
7 additional issues have come up that are briefly
8 referred to the generic letter but whose significance
9 was not known at the time of the generic letter? And
10 now chemical effects have been found to be a problem.

11 In-vessel effects have been found to be a problem.
12 And we have not gone back to the CRGR since 2004.

13 So there is a sensitivity here as to
14 whether we should do that. And so we are in fact
15 going to consult with the CRGR and baseline ourselves
16 as to where we are now with regard to backfit.

17 MR. RULAND: Mike, could you explain just
18 a little bit about what CRGR is and what its role is?

19 MR. SCOTT: Okay. I'm sorry. The CRGR
20 stands for the Committee to Review Generic
21 Requirements which is intended to provide appropriate
22 oversight of staff attempts to backfit onto the
23 industry.

24 MEMBER CORRADINI: So that means -- I'm
25 still not sure that some of us appreciate this. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what?

2 MR. SCOTT: I guess the bottom line is we
3 will go to the CRGR and we will ask them for their
4 input on whether we need to be invoking the backfit
5 rule for 10 CFR 50.109 which contains requirements for
6 analyses for the staff to proceed along a given path
7 that we proposed to take that could potentially result
8 in licensees having to making plant changes.

9 MR. RULAND: In simple terms, if a
10 requirement -- there are certain exceptions to the
11 backfit requirements to do cost/benefit analyses and
12 those exceptions typically are you don't have to do a
13 cost/benefit analysis if it's required for compliance
14 or if it's required to assure reasonable assurance of
15 adequate protection. Otherwise the staff is required
16 to be able to show that it is a substantial safety
17 benefit to backfit a licensee for a certain set of
18 modifications.

19 So what was posed to us we believe in this
20 question is given all the modifications that have
21 already taken place are we now at a point that we need
22 to relook at the backfit rule and whether or not
23 additional modifications vis-a-vis dose and cost
24 associated with insulation whether the backfit rule is
25 in play now. So staff to make sure that we're still

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on solid ground we're going to meet with the Committee
2 to review generic requirements prior to the Commission
3 paper going out.

4 MR. SCOTT: Just for additional
5 perspective Generic Letter 2004-02 was issued under
6 that backfit compliance exception that Bill Ruland is
7 talking about.

8 MEMBER CORRADINI: So just to be clear,
9 following the instructions from the Commission or the
10 Commission directive, it would go back. It would get
11 looked at. Then all current changes that have been
12 already instituted will be added up compared to what
13 might have to be done to determine whether you have to
14 essentially to relook at the backfit.

15 I don't -- I understand what you're said.
16 I'm just trying to understand how this all plays out.

17 MR. RULAND: Exactly how this is going to
18 play out is something we're going to have to develop.

19 MEMBER CORRADINI: Okay. Thank you.

20 MR. RULAND: Basically the staff is going
21 to develop a strategy about how we're going to answer
22 this question. And it would be premature at this
23 point for us to say how we're going to answer it.

24 MR. SCOTT: But those changes that have
25 been made to date have been made. So the question is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this whole series of question exist because the staff
2 took a view in early 2010 that we needed to bring this
3 issue to closure for all the licensees. And we took a
4 strong point of view on that and considered various
5 regulatory paths forward that were of concern and that
6 potentially could result in additional plant changes.

7 And the Commission has asked us to provide them as
8 you can see from these information points here.
9 They've asked us to provide them the information for
10 them to make a policy decision as to whether the path
11 the staff took before or some other path would be the
12 best one to go forward. And this backfit is a part of
13 that.

14 MEMBER CORRADINI: Thank you.

15 MR. RULAND: Just if I mean, Mr. Chairman,
16 just add one specific item to this matter. The staff
17 was intending to use a certain type of letter that's
18 in license conditions in 10 CFR that would require
19 licensees to respond to us about how they were going
20 to bring this to closure. And those letters were
21 drafted and we were moving forward with those letters.

22 And we even described that approach in the
23 Commission meeting.

24 And the reason we were taking that
25 approach is we were asked by our management we want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get this thing, attempt to get this issue, closed in
2 2010. And that was our vehicle to do this.

3 MR. SCOTT: And it's actually specifically
4 addressed in the staff requirements memorandum. Those
5 are -- The rule that he's referring to is 10 CFR
6 50.54(f) and the second paragraph of the SRM says,
7 don't do that until you get further direction from the
8 Commission. So we are holding those up awaiting that
9 direction. And there's a process to clearly go
10 through to get there.

11 MEMBER CORRADINI: Thank you.

12 CHAIR ABDEL-KHALIK: What is ACRS' role in
13 responding to or evaluating or reviewing whatever you
14 come up with on these issues?

15 MR. SCOTT: The ACRS has no specified role
16 in the SRM. I'm sure I'm not telling you something
17 you don't already know. Clearly, you can write a
18 letter on it if you choose.

19 CHAIR ABDEL-KHALIK: Okay.

20 MR. SCOTT: I think we've talked about
21 this one. Moving on.

22 CHAIR ABDEL-KHALIK: So does the time line
23 allow for you to present sufficiently detailed and
24 well formulated answers to these various issues for
25 ACRS review to afford us the opportunity to comment in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 writing on your response?

2 MR. RULAND: No. We have a very short
3 time line for this Commission paper that the
4 Commission has imposed upon us. And if you work
5 backwards, it's the end of August. So basically the
6 end of July this has to be in concurrence which
7 essentially means by the end of this month the staff
8 will have completed the formulation of our response.

9 CHAIR ABDEL-KHALIK: That, of course, does
10 not prevent us from commenting after the fact.

11 MR. RULAND: That's correct. Thank you,
12 Mike.

13 CHAIR ABDEL-KHALIK: Thank you. Please
14 continue.

15 MR. SCOTT: Okay. Where are we? A lot of
16 this we already talked about. Thirty-nine of 69 are
17 basically done. That number goes up two or three
18 plants a month. However, we are getting down to the
19 challenging plants here. So it may be one of those
20 asymptotic kind of curves.

21 MEMBER RAY: Excuse me. This doesn't
22 include certified designs that are --

23 MR. SCOTT: No. This is only existing
24 operating reactors.

25 MEMBER RAY: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: We are closely integrated with
2 new reactors. They sit in on our meetings. We are
3 sending a person to observe a foreign strainer test in
4 support of their work. So we are integrated with
5 them, but it's a separate proceeding.

6 MEMBER RAY: Well, what everyone said
7 about time lines is of some interest to me in
8 particular because of new reactors.

9 MR. SCOTT: Right.

10 MEMBER RAY: So I was trying to get at
11 whether you were focused on that at all. It sounds
12 like that process is just observing what you're
13 reporting to us today.

14 MR. SCOTT: Is there someone from new
15 reactors in the audience that would care to speak to
16 this?

17 MEMBER SIEBER: No.

18 MEMBER RAY: I asked but they don't want
19 to speak to it. That's okay.

20 MEMBER BANERJEE: You don't want to put
21 them on the spot right now.

22 MR. SCOTT: So clearly as you're aware the
23 sump performance issue is being evaluated by new
24 reactors people and I believe for some of the plants
25 it is one of the more thorny issues to address. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm really not prepared to go much beyond that other
2 than to say we talk to them a lot and they talk to us
3 a lot.

4 MEMBER RAY: Okay.

5 MR. SCOTT: I think that would be a
6 separate briefing.

7 MEMBER BANERJEE: In the interest of time,
8 we might need to take that up separately.

9 MEMBER RAY: That's fine. I just want to
10 be clear.

11 MR. SCOTT: Okay. I think all the rest of
12 the bullets on there we've talked about. Refinements.
13 We've talked about -- Refinements are sort of a word
14 that I tend to use to talk about we're not real happy
15 with the assumptions that are made and the evaluation
16 methodology. How can we change them to remove
17 conservatisms because that's what these refinements
18 are about?

19 We talked about the jet impingement
20 testing, the third bullet, already. I said we would
21 talk about leak-before-break and 50.56(a). So to talk
22 about leak-before-break, I think we already mentioned
23 that the industry proposed that we reconsider GDC-04
24 application to some performance evaluations.

25 What you see in the second bullet is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 literal quote from the regulations regarding
2 application of leak-before-break. This has been
3 sought in the past with regard to treatment or use for
4 sump performance evaluations and the NRC has twice
5 previously rejected it. We took the position that the
6 credit sought was not consistent with the Commission's
7 intent when it approved the rule. And so we denied
8 it.

9 Now in 2010 the industry has come in again
10 to ask for this approval. And as you know it's in the
11 Commission's staff requirement memorandum. So we will
12 be reporting to the Commission on it.

13 Why have we in the past had concerns about
14 it? The original intent was to allow removal of
15 specific equipment, pipe whip restraints, whose
16 presence was adverse to being able to adequately
17 inspect the pipes and whose presence was not
18 considered to be necessary.

19 If credit for sumps were allowed, it would
20 remove some break locations from consideration for
21 sump evaluations. That's good potentially for
22 licensees that have fibrous insulation remaining to
23 the extent they can take some of those insulation
24 configurations off the table for this issue.

25 MEMBER CORRADINI: So can you just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 illuminate for some of us that don't have background
2 why some because of where the pipe restraints are
3 relative to the break location? I don't understand
4 why it's some.

5 MR. SCOTT: It says some break locations.

6 Okay.

7 MEMBER CORRADINI: Yes.

8 MR. SCOTT: In order to -- And you'll mine
9 my database pretty quickly here. But in order to
10 achieve credit for LBB the licensee must provide
11 assurances that in fact it will be validate that there
12 will not be a break. High confidence there will not
13 be a break. And so they need to get that. They need
14 to submit that to the Commission for approval to have
15 credit for it. And it's somewhat plant-specific,
16 although there are limitations on it.

17 VICE CHAIR ARMIJO: But I thought that was
18 really dependent on the properties of the material,
19 the ductility in the material that defined whether you
20 had a leak-before-break situation or a brittle.

21 MR. SCOTT: The material is part of it.
22 The inspection requirements are part of it and
23 geometry.

24 MR. RULAND: And whether there is an
25 active degradation mechanism that hasn't been fully

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 addressed.

2 VICE CHAIR ARMIJO: Yes, like IGSCC,
3 PWSCC.

4 MR. RULAND: Right.

5 VICE CHAIR ARMIJO: That's been -- Those
6 have been the reasons why we had pipe cracking and I'm
7 just wondering what is the industry trying to say.
8 Just that would just reduce the number of locations
9 that they could possibly exclude from this risk.

10 MR. SCOTT: That's correct.

11 VICE CHAIR ARMIJO: Or it would reduce the
12 size of the break.

13 MR. SCOTT: No, they would take some
14 breaks off the table. And it is depended on the size
15 of the pipe.

16 VICE CHAIR ARMIJO: Sure.

17 MEMBER CORRADINI: So the basis by which
18 you rejected this one and they tried this twice before
19 was?

20 MR. SCOTT: It was we looked at the
21 statements of consideration that the Commission had
22 issued with the regulations and based on our views of
23 what the Commission intended which again it was almost
24 like removing those pipe restraints was almost a
25 guaranteed safety benefit. And this is not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guaranteed safety benefit. You could argue that it is
2 removing some defense-in-depth and that was the
3 staff's view of it. And the staff looked at the
4 guidance from the Commission and concluded that was
5 what the Commission had in mind and the staff had
6 concerns about it as well and therefore we did not
7 accept it.

8 MEMBER BANERJEE: Mike, there is also, I
9 mean, for your information letters from various groups
10 who show that things have leaked and nothing has been
11 done and there's all sorts of issues here which I
12 think the staff's position is fairly extensive.

13 MEMBER CORRADINI: I understand. But the
14 staff position -- I understand that I guess, but the
15 staff position is there was no accrued safety benefit
16 from this request. Whereas in the piping restraints
17 there was an obviously accrued safety benefit. Is
18 that what -- I want to make sure --

19 MR. SCOTT: I guess that's a fair way of
20 saying it. Yes. I believe that would be adequate.

21 MR. RULAND: In addition, the staff
22 believes that at this point if you were to use credit
23 for leak-before-break it is a policy issue that would
24 have to be approved by the Commission.

25 MR. SCOTT: And clearly this SECY would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a vehicle for that to happen.

2 MEMBER CORRADINI: Okay. Thank you.

3 MR. SCOTT: So we are evaluating this.
4 We also -- In addition to getting the input from the
5 Nuclear Energy Institute we got an input from the
6 Union of Concerned Scientists with a somewhat
7 different view and we're evaluating that, too. And
8 we're taking a look at it from the staff's experience
9 with this issue, as was referred to the various
10 material issues that have come up over the past few
11 years, and taking all that into account. And we will
12 make a recommendation to the Commission on this and
13 all the other items that are out there.

14 Obviously, since we've rejected it twice
15 for what we thought were good reasons at the time it's
16 not a trivially-easy matter to approve it at this
17 time. But we are taking a fresh look at it.

18 Now I'm going to talk about 50.46(a) which
19 is the risk-informed ECCS regulations that are
20 approaching final rulemaking. The existing
21 regulations, of course, require evaluation of a
22 double-ended guillotine break of the largest pipe in
23 the RCS as a design basis LOCA accident. And it must
24 include, you see, the things on the slide here,
25 assumption of loss of offsite power, worst single

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 failure and credit only for safety-grade systems. The
2 last one kind of tends to be key in this discussion
3 which we'll talk about.

4 The proposed risk-informed regulations
5 would change the side of the largest pipe break that
6 must be evaluated as a design basis LOCA which is
7 referred to as a transition break size. For breaks
8 larger than that, the evaluations could be performed
9 with realistic inputs, no longer require assumption of
10 a single failure, without assuming loss of offsite
11 power and taking credit for non-safety equipment.

12 How can this play out in the sump problem?

13 One example would be sump plants have a backflush
14 capability that's non-safety grade. And so there
15 would be potential here incorporating that. So there
16 is potential use to the licensees if this rule is
17 issued and I think my next slide speaks to the --

18 MEMBER BANERJEE: So the break size is not
19 going to make a huge difference. It would be
20 primarily the non-safety grade equipment used from
21 what I can see there.

22 MEMBER SIEBER: Right.

23 MR. SCOTT: You may well be right with
24 that. There is already a risk-informed alternative to
25 the deterministic evaluations in our safety evaluation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we issued in 2004. So this was already open to
2 the licensees. Now there are some differences between
3 where this proposed 50.46(a) would go and where the
4 previous rule or previous guidance went with regard to
5 that subject.

6 The exact amount of benefit that this
7 would have for the licensees (1) is plant specific
8 depending on the plant situation and (2) is under
9 current discussion within the staff. So I can't
10 convey to you a staff position today as to our views
11 on the usefulness of this. I may be useful for some
12 licensees.

13 You may be interested to know that the
14 industry having suggested leak-before-break to us,
15 having heard the subject of 10 CFR 50.46(a) come up at
16 the Commission meeting, sent another letter and said
17 we think that LBB is the better choice here because
18 it's much nearer term than would be this new proposed
19 rule. Although it says here on the slide the staff
20 expects to send a proposed rule to the Commission in
21 December of this year, the final rule, the question
22 remains as to whether there would be need to be
23 implementation guidance. And again there are
24 differing views on that subject that we're trying to
25 work out now within the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIR ARMIJO: I just want to make
2 sure that I understand. One of the numbers I've heard
3 on the transition break size for the 50 --

4 MEMBER BANERJEE: Fourteen inches.

5 VICE CHAIR ARMIJO: It's 17 I heard. But
6 let's say it was 17 versus a 28 inch pipe. That
7 surely would have a huge difference on the zone of
8 influence, wouldn't it, and the amount of debris
9 generated?

10 MR. SCOTT: Yes, potentially so. But
11 here's one of the issues that comes up. There has
12 been a -- Licensees tend to -- Or maybe it's
13 licensees, maybe it's industry, tend to take the view
14 that if we can fix the double-ended guillotine break
15 assumption here, that we'll get done with this
16 strainer problem and we can declare victory. The
17 problem is as I referred to several times earlier in
18 the presentation a small amount of this debris can go
19 a long way.

20 VICE CHAIR ARMIJO: Yes.

21 MR. SCOTT: And so it is possible that a
22 large-small break could cause strainer performance
23 issues. So we can't conclude that hey, if we can just
24 take double-ended guillotine break off the table,
25 we're done. We're not prepared to go there. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 again there are voices who say, this is not a safety
2 issue anymore. You should be walking away right now.

3 We're not prepared to go there.

4 MR. COLLINS: This is Tim Collins from the
5 staff. The proposed 50.46(a) still requires that
6 licensees demonstrate the ability to mitigate a
7 double-ended guillotine break. It's just that there's
8 relaxed smaller -- in the analysis. So the largest
9 break size would still need to be addressed under
10 50.46(a).

11 VICE CHAIR ARMIJO: But I thought the
12 largest --

13 MR. SCOTT: Potentially not under LBB.

14 MR. COLLINS: Well, LBB is a different
15 issue.

16 MEMBER SIEBER: That smaller break size
17 doesn't necessarily mean that a proportionately
18 smaller amount of debris generation because blowdown
19 is extended for longer periods of time and some of the
20 debris generation comes from the fatigue of the
21 components and so forth. It takes some time.

22 MR. SCOTT: That's a part of the picture.
23 The other part is that that even if it does result in
24 less debris you get this potential thin-bed effect
25 that we've observed. Less could be worse potentially.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Depending on the
2 composition.

3 MR. SCOTT: And depending on the strainer
4 and all these other things. See, that's one of the
5 thorniest parts of this issue is just --

6 MEMBER SIEBER: Right.

7 MEMBER BANERJEE: I think we're going to
8 have to keep moving, Mike.

9 MR. SCOTT: I think we're almost done.

10 MEMBER SIEBER: Yes.

11 MR. SCOTT: Okay. So path forward. We
12 talked the uncertainties in strainer performance have
13 challenged closure of this issue for some plants.
14 Again, we're over halfway done. We're approving one
15 or two plants per month moving forward. That rate may
16 drop off especially pending the resolution of the path
17 forward as we talked about with Commission guidance.

18 The staff believes that inadequate
19 strainer performance can challenge long-term core
20 cooling and maintenance of core integrity. When you
21 take that into account along with the uncertainties
22 that we've talked about we are not to the point of
23 agreeing with the assertion that was made in the
24 Commission meeting of April 15th of this year that
25 GSI-191 is not a safety issue and we should be just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done with it. We would love to be done with it.
2 We're not at that point yet. We are at that point for
3 many plants but not for all of them.

4 We will continue consistent with
5 Commission direction our successful plant-specific
6 issue resolution process. We believe we have a good
7 process and it's working.

8 We do need to resolve the in-vessel
9 effects issue. I've talked to you about the
10 challenges that stand in the way of that. We are
11 working as best we can to resolve those and get that
12 in front of you because you will be on our critical
13 path soon for that.

14 After all of the licensees have received
15 closure letters, then we will close this issue. Our
16 most recent objective had been to close it in 2010.
17 And that will now no longer happen. When we will
18 close it depends on our path forward as determined by
19 Commission direction.

20 And the last bullet simply speaks to we
21 will close the issue for each plant when they have a
22 good test and evaluation method and they have
23 exercised that method and they have determined from
24 that method what modifications, if any, are needed to
25 the plant to achieve closure and they have made an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 appropriate commitment to make those modifications.
2 And then we will track them to closure.

3 So what I mean by that is we may close.
4 Optimistically we might close GSI-191 in 2011, but
5 some of the plant modifications will go out. Because
6 if you need to replace insulation, it takes multiple
7 outages to do it. Once we have the methods down and
8 the commitments down, then we will declare this issue
9 resolved and will track the commitments until they're
10 all accomplished.

11 I think we've already talked about all
12 this. So I stand ready to answer your questions.

13 MEMBER BLEY: How many have you closed?

14 MR. SCOTT: Without asterisks zero. With
15 asterisks, 39.

16 MEMBER BANERJEE: Without the --

17 MR. SCOTT: The asterisks is the in-vessel
18 effect.

19 MEMBER BLEY: Right.

20 MR. SCOTT: If you leave that aside, 39 of
21 69 are good to go.

22 MEMBER BANERJEE: But if you guessed, if
23 you want my guess, the ones which they've been able to
24 close will also be -- such a big issue.

25 CHAIR ABDEL-KHALIK: In-vessel effect.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Just a guess.

2 MEMBER BANERJEE: Maybe not for all.

3 MR. SCOTT: Just to give you a
4 perspective, we went to Germany two weeks ago to talk
5 to the German, the GRS organization over there, about
6 this issue and the way they resolved it in Germany.
7 Their strainers are significantly smaller than the
8 ones here. And they have actually multiple methods of
9 backflush some of which might be a little hard to buy
10 into here for various reasons.

11 But their view was that making strainers
12 larger and this is clearly the case. A larger
13 strainer means more bypass all else being equal. And
14 they were worried about the in-vessel effects issue.
15 And so they've taken a somewhat different path.
16 Smaller strainers, backflush capability.

17 And so it is true that solving the issue
18 on one side may --

19 MEMBER RAY: Lead to another problem.

20 MEMBER BANERJEE: But if you have seen the
21 backflush tests which I have they are not all that
22 convincing. This cake falls off and then comes right
23 back.

24 MR. SCOTT: It does. When you do the
25 backflush --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: Also dump it somewhere
2 special.

3 MR. SCOTT: The actual backflush event
4 itself also increases the bypass, of course. So the
5 German approach is not to do that until they
6 absolutely need to do that. But they do have the
7 capability?

8 VICE CHAIR ARMIJO: What have the Swedes
9 done? Much of this problem occurred in Swedish
10 plants, the earliest one that I remember. That was in
11 BWRs. Okay.

12 MR. SCOTT: There has not been a
13 challenging event to the PWRs of course.

14 VICE CHAIR ARMIJO: Have they modified
15 their PWRs?

16 MR. SCOTT: I --

17 VICE CHAIR ARMIJO: Do they have any?

18 MEMBER POWERS: No, they haven't.

19 MR. SCOTT: I can't answer that question.
20 That's one international organization we've not met
21 with. We've met with the French, the Japanese. We've
22 been Taiwan and various organizations. But I can't
23 say we've talked to the Swedes.

24 MEMBER POWERS: They fixed Barseback by
25 closing it down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: I believe they have --

2 MEMBER BANERJEE: It's more like Salem
3 from what I've seen.

4 MR. SCOTT: We would like to hear their
5 latest developments. We attempted to arrange a three-
6 party meeting when we went to German meeting. But
7 they were unable to attend.

8 MEMBER SHACK: The Germans usually leak-
9 before-break, don't they?

10 MR. SCOTT: They have their own version.

11 MEMBER SHACK: Their own version of it.

12 MR. SCOTT: It's not exactly the same.

13 MEMBER SHACK: Right. It's not the same,
14 but I mean it's not a double-ended guillotine break.
15 Just an offset break.

16 MR. SCOTT: Yes. Steve Smith, where are
17 you?

18 (Simultaneous speaking.)

19 MEMBER BANERJEE: A little earlier you
20 wanted to close the session.

21 MR. SMITH: The Germans use for the ZOI
22 side they use a 0.1 area, the full area of the pipe of
23 the largest pipe. So it's similar to what we're
24 recommending for the 50.46(a) rule, similar break
25 size, about 11 inch internal diameter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It depends on if you have a really large
2 loop pipe it might be bigger. And a smaller loop pipe
3 would be smaller. But they ratio the area of the
4 pipe.

5 MEMBER RAY: Before you go, could I ask.
6 I didn't want to take time on my question about
7 scouring. But could the staff recommend to a read-on
8 reference for this conclusion that we're conservative
9 with regard to scouring? Concrete scouring I'm
10 talking about.

11 MR. SCOTT: If we have a reference, yes,
12 we will do that.

13 MEMBER RAY: Okay.

14 CHAIR ABDEL-KHALIK: We do have ten
15 minutes and if Members wish, we can close this session
16 and hear about the discrepancy in the testing between
17 the two vendors.

18 MEMBER BANERJEE: The two issues --

19 CHAIR ABDEL-KHALIK: And there may be
20 another issue also that needs to be discussed in
21 closed session.

22 MR. SCOTT: The other one you considered
23 was the ZOI test.

24 MEMBER BANERJEE: Well, one was the ZOI
25 and the other was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: The in-vessel which was what
2 he was referring to.

3 MEMBER BANERJEE: So both of them now if
4 you --

5 CHAIR ABDEL-KHALIK: I think that would be
6 appropriate at this time.

7 MEMBER BANERJEE: Now who is going to make
8 sure that only --

9 MR. ROACH: I was going to say it may be a
10 problem because we didn't anticipate doing this in
11 advance. So it wasn't --

12 VICE CHAIR ARMIJO: We've got a lot of
13 folks out there.

14 MR. ROACH: Also I would say given the
15 variety of folks in the room it's going to take a more
16 than a few minutes to ascertain who can be here and
17 who shouldn't be.

18 MR. SCOTT: We could take an early break
19 and come back.

20 MR. ROACH: Unless it's absolutely
21 necessary, I would recommend against it unless --

22 MR. SCOTT: We will, of course, be coming
23 back to you in the fall to discuss these subjects in
24 detail.

25 VICE CHAIR ARMIJO: If you have some test

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reports or documents that you could just send us we
2 can read it.

3 MR. SCOTT: I can certainly send you the
4 staff's letter to the industry where we cited our
5 reasons for rejecting the ZOI reports.

6 VICE CHAIR ARMIJO: That would make me
7 happy.

8 MR. SCOTT: Okay.

9 MEMBER CORRADINI: And the in-vessel
10 effects you're still analyzing.

11 MR. SCOTT: Yes.

12 MR. RULAND: In addition if I may.

13 CHAIR ABDEL-KHALIK: One at a time please.
14 Go ahead.

15 MR. RULAND: Thank you, sir. In addition,
16 the staff has not accepted either of the issues that
17 the industry has proposed, either the cross test or
18 the ZOI. So it's not a question of --

19 CHAIR ABDEL-KHALIK: That's fine. Given
20 the complications we will forego the closed session
21 option at this time. So it's still in your hands, Dr.
22 Banerjee, to find out if there are any additional
23 questions.

24 MEMBER BANERJEE: That's up to the --

25 VICE CHAIR ARMIJO: I would still like the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 documents whatever your staff letter or whatever, just
2 get copies of that. The status of what your position
3 is.

4 MR. SCOTT: The ZOI rejection letter is
5 what we can send you.

6 VICE CHAIR ARMIJO: Yes. Appreciate that.

7 MEMBER POWERS: That would be useful.

8 MR. SCOTT: Okay.

9 MEMBER POWERS: Said, we can just ask for
10 if Mike can come back and it doesn't interfere too
11 much in their pressure to meet the Commission's
12 deadline to give us another informal discussion much
13 like he's done here on those particular items where
14 the session has to be closed.

15 CHAIR ABDEL-KHALIK: During the July
16 meeting.

17 MEMBER POWERS: During the July meeting.
18 I don't know how much it interferes when presumably we
19 would look for nothing more than just this kind of
20 informal discussion.

21 CHAIR ABDEL-KHALIK: And it would be
22 focused and short. But we will discuss offline. It's
23 not a given --

24 MEMBER POWERS: Thank you, Mr. Chair.

25 (Simultaneous speaking.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR ABDEL-KHALIK: One at a time please.

2 MEMBER BANERJEE: Okay. Questions.

3 Anybody with any questions?

4 MEMBER RAY: I got one request
5 outstanding. Sort of like Sam I guess I would like to
6 pursue further the issue of scouring. It came up in
7 another context and the response wasn't very
8 satisfying. So I'm just trying to find out if there's
9 some better information available.

10 MR. SCOTT: We will get you what we have.

11 MEMBER CORRADINI: So from a timing
12 standpoint, Mr. Chairman, I don't know whether to
13 address to Sanjoy or to you, the Thermal Hydraulics
14 Subcommittee or the full Committee. I guess it seems
15 to me given the short time line you have laid out
16 which is by the end of June you're going to know what
17 you want to do and then go into concurrence. By the
18 end of July, it will be done with concurrence and it
19 will go into the Commission. The Commission is going
20 to get it in August. Where in that is it logical for
21 us to hear what they're suggesting in terms of their
22 response to the SRM so that we can then if we choose
23 to write a letter, at least, put some sort of some
24 advice on paper?

25 MEMBER BANERJEE: I don't think we can do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anything that affects their response clearly.

2 MEMBER CORRADINI: Clearly. But I'm
3 asking where should we enter into it given their rapid
4 need to respond.

5 CHAIR ABDEL-KHALIK: Let us discuss this
6 issue internally.

7 MEMBER CORRADINI: Okay.

8 CHAIR ABDEL-KHALIK: As to how we're going
9 to approach this rather than in this forum.

10 MEMBER CORRADINI: That's fine. But I do
11 think we have to do something once we see their --

12 MEMBER BANERJEE: Let's discuss it
13 separately.

14 MEMBER SIEBER: We'll decide.

15 MEMBER BANERJEE: But first I'd really
16 like to thank you, Mike. This was very, very -- You
17 gave a very succinct report of what's going on and it
18 was very informative. Liked it a lot and thank you
19 also, Bill. So we are very happy with hearing from
20 you on this.

21 MR. SCOTT: Thank you. Pleased to be here
22 as always. Would you like me to be available for this
23 follow-on discussion that you're going to have among
24 yourselves in case you have a question for me?

25 MEMBER POWERS: I don't think it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 necessary.

2 CHAIR ABDEL-KHALIK: That is not
3 necessary.

4 MR. SCOTT: Okay.

5 CHAIR ABDEL-KHALIK: I think we know your
6 time constraints and therefore we will discuss it
7 internally as to what our next step will be. Okay/

8 MR. SCOTT: Okay.

9 CHAIR ABDEL-KHALIK: Thank you very much.

10 MEMBER BANERJEE: Thanks, Mike. And I
11 guess I'll hand it back to you, Mr. Chairman.

12 CHAIR ABDEL-KHALIK: Okay.

13 MEMBER BANERJEE: Before time five
14 minutes.

15 CHAIR ABDEL-KHALIK: Thank you. We will
16 recess until 2:45 p.m. At that time we will be off
17 the record.

18 (Whereupon, at 2:22 p.m., the above-
19 entitled matter was closed.)

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Presentation to the 573rd ACRS Meeting

**ISG-013: “Assessing the Consequences of an Accidental Release of
Radioactive Materials from Liquid Waste Tanks”**

&

**ISG-014: “Assessing Groundwater Flow and Transport of
Accidental Radiological Releases”**

June 10, 2010

Jean-Claude Dehmel (NRO/DCIP/CHPB) &
Hosung Ahn (NRO/DSEER/RHEB)

Introduction (1/2)

- ISG-013 Purpose (SRP 11.2, BTP 11-6, and SRP 2.4.13)
 - Justify the selected tank and tank radioactivity inventory
 - Evaluate tank, tank location, and facility design features that may mitigate the impact of a release
 - Conduct a radiological assessment of the postulated failure of a tank containing liquid waste on surface and ground water
 - Assign TS for maximum radioactivity inventory in tank
 - If facility design or site fail acceptance SRP criteria, applicant can:
 - > upgrade the tank and tank room designs, or
 - > reduce TS limits on tank's maximum radioactivity inventory

- ISG-014 Purpose (SRP 2.4.12, SRP 2.4.13, and RG 1.206)
 - To clarify FSAR 2.4.12&13 radiological consequence analysis in groundwater in order to more efficiently meet regulatory requirements.
 - To reconcile the inconsistencies between the existing guides
 - To provide practical guidance in reviewing:
 - * Base hydrologic condition
 - * Pathways and receptor
 - * Hydrogeologic characterization
 - * Groundwater modeling

- Why are these ISGs needed?
 - Guidance difficult to implement based on experience in reviewing ESP/COL applications
 - Current guidance is internally inconsistent between SRP Sections 2.4.12 & 2.4.13 and SRP 11.2 & BTP 11-6
 - Clarify technical guidance and regulatory requirements in applying SRP Section 11.2 with BTP 11-6 and SRP Sections 2.4.12 and 2.4.13 for the review of associated FSAR sections
 - Reconcile differences in existing guides to facilitate applicant's efforts in responding to regulatory requirements and guidance
 - Facilitate and expedite the staff's review of related FSAR sections of ESP/COL applications

Regulatory Basis




- **Regulatory Basis**
 - 10 CFR 52.79, as it relates to equipment used to control releases
 - 10 CFR 50.34a, as it relates to equipment used to control releases
 - 10 CFR 50.36a, as it relates to technical specifications
 - GCD 60 and 61 (Part 50, App. A), as they relate to the control of releases
 - 10 CFR 100.20 (c)(3), as it relates to establish on-site hydrogeologic characters
- **Regulatory Guidance**
 - SRP Section 11.2 & BTP 11-6 for release scenario and source term
 - SRP Sections 2.4.12 & 2.4.13 for ground water flow and transport
 - RG 1.206 Sections 11.2, 2.4.12, & 2.4.13, as guidance to COL applicants
 - RG 1.143, as it relates to the design features of LWMS
 - RG 1.113 and NUREG/CR-3332, as they relate to modeling aquatic dispersion
 - NUREG/CR-6805, as it relates to the development of conceptual site models
- **SRP 11.2 and BTP 11-6 Acceptance Criteria Adopted from:**
 - 10 CFR Part 20, App. B , Table 2, Col, 2 effluent concentration limits, *or*
 - 10 CFR Part 20 limit of 100 mrem for non-drinking water pathways

ISG-013 Interim Guidance

□ Proposed ISG-013 clarifies guidance on:

- Selection of system tank(s) and failure mechanisms
- Credit for passive and durable mitigating design features
- Conditions that envelope site characteristics
- Application of assumptions and level of conservatism
- Development of radioactive source term for tank(s)
- Radioactivity transport in ground or surface water
- Release pathways and offsite exposure scenarios
- Acceptance criteria and exposure pathways
- Tank specifications on max radioactivity concentration levels
- Language used in SER evaluation findings

ISG-014: Radiological Consequence Analysis in Groundwater



* ECL: Effluent Concentration Limits

ISG-014 Topics

- Clarify the review areas and review interfaces in SRP 2.4.12&13
- Reconcile the differences between SRP Sections 2.4.13 and 11.2, and clarify the conservatism in defining a base hydrologic condition
- Provide the guideline for choosing the potential receptor locations
- Credit for mitigating design features in SRP 2.4.13 consequence analysis
- Propose practical guidance to meet the requirement of on-site hydrogeology measurements specified in 10 CFR 100.20(c)(3)
- Provide guidance for developing conceptual site models, and groundwater flow models.
- Recommend a hierarchical approach for :
 - Radiological consequence analysis in FSAR 2.4.13
 - Determining species for transport parameter (K_d) sampling, and
 - Groundwater flow modeling

Resolution and Applicability

- Final Resolution:
 - Reviewing and evaluation of ACRS, public, and industry comments on ISG-013 and ISG-014
 - Finalization of ISG-013 and ISG-014 with incorporation of ACRS, public, and industry comments
 - Updating SRP Sections 2.4.12, 2.4.13, and 11.2, and BTP 11-6 given final issuance of ISG-013 and ISG-014 (as directed by NRO in updating infrastructure documents)
- Applicability to Part 52 COL Applicants:
 - Revised guidance will be applicable to all COL/ESP license applications submitted after the formal issuance ISG-013 and ISG-014

QUESTIONS ?



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Risk-Informed Guidance for New Reactors

Advisory Committee on Reactor Safeguards

Contacts: Donald A. Dube, Office of New Reactors, (301) 415-1483

Sunil D. Weerakkody, Office of Nuclear Reactor Regulation, (301) 415-2870

June 10, 2010

Meeting Purpose

- **Briefing on the status of risk-informed guidance for changes to the licensing basis, including operational programs, and to the Reactor Oversight Process (ROP) for new light-water reactors**

Agenda

- **Risk-informed initiatives for new reactors**
- **Status of stakeholder engagement**
- **Evolution of the staff's views**
- **Approaches considered**
- **Next steps**



Risk-Informed Initiatives for New Reactors

- **In the near term, risk-informed applications have been proposed:**
 - **Risk-Managed Technical Specifications**
 - **Risk-informed completion times**
 - **Surveillance frequency control program**
- **Longer term initiatives (post-COL) may include:**
 - **EPRI research program on risk-informed inservice inspection of piping**
 - **Special treatment requirements (10CFR50.69)**

New Reactor Implementation Issues

- **Review of these applications raised questions regarding the appropriate risk metric acceptance guidelines for implementation of risk-informed initiatives for new reactors, as well as thresholds in the ROP**

Stakeholder Engagement

- **February 12, 2009 interoffice memorandum and white paper from Executive Director for Operations on options for risk metrics for new reactors (ADAMS ML090150636 and ML090160004)**
- **First public meeting, February 18, 2009, to engage stakeholders and obtain their feedback on the issues and potential options (ML090570356)**
- **2009 Regulatory Information Conference presentation**
- **Nuclear Energy Institute (NEI) white paper to the ACRS staff, March 27, 2009 (ML090900674).**
- **ACRS briefing on April 3, 2009 (ML091030667)**
- **ACRS Subcommittee on Reliability & PRA briefing on June 2, 2009, with views from industry representatives and the Union of Concerned Scientists (ML092040138)**
- **Second public meeting, September 29, 2009, that focused on the potential issues associated with the ROP (ML092780211)**
- **Staff presentation at American Nuclear Society 2009 embedded topical meeting, November 17, 2009**
- **Third public meeting, June 3, 2010, that summarized the draft Commission paper**

Evolution of Staff's Views

- **No early staff consensus on approach**
- **Initial staff concerns with risk acceptance guidelines for changes to the licensing basis (Regulatory Guide 1.174), and potential options (*relative* versus *absolute* change in core damage frequency (CDF) and large release frequency (LRF))**
- **More recently, less concern with numerical guidelines and more on**
 - **“Assuring that the level of enhanced safety believed to be achieved with this design will be reasonably maintained”**
 - **The implementation of 50.59-like process for new reactors**
- **Staff consensus on high-level approach across the agency including all regions**

Staff Requirements

Memorandum on SECY-90-377

- **The Commission approved a process similar to 10 CFR 50.59 for making changes to Tier 2 information between combined license (COL) issuance and authorization for operation**
- **The Commission stated that “the staff should ensure that this process requires **preservation of the severe accident, human factors, and operating experience insights** that are part of the certified design”**
- **Under Part 52, the process for changes and departures for each certified reactor design is found in Section VIII of the appendix that contains its design certification rule**



Statement of Considerations for ABWR Design Certification

“The Commission recognizes that the ABWR design not only meets the Commission’s safety goals for internal events, but also offers a substantial overall enhancement in safety as compared, generally, with current generation of operating power reactors...The Commission recognizes that the safety enhancement is the result of many elements of the design, and that much but not all of it is reflected in the results of the probabilistic risk assessment (PRA) performed and documented for them. In adopting a rule that **the safety enhancement should not be eroded significantly by exemption requests**, the Commission recognizes and expects that this will require both careful analysis and sound judgment, especially considering uncertainties in the PRA and the lack of a precise, quantified definition of the enhancement which would be used as the standard.”

Statement of Considerations for ABWR (cont.)

“The Commission on its part also has a reasonable expectation that vendors and utilities will cooperate with the Commission in **assuring that the level of enhanced safety believed to be achieved with this design will be reasonably maintained for the period of the certification (including renewal). This expectation that industry will cooperate with NRC in maintaining the safety level of the certified designs applies to design changes suggested by new information, to renewals, and to changes under section VIII.B.5 of the final rule. If this reasonable expectation is not realized, the Commission would carefully review the underlying reasons and, if the circumstances were sufficiently persuasive, consider the need to reexamine the backfitting and renewal standards in Part 52 and the criteria for Tier 2 changes under section VIII.B.5.”**

Current Regulatory Guidance for Risk-Informed Initiatives

- **Regulatory guidance associated with risk-informed initiatives for currently operating reactors are based on Commission's Safety Goals (e.g., RG 1.174, 1.175, 1.177, 1.178, 1.201)**
- **A key principle of RG 1.174 is that “when proposed changes result in an increase in core damage frequency or risk, the increases should be small and consistent with the intent of the Commission's Safety Goal Policy Statement”**

From RG 1.174

- **Five principles for making risk-informed decisions**
 - **The proposed change:**
 - Meets current **regulations** (unless exemption request)
 - Is consistent with the **defense-in-depth** philosophy
 - Maintains sufficient **safety margins**
 - Results in an increase in CDF or risk that is **small** and consistent with the intent of the Commission's Safety Goal Policy Statement
 - Will be monitored using **performance measurement** strategies.

From RG 1.174




Figure 3. Acceptance Guidelines for Core Damage Frequency (CDF)




Figure 4. Acceptance Guidelines for Large Early Release Frequency (LERF)

Current Regulatory Guidance for Risk-Informed Initiatives (cont.)


- **Regulatory Guide 1.174, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis”**
- **Risk-Acceptance Guidelines:**
 - **Baseline risk metrics of CDF and LERF**
 - AND**
 - **Δ CDF and Δ LERF due to change**
- **Basis:**
 - **Increases should be limited to small increments**
 - **CDF threshold related to backfit regulatory analysis guidelines**
 - **Δ CDF limit based on *absolute* change and set close to limit of resolution of PRA models**

Fundamental Issue before the Staff

- **Current guidance could allow large relative changes to CDF and containment performance for new reactors**

Hypothetical Example

- A new reactor design has a baseline CDF of 1×10^{-7} /yr
- A proposed design change results in a CDF increase of 7×10^{-8} /yr (70% increase).



X

Figure 3. Acceptance Guidelines for Core Damage Frequency (CDF)

Example: MD 8.3 Incident Investigation

Estimated Conditional Core Damage Probability (CCDP)				
CCDP < 1E-6	1E-6 – 1E-5	1E-5 – 1E-4	1E-4 – 1E-3	CCDP > 1E-3
No additional inspection				
	Special inspection			
		AIT		
			IIT	



New Rx SGTR **Current SGTR**


New Rx LOOP


Current LOOP

Approaches Considered

- **No changes to the current regulatory guidance, or *status quo***
 - **Provides incentive to build reactors with enhanced severe accident safety features**
 - **Applicants and licensees who invest in and maintain additional safety features have more flexibility to operate the plants with a reduction in regulatory interactions**
 - **The staff concluded, however, that this approach did not meet Commission expectations in that this approach may not prevent significant decrease in enhanced safety through changes to the licensing basis and plant operations over plant life**
 - **In addition, this approach may not provide for meaningful regulatory oversight that supports NRC's response and inspection**

Approaches (cont.)

- **Modify the risk-informed guidance to include a new lower risk metric for the ROP and changes to the licensing basis**
 - Supports the Commission’s expectation that new plants have enhanced severe accident safety performance and that advanced reactors provide enhanced margins of safety
 - Approach goes beyond the Commission’s expectation by essentially *requiring* the continued maintenance of the enhanced margin of safety
 - Approach may be inconsistent with the Commission’s statement on the Regulation of Advanced Reactors in 2008 that the “policy statement does not state that advanced reactor designs must be safer than the current generation of reactors”
 - Would create a risk-informed framework that is, in effect, inconsistent with the underlying technical basis for the current thresholds that are derived from the Commission Safety Goals and implemented in RG 1.174
 - Could have unintended consequences in that new reactors with enhanced safety features would have less operational flexibility than the current fleet of reactors

Approach Selected by Staff

- **Identify specific changes to the risk-informed guidance for changes to the licensing basis that would prevent a significant decrease in the level of safety of the new reactor over its life**
- **Identify specific changes to the risk-informed guidance for the ROP to provide for meaningful regulatory oversight**

For changes to the licensing basis and operational programs

- **Evaluate how to modify the risk-informed guidance to prevent a significant decrease in the level of safety provided by certified designs**
- **Evaluate how to supplement the CDF and LERF acceptance guidelines to recognize the lower risk profiles of new reactors**
- **Utilize stakeholder involvement in the evaluation and development of detailed changes to risk-informed regulatory guidance**
- **Evaluate the merits of developing additional criteria (e.g., deterministic, defense in depth) to support the change process**
- **Evaluate proposed changes to guidance to ensure that the changes do not create unintended consequences such as creating disincentives for safer designs on the one hand, or allowing degradation of passive safety system performance on the other hand**
- **Develop guidance to implement Section VIII.B.5.c of the design certification rules**

For changes to the ROP

- **Utilize stakeholder involvement in the evaluation and development of changes to the guidance**
- **Evaluate the criteria for plant placement in the action matrix to assess whether the current process would ensure that operational performance that results in significant reductions in the level of safety provided by the certified design is fully understood by the licensee and NRC and is effectively corrected**
- **Evaluate the merits of developing additional criteria (e.g., deterministic, change in risk) to support NRC's response to findings and performance trends**
- **Evaluate any potential ROP changes to avoid unintended consequences such as creating disincentives for safer designs on the one hand; or allowing degradation of passive safety system performance on the other hand; or diverting the attention of NRC inspectors from issues of higher safety significance on currently operating reactors**

For changes to the ROP (cont.)

- **Consider the need to risk-weight or otherwise weight findings associated with passive systems to reflect the difficulty of recognizing the degradation of passive systems**
- **Continue to independently assess licensee performance in the area of safety culture since safety culture addresses common underlying factors that affect plant safety**
- **Evaluate maintaining or changing the current thresholds for green, white, yellow, red risk-significant findings and performance indicators, given that low-risk designs may rarely if ever cross the current white threshold**
- **Consider the advantages and disadvantages of applying any potential changes to the ROP to currently operating reactors**

Summary

- **New light-water reactor risk profiles generally lower than currently operating reactors**
- **Early staff concern with risk metrics for changes to licensing basis and ROP thresholds**
- **Staff's concerns have evolved to those of how to**
 - **assure enhanced level of severe accident capability is maintained**
 - **implement a 50.59-like process**
- **Staff prepared to engage stakeholders to develop appropriate guidance**

Next Steps

- **Issue final Commission Paper**
- **Staff to continue to engage stakeholders regarding specific changes to industry and NRC guidance documents**
- **Staff to proceed with evaluation of applications for risk-informed initiatives for new reactors**
- **Parallel but extended effort to address ROP issues**



Back-up slides

Relevant Commission Policy Statements

- **Severe Reactor Accidents Regarding Future Designs and Existing Plants (1985)**
- **Regulation of Advanced Nuclear Power Plants (1986 & 2008)**
- **Commission Safety Goals (1986)**

Commission's Safety Goals (1986)

- Commission's SAFETY GOALS specify how safe is safe enough
 - Qualitative safety goals
 - Quantitative health objectives
 - General performance guideline for staff examination

Risk Metrics for Operating Reactors

- **Core Damage Frequency (CDF) $< 10^{-4}$ /yr**
 - **Surrogate for latent cancer fatalities in the Commission's quantitative health objective (QHO)**
- **Large Early Release Frequency (LERF) $< 10^{-5}$ /yr**
 - **Surrogate for prompt fatalities in QHO**

Commission's Expectations for New Reactors

Severe Reactor Accidents Regarding Future Designs and Existing Plants (1985)

The Commission “fully expects that vendors engaged in designing new standard (or custom) plants will achieve a higher standard of severe accident safety performance than their prior designs.”

Regulation of Advanced Nuclear Power Plants (1986)

“Furthermore, the Commission expects that advanced reactors will provide enhanced margins of safety and/or utilize simplified, inherent, passive, or other innovative means to accomplish their safety functions.”


Risk Goals for New Reactors

- **SECY-90-016 Staff Recommendations**
 - **CDF $< 1 \times 10^{-5}$ /yr**
 - **LRF $< 1 \times 10^{-6}$ /yr**
 - **CCFP less than approximately 0.1**


- **In the associated SRM, the Commission disapproved the use of CDF $< 1 \times 10^{-5}$ /yr and approved:**
 - **CDF $< 1 \times 10^{-4}$ /yr**
 - **LRF $< 1 \times 10^{-6}$ /yr**
 - **CCFP less than approximately 0.1**

CDF and LRF by Plant Type

(internal events at-power for U.S. plants only)



(internal events at-power only)



Source:
 NUREG-1560



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

**Status on Resolution of
Generic Safety Issue (GSI) 191
Pressurized Water Reactor Sump Performance**

Presented by:

Michael Scott

Office of Nuclear Reactor Regulation

Presented to:

Advisory Committee on Reactor Safeguards

June 10, 2010

Purpose of Brief

- Provide background, current status, planned path forward, and key messages on GSI-191 and Generic Letter (GL) 2004-02

Background

- NRC opened GSI-191, Assessment of Debris Accumulation on PWR Sump Performance, in 1996, and sponsored new research in the late 90s for PWRs
- GL 2004-02 requested licensees perform detailed mechanistic evaluations of emergency core cooling system (ECCS) and containment spray system (CSS) functions and make modifications as needed by December 31, 2007
- NRC staff and ACRS concluded that near-term action to make PWR strainers larger was prudent
- Licensees increased strainer sizes by 1-2 orders of magnitude

Developments Since 2007

- NRC staff issued revised guidance in early 2008 regarding head loss testing, coatings, and chemical effects
- In many cases, licensee GL responses did not provide detail sufficient to determine that testing and evaluation methods were acceptable, resulting in a large number of requests for additional information (RAIs)
- ACRS questions regarding a 2008 draft safety evaluation for in-vessel downstream effects caused the staff to re-examine its views on the subject
- The NRC staff raised concerns regarding industry zone-of-influence (ZOI) testing

Zone of Influence

- Some licensees had sponsored jet impingement testing intended to justify reduced ZOIs for specific insulation and coatings
- NRC reviewed the reports and found issues
- Extended discussions were held to resolve issues – some were resolved, others not
- In late 2009, as a result of NRC questions, industry identified a design error with the test loop used for industry ZOI testing - so reduced industry ZOIs were undercalculated
- NRC informed industry that we do not accept the subject reports for insulation and inorganic zinc coatings
- Industry considering additional testing and analysis – could raise additional questions


In-vessel Effects

- Industry submitted Topical Report WCAP-16793 Revision 1 to address in-vessel downstream effects
- NRC issued RAIs to industry – responses received
- Testing has shown that the two vendors' fuels appear to behave very differently in response to debris intrusion
- NRC believes “cross-testing” would likely show whether the difference is related to fuel design or is a testing issue
- NRC continuing to work with vendors to resolve the unexpected difference in behavior
- NRC working to issue safety evaluation in 2010

Sump Issue Challenges

- Numerous phenomena – e.g., debris generation, zone of influence, debris characterization, latent debris, debris transport, water hold-up, strainer headloss and vortexing, chemical effects, and downstream in-vessel effects
- No reliable models for some aspects of strainer performance evaluations, so licensees rely on complex scaled-down testing
- Small amounts of certain materials can be very problematic for sump performance
- Head loss behavior is non-linear so margins are difficult to predict
- Testing frequently has resulted in surprises

Review and Closure Process



Recent Developments

- Staff and licensees briefed Commission on GSI-191 status on 4/15/2010
- Licensee presenters stated view that GSI-191 is no longer a safety issue and that staff plans for near-term closure would cause
 - Replacement of effectively all fibrous insulation
 - Large radiation exposures to plant personnel
- Nuclear Energy Institute has proposed that staff allow application of General Design Criterion 4 (leak-before-break) to sump performance evaluations

Staff Requirements Memorandum

- Staff should not issue letters under 10 CFR 50.54(f) pending further Commission direction
- Staff should report to Commission by 8/27/2010 on potential approaches to closure, including:
 - Realistic ZOI
 - Application of GDC-4
 - In-vessel effects
 - Risk-informed resolution (e.g., 10 CFR 50.46a)
 - Alternative regulatory treatment of in-vessel effects
 - Dose impact of resolution options
- Staff is developing requested information and proposed path forward

Resolution Status

- The staff has concluded that strainer performance has been adequately demonstrated (except for in-vessel effects) for 39 of 69 U.S. PWRs
- NRC staff expects some “high fiber” plants may require additional testing and/or modifications to satisfactorily address the generic issue – NRC refusal to accept ZOI reductions has challenged these plants
- NRC staff providing options and recommendations to the Commission to support decision-making on path forward

Refinements

- Leak-before-break
- Risk-informed ECCS regulations
- Jet impingement testing (already discussed)

Leak-before-break (LBB)

- Industry has proposed that NRC reconsider application of General Design criterion 4 to sump performance evaluations
- “Dynamic effects associated with postulated pipe ruptures in nuclear power units may be excluded from the design basis when analyses reviewed and approved by the Commission demonstrate that the probability of fluid system piping rupture is extremely low under conditions consistent with the design basis for the piping”
- NRC staff had twice previously rejected application to sump evaluations

Leak-before-break (Continued)

- Original intent of LBB was to allow removal of specific equipment (pipe whip restraints, etc.) whose absence would potentially enhance safety
- If credit sought and approved, could remove some break locations from consideration for sump evaluations
- Major challenge to approve this credit for sump performance evaluations

Existing ECCS Regulations

- Existing regulations require evaluation of a double-ended guillotine break of the largest pipe in the reactor coolant system as a design basis loss-of-coolant accident (LOCA)
- Performance demonstration for design basis LOCAs must include
 - assumption of loss of offsite power,
 - assumption of the worst single failure, and
 - credit only for safety-grade systems

Proposed Risk-informed ECCS Regulations

- Proposed risk-informed ECCS regulations would change the size of the largest pipe break that must be evaluated as a “design basis” LOCA (“transition break size”)
- For breaks larger than the transition break size, evaluations can be performed:
 - using realistic inputs for strainer performance
 - without inclusion of a single failure
 - without assuming that offsite power is lost and taking credit for non-safety equipment

Proposed Risk-informed ECCS Regulations (cont'd)

- Transition break size for PWRs is defined in 10 CFR 50.46a as the “largest attached pipe to the reactor coolant system” (pressurizer surge line)
- If implemented, rule could assist some licensees, though they would still need design basis analyses for smaller breaks, which could pose problems
- NRC staff expects to send proposed rule to the Commission for approval December 2010

Path Forward

- Uncertainties in strainer performance have challenged closure of the debris clogging issue for some plants
- Inadequate strainer performance can challenge long-term core cooling and maintenance of core integrity
- Plant-specific issue resolution will continue, consistent with Commission direction
- In-vessel effects issue needs to be resolved
- After all licensees have been issued closure letters, GL 2004-02 will be formally closed
- Some plant modifications may need to be made after planned issue closure – NRC will track all commitments to completion

Conclusions

- NRC closing GSI-191 one plant at a time – over half complete (with exception of in-vessel effects)
- Remaining plants are generally those with most fibrous and particulate insulation
- NRC staff providing options and recommendations to support Commission direction on path forward