CCNPP3COLA PEmails

From: Arora, Surinder
Sent: Friday, June 11, 2010 7:30 AM
To: 'Poche, Robert'; 'cc3project@constellation.com'
Cc: CCNPP3COL Resource; Roach, Edward; Bernal, Sara; Colaccino, Joseph; Biggins, James; Vrahoretis, Susan; Chazell, Russell
Subject: FW: FINAL RAI 248 CHPB 4731
Attachments: FINAL RAI 248 CHPB 4731.doc

MESSAGE **RESENT** WITH THE CORRECT ATTACHMENT.

Please disregard the earlier message.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

From: Arora, Surinder
Sent: Friday, June 11, 2010 7:18 AM
To: 'Poche, Robert'; 'cc3project@constellation.com'
Cc: CCNPP3COL Resource; Roach, Edward; Bernal, Sara; Colaccino, Joseph; Biggins, James; Vrahoretis, Susan; Chazell, Russell
Subject: FINAL RAI 248 CHPB 4731

Rob,

Attached please find the subject request for additional information (RAI). The draft of this RAI was sent to you on June 3, 2010. As confirmed by you on phone on June 10, 2010, UniStar does not require a clarification phone call on this RAI.

The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a schedule date for submitting your technically correct and complete response will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the review schedule.

Your response letter should also include a statement confirming that the response does or does not contain any sensitive or proprietary information.

Thanks.

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 1386

Mail Envelope Properties (B46615B367D1144982B324704E3BCEED276FFCD271)

Subject: FW: FINAL RAI 248 CHPB 4731
Sent Date: 6/11/2010 7:29:51 AM
Received Date: 6/11/2010 7:30:12 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:
"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Roach, Edward" <Edward.Roach@nrc.gov>
Tracking Status: None
"Bernal, Sara" <Sara.Bernal@nrc.gov>
Tracking Status: None
"Colaccino, Joseph" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Biggins, James" <James.Biggins@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Chazell, Russell" <Russell.Chazell@nrc.gov>
Tracking Status: None
"'Poche, Robert'" <Robert.Poche@constellation.com>
Tracking Status: None
"'cc3project@constellation.com'" <cc3project@constellation.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	2004	6/11/2010 7:30:12 AM
FINAL RAI 248 CHPB 4731.doc	30714	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 248 (eRAI 4731)

6/11/2010

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016
SRP Section: 01 - Introduction and Interfaces
Application Section: Chapter 1, Introduction and General Description of the plant

QUESTIONS for Health Physics Branch (CHPB)

01-10

In UniStar's letter transmitting Revision 2 of the COL application, dated March 14, 2008, and in Part 1, "General and Financial Information," of the COL application, UniStar requested material licenses for receipt, possession and use of source, byproduct and special nuclear material in accordance with Commission regulations in 10 CFR Parts 30, 40, and 70.

However, in order for the staff to conduct its review, the applicant should address their request for these licenses in Chapter 1 of the FSAR. In addition, the request should point to other parts of the FSAR that provide sufficient information in the areas of radiation protection (including sealed source leak testing and maintenance), fire protection, training, security and emergency planning, to support compliance with the applicable portions of 10 CFR Parts 30, 40 and 70.

Please revise the FSAR as described above and as necessary to include sufficient information for staff to complete 10 CFR Parts 30, 40 and 70 license reviews.