

June 25, 2010

NRC 2010-0090 TS 5.5.13 10 CFR 50.71(e)

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555

Point Beach Nuclear Plant, Units 1 and 2 Dockets 50-266 and 50-301 Renewed License Nos. DPR-24 and DPR-27

## **Technical Specification Bases Change Summary**

In accordance with the requirements of Technical Specification 5.5.13 and 10 CFR 50.71(e), NextEra Energy Point Beach, LLC (NextEra), is submitting a summary of changes made to the Point Beach Nuclear Plant (PBNP) Technical Specification Bases.

The enclosure contains the Technical Specification (TS) Bases change summary for the period January 1, 2009, through December 31, 2009.

This letter contains no new commitments and no revisions to existing commitments.

If you have questions or require additional information, please contact James Costedio at 920/755-7427.

Very truly yours,

NextEra Energy Point Beach, LLC

James Costedio

Licensing Manager

**Enclosure** 

cc: Administrator, Region III, USNRC

Project Manager, Point Beach Nuclear Plant, USNRC Resident Inspector, Point Beach Nuclear Plant, USNRC

## **ENCLOSURE**

## NEXT ERA ENERGY POINT BEACH, LLC POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

## **TECHNICAL SPECIFICATIONS BASES CHANGE SUMMARY FOR 2009**

Date of Change	Affected Section		<u>Summary</u>
02/02/09	B 3.6.5	B 3.6.5-2 through B.3.6.5-3	Revised Containment Average Air Temperature to incorporate new Values.
03/02/09	B 3.7.11	B 3.7.11-1 through B 3.7.11-3	Corrected Bases references that supported NRC SE dated September 4, 1997 for Amendments 179/183.
03/16/09	B 3.8.3	B 3.8.3-1	Editorial change (grammatical).
05/06/10	B 3.7.11	B 3.7.11-1 through B 3.7.11-4	Changed per NRC SE dated March 5, 2010 for Amendments 236/240.
05/06/10	B 3.7.12	B 3.7.12-1 through B 3.7.12-3	Changed per NRC SE dated March 5, 2010 for Amendments 236/240.
06/01/09	B 3.8.1	B 3.8.1-5 B 3.8.1-22 B 3.8.1-23	Revised the allowable room temperature in the emergency diesel generator G-01 and G-02 rooms from ≤ 120°F to ≤ 115°F. Added Calculation reference supporting temperature change.
06/15/09	B 3.7.2	B 3.7.2-2	Revised to be aligned with Technical Specification limits for steam generator tube leakage.
09/14/09	B 3.3.1	B 3.3.1-17	Changed to reflect the increase in time delay for the 4160 V Bus A01/A02 UV trip relays and clarifies that the A01/A02 UV Trip is independent of the reactor coolant flow-low(two loops) reactor trip.
09/14/09	B 3.6.4	B 3.6.4-1	Revised to reflect new containment pressure and temperature analyses for LOCA/SLB accident as a result of feedwater heater replacement.
09/14/09	B 3.6.5	B 3.6.5-2	Revised to reflect new containment pressure and temperature analyses for LOCA/SLB accident as a result of feedwater heater replacement.

<u>Date of</u> <u>Change</u>	Affected Section		<u>Summary</u>
10/11/09	В 3.4.14	B 3.4.14-2 and B 3.4.14-4 through B 3.4.14-5	Editorial change to reflect inservice inspection Code references contained in 10 CFR 50.55(a).
11/16/09	B 3.8.3	B 3.8.3-1	Revised to resolve the storage requirements of fuel oil between the two fuel oil storage tanks.
11/24/09	B 3.6.6	B 3.6.6-2 through B 3.6.6-3	Revised to reflect modifications performed to the Unit 2containment spray system.
11/30/09	B 3.5.4	B 3.5.4-2 through B 3.5.4-3	Corrected to reflect NRC SE dated August 8, 2001, for Amendments 201/206 and inservice inspection Code references contained in 10 CFR 50.55(a).
11/30/09	B 3.7.2	B 3.7.2-2 through B 3.7.2-3	Editorial change (pagination).