



Nebraska Public Power District

"Always there when you need us"

NLS2010061
June 25, 2010

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

Subject: Changes to the Cooper Nuclear Station License Renewal Application in Response to Safety Evaluation Report with Open Items
Cooper Nuclear Station, Docket No. 50-298, DPR-46

Reference: Letter from Brian J. O'Grady, Nebraska Public Power District, to U.S. Nuclear Regulatory Commission, dated May 26, 2010, "NPPD Comments on Safety Evaluation Report with Open Items Related to the License Renewal of Cooper Nuclear Station" (NLS2010051).

Dear Sir or Madam:

The purpose of this letter is for the Nebraska Public Power District (NPPD) to submit changes to the Cooper Nuclear Station (CNS) License Renewal Application (LRA) related to the NPPD comments provided in the referenced letter. Attachment 2, Page 1 of 1, was inadvertently omitted from that letter. These LRA changes are provided in the Enclosure to this letter.

Should you have any questions regarding this submittal, please contact David Bremer, License Renewal Project Manager, at (402) 825-5673.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 6/25/10
(Date)

Sincerely,

Brian J. O'Grady
Vice President-Nuclear and
Chief Nuclear Officer

/wv

A136
NPPD

NLS2010061

Page 2 of 2

Enclosure

cc: Regional Administrator w/ enclosure
USNRC - Region IV

Cooper Project Manager w/ enclosure
USNRC - NRR Project Directorate IV-1

Senior Resident Inspector w/ enclosure
USNRC - CNS

Nebraska Health and Human Services w/ enclosure
Department of Regulation and Licensure

NPG Distribution w/enclosure

CNS Records w/ enclosure

NLS2010061
Enclosure

Enclosure

Attachment 2 to NLS2010051

**Changes to the Cooper Nuclear Station
License Renewal Application**

Attachment 2

Changes to the Cooper Nuclear Station License Renewal Application

As a result of reviewing the Nuclear Regulatory Commission (NRC) Safety Evaluation Report (SER), the Nebraska Public Power District (NPPD) identified certain corrections/enhancements to the License Renewal Application (LRA). They are presented in underline/strikeout format.

1. LRA Section A.1.1.33 will be revised as follows:

“The Reactor Vessel Surveillance Maintenance Program will be enhanced as follows.

- ~~If the CNS standby capsule is removed from the reactor vessel without the intent to test it, the capsule will be stored in a manner which maintains it in a condition which would permit its future use, including during the period of extended operation, if necessary.~~
- Ensure that the additional requirements specified in the final NRC safety evaluation for BWRVIP-116 will be addressed before the period of extended operation.

This eEnhancements will be implemented prior to the period of extended operation.”

Reference: Cooper Nuclear Station (CNS) does not have a standby capsule. Moreover, the third License Condition described in Section 1.7 of the NRC SER subsumes the need to make this commitment should NPPD acquire one in the future. Accordingly, it is being deleted.

2. LRA Section B.1.33 will be revised as follows:

“The following enhancements will be implemented prior to the period of extended operation.

Elements Affected	Enhancements
5. Monitoring and Trending	If the CNS standby capsule is removed from the reactor vessel without the intent to test it, the capsule will be stored in a manner which maintains it in a condition which would permit its future use, including during the period of extended operation, if necessary.”

Reference: CNS does not have a standby capsule. Moreover, the third License Condition described in Section 1.7 of the NRC SER subsumes the need to make this commitment should NPPD acquire one in the future. Accordingly, it is being deleted.

Correspondence Number: NLS2010061

The following table identifies those actions committed to by Nebraska Public Power District (NPPD) in this document. Any other actions discussed in the submittal represent intended or planned actions by NPPD. They are described for information only and are not regulatory commitments. Please notify the Licensing Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

COMMITMENT	COMMITMENT NUMBER	COMMITTED DATE OR OUTAGE
None		