

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 Radiation Protection and Nuclear Materials
 Groundwater Contamination at Nuclear
 Powerplants

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, May 18, 2010

Work Order No.: NRC-242

Pages 1-78

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2 DISCLAIMER

3
4
5 UNITED STATES NUCLEAR REGULATORY COMMISSION'S
6 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

7
8
9 The contents of this transcript of the
10 proceeding of the United States Nuclear Regulatory
11 Commission Advisory Committee on Reactor Safeguards,
12 as reported herein, is a record of the discussions
13 recorded at the meeting.

14
15 This transcript has not been reviewed,
16 corrected, and edited, and it may contain
17 inaccuracies.

18
19
20
21
22
NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

+ + + + +

SUBCOMMITTEE ON RADIATION PROTECTION
AND NUCLEAR MATERIALS

+ + + + +

TUESDAY,

MAY 18, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
Regulatory Commission, Two White Flint North,
Room T2B3, 11545 Rockville Pike, at 1:00 p.m.,
Dr. Michael T. Ryan, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

MICHAEL T. RYAN, Chairman

ACRS STAFF PRESENT:

DEREK WIDMAYER, Designated Federal Official

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ALSO PRESENT:

ED ROACH, NRO

RICHARD RAIONE, NRO

JEAN-CLAUDE DEHMEL, NRO

HOSUNG AHN, NRO

JOE GIACINTO, NRO

STEVE SCHAFFER, NRO

SHERYL BURROWS, NRO

GOUTAM BAACHI, NRO

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

TABLE OF CONTENTS

	<u>PAGE</u>
I. Introduction	4
II. NRO Opening Remarks	5
III. ISG-013 Presentation	9
IV. ISG-014 Presentation	43
V. Public Comments	--
VI. Subcommittee Discussion	65

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2 P-R-O-C-E-E-D-I-N-G-S

3 (1:00 p.m.)

4 CHAIRMAN RYAN: It is the appointed hour,
5 so we will begin. ACRS members in attendance are me.

6 The other members are not here today.

7 Derek Widmayer of the ACRS staff is the
8 Designated Federal Official for this meeting. The
9 purpose of the meeting is to review and discuss two
10 guidance documents that address the ongoing issue of
11 leaking underground pipes and groundwater
12 contamination at nuclear powerplants.

13 The two documents are ISG-013, "Assessing
14 the Consequences of an Accidental Release of
15 Radioactive Material from Liquid Waste Tanks for
16 Combined License Applications," and ISG-014,
17 "Assessing Groundwater Flow and Transport of
18 Accidental Radionuclide Releases."

19 The Subcommittee will hear presentations
20 by, and hold discussions with, representatives of the
21 NRC staff and other interested persons regarding this
22 matter. The Subcommittee will gather information,
23 analyze relevant issues and facts, and formulate
24 positions and actions as appropriate, with
25 deliberation by the full Committee at its June

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meeting.

2 The rules of participation in today's
3 meeting have been announced as part of the notice of
4 this meeting previously published in the Federal
5 Register. We have received no written comments or
6 requests for time to make oral statements from members
7 of the public regarding today's meeting.

8 A transcript of the meeting is being kept
9 and will be made available, as stated in the Federal
10 Register notice. Therefore, we request that
11 participants in this meeting use the microphones
12 located throughout the meeting room when addressing
13 the Subcommittee. The participants should first
14 identify themselves, and speak with sufficient clarity
15 and volume, so they may be readily heard.

16 Copies of the meeting agenda and handouts
17 are available at the back of the room.

18 We will now proceed with the meeting, and
19 I call on Mr. Ed Roach and Mr. Rick Raione. Is that
20 correct?

21 MR. RAIONE: Yes, sir.

22 CHAIRMAN RYAN: Okay. Thank you. Of NRO
23 staff for some introductory remarks. Ed?

24 MR. ROACH: Thank you, Mike, and good
25 afternoon to all of the attendees today. My name is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Ed Roach, and I'm the Branch Chief for New Reactors
2 and Health Physics. And the topic we are discussing
3 today is the Interim Staff Guidance 13 and 14, which
4 were prepared by Health Physics Branch and the
5 Hydrology Branch of NRO.

6 And as far as the Health Physics Branch,
7 we originally placed this out for comment in May 2009.

8 And this was brought out as we performed our ongoing
9 COLA reviews, identifying several inconsistencies in
10 the standard review plan NUREG-0800 guidance and the
11 information the applicant submitted and we needed to
12 make a reasonable determination.

13 As a result of that, a team of our staff
14 put together the draft ISG-013 and worked with
15 Hydrology to develop ISG-014, to make sure they made
16 it up. What we found is that we -- when ISG-014 was
17 ready to go for public comment, ISG-013 was laced out
18 again on the Federal Register for comments.

19 And at this point, we have just received
20 comments from NEI, and we are beginning to address
21 those. Those comments will be discussed at our next
22 NEI public meeting that our staff has, and that is
23 May 26th. And so we will continue to resolve the
24 issues and discrepancies and address the comments and
25 any other public comments that were submitted on this.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So without --

2 CHAIRMAN RYAN: I think it's fair to say,
3 just based on your comment about NEI, we are really in
4 the information-gathering. We have not seen your
5 comments or -- and we would like to, because I'm sure
6 that's going to have an impact on the Committee's
7 thinking. So I'm not sure where our schedule will be
8 going forward in terms of hearing and, you know,
9 gathering the rest of the information. It might have
10 an impact on when the letter lands in the schedule.

11 MR. ROACH: Yes. They were submitted to
12 the public document approximately, I believe, a week
13 ago.

14 CHAIRMAN RYAN: Okay.

15 MR. ROACH: So we anticipate starting to
16 work on them and open the discussions at the NRC/NEI
17 Health Physics public meeting.

18 CHAIRMAN RYAN: Okay. Great.

19 MR. ROACH: So, and any other public
20 comments that came in. We're not aware of any yet.

21 What I'd like to do is introduce a senior
22 member of my staff after Richard Raione has discussed,
23 and that is Jean-Claude Dehmel, who is the responsible
24 individual for the development of the ISG, and the
25 rest of the team that supported him is here also.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So I will now turn it over to Rich Raione
2 for his introductory comments.

3 MR. RAIONE: Good afternoon. My name is
4 Richard Raione. I'm the Chief of the Hydrologic
5 Engineering Branch. ISG-014 is designed to provide
6 improved guidance to our staff on how to deal with the
7 radiological consequence of accidental liquid
8 radioactive release scenarios dealing primarily with
9 groundwater.

10 As a branch, we noticed a lot of RAIs
11 being issued to address the regulatory requirement for
12 this analysis. So this guidance is intended to
13 clarify existing guidance provided in SRP 2.4.12 and
14 2.4.13, in addition to Reg Guide 1.206.

15 A risk-informed hierarchial process is
16 proposed, where conservatively-bounding scenarios can
17 be first applied to determine compliance with Part 20,
18 Appendix B. An example of this approach could involve
19 an applicant setting K_d values to zero. This would
20 normally mean that the time of transport is minimized,
21 and, therefore, resulting in a maximum concentration
22 at the receptor point.

23 For this example, then, carried forward,
24 the applicant would determine radioactive
25 concentrations at a receptor point offsite, and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 comparing these concentrations with the ECLs, also
2 known as effluent control limits, to determine the rad
3 risk. This ISG allows for the flexibility, however,
4 of ratcheting in more realism throughout the process,
5 such as the collection and analyses of onsite
6 measurements of K_d as appropriate.

7 I would like to thank Dr. Hosung Ahn, Joe
8 Giacinto, and Mark McBride for their efforts in
9 drafting this ISG at this point, and Dr. Hosung Ahn
10 will be providing -- or presenting for the branch, for
11 RHEB.

12 MR. DEHMEL: All right. This presentation
13 consists of five major parts -- an introduction,
14 addressing the need of ISG-013, given SRP Section 11.2
15 and BTP 11.6, and some of the underlying regulatory
16 bases; and a review of issues and bases for the
17 proposed update; some of the core elements of the
18 proposed interim guidance with selected points of
19 emphasis, which I am going to go over. And we are
20 also going to look at whether the revised guidance
21 affects the areas of review and interface with other
22 SRP sections in the context of Section 11.2 and BTP
23 11.6.

24 And then, finally, an approach -- the
25 approach that we are thinking about in finalizing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ISG-014, with -- obviously, integrated with the
2 comments and resolution of issues on ISG-014, given
3 public and industry comments, any comments that this
4 has generated.

5 So why is this ISG needed? This ISG is
6 needed because of inconsistent and incomplete guidance
7 within SRP Section 11.2, BTP 11.6, and the interface
8 with SRP Section 2.4.13.

9 In the context of BTP 11.6, the issues are
10 associated with the scope of acceptance criteria and
11 consideration for design features that may mitigate
12 the impact of a release, definition, and selection of
13 all site dose receptors, and assume release scenarios
14 and potential impact on surface water bodies and
15 direct exposure pathways.

16 On the development of radioactive source
17 term, there is a need to provide further guidance on
18 the selection of radionuclide and radionuclide
19 distributions, selection of plant systems, and tank
20 assumed to fail, processes by which radioactivity is
21 assumed to be released in the environment, and
22 clarification on the degree of conservatism that would
23 need to be applied specifically between BTP 11.6 and
24 SRP Section 2.4.13.

25 Just as an example of some of the issues

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we found in reviewing design certification and
2 COLA applications, some of the things that we kind of
3 stumbled across and had to deal with with the
4 applicant involve assumptions and credits for
5 mitigating design features, assumptions on the release
6 mechanism and duration of the release, source term
7 development, and assumed radionuclide distributions,
8 determining the point of compliance in the context of
9 both SRP sections, and whether the point of compliance
10 includes drinking water.

11 These slides identify the applicable
12 regulatory requirement and regulatory guidance. It
13 should be noted that there are no requirements in the
14 regulation that specifically forces the applicant to
15 actually do that kind of analysis. It is all
16 inherently contained within the SRP NUREG-0800,
17 Section 2.4.13, and 11.2, and BTP 11.6.

18 CHAIRMAN RYAN: Jean-Claude, isn't that a
19 fairly narrow view of the world, though? I mean, you
20 know, a powerplant has a water permit for some local
21 government unit. And I just wonder how we can
22 recognize that they have other obligations that impact
23 on what they do in this meeting the NRC obligations?
24 You know, I mean, my simple-minded view is that
25 25 millirem is the dose number we use for NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculations, but very quickly at the Franz plus one
2 foot it is four millirem. So how can we look at the
3 NRC requirements in isolation of the others?

4 MR. DEHMEL: Okay. Let's --

5 CHAIRMAN RYAN: I know that is the million
6 dollar question right out of the box.

7 MR. DEHMEL: Yes. But we should maybe go
8 back and understand the underlying premise of how this
9 accident scenario, this consideration, came to being.

10 It is there purely for two things.

11 One of engineering analysis of the design
12 features of the building, and if there were -- if
13 there were a major malfunction of the equipment, if it
14 were to fail and there were to be a leak, ultimately
15 that information, the purpose of that information is
16 to actually set a tech spec on the amount of
17 radioactivity on that particular tank for the assumed
18 dose receptor locations, such that if you had
19 radioactivity in that tank and it leaked you wouldn't
20 exceed the tech specs and the dose that was applied at
21 the particular time.

22 CHAIRMAN RYAN: So 25 millirem.

23 MR. DEHMEL: No. So right now -- right
24 now, the way it was always set up, if you go back to
25 1975, in the SRP and Reg Guide 1.70, it was always

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 based on the effluent concentration limits of
2 Appendix B2, Part 20.

3 And so with the various successions over
4 the -- the various revisions of the guidance, the SRP,
5 the Reg Guide 1.70 and 1.206, and now the revised SRP
6 and BTP, the dose is still based on -- or the main
7 acceptance criteria surveys on meeting the effluent
8 concentration limits of Appendix B2, Part 20, Table 2,
9 Column 2.

10 So currently it is 50 millirem, if you
11 were just to look at the effluent concentration limits
12 of Part 20, and it is for that sole purpose. So
13 basically, in the context of 11.2, and BTP 11.6, it is
14 viewed as an engineering analysis for the purpose of
15 specifying specific tech specs for the amount of
16 radioactivity you might have or might be allowed in a
17 tank that we are "limiting" for the purpose of storing
18 radioactive liquid waste.

19 CHAIRMAN RYAN: In your view, does that
20 cover not only the accident scenarios like you
21 describe but the slow, ongoing leakage scenarios?

22 MR. DEHMEL: No, absolutely not. It
23 presumes a pump failure or pump release. That's it.

24 CHAIRMAN RYAN: So there immediate
25 observation, and some action would be taken --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEHMEL: Exactly.

2 CHAIRMAN RYAN: -- to address it right
3 away.

4 MR. DEHMEL: Exactly.

5 CHAIRMAN RYAN: That's the assumption.

6 MR. DEHMEL: This does not deal at all
7 with slow, protracted leaks on pipes and other parts
8 of the facility and buildings. It is -- those aspects
9 are currently captured in Part 20, 1406, and
10 associated requirements of the design criteria that,
11 you know, there should be no unmonitored and non-
12 controlled releases.

13 So the evolution of the BTP and how it
14 evolved essentially was for -- well, it initially was
15 in Chapter 15, and later on it was thought that, well,
16 this is not a design basis type of accident, so it was
17 moved into Chapter 11.2. And we have a parallel
18 scenario for the failure of the gas -- the gaseous
19 waste management system, where you -- if you have a
20 PWR, you have delay tanks, or you have BWR, you have
21 charcoal delay bed, there is an analogous analysis
22 just for that purpose as well.

23 So those -- in the context of 11.2 and
24 BTP, it is that it is really addressing, you know,
25 kind of an assessment of the engineering capabilities

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the building, of the facilities. And then, given
2 that, one would assign a tech spec either on the gas
3 delay tank -- on the gas decay tank or the gaseous
4 waste management system or in the liquid rad waste
5 tank.

6 CHAIRMAN RYAN: Okay.

7 MR. DEHMEL: So it is kind of disconnected
8 and divorced with the current issues with what we see
9 and we read about, all the tritium leaks and so on.

10 CHAIRMAN RYAN: Okay. That needs to be
11 rethought.

12 MR. DEHMEL: That's one option. The one
13 that we, the staff, are confined to the context of how
14 this -- these requirements evolve. The thinking about
15 the ISG-013 and for ISG-014 is that we are thinking
16 about restructuring or providing more information,
17 more guidance, in the original intent of 2.4.13,
18 original intent of SRP 11.2, and BTP 11.6.

19 What you're talking about is going beyond
20 what were -- the intent of those -- of the
21 requirements or guidance in the SRP. And that
22 essentially is something that would require perhaps
23 some additional licensing, you know, review -- in
24 other words, it's above the technical staff's
25 consideration. It would be an issue, for example, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 NRO, or DNRL would have to tackle and address.

2 MR. ROACH: Mike, this is Ed Roach again.

3 Along that line, the low activity, large volume tank
4 is another failure that, you know, we think needs to
5 be addressed as part of this, because there are tanks
6 that -- say a condensate tank on a facility that could
7 develop a leak and fail, and that may be an insidious
8 leakage into the groundwater as opposed to the
9 catastrophic failure.

10 There have been questions asked about that
11 in various applications. So those questions are being
12 asked at the application level, and using 10 CFR
13 20.1406, and Reg Guide 4.21 as the basis for that.

14 CHAIRMAN RYAN: Yes.

15 MR. ROACH: Again, having reviewed this,
16 this does come from the evaluation section of the
17 former standard review plan 15.7.3, "Postulated
18 Radioactive Releases Due to Liquid-Containing Tank
19 Failures." And this had I think its nexus in the fact
20 that many of the original sites had refueling water
21 tanks located outside of the auxiliary building and
22 were subject to either a vehicle accident and
23 subsequent catastrophic dump into the storm sewer.

24 So we -- that got carried into the March
25 2007 version in Chapter 11 of the BTP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: Yes.

2 MR. ROACH: And so in our reviews we found
3 areas for improvement, and that's our -- that has been
4 our direction, yes.

5 CHAIRMAN RYAN: Kind of leaving 1406 aside
6 I guess is really what you're saying.

7 MR. ROACH: Although I think -- this is Ed
8 Roach again. I think in the ISG-014 there is some
9 discussion of the 20.1406 features that could be used
10 to mitigate the consequences or the likelihood of it
11 making it to the groundwater/surface water.

12 CHAIRMAN RYAN: I mean, I guess you could
13 make an argument that the catastrophic values in the
14 -- you know, truck crashing into a tank or whatever it
15 might be, are not as important as the incipient slow
16 leakage.

17 MR. ROACH: I think -- and this is where
18 the paradigm diverges here -- is that in the realm of
19 safety, the concern is the dose to the receptor at
20 that point, and then the 20.1406 tends to be the
21 residual radioactivity, because it is -- to have
22 enough activity into the environment to give that dose
23 to the receptor is very difficult. I don't disagree
24 with the fact that it is something we additionally
25 need to look at, because it is putting something in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the groundwater that doesn't belong there. So --

2 CHAIRMAN RYAN: It is a dose issue,
3 because, you know, I guess even though the NRC doesn't
4 -- may not agree with the numerical model, or may -- I
5 don't know -- but for groundwater it is four millirem.

6 MR. ROACH: We are going to change that.

7 CHAIRMAN RYAN: So very quickly you've got
8 a situation where you're at a licensed facility,
9 everything is rosy with 25 millirem, or whatever
10 number you want to, you know, apply. If you get off
11 the fence, you're not longer in that regime. You can
12 -- I mean, you could make an argument either way.
13 Well, it was compliant when it left or it's compliant
14 now, it is compliant here, and it's not the same
15 standard going forward, so it doesn't comply. I'm
16 sure you've heard all of that before.

17 MR. ROACH: Yes. Just for -- yes. Just
18 for clarification, the four millirem limit you speak
19 of is from the --

20 CHAIRMAN RYAN: From the EPA with drinking
21 water.

22 MR. ROACH: -- drinking water.

23 CHAIRMAN RYAN: Yes.

24 MR. ROACH: Okay. As opposed to a
25 radiological effluent or --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: Right.

2 MR. ROACH: -- environmental monitoring
3 type, yes, okay. I concur, I agree with that. And
4 the fact that once radioactive effluents are released
5 into the groundwater, essentially the mitigation
6 opportunities are very difficult. And the likelihood
7 of you recovering that and minimizing the dose, making
8 it ALARA offsite, are what I would consider difficult.

9 CHAIRMAN RYAN: Okay. Again, I'm just
10 trying to understand, you know, how that context is --
11 I know there is a task force that is kind of wrestling
12 with those questions, but it is not unrelated to these
13 two ISGs.

14 MR. ROACH: Yes.

15 CHAIRMAN RYAN: I don't --

16 MR. ROACH: I will agree with you that it
17 is not unrelated, because it is central to everything
18 we think of right now. But in the case of --

19 CHAIRMAN RYAN: How it's related is yet to
20 be determined.

21 MR. ROACH: Exactly.

22 CHAIRMAN RYAN: I'll agree with you as
23 well, so --

24 MR. ROACH: Yes. That's how we are trying
25 to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: Yes.

2 MR. ROACH: -- evaluate that piece of it.

3 CHAIRMAN RYAN: Okay. Thanks. Sorry,
4 Jean-Claude.

5 MR. DEHMEL: That's quite all right.

6 Now, I mean, we understand the issue that
7 you're bringing up. The only thinking -- the thought
8 right now is that you may have to find another vehicle
9 with which to deal with this. You know, the use of
10 BTP 11.6 and 2.4.13 may not be the appropriate vehicle
11 for this, so we may have to develop -- we would have
12 to -- if we were going that way, we probably would
13 have to develop another section in the SRP that would
14 essentially address the issues with slow protracted
15 releases from piping and equipment that leak over the
16 years.

17 MR. WIDMAYER: I guess I got confused --
18 as Ed pointed out, when I read ISG-014, and all of a
19 sudden 20.1406 came up, I really could not figure out
20 what was going on. And it was difficult to understand
21 the nexus of the two, and whether or not 20.1406 is
22 relevant or irrelevant or --

23 MR. DEHMEL: In the context of BTP 11.6
24 and Section 11.2, for the purpose of this
25 presentation, no, it's not relevant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WIDMAYER: For yours. But what about
2 for Hosung's?

3 DR. AHN: This is Hosung Ahn. Before I
4 developed the ISG-014, we consulted with OGC on
5 whether we included 20.1406 on this or not, and OGC
6 said that we should separate that from this guidance,
7 because this is only for the safety and that may be
8 handled on IRG-4.21 and the NEI-0808. So they said
9 that it's better to separate that. That's what I
10 wrote.

11 MR. RAIONE: This is Richard Raione. One
12 other point may be that what may help to clarify this
13 is ISG-014 really looks at the physical processes, the
14 physical hydrology or physical hydrogeology to derive
15 projected concentrations at offsite locations, the
16 receptor points, etcetera, maybe more than one. So
17 that may be one way to look at it.

18 We are differentiating from health physics
19 and pure hydrology, looking at release scenarios.
20 When you look at the overall context, though, I can
21 understand -- where ISG-014 and 013 don't address
22 chronic sort of impacts, we are looking at acute -- if
23 I could use that terminology -- and it's just looking
24 at one potential theoretical release scenario.

25 There are several that of course are being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looked at now. How to tie them all together, what to
2 integrate, what not to integrate I think is the
3 difficult question to answer.

4 MR. DEHMEL: Okay. So, again, going back
5 to -- so the current requirements are contained in SRP
6 Section 11.2, BTP 11.6, and also in Reg Guide 1.206.

7 As I mentioned earlier, the accident
8 failure scenario considerations were initially
9 contained in Chapter 15 of the SRP, and the FSAR, but
10 it was later on thought that this would be more like
11 an anticipated operational occurrence as opposed to a
12 design basis accident, so it was moved in
13 Chapter 11.2.

14 There is additional guidance provided in
15 NUREG-0133. This is the document that basically forms
16 the basis of the ODCM that is dated October 1978. And
17 with NUREG-0133, this is when -- the first appearance
18 of the assignment of a technical specification on the
19 amount of radioactivity that would be allowed in a
20 specific tank outside of containment.

21 Now, as part of the effort that led to the
22 March 2007 revision of the SRP, we, the staff,
23 identified working on revising Chapter 11 and looking
24 at Section 2.4.13, and we identify a number of
25 inconsistencies and issues that we wanted to address.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But at the time, there was a concern that
2 the NRC should not change its licensing basis. And,
3 in essence, we were told at that point, given that we
4 are in the process of preparing a revised SRP and new
5 Reg Guide 1.206, at the same time applicants were
6 cranking out design certification application, that at
7 that time the NRC should not be changing its licensing
8 basis work. So we were essentially throttled back and
9 trying to make certain changes to the SRP and the
10 associated guidance.

11 So this slide identifies an example of
12 issues forming the basis of the update. The main
13 point of these slides -- and we'll see that they are
14 carried on later on. The main point of these slides
15 are plant design features and actual or assumed site
16 features. So this is essentially now a cross-
17 connection or an interface between BTP 11.2 and SRP
18 Section 2.4.13.

19 Application of conservative versus average
20 assumptions in formulating the accidents and
21 conditions, the use of passive and durable mitigating
22 design features, tank selection and failure
23 mechanisms, radionuclide mobility, gradient
24 application of simple to more complex transport
25 models, and that is going to be addressed in more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 detail during the next presentation, and a need for
2 expanded scenarios to differentiate drinking and non-
3 drinking water pathways.

4 So this is the first of three slides
5 addressing the core elements of the proposed revised
6 guidance. On failure mechanism, the proposed guidance
7 provides clarification and justification of the
8 postulated failure, addresses more specifically tank
9 selection and location, indoors versus outdoor,
10 ranking the tanks in terms of activity and inventory
11 against volumes, and whether the release is surface
12 bodies or groundwater.

13 This essentially is an illustration or our
14 further clarification, further point of what Ed
15 mentioned earlier, is that now we are -- with the
16 revised guidance, we are forcing the staff and the
17 applicant to look at two different types of
18 inventories -- large volume and low activity, low
19 volume or high activity. And the idea is to capture
20 the kind of tanks that would be the most limiting.

21 For mitigating design features, the
22 expanded guidance focuses on the use of passive and
23 durable design features, with the ability to contain
24 the entire tank volume and the capability to spill
25 liquids through an appropriate system or tanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For radioactive source term, the emphasis
2 is on justification of the selected tank, and its
3 liquid inventory, irradiated material inventory,
4 distinction between short and long-lived radionuclides
5 with respect to surface, or groundwater impacts and
6 environmental mobility.

7 The guidance has been expanded to now
8 consider the fact that -- because typically the
9 thought was this -- the major impact would always be
10 groundwater, a pathway. And as a result of that, the
11 analysis tended to exclude short-lived radionuclides
12 and focus on the longer-lived radionuclide.

13 Now, we have added a new dimension to the
14 requirement by adding surface pathway, where now you
15 want to consider both short-lived and long-lived
16 radionuclide. Well, for groundwater pathway, the
17 focus will still be on longer-lived radionuclide,
18 unless it can be shown that there is some enhanced
19 mobility of the radioactivity, and, therefore, one
20 might retain a number of radionuclides.

21 CHAIRMAN RYAN: Why doesn't it show
22 tritium on there?

23 MR. DEHMEL: Hmm?

24 CHAIRMAN RYAN: Why isn't tritium on the
25 list in the last -- I know this is long-lived and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 environmentally mobile, but tritium --

2 MR. DEHMEL: Oh, no. Tritium -- sorry,
3 tritium is there.

4 CHAIRMAN RYAN: Okay.

5 MR. DEHMEL: Yes, tritium is there. Yes,
6 it's not listed there, but if you look at ISG-013 we
7 have a table in the back.

8 CHAIRMAN RYAN: It is there?

9 MR. DEHMEL: It is there, absolutely.

10 CHAIRMAN RYAN: Okay. That is a promise,
11 okay. I was going to say, that's your number one
12 friend if you are trying to do some modeling.

13 MR. DEHMEL: Yes.

14 CHAIRMAN RYAN: Okay. Fair enough. Very
15 good.

16 MR. DEHMEL: Yes. The thought was that,
17 you know, it's like tritium we would be expecting
18 anyway. So these are other radionuclides that we
19 don't see being considered in the application. For
20 example, DC-99 and INL-129, we don't see these being
21 essentially included in the applications.

22 CHAIRMAN RYAN: Well, but, you know, we
23 just accept the fact tritium is going to be there I
24 guess. I mean, it can be there in fairly large
25 numbers, but, again, that to me is a significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potential for discontinuity between what a groundwater
2 standard might be, what a local standard might be,
3 versus drinking water versus an NRC dose-based or
4 risk-informed release criteria. Twenty thousand
5 picocuries per liter is of no consequence in a license
6 situation. It is four millirem for an entire year of
7 drinking water.

8 So how do we deal with that discontinuity?

9 I guess that's the sort of central question I keep
10 coming back to when I think about this. The structure
11 of the analysis isn't as problematic as the potential
12 disconnect between two rules of what is okay.

13 MR. DEHMEL: The requirement to address
14 the other regulatory requirement -- and if you look at
15 the drinking water standard -- if you have -- if a
16 leak were to occur from a tank, it were to fail, it
17 does not absolve the applicant or the operator to
18 actually consider all other regulatory requirements.

19 CHAIRMAN RYAN: NRC regulations to.

20 MR. DEHMEL: Yes, all other regulatory
21 requirements, in addition to NRC. So the operator or
22 the applicant is bound by a number of things. One is
23 to confirm that all NRC regulatory requirements are
24 met, and then consider other federal regulatory
25 requirements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 For example, the EPA drinking water
2 standard is not specifically addressed in the
3 regulation the same way 40 CFR 190 is. But it is
4 embedded in the offsite dose calculation manual. That
5 makes reference that if you have a drinking water
6 pathway near the site, that you should apply the
7 drinking water standards, and look at the impact of
8 the release and see whether or not there are any
9 implications on their drinking water standard. So
10 that's addressed in NUREG-1301 and 1302.

11 CHAIRMAN RYAN: And, of course, those --

12 MR. DEHMEL: It's not embedded in the
13 regulation.

14 CHAIRMAN RYAN: And some states deal with
15 that in an even more specific way. They say it is a
16 drinking water source or a potential drinking water
17 source. So potential resources are also protected
18 sometimes at the local level.

19 MR. DEHMEL: Yes. Yes, that's right.
20 There are other states -- that's right. Right. So --

21 CHAIRMAN RYAN: Particularly out west it
22 gets very complicated, but, you know, it's just
23 somewhere I see that, you know, meeting one
24 requirement doesn't necessarily get you to where you
25 are meeting other or all requirements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Anyway, go ahead. I'm sorry I
2 interrupted.

3 MR. DEHMEL: No, it's all right.

4 This slide addresses the two other
5 elements. The first one provides clarification on
6 approaches used to describe the transport -- the
7 transport of radioactivity in ground and surface
8 water, with the emphasis being on the assumed or known
9 facility and site features, the mechanism that would
10 impact the direction of travel, dispersion of the
11 radioactivity to an outside dose receptor. And,
12 again, that aspect will be presented later on as part
13 of the presentation with -- on ISG-014 in greater
14 detail.

15 The second one focuses on exposure
16 scenarios and acceptance criteria, with the
17 distinction being made on whether the scenario
18 involves direct or indirect exposure pathway. The
19 exposure pathways are direct consumption of ground or
20 surface water. The indirect pathways include the
21 consumption of fish from impacted surface water
22 bodies, and food product impacted by crop and pasture
23 irrigation and livestock watering.

24 It was felt that we should provide more
25 guidance in ISG-013, because in the prior guidance the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 indirect exposure pathways were always being treated
2 as a footnote in the guidance, in what used to be
3 15.7.3 and even in the 1981 version of the SRP. So we
4 felt that it was important to bring this --
5 essentially make it a co-equal with respect to the
6 impact on drinking water.

7 So for direct exposure pathways, the
8 adopted acceptance criteria are the effluent
9 concentration limits of Part 20, Appendix B, Table 2,
10 concentrations, applying some of the ratios to all new
11 radionuclides, all identified radionuclides. And for
12 indirect exposure pathways, the adopted acceptance
13 criteria is 100 millirem dose limit from Part 20.

14 Again, this is in parallel with what is
15 done for a similar accident in Chapter 11.3, the
16 annealed gas system. It is also 100 millirem. Again,
17 it is an acceptance criteria applied to a specific
18 event. It is not a demonstration -- it is not a
19 requirement demonstration with Part 20 requirements or
20 Part 50, Appendix I.

21 So one point I want to reiterate here, the
22 SRP acceptance criterion should not be construed as a
23 demonstration of compliance with Part 20 per se.
24 Rather, they are used as a measure of radiological
25 impact in assessing the consequences and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptability of a tank failure, with the
2 understanding that if you were -- if a scenario were
3 to occur or a situation were to occur where one would
4 exceed the 100 millirem or the effluent concentration
5 limits of Part 20, Appendix B, there are two issues,
6 two options there.

7 One is to change the design such that one
8 may include, for example, install liners in the rooms
9 and cubicles where the tanks are located, such that
10 there would be no such release. And the other one is
11 if there were a release, let's assume the design was
12 not upgraded, then there would be a tech spec imposed
13 on the total inventory of radioactivity and the
14 radionuclide mix for that particular tank. It's the
15 most limiting tank.

16 This leads to this slide here. So the
17 first one -- the first item here is -- places the
18 emphasis on the staff to confirm that the applicant's
19 assessment or results are used to specify maximum
20 quantities of radioactivity with a limiting tank or
21 tanks, and identify whether the radioactivity -- the
22 rad inventory or concentration limits are based on
23 direct or indirect exposure pathways.

24 The revised guidance would identify the
25 operational program and procedures in assuring that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the implementation of the tech specs stays current in
2 light of the result of the current line use senses, or
3 the period line use senses that are conducted.

4 The second part of the slide proposes a
5 revision to the evaluation finding used by the staff
6 in the conclusions sections of the safety evaluation
7 report. So the evaluation findings would be revised
8 to reflect the revised guidance, meaning the final
9 version of ISG-013 in this case, and the wording and
10 the format with regards to findings would be
11 consistent with current practices in the other SRP
12 sections. So this is kind of standard blurb that
13 would be applied.

14 CHAIRMAN RYAN: How would you get to --
15 I'm struggling with drinking water versus non-drinking
16 water pathways.

17 MR. DEHMEL: Because if you were to go
18 back and look at kind of the history of 15.7.3 and
19 BTP 11.6, the main focus was always on drinking water.

20 And in variant footnotes, it said -- if I can find an
21 example here -- original footnote, here is a perfect
22 example of a 1981 SRP, so it focuses on groundwater,
23 and then it says -- the footnote says, "Supply means
24 as well as -- means a well or surface water intake
25 that is used as a water source, with direct human

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consumption," and then it says, "or indirectly to
2 animal, crop, and food processing."

3 CHAIRMAN RYAN: Okay. So this was --

4 MR. DEHMEL: So --

5 CHAIRMAN RYAN: -- written before EPA came
6 into existence.

7 MR. DEHMEL: Yes.

8 CHAIRMAN RYAN: The definition is
9 different.

10 MR. DEHMEL: We understand. We
11 understand.

12 CHAIRMAN RYAN: Yes. So I guess I'm
13 struggling with -- that doesn't help me very much,
14 because I know there is something that supersedes
15 that. I mean, you know, it's not a matter of
16 technical regulation or technical aspects of
17 regulation. It is what the law says groundwater is.
18 It is now defined.

19 You can tell me if I'm wrong. I mean, I'm
20 just trying to understand how we fit together some of
21 these, you know, now 30-year old guidance documents
22 into a regulatory structure that has evolved pretty
23 substantially.

24 MR. ROACH: This is Ed Roach again. In
25 working with Jean-Claude on this topic, I will tell

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you that we have had a meeting with the EPA where they
2 have come in and talked about their possible revision
3 to 40 CFR 190, and their discussion of possibly
4 incorporating groundwater in that part of the rule.
5 But they're at the very early stages, and they haven't
6 seen anything that is going to drive them that way
7 unless it's a real push from the NRC.

8 Now, getting back to what Jean-Claude --
9 the approach we're taking is the approach we have
10 taken for many years as far as the effluent releases,
11 and looking at groundwater as being the offsite --
12 understanding that that is offsite and that's when the
13 -- you start interfering with the EPA. You are still
14 required to meet the EPA guidance, whether or not you
15 have a license to operate a facility under the NRC.

16 So that doesn't go -- I was actually
17 looking in here to find out where that statement is in
18 Part 52, because I believe I read that earlier.
19 That's what I was looking for.

20 CHAIRMAN RYAN: Okay.

21 MR. DEHMEL: I think we understand the
22 disconnect. We were well aware --

23 CHAIRMAN RYAN: Oh, sure. Sure you were.

24 MR. DEHMEL: The question is, you know, if
25 we are going to go along the line of -- that you would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like us to see, it's a major revision of the
2 regulation, of the requirements that are identified in
3 the SRP and in the reg guide. So somebody would have
4 to essentially direct us to do this, because right now
5 we have kind of a, you know, technical and regulatory
6 straitjacket on.

7 MR. ROACH: That's the ACRS.

8 (Laughter.)

9 CHAIRMAN RYAN: No. You know, and again,
10 I'm not trying to pick a fight here. Just -- I'm
11 trying to understand how we deal with what is an
12 obvious disconnect to me. I mean, it just seems clear
13 that it's not well aligned.

14 Now, you know, I mean -- and I have bumped
15 into this a couple of other times. You know, for
16 example, if you have a spill inside the plant, my God,
17 we're clean it up right then and there. You know, if
18 I have a spill outside, I would log it in the logbook
19 and I'm done. You know, that to me doesn't seem like
20 the same ALARA practice. Just an example. So that's
21 why I'm struggling with it. Press on.

22 MR. ROACH: Yes. I --

23 MR. RAIONE: Be careful what you say.

24 (Laughter.)

25 MR. ROACH: Yes, I -- I don't think we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 here to pick a fight either, and the obvious
2 disconnect between, you know, evaluating to the
3 groundwater four millirem per year standard, as
4 opposed to the effluent standards of Part 20 and
5 10 CFR Appendix I, and the other guidance we use, is
6 -- it has been there, and we haven't necessarily
7 resolved that disconnect.

8 We understand that at the site boundary we
9 treat it as -- if you exceed the limits at the site
10 boundary by finding it in a well, then you are in EPA
11 space. The operator is held liable for that.

12 CHAIRMAN RYAN: Okay.

13 MR. DEHMEL: This slide addresses the
14 areas of review and interface contained in SRP Section
15 11.2 and BTP 11.6, with other SRP sections.

16 So, basically, the areas of review --
17 acceptance criteria, technical rationale, review
18 procedure sections of the SRP and BTP, will be updated
19 to reflect a final version of ISG-013 and 014. So
20 this is essentially a simple editorial fix.

21 The interface pointers identified in
22 Section 11.2 and BTP 11.6 would remain -- would remain
23 the same, and there would be no changes with respect
24 to the revisions of ISG-013 and 014.

25 So with the resolution of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicability of the two interim staff guidance
2 documents, just, again, as a reminder, those were
3 issued in two Federal Register notices on
4 February 24th of this year. The comment closing --
5 public comment date was on April 24th. We have
6 received some comments from NEI on behalf of the
7 nuclear industry. We were told that the comments
8 reflect expert from -- with utilities.

9 COL applicants are putting applications
10 together, as well as the engineering and the
11 construction firms, who actually are about to build
12 these plants. So we have yet to evaluate the
13 comments. And as I had mentioned, we may be receiving
14 some other public comments.

15 So the resolution of both ISGs, or in this
16 case ISG-013, will take into account whatever, you
17 know, public comments we have received, as well as
18 comments from ACRS. They are going to be closely
19 coordinated to make sure that we have no conflict
20 between ISG-013 and ISG-014.

21 And then, the applicability of the revised
22 guidance will take effect once those two documents are
23 issued as final documents. You know, they will be
24 posted again in the Federal Register, and also posted
25 on the NRC website as final.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And that's all I have.

2 And then, the last slide, which you --
3 documents the full citation, since we abbreviated a
4 lot of the designations.

5 CHAIRMAN RYAN: Okay. Thanks.

6 MR. DEHMEL: Further questions?

7 CHAIRMAN RYAN: No. You don't get a lot
8 when you have one member sitting here, so --

9 MR. ROACH: Can I just clarify, Mike?
10 This is Ed Roach again. If I were to characterize
11 your concern, it is, how do we address the obvious
12 disconnect between the drinking water standards and
13 the Part 20, Table 2, Appendix B limits used for the
14 evaluations?

15 CHAIRMAN RYAN: I think it is just a
16 slight -- it is not just the drinking water standard
17 or any other applicable -- and it might be a plant-
18 specific, local requirement, because some of those
19 are, you know, even different from the EPA.

20 So, you know, it -- and it's broader than
21 that, too. There's -- you know, the 1406, it looks
22 farther ahead to decommissioning questions. So
23 somehow all of that has got to come together into one
24 coherent plan.

25 Now, it may not necessarily mean the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation numbers. I think, Jean-Claude, you very
2 clearly pointed out that different evaluations have
3 different purposes. So we are not looking at
4 necessarily real doses to real people. We are looking
5 at, you know, accident situations, theoretical doses,
6 and some structure of how that assesses properly the
7 risks that might be involved.

8 So I am completely understanding of that,
9 but at some point, you know, it seems that
10 communicating all of these different bases to the
11 public is very tough. High is a four here and 100
12 there and 25 there, and, you know, what's going on?
13 You know, so somehow we've got to either roadmap these
14 differences carefully and explain them, or develop
15 some consistencies, or both, to be successful moving
16 forward.

17 The tritium task force is a good example
18 there. You know, we were talking about all of these
19 numbers, and lots of plants spent lots of money
20 putting in lots of holes.

21 So, you know, that's really my concern is,
22 how do we get to some consistent picture of how all of
23 the risks that are involved here are assessed? And,
24 clearly, pre-construction axial analysis is one venue;
25 operations with, you know, ongoing, routine,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 authorized releases is another; undetected releases
2 during operations is another.

3 Then, we get to the extended operations
4 questions, you know, the integrity of underground
5 systems, and all of the rest, and ultimately we get to
6 decommissioning where we've got a new set of numbers
7 to work with. And, you know, in some cases, you know,
8 undetected -- previously undetected groundwater
9 contamination, Yankee Rowe for example.

10 And we've got two plants that are
11 licensed, you know, wrestling with it right now that
12 may have impact on their licenses. So somehow there
13 has got to be some coherence put to all of that.
14 "Because it has always been this way" doesn't do me a
15 lot of good.

16 MR. ROACH: That is usually the term that
17 puts the hair up on the back on my neck, so my sense
18 is that the focus here for Jean-Claude was to explain
19 what we are trying to do with ISG-013. And the
20 tritium task force in the previous 2006 published
21 document on lessons learned from undetected leakage,
22 the tritium groundwater, they opened our eyes, and we
23 used those lessons learned to formulate the guidance
24 for 1406.

25 But there are many other, you know, daily

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issues that come to light about tritium at one plant
2 or another that we look at that, and then drag that
3 back to new reactors. But from the agency's
4 viewpoint, we would need to really define what the
5 expectation is for the licensees and step in as the
6 regulator and demand compliance.

7 CHAIRMAN RYAN: So I guess it gets really
8 to the question of, you know, do you feel like ISG-013
9 and 014, and the revisions you've made, have taken a
10 step toward getting at these tougher, more complicated
11 questions?

12 MR. ROACH: Fourteen probably discussed --
13 links 20.1406 more to it. I thought on 13 we were
14 much more focused than the --

15 CHAIRMAN RYAN: Addressed the accident --

16 MR. ROACH: -- the issues -- yes, the
17 accident analysis and the issues we have uncovered in
18 the course of our lessons learned from doing the
19 reviews.

20 CHAIRMAN RYAN: And that is fair enough.
21 I mean, I appreciate that. But, you know, and that's
22 a reasonable conclusion for us to take away. Your
23 purpose wasn't to pull it all together and address
24 some of these other questions, although --

25 MR. ROACH: And I have yet to see the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 final document from the tritium lessons learned task
2 force that just came out. So I understand there will
3 be a recommendation or two for NRO, and -- but I'm not
4 sure what other ones will be agency-wide.

5 CHAIRMAN RYAN: Okay. Thanks.

6 MR. DEHMEL: One fix would be to put
7 ISG-013 or BTP 11.6 back in Chapter 15. This way it
8 will be clear not to be confused with the other
9 requirements in Section 11.2 of the SRP, which
10 essentially is more traditional requirement, Part 20,
11 drinking water standard, and all -- you know, and all
12 of these other --

13 CHAIRMAN RYAN: Well, that's a good point.

14 MR. DEHMEL: You know, and this way it is
15 understood what the purpose of BTP 11.6 is all about.
16 It is "an accident," an analysis -- an engineering
17 analysis that will be used to assign concentration in
18 the -- in a specific tank, not to be confused with the
19 other requirements that are identified in 11.2.

20 CHAIRMAN RYAN: Yes, that's a good point.

21 I mean, in essence, what I'm taking away from your
22 comment is that ISG-013 is really designed to set tank
23 limits more than anything else.

24 MR. DEHMEL: Right.

25 CHAIRMAN RYAN: Is that fair? Is that a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fair conclusion?

2 MR. DEHMEL: Yes, that's correct.

3 DR. AHN: It is my pleasure to present on
4 ISG-014 to ACRS Subcommittee members on radiological
5 protection and the nuclear material. And recently we
6 have -- radiological containment in groundwater has
7 become a hot topic here at the NRC, so I think this
8 topic may be very interesting to everybody, including
9 the ACRS Subcommittee.

10 Okay. My name is Hosung Ahn. I am a
11 hydrologist with Hydrology Engineering Branch of NRO.

12 And in developing this ISG-014, many of our staff
13 hydrologists have made -- including Mark McBride, Joe
14 Giacinto -- he is in the back -- and Dan Barnhurst and
15 Nebiuy Tiruneh, and Richard Raione -- he is my branch
16 chief -- and also Goutam Baachi, he is in the back.

17 In addition, when we developed this
18 ISG-014, we discussed it a lot and worked together
19 with the health physics group, including Ed Roach and
20 Jean-Claude and Steve Schaffer. He is also in the
21 back.

22 And we also communicate with a lot -- we
23 also communicate with OGC a lot, because we have so
24 many issues on our -- so many topics and issues on our
25 -- in reviewing FSAR with our team. And eventually we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 issued RAIs and open item on those sections when we
2 reviewed the FSAR. That's why we initiated this ISG
3 development, and we tried to clarify those kind of
4 issues.

5 Once we developed this ISG, we also
6 distribute this draft guidance to other offices,
7 including NRR and OGC and Research. And we also get a
8 lot of good comment and good constructive suggestions
9 from them. So this is our draft final version of ISG.

10 So this guidance is -- as I mentioned
11 before, this guidance is needed in reviewing the new
12 reactor licensing applications, especially for FSAR
13 Section 2.4.12 and 13. So I am going to start with a
14 brief introduction of why we are -- need this
15 guidance. Richard Raione already mentioned that, but
16 I will clarify that a little bit.

17 Then, I will also introduce how this ISG
18 is related to the existing guidance that are polarized
19 in that. Then, I will also introduce the regulatory
20 requirement and existing guidance with what are the
21 major issues on our SRP areas. I'll introduce that.

22 Then, I will also explain what we are
23 currently doing for identifying the groundwater
24 pathway and how we approach it, the proposed
25 radionuclear consequence. And based on that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 explanation, I may explain the proposed ISG on each
2 subtopical area, including onsite hydrogeology, a
3 screening method for measuring geochemical property,
4 or groundwater modeling, including conceptual site
5 model and as well as a numerical -- mathematical
6 numerical model. Then, how we propose the higher
7 consequence analysis. So that's pretty much the scope
8 I will present.

9 And I present a simple graphic showing the
10 groundwater content map from there -- how we postulate
11 groundwater pathway. On this example, groundwater
12 system is quite simple and stationary, so we can
13 easily postulate groundwater pathway. However, in
14 some cases it is not as simple, and sometimes we use
15 the groundwater model. So I will explain that later
16 in detail.

17 As an introduction, why we needed this
18 ISG? On FSAR 2.4, that is the hydrology chapter, it
19 consists of about 14 sections, and especially it is
20 dealing with groundwater. And for the safety
21 groundwater issue, we have several different concerns
22 there, and one is the -- what is the impact of
23 groundwater to the plant and other outside users?
24 That is one of the critical groundwater issues.

25 And the other one is, what is the maximum

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 groundwater level? That is one of the design
2 conditions on the design certificate. So depending on
3 the design certificate, the site should meet maximum
4 groundwater level.

5 And the last one is the groundwater
6 contamination issue. That is what we are handling on
7 this ISG-014.

8 So FSAR 2.4.12 and 13, we have items
9 including SRP 2.4.12 and 13, as well as we have the
10 guidance on RG 1.206 that describes how we handle
11 those topics.

12 However, there are requirements, but
13 guidance sometimes is not clear or the guidance is
14 very limited on specialty areas. That is why we try
15 to develop this new interim staff guidance.

16 So the goal of this interim staff -- the
17 purpose of this interim staff guidance is provide
18 supplemental guidance on existing guidance of SRP
19 2.4.12, 13, and RG 1.206. Instead of repeating
20 current guidance, we are going to supplement this
21 guidance. That's the purpose of this ISG.

22 Regulatory basis, I think most of them
23 Jean-Claude already introduced, but let me just make a
24 brief introduction. Regulatory basis for FSAR 2.4.12
25 and 2.4.13 are the 10 CFR 20.1403 and 1302 for dose,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and we also used Part 20, Appendix B, for effluent
2 concentration limit or the so-called ECL.

3 Then, for the COL requirement, Part 52.79
4 describes that area. Then, one of the problematic
5 areas is the Part 120. Part 120 is for the --
6 establishing onsite hydrogeologic characteristic.
7 That statement is very broad, but we don't have
8 detailed guidance. That's why we -- I introduced that
9 Part 120 more in detail on the issue area.

10 Then, regulatory guidance, as I mentioned,
11 SRP Sections 2.4.12 and 13 for groundwater flow and
12 transport, as well as RG 1.206. Then, we also used
13 SRP 11.2 and Branch Technical Position 11.6, as well
14 as ISG-014 for accidental release scenario.

15 So we postulate accidental release
16 scenario, then we took that -- we take that scenario,
17 then we -- the radiological consequence analysis in
18 groundwater. That's what we do.

19 And this ISG handled the following
20 specific topical area, including hydrogeologic-based
21 condition, hydrogeologic characteristic -- that means
22 the onsite hydrogeologic characteristic. Then, we
23 propose the guidance on conceptual site model as a
24 pathway and the receptor point. Then, we made the
25 guidance on hierarchial consequence analysis on this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ISG-014.

2 So what other issues -- there are many
3 issues, but I summarized those issues in four
4 different categories. First, we don't have detailed
5 guidance for Part 20(c)(3). I quote that on there,
6 and it's really like -- that is important to
7 hydrogeologic radionuclide transport, and must be
8 obtained from onsite measurement. So this is the
9 requirement for onsite hydrogeologic characterization.

10 And this -- they give some specific
11 example, like such as soil, sediment, and rock
12 characteristic, and absorption and retention
13 coefficient that is related to decay venue. And
14 groundwater velocity as well as distance from the
15 nearest body.

16 So they gave a specific requirement, but
17 we don't have specific guidance on what extent or what
18 frequency we should obtain those -- the onsite
19 hydrogeology. So that's one of the biggest issue --
20 biggest topic on FSAR 2.7.13. And when we reviewed
21 FSAR over those sections, we issued virtually a lot of
22 RAIs and sometimes a lot of open items. That's why we
23 developed this guidance, and we tried to clarify some
24 of those issues.

25 The second issue is there are some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 inconsistencies in SRP 2.4.13 and Section 11.2,
2 especially on what kind of base hydrogeologic
3 condition we should use when we do the consequence
4 analysis. In specific, on SRP 2.4.13, it describes
5 that we should demonstrate thoroughly conservative
6 assumption.

7 However, if you look at SRP 11.2, it
8 specifies that it should be based on the average
9 hydrologic condition. What -- I mean, the hydrologic
10 condition may be pressure test or flow or groundwater
11 level. So there are some differences in what we
12 should use on 2.4.13. That was the issue. So we are
13 going to clarify that issue.

14 Or so -- even between the SRP 2.4.13 and
15 2.4 -- between 2.4.12, 13, and RG 1.206, there are
16 slightly different definitional review areas or
17 acceptance criteria. So we tried to clarify and
18 reconcile those kinds of inconsistency issues.

19 And, finally, SRP 11.2, FSAR 11.2, is
20 dose-based consequence analysis. However, we used the
21 concentration based -- consequence analysis in 2.4.13.

22 So it is -- I clarify it in ISG.

23 And the first issues are absence of clear
24 guidance or limited guidance on groundwater pathways,
25 reviewing groundwater pathway, identifying receptor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point, and analyzing radionuclide consequence
2 analysis, as well as numerical and conceptual model
3 development.

4 So, first, I will provide some -- an
5 example of how we postulate conceptual site model, and
6 from there how we identify groundwater pathway as an
7 example. First, the conceptual site model is a
8 qualitative description of the important future event
9 and process of groundwater flow and transport. That
10 is the definition.

11 And on the right-hand side, I present a
12 simple conceptual site model on groundwater, and on
13 the right-hand side how we postulate the conceptual
14 site model or pathway on the special dimension.

15 If you look at -- on the right-hand side
16 of the graph, we first need to identify the location
17 of the source that is on the bottom -- the nuclear
18 island. From there, how the containment is -- does
19 containment go through the groundwater? Then, it may
20 go -- end up to the pond, then it will go down through
21 the creek, then eventually go to the river.

22 So that's the way we normally generate the
23 pathway. In some cases it is simple, in some cases it
24 is not simple, and sometimes we need to rely on
25 detailed ground or a numerical ground -- or a model to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 postulate, especially the groundwater pathway.

2 And one of the issues on there is that,
3 what is the receptor point? It looks like it's simple
4 to pick the receptor point, but in reality it may not.

5 So that's why I introduced that, how we -- on ISG how
6 we defined the receptor point.

7 A receptor point -- on ISG we defined the
8 source of the part of the water located in the offsite
9 unrestricted area, and the definition of "unrestricted
10 area" is Part 20.1003.

11 On this left-hand side, the red line on
12 the northern side is the site boundary. So we should
13 look at where is the public water use location outside
14 of this boundary. For this example, that is the
15 Savannah River, and actual receptor point is about 30
16 miles downstream.

17 But they just choose the Savannah River on
18 that point -- on that point as a receptor point
19 conservatively. So they make conservative consequence
20 analysis, and check with ECL whether they meet the
21 Part 20 compliance or not.

22 Then, when we reviewed that, we look at
23 the -- what would be the potential future receptor
24 point. When we look at that, we found that --

25 CHAIRMAN RYAN: You are not going to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 able to stand and point. You'll have to tell us,
2 because if you get away from the microphone, he can't
3 hear you.

4 DR. AHN: One corner of that creek area,
5 that is owned by --

6 MR. WIDMAYER: You can use the arrow from
7 the mouse.

8 DR. AHN: Yes.

9 MR. WIDMAYER: The white one.

10 DR. AHN: Okay.

11 MR. WIDMAYER: There you go.

12 DR. AHN: That point. That area is
13 accessed by public land. So, and that is usually used
14 by -- used for recreation purpose and sometimes there
15 are a lot of the cars parking on there, and they may
16 try to use the creek water as a drinking source.

17 So what we think -- in the future we set
18 the point for that area. So when we did 2.4.12 safety
19 evaluation, we choose that point as the receptor point
20 and estimate dose consequence and checked the Part 20
21 compliance. So that's one example.

22 Where is the receptor point? Sometimes it
23 can arguable, and what we recommend on this ISG is may
24 use conservatively on upstream point as a receptor
25 point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: Yes. And that could
2 change in the life of the plant. I mean, you may have
3 groundwater withdrawals that are closer than you ever
4 modeled in the licensing phase. And, you know, your
5 area around the plant has developed, and now you've
6 got new withdrawal points for groundwater. So there's
7 lots of possibilities where that could shift.

8 DR. AHN: Yes. Yes, that's what we --
9 yes. That's why when we choose the receptor point, we
10 should consider all of the future scenarios.

11 CHAIRMAN RYAN: I mean, again, you just
12 said they picked the Savannah River, or they did. I
13 sure wouldn't pick the river. I would pick about 100
14 feet into the river.

15 DR. AHN: Yes, yes. That point is --

16 CHAIRMAN RYAN: Yes, that's fine.

17 DR. AHN: -- potential future. So, or, in
18 fact, when we estimate dilution, we actually don't
19 have a measured flow on that creek point. So actual
20 Part 20 compliance point is more upstream on that
21 area, the creek area, on that site. We have to
22 measure the flow, so we call that as a pseudo-
23 compliance point, and we use that point as a -- to
24 protect the Part 20 compliance.

25 So there are a lot of different ways we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can apply conservatively -- we can select the receptor
2 point conservatively. So we describe that on our SRP.

3 In general, pathway on the surface water
4 may be easy, but groundwater pathway -- identifying
5 groundwater pathways are not easy, so sometimes we
6 need to use the numerical groundwater model to
7 postulate pathway.

8 So once we identify a pathway and the
9 travel time through that -- each of the pathway, then
10 we can easily estimate the consequence -- radiological
11 concentration on the -- at the receptor point. Then,
12 we compare that with the ECL barriers. That's what we
13 normally do on 2.4.13 analysis.

14 Then are the radiological consequence
15 analysis for 2.4.13. We can just detail the flow
16 transport model, but problems that -- we have so many
17 radionuclide species. For example, for the AP1000 we
18 have almost 53 different species, and the consequence
19 analysis of each and every radionuclide is nearly
20 impossible. That's why we proposed a simple
21 hierarchial approach for this consequence analysis.

22 So on the right-hand side of this
23 flowchart, we identify -- first, we collect all
24 available hydrologic or hydrogeologic data, and based
25 on that we make onsite characterization of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hydrogeology and identify release and receptor point.

2 Then, we develop site conceptual model and
3 the identified pathway and estimate travel time. So
4 those belong to FSAR 2.4.12.

5 Then, on FSAR 11.2, they define "release
6 scenario" and "source term" on there, and we took that
7 information to -- then, we made radiological
8 consequence analysis.

9 So first step we look at is whether this
10 selected design certificate has mitigation design
11 future or not. That is only prior to the repeat rad
12 waste management system tank sample component.

13 So if they have mitigation design futures
14 present on there, for example, ESBWR, they -- we
15 approve that they have the mitigation design future
16 criteria. Then, we skip consequence analysis and wrap
17 up the 2.4.13 analysis. If they do not, then we do
18 the consequence analysis.

19 First, when we do the consequence
20 analysis, we may try very conservative and simple
21 equation, simple transportation equation, and make
22 transport calculation and estimate the concentration
23 at the receptor point, then compare it with Part 20
24 ECL failures.

25 And if they meet -- if they meet Part 20

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ECL compliance, then we can stop the analysis, or, if
2 they do not meet, then we will look at more detailed
3 and complex transport equation, and check whether they
4 meet Part 20 compliance or not.

5 And if we use the most complex equation,
6 most detailed equation and still they don't meet the
7 Part 20 compliance, then we recommend to develop a
8 technical specification. Mitigation design future is
9 what we recommend, and the -- to handle that part.

10 So that is the -- what we proposed on ISG-
11 014.

12 CHAIRMAN RYAN: Do you recommend specific
13 modeling tools or techniques? Or do you just leave
14 that to the applicant?

15 DR. AHN: No. We leave that to the
16 applicant. But, in general, we use a simple analogy
17 calculations to estimate the peak concentration at the
18 receptor point. So it is like an expression model,
19 and we applied 53 different --

20 MR. SIMMONS: So very simple. You have
21 to --

22 DR. AHN: It's very simple. However, we
23 can also use like an offsite model or other model.
24 That's possible. Nobody did it that way.

25 MR. SIMMONS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. AHN: So as for post-ISG, let's
2 explain on this specific pathway.

3 CHAIRMAN RYAN: I'm going to ask, is this
4 a good time to take just a five-minute break? Because
5 being only one person, I can't take a break and not
6 stop. So if we could just take a five-minute break,
7 and we'll come back.

8 (Whereupon, the proceedings in the foregoing matter
9 went off the record at 2:17 p.m. and went
10 back on the record at 2:20 p.m.)

11 CHAIRMAN RYAN: Okay. We'll open the
12 record. And thank you, Dr. Ahn, I appreciate your
13 patience.

14 DR. AHN: Okay. Let's talk about onsite
15 hydrogeology. That is the compliance of Part 120.

16 As I mentioned before, the regulation is
17 very broad, and we don't have specific extent on the
18 frequency of the onsite measurement. That's why we
19 tried to provide the same specific guidance on this
20 onsite measurement.

21 The first one, applicant must collect
22 sufficient onsite hydrogeologic data to predict
23 pathways and travel time. And that's the main purpose
24 of this measurement.

25 And second, the consequence analysis in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FSAR 2.4.13 should be based on a long-term annual
2 average of hydrologic condition, to remain consistent
3 with SRP -- FSAR 11.2.

4 Even though we specify long-term annual
5 average, it is easy to estimate peak failure
6 conservatively. So most of the estimates, peak
7 failure, and if they meet Part 20 -- okay, ECL
8 compliance, then it is okay. There are rooms to have
9 more detailed analysis on there.

10 The long-term groundwater -- when they are
11 -- especially for the new site, they don't have long-
12 term data. So how do we define "long-term annual
13 average"? Sometimes it is problematic. So we
14 recommend that applicant may use either indirect
15 method based on the transportation method or correlate
16 -- statistical correlation method to set up the long-
17 term average condition. And then they can estimate
18 the consequence, they can do the consequence analysis.
19 So we gave some latitude on there.

20 Then, hydrologic parameter should be
21 representative -- for example, the pumping test or
22 slow test is one good example. And still some
23 applicants are relying on slow tests. But when we do
24 the groundwater model, slow tested data is almost
25 useless, so we recommend to use kind of the pumping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 test.

2 CHAIRMAN RYAN: I would agree with that.

3 DR. AHN: It's very simple. I give some
4 guidance on there.

5 And next is dealing with the
6 K distribution coefficient. And when we review the --
7 first, let me explain it. Measuring K_d value is quite
8 challenging, because we have so many different
9 radionuclide species, and sometimes measuring short
10 half-life radionuclide is problematic.

11 So we should -- we cannot measure the
12 K_d value for each and every species, so we should
13 screen them based on the risk-informed approach. I
14 explained that a little bit in detail. However, the
15 sample for K_d value measure should be fairly
16 representative conditions. Then, it should be --
17 sometimes the applicants say that -- they take the
18 rock sample and they crush it and they measure the
19 K_d value. But how that is represented in the field
20 condition, that is a question I will -- we will give
21 specific guidance.

22 And for each identified pathway, at least
23 -- or through representative samples for K_d values
24 should be taken? That is the minimum, and we can --
25 applicant can measure more than that. The reason why

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I -- we put that way is that even three -- two to
2 three samples for -- for example, if you have four
3 pathways and 10 species, you should take a lot of
4 samples. Of course, they take time, and that's why we
5 may provide some minimum guidance for that for K_d
6 sampling?

7 CHAIRMAN RYAN: So what is the minimum
8 guidance for K_d sampling?

9 DR. AHN: At least two or three samples
10 around the pathway. That's what we believe is the
11 minimum guidance.

12 CHAIRMAN RYAN: Okay.

13 DR. AHN: There are -- I will introduce
14 how we apply a screening approach for K_d sampling. I
15 mention this characterizes -- the K_d value is
16 challenging, because there are so many species. And
17 for some short-lived K_d , you combine the K_d barriers,
18 it's very challenging.

19 So we need to be selective to estimate the
20 K_d barriers. So one of the recommended methods -- or
21 it's -- we have already used that kind of screening
22 approach to identify the species for K_d , then measure
23 the K_d barrier.

24 First, we may use only decay and dilution
25 process, and check Part 20 compliance. And if they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't -- if a species doesn't meet Part 20 compliance,
2 then we may choose to send for the -- and estimate K_d
3 values. So that's kind of a simpler approach to
4 select a species for K_d sampling.

5 And an example of how we combine different
6 transport process and screening the radionuclide
7 species, then determine which species we need to
8 sample, and the major K_d barrier. That's one reason
9 for -- of the higher -- use of the hierarchial
10 approach.

11 Then, how we review groundwater modeling
12 and pathway. The applicant was -- developed a
13 conceptual site model of groundwater flow and
14 transport. And the guidance in -- guidance for
15 conceptual model is given in NUREG/CR-6805, or there
16 are a lot of different guidance. So we can use that.

17 Then, identifying pathway in the --
18 measure the considerable uncertainty of the model,
19 uncertainty of the data, as well as uncertainty of the
20 scenario -- the conservative scenario as well as the
21 future or use the scenario. Then, we should develop
22 the conservative or the conceptual site model.

23 If the site is -- site hydrogeology is
24 quite complicated. We can use the micro model, either
25 analytical solution or a numerical model based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 site complexity and postulate the groundwater pathway.

2 And Appendix A of this interim staff
3 guidance provides specific guidance for numerical
4 modeling for 12 and 13.

5 As a consequence analysis, as I mention on
6 page 7, we propose a hierarchial approach for the
7 radiation consequence analysis, as well as determining
8 species for K_d sampling and the groundwater flow
9 model, so to minimize the effort and make reasonable
10 analysis.

11 And the staff needs to come from Part 20
12 and this compliance. And this -- the public is -- for
13 the analysis, we analyzed consequence only for direct
14 public oral use. However, I think the FSAR 11.2, they
15 consider both direct and indirect oral use. And if
16 ECL is not met, then staff may recommend to --
17 recommend that applicant should provide mitigation
18 design futures or technical specification. And that
19 is all belonging to the FSAR 11.2.

20 The first bullet, check compliance with
21 the provision of EPA's generally applicable
22 environmental validation standard in 40 CFR Part 190.

23 We discussed that on previous presentation, but it is
24 specified on current SRP 2.4.13. And we discussed
25 this issue with OGC, and whether we need to keep this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guidance or not on ISG-014.

2 And they said NRC doesn't have authority
3 to confirm this one. However, sometimes EPA drinking
4 water standard has -- is more conservative. So when
5 we determine onsite measurement based on the
6 consequence analysis, we may use some more
7 conservative approach, conservative standard, to
8 determine onsite measurement.

9 This way, we try to keep this standard in
10 here. That may make it slightly different from ISG-
11 013. But as a hydrogeologist, we may apply a more
12 conservative standard and determine that degree of
13 onsite --

14 MR. BLAIR: But they're both drinking
15 water standards, and they are different by a factor of
16 12 based on the fact the dose is different by a factor
17 of 12.

18 DR. AHN: On this particular example, we
19 are concerning the tritium. And ECL tritium barrier
20 is 30,000 picocuries per year. However, EPA drinking
21 water standard is 20,000 picocuries per year.

22 So EPA is more conservative. And when we
23 decide K_d value estimate, and other onsite
24 characteristics, we try to use the more conservative
25 standard. That's why we keep the guidance in here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: I'm confused. The dose
2 basis is 50 versus four.

3 DR. AHN: That's dose, but concentration
4 basis is 30,000 versus 20.

5 CHAIRMAN RYAN: I understand the drinking
6 water standard is 20, but how do you get 50 millirem
7 from 30,000 picocuries per liter per year.

8 DR. AHN: I guess it depends how --

9 MR. ROACH: I think the question is if --
10 if the EPA standard is 20,000 picocuries per liter,
11 and it still four millirem --

12 CHAIRMAN RYAN: How does --

13 MR. ROACH: -- per year --

14 CHAIRMAN RYAN: How does 30,000 give you
15 50?

16 DR. AHN: It doesn't.

17 MR. ROACH: It doesn't. It is all the
18 constituents of the Appendix B, Table 2.

19 CHAIRMAN RYAN: I misunderstood. I
20 thought we were just talking about just tritium.

21 MR. ROACH: I believe Dr. --

22 CHAIRMAN RYAN: I apologize.

23 MR. ROACH: -- Ahn is just comparing the
24 tritium values.

25 CHAIRMAN RYAN: If it was just tritium.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. AHN: Yes.

2 CHAIRMAN RYAN: Okay. I'm with you now.
3 Thanks. Sorry.

4 DR. AHN: And the applicant may keep the
5 consequence analysis, if they have mitigation design
6 future. That was not specified on the previous SRP
7 2.4.13, but we include that on our ISG-014. And
8 consequence analysis in 013 is limited to waste
9 management system only, not leak or spills.

10 Resolution and applicability is covered in
11 previous -- for 013, so that's pretty much what I
12 prepared for the presentation.

13 CHAIRMAN RYAN: Okay. Thanks. I guess
14 the real takeaway message is these two updates to ISG
15 is really intended to update the calculations and
16 support accident analysis, and that's it. But that
17 leaves us with other challenges in terms of, what do
18 we do beyond that?

19 MR. DEHMEL: Those challenges remain, no
20 matter what -- this was -- this is always going to be
21 a challenge, in a way.

22 CHAIRMAN RYAN: It follows my catch phrase
23 that all of the stuff has already been done. So --

24 DR. AHN: I think that before we develop,
25 we discussed with OGC to -- to estimate the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consequence analysis on two different places, and what
2 is the meaning of that. And OGC said that FSAR
3 Section 11.2 has finality. Then, why we do a
4 consequence analysis in 2.4.13? It's more like how we
5 understand onsite hydrogeology and how we collect
6 onsite data? That's the main purpose of this 2.4.13
7 consequence analysis. So we developed the guidance on
8 that way.

9 CHAIRMAN RYAN: Well, and I appreciate the
10 point that you have to understand the site to
11 understand how the water is going to behave. I mean,
12 that's clear. It sometimes takes a little bit more
13 work than you might anticipate, but that's fine.

14 MR. DEHMEL: Jean-Claude Dehmel. One
15 approach here would be to build essentially walls
16 around each of these requirements -- 2.4.13 and BTP
17 11.3. I'm sorry, 11.2, BTP 11.6.

18 One is, if you look at the requirements in
19 Part 100, 120(c)(3), it is a characterization of the
20 site. And so you could confine, you know, 2.4.12 and
21 2.4.13 in that context.

22 And then, keep the requirements of BTP
23 11.6 in the context of whether it should remain in
24 11.2 or be shifted to Chapter 15, and keep those, in
25 essence, separate, recognizing that the models one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would use to assess the consequence of a tank failure,
2 the guidance could be self-contained in a newly-
3 relocated BTP 11.6, and essentially leave the
4 applicant to provide justification for the groundwater
5 model that may be used for the purpose of the analysis
6 and thereby keeping the two separate and eliminating
7 this confusion.

8 CHAIRMAN RYAN: It really is a confusion
9 that does need some attention. And I think that's not
10 a bad suggestion, Jean-Claude. I mean, to me, a
11 stylized calculation that is done for an accident
12 analysis, you know, I rammed something into a tank of
13 water, and then the water goes somewhere and I have to
14 assess the impacts, is a whole lot different than what
15 is the true geohydrologic scheme of like the long-term
16 incipient contamination, should it exist?

17 MR. DEHMEL: Absolutely.

18 CHAIRMAN RYAN: So I appreciate that. If
19 I heard you right, one of your suggestions is to move
20 the ISG and tie it back to Chapter 15 versus
21 Chapter 11.

22 MR. DEHMEL: Yes. And if we're going to
23 do that for the rad waste tank failure, we should do
24 it, then, as well as for the gaseous waste management
25 component failure, because this is analogous --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: Yes.

2 MR. DEHMEL: -- you know --

3 CHAIRMAN RYAN: You didn't touch on that
4 today, but it's clearly the --

5 MR. DEHMEL: Yes, right.

6 CHAIRMAN RYAN: -- atmospheric release
7 version of the same kind of thing.

8 MR. DEHMEL: So we would move that as
9 well, because the two are synonymous to one another.
10 And the calculational methodology, and so on, is the
11 same, essentially is, you know, a fairly simple
12 approach, you know, some degree of conservatism, and
13 it's simple. It's a very simple analysis.

14 CHAIRMAN RYAN: And the purpose isn't to
15 assess the consequence. The purpose of it is to set a
16 limit of what can be that tank or that system or that
17 whatever. I think that's really the key to me is it's
18 not so much that you're analyzing a water problem or
19 an air problem. It's that you're analyzing it for the
20 purpose of setting an operational limit, not assessing
21 impacts.

22 MR. DEHMEL: It hinges on whether or not
23 there are design -- engineered design safety features
24 that would preclude the release to the environment.
25 So if -- for example, we had the situation with ESBWR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 They decided to install liners in the cubicles where
2 the rad waste tanks are located, and thereby they just
3 went away with that analysis.

4 But they did the counterpart analysis is
5 that -- now, if you have a spill out of the tank into
6 a cubicle, they did the analysis that was contained
7 way, way back when. And, again, the early guidance to
8 staff and the applicant was the volatile component
9 that would be contained in the water would now be
10 released to the rad waste building stack. So they did
11 that analysis as essentially being the alternative
12 analysis assessing the consequences of that. that
13 used to be in the guidance, but it has been dropped.

14 CHAIRMAN RYAN: Right.

15 MR. DEHMEL: I don't -- there are a lot of
16 things that have been changed in the guidance that we
17 were not able to identify. These are the things we
18 identified when we started to revise this in March
19 2007, and we presented those to management, and
20 management said that the NRO had no time to do this,
21 because it was very time-consuming, which was correct
22 -- to trace it and come up with alternative analyses
23 and guidance to the staff and the applicant.

24 And, two -- and that was the most
25 important factor -- was let's not change the licensing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basis as we are preparing breakout, and as applicants
2 are preparing applications. So we had a March 2007
3 due date, and we had to crank those out.

4 So in the context of Chapter 11, the only
5 thing that we were able to do -- expand the guidance
6 on the outside dose calculation manual, expand the
7 guidance on the process control program, expand a
8 little bit more guidance on -- with 40 CFR 190, and
9 then we were able to introduce the newer standard
10 1813.1 on sampling.

11 So those were, in essence, the changes
12 that we were able to capture and put into the March
13 2007 revision of Chapter 11. That's as far as we
14 could go.

15 CHAIRMAN RYAN: So at this point it
16 remains unattached to the rest of the geohydrologic
17 questions that we have touched on earlier today?

18 MR. ROACH: And what I would like to do,
19 Mike -- this is Ed Roach again -- is just remind the
20 Committee that about a year ago we did present
21 ISG-006, which described guidance for the staff to
22 review for looking at 20.1406 for the systems and the
23 type of controls and barriers. And that ISG will get
24 wrapped back into Chapter 12 and Chapter 11 and the
25 other appropriate features and chapters in the SRP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The one that isn't reflected there is it
2 doesn't go into an analysis of groundwater as far as
3 drinking water standards.

4 CHAIRMAN RYAN: And that would put the
5 engineering side on the front end of what you can do
6 to prevent having 1406 problems.

7 MR. ROACH: That's correct. That's how we
8 reviewed it, but --

9 CHAIRMAN RYAN: And it's how do you
10 analyze one if you have one, yes. I remember that,
11 sure.

12 So I guess, thinking ahead to the
13 presentation for the full Committee, I guess I would
14 make sure that we cover this up front, you know, this
15 issue of what is separate from what, and what the
16 endpoint goals were from the various calculations.

17 And I will help you remind folks that, you
18 know, this is a different question, and it's not
19 totally unrelated because it's the same site, the same
20 model, and the same kinds of questions will come up.
21 What are you modeling for the licensing purpose --
22 which is clear now to me -- for an accident analysis
23 or for an operating condition that is discovered?
24 Which there have been a couple of those. Or whether
25 that is a long-term performance question and ends up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 connecting to other regulatory settings, which mean
2 differing end dose bases than 10 CFR.

3 Is that a fair summary?

4 MR. ROACH: I concur with that. This is
5 Ed Roach again. And I think the point we could do a
6 good job is making clear up front, as you said, where
7 this fits into the scheme, and then what other --
8 maybe in discussion space what other items are out
9 there. And then, I think it is a fair comment
10 regarding the risk basis for all the different
11 regulations, how do they mesh together? I think
12 that's an issue the agency needs to take on.

13 I don't know who is going to do it, but it
14 is clearly -- that adds to the difficulty in
15 communicating risk to the stakeholders in the public
16 meetings. And clearly if the science or the
17 calculations say there is minimal risk to the
18 individuals as a result of this groundwater
19 contamination, we haven't been very successful in
20 convincing or communicating that.

21 CHAIRMAN RYAN: Well, and I think part of
22 it is that, you know, the numbers are just all over
23 the place. When you look at standards versus, you
24 know, what you can actually calculate, and so on, it
25 is just -- it is just tough to get across that, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know, four, 25, or 100, or some other number, in the
2 context of environmental modeling are all the same
3 number, if that's your final number. And the
4 uncertainties in that sort of a model are pretty
5 significant and hard to reduce without tremendous time
6 and expenditure of resources to do it.

7 So I appreciate that probably more than
8 most, having done that kind of work at Barnwell for 20
9 years, including a 15-foot wide infiltrometer that
10 went all the way down to the bottom of the trench.

11 So, you know, it's fascinating work to do,
12 and, you know, you can come up with better and better
13 models the harder you work at it and the longer you
14 work at it. But, you know, we are kind of addressing
15 different regulatory goals. But the real disconnect,
16 which is bigger than what you -- there was one more
17 rung on the ladder, I think, and that's the
18 interagency connects -- or disconnects. I don't know
19 what to say about that except they're clearly there.

20 MR. RAIONE: If you are a member of the
21 public, and you are looking at this and the various
22 stages of all the reviews that we are in, and for the
23 majority of cases, if not all of them, we're saying
24 ECLs are fine, and the 2.4.13 scenarios.

25 And a member of the public would ask the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question, well, but the tritium from the operating
2 plants -- I mean, you guys are looking at this. How
3 does this relate to another picture? And I think
4 doing that tie-in is going to be important. And how
5 you do that -- this is what you had mentioned earlier
6 -- is going to be it is timely.

7 CHAIRMAN RYAN: It does have implications.
8 Again, the one last time is that the 1406 framework
9 of, you know, what decommissioning is going to look
10 like, you know, and to tie that to extension -- you
11 know, talking 48 on 60, and we even heard 80 talked
12 about once or twice.

13 You know, it gets to be a very complicated
14 question for how the behaviors of these systems will
15 begin with this longer timeframe.

16 MR. WIDMAYER: It seems like there was an
17 opportunity at this juncture -- I understand what your
18 pressures were and the timing and everything like
19 that. So that was something that I guess I was a
20 little bit surprised at when I read them was that it
21 seemed like we were missing an opportunity to do some
22 of this. But --

23 MR. ROACH: Again, I would just state that
24 I think we didn't view it in that framework as much as
25 recognizing that there were opportunities to fix the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 standard review plan and make it --

2 CHAIRMAN RYAN: Right.

3 MR. ROACH: -- work for both us and the
4 applicants, so that it was pretty clear what they
5 needed to provide. And that's what we were going
6 after at that point.

7 And I think when we developed the ISG it
8 was probably about a year ago or so -- our draft. And
9 so at that time we were finally getting our hands
10 around the guidance associated with 20.1406 and
11 related documents -- 4.21, NEI-0808 type documents.
12 So, but I agree, we need to look at this in a hard
13 light.

14 CHAIRMAN RYAN: There was a part 2 and a
15 1301 that -- you mentioned F.

16 MR. ROACH: Yes.

17 CHAIRMAN RYAN: The Commission shall set
18 any other requirement it likes basically regarding
19 effluents, and so on. How about E? In addition to
20 the requirements of this part, the licensee is subject
21 to the provisions of EPA's generally applicable
22 environmental radiation standards in 40 CFR 190, shall
23 comply with --

24 MR. ROACH: I don't believe 40 CFR 190
25 talks groundwater.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN RYAN: No, it doesn't.

2 MR. ROACH: It just talks about air and --

3 CHAIRMAN RYAN: Yes.

4 MR. ROACH: Yes, that's what we have been
5 trying to get to is, do we put that in our
6 regulations?

7 CHAIRMAN RYAN: Okay. So that's what is
8 kind of being thought through. Okay. Well, I
9 appreciate it. It has been a very informative
10 briefing and afternoon.

11 Are there any other questions or comments
12 or anything else you would like to add?

13 (No response.)

14 Thank you for a great set of presentations
15 and good discussion.

16 MR. ROACH: Okay. Well, thank you for
17 your patience and --

18 CHAIRMAN RYAN: And I think, just in
19 closing, our -- my role will be to offer a summary to
20 the full Committee, and then have you come back and
21 do, you know, I am going to guess an hour's worth of
22 some of the presentations that you gave today.

23 And, again, I would maybe reemphasize the
24 shift on to some of these harder questions that you
25 are fully aware of clearly, and you know all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 history of them, probably better than anybody else at
2 the table will. So if you can, you know, start with
3 those insights, and then define where the ISG-013 and
4 014 fit in within that greater whirlwind of things,
5 and things that are ongoing, that would really help
6 them I think better understand more quickly what it is
7 you're trying to accomplish with these two ISGs.

8 MR. ROACH: Okay.

9 CHAIRMAN RYAN: Is that a fair comment?

10 MR. ROACH: I'm certainly good with that.

11 CHAIRMAN RYAN: Okay. And, you know, I
12 think -- while Dr. Ahn and I could probably spend the
13 rest of the day talking about various geohydrologic
14 approaches, maybe -- I'm not sure how much that would
15 add to the sort of more central theme, but we would
16 sure like to hear you -- you know, how does the
17 modeling fit into how you make up some of these? But
18 I'm not sure that too many of the folks would be
19 interested in much of the detail on, you know, the
20 specifics of the model. So just that's one way to
21 conserve some time.

22 With that, thank you very much for your
23 time and attention and participation. We appreciate
24 it very much.

25 MR. ROACH: We'd like to thank the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Committee.

2 CHAIRMAN RYAN: Sure. Are there any other
3 last comments?

4 (No response.)

5 We'll close the record.

6 (Whereupon, at 2:51 p.m., the proceedings in the
7 foregoing matter were adjourned.)

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Presentation to the ACRS

Radiation Protection and Nuclear Materials Subcommittee Meeting:

**ISG-013: “Assessing the Consequences of an
Accidental Release of Radioactive Materials
from Liquid Waste Tanks”**

May 18, 2010

Jean-Claude Dehmel
NRO/DCIP/CHPB

Overview



Contributors: Jean-Claude Dehmel, Steve Schaffer, Edward Roach (CHPB Branch Chief)

- Introduction
- Issues & Basis for Update
- Overview of Proposed ISG
 - Failure and release mechanisms
 - Mitigating design features
 - Radioactivity source term
 - Ground or surface water transport
 - Exposure scenarios
 - Acceptance criteria
 - Specifications on tank concentrations
 - Evaluation findings of COLA reviews
- Area of Review & Interface
- Resolution and Applicability

Introduction (1/2)

- Why Is This IGS Needed?
 - Current guidance is internally inconsistent between SRP Sections 2.4.13 and 11.2 and BTP 11-6 to SRP Section 11.2
 - Guidance difficult to implement based on experience with reviews of COL applications
 - Clarify technical guidance and regulatory requirements in applying SRP Section 11.2 with BTP 11-6 and SRP Section 2.4.13 for the review of associated FSAR sections
- ISG Purpose
 - Provide guidance to staff and applicants in structuring the analyses of accidental releases from radioactive liquid waste tanks to groundwater or surface water, and
 - Provide clarification in assessing compliance with regulatory requirements and SRP acceptance criteria

Introduction (2/2)

- **Regulatory Basis**
 - 10 CFR 52.79 , as it relates to equipment used to control releases
 - 10 CFR 50.34a , as it relates to equipment used to control releases
 - 10 CFR 50.36a, as it relates to technical specifications
 - GCD 60 and 61 (Part 50, App. A), as they relate to the control of releases
 - 10 CFR 100.20 (c)(3), as it relates to hydrological transport of radioactivity
- **Regulatory Guidance**
 - SRP Section 11.2 & BTP 11-6 for release scenario and source term
 - SRP Sections 2.4.12 & 2.4.13 for ground water flow and transport
 - RG 1.206 Sections 11.2, 2.4.12, & 2.4.13, as guidance to COL applicants
 - RG 1.143, as it relates to the design features of LWMS
 - RG 1.113 and NUREG/CR-3332, as they relate to modeling aquatic dispersion
- **SRP 11.2 and BTP 11-6 Acceptance Criteria Adopted from:**
 - 10 CFR Part 20, App. B , Table 2, Col, 2 effluent concentration limits, or
 - 10 CFR Part 20 limit of 100 mrem for non-drinking water pathways

Issues & Basis for Update

- Poorly integrated guidance between SRP Section 11.2 (with BTP 11-6) and SRP Section 2.4.13 (plant design features vs actual site features)
- Inconsistent set of SRP acceptance criteria (Part 100.20, Part 20, BTP 11-6) among SRP sections, and description of conditions that envelope site characteristics (conservative vs average conditions)
- Inconsistent guidance in the use of mitigating design features in mitigating radiological impacts (passive and durable features)
- Expand guidance on selection of tanks, failure mechanisms, radiological source terms [nuclides C-14, Ni-63, Sr-90, Tc-99, I-129, Cs-137) and tank selection)], and factors affecting radionuclide transport (enhanced mobility)
- Expand guidance in modeling surface or ground water transport processes from the point of release to dose receptor, including retardation, dispersion, and dilution mechanisms starting with simple models and progressing to more complex ones
- Provide guidance in defining ground and surface water release pathways, exposure pathways, and dose receptors (drinking vs non-drinking pathways)

Proposed Interim Guidance (1/3)

- ❑ Proposed ISG-013 expands and revises:
 - Failure mechanisms and radioactivity releases
 - Technical justification for the postulated failure
 - Consideration for indoor and outdoor tanks
 - Ranking of tanks, low-volume & high-activity vs high-volume & low-activity
 - Prompt vs delayed impacts (releases to surface or ground water bodies)
 - Mitigating design features
 - Use of steel liners, retention basins, dikes, etc.
 - Capability to retain entire volume
 - Capability to pump liquid to other tanks
 - Passive and durable design features
 - Radioactive source term
 - Basis of selected system and tank liquid inventory
 - Radionuclide distribution and concentrations of failed tank
 - Short and long-lived radionuclides vs surface or ground water releases
 - Long-lived and environmentally mobile nuclides (C-14, Tc-99, Sr-90, I-129, Cs-137)

Proposed Interim Guidance (2/3)

- ❑ Proposed ISG-013 expands and revises:
 - Radioactivity transport in ground or surface water
 - Release scenario and assumed conservatism (adverse conditions)
 - Influence of plant structures and facilities on direction and travel path
 - Presence of agents at operating sites that would enhance mobility
 - Transport and dispersion mechanisms of radioactivity to offsite receptors
 - Impact of site conditions, water withdrawal rates, drought conditions, etc.
 - Exposure scenarios and acceptance criteria
 - Direct pathways, surface water body or well water consumption
 - Indirect pathways, fish, invertebrates, crop irrigation, livestock
 - Reliance on local or regional information and land-use census
 - SRP acceptance criteria taken from Part 20 , App. B ,Table 2, Col.2 ECLs, and Part 20.1301 dose limit to members of the public

Proposed Interim Guidance (3/3)

- ❑ Proposed ISG-013 expands and revises:
 - Specifications on tank radioactivity concentration levels
 - Staff to confirm that proposed technical specification limiting radioactivity levels in tanks is consistent with analysis
 - Staff to confirm that FSAR Chapter 16 addresses this commitment in the COL
 - Staff to confirm that the technical specification is supported by the implementation of operational programs and procedures
 - Evaluation findings for combined license reviews
 - Staff evaluation findings revised to reflect expanded guidance
 - Evaluation findings updated to address requirements of Part 100.20 (c)
 - Evaluation findings revised to differentiate between acceptance criteria (drinking vs non-drinking water pathways)
 - Evaluation findings updated to address mitigating design features

Area of Review, Interface

- **SRP 11.2/BTP 11-6 Interface with Other SRP Sections:**
 - SRP 2.4.12, as it relates to the characterization of ground water
 - SRP 2.4.13, as it relates accidental releases of radioactivity in ground and surface water
 - SRP 3.2.1 and 3.2.2, as they relate to seismic and system quality group classifications of LWMS SSC
 - SRP 9.3, as its relates to plant systems and component interfaces with the LWMS
 - SRP 16, as it relates to specifying maximum concentration levels in tanks
 - SRP 13.4, as it relates to the development and implementation of operational programs in avoiding uncontrolled and unmonitored radioactive releases

Resolution and Applicability

- **Final Resolution:**
 - Review and evaluation of ACRS, public, and industry comments on ISG-013 and ISG-014
 - Finalization of ISG-013 and ISG-014 with incorporation of ACRS, public, and industry comments
 - Update SRP Section 11.2 and BTP 11-6 given final issuance of ISG-013 and ISG-014 (as directed by NRO in updating infrastructure documents)
- **Applicability to Part 52 COL Applicants:**
 - Revised guidance will be applicable to all COL/ESP license applications submitted after the formal issuance ISG-013 and ISG-014

QUESTIONS ?

Document Citations

- SRP 2.4.12, Ground water
- SRP 2.4.13, Accidental releases of radioactive liquid effluents in ground and surface waters
- SRP 3.2.1, Seismic classification
- SRP 3.2.2, System quality group classification
- SRP 9.3, Process auxiliaries
- SRP 11.2, Liquid waste management system
- BTP 11-6, Postulated radioactive releases due to liquid-containing tank failures
- SRP 13.4, Operational programs
- SRP 16, Technical specifications
- RG 1.113, Estimating aquatic dispersion of effluents from accidental and routine reactor releases for the purpose of implementing Appendix I
- RG 1.143, Design guidance for radioactive waste management systems, structures and components installed in light-water-cooled nuclear reactor power plants
- NUREG/CR-3332, Radiological risk assessment
- Part 50, App. A, GDC 60, Control of releases of radioactive materials to the environment
- Part 50, App. A, GDC 61, Fuel storage and handling and radioactivity control
- Part 100.20, Factors to be considered when evaluating sites
- Part 50.34a, Design objectives for equipment to control releases of radioactive material in effluents – nuclear power reactors
- Part 50.36a, Technical specifications on effluents from nuclear power reactors
- Part 20, Standards for protection against radiation
- Part 52, Subpart C - Combined licenses, Part 52.79, Contents of applications; technical information in final safety analysis report



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Presentation to the ACRS

Radiation Protection and Nuclear Materials Subcommittee Meeting:

ISG-014: “Assessing Groundwater Flow and Transport of Accidental Radiological Releases”

May 18, 2010

Hosung Ahn, Ph.D., P.E.
NRO/DSER/RHEB

Table of Contents



Contributors:

Hosung Ahn (Lead)

Mark McBride Joe Giacinto

Dan Barnhurst Nebiyu Tiruneh

Richard Raione (RHEB Chief)

- Introduction
- Regulatory Basis and Guide
- Example of Conceptual Site Model
- Flowchart for Consequence Analysis
- Proposed ISG
 - On-site Hydrogeology
 - Screening Approach
 - Groundwater Modeling
 - Consequence Analysis
- Resolution and Applicability

Introduction

- Why Is This ISG Needed?
 - Absence of clear guidance in reviewing FSAR Sections:
 - 2.4.12 (Groundwater), and
 - 2.4.13 (Radiological consequence analysis in groundwater and surface water).
 - The goal of this ISG is to reconcile and clarify FSAR 2.4.12&13 topics in order to more efficiently meet regulatory requirements.
- ISG Purpose
 - To supplement the guidance in SRP Sections 2.4.12&13 in analyzing the consequences of accidental releases of radioactive liquid effluents to groundwater and surface water.



Regulatory Basis and Guide

- Regulatory Basis for FSAR 2.4.12 and 2.4.13:
 - 10 CFR 20.1301 10 CFR 20.1302 for dose limits
 - Appendix B to 10 CFR Part 20 for Effluent Concentration Limits (ECL)
 - 10 CFR 52.79 for COL requirements
 - 10 CFR 100.20 for establishing on-site hydrogeologic characters
- Regulatory Guide
 - SRP Sections 2.4.12 & 2.4.13 for groundwater flow and transport
 - RG 1.206 Sections 2.4.12 & 2.4.13 for COL/ESP applications
 - SRP Section 11.2 and BTP 11-6 for accidental release scenario
 - ISG-013 for accidental release scenario
- This ISG will clarify specific guidance on:
 - Hydrogeologic base condition
 - Conceptual site model
 - Consequence analysis
 - Hydrogeologic characteristics
 - Pathways and receptor

Issues




- No detailed guidance for 10 CFR 100.20(c)(3):
“Factors important to hydrological radionuclide transport (such as soil, sediment, and rock characteristics, adsorption and retention coefficients, ground water velocity, and distances to the nearest surface body of water) must be obtained from on-site measurements.”
- There are inconsistencies (1) between SRP Sections 2.4.13 and Section 11.2/BTP 11-6 on base hydrologic condition in a consequence analysis, and (2) between SRP and RG 1.206 on the review areas.
- Absence of clear guidance in reviewing groundwater pathways, identifying receptors, and analyzing radiological consequence.
- Limited guidance in reviewing conceptual site model and numerical groundwater flow model.

Example of a Conceptual Site Model



Note: CSM is a qualitative description of the important features, events, and processes of groundwater flow and transport.

Radiological Consequence Analysis



* ECL: Effluent Concentration Limits

On-site Hydrogeology

- COL/ESP applicants must collect sufficient on-site hydrogeologic data to predict pathways and travel times accurately in a risk-informed approach.
- The consequence analysis in FSAR 2.4.13 should be based on a long-term annual average hydrogeologic condition.
- Long-term groundwater levels, if not available, could be estimated alternatively using either transposition or correlation methods.
- Hydrogeologic parameters should be representative in space (e.g., pumping test vs. slug test).
- Transport parameters (e.g., distribution coefficient K_d) must be representative of field (undisturbed) conditions, if measured.
- When measuring material K_d values, at least two or three aquifer samples along each pathway should be taken.

Screening Approach for K_d

- Characterization of K_d values is challenging due to the number of radionuclide species and the intrinsic variability of aquifer materials.
- Determining K_d values for short half-life is generally not practical.
- Could use a screening approach to determine radionuclide species for K_d sampling:
 - Estimate concentrations with only decay and dilution processes (no dispersion),
 - Identify species that exceed the applicable concentration or dose limits at the receptor point.
 - Determine K_d values for the identified species using aquifer material samples collected on-site.
- An example screening approach using different transport processes:
 - Decay only (start with all species)
 - Decay + Dilution (determine species for K_d)
 - Decay + Dilution + Dispersion (could use K_d of zero or real values)
 - Decay + Dilution + Dispersion + Adsorption & Diffusion (need K_d values)

Groundwater Modeling and Pathways

- Must develop a conceptual site model of groundwater flow and transport: Guidance is given in NUREG/CR-6805 and others.
- Identify pathways and plausible alternatives considering:
 - Uncertainty of the assumptions used to develop a conceptual model
 - Variability and uncertainty in hydrogeologic data and parameters
 - Uncertainty of contamination scenarios and future water uses
- Numerical Modeling
 - Analytical solution could be used for a uniform, steady flow regime.
 - Detailed numerical model must be used for a complex groundwater system or the groundwater system which could be changed by proposed plant facilities.
 - Attachment A of ISG-014 provides guidance in reviewing a numerical groundwater flow model, including acceptance criteria needed for FSAR 2.4.12&13.

Consequence Analysis

- A hierarchical approach is acceptable and recommended for:
 - Radiological consequence analysis in FSAR 2.4.13
 - Determining specifics for on-site K_d sampling, and
 - Groundwater flow modeling
- Staff to confirm the Part 20 Appendix B ECL compliance against direct public water uses at receptor point(s).
- If the ECL is not met, staff to confirm that applicant provides mitigating design features or technical specifications to limit tank volume and/or concentration.
- Check the compliance with the provisions of EPA's generally applicable environmental radiation standards in 40 CFR Part 190.
- Skip consequence analysis if mitigating design features are found acceptable.
- The consequence analysis in FSAR 2.4.13 is limited to the Liquid Radwaste Management System only.

Resolution and Applicability

- Final Resolution:
 - Incorporate ISG-013 and ISG-014 in future updates of SRP Sections 2.4.12 and 2.4.13.
- Applicability:
 - ISG-014 is applicable to all future COL/ESP license applications submitted under 10 CFR Part 52, “Licenses, Certifications, and Approvals for Nuclear Power Plants.”

QUESTIONS ?