

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 EPR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, May 21, 2010

Work Order No.: NRC-263

Pages 1-130

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

EPR SUBCOMMITTEE

+ + + + +

FRIDAY

MAY 21, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee convened at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Dr. Dana
Powers, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

DANA A. POWERS, Chairman

MICHAEL T. RYAN

WILLIAM J. SHACK

JOHN W. STETKAR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

NRC STAFF PRESENT:

DEREK WIDMAYER, Cognizant Staff Engineer and
Designated Federal Official

SURINDER ARORA

JASON CARNEAL

HANH PHAN

MALCOLM PATTERSON

DON DUBE

ALSO PRESENT:

GREG GIBSON

GENE HUGHES

JOSH REINERT

SANDRA SLOAN

VESNA DIMITRIJEVIC (via teleconference)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:28 a.m.

CHAIRMAN POWERS: The meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards, US EPR Subcommittee.

I'm Dana Powers, chairman of the subcommittee.

ACRS members in attendance are Bill Shack, John Stetkar, Michael Ryan, and Derek Widmayer of the ACRS staff, is the designated federal official for the meeting.

The purpose of this meeting is to continue our review of the SER with Open Items for the combined for the Combined License Application submitted by UniStar Energy for the Calvert Cliffs Nuclear Power Plant Unit 3.

We will hear presentations to discuss Chapter 19 PRA and severe accident evaluation, and we will also continue our discussion on Chapter 19, the DCD SER with Open Items.

I would just like to pause and congratulate everyone at Calvert Cliffs for the wonderful things said about them in the recent Nuclear News, and their outstanding capacity factor that they've been able to maintain over the years. I'm sure you are all very proud and you deserve our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 congratulations.

2 The subcommittee will hear presentations
3 by and hold discussions with representatives of
4 UniStar, AREVA NP and the NRC staff, and other
5 interested persons regarding these matters.

6 The subcommittee will gather relevant
7 information today and plan stake results of the review
8 of this chapter, along with other chapters reviewed by
9 the subcommittee, in other subcommittee meetings to
10 the full committee, at a future full committee
11 meeting.

12 And we might just discuss that. Well,
13 let's not. We'll discuss that in June, I suspect,
14 when we're going to bring all this together to the
15 full committee meeting and round out some of these
16 things, so that we can move to the next phase as
17 quickly as we can on some of these chapters. Things
18 are moving right along here.

19 The rules for participation in today's
20 meeting have been announced as part of a notice of
21 this meeting previously published in the Federal
22 Register.

23 We have received no request from members
24 of the public to speak at today's meeting.

25 But should anyone want to speak, all you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have to do is get my attention and we'll make time on
2 the agenda for you to speak.

3 A transcript of the meeting is being kept
4 and will be made available as stated in the Federal
5 Register notice. Therefore we request that
6 participants in this meeting use the microphones
7 located throughout the meeting room in addressing the
8 subcommittee.

9 The participants should first identify
10 themselves, and speak with sufficient clarity and
11 volume so they may be readily heard. Copies of the
12 meeting agenda and handouts are available in the back
13 of the meeting room.

14 We have also the infamous telephone
15 bridgeline, which surprisingly, works very well. It
16 has been established with the meeting room today, and
17 I understand we'll have participants from UniStar and
18 AREVA NP on the line at various times throughout the
19 meeting.

20 So we request that participants on the
21 bridgeline identify themselves when they speak, and to
22 keep their telephone on mute during the times when
23 they're just listening.

24 Do any of the members of the subcommittee
25 have any opening comments they'd care to make?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I see no "burning issues" presented to us,
2 so I will turn now to Surinder Arora, the NRO project
3 mentor for a review of the Calvert Cliffs Unit 3 COL
4 for some introductory comments.

5 MR. ARORA: Thank you, Dr. Powers. Good
6 morning. My name is Surinder Arora and I'm the lead
7 PM for Calvert Cliffs Nuclear Power Plant Unit 3
8 combined license application.

9 This is our third meeting with the
10 subcommittee, and in the previous two meetings, we
11 have presented a total of five FSAR chapters. They
12 are SERs with Open Items. And in this meeting, we are
13 going to be presenting Chapter 19 which is PRA, and
14 Severe Accident Evaluations, the title of the chapter.

15 As done in the previous two meetings, I
16 will give a brief overview of where we are in the
17 review process for Calvert Cliffs combined license
18 application in a couple of slides, and with that,
19 we'll go to the slides.

20 My first slide is -- shows the public
21 milestones for the six phases of the review process,
22 and we have completed Phase I for all chapters, and
23 currently, we are in Phases II, III and IV on various
24 chapters.

25 This presentation is part of Phase III,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and this is the ACRS review plan. We have already
2 completed chapters 8, 4, 5, 12, and 17, and group 3B-
3 2, which only Chapter 19 is being presented today,
4 which is the third line in this slide.

5 The last slide that I have is a generic
6 open item. That is there because the review of the
7 design certification application is being done
8 concurrently with RCOLA application, and until that is
9 done, this will remain an open item, and it will apply
10 to all the chapters which use information from EPR DC,
11 by reference.

12 CHAIRMAN POWERS: Now as I see it, we can
13 take things to the full committee with this particular
14 open item hanging out over everything else. And it's
15 okay. I mean, I don't see that as causing a problem.

16 MR. ARORA: Yes. We are just counting
17 this as a generic open item --

18 CHAIRMAN POWERS: Yes. I mean, it happens
19 for every single one of them. We all know what --
20 everybody understands that things are condition upon
21 this being eventually resolved, and so I see nothing -
22 - I see no big roadblocks in moving ahead here.

23 MR. ARORA: And other specific open items
24 are discussed --

25 CHAIRMAN POWERS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ARORA: -- and we present you the
2 chapters. That's all I had today, in terms of the
3 overview, and with that, I'll ask Mr. Gibson to start.

4 CHAIRMAN POWERS: And some time we need to
5 sort out the schedule on the remaining chapters. I
6 mean, you guys need to do it and then interface with
7 us.

8 MR. ARORA: Sure.

9 CHAIRMAN POWERS: But it looks like we --
10 I mean, first of all, it looks like we're kind of on
11 schedule, and it looks like we don't need to dally too
12 much here, and we can maybe gain some time on the
13 schedule. Because I'm sure Chapter 3 will occupy your
14 attention for a while.

15 Mr. Gibson.

16 MR. GIBSON: Thank you. John Rucki will
17 be coming over to get the slides. My name is Greg
18 Gibson. I'm a vice president of regulatory affairs
19 for UniStar. This is the fourth time we've been
20 before ACRS, and Dr. Powers, would you like me to give
21 my background again, or --

22 CHAIRMAN POWERS: We're getting to know
23 you, Greg. Let's go ahead.

24 MR. GIBSON: Very good. I appreciate that.
25 I'm here for Chapter 19 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: We remember the background
2 of anybody who left San Onofre to go --

3 (Laughter.)

4 CHAIRMAN POWERS: Hey, if you look at the
5 capacity factors, he left, and look what happened to
6 San Onofre.

7 MEMBER STETKAR: And he probably left at
8 an appropriate time to make actually some money in the
9 California housing market.

10 MR. GIBSON: It did collapse right after I
11 left. Okay. Chapter 19, PRA. John, do you want to
12 go to the first slide. As we've done for each of
13 these chapters, we have of course tried to maximize
14 the use of incorporate by reference from the AREVA
15 design certification.

16 So for our presentation, and throughout
17 our effort, we are going to focus on what are the
18 differences that are site-specific, or what are the
19 open items that we specifically have that differ from
20 that. The rest of it would of course be discussed by
21 AREVA, and I know you've had discussions on Chapter 19
22 already, and this afternoon's session will also be
23 involved with some feedback from Dr. Stetkar.

24 John, next slide.

25 We have today Gene here, who is the acting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 director of PRA for UniStar, and he's going to be
2 assisted by Josh Reinert, who is with AREVA and made
3 the AREVA presentation on Chapter 19. Next slide,
4 John.

5 And with that, I'd like to turn over to
6 Gene, who will be discussing all aspects of Chapter 19
7 for us.

8 MR. HUGHES: Okay. Let me start by
9 introducing myself, and then I'll ask Josh to make a
10 few words about himself, so we're both in the record.

11 As I call on him, it won't disrupt the conversation
12 with his introduction.

13 I am Gene Hughes. I'm the acting director
14 of PRA for UniStar. My career in risk assessment
15 began in the '70s with General Electric. I reviewed
16 the inputs to and treatment of the BWR. I left and
17 joined SAI, which later became SAIC, as the utility
18 director, utility services manager, and led the PRA
19 for Limerick, other PRA applications, subsequently
20 formed Erin Engineering managed it for 23 years, left
21 it, and subsequently formed Etranco, a company devoted
22 to primarily development and support of new-build
23 reactor PRA activities, but also engaged in PRA
24 support, both in the U.S. and Japan and France, and
25 with UniStar.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And if Josh can take a moment and
2 introduce himself, we'll have the introductions
3 primarily out of the way.

4 MR. REINERT: I'm Joshua Reinert from
5 AREVA. I started off in the nuclear Navy as a reactor
6 operator and engineering watch supervisor. I received
7 a bachelor's in electrical engineering from the
8 University of Connecticut. Then I went to MIT and
9 studied under George Apostolakis. I received a
10 master's with a these in --including uncertainty and
11 risk-informed decision making. I went to a company
12 based down the street called Information Systems
13 Laboratories where I did PRA contract work for the
14 Offices of Research and Nuclear Material Safety and
15 Safeguards.

16 And then I have been at AREVA for three
17 years working on the EPR projects the whole time, and
18 I've been the lead of the COLA EPR projects since
19 about late 2007. That's it.

20 MR. HUGHES: The format for the
21 presentation that I prepared for today is shown on the
22 agenda chart. I thought I would start off with the
23 PRA itself, which you have seen, go through a quick
24 reminder of the update treatment during construction,
25 then leading to the longer term, the plans for it, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then go into departures and site-specific features and
2 exemptions, and go through those, and then take it
3 sort of one by one with internal events, seismic
4 margin, external flooding, and the other items on the
5 agenda, which I think is a logical way to go through
6 it.

7 I think the NRC, in their presentation,
8 may go through the open items and the issues that have
9 been addressed. So I think these will dovetail
10 nicely, but I thought this would be a good way to
11 structure this presentation.

12 To begin, the US EPR FSAR Chapter 19 is
13 incorporated by reference, and what that means for us
14 is the PRA that's described in the US EPR FSAR is
15 indeed the Calvert Cliffs 3 COLA PRA.

16 We've gone through and looked at the site-
17 specific features, and those are bounded, and I will
18 go through those one by one, and in addition, we've
19 looked at external events and confirmed, in our mind,
20 that they can be screened out, and have provided that
21 information to the NRC, so that they are in fact
22 screened.

23 And I'll go through each of those, or at
24 least the significant ones, in enough detail to allow
25 you to probe that and ask questions as you would like.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You can go to the next slide.

2 This slide is a repeat from the Chapter 19
3 of the US EPR. I wanted to put it up because it
4 includes the heading, Calvert Cliffs 3 COLA PRA, and
5 since we have incorporated it by reference, this is in
6 fact our PRA, and I thought it would be wise just to
7 roll through these slides and remind you of what
8 you've seen in the past, and the fact that it does
9 apply to Calvert Cliffs per the application and the
10 FSAR that we've submitted.

11 This is for the internal events and
12 dominated by loss of offsite power. It includes fire,
13 it's fairly straightforward, and I think you've seen
14 it before. So I'll go to the next slide.

15 This looks at shutdown events. The core
16 damage frequency from shutdown events is about 10
17 percent of that from internal events. Just to remind
18 you, the internal event number is 5.8 times -- or 5.3
19 times ten to the minus seven per year, and the number
20 here is 5.8 times ten to the minus eight. Go to the
21 next one.

22 This looks at the large release frequency,
23 which is on the order of 10 percent, slightly less,
24 and again, this is directly from the Calvert Cliffs
25 PRA. It's from the US EPR FSAR PRA. It is the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as that which you've seen before. Go to the next.

2 This slide transitions to another slide,
3 or a variation of one that you have also seen in the
4 past. We were here, a few weeks ago, talking about
5 Chapter 17, and in that chapter we talked about the
6 Design Reliability Assurance Program.

7 I wanted to use this similar slide from
8 that, to point out that the PRA as we have it today,
9 at the DC stage and the COLA, our PRA is one that
10 reflects the initial design. The design is not
11 complete in all respects.

12 We've looked at the design comparison
13 between the plant that we have at Calvert Cliffs and
14 that which is described in the design certification
15 application, and there are very few departures, or
16 differences, and we will describe those in a moment.

17 The PRA is described as being used during
18 the construction process for a few key areas. These
19 include alternative evaluations in support of the
20 design effort, looking at procedures as they're
21 developed, technical specification inputs, and of
22 course the Design Reliability Assurance Program which
23 we describe and that supports procurement.

24 In addition to those types of
25 applications, there are other, what we would call

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applications of the PRA that are more detailed. 10
2 CFR 50.69, tech spec enhancement, using the type of
3 approach that South Texas has adopted. And we have
4 not committed to those. So those are not described in
5 the FSAR or in the commitment. Those are shown on
6 this slide as potentials, off to the right, after fuel
7 load, and those types of things may be considered and
8 there may be discussion of those. But those are not
9 in the application that we've provided.

10 MEMBER STETKAR: So Gene, in practice for
11 the COL stage, the only -- I hate to call it an
12 application but for lack of a better term -- the only
13 application of the PRA is indeed to support the
14 population of the Reliability Assurance Program list;
15 is that correct?

16 MR. HUGHES: There are actually two uses.
17 That's one. The other is to use the PRA in support
18 of SAMDA.

19 MEMBER STETKAR: Oh, okay. Great. Thank
20 you.

21 MR. HUGHES: Next slide. There are seven
22 departures and eight exemptions identified on this
23 slide. If you compare this to the latest submittal,
24 the numbers are slightly different. There are five
25 departures and six exemptions described, but this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reflects ongoing discussions with RAIs and updates the
2 number to the current number, and I'm going to go
3 through them for you now.

4 Looking at the departures, the first is
5 the maximum differential settlement across the
6 basemat, which is a structural issue not in the PRA,
7 and so that has no impact on what we're doing. The
8 second and third deal with atmospheric dispersion, and
9 these are for deterministic calculations, and for
10 these deterministic calculations you're looking at the
11 dose in a particular direction with a chi over q type
12 calculation.

13 In the PRA, we don't use that sort of
14 approach. In the SAMDA, which is where this would
15 come up, we use the windrows for the facility, we use
16 the population, and so this also does not affect the
17 SAMDA.

18 For consistency with this discussion, the
19 SAMDA is described in the Environmental Report and we
20 did not plan to go into that today.

21 The fourth item here is the toxic gas
22 detection and isolation. This is the system that
23 deals with ammonia, with chlorine detection, isolation
24 of the control room, and as you'll see when we get
25 into the external events description, we have a basis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on which to remove that system. We do not need it for
2 Calvert Cliffs Unit 3. Next slide.

3 The fifth is the soil shear wave velocity,
4 and this is one in which the nuclear island meets the
5 US EPR shear wave design velocity of a 1,000 feet per
6 second minimum.

7 What we've done is look at the site-
8 specific features and the site-specific buildings, and
9 the ESW building and the EPG building, emergency power
10 generation building, have soil that's slightly
11 different. But we've looked at this from a
12 deterministic defense-in-depth approach, and
13 identified a limit that would be consistent with the
14 structural design capability associated with a 1,000
15 feet per second in the original design certification
16 application, and have high confidence that there will
17 not be a design problem for these structures.

18 In the case of the ESW building, the best
19 estimate is above a thousand, but we've identified,
20 since it was close, that it could be as low as 720,
21 with no problem from a deterministic perspective.

22 Likewise for the emergency power
23 generation building, the best estimate is actually
24 below one thousand, but we've looked at what it could
25 be to achieve the type of structural strength that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 need, and it could be as low as 630 feet per second.

2 So we have high confidence from a design
3 perspective, that there's not a problem, and those
4 types of discussions will occur in the meetings and
5 discussions of the detailed structural design.

6 The SMA of course relies upon the soil-
7 structure interaction with the facility, and the NRC
8 has identified an item for us to continue to look at.

9 We believe there is no problem but we continue to
10 have it under investigation and we will be providing
11 additional information on that. Next slide.

12 Looking at the in-structure response
13 spectra, the Calvert Cliffs 3 in-service -- there are
14 more acronyms in this particular item than I'm used to
15 doing. So Josh be ready, and correct me when I step
16 aside here.

17 MR. REINERT: Okay.

18 MR. HUGHES: The issue is the in-structure
19 response spectra is -- we look at Calvert Cliffs 3,
20 and there's a small exceedance at the low-frequency
21 end when you overlay the curves. It's -- from 10 feet
22 away it's imperceptible. But there is an exceedance
23 that's identified.

24 We looked at the Seismic Margin Assessment
25 and it's based upon the ground-motion response

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spectra, and the ground-motion response spectra is, in
2 fact, bounded by the EPR SSE approach.

3 And so there's no impact on the SMA when
4 we look at it in terms of that. But there is a design
5 issue that resulted in this being a departure and
6 that's being treated in the seismic side.

7 Did I do okay, Josh?

8 MR. REINERT: That's fine.

9 MR. HUGHES: And all of those acronyms are
10 in the last slide. So I don't think I made any new
11 territory. The seventh is the normal power supply
12 system, the 480 volt, the 6.9 kV cooling tower fans.

13 The cooling tower fans are unique to the
14 cooling tower. The cooling tower has some attributes
15 that impact what the size of the fans should be.

16 It's my understanding that the total
17 horsepower is not changed but the actual fan size, in
18 dealing with procurement, moved it from 480 volt to
19 6.9 kV. The number of fans was shifted from something
20 52 to 46 or 48, I forget the exact number.

21 It's not a significant departure from a
22 PRA perspective and it's primarily to accommodate
23 procurement of these items.

24 MEMBER STETKAR: Perhaps the number and
25 horsepower of fans isn't but you actually have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reconfigured the 6.9 kV and 480 volt electric power
2 configuration, to some extent. You've added some 480
3 volt motor control centers in the ultimate heat sink
4 makeup water building, that didn't exist in the
5 certified design.

6 You've reconfigured some of the baseloads
7 on a 6.9 kV system. You've added a new supply to
8 support the switchyard loads, out in the switchyard,
9 which could affect offsite power recovery probability
10 some.

11 I'm curious why the electric power system
12 model in the PRA doesn't need to be revised to account
13 for those changes.

14 MR. HUGHES: I'm going to go into the
15 electric power model in just a few minutes --

16 MEMBER STETKAR: Okay. No problem.

17 MR. HUGHES: -- and this will give Josh
18 time to help me develop a best response to what is a
19 pending question; if you will hold off.

20 MEMBER STETKAR: Sorry. I'll wait.
21 Thanks.

22 MR. HUGHES: Please go ahead, John.
23 Looking at the exemptions, I put in italics the
24 exemptions that are the same as the departures. The
25 reasons for these being exemptions is once the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certification application is approved, then it will
2 become something that will be have to be taken
3 exemption with. So these are the same. The items
4 that are shown here, that are different, include the
5 fitness for duty program, which is a scheduling issue,
6 that can't really be done yet, and it's not in the
7 PRA. The use of advanced zirconium alloy fuel rod.

8 We looked at the MAAP analysis deck and
9 there's nothing in the advanced alloy fuel rod that
10 would impact that. So with consistent severe accident
11 assessments, we've identified nothing that would
12 deviate as a result of this. So it's not PRA-
13 impacting. And the general technical specifications
14 and bases is a scheduling issue and it really can't be
15 done yet.

16 So these items are exemptions but they are
17 things that don't have a significant impact on the
18 PRA.

19 MEMBER STETKAR: Let me interrupt you for
20 a second here. Regarding the tech specs, you're
21 adopting the tech specs that are in the DCD PRA
22 verbatim; right?

23 MR. HUGHES: Yes.

24 MEMBER STETKAR: Okay. And those tech
25 specs allow you -- I don't remember what it was -- I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think it's 120 days, basically, for -- the way they're
2 written, they basically allow you to take each
3 division out of service for 120 days, and there are
4 allowances for I think 72 hours, that you can have two
5 pieces of equipment in the same division out of
6 service simultaneously, not necessarily for planned
7 maintenance, but it could be corrective maintenance in
8 conjunction with planned maintenance.

9 Have you thought, at all, how Calvert
10 Cliffs is actually going to organize their preventive
11 maintenance programs within the context of the PRA?
12 Well, the PRA and the technical specifications.
13 Because that can have an effect on the PRA.

14 MR. HUGHES: Are you asking whether or not
15 there will be maintenance performed with the plant at-
16 power?

17 MEMBER STETKAR: Yes. I am.

18 MR. HUGHES: I'm certain there will be
19 maintenance performed with the plant at-power.

20 MEMBER STETKAR: Preventive main --
21 planned preventive maintenance?

22 MR. HUGHES: Yes.

23 MEMBER STETKAR: Do you have any notion
24 yet -- does Calvert Cliffs have any notion yet, how
25 that might be performed? For example, I'm familiar

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with many plants in Europe that have similar four-
2 train designs, that perform the preventive, scheduled
3 preventive maintenance on-line, in a type of rolling
4 divisional program, if I can call it that. In other
5 words, they do, they take all equipment on Division 1
6 out of service, do all the preventive maintenance on
7 Division 1, return it to service, do it for Division
8 2, do it for Division 3, do it for Division 4.

9 So they find it useful to do it that way
10 for both scheduling and configuration control in the
11 plant, so that they basically know what's out of
12 service at the same time.

13 Do you have any idea whether Calvert
14 Cliffs plans to do a similar type of maintenance?

15 MR. HUGHES: I think -- I would think it's
16 premature to be able to answer that. I think the
17 direct answer would be we've not addressed that yet.
18 I would observe, just independent of the Calvert
19 Cliffs evaluation, that many plants in the U.S. have A
20 weeks, B weeks. They do that type of approach and so
21 it's fairly common.

22 MEMBER STETKAR: Yes.

23 MR. HUGHES: So I would be expecting that
24 it would probably be common here, but the truthful
25 answer is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes.

2 MR. HUGHES: -- we haven't gotten there
3 yet.

4 MEMBER STETKAR: You haven't thought that
5 far. Okay. Thank you.

6 MR. HUGHES: Looking at the --well, next.
7 Going through the site-specific features, the
8 ultimate heat sink makeup water system has adequate
9 capacity for 72 hours, plus makeup, to achieve the
10 longer period. It's not significantly different. In
11 fact it's not different at all from that that's
12 included in the design certification. But it is a
13 site-specific feature.

14 The Circulating Water System has been
15 evaluated, it's been looked at from the standpoint of
16 causing a trip, and from the standpoint of providing
17 support, should one be required, and the treatment in
18 the design certification PRA, the US EPR PRA is
19 bounding.

20 The Raw Water System includes the
21 essential service water makeup supply, is not in the
22 PRA, and there's no recovery credit for that, so it's
23 no impact.

24 The sewage water treatment is not in the
25 PRA. The security access facility and warehouses are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not in the PRA. There is a central gas distribution
2 system which is called the system, but is in fact
3 where gaseous quantities are available to be provided
4 to the station, and we've looked at that under
5 external events.

6 It is not located near the structures that
7 we would be concerned about, and I'll discuss that
8 further under external events in a moment. We've
9 looked at potable and sanitary water system and
10 they're not in the PRA.

11 MEMBER STETKAR: The central gas
12 distribution system -- I'm assuming that pipes
13 hydrogen out to the turbine building and out to the
14 volume control tank. Does the internal fire part of
15 the risk assessment account for things like hydrogen
16 explosions in the turbine building?

17 That's a generic question, obviously,
18 because, you know, where the precise pipes are routed,
19 you know, when you finally build the turbine building,
20 is going to be different.

21 MR. HUGHES: Yes.

22 MEMBER STETKAR: But I was just curious
23 whether, since you mentioned the gas distribution
24 system --

25 MR. HUGHES: It's an interesting question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and I'm actually -- my mind is going to NUREG-6850 and
2 what's done with fire PRAs, and I don't recall vast
3 treatment of pipe failure leading to that sort of
4 thing.

5 MEMBER STETKAR: Well, it doesn't
6 necessarily have to be a pipe failure.

7 MR. HUGHES: It could be of some purpose -
8 -

9 MEMBER STETKAR: When I worked at Zion, I
10 had a melted spot on my hardhat, where I tried to put
11 out a fire by quenching it just because we had a
12 little hydrogen leak on a seal oil unit. So it
13 doesn't have to be a pipe break.

14 MR. HUGHES: Yes. Josh, do you recall if
15 that was looked at?

16 MR. REINERT: I don't remember if that
17 specifically is included in the fire PRA area. I know
18 we did -- I know we initially used a research, an NRC
19 research document to come up with turbine building
20 fire frequencies, and later, we did some sensitivity
21 studies using -- I think it's NUREG-6850. So I would
22 think that --

23 MEMBER STETKAR: It would be more in terms
24 of the consequence of the fire rather than -- you
25 know, it's probably rolled up in the frequency. Its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 consequences -- that's all right. I was just curious.

2 Go on. I don't want to hold up the time.

3 MR. HUGHES: Okay. Go to the next one.
4 Fire suppression systems are credited in the turbine
5 building. The credit in the turbine building is --
6 the turbine building is in fact for fire treatment
7 treated broadly as a single area and it is credited.
8 The RCPs are also relying upon fire suppression and
9 they also have oil collection capabilities, should
10 there be an oil leak for the reactor coolant pumps.

11 This treatment is in the Design
12 Certification PRA, the US EPR PRA and is basically the
13 same.

14 The Fire Water Supply System is included
15 in the flooding PRA, only credited to support fire
16 suppression systems in the fire PRA in the US EPR PRA.

17 So these are also included and are consistent.

18 We looked at site-specific features:
19 turbine building, the switchgear building, grid
20 systems control building, duct banks, the switchyard
21 and while these are site-specific, the treatment of
22 them in terms of equipment and the items inside them
23 is consistent between the Design Certification PRA and
24 the PRA for the COLA Applications. Next slide.

25 This chart is to begin a discussion of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loss of offsite power. I will acknowledge going in
2 that this chart has more detail in it than I'm
3 prepared to address in the presentation. I believe
4 you had a meeting recently on Chapter 8, and this was
5 discussed in substantial detail there.

6 So I put this chart in just to remind you
7 of that discussion as we go into the way we looked at
8 loss of offsite power.

9 The US EPR FSAR has a conceptual
10 switchyard design and the breaker-and-a-half scheme --
11 and this gets at the question that you asked, Dr.
12 Stetkar, or it will open the opportunity to continue
13 the dialogue.

14 The FSAR has a conceptual switchyard
15 design, it uses a breaker-and-a-half scheme that's
16 been adopted in the COLA so there's no change from
17 that approach and from that general design.

18 The capability for runback and supply of
19 house loads from the main generator, the Island Mode,
20 is adopted by the Calvert Cliffs Unit 3 plant and is
21 incorporated in the PRA so the treatment is
22 consistent.

23 There is a site-specific transformer added
24 to support plume abatement, wastewater treatment,
25 desalination and we believe the impact of that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minimal. Next slide.

2 The key features of the switchyard. The
3 switchyard is incorporated based upon a qualitative
4 evaluation. There is a very detailed FMEA in the FSAR
5 for it and it's been reviewed in great detail.

6 What we looked at, from the standpoint of
7 the PRA, was a qualitative review. The design uses a
8 approach that is considered to be among the better to
9 the best, with the number of breakers and the way that
10 it has itself configured. It allows maximum
11 flexibility with no single failure causing loss of
12 offsite power.

13 Any single component can be out of service
14 and it doesn't disrupt connections. The capability
15 for runback and supply, called the Island Mode, is
16 representative of a feature that can prevent reactor
17 trip in cases and thereby reduce the challenges for
18 the nuclear plant to go through a response and shut
19 down.

20 Restoration of power can rely on one of
21 two breakers. Each breaker has one coil in each and
22 we recognize that this was a question asked earlier
23 and so you can restore by going in either of two
24 directions, which gives you access to two coils, one
25 in each of two different breakers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The batteries are in two divisions. They
2 are monitored. The detailed design of the batteries
3 in that part of the switchyard is not available, so
4 the short answer is there is not a detailed PRA
5 analysis of the switchyard. There's a review of the
6 features. There's consistency between the Design
7 Certification or US EPR PRA and the switchyard as it's
8 described for the plant and based on that, we have
9 concluded that it is in fact representative of and
10 bounded by the US EPR PRA.

11 This looks at the numbers, and this is a
12 chart that I adopted from the NRC's SER, and I would
13 give them credit for this chart. We were about to
14 create this chart and we realized we were duplicating
15 something someone else had done, so I would thank them
16 for it.

17 It breaks this chart -- or the chart
18 breaks the loss of offsite power category into plant-
19 centered, switchyard-centered, grid-related and
20 weather-related causes of loss of offsite power.

21 The second column looks at the NUREG/CR-
22 6890 generic value. The third column is the EPR value
23 and then the next two columns look at what the Calvert
24 Cliffs Unit 1 and 2 would be, and what Calvert Cliffs
25 Unit 3 has chosen to be representative of the plant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: And I can't resist
2 commenting that there's not a little -- not even a
3 hint of an indication of the uncertainties on these
4 calculated values.

5 MR. HUGHES: That's absolutely correct and
6 is true of almost every value --

7 CHAIRMAN POWERS: Everywhere --

8 MR. HUGHES: Everywhere it occurs.

9 CHAIRMAN POWERS: And more's the pity.

10 MR. HUGHES: I must comment because I
11 agree with you. The comment I would make is we all
12 know that the uncertainty is a critical and important
13 thing. Uncertainty is treated in the PRAs, but when
14 we report the results and we look at what we provide
15 for regulatory applications, we all too often identify
16 the central value or the mean and I think it's
17 unfortunate. We could certainly add uncertainties to
18 these and we could expand it but the reality is most
19 of the limits or most of the things that people look
20 for is this number and I would agree with you that it
21 is a preoccupation with a single number. I notice
22 that we've been joined by some people that are
23 involved in the metrics issue and that, too, tends to
24 address this thing in this way.

25 And it's a challenge we have to make sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we carry the uncertainty into the way it should
2 actually be treated.

3 MEMBER STETKAR: Gene, I don't know
4 whether this is the appropriate time or perhaps later,
5 when we discuss the design PRA. I must admit, I was
6 surprised when I saw this table in the staff summary
7 of the SER. I was glad to see it and I talked to the
8 AREVA PRA people. I asked them specifically whether or
9 not the PRA includes credit for the load rejection
10 capability of the power plant and they told me
11 specifically that, no, it doesn't, and now I've
12 learned that it does, at least in the loss of offsite
13 power because that's one of the things I wanted to
14 look into, but I didn't because I was told that the
15 PRA doesn't include credit for that.

16 So now that I know that it includes credit
17 for the load-rejection capability for loss of offsite
18 power, my question is, does it include credit for the
19 load-rejection capability for any other initiating
20 event. I want an answer, yes or no on the record,
21 please.

22 MR. HUGHES: Let me turn to Josh. I could
23 answer it but I want to make sure it's the correct
24 answer.

25 MR. REINERT: The answer is no, I just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can't think of any other --

2 MEMBER STETKAR: Well, be careful because
3 you're on the record now. When I asked people off the
4 record, I got that same answer, no and that was
5 obviously not correct, off the record, so I would like
6 the correct answer on the record.

7 MR. HUGHES: Okay. Let me give you a
8 brief answer. What we see here in the grid-related
9 column is where we have taken credit for the load-
10 rejection being treated with the .32 factor. The .32
11 factor is taken from the URD of EPR--

12 MEMBER STETKAR: Gene, if I had a chance -
13 - I'm sorry, I'm just going to cut you off. If I had
14 a chance to look at it, I would have gained some
15 confidence about what was done and perhaps where the
16 values came from. I didn't get a chance to do that
17 because I was told, no, the PRA doesn't include credit
18 for that. So I didn't have a -- and I don't care,
19 right now, where the numbers come from.

20 MR. HUGHES: The important thing is, in
21 order to accurately answer your yes-or-no question, I
22 think the appropriate thing for Josh and I to do is
23 to, either during a break or while I'm here, perhaps
24 Josh can look it up, or someone can help us get the
25 value for the .68 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I don't care about the
2 number. I care about whether any numerical credit was
3 taken anywhere. Anywhere. I don't care what number
4 was used. If it was non-1, I care about if it was
5 used and where it was used.

6 MR. HUGHES: The one place --

7 MEMBER STETKAR: Obviously, it was used
8 here.

9 MR. HUGHES: Obviously, it was used here
10 and I believe the answer to your question includes
11 what's included in the .68 that was adopted from the
12 Utility Requirements Document and I believe that it is
13 only the loss of offsite power in this treatment. But
14 I would like to confirm that by looking up that value,
15 to make certain that that is in fact what is in that
16 .68 value. But that value is --

17 MEMBER STETKAR: I'm not quite sure why
18 the .68 is relevant because the 68 percent of the time
19 that a loss of offsite power event does not result in
20 a plant trip is a non-event. So I'm not quite sure
21 what that 68 percent of the time applies to anything
22 as far as any other initiating event in the plant,
23 like a generator trip, or, you know, things like that.

24 So I'm not quite sure why the number is
25 relevant to whether or not credit has been taken for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 any other initiating event.

2 MR. HUGHES: We will confirm before the
3 presentation is completed that this is the only place
4 the .68 is applied.

5 MR. REINERT: Yes. This is the only
6 place. We took credit for load-rejection on grid-
7 related LOOP, and we did take credit for that in grid-
8 related LOOP, and we did not take credit for load-
9 reduction anywhere else in the--

10 MEMBER STETKAR: Interesting that you took
11 credit for grid-related LOOP and -- because the plant
12 knows that it's grid-related and not switchyard-
13 related?

14 MR. REINERT: No.

15 MEMBER STETKAR: Okay. It knows that it's
16 grid-related and not weather-related?

17 MR. REINERT: No.

18 MEMBER STETKAR: Okay. The plant probably
19 doesn't know that it's grid-related. The grid-related
20 happens to be the largest number, so you took credit
21 to reduce the largest number.

22 MR. REINERT: Well, we had reason to take
23 credit for it in several types of LOOPS, but there was
24 an argument not to take credit for it in the LOOPS
25 non-regulated, so --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Because the plant knows
2 that it's a weather-related loss of offsite power.

3 MR. REINERT: So we conservatively did not
4 take credit for it in the non-grid-related LOOPs. We
5 couldn't think of any reason not to take credit for it
6 for grid-related LOOPs, so that's why we did.

7 MEMBER STETKAR: Why was only the
8 switchyard-centered, the other large number here,
9 modified for consequential loss of offsite power,
10 which is a rather difficult and site-specific issue to
11 get your hands around and you've reduced the
12 switchyard-centered frequency by about 38 or 40
13 percent?

14 MR. HUGHES: The reason for that is the
15 way that the systems are modeled and the event trees
16 are modeled. The consequential loss of offsite power
17 is treated but it's not treated as this initiating
18 event. It's treated as a --

19 MEMBER STETKAR: That's correct, and most
20 PRAs, indeed, use the frequencies in the left-hand
21 column for their initiating event frequency. Some
22 PRAs indeed do take credit for the plant runback
23 features, and if you have reasonable data to support --
24 -- I'm not arguing that it's unreasonable to account
25 for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm arguing that I was told that it didn't.

2 If you're going to take credit for it,
3 it's not clear why you wouldn't take credit for it
4 across the board.

5 On the other hand, when people take credit
6 for that runback feature, they typically will take
7 credit for it across the board. Many, many people
8 today do indeed model consequential loss of offsite
9 power but I'd never seen anyone reduce the loss of
10 offsite power initiating event frequency the way
11 you've done to account for that.

12 I wasn't aware of this either when I went
13 through the review. I tended not to look at the
14 numbers.

15 MR. HUGHES: Let me ask Josh to expand
16 upon the answer, but my understanding is those
17 particular consequential loss of offsite power events
18 are treated as part of and a branch of the events for
19 which they occurred.

20 So if you have a turbine trip and you have
21 consequential loss of offsite power, then you lose the
22 offsite power support and you stay in the turbine
23 trip. Is that correct, Josh?

24 MR. REINERT: That's right.

25 MEMBER STETKAR: That is true. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 models do indeed explicitly account for consequential
2 losses of offsite power. The plant trips and then the
3 grid goes away. It's not clear what fraction of the
4 initiating event frequencies, losses of offsite power
5 events and NUREG/CR-6890, are attributable to that
6 particular phenomenon.

7 MR. REINERT: I think I can explain
8 better, or just related to this consequential-LOOP
9 issue. The reason why it's all taken out of this
10 switchyard-centered is -- it's a table in the NUREG-
11 6890, where it lists all the LOOPS that have happened
12 and how many were in each type of -- or in each LOOP
13 category. In all of the consequential LOOPS, there
14 were three out of, I think, 13 switchyard-related
15 LOOPS. So all of the consequential LOOPS that make up
16 the LOOP frequency were all considered to be
17 switchyard-related.

18 MEMBER STETKAR: Can you give me that
19 table number? I need to think.

20 MR. REINERT: I'll have to look it up.
21 I'll give it to you.

22 MEMBER STETKAR: Yes, that's fine. Okay.
23 Thanks. The reason, obviously, why I'm dwelling on
24 this is that loss of offsite power is the most
25 important contributor, and we've reduced the loss of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 offsite power initiating event frequency here to
2 something on the order of about 60 percent of what the
3 NUREG has, so it's a measurable event. Otherwise, I
4 wouldn't be quibbling over, you know, small numbers.

5 MR. HUGHES: You're absolutely correct.
6 Okay. This looks at the at-power loss of offsite
7 power recovery values and the US EPR value is shown
8 compared to the equivalent Calvert 3, or Calvert
9 Cliffs Unit 3 value, and it demonstrates that the US
10 EPR value is conservative. And this looks at the case
11 of LOOP, or loss of offsite power at shutdown, which
12 occurs over a 24 hour period with recovery and again,
13 it compares the numbers, to demonstrate that the
14 numbers are either the same or they are less than the
15 EPR value.

16 CHAIRMAN POWERS: I have to admit, Gene, I
17 do not hold with this table at all. This one's kind
18 of a mystery to me.

19 MR. HUGHES: Let's go into that and see if
20 we can explain it. What this value is looking at is
21 the shutdown loss of offsite power frequency and the
22 SD LOOP24 is the loss of offsite power in a 24-hour
23 period and the recovery is the likelihood of recovery
24 of that event and, Josh, can you add to that to
25 explain, or how can we illuminate this chart?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REINERT: Well, the shutdown LOOP
2 frequency for US EPR and for CCNPP, those are both
3 taken from 6890. The US EPR value is an industry-wide
4 average and the Calvert Cliffs value is Calvert
5 Cliffs-specific for 1 and 2. Shutdown LOOP recovery
6 is also taken directly from 6890. So the .413 value
7 is taken right out of 6890. There's no -- for
8 shutdown LOOP recovery, 6890 does not provide site-
9 specific values, so we felt comfortable using that
10 .413 value for Calvert Cliffs.

11 MEMBER STETKAR: It might help to explain
12 to the other Subcommittee members, when you say
13 shutdown LOOP recovery, .413 per event, what that
14 means. I'm not sure if that's a source of confusion.

15 MR. REINERT: Okay. That's the
16 probability that, given a LOOP during shutdown, that
17 you have a recovery within a time, and I can't
18 remember if we modeled that time as being one hour or
19 two hours. So that would be the probability of
20 recovering offsite power, given that you had a LOOP
21 during shutdown.

22 MEMBER STETKAR: Recovering or failing to
23 recover?

24 MR. REINERT: Shutdown LOOP recovery, so
25 the probability of recovery.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I want to check whether
2 it's a recovery or failure to recover.

3 CHAIRMAN POWERS: That it's .413 and not
4 .412. If it was .412, you know, it'd just be totally
5 unacceptable.

6 MR. HUGHES: Well, it's a value taken from
7 a NUREG.

8 CHAIRMAN POWERS: That does not bless it.

9 MR. HUGHES: I understand.

10 CHAIRMAN POWERS: Okay. At least I know
11 where the number came from. What's under equivalent
12 CCNPP is just a copy of the number that came out of
13 the NUREG, that it is not equivalent -- it's not a
14 measured value of CCNPP.

15 MR. HUGHES: Oh, that's correct.

16 CHAIRMAN POWERS: Right.

17 MR. HUGHES: On internal flooding, I
18 thought we would now go through some of the events
19 that were analyzed, the more significant ones. The
20 Nuclear Island is unchanged from the US EPR to the
21 Combined Operating License Application, so it's
22 incorporated by reference.

23 Nuclear Island flooding is treated in the
24 PRA. There are no changes to it, so it's
25 incorporated. On the balance of plant, the turbine

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 building is unique, and the value used for that is 3.3
2 ten to the minus two per year in the base PRA.

3 Josh, I'm going to ask you to help me with
4 this particular value because this one is taken from
5 NUREG/CR-2300.

6 MR. REINERT: That's right.

7 MR. HUGHES: And this is the value that we
8 concluded when we went through it, is conservative for
9 a modern turbine building and the detailed design is
10 not yet complete and I was about to describe any of
11 the detailed design features that have been looked at
12 and I don't recall that any of those are different
13 from what was treated in the US EPR PRA and the US EPR
14 PRA, in fact, is a coarse treatment of this that's
15 conservative.

16 So is that -- would you care to expand on
17 that or --

18 MR. REINERT: I would just add that I can
19 confirm that the Calvert Cliffs 3 design is not
20 different than what we thought it was going to be when
21 we did the DC work. But we didn't model it in much
22 detail. So, for example, we didn't model the number
23 of circ water pumps. So it's true that it's
24 consistent with what we thought it was going to be but
25 we didn't model it to that level of detail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Let me, just to get
2 something on the record. This number of 3.3E to the
3 minus two per year that you've characterized as
4 conservative for a yet-to-be-designed turbine building
5 configuration with not quite known plant-specific
6 water systems routed through that turbine building is,
7 indeed, derived from NUREG/CR-2300, which, indeed, was
8 published in 1983. The number, in fact, was derived
9 from Table 11-9 in that NUREG, which was from a
10 compilation of events published in 1981 in a document,
11 and it used to be a periodical called Nuclear Power
12 Experience.

13 So we're looking at reported events of,
14 maybe, turbine building floods in a few U.S. nuclear
15 power plants that were operating before, let's say
16 about 1980, and saying that that number is a
17 conservative estimate for the frequency of internal
18 flooding in the US EPR, or the generic EPR turbine
19 building. It's hard to believe that that has any
20 relevance whatsoever.

21 It's also hard to believe that you didn't
22 go look at, for example, all of the internal flooding
23 studies that were done to support all of the IPE
24 submittals, which at least were done in the early 90s.

25 Not clear what data they used but perhaps a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit more operating experience.

2 So it's not at all clear to me why you can
3 say this number is generically conservative to
4 something that we don't know anything about yet,
5 especially given the fact that it's at least 30 years
6 old and derived from only reported events because I
7 used to work with nuclear power experience quite
8 extensively. They took primarily LERs. So they
9 didn't use, at least in those days, they didn't use
10 information from plants if it was not a reportable
11 event.

12 A lot of turbine building flooding events
13 are probably not reportable because they didn't affect
14 safety systems. So it's really not at all clear how
15 this number is relevant to anything.

16 MR. HUGHES: The number was chosen because
17 it was available and it was in a reference and they
18 comparison was made based on a perception that that
19 number was probably appropriate at the time for
20 treatment of plants that were much older and design
21 enhancements have occurred, improvements had occurred,
22 and the expectation that an as-yet undesigned and
23 incomplete design would be at least as good if not
24 better than that number.

25 Hence, that number was used in the PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Is there anything to add to that, Josh?

2 MR. REINERT: I would just add that I
3 don't know what all -- I don't remember what all
4 sources were looked at to come up with possible
5 frequencies but I'm sure we looked at more than just
6 the NUREG-2300. So I don't think that it's adequate
7 to say that we just looked at this one number and
8 didn't look at anything else. I'm sure that we looked
9 at other numbers. I just don't know what they are.

10 MR. HUGHES: Okay. Looking at internal
11 fire risk assessment, again, the Nuclear Island
12 internal fire has no departures, so the fire PRA
13 treatment in the US EPR PRA is incorporated by
14 reference.

15 For the turbine building internal fire,
16 there are no Calvert Cliffs 3 departures. The design
17 description in the US EPR FSAR is conceptual and that
18 includes the systems that are identified on the chart.

19 The preliminary design is consistent with those
20 conceptual design features, and so there's no design
21 change or shift, and the internal fire risk assessment
22 is incorporated by reference.

23 Seismic margin. Again, it's incorporated
24 by reference in its entirety. I identified, earlier,
25 the unique features of the soil that are continuing to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be looked at to make sure that these are in fact
2 consistent with the 1.67 times GMRS. There's an
3 expectation that they are. There's a belief that they
4 are but the final word on that will be submitted in
5 the future as we complete the response to ongoing
6 questions.

7 And I believe this is identified as a
8 subject in the SER to be closed.

9 MEMBER STETKAR: Did you look at, when you
10 say there's no unique plant features that affect the
11 seismic margins analysis, are there any underground
12 cable ducts or underground pipeways that contain
13 cables or piping for systems that are modeled in the
14 PRA, that are a site-specific design feature that
15 could be affected by the seismic, and did you look at
16 those?

17 MR. HUGHES: I did not specifically look
18 at that and I'll ask Josh if he did.

19 MR. REINERT: Those ducts do exist and
20 some of them do contain equipment modeled in the PRA.

21 I think what this is trying to say is that there
22 aren't any Calvert Cliffs-unique features, that would
23 impact the work that was done in the DC for soil
24 features, which I think goes to your point. That's
25 all Calvert Cliffs-specific work, and we still need to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 --

2 MEMBER STETKAR: That's still in part of
3 the on --what you're saying --

4 MR. REINERT: It's still ongoing.

5 MEMBER STETKAR: -- is that's still in
6 part of the ongoing issue. Okay.

7 MR. REINERT: That's right.

8 CHAIRMAN POWERS: Let me make sure I
9 understand. When you say there are no unique plant
10 features relative to the generic design -- because
11 there are unique features that affect the seismic
12 margins analysis relative to an arbitrary plant or
13 even your adjacent plants.

14 MR. HUGHES: I'm not sure I understood the
15 question.

16 CHAIRMAN POWERS: The question is, the
17 statement up there is there are no unique plant
18 features that impact the seismic margins analysis.
19 That means unique relative to the generic EPR design.

20 MR. HUGHES: That's correct.

21 CHAIRMAN POWERS: Because there clearly
22 are unique features relative to an arbitrary plant, or
23 even the plants that you currently have operating at
24 Calvert Cliffs.

25 MR. HUGHES: That's correct. Okay. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is a list of external events and as you can tell,
2 there are a number of them and we've gone through them
3 and spent time with them and I'm now going to go
4 through them in a little bit more detail.

5 Now we go to the -- let's begin this
6 journey. High winds. The Nuclear Island is designed
7 for a 155 mile per hour three-second gust. The
8 structures are designed consistent with applicable
9 standards. A look has been done at the failure of
10 non-safety-related structures to determine if they
11 would impact the Nuclear Island and they will not.
12 The tornado wind design is 230 miles per hour design
13 basis and safety-related structures meet the design
14 objective.

15 And so for tornado, we have significant
16 capability and the CDF associated with that has been
17 evaluated, and a value of five minus eight per year
18 determined, and this looks at the combination of the
19 tornado and the structural impact and that risk is
20 very, very low in this sort of assessment.

21 CHAIRMAN POWERS: Your plant -- this plant
22 that you're proposing to build on this site might
23 operate for as long as 60 years?

24 MR. HUGHES: Yes.

25 CHAIRMAN POWERS: I have a large number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 people telling me that there is climate change going
2 on.

3 MR. HUGHES: Yes.

4 CHAIRMAN POWERS: And they insist to me
5 that things are getting -- will only get worse. They
6 never tell me things are going to get better. In
7 particular, they tell me that tornado frequencies and
8 intensities will go up as a result of these changes.
9 Do you factor that in when you look at these?

10 MR. HUGHES: No.

11 CHAIRMAN POWERS: Why?

12 MR. HUGHES: We factor in the analysis
13 based upon available data. Conjecture that it could
14 increase is certainly something that can be made and
15 we have margin in the analysis and in the values and
16 based upon that margin and meeting the structural
17 design capability, we anticipate from a PRA
18 perspective, that that treats the issue the way it
19 should be treated, the way the consensus community
20 would have and so we rely upon that treatment in the
21 structural area.

22 CHAIRMAN POWERS: I mean, you say the
23 consensus community. If I talk to, I can't call them
24 friends, exactly, but acquaintances that are heavily
25 into this climate change, they'll tell me that 280

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mile per hour tornadoes are entirely possible and
2 we'll see lots more of them. I mean, I have no idea,
3 I know nothing about what triggers tornadoes.

4 MR. HUGHES: When I say the consensus
5 community, what I'm referring to is, for example, the
6 treatment in the Reg Guide 1.76, the regions that have
7 been looked at, the documentation that's in those
8 areas, as to what the type of tornado design basis
9 should be.

10 And so this is the approach that's taken.

11 If there were a decision made that the design basis
12 needed to be strengthened, then that could be looked
13 at. So from a PRA perspective, we assume that it
14 meets that design.

15 MEMBER STETKAR: Let's see if you have an
16 answer for a previous one. Let's see if we can finish
17 up the tornado discussion here.

18 I notice that core damage frequency at 5.4
19 times ten to the minus eight, following up on Dr.
20 Powers' comments, was derived from a tornado impact
21 frequency of 6 times ten to the minus five per year,
22 which seems pretty low but I don't have the analyses
23 available so I don't know what wind speeds those apply
24 to and I don't know what kind of tornado footprint you
25 used. It's all a very kind of site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculation.

2 It seems a bit low, looking at, you know,
3 tornado data, damage data. But I don't know what the
4 tornado frequencies for, you know, a 50-mile radius,
5 let's say, around your plant looks like. I didn't
6 bother to go look that up.

7 That notwithstanding, 5.4 times ten to the
8 minus eight is a -- you say approximately 10 percent
9 of the baseline core damage frequency.

10 You've explicitly quantified many, many,
11 many, many, many, many, many contributors that are
12 much, much, much, much smaller than that. So it's not
13 clear why you're justified screening out this
14 contributor which is conceptually substantially larger
15 than a lot of the things you've already quantified.

16 Can you comment on that.

17 MR. HUGHES: Yes. I think the treatment
18 in the US EPR is to address this and screen it out.
19 It applies to many, many different plants and they've
20 taken Region 1, which is one of the most severe, and
21 used that data to calculate something that would
22 screen it out. In looking at Calvert Cliffs Unit 3,
23 we concluded that that treatment was conservative for
24 our plant and as a result, we adopted the same
25 approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: No. But your six times ten
2 to the minus five is a localized tornado-strike
3 frequency.

4 MEMBER STETKAR: I would assume so, since
5 you calc -- it's 6.1 times ten to the minus five,
6 also. It's not 6.0. Point one.

7 CHAIRMAN POWERS: It's a very good thing,
8 too, because --

9 MEMBER STETKAR: If it were 6.2, it might
10 be --

11 CHAIRMAN POWERS: Be totally unacceptable.

12 MR. REINERT: I can add something on why
13 we screen some things and don't screen others. We're
14 really only allowed to screen some things based on the
15 PRA standard. The external events, other than
16 internal fire, internal flood and seismic, we're
17 allowed to screen. So where we could, we screened
18 those.

19 The other contributors, we're not allowed
20 to screen.

21 MEMBER STETKAR: You're allowed to --
22 well, but let's be realistic here. You're allowed to
23 screen things if there's confidence that they're a
24 small contributor to overall risk.

25 MR. REINERT: That's true. You're right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: This is not a small
2 contributor to overall risk. It's a measurable
3 fraction of a very small number, but it's more
4 important than many other measurable fractions to a
5 very small number. You started out your presentation
6 with these nice colored pie charts that show all of
7 these very small fractions of a very small number.
8 This is another one, and it's not -- if that number
9 came out to be ten to the minus twelve, you know, I
10 start to think that that's perhaps a very, very small
11 fraction of a very small number.

12 But it's not at all clear, how you're
13 justified screening that out based on your already-low
14 core damage frequency. This is yet another
15 contributor. If, indeed, the estimated frequency
16 that you've used with the -- and you've obviously run
17 this through your model with some evaluation of the
18 impact -- if that has some credibility within the
19 context of the PRA, I don't understand how it can be
20 screened out.

21 MR. REINERT: Well, this was a bounding
22 analysis. We -- I should clarify what I said earlier.

23 We're allowed to screen out some external events
24 using this probabilistic cut-off criteria for the
25 other internal events, internal fire, flood and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 seismic. You're allowed to screen based on different
2 criteria, and that's I think what you were alluding
3 to, where, if you can show that it's a similar
4 initiator but that the consequence is a couple of
5 orders of magnitude less, then you can screen out.

6 So that's why not every initiator
7 conceivable is in the initiating events.

8 Here, we're screening -- here, this is an
9 external event that we're allowed to screen based on
10 just a flat probabilistic cut-off. So we did a very
11 conservative bounding analysis which is just kind of
12 roughly described here.

13 MEMBER STETKAR: How conservatively
14 bounding -- you know, I'll put you on the spot.
15 You're using words, conservative and bounding, which
16 are not technical, quantitative words; they're simply
17 words. What's your best estimate on the core damage
18 frequency? Is it a factor of ten lower than this?

19 Is it a factor of a hundred? Is it a
20 factor of 10,000 lower than this?

21 MR. REINERT: I would really just be
22 guessing. We didn't do further analysis other than to
23 come up with this number.

24 MEMBER STETKAR: You did a detailed
25 analysis on shutdown events and the total core damage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency from everything that you considered during
2 shutdown is 5.8 times ten to the minus eight per year.

3 MR. REINERT: That's right.

4 MEMBER STETKAR: About equal to this.
5 You've subdivided that into things that are as small
6 as a one percent contributor to that small value.

7 MR. REINERT: Well, that's true but that
8 doesn't allow me to estimate what the tornado
9 assessment is --

10 MEMBER STETKAR: What you're saying is if
11 you did a real tornado analysis for the Calvert Cliffs
12 site with the Calvert Cliffs PRA, you're confident
13 that, indeed, the core damage frequency would be lower
14 than this value. But you've not done that analysis.

15 MR. REINERT: That's true.

16 MEMBER STETKAR: Well, why don't you do
17 the analysis?

18 MR. HUGHES: The analysis will be part of
19 the PRA that's done at fuel load that meets all of the
20 standards in effect and so, ultimately, that analysis
21 will exist. But at this stage, using the design and
22 this approach, the screening is a reasonable approach
23 to determine whether or not further analysis is
24 required.

25 MEMBER STETKAR: If you did the analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at this stage and it identified particularly
2 vulnerable structures or particular structures that
3 were vulnerable to tornado damage, would that possibly
4 affect any of the construction program?

5 MR. HUGHES: The reason for this
6 particular approach and for the screening is to
7 confirm that there is high confidence that that would
8 not occur. So the hypothetical is of course it could
9 and it would, but it's a hypothetical that, based on
10 this analysis, would not occur.

11 MEMBER STETKAR: I guess we'll talk -- I
12 think there's an open item on this with the staff,
13 isn't there?

14 (No response.)

15 MEMBER STETKAR: Okay. Thanks.

16 MR. HUGHES: Okay, next. The next item is
17 external flooding. This is a qualitative review based
18 on the work that's in Chapter 2. The makeup water
19 intake structure and electrical building meet the
20 deterministic criteria in the SRP and based upon that,
21 we declare that the risk is very, very low without
22 further analysis from external flood.

23 And for this particular site there is
24 substantial margin, so that's an extremely confident
25 assertion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 External fire. Again, this is a
2 qualitative treatment. A review was done. The zone
3 around the plant is cleared. There is an area between
4 the plant and the Bay that the state would like to
5 have some retained foresting on. But looking at it
6 and considering the habitability of the control room,
7 the ability to isolate, the recirculation capability
8 and the capacity with which people could stay in the
9 control room and the likelihood that a forest fire
10 could survive that long and continue to impact the
11 plant, the risk for this is considered to be very,
12 very low based on that qualitative assessment.

13 MEMBER STETKAR: Earlier, you mentioned
14 that the -- I lost the slide, but you'd mentioned that
15 a toxic gas detection system will not be installed --

16 MR. HUGHES: That's correct.

17 MEMBER STETKAR: -- at Calvert Cliffs.
18 Does the control room air intake system include toxic-
19 gas or smoke detection? You mentioned the ability to
20 isolate --

21 MR. HUGHES: The ability to isolate here
22 is a manual isolation.

23 MEMBER STETKAR: Manual. Okay.

24 MR. HUGHES: Airplane crash has been
25 looked at and this is part of an NRC question: RAI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 1.98. It is continuing to be looked at. The value
2 that we've identified here, 1.1 times ten to the minus
3 seven per year is considered to be very, very low, and
4 when I write this phrase, very, very low, I am
5 referring to the fact that, in terms of absolute risk,
6 that's a very low number. In terms of relative, I
7 will acknowledge that it's not that far from the
8 calculated value that we have and, in fact, in an
9 upcoming response, we will be revising this value.
10 This is a conservative value and the revised value
11 will be lower.

12 CHAIRMAN POWERS: How could it go lower?

13 I mean, it seems to me --

14 MR. HUGHES: I think it'll be a range --

15 CHAIRMAN POWERS: -- if you're randomly
16 thinking about airplanes, you're going to come up with
17 numbers on this order.

18 MR. HUGHES: The way these numbers are
19 generated is by analyzing different types of planes
20 and that kind of information is in there.

21 CHAIRMAN POWERS: You don't need to go
22 into detail on this one.

23 MR. HUGHES: Okay.

24 MEMBER STETKAR: Well, let me ask one
25 thing, though, about this number, and I'm searching

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the right section here, just to make sure I don't
2 -- let me ask it because I can't find it quickly, just
3 to keep us on schedule. I found it. That number in
4 the FSAR says, the bounding scenario is an airplane
5 crash into Safeguards Building 1 or Safeguards
6 Building 4 results in a core damage frequency of 1.1E
7 to the minus seven.

8 That is the core damage frequency from one
9 aircraft crash into one -- it's a lumped building.
10 You took one and four together. It's not the total
11 aircraft crash damage frequency from all aircraft
12 crashes into any location in the plant; is that
13 correct? This is only a single scenario.

14 MR. REINERT: No. What you described is
15 one scenario. There are other scenarios but the
16 numbers were so small, that they don't show up when
17 you total them all up. It's almost still the same.

18 MEMBER STETKAR: That's a little
19 surprising but --

20 MR. REINERT: And also, I want to clarify
21 that the name of the scenario is as you describe but
22 the structures that are assumed failed are more than
23 just the one Safeguard Building. So we looked at
24 all the structures that would fail, given that an
25 airplane would come in from a certain direction, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 failed those structures.

2 MEMBER STETKAR: Yes. We've got to be a
3 little careful about--

4 MR. REINERT: Right.

5 MEMBER STETKAR: Okay. I just, when I
6 read through it, the way it's characterized, at least
7 in the FSAR, is it's characterized as the frequency
8 from the bounding scenario. And there is a discussion
9 in the FSAR of other crash scenarios that are, you
10 know, apparently quantified, that they're not results
11 in there.

12 The only caution that I have is that when
13 you refine the numbers, in response to the RAI, be
14 sure that you clarify what the total aircraft crash
15 damage frequency is from all crash scenarios. Don't
16 restrict that only to core damage. Obviously, you
17 want to look at large release frequency also.

18 MR. HUGHES: Okay. So noted. Okay. We
19 now get into a number of offsite hazards, and for
20 highway hazards, the conclusion is reached that they
21 are simply too far away. We looked at different types
22 of releases that could occur, and they really could
23 not affect the plant.

24 For waterway, we looked at the fact that
25 in many cases they are far enough away, that even on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the waterway there would not be an impact on the
2 plant. With ammonia, we identified there could be,
3 but the number of shipments per year is 10 percent of
4 the limit for screening from the SRP, and so we
5 adopted the screen.

6 For pipeline, it's too far away.

7 Yes?

8 MEMBER STETKAR: Just remember, the SRP,
9 those numbers presume that your core damage frequency
10 is somewhere around ten to the minus four per year.
11 Yours isn't.

12 MR. HUGHES: This is an interesting
13 comment that I will respond to. I agree that it's
14 appropriate to consider the impact of a particular
15 type of accident on your perspective of the risk of
16 the facility. So given a very low-risk facility, it's
17 certainly appropriate to consider that in determining
18 what should be treated and where it should be.

19 That said, I think there are limits on how
20 far we should go in terms of identifying a number for
21 screening, based solely on the fact that it is
22 relative to the things that are not screened. I think
23 the fact that the risk itself is determined to be,
24 based on a reasonable analysis, very low, is
25 sufficient to defer any further calculations until the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time at which one is going to do that analysis in
2 detail.

3 MEMBER STETKAR: I just -- you know, we
4 need to keep on schedule here. This is a sort of
5 philosophical discussion.

6 MR. HUGHES: It is.

7 MEMBER STETKAR: The only point to that is
8 that once something is screened out, it tends not to
9 be looked at again. It tends to disappear because
10 there was justification to remove it. And there's a
11 bit of danger about that. And that's especially true
12 as you go from a conceptual design down to a more
13 focused plant-specific design.

14 The other problem is that if we indeed are
15 performing risk assessment to both understand, from a
16 public health perspective, what the risk from a
17 facility is, I'd want confidence that my estimation of
18 that is relatively complete.

19 And from an internal perspective, if,
20 indeed, my risk is driven by a large number of
21 external conditions that are beyond my control as an
22 owner-operator, that's important information to me
23 because that says that there isn't much that I can do
24 to the internal parts of my plant, that's actually
25 going to affect that overall risk.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I mean, it's important knowledge to the
2 owner-operator of the plant, even though a lot of
3 these things may be cumulatively small. That is
4 important perspective, even from managing your day to
5 day operations. You know, do I put in yet one more
6 widget to yet reduce an internal core damage frequency
7 by another, you know, 7 percent, when, indeed, we have
8 good confidence that the overall risk is driven by a
9 lot of other things?

10 So that's another kind of impetus to think
11 seriously about these other contributors. End of
12 philosophy.

13 MR. HUGHES: Well, one other piece of
14 philosophy, if you'll bear with me, and I'm keenly
15 aware of the time. The other part of this
16 philosophical discussion I think should include, at
17 some other time, consideration of the fact that
18 different hazards, when looked at in different ways,
19 can contribute more or less conservatism in the way
20 they're addressed, and that can affect the perception
21 of what should be done about them.

22 And so care has to be taken to not only
23 identify the uncertainty, but also to identify the
24 certain conservatism that might be, because that can
25 affect the owner-operator's perception of what these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things might be. The total picture needs to be
2 presented.

3 Continuing with the chart, railroads are
4 not nearby. The nearby facilities that are there
5 include gasoline, explosion or release from Calvert
6 Cliffs 1, 2 and 3, things that are stored on site;
7 ammonium hydroxide, rather; an LNG terminal; and
8 looking at each of these, the initiating event
9 frequency was first determined to be less than one
10 minus six per year, but acknowledging that this is a
11 criterion that leaves some question for a plant with
12 such a low core damage frequency, the initiating event
13 frequency is actually less than one minus seven per
14 year.

15 Am I correct, Josh?

16 MR. REINERT: No. Some of the initiating
17 event frequencies, right now, are higher than one
18 minus seven.

19 MR. HUGHES: But that's only for the
20 initiating event--

21 MR. REINERT: The initiating event.

22 MR. HUGHES: -- not for something that
23 would affect the plant?

24 MR. REINERT: That's right.

25 MR. HUGHES: So the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Wait. Are you saying
2 that explosions in an LNG terminal is less than ten to
3 the minus -- I don't understand numbers that small --
4 six or seven per year? Or is that the frequency of an
5 explosion at an LNG terminal that would have an impact
6 on the plant?

7 MR. REINERT: For the LNG terminal, any
8 explosion would not impact the plant.

9 MEMBER STETKAR: Okay.

10 MR. HUGHES: We screen that on distance
11 rather than frequency.

12 MEMBER STETKAR: I just want to make sure
13 that we're not saying that, you know, LNG terminals --

14 MR. HUGHES: It's a pretty good LNG
15 terminal.

16 MEMBER STETKAR: That's a darn good LNG --
17 I'll buy that one.

18 MR. HUGHES: Okay. To summarize, there
19 are currently no ASLB contentions related to this
20 area. I have not mentioned, by the way, the severe
21 accident part of chapter nineteen.

22 The severe accident part, we've identified
23 no departures that would impact what's treated there.

24 There is an open RAI related to -- in fact, we just
25 answered the question. There is a question related to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our use of the severe accident management guidance
2 procedures, and the answer we provided was one that
3 basically pointed to the fact that there are revisions
4 coming, and when the revisions are made and the
5 documents are correct, we can reference, and so the
6 expectation is that we will follow the severe accident
7 management guidelines exactly as they are developed,
8 and that commitment will be made when the documents
9 are in the right position to be made.

10 Unique plant features are bounded, and we
11 looked at departures and exceptions, and so we've
12 chosen to adopt the US EPR PRA, by reference, as the
13 Calvert Cliffs Unit 3 PRA as we've described today.

14 MR. GIBSON: We did have a request, Dr.
15 Stetkar. If you would like to speak, we do have an
16 individual from AREVA who has interfaced with you
17 during your visit with regard to the credit for the
18 load rejection in the PRA.

19 If you would like to take that, or we can
20 take that offline. Whichever you would like to do.

21 MEMBER STETKAR: I guess in the interest
22 of time, let's see how it goes, Greg.

23 MR. GIBSON: Okay.

24 MEMBER STETKAR: Perhaps if there's time
25 left later -- it's a big enough issue, that if we can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do it online that's fine, but I don't want to
2 necessarily get into a detailed discussion that's
3 going to take time away from the staff's presentation,
4 or other things we have on the agenda.

5 MR. GIBSON: Understand.

6 MEMBER STETKAR: So let's -- if we have
7 time at the end, we can do that. Otherwise, we'll do
8 it offline.

9 CHAIRMAN POWERS: I'm sure we'll have
10 time.

11 MR. GIBSON: Very good.

12 CHAIRMAN POWERS: What I propose now is
13 that we go ahead and take our break for 15 minutes
14 now, and then we'll come back and listen to the
15 staff's presentation, if that's acceptable. So 15
16 minutes and we'll come back.

17 (Whereupon, the above-entitled proceeding
18 went off the record at 9:54 a.m. and resumed at 10:13
19 a.m.)

20 CHAIRMAN POWERS: Let's get back into
21 session. Surinder, it's your--

22 MR. ARORA: Good morning. We are here to
23 present the staff's presentation on Chapter 19, and I
24 would like to introduce Jason Carneal. He's the
25 project manager, Chapter PM, for chapter 19, and he

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and the representatives from technical staff will be
2 making the presentation today.

3 Jason.

4 MR. CARNEAL: Thank you, Surinder. My
5 name is Jason Carneal. I'm the Chapter PM for
6 Chapters 4, 6, 15, 17 and 19 in the US EPR Design
7 Center. I received a bachelor's and master's in
8 engineering mechanics from Virginia Tech, and before
9 coming to the NRC, I worked for four years as a
10 mechanical engineer at the Naval Surface Warfare
11 Center, Carderock Division, where I performed
12 experimental studies on naval hydrodynamics.

13 CHAIRMAN POWERS: How could you give that
14 up? Because this is so important to the national
15 interest. That's the answer, right?

16 (Laughter.)

17 MR. CARNEAL: That's right. And the pay
18 here is slightly better than at the Navy.

19 CHAIRMAN POWERS: Ah. But the rewards.

20 MR. CARNEAL: This presentation will cover
21 the staff's safety evaluation report with open items
22 for Chapter 19, Probabilistic Risk Assessment and
23 severe accident mitigation.

24 There are several representatives from the
25 technical staff that were involved in this review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Today, we're joined by Hanh Phan and Malcolm Patterson
2 from the PRA and Severe Accidents Branch. Also the
3 Lead PM on this project is Surinder Arora, and the
4 previous Chapter PM was Prosanta Chowdhury who was
5 involved in most of this work.

6 This presentation will cover our review of
7 sections 19.1, Probabilistic Risk Assessment, and
8 Section 19.2, Severe Accident Evaluation. We'll cover
9 the COL information items of interest, including the
10 open items that remain, carrying into Phase IV of our
11 review.

12 In Chapter 19, we have a total of seven
13 open items. Six open items are in section 19.1, and
14 there's one outstanding open item in section 19.2 for
15 severe accidents.

16 In total, we've issued six sets of RAIs
17 and 25 questions during our review of the Calvert
18 Cliffs application.

19 The next slide gives a high-level overview
20 of the open items that remain in our review of Chapter
21 19. They include issues relating to seismic
22 sequences, external events, airplane crash events, and
23 toxic chemical release.

24 On the next slide the remaining three open
25 items are mentioned, the high-level summary, tornado

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 strike frequency, hurricanes, and severe accident
2 management guidelines.

3 If you have any detailed questions that we
4 don't mention in the subsequent presentation, please
5 let us know and we'll try to address your comments.

6 CHAIRMAN POWERS: Okay. Your intent is to
7 go through each of these open items and have us
8 interrogate in detail, right?

9 MR. CARNEAL: I think the majority of the
10 open items are covered, but there might be one or two
11 that are not mentioned specifically in a subsequent
12 presentation --

13 CHAIRMAN POWERS: Okay. So we need to be
14 alert.

15 MR. CARNEAL: So if we miss something,
16 please let us know.

17 CHAIRMAN POWERS: We're not noted for
18 being reticent.

19 MR. CARNEAL: Okay. With that, I'll turn
20 the presentation over to Hanh Phan, the lead technical
21 reviewer.

22 MR. PHAN: Thank you, Jason. My name is
23 Hanh Phan and I am the lead reviewer for US EPR DC and
24 Calvert Cliffs Nuclear Power Plant Unit 3, COL FSAR,
25 Chapter 19.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Today, my colleagues and I will be
2 presenting the staff evaluation on the Calvert Cliffs
3 PRA and the Severe Accident.

4 I have over 20 years in nuclear,
5 specializing in PRA and reliability. I have led PRA
6 development and PRA application. I joined the NRC in
7 2006. Prior to that, I worked at the nuclear power
8 plants in the national labs. I have a bachelor's and
9 master's degrees in electrical engineering from
10 Washington State University.

11 I would start my presentation by the
12 approach that the staff has taken to review Calvert
13 Cliffs Chapter 19.

14 The staff review focused on the 11 COL
15 information items identified in the U.S. EPR DC FSAR
16 and the Calvert Cliffs FSAR, and additional plant-
17 specific information provided in the Calvert Cliffs
18 Unit 3 FSAR.

19 To come to the conclusion, the staff
20 discussed plant-specific information with all the
21 technical branches. We discussed technical issues
22 with other NRC offices. We ensured consistency with
23 other COL applications, and we ensured consistency
24 with the analyses documented in other chapters. Next
25 slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 As described in the COL FSAR, several
2 external events were screened out from the PRA by
3 using deterministic or probabilistic screening
4 approach. For the deterministic screening assessment,
5 the staff ensured and confirmed that the potential
6 hazards associated with the postulated external event
7 does not adversely affect the plant.

8 Second, the plant is designed to
9 accommodate the maximum size of the postulated
10 external event.

11 For the probabilistic screening
12 assessment, the staff confirmed conformance with Reg
13 Guide 1.200 quantitative screening criteria, and
14 ensure that the conservative estimate that the CDF and
15 LRF are lower than the baseline risk values. Next
16 slide, please.

17 For the next 13 slides, we will go through
18 11 COL information items presented in the FSAR Chapter
19 19.

20 COL Information Item 19.0-1 directs the
21 COL applicant to either confirm that the PRA in the DC
22 bounds the site-specific design information and any
23 design changes or departures, or update the PRA to
24 reflect this information.

25 The COL FSAR states that the US EPR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design-specific PRA bounds Calvert Cliffs PRA.

2 Currently, the staff is unable to finalize
3 its conclusion on this information item since this
4 item relates to other areas such as: supplemental
5 information provided by the COL applicant to address
6 site-specific design information; site-specific
7 effects of seismic hazards; and site-specific external
8 events. Those we have a few open items as Jason
9 mentioned earlier. Next slide, please.

10 On the next three slides, COL Information
11 Items 19.1-1, 19.1-2 and 19.1-3 direct the COL
12 applicant to describe the uses of PRA in support of
13 licensee programs, and to identify and describe risk-
14 informed applications being implemented during the COL
15 application phase, construction phase, and operational
16 phase, respectively.

17 In the FSAR, the COL applicant stated that
18 during the application phase, construction phase, and
19 operational phase, no risk-informed application are
20 proposed. The staff concludes that the COL applicant
21 has fully addressed COL's information items 19.1-1,
22 19.1-2, and 19.1-3, consistent with the SRP. Next
23 slide, please. Please go to slide thirteen.

24 COL Information Item 19.1-4 directs the
25 COL applicant to conduct a peer review of the PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 relative to the ASME PRA standard prior to use of the
2 PRA to support risk-informed application or before
3 fuel load. The staff recognized that because the full
4 peer review cannot be completed prior to construction
5 of Calvert Cliffs Unit 3 due to the lack of plant
6 procedures and plant walkdowns, and the others. Thus,
7 the staff concludes that the COL applicant has
8 properly addressed COL information items 19.1-4 by
9 including the following statement as a proposed
10 license condition in Part 10, Section 2 of the CCNPP
11 Unit 3 COL application.

12 The statement states that a peer review of
13 the PRA relative to the ASME PRA standard shall be
14 performed prior to the use of the PRA to support risk-
15 informed applications or before fuel load. Next
16 slide, please.

17 COL Information Item 19.1-5 directs the
18 COL applicant to describe the COL applicant's PRA
19 maintenance and upgrade program. The staff determines
20 that the COL applicant has properly addressed COL
21 information Item 19.1-5 by including the following
22 statement as a proposed license condition in Part 10,
23 Section 2, of the Calvert Cliffs Unit 3 COL
24 application. The CCNPP Unit 3 PRA shall be treated as
25 a living document. A PRA Configuration Control

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Program shall be put in place to maintain or upgrade
2 the PRA, as defined in ASME Standard 2007 and as
3 clarified by Reg Guide 1.200. Next slide, please.

4 COL information Item 19.1-6 directs the
5 COL applicant to confirm that the US EPR design-
6 specific PRA-based seismic margins assessment is
7 bounding for their specific site.

8 In COL FSAR, the COL applicant made a
9 comparison of the site-specific GMRS to the US EPR
10 CSDRS, and demonstrated that the GMRS is lower than
11 the CSDRS.

12 The applicant concluded that the seismic
13 demands for Calvert Cliffs Unit 3 are lower than that
14 used for the US EPR FSAR. Therefore, the US EPR FSAR
15 bounds site-specific parameters and they do not have a
16 significant impact on the Calvert Cliffs Unit 3 PRA
17 results and insights.

18 In accordance with 10 CFR Part 52, the
19 staff expects that the applicant describe the update
20 of the US EPR design-specific PRA-based seismic margin
21 analysis to incorporate site-specific and plant-
22 specific information.

23 Thus, in RAI 160, Question 19-19, the
24 staff requested that the COL applicant provide an
25 update to the system model developed in the US EPR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 FSAR to identify and incorporate any site-specific
2 capacity reductions due to site-specific effects and
3 site-specific structures. In addition, the COL should
4 demonstrate the plant seismic margins to be 1.67 times
5 the site SSE.

6 The staff is currently reviewing the
7 response. Question 19-19 is being tracked as an open
8 item. For additional information, recently, the staff
9 received the seismic evaluation from AREVA during
10 shutdown.

11 The staff is going to ask the COL
12 applicant to release it and analyze the seismic risk
13 during shutdown, and that is not in the safety
14 evaluations yet.

15 COL Information Item 19.1-7 directs the
16 COL applicant to perform site-specific screening
17 analysis and site-specific risk analysis for
18 applicable external events.

19 The applicant addressed all external
20 events listed in Appendix A of the ANSI/ANS 2003,
21 "External Events in PRA Methodology." This is
22 consistent with the ASME/ANS 2009 combined PRA
23 standard. The applicant follows the guidance in the
24 ANS standard as well as guidance in NUREG-1407 to
25 evaluate the external events. Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Reg Guide 1.200, Section C.1.2.5., states
2 that: It is recognized that for those new reactor
3 designs with substantially lower risk profiles, for
4 example, internal events CDF below 1E minus 6 per
5 year, the quantitative screening value should be
6 adjusted according to the relative baseline risk
7 value.

8 The staff found that some external events
9 were screened out using the screening values higher
10 than the Calvert Cliffs baseline CDF. For example,
11 the airplane crash. The bounding CDF was estimated to
12 be 1.1 minus seven per year and the applicant screens
13 that event out from the PRA.

14 The staff has one specific question
15 regarding to that event, and that question is being
16 tracked as an open item, 19-21.

17 In Question 19-13 and follow-up question
18 19-20, the staff requested that the COL applicant
19 reassess the external events using an appropriate PRA
20 screening value, or quantitatively justify that when
21 all conservatisms are removed from the analysis, the
22 resulting CDF and LRF would be significantly lower
23 than the total baseline CDF and LRF.

24 Question 19-20 is being tracked as an open
25 item.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COL Information Item 19.1-8 directs the
2 COL applicant to describe the use of PRA in support of
3 site-specific design programs and processes during the
4 design phase.

5 The COL FSAR states that during the design
6 phase, no additional PRA-related design activities are
7 anticipated for Calvert Cliffs Unit 3.

8 With that, I'd like to turn over to
9 Malcolm Patterson. He is going to cover COL
10 Information 19.1-9 and the Severe Accident evaluation.

11 MR. PATTERSON: Thank you. I'm Malcolm
12 Patterson. A brief bit on my background. I graduated
13 from the Naval Academy with a bachelor's in systems
14 engineering in 1975. I've been involved in nuclear
15 matters ever since, including 10 years at a utility in
16 the design organization and 16 years in various
17 consulting roles, before I came to the NRC three years
18 ago. I've in PRA here, both in NRR and now in NRO.

19 The review was actually conducted by
20 Teresa Clark, who's appeared before you before, but
21 now I have responsibility for Chapter 19. The basic
22 approach taken for internal events was simply to
23 confirm the site-specific and plant-specific features
24 were consistent with the EPR PRA, which was
25 incorporated by reference.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Focus was on loss of offsite power and on
2 balance-of-plant systems that might be affected by
3 local factors, primarily circulating water and
4 supporting systems, and the result was confirmation
5 that, in fact, the assumptions of the EPR PRA were
6 bounding. In the area of severe accidents --

7 MEMBER STETKAR: Malcolm, let me stop you.
8 You didn't think I was going to be quiet for the
9 entire presentation, did you?

10 MR. PATTERSON: I was hoping.

11 MEMBER STETKAR: We already talked about
12 the loss of offsite power, so I'm not going to say
13 much of anything more about that.

14 One area, and you did have it on your
15 slide there, the balance-of-plant systems, in
16 particular, circulating water. It's asserted that the
17 design PRA models for the circulating water system are
18 appropriately bounding and conservative for the
19 design-specific configuration of those systems.

20 I happen to know that the models for those
21 systems in the design PRA consists of one basic event.

22 That basic event is assigned a number for the
23 purposes of initiating event frequency of 1.0, a not
24 precise number, E to the minus 2 event per year. One
25 event in a 100 years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And that number is then backed down to an
2 hourly failure rate that's applied over 24-hour
3 mission time to get the unavailability of that basic
4 event. It has no links whatsoever to support systems.

5 It has no links to numbers of pumps. It is simply a
6 number.

7 It's curious, why that number is a
8 appropriately bounding model for the actual plant-
9 specific configuration of the cooling water systems,
10 and their dependencies.

11 MR. PATTERSON: What they have is four 25
12 percent circulating water pumps, and modeling that
13 wasn't, didn't give us a challenge in reaching a one
14 times ten to the minus two failure rate.

15 But I'd have to come back to deal with
16 anything --

17 MEMBER STETKAR: I'm not so concerned
18 about four pumps failing, you know, put a common-cause
19 failure on it, whatever you want to do. I'm a little
20 bit more concerned about modeling the actual
21 configuration of the plant with the fact that it does
22 have four pumps but they're powered from four specific
23 electrical buses. Failures of electrical power have
24 then impacts on availability of cooling water.

25 I believe it's the circulating water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system supplies the auxiliary cooling water system. I
2 don't know -- our problem is we don't enough about the
3 plant yet, as a subcommittee, to go much further into
4 systems designs, but I'm assuming the Auxiliary
5 Cooling Water System cools some things by its nature.

6 I think it actually cools the turbine
7 building closed cooling water system which cools
8 everything in the turbine building.

9 And it's with those types of systems
10 interactions and support system failures, that it's
11 not clear that a ten to the minus two number -- or
12 granted, a ten to the minus two number for failure of
13 four pumps is an appropriately bounding number. It's
14 not clear that that number bounds the effects of all
15 of the cooling water systems in the integrated PRA.

16 Numerically, it might. I'm not trying to
17 say that perhaps the plant-specific cooling water
18 design is risk-significant, but it's not clear that
19 that number justifies lack of a more detailed
20 evaluation of that design and its dependencies and
21 interactions.

22 MR. PATTERSON: Point taken. The issue
23 was the level of confidence that we needed to come to
24 the conclusion that this plant was in fact bounded by
25 the EPR PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: And that's the important
2 thing. Remember that the design PRA, very small
3 contributors to a very small number, is bounding for
4 this perhaps slightly larger or slightly smaller
5 contributor to a very small number. If, indeed, the
6 real contribution is smaller, then indeed, the design
7 PRA is bounding.

8 If a real model of the system shows a
9 slightly higher contributor, then the design PRA is
10 not bounding. It's not bounding. The overall risk
11 might be acceptable, certainly, the contributors to
12 the risk might be well-balanced, but it's difficult to
13 state that the design PRA is a bounding PRA then,
14 which is the statement that's being made.

15 MR. PATTERSON: Yes.

16 MEMBER STETKAR: I don't know --

17 MR. PATTERSON: I don't have any response
18 for you other than to say that at the time of fuel
19 load, a realistic plant PRA is expected to model those
20 details. We weren't looking to find that level of
21 detail in this PRA at the time of COL.

22 CHAIRMAN POWERS: Well, there you go.

23 MR. PATTERSON: On severe accidents, here,
24 again, the Calvert Cliffs application incorporated the
25 EPR design by reference. There is an issue, COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Information Item 19.1-9, indicates that the COL
2 applicant should review, as designed and as-built
3 information, and conduct walkdowns, as necessary, to
4 confirm that the assumptions used in the PRA remain
5 valid. Obviously, this is not practical.

6 What has been done is that a license
7 condition has been proposed to have this activity
8 performed before fuel load, and the staff considers
9 this acceptable.

10 Now we'll get to severe accidents. The
11 applicant that references the US ERP design
12 certification will develop and implement severe
13 accident management guidelines prior to fuel loading
14 using the operating strategies for severe accidents.
15 We have a response from Calvert Cliffs and are
16 tracking as an open item until it's resolved.

17 MR. PHAN: With that, the staff would be
18 happy to take any questions you have on our
19 evaluation.

20 MEMBER SHACK: Just one, that John sort of
21 brought it up earlier, that you have two outs here.
22 You know, if you meet essentially the deterministic
23 criteria in the SRP, you can walk; otherwise, you have
24 to go through this kind of screening criteria. And
25 implicit in those deterministic criteria is probably

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an assumption that the risk is small, and it used to
2 be small compared to the baseline PRA.

3 But it's not at all clear to me that the
4 risks from those sort of deterministic calculations
5 are any different than the kind of semi-quantitative
6 screenings we're now applying, and, you know,
7 sometimes you get to walk and sometimes you don't.

8 Is there any thought to whether those are
9 inconsistencies in the SRP criteria for, between the
10 deterministic and the qualitative CDF/LRF screening
11 kind of criteria.

12 MR. PHAN: Yes. The SRP allows the
13 applicant to screen out the event if that event met
14 the deterministic criteria of the SRP. However, from
15 the staff performance, for those that we believe to
16 have potential impacts to the baseline risks, such as
17 airplane crash or transportation, or any, like
18 tornadoes or high winds, we look into the
19 probabilistic because the information provided in
20 Chapter 19, that the PRA side, not the deterministic
21 side. So we look into every single external events
22 for both. If we believe, or if the applicant can
23 justify that the events cannot have any significant
24 impacts, as tsunami, then we can allow the screenings
25 using just deterministic approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Otherwise, we look into the probabilistic
2 side of it.

3 MEMBER SHACK: Okay. You know, when I
4 have an EPR or an ESBWR, and my baseline risk is, you
5 know, on the order of ten to the minus seven, you
6 know, there was some implicit assumption in the choice
7 of the deterministic criteria, even, I think, if the
8 risks were small, and it's not clear that there's a
9 consistency there.

10 MR. PATTERSON: Right. Where we have
11 open items, it's because the staff thinks that these
12 issues should be aired in the PRA and incorporated in
13 the values adopted as the CDF for the plant. We're
14 not saying that there's anything the applicant can do
15 about accidental aircraft impact.

16 We're just saying this is the reality -- a
17 large -- a larger percentage of your total risk is
18 coming from external events, and that should affect
19 the way we look at plants.

20 MR. PHAN: In RAI, we did request the
21 applicant to enclose the CDF for external events, if
22 that have like 10 percent contribution to the total
23 core damage frequency, the baseline core damage
24 frequency.

25 MR. DUBE: This is Don Dube, Office of New

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Reactors. Just a little history behind this. The SRP
2 screening sort of was a holder from IPEEE days, which
3 was obviously for currently operating plants, and was
4 fine for -- when the core damage frequency baselines
5 are in the ten to minus five to ten to minus four
6 range, but as you mentioned, you know, the current
7 generation of plants we're seeing ten to minus eight,
8 ten to minus seven, you know, at most ten to minus six
9 kind of core damage frequencies.

10 And so it begs the question, you know, is
11 the SRP and the ten to minus six, that's in the
12 ASME/AMS standard appropriate for advanced light water
13 reactors where the baselines are so much lower? And
14 so as a result of that, in Draft Guide 1200, and now
15 the revision to Reg Guide 1.200, which is on technical
16 adequacy, we inserted this paragraph, kind of as a
17 warning, or a caution, that, you know, those screening
18 values were fine for currently-operating reactors, but
19 obviously it's inadequate for when the baseline or
20 internal events core damage frequency is so much
21 lower, and then one should use an appropriately lower
22 screening value.

23 We were careful not to specify any
24 particular number, leave it to the applicant, but we
25 had that concern.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: I was just wondering if
2 there was any consistency, because you haven't
3 adjusted the deterministic requirements, which again,
4 while they don't explicitly have a risk to them, you
5 implicitly believe that if you follow the
6 deterministic requirements, the risk was small, and
7 it's certainly small compared to ten to the minus
8 four.

9 MR. DUBE: Right.

10 MEMBER SHACK: Whether it's small to ten
11 to the minus seven or ten to the minus eight is a
12 slightly different question.

13 MR. DUBE: Right.

14 MEMBER SHACK: And I guess the answer is
15 nobody's thought about that yet. We're just -- you
16 just sort of -- you're still using those deterministic
17 as a get out of jail free card and --

18 MR. DUBE: Well, actually, the way it was
19 -- and we have actually an action to come with another
20 revision to Reg Guide 1.200, because the way this
21 caution that I mentioned was put into the Reg Guide
22 was probably put in the wrong place, grammatically, so
23 that the SRP is -- can be used, and it really should
24 have been an overall escape, regardless of the SRP.

25 One still should look at these external

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 events and --

2 MEMBER SHACK: Well, I suppose you need
3 risk metrics for these new reactors first.

4 MR. DUBE: Right. And so even if it meets
5 the 75 SRP, if the baseline -- if the potential
6 contribution of an external event is of the order of
7 internal events, it shouldn't be screened out. So
8 we're actually looking to revise Reg Guide 1.200, on
9 an expedited basis, to address that concern, exactly
10 what you mentioned.

11 MR. PHAN: Dr. Shack, in the SRP, the
12 criterias, including that either deterministic or
13 probabilistic. My personal thinking, that "or" ought
14 to be an "and." And external events, that's an "and,"
15 not an "or," which means that they have to meet both
16 deterministic and probabilistic performance.

17 MEMBER SHACK: It's another way to look at
18 it. But I think most people treat them as an or gate
19 rather than --

20 MR. PHAN: Yes.

21 MR. PATTERSON: It is hard to argue,
22 though, that the deterministic requirements should be
23 tightened, because we are achieving the safety goals.

24 MEMBER SHACK: You can make the same
25 argument about the qualitative screening, although you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can argue that one, you're looking for a realistic
2 assessment. But like I said, it does need some
3 connection with the risk metrics that you're going to
4 use for these advanced reactors.

5 MR. PATTERSON: We're looking for a
6 complete assessment of risk and the point of screening
7 was to say these don't contribute to risk, and that's
8 --

9 MEMBER SHACK: But those deterministic
10 ones that you're screening out, on the level that
11 we're talking about, aren't so clear that they are
12 contributors to risk.

13 Once we get down to these levels, it --

14 MEMBER STETKAR: When you have a small
15 total that's comprised of, you know, 50 equal two
16 percent contributors, it's really difficult to find
17 something that's insignificant compared to any of
18 those.

19 Malcolm, I wanted to ask you, just
20 following up on one, back to the question I asked the
21 applicant about their internal flood frequency. I
22 noticed you had an RAI and a question about that, and
23 you concluded that the frequency -- I'll quote it.

24 The staff's review concludes that the use
25 of 3.3E to the minus 2 per year of NUREG/CR-2300 is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reasonable for CCNP Unit 3 turbine building flooding
2 and does not have a significant impact on the results
3 and insights of the PRA at the COL stage.

4 Why does the staff -- just simply because
5 it's a number in a NUREG -- why does the staff accept
6 a 30 year old estimate that's derived from a very
7 small number of nuclear power plants in the United
8 States, from probably only in the 1980s, as the basis
9 for an internal flooding frequency for this particular
10 plant?

11 MR. PHAN: In the AREVA EPR DC
12 application, AREVA used generic numbers and the staff
13 is asking why. And also in Question 19-14, the staff
14 also asks the COL applicant to justify the use of that
15 value.

16 In their response, they say in that
17 because no detailed information available at the
18 application stage, which means that they cannot
19 correlate the frequency based on the pipe segments at
20 this stage. So with that, the staff is expecting to
21 see more details when the full PRA developed
22 consistence with the ASME standard at the fuel load,
23 and this information will be updated to reflect that.

24 At this point, because they justify case
25 of no detail available, so the staff did accept the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 numbers.

2 MEMBER STETKAR: The staff has it as -- I
3 can't speak clearly -- but the staff has available the
4 IPEEE studies that were submitted from every plant in
5 the United States, is that correct?

6 MR. PHAN: Yes.

7 MEMBER STETKAR: Did they quantify
8 frequencies of internal flooding in the turbine
9 building?

10 MR. PHAN: I don't have the answer to
11 that.

12 MEMBER STETKAR: Since you don't have that
13 answer, my next question was did you go back and look
14 at those IPEEEs--

15 MR. PHAN: Yes, I --

16 MEMBER STETKAR: -- to see what
17 frequencies were used in those studies and recognizing
18 --

19 MR. PHAN: Yes, I --

20 MEMBER STETKAR: Let me finish.

21 MR. PHAN: Yes.

22 MEMBER STETKAR: -- recognizing that they
23 are, in principle, plant-specific studies, but look at
24 the range of those plant-specific frequencies and see
25 how they, at least, on a -- as a generic estimator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with some uncertainty, some variability anyway,
2 compared to this 3.3E to the minus two number?

3 MR. PHAN: Yes, I did look at NUREG-1507
4 for the IPEEE. However, I did not look into specific
5 flooding frequency for the turbine building.

6 MEMBER STETKAR: I think that would be an
7 interesting piece of information, recognizing that
8 those frequencies are probably out of date, because
9 they're also at least 20 years old now. But it would
10 be an interesting piece of information to gain some
11 confidence, at least, in whether this number is, you
12 know, high, low, or indifferent compared to those
13 frequencies.

14 CHAIRMAN POWERS: I would like to revisit
15 the staff's view on this other thing, on things like
16 the frequencies of intense tornadoes, hurricanes, and
17 things like that, where we tend to do that primarily
18 based on the historical record, and now we have people
19 calling into question the applicability of that
20 historical record.

21 What do we do about that?

22 MR. PHAN: The staff has one open item on
23 the tornado frequency. The applicant provides the
24 values of -- I apologize, I have to say this
25 correctly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: 6.1 times ten to the minus
2 five.

3 MR. PHAN: Thank you, sir.

4 Without any justification. So that's
5 being tracked as an open item.

6 MEMBER SHACK: But he's going to go back
7 and compute that out of NUREG/CR-4461, which doesn't
8 address Dr. Powers's question. Although it's a 2007
9 revision. I mean, it's about --

10 CHAIRMAN POWERS: It doesn't matter. I'm
11 more worried about the 2067 frequencies of tornadoes
12 and hurricanes, and I have a community of people that
13 claim they know things about hurricane frequencies.
14 I'm not in a position to independently judge the
15 quality of their information. And in that community,
16 there seems to be two schools of thought.

17 One says -- they all seem to think that
18 the hurricane frequencies go up. One school of
19 thought claims that very intense hurricane frequencies
20 also goes up in approximate proportion to the number
21 of intense hurricanes that we have now. And the other
22 one says no, verily, it goes down, and we have lots of
23 hurricanes but there are not so many intense ones.

24 I have no basis for judging this
25 information, except to say, okay, here's some expert

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 opinion of people that study these things. They,
2 sadly, have a vested interest in the outcome of this,
3 I'm finding. And I don't know what to do about it.

4 And since I know the staff is much
5 brighter on these matters than I will ever hope to be,
6 if I stay up at night studying, I'll ask you guys.
7 What do you do about this? Since you're about to
8 certify or license, in this case, a plant that, it
9 could be around till 2067, when some people claim that
10 the world will come to an end.

11 I know you don't care if the world's going
12 to come to an end.

13 MR. PHAN: One step that the staff can be
14 taking is to Google the history -- we've got to Google
15 the history about Calvert Cliffs to see any hurricanes
16 in the past and --

17 CHAIRMAN POWERS: But they say that -- I
18 mean, I know the hurricane frequency on the Atlantic
19 Coast. The history is known extremely well. I mean,
20 if we were working on a Gulf Coast plant, then I'd
21 say, well, maybe we don't know too much. But that's
22 not the problem. The problem is that we now have oil
23 flooding into the only intakes, and things like that.

24 But for the Atlantic Coast, we're in good
25 shape. We know how often hurricanes hit, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hurricanes hit the Maryland coast only if they're very
2 intense and take a very peculiar track.

3 I have people telling me that, now all
4 that historical record is out, and indeed, the
5 tracking of hurricanes is going to be different. I
6 have no idea whether they're right. So what do we do
7 about that?

8 MR. PATTERSON: My bias is to update the
9 data as new data appears.

10 CHAIRMAN POWERS: The difficulty of course
11 is the plant's going to be built, and you're going to
12 come along and say, oh, these guys were right, these
13 intense hurricanes are going to go up. But there's
14 nothing we can do about it because the plant's already
15 built and we've given it a license. That's the
16 problem.

17 MEMBER STETKAR: Let me join in the
18 philosophical fray here. I know you're asking the
19 staff, but I look at it, Dana, as -- it's an excellent
20 question. Can the plant do anything about severe
21 hurricanes once it's built? No, it certainly can't.
22 If hurricanes were, under the current frequencies and
23 severities that are assigned, if they were a very
24 significant contributor to the plant, A, I'd be
25 worried about it today, and I'd be more worried about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it in the future.

2 If it's a very small contribution today
3 and can be justified, it might get larger in the
4 future, but it's unlikely that it would raise to, you
5 know, a factor of ten times higher from its current
6 contribution. That's philosophical because you can
7 argue about the numbers.

8 On the other hand, if hurricanes are
9 screened out entirely and are never revisited again as
10 we gather more data, without the ability to actually
11 quantify the effects of changes, measured changes or
12 projected changes in climatological data, we've lost
13 the ability to understand what that risk might be.

14 So I view it, you know, if it's screened
15 out entirely at this stage in the game, it's not
16 likely to ever be reintroduced. That's the way PRA
17 works. And if the hazard becomes much higher in the
18 future, unless the really catastrophic hurricane just
19 happens to hit the Calvert Cliffs site, it's very
20 unlikely that the PRA will ever go back and revisit
21 those screening analyses. So your concerns I
22 translate more into a even more importance assigned to
23 whether or not those issues, those climatological
24 issues are screened out and forever to not be
25 revisited in terms of this PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Because at least if it's in there, if you
2 have some evidence, you can --

3 CHAIRMAN POWERS: Let me get you a little
4 more excited. The issues of hurricanes is just one
5 issue here. The problem is hurricanes, especially the
6 more intense hurricanes, spawn tornadoes.

7 MEMBER STETKAR: They spawn tornadoes.
8 That's right.

9 CHAIRMAN POWERS: And we have on this site
10 a peculiar railway for the offsite power. What is
11 your response?

12 MEMBER STETKAR: The same thing. I'd
13 certainly want them in the PRA.

14 CHAIRMAN POWERS: Would you treat them --
15 would you treat the hurricane and, consequently, the
16 tornado frequency as an uncertain feature of the PRA
17 and try to quantify the magnitude and the uncertainty?

18 MEMBER STETKAR: I would try to do that;
19 yes.

20 CHAIRMAN POWERS: I mean, my perception is
21 that people have predicted frequencies for hurricanes,
22 and I presume one can provide frequencies of
23 tornadoes, and the two schools of thought I spoke of
24 have different degrees --

25 MEMBER STETKAR: Right. And you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 assign uncertainties based on those schools of
2 thought. Indeed. And indeed in some studies, that
3 type of analysis has been done. Even trying to
4 project out into the future.

5 CHAIRMAN POWERS: That's exactly what we
6 do on seismic right now.

7 MEMBER STETKAR: Right.

8 CHAIRMAN POWERS: And so we come out with
9 seismic hazard curves. Instead of seismic hazard
10 curves, we come out with deleterious tornado curves,
11 or something. I don't know --

12 MEMBER STETKAR: Yes. I mean, the good
13 news is at least here, in tornado and hurricane land,
14 we at least have a reasonable library of historical
15 data, even site-centered historical data, to somewhat
16 anchor that thought process better than --

17 CHAIRMAN POWERS: Yes. We're in vastly
18 better shape here because we have extremely good data
19 for -- back to 1750 on hurricane frequencies on the
20 Atlantic Coast. So I mean, yes, the bands are not
21 going to --

22 MEMBER STETKAR: The uncertainty bands --

23 CHAIRMAN POWERS: -- the uncertainty bands
24 are going to be totally driven by this prognostication
25 of the future, and I just don't know -- I don't know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 how to do it and how to handle it here. So like I
2 said, I will kick it into the hands of the technically
3 superb staff, and they can tell me about this. But I
4 think it's going to come up again.

5 Any other questions for the presenters?

6 MEMBER RYAN: No, sir.

7 CHAIRMAN POWERS: You have none?

8 I want to pose a question to the
9 subcommittee, and perhaps we will reserve answers,
10 answering this question until after we've heard from
11 our next speaker. And that is John's raised this
12 issue about the use of the NUREG/CR-2300 value in
13 these analyses of flooding, turbine building flooding,
14 and their relatively geriatric and questionable
15 nature.

16 Is this an issue -- it's a generic issue.

17 It, as I see it right now, is not a question for --
18 peculiar to Calvert Cliffs. It's a generic issue that
19 we ought to bring to the ACRS's attention and try to
20 understand further what the data are that constitute
21 this recommended number.

22 And is there a better number that could be
23 formulated? I mean, I don't -- people have to use what
24 they have in the processes that are used for this
25 RCOLA, and I don't raise questions about that so much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as the more generic question of, okay, people are
2 going to use this number because that's the number
3 that they have available, and they can't invent it out
4 of whole cloth and here it is.

5 But, quite frankly, I know that at the
6 time NUREG/CR-2300 was written, we were not
7 particularly sensitized to the issue of floods. And
8 in fact we only got sensitized to the issue of floods
9 after we did the IPEEE in connection, and a very good
10 engineer at Oconee thought about floods carefully and
11 said, whoops, I've got a problem.

12 And then subsequently other information's
13 been generated. I also know that the information
14 generated in the particular 2300 was, you know, based
15 on LERs and reportable floods, whereas flood frequency
16 -- I mean, a lot of floods just don't get reported.
17 And in fact what's reported in LER as a flood you
18 might not actually think is a flood.

19 And so I pose that question to the
20 committee, and we may choose to answer that later.

21 (Coughing.)

22 MEMBER STETKAR: You've choked me up, Dr.
23 Powers. I think it is -- and it is it's generic. I
24 mean, it's not directly relevant to this particular
25 proceeding. But I think there are a number of areas

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where, as you describe them, geriatric type numbers --

2 CHAIRMAN POWERS: Oh, I'm extremely
3 familiar with geriatric topics.

4 MEMBER STETKAR: -- and methods are
5 floating around. They're being used to support PRA
6 analyses, screening analyses. I think it is an issue.

7 We've talked about a couple of others, in other
8 subcommittee meetings, where it may be time for the
9 agency to revisit some of those values that are still
10 trudging around in NUREGs and Reg Guides and methods
11 and things like that, especially in the area of things
12 like external events, flooding. Fires is a little bit
13 better only because of the more recent --

14 CHAIRMAN POWERS: It's gotten --

15 MEMBER STETKAR: It is a -- recent
16 attention. But the issue of flooding events, internal
17 flooding events, and certainly the whole issue of
18 external events, I think, does make sense. But,
19 again, it's a generic question that we should probably
20 discuss either as a committee, or a PRA subcommittee,
21 or something like that.

22 CHAIRMAN POWERS: Why don't we -- well,
23 we're certainly going to listen to the next speaker,
24 but maybe we should formulate a note to the P&P
25 Committee and ask them if this is not an issue that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they should consider addressing. I mean, part of our
2 job is to gather relevant information, and it doesn't
3 really have to be specific to the task before us. But
4 if it's one that emerges, that looks like it's
5 something that we ought to have more information
6 about, especially it is my perception that these
7 advanced plants have become incredibly safe with
8 respect to the classic internal initiators that we
9 consider, and now it's all these ancillary things that
10 were, oh, by the way, in the past because the internal
11 event frequencies were high enough that you weren't
12 concerned about them.

13 Now these things are emerging as more of a
14 concern. Maybe we can -- a note to send to P&P and
15 let -- we'll kick the ball over into their court and
16 let them handle it.

17 MEMBER SHACK: Just to be fair to the
18 staff, though, I mean, the COL applicant concluded
19 that was a bounding thing. The staff just said it was
20 reasonable and it didn't have a significant impact on
21 the results and insights for the PRA at the COL stage,
22 which is a more prudential statement.

23 MEMBER STETKAR: That's okay. It is, but,
24 again, I'll come back to the fact that the staff has
25 made the determination that the COL -- that the design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PRA is, indeed, a bounding PRA, so --

2 MEMBER SHACK: Well, that's not what it
3 says here.

4 MEMBER STETKAR: It doesn't say for that
5 particular line item, but the overarching is that the
6 PRA is a bounding PRA. So the question is, is the
7 staff confident that that frequency, not as reasonable
8 and as a small contributor, but, indeed, as a bounding
9 frequency based on the available generic information
10 they have available at their --

11 CHAIRMAN POWERS: Again, my concern has
12 nothing to do with this RCOLA, or the Certification.
13 It is a generic issue. I have no reason to doubt the
14 statements made in the -- by the applicant here. He's
15 confident that he's done a bounding -- that the number
16 is bounding for his case. He knows his plant far
17 better than I do. He will get a chance to correct his
18 statement, if he's wrong, prior to fuel load. I'm
19 concerned more in a generic sense, where it gets used
20 elsewhere, even in existing plants.

21 So I'm not putting any burden on -- I
22 mean, you guys aren't going to be the ones that are
23 going to respond to this, it's going to be somebody
24 else, and whatnot.

25 Okay. We do have another speaker on our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 agenda. I think he's going to have to provide us a
2 very detailed introduction on why he's qualified to
3 speak before this august body before we listen to a
4 word he has to say, otherwise.

5 Mr. Stetkar.

6 MEMBER STETKAR: Good heavens. I'm
7 qualified to speak because I was the only member who
8 would do this. What more do you want?

9 MEMBER RYAN: Sounds good enough to me.

10 MEMBER STETKAR: Look up my CV. It's
11 somewhere.

12 CHAIRMAN POWERS: Well, let me just
13 interrupt. Thank you very much.

14 MR. CARNEAL: Thank you.

15 MEMBER STETKAR: What I want to do is we
16 have a somewhat out-of-the-ordinary exercise that I
17 participated in for two and a half days, April 21st to
18 the 23rd of this year, where, because the PRA itself -
19 - and by the PRA I mean the actual models and the
20 physical PRA models. The event trees are submitted in
21 Chapter 19, but the fault trees and a lot of the
22 supporting analyses are not because they're not
23 available to us. It's difficult for us, as a
24 subcommittee, to draw any independent conclusions
25 regarding the technical quality of the PRA or its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 adequacy to support any of the conclusions that are
2 drawn.

3 And that's one of our roles, is to not
4 just look at the staff's review, and it's something
5 that we do routinely when we have the information
6 available.

7 Since the information wasn't available, I
8 had a meeting with the AREVA PRA team, and, first of
9 all, before I talk about the details of the meeting,
10 I'd really like to honestly thank the AREVA folks for
11 just being tremendously cooperative.

12 They came down here with their models on a
13 computer. They had precisely the right people who
14 came. We had a wonderfully open technical
15 interchange, shared information. It was just a
16 really, really good experience, and I know it was
17 difficult for them to support logistically. I know
18 that they weren't quite sure what they were getting
19 into when they started.

20 So I just would like to really, really
21 express my appreciation to AREVA for doing that.
22 Honestly, it really --

23 CHAIRMAN POWERS: What kind of a lunch did
24 they buy for you anyway?

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: They cannot buy me lunch
2 and I -- no. It was really good, and I honestly
3 really, really appreciate that. I think that it was -
4 - there is no way, independently, if I had been given
5 -- even if I had been given the model on a computer,
6 there's no way I could have done what I did as
7 efficiently, and there's certainly no way that I could
8 have done that if I just had stacks and stacks of
9 printouts of fault trees.

10 We had the person who was the puppet-
11 master, if I can qualify it that way, of the model, so
12 he knew how to navigate through the model immediately
13 to show me things I was asking about. It was very
14 good.

15 Why did I do that? Well, as I said, it
16 was basically an effort to develop an independent
17 sense of confidence, if nothing else, in the quality
18 and level of detail in the PRA. In other words, the
19 PRA has presented numerical results and contributors
20 to support both the DCD and, now, the COL since it's
21 been adopted, and for us, as a subcommittee, to gain
22 confidence that, indeed, those are reasonable
23 assessments of the risk of this plant, without being
24 unduly influenced by either the staff's review or
25 AREVA's presentation. I thought this was a worthwhile

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exercise.

2 So I spent two and a half days. A single
3 person doing a two-and-a-half day spot check, and I'll
4 call it that -- I will not call it a review because it
5 was not a review.

6 A single person doing a two-and-a-half day
7 spot check of bits and pieces of the model certainly
8 is not a full review of the PRA, in any way, shape, or
9 form. So take anything that I have to say within that
10 context. And that's an important context.

11 What I did do is I selected, for a
12 context, five nominal event scenarios. And they were
13 not selected at random. They were selected to examine
14 specific parts of the model that had been troublesome
15 in the past, both horizontally, if I can characterize
16 it that way -- it's kind of a three-dimensional
17 matrix. Horizontally, in the sense of different
18 categories of initiating events. Horizontally, in the
19 sense of Level 1 straight through Level 2 models.

20 And then vertically, using those scenarios
21 as a context for mining down selectively into some of
22 the details of the fault tree models to understand
23 whether or not they're constructed to support the
24 context of those scenarios, and also a more generic
25 sense of what is modeled, what is not modeled. I find

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that a fairly useful type of format to do these kind
2 of spot checks rather than trying to just take a look
3 at a generic event tree, for example, the loss of
4 offsite power, loss of feedwater event tree, and try
5 to think about all of the possible issues of it.

6 So I looked at a loss of offsite power
7 initiating event that eventually transpired to a high-
8 pressure melt scenario because high-pressure melts are
9 generally interesting and I wanted to make sure that,
10 indeed, all features of that type of scenario were
11 captured, and I wanted to understand how high-pressure
12 melts were indeed treated as we went from the Level 1
13 models to the Level 2 models.

14 And loss of offsite power, in itself,
15 generally presents some interesting modeling issues.
16 I selected a steam generator tube rupture initiating
17 event because the tube rupture models also tend to
18 apply some quite interesting modeling and analysis
19 challenges in terms of event timing and operator
20 interactions.

21 And, of course, tube ruptures can be an
22 important contributor to offsite releases, so I wanted
23 to see how they were treated, again, from the Level 1
24 through the Level 2 models.

25 I selected a loss of component cooling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water initiating event, which also eventually resulted
2 in a high-pressure melt scenario. I wasn't as
3 concerned about the high-pressure melt aspects of it
4 in the Level 2 models. I wanted to make sure how the
5 Level 1 models treated interactions with support
6 systems.

7 We looked at a fire initiating event, in
8 particular, a fire in the cable floor, to see how
9 they'd modeled fires and how they were evaluated
10 through the modeling process.

11 And we looked at a loss of component
12 cooling water initiating event during a particular
13 plant shutdown state to examine how they'd done that
14 during shutdown. So that gives -- gave me a little
15 bit of a sense across the different types of models,
16 different categories of initiating events. That's
17 basically the scope of what we looked at.

18 Now overall conclusions. Let me hit high-
19 level things first, and we can go into as much
20 excruciating detail as the subcommittee would like.

21 High-level conclusions. This is my
22 personal opinion. This is not the subcommittee's,
23 certainly not the ACRS's opinion.

24 The models are quite detailed. They -- is
25 the -- if I were to be asked a question, is the level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of detail and the level of sophistication in the PRA,
2 if I can use the term sophistication, adequate to
3 support the conclusion that the overall risk from this
4 plant is well below the safety goal, for example,
5 criteria both for core damage frequency and for large
6 release frequency? My answer to that question would
7 be yes, it is. It's a -- for this stage of the plant
8 design, it's a very well-developed, detailed PRA.

9 CHAIRMAN POWERS: You're saying that if
10 one attempted to do analyses necessary to compare the
11 risk of this plant to the safety goals, the model is
12 adequate to do that, because they certainly have not
13 done those analyses?

14 MEMBER STETKAR: I didn't quite go that
15 far. I'm talking about adequate to support confidence
16 in a margin, where that margin is not a precisely-
17 defined numerical value. For example, the -- let me
18 go on a little bit further to try to explain what I'm
19 talking about.

20 CHAIRMAN POWERS: Okay.

21 MEMBER STETKAR: Do I have any confidence
22 that, indeed, the published core damage frequency and
23 large release frequency are the actual core damage
24 frequency and large release frequency for this plant?
25 No. I don't. I don't.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: Of course not.

2 MEMBER STETKAR: In fact there's
3 reasonable evidence, at least even in the limited
4 stuff that I looked at, to say that it's quite likely
5 that they're optimistic.

6 CHAIRMAN POWERS: Yes.

7 MEMBER STETKAR: How optimistic -- and I'm
8 going to ignore the seismic issue completely for the
9 moment because they've not quantified seismic. How
10 optimistic? I can't make that type of determination.

11 There's been -- I have examples, specific examples,
12 where I think I've identified sources of optimism,
13 both in the Level 1 model and the Level 2 model, that
14 would make those numbers increase.

15 How much do I think they would increase?
16 I don't think that they would increase by an order of
17 magnitude, either one of them, the large release
18 frequency or the core damage frequency. They might
19 come close to an order of magnitude. But that still
20 gives me ample margin below those -- the safety goal
21 values.

22 CHAIRMAN POWERS: No, you can't -- they
23 simply have not done the analyses to compare to the
24 safety --

25 MEMBER STETKAR: That's true.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: Okay. What you're
2 saying is -- I mean, you're saying that they're not
3 going to increase by an order of magnitude, says
4 something but --

5 MEMBER STETKAR: That says something.
6 But, again, what I'm going for here is that as a
7 committee or as an agency I think that we have to be
8 sensitive to two things, and that is, what is the PRA
9 being used for?

10 That in the design stage, it's being used,
11 as best as I can tell, for a couple of different
12 purposes. One purpose is to gain some confidence
13 about where the risk of this particular design is,
14 relative to our current fleet of operating plants and
15 relative to the safety goals, without being too
16 quantitative about that comparison.

17 And my conclusion regarding the quality
18 and level of detail in the PRA, for that purpose, is
19 that it's adequate to gain that confidence, that,
20 indeed, it can be used for that purpose, and the
21 overall conclusions are justified, without being very,
22 very precise about the numbers.

23 Okay. The second important use of the
24 PRA, at least in this particular design center -- and
25 I'm not going to talk about severe accident management

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because it's a separate issue.

2 CHAIRMAN POWERS: Yes. It's somebody
3 else's issue.

4 MEMBER STETKAR: So I'll keep within what
5 we've been talking about. The second use of the PRA
6 is to populate the lists that are used for the
7 Reliability Assurance Program.

8 We've had presentations on Chapter 17, and
9 there seems to be, at the current time, some
10 uncertainty about how those Reliability Assurance
11 Program lists will be characterized at the point of
12 COL issuance.

13 I've heard -- I believe in the
14 presentation for Chapter 15 we heard that at the
15 moment they're characterized at only the system level,
16 which is fine. I've heard concepts that perhaps they
17 might be characterized at not the system level but at
18 the sub-system level, for example, flow paths, trains,
19 or something like that.

20 That doesn't exist right now. That's
21 simply something I've heard. I've also heard that
22 they might be characterized at the level of detail of
23 individual components and failure modes. For example,
24 a reliability of a particular valve failing to open on
25 demand might be the level of detail in the Reliability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Assurance Program list.

2 Now with regard to the PRA, quality and
3 level of detail to support that type of use of the
4 PRA, can it be used to identify systems that are --
5 should be on the Reliability Assurance Program list?
6 Absolutely, it can. Absolutely, without a doubt. No
7 problem at all. I'm even confident enough -- and,
8 again, this is personal confidence -- I'm even
9 confident enough that it can be used to identify sub-
10 system on the level of flow paths and trains.

11 Can it be used to identify individual
12 components or even a subset of that down to individual
13 failure modes for those components? No. It cannot.
14 The reason for that is there are too many assumptions
15 that are put in the PRA, both potentially optimistic
16 and known conservative assumptions that will, indeed,
17 skew the risk importance measures, such that if you
18 are trying to identify individual components, or even,
19 at a lower level, specific failure modes, based on
20 very, very specific risk-importance measures of a
21 Fussell-Vesely importance greater than .005 or a Risk
22 Achievement Worth of greater than 2.000. I would be
23 concerned about using those very, very strict
24 numerical criteria at that level of detail, at the
25 current moment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I think it's -- could you identify large
2 pumps and diesel generators? Well, yes, you could,
3 but --

4 CHAIRMAN POWERS: You can do that without
5 --

6 MEMBER STETKAR: But you can do that with
7 -- but going down to identify a particular motor-
8 operated valve, let's say, in a particular flow path,
9 and the fact that it does not need to be on the
10 importance list because its Risk Achievement Worth is
11 1.995 and its Fussell-Vesely importance is .0045 for
12 any failure mode that could be modeled, is something
13 that the current PRA can't be used for.

14 So that's a caution in terms of the level
15 of detail that will be developed in those Reliability
16 Assurance Program lists and how the PRA will be used
17 to support that. And in terms of high level, I think
18 that's pretty much all I wanted to say as far as
19 getting things on the record.

20 Now I'm certainly willing to talk about
21 more specific details of things that I looked at.
22 It's pretty much -- this is a report for the
23 subcommittee.

24 CHAIRMAN POWERS: Right.

25 MEMBER STETKAR: It's the Subcommittee's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 members, what do you want to hear?

2 CHAIRMAN POWERS: Yes. Are you going to
3 provide us a written report?

4 MEMBER STETKAR: I can provide you a
5 written report.

6 CHAIRMAN POWERS: Why don't you do that.

7 MEMBER STETKAR: I will do that.

8 CHAIRMAN POWERS: I think that would be of
9 interest. I think the -- to my mind, the outcome of
10 our first meeting on Chapter 19 was an interest in
11 doing just exactly what you have done, to pursue a few
12 things in some detail, and it sounds like, that you
13 have done that.

14 MEMBER STETKAR: Yes.

15 CHAIRMAN POWERS: And that we have
16 benefitted greatly from that.

17 Are there other comments people would like
18 to make?

19 MEMBER SHACK: Did you look at the impact
20 of human reliability --

21 MEMBER STETKAR: I did.

22 MEMBER SHACK: -- which is a controversial
23 topic?

24 MEMBER STETKAR: I did. A couple of
25 things that I have to mention, if we want to talk a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 little bit about details.

2 One thing that I did not look at, and I
3 actively did not look at this, is the underlying
4 failure rates for equipment. The underlying human
5 error probabilities, for example. I did not look at
6 the human reliability analysis, at that level of
7 detail.

8 I didn't look at the data analysis to see
9 where they derived data for the failure rate for a
10 pump. I didn't look at the initiating event frequency
11 analyses. I probably should have, given what I've
12 learned about the loss of offsite power. But I didn't
13 because my basic focus was, in two and a half days, to
14 gain some confidence about what is in the PRA and what
15 is not in the PRA, rather than that level of detail.

16 That being said, one of the areas that I
17 did pay very close attention to was the treatment, for
18 example, of human dependencies and timing of human
19 actions within the context of these scenarios.

20 I looked at that issue for the loss of
21 offsite power model. I looked at it pretty closely
22 for the tube rupture model because human performance
23 tends to be quite important and through the process,
24 from Level 1 to Level 2, because people have operator
25 actions out in the Level 2 models that oftentimes are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 completely dissociated from the same people in the
2 Level 1 model. From what I saw, they did it
3 wonderfully. They treated the dependencies -- now the
4 dependencies, you can't find them in the model when
5 you look at the model because the dependencies are
6 treated off-line in post-processing of the cutsets.

7 There's a bit of a philosophical problem
8 doing that because you only post-process the cutsets
9 that survive above your truncation scheme. But they
10 set the truncation values reasonably low. And in the
11 four or five instances where I looked at and
12 challenged them to see whether or not they had treated
13 the dependencies, they had always treated them.

14 Now whether or not the numbers that were
15 assigned for those dependencies are adequate, whether
16 or not -- is a different issue. But, indeed, they
17 were explicitly treated and done in a very systematic
18 manner. But, again, offline. You can't see that by
19 just looking at the fault trees. In fact, you can't
20 see it by looking at the initial cutsets that the
21 fault trees generate.

22 The initial cutsets generate human errors
23 as if they are completely independent. Those cutsets
24 are then run through a post-processor with rules,
25 which if I were doing a detailed review of the PRA,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'd be really interested in looking at those rules, to
2 then determine which combinations of specific actions
3 are coupled through a dependency model.

4 They did have, you know, the appropriate
5 human actions identified for responses, you know,
6 typical responses to events. So that was one area
7 where I was pleasantly surprised, actually.

8 One thing from -- that I did identify, and
9 I should have mentioned this earlier, from a modeling
10 perspective, is that in the FSAR, Chapter 19 of the
11 FSAR, as I mentioned earlier, there are not fault
12 trees presented. However, the event trees are
13 presented in Chapter 19 of the FSAR. Both the Level 1
14 event trees and the Level 2 event trees are presented.

15 What is not presented is what I believe --
16 I've been using the term bridge trees. Do you guys
17 use the term bridge trees?

18 MR. REINERT: Bridge trees.

19 MEMBER STETKAR: Bridge trees. There are
20 bridge trees. The Level 2 event trees are not
21 directly linked to the end of the Level 1 event tree
22 sequences, as you might be led to believe reading the
23 PRA summary information.

24 Indeed, there's an intermediate processing
25 that's done. Now in many cases, that intermediate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 processing is an artifice of the particular software
2 that they're using because they use an intermediate
3 logic structure to essentially hang identification
4 flags on specific sequences so that particular
5 conditions can then be identified later in the Level 2
6 trees.

7 It would be the equivalent, logical
8 equivalent, of identifying house events or boundary
9 conditions. They've done the bookkeeping through a
10 logic branching process. But it's -- that does not
11 affect the sequence progression. It's simply a
12 bookkeeping issue.

13 However, those bridge trees that do not
14 appear in Chapter 19 indeed do include functional
15 models for things. For example, they, in the loss of
16 offsite power event tree, they include models for
17 electric power recovery, for both in-vessel core
18 damage mitigation and for eventual containment
19 mitigation. So there are a couple of different
20 electric power recovery models hidden in that bridge
21 tree.

22 There are models for the operators
23 actively depressurizing the primary system during
24 high-pressure melt scenarios. There is a model for
25 that in the Level 2 event tree also.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So there's a little bit of a complex
2 information -- for example, in the loss of offsite
3 power model, in the Level 1 tree, I have models for
4 operators initiating bleed-and-feed cooling, which
5 involves them opening up relief paths. In the bridge
6 tree, I have a model for operators depressurizing the
7 primary system, which involves them opening up relief
8 paths, and in the Level 2 event tree, I have a model
9 for operators opening relief paths to depressurize.

10 I looked at those models, and they're
11 actually quantified correctly because once you link
12 everything together, indeed, the model solution will
13 come out with the right contributors.

14 From a review, a staff's-review
15 perspective, I don't know whether they looked at the
16 bridge trees because they indeed will have some --
17 some of those, some fraction of the initial high-
18 pressure sequences to a low-pressure late tree.

19 In the tube rupture model, for example,
20 the bridge tree for the tube rupture model has in it -
21 - I have to be careful here. This is one I don't
22 remember. I said I have a report, and it's a lengthy
23 report.

24 Now I can't find the -- I can't find it
25 right now. It's -- I believe it's --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: If you were doing this
2 electronically, John, you'd just search for "tube,"
3 and we'd find it.

4 MEMBER STETKAR: Well, I've got the tube,
5 I'm -- it's -- any bridge tree for the tube rupture
6 model, the Level 2 models differentiate between
7 whether or not I have a scrubbed release or an
8 unscrubbed release. The determination -- some
9 sequences coming out of the Level 1 model, it's clear
10 that they're not scrubbed. Those are transferred
11 directly to the Level 2 model.

12 Some sequences coming out of the Level 1
13 model, it's actually indeterminate whether they'd be
14 scrubbed or not. That determination is made in the
15 bridge tree, and then subsequently, they're sent to
16 either a scrubbed release Level 2 tree or an
17 unscrubbed release 2.

18 So the message is that, indeed, there is
19 an actual part of the entire PRA model in these bridge
20 trees, that is not in the Chapter 19 documentation.
21 On the other hand, none of the fault trees are in the
22 Chapter 19 documentation either. So we know that
23 Chapter 19's only a summary.

24 CHAIRMAN POWERS: I think we look forward
25 to looking at what you had to say, but I'm going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 come out of this thinking that most of the queries
2 that we had about the PRA at the conclusion of our
3 first meeting with the Certification Applicant on
4 Chapter 19 have been largely allayed.

5 MEMBER STETKAR: This was a real
6 confidence-builder. It actually was.

7 CHAIRMAN POWERS: And that's what we're
8 looking for.

9 MEMBER STETKAR: That's right.

10 CHAIRMAN POWERS: It was not -- I mean,
11 it's not like we had any pointed -- we had a couple
12 pointed questions, but that was not the purpose of
13 this exercise.

14 MEMBER STETKAR: Right, right. There's
15 still -- I mean, when you see the report, there are a
16 lot of details here. You look at -- there are
17 identified sources of conservatism, there are
18 identified sources of optimism, but, again, they're
19 focused issues, and they shouldn't necessarily, when
20 you read the report, be interpreted as a broad
21 statement regarding the overall quality or
22 conclusions, which is what I'm trying to back out, at
23 least through this presentation.

24 So, yes, I think you're right, Dana, that
25 this exercise did resolve a lot of those kind of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 uneasiness issues that we had at the conclusion of the
2 subcommittee meeting.

3 CHAIRMAN POWERS: I don't know there was
4 uneasiness, but it's just part of our job to have some
5 confidence in the PRA.

6 MEMBER STETKAR: Yes, yes.

7 CHAIRMAN POWERS: And we never expected a
8 presentation, oral presentation, in a limited amount
9 of time, to give us that confidence. But I think that
10 little check box -- I mean, 19 is one of our big time-
11 consumers here, and that check box on 19 is now -- I
12 think we can check that, and we have a couple of
13 things in Severe Accident we'll check, and then what
14 I'm driving for is at some point we have to tell the
15 Certification Applicant he can move chapters from 3 to
16 4 -- and we need to think about doing that. So we'll
17 go through our checks and get on with it. Very
18 useful.

19 MR. WIDMAYER: Logistically, is it
20 appropriate to addend the report to the minutes of
21 this meeting? Is that what you want to do, or --

22 CHAIRMAN POWERS: Well, right now, I think
23 I want to look at it.

24 MR. WIDMAYER: Right.

25 CHAIRMAN POWERS: And then we'll -- we may

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have to append it. We'll chat as we formulate the
2 minutes here.

3 MR. WIDMAYER: Okay.

4 MEMBER STETKAR: I think that's probably
5 the best one. Let me circulate it to the subcommittee
6 members and see whether you want any higher-level
7 conclusions, for example, or whether what I have here
8 is--

9 CHAIRMAN POWERS: I mean, I think anything
10 that we write, or we suggest to the full committee to
11 write, will be fairly high level --

12 MEMBER STETKAR: Yes. And that's the
13 subcommittee. What I plan to do is submit what I have
14 here in my hand, which, by and large, is a fairly --
15 the results are fairly detailed information.

16 CHAIRMAN POWERS: Yes.

17 MEMBER STETKAR: If you want higher-level
18 information, I'd like some feedback from the
19 subcommittee--

20 CHAIRMAN POWERS: Yes. I mean --

21 MEMBER STETKAR: -- you know, in that
22 sense, before we --

23 CHAIRMAN POWERS: -- we have time to work
24 on them.

25 MEMBER STETKAR: Before we take, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 take any formal action on this report.

2 CHAIRMAN POWERS: Very good. Very good.
3 Any other comments the committee would like to make?
4 It's becoming a tradition for all of these things --
5 outstanding presentations, very informative, very
6 useful.

7 Sir.

8 MR. GIBSON: Dr. Stetkar, did you want to
9 follow up on that one item that we had with regard to
10 the credit for the load reduction in the PRA? Also I
11 do have one minor correction on a particular slide we
12 would like to make also.

13 MEMBER STETKAR: That would be great, if
14 we can do it in 15 minutes, without boring the rest of
15 the subcommittee.

16 MR. GIBSON: I believe we can.

17 MEMBER STETKAR: Okay.

18 MR. GIBSON: Vesna will be available --

19 MS. SLOAN: Can you just make sure, can
20 you ask, make sure Vesna's on the line?

21 MEMBER STETKAR: Vesna, are you on the
22 line? Theron, can we open it up the other direction.
23 Vesna?

24 MS. DIMITRIJEVIC: Yes. I am on the line.

25 MEMBER STETKAR: State -- just for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 record, Vesna, state your name and affiliation.

2 MS. DIMITRIJEVIC: I'm Vesna Dimitrijevic.

3 I'm a lead, technical lead on the EPR PRA for Design
4 Certification.

5 MEMBER STETKAR: Vesna, step back a bit
6 from the microphone because our recorder is wincing.
7 Just -- we can hear you real well.

8 MS. DIMITRIJEVIC: I do have a loud voice.
9 Very definitely. Well, I just want to confirm that
10 there was misunderstanding in my communication with
11 Mr. Stetkar because my interpretation of his question
12 -- because he did ask did we model, you know, the load
13 rejection in the PRA. My response was, no, we didn't
14 model, and then I said but we consider it through the
15 frequency.

16 MEMBER STETKAR: Yes. I didn't, I didn't
17 make that note, Vesna. So that could have been my
18 problem.

19 MS. DIMITRIJEVIC: Yes. Then I -- you
20 said that you look in frequency, it was another ten to
21 minus two, it look reasonable, and then we never
22 continue on that discussion.

23 MEMBER STETKAR: Right. Yes. And as I
24 mentioned, I was focusing less on numbers.

25 Now since you're on the line, can you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 has the load rejection capability been included
2 anywhere else as a numerical modifier for any other
3 initiating event frequency?

4 MS. DIMITRIJEVIC: Not for any other
5 initiating event or -- but it was considered also in
6 recovery of offsite power. So it is -- I mean, it is
7 all included in frequencies of the offsite power, loss
8 of offsite power and recovery of offsite power.

9 MEMBER STETKAR: Well, in --

10 MS. DIMITRIJEVIC: Not in any other
11 initiating event.

12 MEMBER STETKAR: Yes.

13 MS. DIMITRIJEVIC: Not in any initiating
14 event which is not related to offsite power.

15 MEMBER STETKAR: That was my question, in
16 terms of initiating event.

17 MS. DIMITRIJEVIC: Yes.

18 MEMBER STETKAR: So if I were to look for
19 the treatment of that load reject capability -- or I'd
20 call it a plant-runback capability, the only model
21 that that would affect would be loss of offsite power;
22 is that correct?

23 MS. DIMITRIJEVIC: Right. And not model,
24 actually, only sequence. We didn't really consider --

25 MEMBER STETKAR: I use model -- yes. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 use model in the generic sense as everything from
2 initiating event frequency through all of the numbers,
3 through, you know, logic structure. That's probably
4 where we miscommunicated because my concept of the
5 model is everything --

6 MS. DIMITRIJEVIC: Yes. That's where we
7 miscommunicated. Yes. I just wanted to state that we
8 didn't model configuration where the power is supplied
9 from the generator. We just consider -- I mean, we
10 modified frequency.

11 MEMBER STETKAR: Right, right. Okay.
12 Thank you. You had one other, you said?

13 MR. GIBSON: Yes. We had one other. It's
14 Slide 23.

15 MR. HUGHES: Yes, on Slide 23, the slide
16 has an error in the left-hand column. It describes
17 shutdown, loss of offsite power recovery. And it
18 should be shutdown, loss of offsite power, non-
19 recovery. So please make that note.

20 MEMBER STETKAR: Thank you.

21 MR. HUGHES: Actually, thank you.

22 CHAIRMAN POWERS: Good.

23 MEMBER STETKAR: Thank you.

24 CHAIRMAN POWERS: Any other comments
25 anybody would care to make?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Again, I thank the staff as well for all
2 your hard work, and I think at that point we can
3 adjourn.

4 (Whereupon, at 11:48 a.m., the above-
5 entitled matter was adjourned.)

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24


25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

A large, decorative graphic consisting of two overlapping blue swooshes that curve from the left side of the slide towards the right. At the end of the lower swoosh on the right side is a large, solid blue five-pointed star.

UNISTAR NUCLEAR ENERGY

**Presentation to ACRS
U.S. EPR™ Subcommittee
Calvert Cliffs Nuclear Power Plant Unit 3 FSAR
Chapter 19, Probabilistic Risk Assessment
and Severe Accident Evaluation
MAY 21, 2010**

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Introduction



- RCOLA authored using 'Incorporate by Reference' (IBR) methodology.
- To simplify document presentation and review, only supplemental information, or site-specific information, or departures from the U.S. EPR FSAR are contained in the COLA.
- Eleven COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 19.
- AREVA - ACRS Meeting for U.S. EPR FSAR Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation, occurred on February 18-19, 2010 and April 21-23, 2010.

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Introduction



- Today's presentation was prepared by UniStar and is supported by AREVA (U.S. EPR Supplier).
 - Gene Hughes (UniStar Acting Director of PRA)
 - Josh Reinert (AREVA COLA PRA Lead)
- Gene Hughes, UniStar Acting Director of PRA, will present the Calvert Cliffs Unit 3 COLA Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation.

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Agenda



- Calvert Cliffs 3 COLA PRA
- Update During Design and Construction, Transition to Long Term Operation
- Departures and Exemptions (COLA Part 7) and Site-Specific Features
- Internal Events
 - General Summary
 - Loss of Offsite Power (LOOP)
 - Internal Fire
 - Internal Flooding
- Seismic Margins Assessment
- External Flooding
- External Fire
- Other External Events
- Conclusion

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Calvert Cliffs 3 COLA PRA




- U.S. EPR FSAR Chapter 19 is IBR
 - Section 19.1, Probabilistic Risk Assessment
 - Section 19.2, Severe Accident Evaluations
- U.S. EPR FSAR PRA is the Calvert Cliffs 3 COLA PRA
- Calvert Cliffs site-specific features considered - Bounded
- Site-specific external events screened out
- Risk of Calvert Cliffs 3 bounded by U.S. EPR FSAR PRA

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Calvert Cliffs 3 COLA PRA



Summary of U.S. EPR FSAR and Calvert Cliffs 3 PRA Results At-Power Events



Total At Power CDF = 5.3E-07


Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Calvert Cliffs 3 COLA PRA



Summary of U.S. EPR FSAR and Calvert Cliffs 3 PRA Results Shutdown Events

Initiator Contributions to Shutdown CDF

- CA - RHR to Draindown
- CB - Draindown to Head Off
- D - Head Off to Cavity Flood
- E - Cavity Flood to Defuel




Shutdown CDF: 5.8E-08/yr

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Calvert Cliffs 3 COLA PRA




Summary of U.S. EPR FSAR and Calvert Cliffs 3 PRA Results Large Release Frequency




Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Calvert Cliffs 3 COLA PRA



Summary of U.S. EPR FSAR and Calvert Cliffs 3 PRA Results
Large Release Frequency For Shutdown



Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Update During Design and Construction



Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Departures, Exemptions, Site-Specific Features



- 7 Departures from DC
- 8 Exemptions
- Calvert Cliffs 3 Site-Specific Refinements

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Departures from U.S. EPR FSAR



1. Maximum Differential Settlement (across the base-mat)
 - Structural issue not in PRA
2. Maximum Annual Average Atmospheric Dispersion Factor (0.5 mile – limiting sector)
 - Design basis issue – does not impact SAMDA
3. Accident Atmospheric Dispersion Factor (0-2 hour, Low Population Zone, 1.5 miles)
 - Design basis issue – does not impact SAMDA
4. Toxic Gas Detection and Isolation
 - System removed

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Departures from U.S. EPR FSAR



(continued)

5. Soil Shear Wave Velocity (SWV)
 - Nuclear Island meets U.S. EPR FSAR design basis SWV (1000 ft/sec)
 - ESWB soil SWV best estimate 1080 ft/sec versus 720 ft/sec limit
 - high confidence, no design problem / SMA impact under evaluation
 - EPGB soil SWV best estimate 900 ft/sec versus 630 ft/sec limit
 - high confidence, no design problem / SMA impact under evaluation

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Departures from U.S. EPR FSAR



(continued)

6. In-Structure Response Spectra (ISRS)
 - Calvert Cliffs 3 ISRS exceedance from low frequency SSE exceedance
 - Seismic margins assessment (SMA) based upon ground motion response spectrum (GMRS)
 - Calvert Cliffs 3 GMRS bounded by EPR SSE
 - No impact on SMA
7. Normal Power Supply System
 - 480V to 6.9kV cooling tower fans

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Exemptions Required



1. *Maximum Differential Settlement (across the basemat)*
2. *Maximum Annual Average Atmospheric Dispersion Factor (0.5 mile – limiting sector)*
3. *Accident Atmospheric Dispersion Factor (0-2 hour, Low Population Zone, 1.5 miles)*
4. Fitness For Duty Program – Schedule Issue, not in PRA
5. Use of M5™ Advanced Zirconium Alloy Fuel Rod Cladding
 - Included in MAAP Analysis deck / Severe Accident assessments
6. *Toxic Gas Detection and Isolation*
7. *Shear Wave Velocity*
8. Generic Technical Specifications and Bases - Setpoint Control Program – Schedule Issue, not in PRA

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Site Specific Features



- UHS Makeup Water System – Adequate capacity 72 hour plus makeup
- Circulating Water System – Evaluated and treatment confirmed
- Raw Water System, includes Essential Service Water Normal Makeup Supply – Not in PRA (no recovery action to credit Raw Water System)
- Sewage Water Treatment System – Not in PRA
- Security Access Facility, including warehouse – Not in PRA
- Central Gas Distribution System – Discussed under External Events
- Potable and Sanitary Water Systems – Not in PRA

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Site Specific Features




(continued)

- Fire Suppression Systems – Credited in Turbine Building and for RCPs
- Fire Water Supply System – Included in Flooding PRA; only credited to support Fire Suppression Systems in Fire PRA
- Site-Specific Structures
 - Turbine building
 - Switchgear building
 - Grid systems control building plus duct banks - switchyard

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power



UNIT 3 SWITCHYARD

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power



- U.S. EPR FSAR has only conceptual switchyard design
- Breaker-and-a-half scheme in conceptual switchyard design adopted in COLA – no change from U.S. EPR FSAR
- Capability for runback and supply to house loads from main generator in the event of a load rejection (Island Mode) – no change from U.S. EPR FSAR
- Site specific transformer added – plume abatement, waste water treatment, desalinization plant

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power



Switchyard Key PRA Features

- Solid design – better to best industry practice
- Allows maximum flexibility
- No single failure will cause LOOP
- Any single component can be out of service with no disruption of power connections
- Capability for runback and supply to house loads from main generator in the event of a load rejection (Island Mode) - prevents reactor trip in such cases
- Restoration of power can rely on one of two breakers (one close coil each)
- Battery (two divisions) monitored – detail design ongoing

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power

Table 19.1-1 CCNPP Unit 3 LOOP Frequency Derivation

LOOP Category	NUREG/CR-6890 Generic Values (/yr)	U.S. EPR Generic Values (/yr)	NUREG/CR-6890 for CCNPP Units 1 and 2 (/yr)	CCNPP Unit 3 (/yr)
Plant-centered	2.07E-3	2.07E-3	2.01E-3	2.07E-3
Switchyard-centered	1.04E-2	6.21E-3 (modified for consequential LOOP)	9.02E-3	6.21E-3
Grid-related	1.86E-2	$1.86 \times 0.32 = 5.96E-3$ (modified for load rejection)	1.47E-2	$1.47E-2 \times 0.32 = 4.7E-3$
Weather-related	4.83E-3	4.83E-3	3.84E-3	3.84E-3
All	3.59E-2	1.91E-2	2.96E-2	1.68E-2

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power



LOOP Recovery - PRA Treatment (RAI 17 Response)

Table 19-1-1: At-Power LOOP Recovery Basic Events

ID	Description	U.S. EPR Value	Equivalent CCNPP Unit 3 Value
REC OSP 1HR	Failure to Recover Offsite Power Within 1 Hour	5.30E-01	5.16E-01
REC OSP 2HR	Failure to Recover Offsite Power Within 2 Hours	3.18E-01	3.07E-01
LOOP24+REC	Loss of Offsite Power During Mission Time and Failure of Recovery Within 1 Hour	4.80E-05	3.70E-05

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Loss of Offsite Power



LOOP at SHUTDOWN Event: SD LOOP24+REC

Description	U.S. EPR Value	Equivalent CCNPP
Shutdown LOOP Frequency	0.2/yr	Unit 1 = 0.183 Unit 2 = 0.184
Shutdown LOOP Recovery	0.413/event	0.413/event

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Internal Flooding



- Nuclear island unchanged from U.S. EPR FSAR – IBR
- Nuclear Island flooding treated in PRA – no changes
- BOP Challenges – Turbine Building = $3.3E-02$ /yr in base PRA
- Calvert Cliffs 3 qualitative evaluation confirmed treatment
 - Conservative NUREG/CR-2300 value adopted
 - Includes Circulating Water System
 - Detailed design ongoing

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Internal Fire



Internal Fire Risk Assessment Incorporated by Reference

- Nuclear Island Internal Fire – No Calvert Cliffs 3 departures
- Turbine Building Internal Fire – No Calvert Cliffs 3 departures
 - U.S. EPR FSAR design description is conceptual
 - Main Feedwater
 - Startup and Shutdown
 - Condenser
 - Circulating Water System
 - Turbine Bypass valves
 - Closed Cooling Water System
 - Auxiliary Cooling Water System
 - Calvert Cliffs 3 site-specific preliminary design consistent with U.S. EPR FSAR conceptual design

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

Seismic Margins Assessment



- Seismic Margins Assessment (SMA) - IBR in entirety
- No unique plant features that impact the SMA
- Soil features
 - Shear wave velocity addressed as a departure
 - SMA impact under evaluation
 - Ground water issue addressed – no longer a departure
- Site-specific structures
 - HCLPF > 1.67 X GMRS

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

External Events



- High Winds and Tornado Risk Evaluation
 - High Wind Load
 - Tornado Wind Load
 - Tornado Missiles
- External Flooding Evaluation
- External Fire Evaluation
- Aircraft Crash Hazard Risk Evaluation
- Industrial and Transportation Accidents Risk Evaluation
 - Highway Hazards
 - Waterway Hazards
 - Pipeline Hazards
 - Railway Hazards
 - Nearby Facilities Hazards
- Other External Events easily screened

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

External Events



High Winds - Tornado Risk

- Nuclear island designed for 155 mph 3-sec gust
- Non-safety structures designed to ASCE 7-05
- Failure of non-safety related structures will not impact nuclear island
- Tornado: 230 mph design basis (RG 1.76 Region 1, most severe)
 - Safety related structures meet design above
 - Non-safety structures assumed destroyed at 102 mph
 - Missile analysis also designed for Region 1
 - CDF = $5.4E-08$ /yr (approximately 10% of Baseline CDF)



Risk very, very low

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

External Events



External Flooding Evaluation

- Qualitative
- Safety-related structures would not flood using FSAR Section 2 Analysis
- UHS makeup water intake structure and electrical building meet deterministic flooding protection measures (SRP 2.4.10)



Risk very, very low

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

External Events



External Fire

- Qualitative treatment
- FSAR Section 2 analysis
- Cleared zone around the plant
- Habitability of control room protected by isolation, recirculation, operation at positive pressure, capacity for 8 people to occupy for 70 hours without makeup air, breathing apparatus



Risk very, very low

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation

External Events

Airplane Crash

- DOE Standard: STD-3014-2006 applied
 - Three target sets considered
 - CDF = $1.1\text{E-}07/\text{yr}$



Risk level very, very low

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Offsite Hazards



Hazard	Conclusion
Highway Hazard	All too far away to impact plant
Waterway	All too far away to impact plant except for ammonia: < 5 shipments / year (50 limit for screening)
Pipeline	All too far away to impact plant
Railroads	All too far away to impact plant (railroads > 5 miles)
Nearby Facilities: <ul style="list-style-type: none">• Calvert Cliffs 1, 2, & 3• LNG Terminal	All too far away to impact plant except: <ul style="list-style-type: none">• Gasoline – explosion and/or vapor release• Ammonium hydroxide Each of these have initiating event frequency < 1E-06/yr

Chapter 19, Probabilistic Risk Assessment and Severe Accident Evaluation Conclusions



- No ASLB Contentions
- U.S. EPR FSAR PRA bounds Calvert Cliffs 3 COLA PRA
- Departures and Exemptions – Bounded by U.S. EPR FSAR PRA
- Plant Unique Features – Bounded by U.S. EPR FSAR PRA
- Risk of Calvert Cliffs 3 represented by U.S. EPR FSAR PRA
- Severe accident evaluations for Calvert Cliffs 3 represented by U.S. EPR FSAR severe accident evaluations

Acronyms

- **ACRS – Advisory Committee on Reactor Safeguards**
- **ASLB – Atomic Safety & Licensing Board**
- **ASCE – American Society of Civil Engineers**
- **CCWS Component Cooling Water System**
- **CDF – Core Damage Frequency**
- **CFR – Code of Federal Regulations**
- **COL – Combined License**
- **COLA – Combined License Application**
- **CWS – Circulating Water System**
- **DC – Design Certification**
- **DOE – Department of Energy**
- **EDF – Électricité de France**
- **EFWS – Emergency Feedwater System**
- **EPGB – Emergency Power Generating Building**
- **ESW(S) – Essential Service Water (System)**
- **ESWB – Essential Service Water Building (Consisting of ESWCT & ESWPB)**
- **ESWCT(S) – Essential Service Water Cooling Tower (Structure)**
- **EOP – Emergency Operating Procedures**
- **FIRE-SAB-MECH – Fire in Safeguard Buildings, Mechanical Areas**
- **FIRE-SWGR – Fire in Switchgear Building**
- **FIRE-SAB14-AC – Fire in Safeguard Buildings 1 or 4 Switchgear Room**
- **FIRE-MS-VR – Fire in MFWS (Main Feedwater) / MSS (Main Steam) Valve Room**
- **FLD-ANN ALL – Flooding in containment annulus that disables all 4 safety trains.**
- **FSAR – Final Safety Analysis Report**
- **ESWPB – Essential Service Water Pump Building**
- **Fire-MCR – Fire in the Main Control Room**
- **FLD-EFW – Flooding from the EFW system**
- **FLD-SAB14 FB – Flooding in a Safeguard Building**
- **FSER – Final Safety Evaluation Report**
- **GMRS – Ground Motion Response Spectra**
- **GT – General Transient**
- **HCLPF – High Confidence, Low Probability of Failure**

Acronyms

- **IBR – Incorporate by Reference**
- **ISLOCA – Interfacing System Loss of Coolant Accident**
- **ISRS – In-Structure Response Spectra**
- **LOCA – Loss of Coolant Accident**
- **LOOP – Loss of Offsite Power**
- **LRF – Large Release Frequency**
- **MAAP – Modular Accident Analysis Program**
- **MCR – Main Control Room**
- **MFW(S) Main Feedwater (System)**
- **MSPI - Mitigating System Performance Index**
- **NEI – Nuclear Energy Institute**
- **NOED – Notice of Enforcement Discretion**
- **NRC – Nuclear Regulatory Commission**
- **OSP – Offsite Power**
- **PRA – Probabilistic Risk Assessment**
- **RCOLA – Reference COL Application**
- **RCP – Reactor Coolant Pump**
- **RHR(S) – Residual Heat Removal (System)**
- **SAMDA – Severe Accident Mitigation Design Alternatives**
- **SD – Shutdown**
- **SDP – Significance Determination Process**
- **SER – Safety Evaluation Report**
- **SGTR Steam Generator Tube Rupture**
- **SLBI – Steam Line Break Inside Containment**
- **SLBO – Steam Line Break Outside Containment**
- **SLOCA – Small Loss of Coolant Accident**
- **SMA – Seismic Margins Assessment**
- **SRP – Standard Review Plan**
- **SSC – Structures, Systems, and Components**
- **SSE – Safe Shutdown Earthquake**
- **UHS – Ultimate Heat Sink**
- **ULD – Uncontrolled Level Drop**



Presentation to the ACRS Subcommittee

**Calvert Cliffs Nuclear Power Plant Unit 3
Combined License Application Review**

Safety Evaluation Report with Open Items

General Presentation

May 21, 2010

Review Schedule (Public Milestones)



Phase - Activity	Target Date
Phase 1 - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI)	April 12, 2010
Phase 2 - SER with Open Items	April 27, 2011
Phase 3 – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items	July 27, 2011
Phase 4 - Advanced SER with No Open Items	January 31, 2012
Phase 5 - ACRS Review of Advanced SER with No Open Items	May 17, 2012
Phase 6 – Final SER with No Open Items	July 17, 2012

ACRS Phase 3 Review Plan



FSAR CHAPTERS GROUPED BY COMPLETION DATES

Group	Chapter(s)	Issue Date	ACRS Meeting
3A-1	8	1/6/2010	2/18/2010
3B-1	4 5 12 17	3/20/2010 3/22/2010 3/12/2010 3/19/2010	4/20/2010
3B-2	19	4/20/2010	5/21/2010
3B3, 3B4, 3B5	Remaining 13 Chapters		Meeting Dates not yet finalized

Information Incorporated by Reference



Several chapters of the COLA FSAR incorporate by reference the U.S. EPR Design Certification application, which is currently being reviewed under Docket No. 52-020.

The staff's review of the COL FSAR for the chapters or sections, which incorporate US EPR FSAR by reference, ensures that the combination of the information incorporated by reference from the U.S. EPR FSAR and the information included in the COL FSAR represents the complete scope of information relating to a specific review topic. A generic RAI 222, Question 01-5, has been issued for tracking the open item pertinent to the concurrent review of the US EPR FSAR.

Generic Open Item:

RAI 222, Question 01-5 tracks the ongoing review of the U.S EPR FSAR as an open item for all COLA chapters. This OI will be closed after the design certification is complete.



Presentation to the ACRS Subcommittee

**Calvert Cliffs Nuclear Power Plant Unit 3
Combined License Application Review**

Safety Evaluation Report with Open Items

**Chapter 19: PROBABILISTIC RISK ASSESSMENT &
SEVERE ACCIDENT EVALUATION**

May 21, 2010

Staff Review Team



- **Technical Staff**

 - **PRA and Severe Accidents Branch**

 - ◆ **Hanh Phan** (Lead), Senior Reliability & Risk Engineer
 - ◆ **Edward Fuller**, Senior Reliability & Risk Engineer
 - ◆ **Malcolm Patterson**, Reliability & Risk Engineer
 - ◆ **Eric Powell**, Reliability & Risk Engineer

 - **Structural Engineering Branch 2**

 - ◆ **Jim Xu**, Senior Structural Engineer

- **Project Managers**

 - ◆ **Surinder Arora**
 - ◆ **Jason Carneal**
 - ◆ **Prosanta Chowdhury**

Presentation Outline



Section 19.1 - Probabilistic Risk Assessment

- ◆ COL Information Items
 - 1) Open Items
 - 2) Technical Topics of Interest

Section 19.2 - Severe Accident Evaluation

- ◆ COL Information Item
 - 1) Open Item
 - 2) Technical Topics of Interest

Overview of Calvert Cliffs Combined License Application



Chapter 19 – Probabilistic Risk Assessment and Severe Accident Mitigation		
SE Section (Application Section)	Subject	Number of SE Open Items
19.1	Probabilistic Risk Assessment	6
19.2	Severe Accident Evaluation	1
Totals		7
Total Number of RAIs = 6; Number of Questions = 25		

Description of SE Open Items

- **RAI 160, Question 19-19 (Seismic Accident Sequences):** requests the COL applicant provide an update to the system model developed in the U.S. EPR FSAR for the PRA-based seismic margin assessment
- **RAI 198, Questions 19-20 (External Events):** requests the COL applicant reassess external events and show in applicable cases that the resulting CDF and LRF would be significantly lower than the total baseline U.S. EPR CDF and LRF
- **RAI 198, Question 19-21 (Airplane Crash Events):** requests the COL applicant provide analysis which demonstrates that more realistic CDF and LRF resulting from the airplane crash events are significantly lower than the baseline U.S. EPR CDF and LRF
- **RAI 198, Question 19-22 (Toxic Chemical Release):** requests the COL applicant reassess the toxic chemical release accidents according to RG 1.200 screening criteria

Description of SE Open Items

- **RAI 198, Question 19-23 (Tornado Strike Frequency):** requests the COL applicant describe the basis for CCNPP Unit 3 site-specific tornado strike frequency in sufficient detail to allow the staff to confirm the conclusion drawn in the COL FSAR
- **RAI 198, Question 19-24 (Hurricanes):** requests the COL applicant describe the frequencies and potential consequences of hurricanes at the CCNPP Unit 3 site
- **RAI 241, Question 19-25 (Severe Accident Management Guidelines):** requests that the COL applicant add COL Information Item 19.2-1 to the application and to provide a schedule for implementing the severe accident management guidelines prior to fuel loading

Review Approach (General)

- Discussed plant-specific information with other technical branches
- Discussed technical issues with other NRC offices (e.g., RES and NRR)
- Ensured consistency with other COL applications
- Ensured consistency with the analyses documented in COL FSAR (e.g., Chapter 2, “Site Characteristics” and Chapter 3, “Design of Structures, Components, Equipment, and Systems”)

Review Approach (Screening)

- For the deterministic screening assessment, confirmed that:
 - ♦ The potential hazard associated with the postulated external event does not adversely affect the plant
 - ♦ The plant/site is designed to accommodate the “maximum size” of the postulated external event
- For the probabilistic screening assessment, confirmed conformance with RG 1.200 quantitative screening criteria, specifically:

Can be shown using a demonstrably conservative analysis that the CDF and LRF is reasonably lower than the baseline risk values

COL Information Item 19.0-1



- This item directs the COL applicant to either confirm that the PRA in the DC bounds the site-specific design information and any design changes or departures, or update the PRA to reflect this information.
- The COL FSAR states that the U.S. EPR design-specific PRA bounds CCNPP Unit 3.
- The staff's conclusion on COL Information Item 19.0-1 depends on the evaluation of other areas:
 - ◆ Supplemental information provided by the COL applicant to address site-specific design information
 - ◆ Site-specific effects of seismic hazards (**open item**)
 - ◆ Site-specific external events (**open item**)

COL Information Item 19.1-1



- This item directs the COL applicant to describe the uses of PRA in support of licensee programs and to identify and describe risk-informed applications being implemented during the **COL application phase**.
- The COL FSAR states that during the COL application phase, no risk-informed applications are proposed. The uses of PRA during the COL application phase include:
 - ◆ Identifying risk-informed safety insights
 - ◆ Providing PRA importance measures
 - ◆ Gaining risk insights
 - ◆ Providing input to the procedure development process

COL Information Item 19.1-2



- This item directs the COL applicant to describe the uses of PRA in support of licensee programs and to identify and describe risk-informed applications being implemented during the **construction phase**.
- The COL FSAR states that during the construction phase, no specific PRA uses are anticipated and no risk-informed applications are proposed.

COL Information Item 19.1-3



- This item directs the COL applicant to describe the uses of the PRA in support of licensee programs and to identify and describe risk-informed applications being implemented during the **operational phase**.
- The COL FSAR states that during the operational phase, no risk-informed applications are proposed.
- The PRA will be used during this phase to support typical licensee programs such as SDP, MSPI, and the maintenance rule program.

COL Information Item 19.1-4



- This item directs the COL applicant to conduct a peer review of the PRA relative to the ASME PRA standard prior to use of the PRA to support risk-informed applications or before fuel load.
- The following statement is included as a proposed **license condition** in Part 10, Section 2 of the CCNPP Unit 3 COL application:

A peer review of the PRA relative to the American Society of Mechanical Engineers (ASME) PRA Standard shall be performed prior to use of the PRA to support risk-informed applications or before initial fuel load.

COL Information Item 19.1-5



- This item directs the COL applicant to describe the COL applicant's PRA maintenance and upgrade program.
- The following statement is included as a proposed **license condition** in Part 10, Section 2 of the CCNPP Unit 3 COL application:

The CCNPP Unit 3 PRA shall be treated as a living document. A PRA Configuration Control Program shall be put in place to maintain (update) or upgrade the PRA, as defined in ASME Standard RA-Sc-2007 and as clarified by RG 1.200.

COL Information Item 19.1-6



- This item directs the COL applicant to confirm that the U.S. EPR design-specific PRA-based seismic margins assessment is bounding for their specific site.
- RAI 160, Question 19-19, requested that the COLA provide an update to the system model developed in the U.S. EPR FSAR to identify and incorporate as applicable any site-specific capacity reductions due to site-specific effects (soil liquefaction, slope failure) and site-specific structures (site-specific intake structure, intake tunnel heat sink). In addition, the COLA should demonstrate the plant seismic margin (in terms of the sequence-level HCLPF capacity) to be 1.67 times the site SSE.
- The staff is currently reviewing the response. **Question 19-19 is being tracked as an open item.**

COL Information Item 19.1-7



- This item directs the COL applicant to perform site-specific screening analysis and site-specific risk analysis for applicable external events.
- The applicant addressed all external events listed in Appendix A of the ANSI/ANS 58.21-2003, “External Events in PRA Methodology,” and followed the guidance in that standard as well as guidance in NUREG-1407, “Procedural and Submittal Guidance for the Individual Plant Examination of External Events (IPEEE) for Severe Accident Vulnerabilities.”

COL Information Item 19.1-7 (Continued)



- RG 1.200, Section C.1.2.5, states

It is recognized that for those new reactor designs with substantially lower risk profiles (e.g., internal events CDF below $1E-6$ /year), the quantitative screening value should be adjusted according to the relative baseline risk value.

- RAI 93, Question 19-13 and follow-up RAI 198, Question 19-20, requested that the COL applicant reassess the external events using an appropriate PRA screening value, or quantitatively justify that when all conservatisms are removed from the analysis, the resulting CDF and LRF would be significantly lower than the total baseline U.S. EPR CDF and LRF.
- **Question 19-20 is being tracked as an open item.**

COL Information Item 19.1-8



- This item directs the COL applicant to describe the uses of PRA in support of site-specific design programs and processes during the design phase.
- The COL FSAR states that during the design phase, no additional PRA-related design activities are anticipated for CCNPP Unit 3.

Review Approach (Internal Events)

- Confirmation that site-specific and plant-specific features are consistent with assumptions of the EPR PRA at design certification
 - ◆ Loss of offsite power (LOOP)
 - Frequency
 - Recovery
 - ◆ Balance-of-plant systems (e.g., circulating water)
- Confirmation that PRA insights and assumptions are preserved.

COL Information Item 19.1-9



- This item directs the COL ***applicant*** to review as-designed and as-built information and conduct walk-downs as necessary to confirm that the assumptions used in the PRA (including PRA inputs to RAP and SAMDA) remain valid. However, this activity cannot be completed prior to licensing and construction.
- The following statement is part of a proposed **license condition** in Part 10, Section 2 of the CCNPP Unit 3 COL application:
 - ♦ As-designed and as-built information shall be reviewed, and walk-downs shall be performed, as necessary, to confirm that the assumptions used in the Probabilistic Risk Assessment (PRA)... remain valid....

COL Information Item 19.2-1



- A COL applicant that references the U.S. EPR design certification will develop and implement severe accident management guidelines prior to fuel loading using the operating strategies for severe accidents (OSSA) methodology described in U.S. EPR FSAR Tier 2, Section 19.2.5.
- The staff is currently reviewing the response. **Question 19-25 is being tracked as an open item.**

ACRONYMS



- **ASME** - American Society of Mechanical Engineers
- **CDF** - core damage frequency
- **CFR** - Code of Federal Regulations
- **COL** - combined construction permit and operating license
- **DC** - design certification
- **EPRI** - Electric Power Research Institute
- **HCLPF** - high-confidence-and-low-probability-of-failure
- **LOOP** - loss of offsite power
- **LRF** - large release frequency
- **OSSA** - operational strategies for severe accidents
- **PRA** - probabilistic risk assessment
- **RAI** - request for additional information
- **SAMDA** - severe accident mitigation design alternatives
- **SE** - safety evaluation
- **SMA** - seismic margin assessment