

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
 ESBWR Subcommittee: OPEN SESSION

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, June 22, 2010

Work Order No.: NRC-308

Pages
1-195

**NEAL R. GROSS AND CO., INC. Court
Reporters and Transcribers 1323 Rhode
Island Avenue, N.W. Washington, D.C.
20005
(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

ESBWR SUBCOMMITTEE

+ + + + +

TUESDAY

JUNE 22, 2010

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee convened at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., Dr. Michael
Corradini, Chair, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

MICHAEL CORRADINI, Chair

SAID ABDEL-KHALIK

J. SAM ARMIJO

MICHAEL T. RYAN

WILLIAM J. SHACK

JOHN W. STETKAR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

CONSULTANTS TO THE SUBCOMMITTEE PRESENT:

THOMAS S. KRESS

NRC STAFF PRESENT:

CHRISTOPHER BROWN, Cognizant Staff Engineer

AMY CUBBAGE

ZAHIRA CRUZ

MARIE POHIDA

JOHN WU

ROBERT DAVIS

DENNIS GALVIN

AMAR PAL

RENALDO JENKINS

DAVID MISENHIMER

GEORGE CICOTTE

TODD HILSMEIER

MARK CARUSO

ALSO PRESENT:

TIM ENFINGER

JERRY DEAVER

JOEL MELITO (via teleconference)

RICK WACHOWIAK

JOHN STRYHAL (via teleconference)

JAMES CASCONI

LEE DOUGHERTY

GARY MILLER

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks and Objectives, Dr. Michael L. Corradini, ACRS.....	5
Staff Opening Remarks, Amy Cubbage, NRO.....	7
Chapter 5 "Reactor Coolant System and Connected Systems"	
GEH, Jerry Deaver, Tim Enfinger (Phone support Joe Melito	9
NRO - Zahira Cruz (PM, John Wu, Marie Pohida.....	37
Chapter 8 "Electrical Power"	
GEH - Rick Wachowiak, (Phone support-Kevin Nunes).....	48
NRO - Dennis Galvin (PM), Amar Pal, Renaldo Jenkins (BC).....	66
Chapter 11 " Radioactive Waste Management"	
GEH - Tim Enfinger, (Phone support-Jim Cascone) 76	
NRO - David Misenhimer (PM), George Cicotte.....	89
Chapter 17 "Quality Assurance"	
GEH-Gary Miller, Lee Dougherty.....	96
NRO - David Misenhimer (PM), Todd Hilsmeier.....	120

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

Chapter 22 "Regulatory Treatment of Non-Safety
Systems"

GEH - Rick Wachowiak, Gary Miller, Lee Dougherty.....	151
NRO - David Misenhimer (PM), Mark Caruso, Edward Harbuck.....	176

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:27 a.m.

CHAIR CORRADINI: The meeting will come to order. This is a subcommittee meeting of the Advisory Committee on Reactor Safeguards, the Subcommittee on the ESBWR. My name is Mike Corradini, Chairman of the Subcommittee.

Subcommittee members in, or soon to be in attendance, are Sam Armijo, Said Abdel-Khalik, Dennis Bry, John Stetkar, Michael Ryan, Bill Shack, and our Consultant Tom Kress.

The purpose of this meeting is to discuss the SERs for Chapter 5, Reactor Coolant System and Connected Systems; Chapter 8, Electrical Power; Chapter 11, Radioactive Waste Management; Chapter 17, Quality Assurance; Chapter 22, Regulatory Treatment of Non-Safety Systems; and Chapter 19, Severe Accidents PRA, in particular the Aircraft Impact Assessment which will be closed all associated with the ESBWR design.

The Subcommittee will hear presentations by and hold discussions with representatives of the NRC staff and the ESBWR applicant General Electric Hitachi Nuclear Energy regarding these matters.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The Subcommittee will gather information,
2 analyze relevant issues and facts, and formulate
3 proposed positions and actions as appropriate for
4 deliberation by the full committee.

5 Christopher Brown is the designated
6 federal official for this meeting. The rules for
7 participation in today's meeting had been announced
8 as part of the notice of this meeting previous
9 published in the Federal Register on May 28, 2010.
10 Portions of this meeting may be closed to protect
11 information that is proprietary to General Electric
12 Hitachi and its contractors pursuant to 5 USC
13 552(b)(c)(4).

14 A transcript of the meeting is being kept
15 and will be made available as stated in the Federal
16 Register notice. It's requested that speakers first
17 identify themselves and speak with sufficient clarity
18 and volume so they can be readily heard. Also,
19 please check and silence all cell phones and
20 Blackberries so we don't have unusual sounds.

21 We have not received any requests from
22 the members of the general public to make oral
23 statements or written comments. GEH has a phone line
24 on for some of their technical staff to call on if
25 they need assistance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Is that phone line already on line?

MR. BROWN: Yes.

CHAIR CORRADINI: All right. I will simply mention at this point that we have had our first subcommittee meeting on what I'll call the final SERs and associated topics back in May where we talked topical reports. We are proceeding now this month with these chapters and we'll proceed additional months with other chapters in July, August, and September which is the set of final SERs with all the open items closed by the staff.

The focus mainly is on these chapters but I guess I invite the committee that if there are things that concern them or any clarification on the final SER comments to please bring them up so that we can clarify or list things that might need to be cleaned up.

Other than that, I'll proceed with the meeting and call on Amy Cubbage, Acting Branch Chief and the lead PM to kick off this.

MS. CUBBAGE: Thank you. Yes, I would like to just follow on to what the subcommittee chair was saying that with these six chapters we're going to cover today in the interest of time we're selected

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 certain topics to cover and those are focusing on
2 significant open items which are now closed and also
3 on selected topics of ACRS interest from previous
4 meetings that we pulled back from the previous
5 meetings and looked at what issues were of interest.

6 Also we have two topics coming up this
7 afternoon that will be a first-time presentation to
8 the committee and that will be on Chapter 17, the
9 risk-significant components and the methodology for
10 the development there, and Chapter 19, Aircraft
11 Impact Assessment.

12 As we go through these chapters we will
13 have selected members of the staff available to
14 address questions that may come up on topics that are
15 not included in the presentation. We'll do our best
16 to answer those questions. If we need to we can call
17 additional people in.

18 With that I would like to turn over to
19 GE, Jerry Deaver and Tim Enfinger, to start off with
20 Chapter 5 this morning.

21 CHAIR CORRADINI: If I might, let me
22 emphasize something, I guess, before we let GEH kick
23 it off to reemphasize. The way we arrange this, as I
24 had said back in May, we are basically taking these
25 chapters, looking at the things we have identified in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 our letters, our interim letters, on these chapters
2 and the focus will be initially that.

3 Also staff with GH are going to go
4 through anything that was open of significance and
5 discuss how it was closed off and we're done, and
6 then the two new issues. The only thing I forgot to
7 mention and emphasize is that the last thing on the
8 agenda, which is Chapter 19, Aircraft Impact
9 Assessment, will be closed so we'll use actually the
10 break in the afternoon to, shall we say, filter and
11 assess those who are in the room so the remaining of
12 the session of that afternoon session will be closed.

13 MS. CUBBAGE: That's right. I expect the
14 first five chapters discussed to be completely open
15 but if GE identifies any information we get into,
16 please alert us so we can close.

17 CHAIR CORRADINI: Okay. So, Jerry, you
18 want to start us off or is it Tim?

19 MR. ENFINGER: Well, I'm just going to
20 introduce Jerry. I'm Tim Enfinger, GEH Reg Affairs.
21 This is my colleague Jerry Deaver with GEH
22 Engineering. He's going to present Chapter 5.

23 MR. DEAVER: I'm Jerry Deaver. I'll lead
24 the presentation at Chapter 5. This is a list of the
25 things that we are going to cover. Basically they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 were open issues at the last meeting in Chapter 5 and
2 there was the 2007 preliminary SER where there were
3 26 open issues at that time. At this time all are
4 resolved and I'm going to cover one which was more
5 interesting and we had several supplements. We had
6 three supplements, RAI 5.4-59. We'll go through that
7 one.

8 Then at the last ACRS meeting there were
9 a couple topics that were of interest which generated
10 new RAIs. That was RAI 5.2-70 related to IASCC of
11 reactor internals, particularly the shroud. Then
12 there was RAI 5.2-71 and its supplement which dealt
13 with grinding and welding issues of reactor pressure
14 boundary components.

15 Then another item that's come up since
16 the last meeting is a code case that is relatively
17 new. It's N-782 dealing with ASME code addition to
18 be used on projects so I'll cover that item also.

19 The first issue is 5.4-59. This
20 basically dealt with the shutdown cooling aspects of
21 the reactor water cooling system particularly during
22 modes five and six. That's during cold shutdown and
23 refueling. There are basically two items of
24 interest. One is the circulation flow, particularly
25 if it gets short-circuited or not. The other is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 elevation of the water level during shutdown which
2 has an affect on the cooling rate.

3 I included this figure to help clarify
4 the actual conditions during cooling. Basically we
5 have steam separators which are in red and, in
6 particular, the separators themselves or the upper
7 part here, this is the area that actually separates
8 steam and turns it back into reactor fluid. It has
9 several exit points along the way and then the one at
10 the bottom is what we point to as the lower exit
11 point for returning flow.

12 Normal reactor water is typically in the
13 middle of the separator skirt area here this being
14 the skirt area so the normal water level is in this
15 region. Then we have feedwater spargers. You see a
16 full sparger here. We have six of them around the
17 circumference. The objective is to balance the flow
18 around the circumference. That is where the
19 returning reactor water cleanup flow comes from that
20 ties into the feedwater system.

21 Then we have the reactor water cooling
22 suction nozzle. We have two of them. One is
23 directly below the feedwater nozzle. Then 180
24 degrees away we have the other one. We have six-
25 speed water nozzles and we have two reactor water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cleanup nozzles.

2 Typically the colder flow comes in to the
3 feedwater in these many directions but we have the
4 hot water being generated from the core is throughout
5 the separator assembly and it flows down through the
6 standpipes that you see here and gets mixed along the
7 way.

8 CHAIR CORRADINI: What are some length
9 scales since you brought up this really nice picture?

10 Do you have approximate length scales so we can
11 understand just the lengths?

12 MR. DEAVER: There is a scale at the
13 bottom.

14 CHAIR CORRADINI: Is there a scale?

15 MR. DEAVER: Yes, but it's very small.

16 CHAIR CORRADINI: Okay. Sorry. I
17 apologize.

18 MR. DEAVER: Eight feet.

19 CHAIR CORRADINI: All right. Got it.
20 Thank you. Never mind. So it's approximately --
21 using that scale it's approximately eight feet from
22 the suction nozzle to the sparger directly above it?
23 Or maybe more like six feet, excuse me?

24 MR. DEAVER: It's 1.7 meters.

25 CHAIR CORRADINI: I deserve that. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Fine. Thank you.

2 MR. DEAVER: Okay. So let's move to the
3 next slide then. Okay. So there were basically two
4 issues we were addressing. One was the circulation
5 path which was in Response A here. We talk about the
6 vertical separation of feedwater flow and the
7 returning flow. We did a number of sensitivity
8 studies to check to see what the affect would be if
9 we didn't get complete mixing and we found we had a
10 lot of margin associated if we had any complete
11 mixing at different flow rates.

12 Then Item B there was a SIL-357 which
13 dealt with the issues associated if the water level
14 isn't high enough it doesn't cover the separators or
15 up to the separator level. Then what happens is you
16 don't get the closed loop cooling occurring and you
17 just simply get heating in the core region.
18 Obviously that's an abnormal condition. You would
19 normally keep the water level up.

20 Specifically that's an issue that is out
21 of tech specs if you are operating with the water too
22 low. That is not a critical thing. It can be
23 readily corrected and once you get the water level
24 back up, then you can continue the cooling cycle
25 again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: I'm sorry that I should
2 remember this but under Modes 5 and 6 is there water
3 level indication at that point that you would know
4 where you were?

5 MR. DEEVER: Yes. There is always water
6 level indication.

7 CHAIR CORRADINI: Okay.

8 MR. DEEVER: And then Item C just
9 identifies that we did a significant amount of
10 analysis to look at the variability of flows and
11 mixing and what's the sensitivity of the mixing
12 itself. We found that typically the mixing could be
13 as low as .68, I believe, mixing factor and still
14 facilitate cool down. The higher flows actually
15 increase or lower the mixing function that you have
16 to have to facilitate cooling so we studied that
17 clearly.

18 And then Item B there were issues
19 associated with the shutdown PRS where we had
20 questions about the significance if cooling wasn't
21 occurring so we addressed those issues and satisfied
22 the questions that came in.

23 MEMBER SHACK: You needed .68. What do
24 you have?

25 MR. DEEVER: Well, ideally you would have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 1. You'd have complete mixing. During different
2 conditions it will change a little bit but we expect
3 it to be close to 1. I failed to mention earlier
4 that this geometry is really typical of BWRs. We are
5 not really doing anything differently here and so if
6 we don't get the factor 1 it just means we are
7 cooling slower.

8 MEMBER ABDEL-KHALIK: Is there much swell
9 of the vessel during Mode 6?

10 MR. DEAVER: We're at shutdown cooling
11 phase right at this point so there is really not much
12 swell at that point. As part of this issue we looked
13 at when we flood up and we are taking the vessel head
14 off and what is happening in the core so there were a
15 lot of nuances that were studied in this RAI.
16 Basically we concluded that we were always able to
17 keep the cooling loop intact and that as such we
18 replace cooling.

19 MEMBER ABDEL-KHALIK: So the steam
20 separators are pretty much full of water?

21 MR. DEAVER: Really when you are still
22 generating heat in the core you are introducing steam
23 into the separator you've still got steam but then
24 the water is picked off and returned to the downcomer
25 region. Ultimately when the head comes off and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 take off the steam separator themselves then
2 everything is flooded.

3 MEMBER ABDEL-KHALIK: So what would be
4 the maximum quality in the separators during refuel?

5 MR. DEAVER: I don't have that figure.
6 During refueling?

7 MEMBER ABDEL-KHALIK: Right. It would be
8 very low, wouldn't it?

9 MR. DEAVER: Right. I mean, actually all
10 we're doing is we've got decay heat occurring and
11 it's water and we'll get some thermal currents in the
12 water but basically we have the reactor water cleanup
13 system operating entirely throughout the refueling
14 cycle and it's positioned at the top of the chimney
15 so that it's picking up the water as soon as it comes
16 out of the chimney so it's pure water at that point.

17
18 MEMBER ARMIJO: The separators and driers
19 aren't even there.

20 MR. DEAVER: Right. They are removed at
21 that point. No steam or bubbles particularly at all.

22 MEMBER ABDEL-KHALIK: All right.

23 MR. DEAVER: Okay. So in conclusion we
24 made the changes associated with this RAI actually in
25 DCD Revision 6 we have no additional changes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 following that.

2 CHAIR CORRADINI: Then changes were what,
3 though? I thought it was more of a clarification. I
4 guess I didn't understand that.

5 MR. DEEVER: What we did is we added a
6 lot of verbiage as to what was happening during the
7 cool down.

8 CHAIR CORRADINI: Oh, okay. So work
9 verbiage, not changes in design. No change in
10 design.

11 MR. DEEVER: No changes in the design at
12 all. Then we have analytically shown that incomplete
13 mixing can be tolerated and it's not going to be a
14 technical issue. One of the other aspects was, okay,
15 you have a temperature differential occurring in the
16 vessel.

17 Does it generate any thermal fatigue and
18 we answered that question also. The temperature
19 differential is like 21 degrees centigrade and it's
20 not large enough to really cause a thermal fatigue
21 issue. The design permits passive response to
22 mitigate loss of shutdown cooling.

23 MEMBER ABDEL-KHALIK: I'm sorry. I may
24 have missed what you said. What were the main
25 changes resulting from this RAI?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DEAVER: They were word changes.

2 MEMBER ABDEL-KHALIK: Word changes.

3 MR. DEAVER: Yes, in the DCD better
4 describing the cool down function, what was happening
5 during different parts of the cool down.

6 MEMBER ABDEL-KHALIK: No physical change.

7 MR. DEAVER: No physical change, no.

8 MEMBER ARMIJO: Is the flow through the
9 RWCU greater in this system than in conventional
10 BWRs? Three percent versus 1 percent or am I
11 confused?

12 MR. DEAVER: Well, the one thing that is
13 changed for BWRs is we had an RHR function before.

14 MEMBER ARMIJO: Right.

15 MR. DEAVER: So really the reactor water
16 cleanup system now covers both functions so it
17 operates at a higher flow rate during the shutdown
18 cooling but during operation it's only at 1 percent
19 of feedwater flow. There it's just doing the
20 cleaning function. We basically combine this system
21 with the RHR function.

22 MEMBER ARMIJO: But it's still a 1
23 percent flow system?

24 MR. DEAVER: During shutdown it's more
25 like 7.5 percent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Yes, it matches
2 essentially.

3 MR. DEAVER: It's a closed loop. We're
4 pulling flow off and returning it.

5 MEMBER SHACK: But you said it's 1
6 percent at normal operation. That's correct.

7 MEMBER ARMIJO: That was my question.

8 MR. DEAVER: Okay. The next topic was
9 RAI 5.22-70. There were two issues. One was
10 basically asking our plan for mitigation of IGSCC and
11 IASCC at the core shroud. The other issue was
12 associated with mitigating devices or things that we
13 could to help mitigate IGSCC and IASCC in the core
14 shroud.

15 Basically as far as the IASCC is
16 concerned we added information into the DCD
17 associated with the fluence level which is five times
18 ten to the 20th neutrons per centimeter squared. And
19 the fact that material hardening and segregation
20 would occur at that level of fluence. We also
21 acknowledge that improvements in water chemistry,
22 particularly hydrogen water chemistry, would be
23 beneficial to both limit susceptibility to IGSCC and
24 IASCC. That was better clarified.

25 MEMBER ABDEL-KHALIK: With typical core

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 designs how long would it take to reach that fluence?

2 MR. DEAVER: Let's see. I don't know the
3 exact timing. It's obviously before 60 years. Our
4 shroud is essentially the same distance from the fuel
5 as in prior BWRs so we reach that level even in the
6 existing BWRs at 40 years.

7 CHAIR CORRADINI: Somewhere between 40
8 and 60. Is that what I hear you say?

9 MR. DEAVER: I believe that's right.

10 MEMBER SHACK: I think it's about 20 to
11 40.

12 MEMBER ARMIJO: I think it's a lot sooner
13 than that.

14 MR. DEAVER: It probably is because we
15 have seen some affects by CC in plants that are
16 approaching 30 years so that's probably more
17 accurate.

18 MEMBER ARMIJO: Could you clarify the
19 water chemistry control? In the DCD you do not have
20 a hydrogen water chemistry system as far as I know,
21 or has that been changed? Proposed Certified Design
22 for ESBWR.

23 MR. DEAVER: Right. Nothing has changed
24 in that regard. We provide the option to attach or
25 include hydrogen water system so we have all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 connections and instrumentation set up but it's an
2 option that the COL holder would --

3 MEMBER ARMIJO: You would expect or be
4 recommending that the COL holder do that because of
5 the protection of the core internals?

6 MR. DEAVER: Right.

7 MEMBER ARMIJO: Okay.

8 MR. DEAVER: Particularly the bottom head
9 is the region that would be protected the most in
10 that scenario. We do recommend and in the different
11 COL applicants are planning to use hydrogen at this
12 point.

13 MEMBER SHACK: This shroud is bolted in,
14 though, right?

15 MR. DEAVER: Yes. That's a belt and
16 suspenders approach in the event something happens
17 just in case.

18 MEMBER SHACK: Are you really proposing
19 to solution anneal the shroud?

20 CHAIR CORRADINI: Yes. We think it's
21 feasible. We recognize that --

22
23 CHAIR CORRADINI: What did you say?

24 MEMBER SHACK: Big furnace.

25 MR. DEAVER: Yes. We've actually located

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 furnaces and our biggest concern is distortion and
2 we'll have to have a lot of fixturing. We found in
3 the past that if we do a water quench it does cause a
4 lot of distortion because you have unequal cooling
5 rate. We found if you do an air quench, blow air and
6 allow it to cool at a little slower rate --

7 MEMBER SHACK: Are you really sure you
8 can cool it fast enough so that you're doing yourself
9 good rather than harm?

10 MR. DEAVER: Yeah. You know, it's not
11 that thick.

12 MEMBER SHACK: That's true.

13 MR. DEAVER: It's two inches. Of course,
14 we have to actually further contract and actually
15 demonstrate it can be done but our intention right
16 now is to do a solution. We think that will take
17 care of all the residual stresses and the surface
18 stresses and that will be a complete solution for the
19 shroud.

20 MEMBER ABDEL-KHALIK: How fast would you
21 have to cool it? Is that possible for cooling with
22 air for a two-inch thick piece of steel?

23 MR. DEAVER: You have to recognize that
24 we're starting with the low carbon material. We've
25 seen cases where even when material has been abused

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with heat treating and such on the early BWRs that it
2 doesn't crack. Obviously you want to cool it down as
3 quickly as possible.

4 You want to get it out of the sensitizing
5 range as quick as possible. By doing all the tests
6 for sensitization and understanding that it's
7 resistant, then the rate is not as important but we
8 will want to take it down as quickly as possible just
9 to make sure we're not introducing issues.

10 MR. DEAVER: So as preventive measures,
11 like I said, we're using .02 percent or lower carbon.

12 We have process controls, water chemistry controls.

13 We are locating wells away from the high fluence
14 region in order to minimize the affect of IASCC. We
15 have discussed the fact that our intention is to
16 solution anneal the shroud.

17 We believe these are the measures that will be
18 effective in mitigating both IGSCC and IASCC.

19 MEMBER SHACK: When you get right down to
20 it that really is probably your best solution for the
21 IASCC problem. You could do all sorts of things to
22 get rid of the IGSCC but getting rid of the stress
23 that is the only guaranteed way.

24 MR. DEAVER: And we have a solid top
25 guide which is the next highest-fluence component so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it won't have any wells in it either. I think that
2 will be a good solution.

3 MEMBER ARMIJO: The top guide is that a
4 casting or --

5 MR. DEAVER: It's a forging.

6 MEMBER ARMIJO: So it's machined out of a
7 big forging?

8 MR. DEAVER: Yeah, we make a plate that
9 is 5.75 inches thick and then we machine the cells
10 out of it so it's a lot of machining.

11 MEMBER ARMIJO: It's a no nonsense
12 approach, isn't it?

13 MR. DEAVER: That's what we've been doing
14 for ABWR and that was successful.

15 MEMBER ARMIJO: Okay.

16 MR. DEAVER: Okay. Moving on to 5.2-71.

17 This deals with the controls on welding and also on
18 grinding to avoid issues associated with cold work.
19 Since Chapter 4 deals with reactor internals and
20 Chapter 5 dealt with the reactor pressure coolant
21 boundary we basically made both sections refer to the
22 other and so we effectively changed both.

23 With regard to welding to be able to
24 better control welding we added requirements for
25 thorough cleaning of weld preps so there are no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 contaminants. We are requiring protective gas purge
2 on the back side of welds. We are prohibiting the
3 use of the small process because it introduces
4 contaminants in the root pass. We are doing visual
5 examinations on each weld pass so this should improve
6 the ability to reduce weld defects.

7 Then with regard to cold work itself when
8 we've had grinding or other identified cold work we
9 limit the cold work by hardness controls. We have
10 bend radii controls when we are forming pieces. Then
11 we have source finish controls. Then if we happen to
12 have conditions that need to be corrected, then we
13 would do a local or a full solution heat treating to
14 anneal the component. We do a flapper wheel metal
15 removal. We do control machining if we could just
16 take out the layer of cold work. Then mechanical
17 polishing and electroplating is another way.

18 MEMBER ARMIJO: You don't mean
19 electropolish?
20

21 MR. DEAVER: Yes, electropolishing. So
22 these are all ways to mitigate the affects of cold
23 work. We minimize well defects and then any affects
24 on the grinding. Typically some amount of grinding
25 on the welds and such for inspection purposes is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 necessary in some cases. Our solution is to work
2 with suppliers that minimize the need for grinding is
3 our intention.

4 Okay. Then we have Code Case N-782.
5 This was a fairly recent code case, as I mentioned.
6 It asked the question what effective edition and
7 addenda cases should be used in lieu of NCA-1140.
8 There's a couple paragraphs that currently define it
9 has to be within three years of the docketed
10 application for the construction permit or it has to
11 be within the latest edition and addenda endorsed by
12 the regulatory authority which causes when they are
13 built to have different editions and addenda of the
14 code.

15 The reply was and the opinion of the
16 committee that the edition and addenda endorsed for
17 the certified design could be used for licensing
18 purposes. What this does it allows ESBWR to have one
19 code edition and addenda to be used for all plants
20 built under the license. This simplifies life by
21 locking in basically the edition and addenda.

22 If we go to the next slide. So we've
23 incorporated this into DCD Rev. 7 and Table 5.2-1.
24 As I said, this will basically mean that the code
25 edition and addenda will remain the same. Experience

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with the code is that it doesn't really change much
2 in time anyway. The fundamentals remain the same.
3 What it will do it will allow the ASME equipment
4 documentation to basically be refused. Of course, we
5 would have to do reconciliations if there are
6 deviations in that but, in essence, it will simplify
7 the code documentation and the closure of ITAACs. Of
8 course, all the ASME code requirements would still be
9 fully met.

10 In summary, we have basically resolved
11 all the open items. There is one item that will be
12 covered at a later time associated with hydrogen
13 detonation which has a small impact on Chapter 5 and
14 Section 54.6. It's just a fairly minor modification.

15
16 At this point components exposed to
17 reactor water we believe are now more robust with
18 better control over the melting and grinding and
19 initial fabrication of the components. Based on
20 operating experience we have now improved the
21 fabrication processes and methods to be implemented
22 in producing reactor internals.

23 CHAIR CORRADINI: So the 5.4-6 will pick
24 up in July when we discuss Chapter 6?

25 MR. DEAVER: Right. We'll cover all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things associated with that.

2 CHAIR CORRADINI: Any other questions by
3 the committee?

4 John.

5 MEMBER STETKAR: There was an open item
6 that has been closed regarding drywell leakage
7 monitoring.

8 MR. DEEVER: Okay.

9 MEMBER STETKAR: I see you're resetting
10 something since it's obviously nothing that you have
11 prepared for this presentation. This is kind of a
12 minor point of clarification for me because I got
13 confused by a statement in the DCD. The staff had
14 questions regarding your setpoint of 5 gpm for
15 allowed leakage and why that is higher than other
16 people have instituted. Apparently, let me call it a
17 compromise, you say that you've established a rate of
18 change alarm.

19 MR. DEEVER: Yes.

20
21 MEMBER STETKAR: What it says in the DCD
22 is a rate of change alarm setpoint is established at
23 a lower limit value of 8.33 liters per minute, 2.2
24 gpm. 2.2 gpm is not a rate of change.

25 MR. DEEVER: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Is that the leakage rate
2 at which the rate of change --

3 MR. DEAVER: Will start to be monitored.

4 MEMBER STETKAR: Will start to be
5 monitored but there is no specification of what that
6 rate of change would be. In other words, it's not an
7 increase of 1 gpm per hour or per day or per year or
8 per minute. There is no specification of that rate
9 of change.

10 MR. DEAVER: What we are trying to do is
11 anticipate is this --

12 MEMBER STETKAR: I understand that but
13 -- I understand the purpose. I'm glad you clarified
14 that it starts at 2 gpm. It doesn't start at 1 gpm
15 which is something you claim you can monitor.
16 Obviously the predictive capability of that depends
17 on the value that rate of change is monitoring.

18 In other words, do you get the alarm at a
19 rate of change of 1 gpm per year? It will come in
20 pretty easily. Or is it 1 gpm per second in which
21 case it doesn't give you very good predictive
22 capability.

23 MR. DEAVER: I think it's really
24 anticipating reaching the five gallons per minute.

25 MEMBER STETKAR: I understand that and I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was curious whether the tech spec should have a
2 specification on the rate at which that alarm --

3 MR. DEAVER: I think we left that
4 purposely open-ended because it can be a gradual
5 change or it could be something that changes and then
6 stops. There are all kinds of scenarios associated
7 with the rate. I think mainly what it's doing is
8 it's giving the operators an indication that there is
9 an issue and that they need to
10 start --

11 MEMBER STETKAR: My concern us the
12 setpoint for that rate determines its efficacy in
13 terms of giving the operators that forewarning. If
14 the setpoint is a very rapid change, it doesn't give
15 them very much forewarning. On the other hand, if
16 it's a very slow change, it also is not very useful.

17 MR. DEAVER: I think the history was that
18 actually we had 5 gpm before. For ABWR it got
19 changed to 1 but then when we tried to design for it
20 we found we couldn't.

21 MEMBER STETKAR: Right. I understand the
22 concern. I agree with you wholeheartedly but as long
23 as you have specified this rate of change alarm as a
24 way to satisfy these concerns, I was just curious
25 whether there should be any specification of what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that rate is or whether it's a variable rate. I
2 guess I don't know how it would be implemented.

3 MR. DEAVER: I guess at a point in time
4 it specifically brings to the attention the leakage
5 issue to the operators. There are certain things
6 that they can do to better understand it.

7 MEMBER STETKAR: Well, let me understand.
8 Does this alarm simply come in when the leakage rate
9 exceeds 2.2 gpm? In that sense it's not a rate of
10 change alarm, it's just an absolute leakage rate
11 alarm. If that's the case, then I understand what
12 it's doing. On the other hand, if it is actually a
13 rate of change alarm, which is measuring the change
14 in the leakage rate as a function of time --

15 MR. DEAVER: I think mainly what we were
16 trying to do is we know that we have a low-level of
17 leakage generally in the plant so we didn't want to
18 target something that was so low that you're always
19 chasing it and trying to figure it out. I think the
20 2.2 was an attempt to kind of set a level that things
21 under that are kind of --

22 MEMBER STETKAR: But from what you just
23 said it's not a rate of change alarm. It's simply a
24 leakage rate alarm.

25 MR. DEAVER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Is that the way to
2 understand this?

3 MR. DEAVER: I haven't reviewed this
4 recently and I don't want to say anything
5 incorrectly.

6 MEMBER STETKAR: If it's an absolute
7 leakage rate alarm I understand what it's doing.
8 It's a forewarning but that is not a rate of change.

9 MEMBER ARMIJO: I would have been 2 gpm
10 per hour or something.

11 CHAIR CORRADINI: So, Jerry, why don't
12 you take this to the side and see during the day if
13 we can just clear it up. I don't think it's a big
14 issue but, on the other hand --

15 MEMBER STETKAR: I just stumbled over the
16 term "rate of change alarm" and what it was doing.

17 MR. DEAVER: One thing we could do if Joe
18 Melito is one the line, he might be able to address
19 it now.

20 Joe, do you have anything to say in that
21 regard?

22 MR. MELITO: This is Joe Melito. That
23 alarm as we resolved in the RAI on that is 2.2 gpm
24 increase in one hour.

25 MEMBER STETKAR: Ah, okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MELITO: Rate of change alarm.

2 MEMBER STETKAR: Okay. 2 gpm per hour.

3 Thank you because that was not elaborated in the SER.

4 It's 2 gpm per hour. Thank you.

5 MR. MELITO: That was the resolution of

6 the RAI, yes.

7 MEMBER STETKAR: Thank you very much.

8 Don't be shy. You could have jumped in earlier.

9 Don't run away. Is that 2.2 gpm per hour actuated at
10 anytime? It is not predicated on any initial leakage
11 rate as a threshold?

12 MR. MELITO: Right. It's just a change
13 within a one-hour time period that the leakage has
14 increased by 2.2 gpm.

15 MEMBER STETKAR: Great, great, great.

16 Thank you.

17 CHAIR CORRADINI: Okay. Other questions?

18 MEMBER ARMIJO: I have a question.

19 CHAIR CORRADINI: Sam, go ahead.

20 MEMBER ARMIJO: At some point in earlier
21 meetings the reactor vessel there was some discussion
22 whether the vessel would be fabricated or assembled
23 in the field in big components or whether it would be
24 built in the factory and ship to the site.

25 I thought the last time I heard you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 decided that you were going to build it in the
2 factory and ship it to the site. Now I see in the
3 SER that decision is TBD and it will be handled as an
4 ITAAC. Could you clarify that, Jerry?

5 MR. DEAVER: Well, the plants or the
6 customers we were working with we fully intended to
7 complete the vessel and ship as a complete vessel.
8 That was clear. That hasn't changed since our last
9 meeting. We are finding there are some customers
10 like in Switzerland where it's been traditional that
11 they assemble vessels at the site.

12 As a matter of fact they just are land-
13 locked and have those issues. We were just recently
14 discussing that issue with them. Our intent is to
15 complete the vessel as a complete vessel where we
16 have that opportunity and can bring it to the site.

17 CHAIR CORRADINI: Is this a flexibility
18 issue? I guess I'm still not --

19 MEMBER ARMIJO: It's a very big vessel.
20 Other vessels, big ones, Clinton or Limerick were
21 site-assembled but this is a really big vessel and
22 I'm just wondering if that is the first of a kind.

23 MR. DEAVER: Typically diameter is the
24 issue. Length isn't such a factor if you're turning.

25 MEMBER ARMIJO: Okay. So that's your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 argument. You think if you have assembled things of
2 that diameter before successfully this is just one of
3 the same?

4 MR. DEAVER: Certainly this is a little
5 larger than we've done before. Our past plants have
6 been diameters up to 251 inch and here we're at 280.

7 It's larger. Creates more challenges. If the
8 transportation study shows that it can be brought in
9 as one piece, that's our preference.

10 CHAIR CORRADINI: Okay.

11 MEMBER ARMIJO: Thanks. But it's now an
12 ITACC, this unit. If I read the SER right it's now a
13 decision on how the vessel is assembled is an ITACC
14 somewhere in here. I guess that's okay if that's
15 okay with the staff.

16 MR. DEAVER: Effectively local post-weld
17 heat treatments after welding are effective and don't
18 represent any degradation in the process. It's more
19 of an economic issue. You would rather do it in one
20 piece.

21 MEMBER ARMIJO: Sure. If you can't get
22 it there, you can't get it there.

23 MR. DEAVER: Right.

24 CHAIR CORRADINI: Okay. So than you very
25 much.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Do we have a presentation now by the
2 staff?

3 MS. CUBBAGE: Yes.

4 CHAIR CORRADINI: Thank you, gentlemen.
5 We'll see you soon, or some of you.

6 Ms. Cruz, are you going to kick this off?

7 MS. CRUZ: Yes.

8 CHAIR CORRADINI: Great.

9 MS. CRUZ: Okay. Good morning, everyone.

10 My name is Zahira Cruz and I'm the Project Manager
11 for Chapter 5. Today the staff will be presenting
12 two topics. One is the RAI 5.4-59 solution will be
13 presented by Marie Pohida. This actually is
14 discussed in Chapter 19 of the SER, the PRA
15 calculations we did.

16 Then John Wu will be presenting the
17 request from the applicant, a new code case. Then I
18 will turn it over to Marie.

19 MS. POHIDA: Thank you very much. I'll
20 proceed to slide 2. We are discussing open item 5.4-
21 59. The basis of this RAI was to support the staff's
22 understanding of shutdown risk. We requested
23 information on the minimum vessel level to support
24 RWCU shutdown cooling operation and basically to make
25 sure we had adequate circulation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Also we wanted to understand the potential for RWCU
2 shutdown cooling flow to bypass the core due to
3 inadequate missing in the downcomer.

4 The basis for this RAI was that this
5 design is different than current operating PWRs where
6 the inlet and the outlet flow is at mid-vessel with
7 the exception of the RWCU drain line. We also want
8 to understand how the GE service information letter
9 357 was being met.

10 This service letter discusses the need
11 for adequate vessel level to ensure adequate core
12 circulation between inside and outside the shroud.
13 There have been a number of shutdown events where
14 core circulation has been interrupted with resulting
15 reactor heat up and repressurization.

16 I would like to proceed to slide 3,
17 please.

18 MEMBER STETKAR: Be careful about your
19 paper on the mic there. The reporter is going to go
20 crazy.

21 MS. POHIDA: I'm sorry?

22 MEMBER STETKAR: And you really don't
23 want him to do that. You have a nice voice to
24 project. There you go.

25 MS. POHIDA: My voice unfortunately is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not soft. In response to RAIs on the issue GE
2 significantly updated the DCD to include the minimum
3 vessel level to support shutdown cooling circulation
4 and it's the first stage spill of the steam
5 separators.

6 We also did a detail discussion on
7 preventing thermal stratification by maintaining
8 vessel levels sufficiently above minimum level.
9 There is also a discussion of mixing within the
10 vessel.

11 I would like to proceed to slide 4,
12 please. To confirm these DCD updates and GE's
13 simplified calculation for core temperature response
14 within the RWCU shutdown cooling model. The office
15 of research performed three dimensional CFD
16 calculations on RWCU shutdown cooling flows.

17 We got the geometry and the mesh model
18 from GE and the CFD model includes the downcomer
19 region, the space around the seed separators, the
20 inlet feedwater spargers, and the lower plenum
21 detail.

22 What we've concluded that downward flow
23 from the separator spillover interacts with the
24 horizontal jets from the feedwater spargers so these
25 spargers physically spread the incoming flow and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 flow interacts with the separator geometry and the
2 spillover flow results in high turbulence and mixing
3 so we were able to resolve the RAI.

4 That concludes my discussion.

5 CHAIR CORRADINI: Before you conclude,
6 this is a note between research and NRO, the
7 analysis?

8 MS. POHIDA: A note?

9 CHAIR CORRADINI: Well, internal memo. I
10 don't remember. I was asking a friend. I can't
11 remember if we've seen this. That's what I guess I
12 was getting at.

13 MEMBER SHACK: How is this documented?

14 CHAIR CORRADINI: I don't remember a
15 presentation on it. I guess that's what started it.

16 MS. POHIDA: The two times we went to the
17 ACRS the calculations were not completed. The
18 calculations were sent to NRO via a letter report
19 from the Office of Research.

20 CHAIR CORRADINI: Okay.

21 MS. POHIDA: I can provide you the ML
22 numbers if you would like.

23 CHAIR CORRADINI: We'd like that.

24 MS. POHIDA: Okay.

25 CHAIR CORRADINI: We love ML numbers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. POHIDA: Is there any further
2 questions? All right. Thank you very much.

3 MS. CRUZ: John.

4 MR. WU: My name is John Wu. I'm with
5 NRO Engineering Mechanics Branch. I'm going to
6 review GE additional request to ASME Code Case N-782
7 in DCD. Here previously from the presentation they
8 had Code Case 782 in there because there is a
9 limitation in the 50.55a(c). There is a requirement.
10 50.55a require a code edition and addenda date must
11 be determined by the requirement of os ASME Section 3
12 NCA-1140. 1140(a)(2) has two limitations on the
13 date. This limitation is presumed by GEH.

14 The code edition and addenda cannot be
15 three years earlier than the date of the construction
16 permit application was docketed and cannot be earlier
17 than the latest code edition and addenda than those
18 by the regulatory authority.

19 The first one now we have North Anna
20 application coming in which is a COL application
21 coming in 2007 and the permit coming in in 2008. The
22 code edition and photo design for the ESBWR was from
23 2001 through 2003 addenda so there is a four-year
24 gap.

25 This is obviously some kind of not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 compliant with 1140 as we say here so they to require
2 in the request the addition of ASME Code Case N-782
3 in the DCD in order to comply. Code Case N-782 which
4 say the code editions and addenda in those for design
5 saved by or licensed by regulatory authority can be
6 used. There is no limitation on the date so will get
7 around the time limitation required and submit it to
8 the DCD.

9 Well, in the DCD otherwise we love that
10 in the DCD. We probably need that to put in every
11 COL application. Every COL application need to have
12 the difference code editions and addenda in order to
13 satisfy NCA-1140. GEH say in the request, and we
14 have reviewed, because the Code Case N-782 is not
15 recorded in the 1.84, Revision 34, therefore, you are
16 based on 50.55(a), item (b)(1)(4).

17 Therefore, it's not incurred in 1.84.
18 Code Case require the staff approval so they sent the
19 Code Case in March and I review the Code Case and
20 approved it. That coding was a requirement of 10 CFR
21 50.55(a)(3)(i) and (ii). (3)(i) says that this 782
22 is alternative rule to NCA-1140.

23 (3)(i) is proposed alternative rule where
24 it provides acceptable level, quality of the level.
25 (ii) is also like this. Also if the proposed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 alternative to aid some kind of hardship without
2 increase, without gaining the benefit of the increase
3 the level of quality.

4 One is we look at if it's a design code
5 edition and addenda in the design already certified
6 licensed by the staff, today it won't be the same as
7 two years from now because the same code edition and
8 addenda. We certify already. We review every
9 response so that would be the same so we don't lose
10 any level of the quality.

11 Two is the day before I said GE indicate
12 in their presentation they want to put that in the
13 standard DCD rather than in COL application. You
14 have to put it in the COL application every time they
15 have to justify 1140.

16 MS. CUBBAGE: Okay. Is there any
17 confusion on what this is for?

18 CHAIR CORRADINI: I think we understand.

19 MS. CUBBAGE: There's a Catch 22 in the
20 regulations and we are highlighting it here because
21 this is one of the few areas where the applicant
22 needed an exemption in the certified design so there
23 is an exemption to regulations that we're approving
24 here to 50.55(a) and that's why.

25 CHAIR CORRADINI: Fine. Other questions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Thank you for the clarification. Any questions?

2 MEMBER ARMIJO: Not on this issue but I
3 want to get a clarification on RAIs that were closed
4 out related to the isolation condenser from the
5 staff.

6 MS. CUBBAGE: I think the reviewer just
7 left because he felt we were passed that issue.

8 CHAIR CORRADINI: Retrieve the reviewer.

9 MEMBER ARMIJO: Whenever you can get him
10 back.

11 MS. CUBBAGE: Sure. Actually, if you
12 would tell me which RAI then the reviewer may be
13 here.

14 MEMBER ARMIJO: It's 5.4-58 and 5.2-56.

15 MS. CUBBAGE: We'll have to try and get
16 someone.

17 MEMBER ARMIJO: When you get somebody.

18 MS. CUBBAGE: The RAI numbers were --

19 MS. CRUZ: 5.4-58 and 5.2-59.

20 MEMBER ARMIJO: 5.2-56.

21 MEMBER STETKAR: You said 5.4-58.

22 MEMBER ARMIJO: There were two, 5.4-58
23 was on the material for the ICS tubes and then 5.2-56
24 related to inspection.

25 MS. CUBBAGE: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DAVIS: What was the question? Okay.
2 I'm sorry.

3 MEMBER ARMIJO: I haven't asked it yet.

4 MR. DAVIS: Oh, all right.

5 MEMBER ARMIJO: We have you now.

6 CHAIR CORRADINI: Go Sam.

7 MEMBER ARMIJO: The staff resolved these
8 RAIs and one related to justifying the use of Alloy
9 600 for the isolation condenser tubes and GE
10 presented a resolution and an explanation of why they
11 chose that material. I don't have a problem with
12 that. The thing I'm still confused is whether these
13 tubes are subject to in-service inspection. The
14 impression I have is that they are not subject to in-
15 service inspection. I was wondering why the staff
16 accepted that.

17 MR. DAVIS: There's been some recent
18 changes obviously because of the hydrogen detonation
19 issue so I have to go back and look it up but I know
20 the PCCS is not going to receive any ISI because it's
21 just that containment pressure and it just sits in
22 demineralized water.

23 The ICS I can't recall off the top of my
24 head what the final resolution of that was. I
25 believe they are going to do a VT2 on those.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: That's what I thought.
2 That's what the SER says.

3 MEMBER ARMIJO: It is not volumetric

4 MR. DAVIS: No, it's not.

5 CHAIR CORRADINI: Let's get a
6 clarification from the applicant. You guys --

7 MR. DEAVER: This is Jerry Deaver with
8 GEH. The current response related to the hydrogen
9 detonation committed to VT2.

10 CHAIR CORRADINI: Does everyone know what
11 that is? Can you expand, please?

12 MEMBER ARMIJO: Look at it.

13
14 MR. DAVIS: I think you have to remember
15 the thickness of these tubes, I mean they are
16 extremely thin so if a crack were to form, I think
17 from initiation to where you could detect it to where
18 it would leak would be probably a very short period
19 of time plus you would get a radiation alarm if you
20 got a leak in one of those ICS tubes because it's
21 pressurized during normal operation. It's just kind
22 of in standby.

23 MEMBER ARMIJO: So you have some other
24 method of knowing whether those tubes are leaking?

25 MR. DAVIS: We revisited this earlier

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because we looked at the well joint design which I
2 don't think they are a completely done design there
3 but it's going to be kind of unique because it has to
4 be a full pen weld onto those headers and the tubes
5 are -- I don't know if somebody can -- I can't
6 remember but they are extremely thin like 1.6
7 millimeters or something like that. We looked at
8 that recently and determined that it would be
9 unrealistic to ask them to do, say, eddy current or
10 volumetric exam because --

11 MEMBER ARMIJO: Even on a sampling basis.

12
13 MR. DAVIS: More than likely. The only
14 way they are ever going to find it is when it leaks
15 because they are so thin. If you initiated that
16 crack, the time to its leaking would probably not be
17 very long.

18 MEMBER ARMIJO: I was just wanting to
19 know if you knew that the isolation condensers would
20 be in good enough shape to do their job when called
21 upon and you're saying a radiation detector would
22 find out that they were leaking because they are
23 pressurized.

24 MR. DAVIS: All those welds are
25 volumetrically inspected. Really they are butt welds

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 where it goes onto the header. They are not like a
2 partial pen jigger because they are so thick there is
3 no way you could do it any other way. Those all
4 receive volumetric exams. I believe and PTs during
5 initial fabrication.

6 CHAIR CORRADINI: Give your name, please.

7 MR. DAVIS: Robert Davis.

8 MEMBER ARMIJO: I understand.

9 CHAIR CORRADINI: You're okay, Sam, now?

10 MEMBER ARMIJO: Yes.

11 CHAIR CORRADINI: Other questions for --
12 are you departing?

13
14 MR. DAVIS: I'm not departing.

15 CHAIR CORRADINI: Any questions from the
16 committee? Okay. We can move on to Chapter 8.
17 Thank you very much for the staff and we may see you
18 again.

19 So we're on to Chapter 8 from GEH. Is
20 that correct?

21 MR. DEEVER: Yes.

22 CHAIR CORRADINI: Oh, look who's here.
23 Mr. Wachowiak, welcome.

24 MR. WACHOWIAK: Good morning. Rick
25 Wachowiak, GEH. I'm going to present Chapter 8. My

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 air cover is being provided by Kevin Nunes and John
2 Stryhal. They should be on the phone.

3 CHAIR CORRADINI: Can I check that?

4 MR. WACHOWIAK: Are you guys there?

5 MR. NUNES: Kevin Nunes.

6 MR. STRYHAL: John Stryhal.

7 MR. WACHOWIAK: All right. Whew, we're
8 all present.

9 So in Chapter 8, which is the Electric
10 Power Section, there were two open items from the
11 previous SER. One of them was covered I think either
12 two or three weeks ago on the battery qualification
13 testing so we are not going to cover that here. We
14 do have the one open item on the battery loading
15 profile. Then we wanted to cover some other design
16 details that had changed since the original SER was
17 written. They are associated with battery type. The
18 configuration is uninterruptible power supply and how
19 that configuration addresses the Forsmark issue or
20 event. And then the configuration of our ancillary
21 diesel generators. We'll start out with the open
22 item.

23 One of the questions that came up was
24 considering what is the loading profile that is going
25 to be put on the batteries and do the batteries have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the sufficient capability to respond to that load
2 profile.

3 We added information to the DCD to
4 describe what the load profile expected on the
5 batteries is. It's in Table 8.3-3. We also
6 provided an ITACC to perform a test on the batteries
7 given the design loan profile following construction.

8 I have the profile listed here on a subsequent slide
9 so we'll get to that. I have the profile listed
10 here on a subsequent slide so we'll get to that.

11 Further information was asked in response
12 to this concerning the battery capacity, the charger,
13 what were the specs on the rectifier. We added
14 another table into the DCD 8.3-4 that had provided
15 the specifications for those components.

16 Let's take a look at the table that
17 essentially we put into the DCD. The method that was
18 used for this is based on IEEE 485, 1997. Basically
19 we divided the DBA up into the significant time
20 frames, none less than 1 minute because the
21 methodology requires that any load you put on the
22 battery has to be analyzed to be sustained for that
23 minutes.

24 In a DBA LOCA we have the zero to one
25 minute time frame. In that time period is when we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 actuate things like RPS and other protective system
2 type of equipment, RPS mainly there. A one to five-
3 minute time frame which there's not really that much
4 going on other than monitoring. Five to seven
5 minutes and seven to 15 minutes are when things like
6 the DPVs and the GDCS squid valves are opening.

7 Seventeen minutes out to the first hour is
8 essentially more monitoring. There is a few more
9 accusations of things. And then everything is quiet
10 from one to 72 hours. Out to the end it's
11 essentially monitoring equipment and it's the steady-
12 state loads that are on all of the RMU's.

13 You'll see that in our divisions Division 1 and
14 2 early on in that first minute there are additional
15 loads there than on the other two mainly because the
16 MSIV pilot solenoids are on that division. You'll
17 notice also that on Divisions 3 and 4 out longer term
18 into the scenario these are additional loads there
19 because the hydrogen and oxygen monitors for the
20 containment are on Division 3 and 4.

21 The calculations that we've done for
22 these show that on Divisions 1 and 2 the calc that
23 was used to respond to this RAI showed that there was
24 about 20 percent margin on Division 1 and 2 and about
25 4 percent margin on Divisions 3 and 4. We've since

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 done updated calculations and we think we can get
2 more margin back than even that but those weren't in
3 the application. The application still has the 20
4 and the 24.

5 MEMBER ABDEL-KHALIK: Do you really know
6 the loads down to five significant figures?

7 MR. WACHOWIAK: No.

8 MEMBER ABDEL-KHALIK: So this table you
9 could round it?

10 MR. WACHOWIAK: It could be rounded.
11 That's correct. The loads that are in here are
12 essentially estimated nameplate loads for the
13 different equipment that we have. We've got the RMUs
14 and the QDCIS cabinets and the other things so I
15 would guess they could be rounded.

16 MR. STRYHAL: Rick, this is John Stryhal,
17 GEH. All of the loads were rounded up and we rounded
18 up to the next highest 100 watts going up on
19 everything. We did that for all of the solenoid
20 valves for the ICs. We did that for the squib firing
21 circuits. In the very beginning that first on
22 division 22, that's where solenoid valves are
23 energized in the beginning. They are then de-
24 energized but we retain that partial few seconds to
25 show that we took that as IEEE 485 request that one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minute. What happens is at the end of one minute our
2 loads have substantially dropped with the actuation
3 or de-actuation of the solenoid valves that are
4 holding the IC valves closed.

5 MR. WACHOWIAK: Okay. So there was --

6 MEMBER ABDEL-KHALIK: It is listed to the
7 one-watt level. Let's be reasonable.

8 MR. WACHOWIAK: I understand. So we move
9 onto the battery type that we selected for the ESBWR.

10 There was question early on the certification on
11 what type of batteries we were going to be using. At
12 one point we looked into valve-regulated lead acid
13 batteries.

14 The main issue that we ran into with that
15 is there really were no standards associated with
16 that type of battery for nuclear power plant
17 applications. After much study between us, our
18 customers and the NRC we went back and looked into
19 the benefits versus the issues that we would run into
20 to use the different types of batteries.

21 Overall I think we determined that the VLA
22 batteries, which are typically used in nuclear power
23 plants today was our best option and basically gave
24 us the most certainty for certification and for
25 construction. Once again the qualification because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they are a long discharge battery, 72 hours, versus
2 eight hours.

3 That was discussed in the previous
4 meetings so I wasn't going to go into that here. If
5 you have any questions from before we can ask our
6 people on the phone. There was shaking of heads here
7 so we have no questions on that.

8 CHAIR CORRADINI: Not now.

9 MR. WACHOWIAK: All right. The
10 uninterruptable power supply, our configuration is
11 set up so that all of the safety related loads are
12 being run off the uninterrupted full power supply so
13 we don't have anything that is directly connected to
14 the battery. I have a schematic on the next page
15 that I'll show how that's arranged.

16 Each of our divisions has two
17 uninterruptable power supplies. They share the load.

18 We talked about this a year or so ago but if there
19 are any further questions on that, we can entertain
20 them now. Each uninterruptible power supply has a
21 rectifier and a converter all combined into one unit.

22 Normally power comes from the isolation power center
23 and the standby power is from the 250-volt battery.

24 Let me just go on to the schematic. Like
25 I had in text on the previous slide, normal power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 comes from the isolation power center down through
2 the rectifier. This is arranged such that if there
3 is a spike or some sort of an interruption from the
4 isolation power center. It will disable the normal
5 power supply line preferentially over the battery
6 supply so that there is always a continuity of power.

7 That was part of the RAI that addressed the force
8 mark of that.

9 The other thing that we did to the
10 configuration was we used to have a bypass
11 transformer that provided power directly from the
12 isolation power center down to the 125 volt
13 uninterruptible line through a transformer.

14 It turns out that configuration can
15 transmit volts from the isolation power center down
16 around the 250 volt power supply and we removed that.

17 There is no need for that transformer in our design.

18 The best way to get rid of that failure mode was
19 just to get rid of that component.

20 As I mentioned, all of the loads are down
21 off the 120 volt uninterruptible power source. We
22 don't have anything that is convected directly to the
23 batteries so everything must come through the
24 uninterruptible power supply.

25 MEMBER STETKAR: Rick, since you have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this nice picture up there and there was quite a bit
2 of discussion in the SER about it, could you briefly
3 tell us about the coordination of the protective
4 trips on the inverter input, the inverter output,
5 battery charger and such?

6 MR. WACHOWIAK: Okay.

7 MEMBER STETKAR: What gets cut off in
8 what time.

9 MR. WACHOWIAK: For that discussion I'll
10 ask John to go through those.

11
12 Tell me where to point, John.

13 MR. STRYHAL: Okay. This is John
14 Stryhal, GEH. The in-volt voltages that could
15 interrupt the inverter could come in through both the
16 battery chargers for the two batteries or through the
17 two inverter rectifiers which are just like battery
18 chargers on other plants.

19 In fact, these are adjustable in voltage
20 also but their voltage is always higher than the
21 normal battery chargers but we get past that. We
22 have a high-voltage transient. Not a surge from
23 lightning. That's taken care of elsewhere and should
24 not reach this point but a high-voltage transient
25 will come all the way through the system as it did at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Forsmark.

2 It's sent in the initial input circuits
3 that are firing the rectifier, the 12 close
4 rectifiers we're using for both the battery chargers
5 and for the rectifier for the inverter. It's sent
6 and it trips that firing post off within one cycle.
7 Within 2 milliseconds if the inverter -- there is a
8 time delay also which prevents the inverter from
9 tripping for 2 milliseconds on this kind of an input
10 surge. Therefore, it can ride through the first
11 cycle of surge that it gets.

12 This system has been presented. It has
13 been tested by the -- we're using the same rectifiers
14 and inverter that have been placed in Forsmark. We
15 initially were going to use them anyway and we
16 followed this from the inception of the Forsmark and
17 so we followed what was done and what was
18 successfully tested.

19 These rectifiers should protect the
20 inverters both from surges going to island mode when
21 we have to reduce power to our plant hotel load from
22 100 percent power. For a fault in the grid that
23 comes through, or for a fault if we were to be on the
24 standby diesel generators and a fault came through
25 from those, it's always going to be stopped by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 rectifier and keep from tripping the inverters.

2 If it were to trip and if one of the
3 rectifiers were to fail on an invertor, the other one
4 could still be there. Don't expect that to happen
5 but that gives a single failure within each division
6 and taking out the transformers, the regulating
7 transformers, will prevent that surge from carrying
8 through and causing damage to the electronic
9 components within the system. We believe that we
10 have placed the best protection currently available
11 and known and tested to prevent these high voltage
12 transients from carrying through.

13 MEMBER STETKAR: John, this is John
14 Stetkar in case -- you can't see who is talking just
15 for the record. I was writing notes as you were
16 talking. Can you go back and just tell me again what
17 the rectifier -- when you say rectifier, that's both
18 rectifier and battery charger.

19 MR. STRYHAL: The rectifier and the
20 battery chargers. The rectifier for the invertor is
21 the same as the battery charger for the batteries.
22 It's different units but they are made by the same
23 company and they have the same input sensing circuit
24 that prevents the firing of the thyristers, to stop
25 the firing. Now, the ones that have already fired

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will fire through the initial cycle but they kill
2 it., They kill the firing circuit so nothing further
3 passes through. At the inverter there is a 2 to 3
4 millisecond time delay. I've slept since I've read
5 the details of it. It allows the initial surge to be
6 dampened within the inverter but prevents further --
7 if the time delay is over you are stripping on the
8 battery so the battery silently transitions in at 250
9 volts or 245 or whatever it's going to show when it
10 gets placed into service through diodes so the
11 battery --

12 MR. WACHOWIAK: Hey, John.

13 MR. STRYHAL: Yes.

14 MEMBER STETKAR: What I was looking for
15 John you mentioned the input trip setpoint. I think
16 you said one cycle and you just reiterated --

17 MR. STRYHAL: The input remains tripped.
18 I'll correct that. The input once it trips there
19 was already --

20 MR. WACHOWIAK: John, let's get the
21 question all the way out before you start answering.

22 MEMBER STETKAR: I was looking for -- you
23 said -- I'm looking for the relative sensitivity and
24 the timing on the rectifier input trip on a voltage
25 spike versus the inverter output time delay. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 already just mentioned that the inverter output time
2 delay for this type of transient is 2 to 3
3 milliseconds.

4 MR. STRYHAL: That is correct.

5 MEMBER STETKAR: What is the sensitivity
6 of the rectifier input trips signal? When do --

7 MR. STRYHAL: When it sees the first
8 cycle up.

9 MEMBER STETKAR: One cycle.

10 MR. STRYHAL: Yes.

11
12 MEMBER STETKAR: Okay. Thanks.

13 MR. STRYHAL: When --

14 MEMBER STETKAR: We're good.

15 MR. STRYHAL: Can I --

16 MEMBER STETKAR: Thanks.

17 MR. WACHOWIAK: One of the things John
18 was talking about on this system was the battery
19 charger. This figure does not show the battery
20 charger so just in case there was any confusion about
21 that it's not on here.

22 MEMBER STETKAR: I thought that's the way
23 it worked. I just wanted to make sure that I had the
24 relative timing down.

25 MR. WACHOWIAK: One of the other things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we had added to the design, and it was mainly in
2 response to the regulatory treatment of nonsafety
3 systems, or the RTNSS aspects of the design over the
4 ancillary diesel generators. We'll talk some more
5 about the RTNSS characteristic later this afternoon
6 but I just want to cover the diesel generators now.

7 They are separate from the standby diesel
8 generators, out standby diesel generators that we
9 have that power the plant investment protection loads
10 and the things needed for bringing the plant online
11 and things like that. Those are separator
12 generators.

13 These are smaller generators
14 approximately in a 1 megawatt range, little bit
15 larger than this. They are fairly small diesel
16 generators. There are two of them, redundant.
17 Essentially what we installed them for was to address
18 the post-72 hour operation of the plant.

19 One of the reasons that we did that, and
20 we'll get to this later this afternoon, things that
21 are required for post-72 hour also need to have
22 enhanced seismic capability because that's one of the
23 things that need to be addressed by that. What we
24 found was it's easier to make these two smaller
25 generators meet all of the seismic requirements than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it would be to go back and make the larger generators
2 meet every one of the seismic requirements. That was
3 the main reason why we went to this to segment out
4 what actually needed the enhanced requirements.

5 We don't credit these in the first 72
6 hours so they are nonsafety related. They are used
7 after 72 hours and they power things like the
8 containment vent fans or PCCS vent fans that we
9 talked about in previous meetings. They provide the
10 control room HVAC for the long-term, post-72 hours,
11 and various other loads which I have on the next
12 chart.

13 They automatically start low voltage on
14 the ancillary bus that brings these generators online
15 just like you would expect. We also have low room
16 temperature which would bring the generators online
17 mainly so we are assured that the auxiliaries that
18 are needed to start the generator are there and
19 within the ranges of their operation so we added the
20 low temperature start as well.

21 Hard to read on here. I think they are
22 easier to read on your actual printed copies. Sorry
23 not for the people in the back with the multiple-page
24 ones but this figure is essentially in the DCD.

25 We have two generators. The ancillary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 buses are provided by either one. I've shown one
2 here but the other generator would be connected to
3 essentially the same bus. We have normal power
4 coming in from the PIP system and PIPV comes on the
5 other side. You'll notice here that I have some of
6 the loads marked with a star. Those are the loads
7 for a RTNSS that actually brought us to needing these
8 generators. We've got, as I mentioned, the PCCS vent
9 fans, the auxiliaries for the generator itself, the
10 main control room HVAC. They provide a backup power
11 for Q-DCIS and you can see all the different things
12 that come under Q-DCIS. All four divisions can be
13 powered by these. We do have an additional pump that
14 used to be in the design, a diesel-powered pump. I'm
15 sorry, move back up. That is a different one. We
16 took credit for our two fire pumps, the diesel fire
17 pump and the electric fire pump and the electric fire
18 pump is provided by this diesel generator.

19 MEMBER STETKAR: You still take credit
20 for the electric --

21 MR. WACHOWIAK: These are the post-72
22 hour fire ponds. They are for refilling the pools.
23 It's not the core injection which is a separate --

24 MEMBER STETKAR: Right, right, right.
25 But you do take credit for the electric still?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: Yes, because mainly, as
2 we will see this afternoon, one of the requirements
3 for RTNSS-B it needed to be single failure proof so
4 we had to have two pumps to perform that function.

5 MEMBER STETKAR: Okay. Yes.

6 MR. WACHOWIAK: The other loads that we
7 put on here we put on because we thought they were a
8 good idea to have those additional loads, especially
9 powering the non-safety-related DCIS circuits for
10 continuity. Those batteries are two-hour batteries
11 and we would like to give the operators as much
12 flexibility and information as possible so these
13 generators will pick up those loads to provide
14 continuity. They are not required.

15 MEMBER STETKAR: I was going to say on a
16 Design Basis Event they have been dead for 70 hours.
17 Right?

18 MR. WACHOWIAK: If this was only the
19 design basis of that but, once again, we don't delay
20 starting these generators for 72 hours. We start
21 those generators when there is no voltage. Those are
22 other loads that make operating the plant and
23 responding to the scenario easier, not necessarily
24 required though.

25 MEMBER ARMIJO: Rich, I don't understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the significance of a low-room temperature for
2 triggering or starting these things. Why do you do
3 it that way? What is so great about low-room
4 temperature?

5 MR. WACHOWIAK: Well, remember this is
6 non-safety-related stuff here. We wanted to have the
7 flexibility of various designs. One of our issues
8 that we ran into was what happens if we don't have
9 this diesel generator start up right at time zero. A
10 lot of times you say, okay, it starts at time zero.
11 Well, if there is no degraded voltage on this bus
12 right at time zero, it may sit there and it might be
13 cold outside and we just want to make sure that the
14 generator itself before it gets into any thermal
15 problems will come online and start heating up the
16 room for itself so it's not sitting dead for 72 hours
17 and then we have to prove that it's going to start in
18 -40 degree weather. That's what the low-room
19 temperature is doing.

20 MEMBER ABDEL-KHALIK: And that setpoint
21 is what?

22 MR. WACHOWIAK: I think that depends on
23 the generator itself and when we inspect the
24 generator we'll need to determine what that
25 temperature is going to be. Any more questions on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this. The requirements we'll get into this
2 afternoon.

3 So I want to summarize that we have
4 closed all the open issues with Chapter 8 and we've
5 come to the point where the staff can present their
6 SER if there are no more questions. Thank you.

7 CHAIR CORRADINI: Thank you, Rick. We'll
8 see you again later this afternoon.

9 Dennis, are you --

10 MR. GALVIN: We're ready.

11 CHAIR CORRADINI: Are you bringing up the
12 staff?

13 MR. WACHOWIAK: Thanks, John.

14 MR. STRYHAL: You're welcome.

15 MR. GALVIN: Okay. So we are here to
16 present the advance final SER for the Chapter 8
17 Electrical Power. I'm the Project Manager Dennis
18 Galvin and Amar Pal is our lead reviewer and he will
19 proceed.

20 MR. PAL: My name is Amar Pal and I'm the
21 NRO BEB. We met with you October 3, 2007. We did
22 DCD Revision 3. We had the one open item on the
23 battery sizing so we are going to discuss that, how
24 you close this battery-sizing issue.

25 Furthermore, we are going to discuss the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 batteries, DPA's ancillary results and the conclusion
2 because the batteries change from the DCD, the LVRA
3 and now change to VLA. UPS also is changed slightly
4 from the DCD Revision 3. I'm going to discuss that
5 later and ancillary diesel generators later on. The
6 one open item related to the SER was RAI 8.3-52
7 involved in sizing of the battery. It did not provide
8 the battery load profile of the sizing of the
9 battery.

10 Finally we had an audit in 2008 and we
11 were convinced that the procedure that is in the IEEE
12 485, especially the rating factor of 1.25 temperature
13 correction factor based on lowest electrolyte
14 temperature of 60 degrees, the design margin, and the
15 uncertainty of the flow margin and the state of
16 charge after 24 hours.

17 Also the competency of the EPA factor of
18 the EPS. I am convinced that the approach is right
19 and it's going to provide the expected results. RAI
20 8.3-52 is closed. There are two batteries, 6,000
21 volts. A total of two 40 cells and the charger is
22 500. As we said, batteries changed from VRLA to VLA
23 in the DCD Revision 6.

24 The VLA has more experience in industry
25 and in the nuclear power plants. Batteries are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 adequately sized to mitigate accident without charger
2 support for 72 hours. Battery qualification will be
3 demonstrated by type testing per licensing topical
4 report NEDE-33516P.

5 All the safety-related loads are provided
6 by the UPS. UPS consists of a rectifier and an
7 inverter. Each division has two UPSs and each UPS
8 normally carry 50 percent of the load. Normal power
9 to UPS is 480 volt from isolation power center (IPC)
10 bus and standby power is 250 volt dc from batteries.

11 We are concerned about the impact of the
12 high voltage transients during islanding mode of
13 operation in RAI 8.2-14. That has been discussed so
14 I'm going to skip that.

15 We assisted on the ITAAC to verify the
16 trip coordination of safety-related battery chargers
17 and UPS input rectifiers with inverters. As a result
18 of that, the same concern. ESBWR design has been
19 changed to eliminate the safety-related UPS bypass
20 transformers because of potential for disruptive
21 voltages and frequencies to reach safety-related
22 loads. RAI 8.2-14 was resolved.

23 Ancillary diesel generators added in DCD
24 Revision 4. Two ADGs provide 480 vol ac power to
25 meet post 72-hour power requirements. They are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 seismic Category II and building seismic Category II.

2 They are not required to support safety-related
3 loads for the first 72 hours following the loss of
4 all other ac power sources. An undervoltage
5 condition on ancillary diesel buses or a low
6 ancillary diesel room temperature will start ADG.

7 The ADGs are part of RTNSS program. The
8 Availability Control Manual requires that two ADGs
9 with fuel tanks, fuel oil transfer pumps and
10 ancillary buses be available during all modes of
11 operation. ADGs are started and operated at rated
12 load for one hour every 92 days. ADGS are load
13 tested at rated load for 24 hours every refueling
14 outage. That gives us some assurance that the ADG
15 will be performing functionally when required.

16 Conclusion: The applicant has provided
17 sufficient information to demonstrate that the
18 offsite power supply system, onsite ac power supply
19 systems, and onsite dc power supply systems are
20 capable of providing power to support the plant's
21 safe operation satisfying the requirements of GDC 17
22 and 18. Additionally, the staff concludes that the
23 ESBWR design is in compliance with 10 CF 50.63 as
24 they relate to the capability to achieve and maintain
25 hot shutdown in the event of an SBO.7.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That concludes my presentation if you
2 have any questions.

3 MEMBER STETKAR: I do.

4 CHAIR CORRADINI: John.

5 MEMBER STETKAR: One section in the LCR
6 addresses specific generic letters and they are
7 generic letters and they are generic letters 84015,
8 88015, and 94001. They are related to basic design
9 and testing requirements for emergency diesel
10 generations.

11 My conclusion is that the applicant
12 doesn't need to comply with -- doesn't need to
13 address, I guess, because they are generic letters
14 -- doesn't need to address, I guess, because they are
15 generic letters, doesn't need to address those
16 generic letters because the design doesn't contain
17 any emergency diesel generators.

18 It does not obviously contain diesel
19 generations, both the standby diesel generators and
20 the ancillary where they are not safety related but
21 they are designated as RTNSS equipment so they are
22 important to safety. I was curious why just because
23 something is not called a safety-related emergency
24 diesel generator it doesn't necessary need to address
25 these issues that apply to things that I would call a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 diesel generator.

2 MR. PAL: Yes. Staff looked at the way
3 that these diesel generators are not required during
4 an accident or shutdown of the plant. That is the
5 main reason we said that the DCD function is not
6 required.

7 CHAIR CORRADINI: Did that answer your
8 question?

9 MEMBER STETKAR: You know, if I were an
10 attorney I would understand that answer. If I'm an
11 engineer I don't understand the answer because these
12 diesels are important to safety. They are RTNSS
13 equipment. They are not insignificant in terms of
14 the overall plant.

15 CHAIR CORRADINI: So your point is
16 because they are RTNSS they ought to be considered
17 emergency --

18 MEMBER STETKAR: I'm trying to get my
19 hands around -- we'll talk more about this this
20 afternoon but I'm trying to get my hands around what
21 it means to be RTNSS and what that classification
22 means in terms of assuring the reliability -- the
23 design, the reliability, and the availability of the
24 equipment.

25 I have to admit I didn't go back and read

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these generic letters so I don't specifically know
2 what issues are highlighted in them but if they apply
3 to the design or the reliability of diesel
4 generators, I'm trying to get my hands around why
5 they are irrelevant.

6 MR. PAL: Well, as I said, they have the
7 availability control and that requires them to do
8 some testing every 92 days and then every refueling
9 outage so that kind of gives you some assurance that
10 these diesels will perform their function.

11 MS. CUBBAGE: I think there are two parts
12 to this. One is what function is required when it's
13 required and then you go into Reliability Assurance
14 Program. They are required to make sure that the
15 diesels are designed adequate to perform those
16 functions in the times required. Again, we can get
17 into that in more detail this afternoon.

18 MEMBER STETKAR: And maybe it's better to
19 discuss it there. The reason that I brought it up is
20 that, for example, GL 84015 is entitled Proposed
21 Staff Actions to Improve and Maintain Diesel
22 Generator Reliability. I'm curious whether the
23 reliability and availability programs proposed under
24 the RTNSS treatment of these diesels basically
25 satisfy the functional concerns of that generic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 letter.

2 MS. CUBBAGE: Well, unless Arm and
3 Renaldo are prepared to address the specific details
4 of that generic letter, we will try to look into it a
5 little bit more and get with you this afternoon on
6 those topics.

7 Do you have anything to add?

8 MR. JENKINS: This is Renaldo
9 Jenkins. The generic letters that you are referring
10 to reflect sort of a fast interaction with industry
11 over time to reflect the concerns the staff had
12 regarding the equipment meaning their specific safety
13 related requirement. In particular there were
14 requirements that the diesel would start within 10
15 seconds. That was tied to the Chapter 15 accident
16 analysis. That was a driver for a lot of the
17 reliability concerns.

18 Now, in RTNSS space you have the same
19 concern regarding the reliability and availability
20 but you don't have the strict technical requirements,
21 let's say, of starting and loading within a specific
22 time. To say that staff would not be interested in
23 ensuring the reliability and availability of the
24 equipment is not exactly true. We should reflect the
25 concerns of the technical requirements embodied in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those generic letters but did not --

2 MEMBER STETKAR: That's a good answer.
3 I'm glad to hear that because I was just a bit
4 concerned that in the SER these generic letters were
5 essentially dismissed as irrelevant simply because
6 these diesels don't have the safety related emergency
7 stamp next to their name.

8 MR. JENKINS: Right. That is where the
9 whole RTNSS program really needs to sort of capture
10 that, the lessons learned over time regarding how we
11 can assure reliability but not have a strict written
12 requirement.

13 MEMBER STETKAR: Okay. Thank you.

14 MS. CUBBAGE: And that thought process
15 went into the staff's determination of applicability
16 of these generic letters, although I --

17 MEMBER STETKAR: I would feel a lot more
18 comfortable if that paragraph was in the SER.

19 MS. CUBBAGE: I agree with you on that
20 point. I think the statement that it's safety-
21 related emergency diesel, that implication to us is
22 the start time, etc.

23 MEMBER STETKAR: And I fully agree with
24 that. It's the reliability availability part of the
25 equation that I wanted to make sure was being picked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 up through the RTNSS program and that there wasn't
2 anything in the RTNSS availability reliability
3 program that was -- I wouldn't say contrary but
4 substantially relaxed from issues that have been
5 identified in those generic letters. I understand
6 the start time. That is clearly a separate issue.

7 MS. CUBBAGE: And just to follow a little
8 bit, that particular generic letter the focus was on
9 station blackout and the batteries, of course, are
10 the line of defense on the ESBWR for safety-related
11 protection on Station Blackout.

12 CHAIR CORRADINI: Do you have --

13 MEMBER STETKAR: No. We'll wait.

14 CHAIR CORRADINI: Okay. Other questions
15 by the committee? Thank you.

16 I think this might be a good time to take
17 a break.

18 MS. CUBBAGE: This would be a great time
19 to take a break.

20 CHAIR CORRADINI: So you can assemble
21 your troops.

22 MS. CUBBAGE: The Chapter 11 folks need
23 to assemble since we are working ahead of schedule.

24 CHAIR CORRADINI: So we'll take a break.
25 We are little bit ahead. We'll start at 10:30 in 15

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 minutes. Thank you.

2 (Whereupon, at 10:12 a.m. off the record
3 until 10:31 a.m.)

4 CHAIR CORRADINI: Okay. Let's get
5 started. I apologize for being late. I'm sorry.

6 Tim, you're up.

7 MR. ENFINGER: I'm Tim Enfinger, GEH Reg
8 Affairs again. I would like to introduce Jim
9 Cascone, the GEH Rad Waste Engineer for ESBWR. He is
10 going to make our presentation for Chapter 11.

11 MR. CASCONI: Again, I'm Jim Cascone,
12 GEH, Chapter 11 engineer. I just wanted to go very
13 quickly through a brief timeline of Chapter 11.
14 Initially Rev. 3 back in February 2007 in the chapter
15 there were no P&IDs and all the systems were
16 considered mobile and conceptual.

17 In Rev. 4, September 7, 2007, detailed
18 P&IDs were included. However, the systems were still
19 consider mobile and conceptual. The last ACRS
20 meeting held in October 2007 was really based on Rev.
21 3, not Rev. 4. Then in Rev. 5 as a result of some
22 supplements to RAIs, which we'll talk about in a bit,
23 the P&IDs are obviously still there and the
24 subsystems are now considered permanent and final,
25 something that the staff can review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 From the SER in 2007 there were three
2 open items, all of which have been resolved. The two
3 more significant open items were RAIs 11.2-16, 11.4-
4 18. We have the same issue. However, the 11.2 RAI
5 was for liquid and the 11.4 is for solid waste. I'll
6 talk about them a little bit more. The
7 third RAI was 11.4-15 and the question was the staff
8 wanted us to include ITACCs for the solid waste
9 system and we did that. That items is resolved.

10 The two more significant RAIs, 11.2-16
11 and 11.4-18, specifically required us to make the
12 systems permanent meaning take out mobile and to also
13 make the designs final and remove the word
14 conceptual.

15 Initially it was our intent to have the
16 COL applicant specify the systems and staff said that
17 they couldn't review something like that. They
18 needed to have a final design so that is what we did.

19 These sections that you see here, 11.2.2.2 and
20 11.2.2.3 and the figures the system process really
21 did not change.

22 What we did is just reworked the words so
23 that mobile was removed and anything that conveyed it
24 to be a conceptual design was removed and we are
25 committed to having these systems as the permanent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 systems so the staff can review it. Really there
2 were no technical changes. We just went from a
3 mobile conceptual design to a permanent more final
4 design.

5 MEMBER ARMIJO: Does that mean it's in a
6 building as opposed to a skid or something like that?

7 MR. CASCONO: Well, the systems
8 themselves we'll talk about that in a little bit
9 here. The actual process of systems will be skid
10 mounted. Yes, they will be anchor-bolted down to the
11 floor and they will have shielding. In fact, there
12 will be some custom shielding.

13 When we actually spec it out in detail
14 the shielding will be -- the plant will provide some
15 mobile shielding and also the actual skids will have
16 shielding. We are getting kind of ahead of
17 ourselves. I'll answer here on another slide. The
18 same thing is true for the solid waste system. We
19 did the same thing, removed mobile and turned it from
20 a conceptual to a final design.

21 Now, this is just a typical P&ID that we
22 have added. All the P&IDs are in the Chapter 11. I
23 understand it's tough to read and I didn't expect you
24 to be able to read it. I just wanted to show the
25 level of detail that we have in the chapter now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 It's significant.

2 I broke that previous slide up into the
3 next three slides. This slide here shows the
4 collection tanks. These tanks are located on the
5 lower elevation of the radwaste building. These
6 tanks are going to be required regardless of what
7 kind of process we have. They are going to be down
8 in concrete vaults. Like I said, regardless of the
9 process, these tanks are required.

10 This slide here is the actual equipment
11 drain process. It is identical to the floor drain
12 process. It's going to be broken up into skids and
13 this equipment here will be located on the grade
14 level elevation of the radwaste building.

15 The grade level elevation of the building
16 is going to be served by the radwaste crane so as the
17 skids come off the truck we'll be able to place them
18 and fix them down and either pipe them up, use hoses,
19 it really hasn't been established yet, and then
20 shield it up.

21 The reason we're going with this is 30
22 years into the life of the plant if someone comes up
23 with a better idea it will be a relatively easy thing
24 to do to pull these skids out and replace them with
25 whatever the better idea is because, again, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 going to be on the level with the crane.

2 Most radwaste buildings to do something
3 like that it is so difficult that it is essentially
4 impossible to do. To do that in an existing radwaste
5 building you would be chipping concrete and a lot of
6 cutting pipe.

7 It would be a very difficult job. Most
8 plants now that use systems, skid-mounted systems,
9 what they have to do is shop around for real estate
10 in order to be able to make use of the latest
11 technology and we built that real estate right into
12 the design.

13 MEMBER RYAN: On this level all of the
14 equipment that we are looking at in this drawing is
15 skid mounted?

16 MR. CASCONI: This drawing here is going
17 to be skid mounted.

18 MEMBER RYAN: And how much work space is
19 represented with this skid-mounted approach? Close
20 to the building?

21 MR. CASCONI: It's a couple of areas of
22 the -- there are going to be two areas on grade
23 elevation, the 4650 elevation. I think we allocated
24 like 50 by 150 feet per system. You've got to
25 understand what you are seeing here can represent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like three different skids.

2 MEMBER RYAN: I appreciate that you are
3 saying that you want to have the ability to change
4 systems out over a lifetime of a plant because
5 radwaste does evolve over time. I'm trying to just
6 get a feel for if 30 years from now I decided I
7 needed a whole new set of skids how much floor space
8 am I getting by removing all this?

9 MR. CASCONI: Like I said, I think we
10 allocated 50 by 150 feet for these skids.

11 MEMBER RYAN: For all three?

12 MR. CASCONI: No, for each one.

13 MEMBER RYAN: For all three?

14 MR. CASCONI: All three. For just this
15 subsystem we have a floor drain system that also has
16 like 50 by 150 feet and that is skid-mounted. In
17 fact, what we did here is both the equipment drain
18 system and the floor drain system are identical
19 processes so we have a certain degree of flexibility
20 now. If one system is down we can pick up using the
21 other system.

22 MEMBER RYAN: Okay. Thanks.

23 MR. CASCONI: Let's go back to the skid.

24 MEMBER STETKAR: Jim, the collection
25 tanks, you said they are basically permanent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CASCONI: Yes, they are permanent.

2 MEMBER STETKAR: Are the cubicles for
3 those tanks lined?

4 MR. CASCONI: Yes.

5 MEMBER STETKAR: Okay.

6 MEMBER RYAN: If there is a skid-mounted
7 system problem, would it drain ultimately to these
8 cubicles?

9 MR. CASCONI: All of these -- actually
10 not to these tanks. They would be going to the floor
11 drain. That level will have floor drains. Yes,
12 absolutely.

13 MEMBER RYAN: Okay.

14 MR. CASCONI: Really, there is not going
15 to be that big of a volume of water there so there is
16 no collection tanks there.

17 Okay. We talked about collection tanks.

18 We talked about processes on the last one. Here
19 we've got these sample tanks again. Regardless of
20 the type of process we are going to need these tanks.

21 These are going to be the last tanks in the process
22 and they are going to be, again, located on the lower
23 elevation of the radwaste building. All the tank
24 cubicles will be lined cubicles. This is the
25 last step before it either gets sent back to the CST

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 or discharged.

2 MEMBER RYAN: I guess the volume of the
3 lined cubicle is enough for one tank?

4 MR. CASCONI: Yes, plus some more. We
5 haven't established it yet but it's going to be more.

6
7 Let's look at the last one. This just
8 summarizes what I just said. Collection and sample
9 tanks are going to be located at lower elevations.
10 We are going to use them regardless of the process.
11 Then the processing equipment is going to be modular
12 on grade elevation. It will permit us to switch
13 systems in the event someone invents a better
14 mousetrap in the future. Thanks. Any questions?

15 MEMBER STETKAR: Yes, a couple questions.

16 The question has nothing to do with anything that
17 you have just presented. The design mentions that
18 the only tank outside of the radwaste building that
19 might contain some level of activity is the
20 Condensate Storage Tank and that is an outdoor tank.

21 I understand it has a berm around it. It has a
22 collection size and things like that. Do the lines
23 that communicate with the Condensate Storage Tank are
24 they routed underground? Do they bury piping?

25 MR. CASCONI: There will be some, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: What provisions are in
2 place for --

3 MR. CASCONE: For the piping going
4 through that building there was a subsequent RAI that
5 we addressed. Those lines will be doubled-walled.

6 MEMBER STETKAR: Double-walled?

7 MR. CASCONE: Yes.

8 MEMBER STETKAR: Is there a leakage
9 monitoring between the walls or simply a double wall?

10 MR. CASCONE: It was simple a double
11 wall. We have not designed a leakage monitoring but
12 the pipes will be double-walled.

13 MEMBER RYAN: How long a run is it?

14 MR. CASCONE: Well, it's not that long.
15 I don't know if I can quote footage but from the
16 turbine building to the CST it's not that long.

17 MEMBER RYAN: Not a 1,000 feet?

18 MR. CASCONE: Not a 1,000 feet.

19 MEMBER RYAN: But more than 100 feet?

20 MR. CASCONE: Probably less than 100
21 feet.

22 MEMBER RYAN: Less than 100 feet. I
23 guess over the long haul if you think of things like
24 lots of heavyweight traffic over it.

25 MR. CASCONE: There won't be any of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 coming over it. It will be between the turbine
2 building and the CST.

3 MEMBER RYAN: Have you picked any
4 materials for this pipe yet?

5 MR. CASCONI: Haven't even selected them.

6 MEMBER RYAN: I guess the whole leakage
7 issue, you know, I'm thinking keep it simple. If
8 you're inside the turb looking up, you'll be able to
9 see the pipe going through and then an annulus
10 around that so it's something that would be
11 relatively visible to an operator on a tour so we
12 haven't really designed anything there yet.

13 MEMBER STETKAR: Jim, if you don't have
14 any in situ monitoring for leakage, you know, leakage
15 monitoring between the double walls or whatever,
16 where are your groundwater monitoring wells located
17 on the site? Are they out on the fence line or are
18 they in close --

19 MR. CASCONI: I can't answer that. It's
20 probably something that is site specific.

21 MEMBER STETKAR: That would be in the
22 COL. Okay.

23 MR. CASCONI: That's not something I can
24 answer.

25 MEMBER STETKAR: Okay. Fair enough.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: There is an interesting and
2 I think important point here is that there has got to
3 be some interaction between surface water, near-
4 surface groundwater, and hopefully not the contents
5 of the pipe. Whatever system you have and whatever
6 the arrangement is, of course, it's going to vary
7 from plant to plant, it's an important question to
8 address.

9 Obviously it's been in the news and has
10 been paid a lot of attention. Double-wall pipes are
11 great stuff but, then again, how do you verify it
12 over 30, 40, 50, 60 years of operation. Something to
13 think about.

14 CHAIR CORRADINI: Other questions, John?

15 MEMBER STETKAR: Yeah, and I'm not sure
16 whether this is fair game but I guess we'll ask it
17 anyway.

18 CHAIR CORRADINI: We can always declare
19 you outside the box. Go ahead.

20 MEMBER STETKAR: You don't need to
21 declare me outside the box.

22 CHAIR CORRADINI: Legally.

23 MEMBER STETKAR: You can put me in the
24 box or whatever. Anyway, apparently the onsite
25 storage capacity, I'm talking about low-level waste

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 storage, has a nominal capacity for about six months.

2 You correctly say that storage capacity is a nominal
3 storage capacity and it's a specific COL items as far
4 as agreements for disposal of that waste. Do you
5 have any estimates based on -- actually Dr. Ryan
6 might know this -- based on our current operating
7 fleet whether six months storage capacity is
8 adequate?

9 CHAIR CORRADINI: Dr. Ryan.

10 MEMBER STETKAR: I'll ask GEH or Dr. Ryan
11 who might --

12 MR. CASCONI: I can tell you right now
13 for most of the plants the answer to that would be no
14 because Barnwell has shut down so right now there
15 isn't a place to ship to so they are going to have to
16 store it until they can find a place to ship it to.

17 MEMBER RYAN: Capacity is not the
18 question. It's access to capacity.

19 MEMBER STETKAR: Well, no. But, I mean,
20 in terms of onsite storage capacity if I were going
21 to build an ESBWR today, I would probably be looking
22 for more onsite storage capacity.

23 MR. CASCONI: It depends on what state
24 you're building it in. Most of the states, like I
25 think 36 or 37, were shipping to Barnwell so to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 answer yes --

2

3

4

5

MEMBER STETKAR: Trying to get a feel for that in terms of the practicalities of putting one here in the U.S. Okay, thanks.

6

7

8

MEMBER RYAN: And I appreciate the fact that's a question you really have to think about it as things evolve and they are evolving all the time.

9

10

Just for everybody's benefit, Texas is in the process of getting a license and Barnwell is closed.

11

12

13

All but the Atlantic Compact states and the current facilities in the Atlantic Compact states as opposed to new ones and --

14

15

CHAIR CORRADINI: But that's a small subset of who used to use it.

16

17

18

19

MEMBER RYAN: Oh, absolutely. EnviroCare is available for some class A waste. As far as utilities go, I mean, some class A waste could go to --

20

MR. CASCONI: To the Utah facility.

21

22

23

MEMBER RYAN: -- Utah. But, you know, at this point the whole question of blending is still out there being assessed now.

24

25

MEMBER STETKAR: It was just a point of -
- I was just trying to get a feel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER RYAN: Thank you very much.

2 MR. CASCONI: Any other questions?

3

4 CHAIR CORRADINI: I think we're done.

5 MR. CASCONI: Thank you very much.

6 CHAIR CORRADINI: David, are you going to
7 lead us off?

8 MR. MISENHIMER: Yes. My name is Dave
9 Misenhimer. I'm the Chapter PM for Chapter 11. It's
10 only been recent that happened but, nonetheless, I'm
11 here as the Chapter PM. George Cicogtte is our
12 technical reviewer who is going to do the
13 presentation today. He is going to focus on the few
14 open items.

15 CHAIR CORRADINI: We're just helping you
16 out.

17 MEMBER STETKAR: When you come to
18 subcommittee meetings you've got to learn to operate
19 the equipment. This is sort of the low budget part
20 of the operation.

21 MR. MISENHIMER: I should have had that
22 set up first. Sorry about that. So, anyway, I'll
23 let George take it from here.

24 MR. CICOTTE: Are you going to operate
25 the slide thing? Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We are here to talk about what is being
2 done about the open items that were resolved and
3 closed since the last time this came before the
4 committee and hopefully we can answer any questions
5 that you have about those items and anything else
6 that has been changed since then.

7 Just a brief overview on that last slide,
8 I guess. Like Mr. Misenhimer I was not on the
9 original review but I have gone over that since I was
10 assigned to this.

11 CHAIR CORRADINI: Speak up a little bit.

12 MR. CICOTTE: I was not originally
13 assigned to this particular design but took that over
14 from Jean-Claude Dehmel. That's why I'm here to take
15 care of this. There have been some things that we
16 went over to make sure we had all our ducks in a row.

17 The remaining open item for Chapter 11
18 was 121.2-16, as the applicant had indicated. Our
19 presentation is basically we had the same information
20 because we were looking at the same things, what they
21 had provided in the initial description and such, and
22 we asked them some more information about it. They
23 provided more information and ultimately it was
24 decided that they would change these from the mobile
25 systems to the permanent systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I know you were asking about the fact
2 that these are skid-mounted and such. As far as what
3 we looked at, although these systems are skid-
4 mounted, you are talking how much room there is for
5 them and such, one of the things that we look at is
6 whether or not the capacity of the building for them
7 is adequate, whether the systems fit in the room,
8 whether it can be shielded, that any leakage inside
9 be properly collected and ventilated and filtered and
10 that sort of thing.

11 We ultimately decided this was
12 sufficient. As far as the safety evaluation goes,
13 whether it's skid-mounted or not doesn't really
14 affect that because it's still designed to be
15 monitored for leakage.

16 MEMBER RYAN: Sometimes maintenance
17 activities, you know, having the ability to take a
18 skid off and out into a different area sometimes buys
19 you a lot from an ALARA standpoint as opposed to a
20 welded firmly-fixed --

21 MR. CICOTTE: From my former life as an
22 HP technician many years ago in a number of power
23 plants, in particular some BWRs, the existing plants
24 a lot of times they will bring in skid-mounted
25 systems and such to augment the capacity for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 particular function and such.

2 As I mentioned, sometimes there are some
3 real estate problems but in this case it's my
4 understanding from what the applicant was talking
5 about and the representation they made to us are the
6 purpose here would be to supplant those systems, not
7 to provide additional skids inside the area but take
8 those out in modular form. As you pointed out, there
9 are some ALARA advantages to going in and cutting and
10 such.

11 I worked on the piping replacement at
12 Peach Bottom and that was very labor-intensive so
13 there are some distinct advantages there. But
14 these systems are designed to pull out and put a new
15 one in. If they made design changes, those would be
16 addressed in the operating side.

17 11.4-18, as they pointed out, pretty much
18 the same thing. It was just that these were solid
19 waste processing systems and that's pretty much the
20 same thing so that was all we had about that.

21 In part because of the fact that they
22 were changing to permanent systems and in part the
23 way that the systems were being described we had
24 asked them to take care of the problem, whether it's
25 a mobile system or permanent system and the effect on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what should be ITAAC. That's really what 11.4-15 was
2 about. There aren't any open items remaining in
3 either 11.2 or 11.4.

4 Any questions for me?

5 MEMBER STETKAR: Yes, George. I hate to
6 hit both you guys with this given your history but
7 it's something I apparently didn't pick up the first
8 time. I wanted a little bit of clarification and
9 maybe GEH can help out. This was with gaseous waste,
10 something we really haven't discussed this morning.

11 There's an analysis performed.
12 Apparently Branch Technical Position 11-5 includes
13 -- again, it's a Branch Technical Position so I don't
14 know whether I should characterize it as a
15 requirement to show that you meet doses at the
16 exclusionary boundary for release duration of two
17 hours from a leak or bypass event in a gaseous waste
18 processing system.

19 GEH has calculated the doses based on a
20 one-hour release rather than a two-hour release. The
21 SER has accepted that based on the fact that the
22 release duration of one hour is classified as being
23 consistent with the isolation time for the system.

24 The analysis that they have performed
25 says the system has to be manually isolated so there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is no automatic isolation of the system.

2 I was curious whether the guidelines
3 under the Branch Technical Position it's okay to take
4 credit for manual isolation of those releases or
5 whether or not a release then, indeed, extends for
6 two hours would still meet the dose requirements. My
7 suspicion is that it wouldn't because otherwise why
8 would they reduce the isolation time.

9 MR. CICOTTE: I believe the premise under
10 which it was approved was that the one-hour time
11 frame -- the two hours was basically kind of a
12 default value in the Branch Technical Position absent
13 additional information. The information that was
14 provided by the applicant in support of having it be
15 one hour was sufficient to conclude that it was not
16 likely that it would last that long, that isolation
17 would be able to be accomplished such that a one-hour
18 duration would be an outside window.

19 Part of their analysis says that the
20 cause of this failure could be, I think they use the
21 term, computer related but I'll substitute digital
22 I&C control system related where the operations might
23 not necessarily have all of the indications available
24 to them that they do under normal situations.

25 MEMBER STETKAR: I guess what I'm asking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is I'm focusing on the fact this is a manual action.

2 Granted one hour is not 10 minutes but whether or
3 not that type of manual isolation is consistent with
4 the staff's interpretation of the guidance.

5 MR. CICOTTE: I'll have to look that up
6 to be certain.

7 MEMBER STETKAR: Again, I have to
8 apologize. I didn't pick it up the first time around
9 as those reading this, "Oh, that's kind of
10 interesting."

11 MR. DEHMEL: Yes, Jean-Claude Dehmel.
12 Yes, it was accepted that the manual isolation option
13 was accepted as being essentially suitable way of
14 terminating this postulated accident

15 MEMBER STETKAR: Okay. Thanks.

16 CHAIR CORRADINI: Other questions? Thank
17 you very much. I think we're running ahead but I
18 would like to continue and start Chapter 17 if we
19 could from GEH before lunch.

20 MR. MISENHIMER: And then we can follow
21 after.

22 CHAIR CORRADINI: Well, it depends.
23 Let's see how it goes.

24 MS. CUBBAGE: I have already contacted
25 Todd and he's on his way.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Amy is organized.

2 MS. CUBBAGE: Right. We are going to do
3 our best to pull everything forward to the extent
4 that staff are available and reachable.

5 CHAIR CORRADINI: And if they're not,
6 we'll just break early for lunch.

7 MS. CUBBAGE: Great. Thank you.

8 CHAIR CORRADINI: Thank you very much.
9 The next team is up.

10 MR. DOUGHERTY: I'm Lee Dougherty with
11 GEH Licensing. I'm going to talk about Chapter 17.
12 17.1 through 3 didn't have any open issues so Gary
13 Miller is going to talk about 17.4, the Reliability
14 Assurance Program.

15 MR. MILLER: Good morning. I'm Gary
16 Miller. I'm the technical lead for PRA for the
17 ESBWR. As Lee said, I will talk through the open
18 item on Section 17.4. There was one item from the
19 2007 SER with open items. It was a request for GEH
20 to provide a list of structure systems and components
21 or, as we say, SSCs, within the scope of the Design
22 for Liability Assurance Program.

23 The open items itself was basically GEH
24 at that point in time said they would provide a list
25 of risk significant components at a later point in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time due to the early development of the PRA itself.

2 This request was actually to provide the list at
3 this phase of the Design Reliability Assurance
4 Program.

5 What I'm going to talk about now is the
6 SSCs that are in the scope of the design phase of the
7 Reliability Assurance Program for the ESBWR and it
8 consist of two major elements and a little bit of
9 overlap but the items that are in the D-RAP are all
10 of the RTNSS structure systems and components so
11 those will be carried on.

12 As well as that there are the risk-
13 significant structure systems and components that
14 were identified in a separate report and that is our
15 NEDO-33411 report and Rev. 2 of that which reflects
16 Rev. 5 of our PRA has been submitted to the NRC to
17 satisfy the request.

18 As I said, the written SSCs, the one
19 portion of it, and that is addressed in DCD Appendix
20 19A and the SER Chapter 22 which we will discuss this
21 afternoon. The remaining portion is the risk-
22 significant SSCs and I would like to walk through a
23 bit of the methodology to give you a background on
24 that.

25 To identify risk significant components

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that would go into the Reliability Assurance Program
2 which would then in the operations phase go into the
3 maintenance rule, we started with a risk ranking
4 similar to what you do in the maintenance rule. The
5 criteria that we used to start off with were for our
6 basic events.

7 Anything with a Fussell-Vesely ranking of
8 greater than .01, greater than or equal to, and a
9 Risk Achievement Worth of greater than or equal to
10 five for individual components or greater than or
11 equal to 50 for common cause failures. That was one
12 of the criteria that we used.

13 MEMBER STETKAR: Gary, let's stop you
14 there. This is going to be telegraphing to the
15 staff, perhaps more a question for them than you.
16 Let me characterize it as the normal screening
17 criteria that are used for determining risk
18 significance or Fussell-Vesely importance greater
19 than .005, essentially half the value that you have
20 used, and a Risk Achievement Worth greater than 2, a
21 value of whatever two-fifths is, 40 percent of what
22 you've used.

23 MEMBER STETKAR: I believe it's greater
24 than 20 for common-cause failures, Risk Achievement
25 Worth. How do you justify using values that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 substantially higher than what I'm characterizing for
2 the moment as the normal values because the
3 application of these values obviously would reduce
4 the number of components in your D-RAP list compared
5 to those other criteria.

6 MR. MILLER: Okay. That's a fair
7 question. Those criteria are discussed in Reg Guide
8 1.174 along with a lot of other industry information.

9 MEMBER STETKAR: I don't think those are
10 in 1.174.

11 MR. MILLER: Okay, risk ranking is
12 discussed.

13 MEMBER STETKAR: Risk ranking is in
14 1.174.

15 MR. MILLER: Okay. Those were derived
16 when we developed the maintenance rule in CRF 50-65.

17 Those guidelines were based at the time on the
18 nuclear plants who typically had a core damage
19 frequency between 10 to the minus per year, 10 to the
20 minus 6 per year. Given that they judge that
21 represented a reasonable risk ranking that would
22 capture the risk insights for the current plants.

23 When we applied those criteria as well as
24 the other criteria such as any cutset within the top
25 95 percent of the core damage frequency the problem

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we ran into was that our core damage frequency, as
2 you know, is two orders of magnitude lower than that
3 so we found that the population of risk ranking that
4 made it above the criteria was exceptionally large
5 and from a reasonableness standpoint a lot of
6 components that should have no risk significance at
7 all were making it into there. So, as I
8 said, we looked at Reg Guide 1.174 which stated that
9 the risk ranking criteria they should be related to
10 core damage frequency and the large release frequency
11 and not necessarily be static numbers like that. We
12 used that to go back and create new criteria as you
13 see there.

14 What we did we looked at changes in risk
15 that would give us a change of greater than about one
16 times 10 to the minus seven per year so that would
17 seem to get us -- that is still an order of magnitude
18 less than what is considered significant in Reg Guide
19 174 but that allowed us uncertainty. We
20 conservatively chose 1E-7 per year. We looked at
21 Fussell-Vesely values and Risk Achievement Worth
22 values.

23 CHAIR CORRADINI: So can I just -- since
24 this is not an area that I understand, I just want to
25 understand your thinking process. So you're saying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you came back to these numbers because they
2 corresponded to a change in the delta-CDF of one
3 times 10 to the minus seven? Is that how I
4 understand what you're saying?

5 MR. MILLER: Yes, that would be -- right.

6
7 CHAIR CORRADINI: These were tuned to
8 give you that result.

9 MR. MILLER: Yes, a little bit. It was
10 more of a shift to gauge it at 1E-7 per year. That's
11 right.

12 CONSULTANT KRESS: That's each component?

13 MR. MILLER: Yes.

14 CONSULTANT KRESS: How many components
15 did you end up with?

16 MR. MILLER: In the risk significant
17 components?

18 CONSULTANT KRESS: Yes.

19 MR. MILLER: Give.

20 CONSULTANT KRESS: We usually end up with
21 hundreds.

22 MR. MILLER: It's not hundreds.

23 CONSULTANT KRESS: It's not hundreds?

24 MR. MILLER: It's not hundreds.

25 CONSULTANT KRESS: I'm trying to modify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the one times 10 to the minus seven by the number.

2 MR. MILLER: I don't know. I couldn't
3 tell you. I would have to look it up as to how many
4 components are risk significant.

5 MEMBER STETKAR: A couple follow-on
6 comments or questions. I suspect you are aware that
7 the staff is currently working on efforts to examine,
8 let's say, risk metrics for the new reactors such
9 that it is not at all clear how the specific
10 numerical values in Reg Guide 1.174 may apply for
11 some of the new reactor designs.

12 MR. MILLER: Right.

13 MEMBER STETKAR: You have to be a little
14 bit careful about referring to 1.174 as a reference.

15 MR. MILLER: Okay.

16 MEMBER STETKAR: That's just a comment.
17 How would you respond if I noted that all of the
18 other design centers that are proposing new reactor
19 certified designs are using the criteria that I
20 characterized as the normal criteria you being the
21 outlier?

22 MR. MILLER: I stand by our analysis.

23 MEMBER STETKAR: That part of the
24 question is going to be more for the staff.

25 CHAIR CORRADINI: I understand. You're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just giving me my heads up.

2 MEMBER STETKAR: That's right.

3 CHAIR CORRADINI: Proceed.

4 MR. WACHOWIAK: This is Rick Wachowiak.

5 I participated in the meeting that the staff had a

6 couple weeks back on the risk metrics.

7 CHAIR CORRADINI: Speak a little louder

8 into the bulb, please.

9 MR. WACHOWIAK: Rick Wachowiak. I was at
10 the meeting and the discussion seems to be moving

11 away from numeric metrics and addressing it in a more

12 defense-in-depth manner. That's the way the staff

13 seems to be moving on that. Reg Guide 1.174 is what

14 we have today so that is what we choose to use.

15 MEMBER STETKAR: There is one issue that

16 we run into with these risk metrics that were

17 developed for plants with totally different risk

18 profiles. If you can go into -- there is a thought

19 experiment that I have. Let's say you have a plant

20 that has, let's say, four different safety

21 components.

22 Each component has a failure rate of 10

23 to the minus three and each one can completely

24 mitigate any accident. Essentially you have a 10 to

25 the minus 12 CDF. With one cutset it has all four of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 those components. Every one of them has a Risk
2 Achievement Worth of 1,000 and every one of them has
3 a Fussell-Vesely of one. But are all four of them
4 risk significant?

5 You can explain that out to any number,
6 six, 12, whatever on down the line. With ESBWR one
7 of the things that we tried to do was have a balanced
8 risk profile so that each system is essentially the
9 same level of importance and the number of systems
10 that you would have to fail, the number of components
11 you would have to fail tend to be low.

12 It's not that exact example but intent
13 was for that example. So what we were trying to look
14 for is a way to take the importance measures that
15 were developed for a completely different risk
16 profile and try to apply it to this plant. The
17 method that we chose was one that was there. Using
18 the 10 to the minus seven value seemed reasonable as
19 it was an order of magnitude below what the Reg Guide
20 says.

21 Then the other issue about the outlier is
22 that the other plants have risk profiles that are
23 closer to what the existing fleet has and so that
24 would be the majority of the justification there.

25 MEMBER SHACK: Of course, you used it for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the ABWR, too.

2 MR. WACHOWIAK: Which is closer to the
3 existing fleet at two times 10 to the minus seven.

4 MEMBER STETKAR: You have to be careful
5 that the ABWR DCD does not specify this. The current
6 ABWR COL FSAR application --

7 MEMBER SHACK: No, the ABWR DCD does.

8 MEMBER STETKAR: Couldn't find it
9 anywhere.

10 MEMBER SHACK: They don't say RAW out
11 loud. They say Risk Achievement Worth

12 MEMBER STETKAR: I know it does in the
13 current COL.

14 MR. WACHOWIAK: We struggled with this
15 trying to figure out what is the right measure.

16 MEMBER STETKAR: It is a struggle and I
17 don't want to go into the philosophical discussion of
18 where the risk metrics are going. It's an open issue
19 right now with the staff. There is not closure on
20 that. However, again it is more important for the
21 staff so perhaps we ought to delay this discussion
22 until the staff comes up.

23 If a piece of equipment on Plant X can
24 double the risk if it's failed and that determination
25 is adequate for that plant to say, "This is important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to me," that same piece of equipment if it doubles
2 the risk on the ESBWR is not important to you. That
3 is the concern. That's the concern.

4 As I said, it's more of a discussion for
5 the staff in terms of consistency in what we feel is
6 important or not important across the fleet during
7 the certification process rather than the absolute
8 criteria that you've used whether it's 10 to the
9 minus seven or 10 to the minus two, or 10 to the
10 minus 30 for that matter.

11 MR. MILLER: Right. I understand.

12 MEMBER STETKAR: I just wanted to kind of
13 get your feedback on some of the rationale for the
14 numbers that were used.

15 MEMBER ABDEL-KHALIK: Could you give us
16 an idea about the change in the number of components
17 in going from two to five? You offered that as the
18 justification for this.

19 MR. MILLER: I don't have the statistics
20 on it but what we found was there were a lot of
21 support systems, maybe turbine component cooling
22 water, things from a practical standpoint would not
23 be risk significant with what you find in a typical
24 plant. It got into supporting systems for perhaps
25 HVAC in some areas.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Is that statistic
2 available somewhere that you can just give us an idea
3 what that number is?

4 MR. MILLER: I think we can generate
5 that, the difference between --

6 MEMBER ABDEL-KHALIK: A RAW of two versus
7 five.

8 MR. MILLER: Five, yes. We can provide
9 that information.

10 MEMBER STETKAR: Gary, were you going to
11 discuss anything -- no you're not -- anything about
12 NEDO-33411? I was curious since that is essentially
13 the documentation for both the process and the list
14 of equipment in D-RAP.

15 MR. MILLER: Right.

16 MEMBER STETKAR: I would like to ask you
17 a little bit about that.

18 MR. MILLER: Well, the remaining bullets
19 are all --

20 MEMBER STETKAR: Okay. Let's go through
21 that.

22 MR. MILLER: Okay. All right. The
23 remaining bullets, as I said, have to do with the
24 different elements that we used to determine the risk
25 significance. It was both probabilistic and a bit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 deterministic. The first one we talked about were
2 the risk rankings.

3 The second one we looked at was the
4 Seismic Margins Assessment that was performed. Any
5 equipment that required a HCLPF or High-Confidence,
6 Low Probability of Failure could withstand a safe
7 shutdown earthquake, those items are listed in DCD
8 19.

9 MEMBER STETKAR: It's too warm in here it
10 goes off.

11 MR. MILLER: Okay. Those were included
12 in scope as risk significant. We also added all
13 RTNSS SSCs meaning the Criteria C and D and that was
14 SSCs relied upon to meet the NRC safety goals as well
15 as those relied upon to meet the containment-
16 performance goals so those were included as risk
17 significant.

18 Then we wrapped it up with an expert
19 review process where we looked at operating
20 experience review and insights from the PRA itself,
21 the severe accident insights, and then an integrated
22 perspective of all that information, sort of an
23 overview type review to make sure that other things
24 were considered on our list. That's a very high-
25 level overview of 33411.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: I'm waiting for your
2 response, please.

3 MEMBER STETKAR: Yes. Is 33411 the
4 complete documentation of that process?

5 MR. MILLER: Yes. It does not contain
6 the --

7 MEMBER STETKAR: Let me ask, I read
8 through that and I looked at the list of equipment
9 and I don't know the plant well enough to look at
10 individual components and failure modes in every last
11 system in the plant so I started thinking about a
12 couple of systems that I at least know a little bit
13 about.

14 For example, the balance of plant-chilled
15 water system and the turbine component cooling water
16 system are not listed in the D-RAP list. Okay, there
17 must be some basis for that. The basis can't be the
18 PRA because those systems are not modeled in the PRA
19 so their importance is precisely zero and the risk
20 achievement worth is precisely zero because they are
21 not in there.

22 So that means that the expert panel must
23 have thought about those systems carefully and made a
24 determination about why they are not on the list. I
25 was curious where that deliberation and determination

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is documented because it's certainly not addressed in
2 NEDO-33411.

3 MR. MILLER: Okay.

4 MEMBER STETKAR: I mean, there might be
5 other systems but those are two that come to my mind
6 and they are relatively extensive support systems
7 that don't obviously cool any safety-related
8 equipment but, for example, they do provide cooling
9 for pretty much everything out in the turbine
10 building --

11 MR. MILLER: Right.

12 MEMBER STETKAR: -- which could have some
13 risk significance but I'm not sure. It's not
14 something I can push a button in the PRA and generate
15 a number because they are not in the PRA. They are
16 just not modeled in the PRA.

17 MR. MILLER: We do some modeling of DCCWS
18 in supporting --

19 MEMBER STETKAR: I couldn't find a basic
20 event for it. Rick might help out but I couldn't
21 find one.

22 MR. MILLER: I know we do.

23 MEMBER STETKAR: There is some
24 justification that failures of TCCS as a contributor
25 to initiating events are somehow rolled into the loss

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of feedwater initiating event frequency which is a
2 generic loss of feedwater initiating event frequency
3 that may be derived from plants that don't have
4 DCCWSs but I couldn't find a basic event even for
5 DCCWS in any of the fault trees. I might have missed
6 it. There are a lot of fault trees.

7 MR. WACHOWIAK: You looked in the fault
8 trees, not in the list of cutsets?

9 MEMBER STETKAR: I looked in the fault
10 trees. I mean, I looked at feedwater. I looked at
11 where the usual suspects would be. I might have
12 missed it. There's a lot of pages of fault trees
13 there and it's pretty hard on a PDF file with a word
14 search.

15 My two concerns relative to this is, No.
16 1, the PRA certainly does not include every system in
17 the plant. It never does. It never does. The
18 expert panel -- the purpose of the expert panel is to
19 think about both the results that are visible from
20 the PRA and see whether something that perhaps was
21 below the numerical criterion established might be
22 elevated to substantial importance due to either
23 deterministic considerations, qualitative
24 considerations, engineering judgment. Make the call
25 that it is judged to be important enough that it gets

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 elevated to be included on the D-RAP list for other
2 considerations.

3 He points to the expert panel also as to
4 think about the things that are not in the PRA to see
5 if they are in there. I mean, a good example,
6 indeed, is the lower drywell equipment hatch that the
7 people thought about and said, "Okay, we're going to
8 put it on but certainly not in the PRA."

9 My concern is how was the expert panel
10 educated about what is and is not in the PRA other
11 than looking at cutsets because obviously if it's in
12 a cutset it's there. If it's not in a cutset, you
13 don't know about it. Where is that expert panel
14 deliberation documented such that I can see, "Oh,
15 yeah. The expert panel indeed thought about this
16 system and dismissed it for the following reasons,"
17 rather than, "Yes, indeed, they thought about that
18 drywell hatch and included it." There is a paragraph
19 about that in that NEDO.

20 MR. MILLER: But what you find in the
21 NEDO is that what we included we discussed the things
22 that we did include. We did not discuss the things
23 that we considered and excluded.

24 MEMBER STETKAR: And excluded. The basis
25 for that, that's what I'm missing in the NEDO and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's why I asked you as a lead-in is the NEDO the
2 full documentation of that process or is there a
3 separate expert panel deliberation report or
4 something.

5 MR. MILLER: There is no formal report on
6 that. Again, I believe there was PRA input to the
7 panel. In the case of TCCW we did talk about what
8 was in the PRA as well as the design which had a lot
9 of redundancy and I believe three trains and things
10 like that. Those things went into the thought
11 process.

12 MEMBER STETKAR: It would be nice to see
13 that thought process and have it documented for
14 posterity. The problem is that once things are not
15 included in the list they hardly ever make it onto a
16 list later on if there are other insights that come
17 out because you could say, "All of those really smart
18 people did all of these really good analyses in the
19 design certification and, in fact, the D-RAP list is
20 part of the certified design documentation so there
21 is a lot of incentive not to add things to that list
22 later on.

23 MS. CUBBAGE: When the staff is up we can
24 describe the RAI. There were a number of RAI's that
25 were asked along the lines that you are talking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about.

2 MEMBER SHACK: Just in general, I mean,
3 your expert panel seemed to add very little to the
4 list compared to the experience that one typically
5 has in these lists where the expert panel adds
6 substantially to the list. I mean, I see two items.

7 Either you've got an extraordinary complete PRA or
8 somehow your criteria seem to be a little different
9 than other people.

10 MEMBER STETKAR: Well, the concern is the
11 expert panel. Granted you have the representative
12 from the PRA team on the expert panel. I don't know
13 who that was but in many cases if the experts on the
14 panel are not PRA practitioners or intimately
15 familiar with the PRA, the presumption is that the
16 PRA is complete and, therefore, if something doesn't
17 show up as important in the PRA this is relatively
18 high reliance on the PRA and those numerical metrics
19 and the cutsets to give one confidence that you don't
20 need to concern yourself with that.

21 Sometimes it's difficult for PRA people
22 to actually explicitly say this is not modeled in the
23 PRA so you experts should kind of think about this.
24 In many cases PRA people because they justify the
25 scope and the results of the PRA for a variety of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reasons will say, "Well, yeah, it might not be
2 modeled explicitly but we feel that we have captured
3 it somehow. That is a different thing if I'm just a
4 straight engineer.

5 MR. WACHOWIAK: This is Rick Wachowak. I
6 think what we might be getting into here is a mixture
7 of maintenance rule and D-RAP. Maintenance rule you
8 end up pulling in a lot of those things from the
9 expert panel because the purpose of the maintenance
10 rule is to ensure that the total equipment is
11 maintained appropriately.

12 The D-RAP, the purpose of the D-RAP is to
13 ensure that the reliability of the components in the
14 plant don't degrade below what was put into the
15 initial PRA. That is the purpose of the D-RAP as
16 stated there.

17 If you look at that population the things
18 that aren't modeled in the PRA can't necessarily
19 degrade to the point where they affect the PRA unless
20 it's the passive things and the structures and things
21 like that. It is more PRA centric than the
22 maintenance rule is. The maintenance rule is covered
23 under a different section which is a COL-Applicant
24 section and it needs to be done under maintenance
25 rule guidance. The D-RAP is used as input to that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 expert panel, not the totality of that expert panel.

2 The other thing that is in the ESBWR
3 Section 17 which may not be in some of the other
4 design centers is that we have a commitment for the
5 COL holder. Once their post-construction PRA is
6 complete they have to go back and revalidate the D-
7 RAP list. That is also listed in our DCD. I don't
8 think that's listed in with some of the other DCDs

9 MEMBER STETKAR: I think it might be.

10 MR. WACHOWIAK: The intent there is to go
11 back and make sure that things like when you add a
12 more detailed HRA after the DAC has been completed
13 did that do anything to change your D-RAP list. We
14 wanted to make sure that resolving those things
15 during construction weren't missed.

16 To answer your question, it really is
17 more PRA centric because the purpose of the D-RAP is
18 to make sure that the components that are modeled in
19 the PRA maintain the reliability and availability
20 that was used in the PRA.

21 MEMBER STETKAR: I don't want to drag
22 this too far on.

23 CHAIR CORRADINI: Well --

24 MEMBER STETKAR: Let me just for now say
25 it is not modeled in the PRA, which my contention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 TCCW is not modeled in the PRA. If I can't find a
2 basic event for it, it's not there. By implication
3 that piece of equipment is perfect. It can never
4 fail because if it does fail it would make the PRA
5 results worse. It might be a small numerical
6 contributor but, indeed, it would make risk go up.
7 It would not make risk go down. Right now its
8 availability is 1.0. It's failure rate is 0.0 in the
9 PRA so if the D-RAP list is going to --

10 MR. WACHOWIAK: The consequence is 0.0.

11 COURT REPORTER: Can you say that into
12 the mic, please? I didn't catch it.

13 MR. WACHOWIAK: The consequence is 0.0
14 so, yeah, it could very well be that it has no
15 impact. You're probably right that it might have
16 some impact but the way it's treated is the
17 consequence of that failure has no impact on the PRA.
18 Therefore, it doesn't --

19 MEMBER STETKAR: It's assumed that it has
20 no impact it's not modeled.

21 MR. WACHOWIAK: That's correct.

22 MEMBER STETKAR: And that's the whole
23 point of having the expert panel to say, "Okay, it's
24 not modeled in the PRA. We have assumed that it has
25 no consequences. Expert panel, do you agree with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that based on looking at the cooling loads, looking
2 at what it supports, and a variety of things that
3 perhaps are not captured explicitly in the PRA.

4 MR. MILLER: Including operating
5 experience.

6 MEMBER STETKAR: Including operating
7 experience, including --

8 MR. MILLER: Including redundancy in
9 design, yes.

10 MEMBER STETKAR: What all goes into that
11 process. I would have been quite happy, to be honest
12 with you, if I saw the fact that, indeed, at a
13 certain point the expert panel considered TCCW and
14 recognized the fact that it was not modeled in the
15 PRA, made a determination that it does not belong on
16 a D-RAP list for the following reasons..... At least
17 it's documented and justified. One could argue with
18 the justification at that point but at least it's
19 there for someone to examine.

20 MS. CUBBAGE: I would also just like to
21 offer that the RTNSS process does a thorough
22 evaluation of nonsafety systems, structures, and
23 components. Anything that ends up in RTNSS ends up
24 in D-RAP by default.

25 MEMBER STETKAR: Okay. Amy, I would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reverse it that certainly the D-RAP list if I use the
2 PRA will absolutely identify everything that is on
3 the RTNSS list. However, if something is not in the
4 PRA -- D-RAP and RTNSS to me is the same topic. It's
5 just simply a different licensing issue.

6 MS. CUBBAGE: But there are deterministic
7 mechanisms that yield RTNSS system structures and
8 components and they all end up in RAP regardless of
9 what the PRA says.

10 MEMBER STETKAR: Okay. Well, I don't
11 honestly believe that the TCCW system would rise to
12 the level of risk significance that it would be
13 considered a RTNSS system.

14 MS. CUBBAGE: Right.

15 MEMBER STETKAR: I'm not arguing with
16 your absolutes.

17 CHAIR CORRADINI: But you think it should
18 be part of it.

19 MEMBER STETKAR: I'm not making a
20 judgment. This is not my design. I am questioning
21 the process that was used to determine what SSCs that
22 are not explicitly modeled in the PRA are either
23 included or excluded from the D-RAP list and the
24 basis for that inclusion or exclusion. That's
25 basically what I'm asking about. If something were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 important enough to then trip over the more risk
2 significant criteria for RTNSS, then I would be
3 talking about RTNSS. Right now because this is
4 Chapter 17 I'm only talking about D-RAP.

5 CHAIR CORRADINI: Do you want to carry
6 this on with the staff in front of you or do you have
7 more for this?

8 MEMBER STETKAR: I don't have anything
9 more. No.

10 CHAIR CORRADINI: Let's bring the staff
11 up and continue this discussion.

12 MR. MISENHIMER: Once again my name is
13 Misenhimer. I'm here again. I'll be here for the
14 rest of the afternoon for the other chapters as well.

15 CHAIR CORRADINI: Okay.

16 MR. MISENHIMER: Our lead technical
17 reviewer is Todd Hilsmeier. He's going to focus on
18 Section 17.4 where there were open items with respect
19 to several RAIs. Basically Section 17.4 deals with
20 the reliability assurance programs during the design
21 phase. I'll let Todd take it from here.

22 MR. HILSMEIER: Thank you, David. Do you
23 want to know my background before I start?

24 CHAIR CORRADINI: We trust that you're
25 bona fide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HILSMEIER: Okay. Thank you. This
2 presentation will discuss the staff's review of the
3 list of SSCs within the scope of the reliability
4 assurance programs for the ESBWR.

5 As a little background information in
6 October of 2007 the staff presented the subcommittee
7 its review of Chapter 17, the ESBWR DCD on quality
8 assurance and the staff identified one open item
9 whereby the applicant identified the SSCs within the
10 scope of RAP.

11 In May 2008 the applicant provided NRC
12 with a list of RAP SSCs for review. For ACRS' letter
13 in November 2007 the staff is presenting today
14 through the subcommittee results of our review of the
15 list of RAP SSCs.

16 The RAP SSCs within the Design
17 Certification envelope includes both all RTNSS SSCs
18 identified under DCD Section 19A which was reviewed
19 as part of DCD Chapter 19. Also within the scope of
20 RAP the additional SSCs identified under Licensing
21 Topical Report NEDO-33411. The review of this report
22 will be discussed in the next slide.

23 Because these RAP SSCs are within the
24 design certification envelope, the DC applicant
25 specified a COL information item in Section 17.4 for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the COL applicant to update the list of RAP SSCs with
2 relevant plant specific information.

3 MEMBER STETKAR: Todd, I didn't get a
4 chance to go back. A few minutes ago GEH indicated
5 that there is a COL information item. I understood
6 their discussion to be more comprehensive than what
7 you have cited because this COL information item is
8 pretty standard. It says if you have any plant or
9 site-specific items, typically they are things like,
10 you know, ultimate heat sink cooling water systems,
11 that type of thing.

12 The COL applicant has to evaluate those
13 to determine whether they should be added to the D-
14 RAP list. Is there anything in the COL information
15 items that specifically requires the COL applicant to
16 go back and do a wholesale reevaluation of the D-RAP
17 list at the time of the COL application? That's what
18 I understood GEH to say just a few minutes ago.

19 MR. HILSMEIER: They need to ensure that
20 the RAP, as described in the DCD, is current for
21 their application. They need to reevaluate
22 everything.

23 MEMBER STETKAR: Everything.

24 MR. HILSMEIER: Right. Including
25 updating the essential elements of D-RAP which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 describes the organization that ensures the PRA is
2 consistent with the design constructed plant.

3 Also there is a COL information item that
4 during the design construction phase that they
5 maintain a list of risk-significant SSCs because as a
6 COL applicant develops their state of the art -- I
7 shouldn't use that word because state of the art is
8 controversial but as a COL licensee develops their
9 plant-specific PRA and has it peer reviewed, they may
10 be identifying additional risk-significant SSCs which
11 also need to be included in the RAP.

12 MEMBER STETKAR: So there is that hook
13 that if the COL -- at the time of the COL issuance
14 there is another chance to go reexamine the entire D-
15 RAP list, not just limited to site-specific items
16 that might make it onto the list because of --

17 MR. HILSMEIER: Right. We always need to
18 ask what are we going to do with this list of risk-
19 significant SSCs. If this list was just going to sit
20 on a bookshelf and nothing be done with it, then peer
21 equality is irrelevant. What is going to be done
22 with these risk-significant SSCs that we have
23 acquired is after subjective -- mainly the nonsafety
24 related RAP SSC are subjected to the quality
25 assurance controls.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If they identify new risk-significant
2 SSCs later on in the design instruction phase, they
3 still need to make sure that the QA is controlled.
4 At this point we just want as complete of a list as
5 we can get based on the current quality of the PRA
6 model.

7 MEMBER STETKAR: That's right. It's in
8 principle in the COL's applicant's best interest to
9 have this list as complete at this stage also.
10 That's their business. That is a risk they are
11 taking.

12 MR. HILSMEIER: It prevents them from
13 having to look back.

14 MEMBER STETKAR: I just wanted to make
15 sure that indeed there was that requirement that the
16 COL applicant go back and reevaluate the whole list.

17 MS. CUBBAGE: I just wanted to set the
18 record straight. What the DCD says is the COL
19 information items is that the applicant will identify
20 the site-specific SSC within the scope or RAP.

21 MEMBER STETKAR: See, that's different.
22 That is the only thing that I found.

23 MS. CUBBAGE: That's the applicant item.
24 There may be something else embedded in the
25 commitment that we would have to dig into. I'll look

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to GE to clarify what they are committing to.

2 MEMBER STETKAR: It's a subtlety, Amy,
3 but it's exactly -- I found that and that's what it
4 says on the slide here but that requirement is simply
5 --

6 MS. CUBBAGE: To add --

7 MEMBER STETKAR: -- to add anything from
8 site-specific design features. And, as I said, in
9 practice what we've seen with other design centers is
10 they typically relate to things like ultimate heat
11 sink. If it's a circulating water, perhaps specific
12 configurations of electric power supplies because of
13 interconnections with the switch yard and so forth.

14 They are typically items that the COL
15 applicant says, "This is different in my site-
16 specific design compared to the certified design.
17 Therefore, I will examine this to see whether it
18 should be included in the D-RAP list." I haven't
19 seen people go back and re-examine anything on the
20 certified design D-RAP list and add anything from the
21 certified design to the D-RAP list that was not in
22 the certified design document.

23 I haven't seen that happen and I haven't
24 seen a requirement for anyone to do that. Yet, what
25 I understood GEH to say is that some place there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the requirement to do that. I guess I'm asking where
2 that is.

3 MR. WACHOWIAK: This is Rick Wachowiak.
4 It's under COL Applicant Item 17.4-2. This is for
5 one which is, as you said, add the site specific.
6 17.4-2 is to provide the description of the
7 operational phase of the reliability assurance
8 program which includes the following requirements and
9 there is a list of bullets here.

10 One of them is to establish PRA
11 importance measures, the expert panel process and
12 deterministic methods to determine the site-specific
13 list of SSCs under the scope of the D-RAP which means
14 to go back and after you have your post-construction
15 PRA which includes all modes, all standards endorsed
16 by the Commission one year prior to fuel load, that
17 peer review PRA to go back and use that and
18 revalidate the list including establishing the
19 correct performance -- I'm sorry, importance measures
20 for those and the expert panel process.

21 That is where we see that there. That
22 process needs to be revalidated. Once you've closed
23 out all the DAC and built all the buildings and
24 components that has to be relooked at.

25 MS. CUBBAGE: So what Rick is referring

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to is in Section 17.4-1 of DCD Rev. 7, bulleted list
2 of items under COL Item 17.4-2-A.

3 MEMBER STETKAR: Where is this, Amy?

4 MS. CUBBAGE: Rev. 7, page 17.4-1 which
5 is --

6 MEMBER STETKAR: Page 17.4-1? Oh, okay.
7 Got it.

8 MS. CUBBAGE: 17 of the PDF.

9 MEMBER STETKAR: I can look --

10 MS. CUBBAGE: 16 and 17.

11 MEMBER STETKAR: I can look at that over
12 the break at lunch rather than taking up our time.
13 I've got the Rev.

14 CHAIR CORRADINI: Let's keep on going.

15 MR. HILSMEIER: It's also included
16 indirectly under the first COL information items. I
17 don't have the --

18 MEMBER STETKAR: I'll look at it over
19 lunch. I've got a reference, rather than taking up
20 meeting time here.

21 MR. HILSMEIER: Let me just say this.
22 Under the first COL information item the COL
23 applicants also need to describe their essential
24 elements of D-RAP. Part of the essential elements of
25 D-RAP includes updating the list of risk-significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SSCs.

2 It's not mentioned in there but when we
3 review the COL applicant's FSAR, essential elements
4 of D-RAP, one of the SRP acceptance criteria is to
5 ensure there is a process for updating and
6 maintaining the list of risk-significant SSCs.

7 MEMBER STETKAR: As long as it's not so
8 finely defined as this, to say site and plant
9 specific with the implication that that certified
10 design D-RAP list can be passed through without a re-
11 examination.

12 MR. HILSMEIER: Right.

13 MS. CUBBAGE: Right. The language is in
14 the body of Section 17.4-1 that does expand on the
15 COL Item 1.

16 MEMBER STETKAR: I'll read it over once.

17 Thanks.

18 CHAIR CORRADINI: Right. Why don't we
19 keep on going.

20 MR. HILSMEIER: Next slide, please. The
21 next two slides presents the staff's review of the
22 methodology that was used for identifying the risk-
23 significant RAP SSCs in NEDO-33411. We issued about
24 10 RAIs with some supplemental RAIs on this
25 methodology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The RAIs address such areas as the basis
2 for the risk-importance thresholds used for
3 identifying the risk-significant RAP SSCs in NEDO-
4 33411. Also have them develop basic events in the
5 PRA for use in identifying the RAP SSCs and use of
6 seismic margin analysis in identifying these RAP
7 SSCs.

8 Next slide. The methodology for
9 identifying the risk-significant RAP SSCS in NEDO-
10 33411 includes the use of at-power and shutdown PRAs
11 for internal and external events resulting in core
12 damage and large radiological reduces.

13 Also, the expert panel's consideration of
14 risk insights and assumptions from the PRA and severe
15 accident evaluation and use of the seismic margin
16 analysis, consideration of operating experience, use
17 of the expert panel's review of all information
18 associated with risk-significant determinations.

19 An expert panel also looked at those SSCs
20 that were considered that risk significant to verify
21 that they purely are not risk significant based on
22 the procedures they described. The staff concluded
23 that the methodology used to identify the RAP SSCs is
24 adequate and meets the guidance in SECY-95-132 and
25 SRP Section 17.4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Now, you've had a while
2 to think about it. Here it comes. How does the
3 staff rationalize the fact if we are looking for
4 consistency in the design certification process among
5 all the design centers, how does the staff
6 rationalize the fact that the numerical criteria used
7 for this one particular design center are different,
8 and I don't like the term but I'll use it, less
9 conservative than the criteria applied for all of the
10 other design centers?

11 MR. HILSMEIER: I'm not sure how you
12 define consistency. One can say the fact that we're
13 using risk-important thresholds as long as the design
14 centers are consistent, although ESBWR does use a
15 different threshold criteria.

16 MEMBER STETKAR: If I have a component,
17 I'll call it Component X for Design A, and failure of
18 that Component X if it were unavailable, if that
19 increases the risk from Design A by a factor of
20 2.0001, for Design Center A that component is
21 considered to be risk significant and it's included
22 in that design center's D-RAP list.

23 On the ESBWR if Component Y is
24 unavailable and it increases the risk by -- I'm
25 sorry, 4.99999, it is not considered risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 significant.

2 MR. HILSMEIER: It may not. It depends
3 on the expert panel's deliberation.

4 MEMBER STETKAR: The expert panel later
5 on but just these numerical criteria first.

6 MR. HILSMEIER: I understand.

7 MEMBER STETKAR: In terms of -- I'm not
8 taking issue with the absolute value understand, I
9 want to be very clear, of the numerical criteria or
10 the bases for those absolute values. I am taking
11 issue with the fact that for consistency in the
12 design certification process we do have indeed, this
13 is true, four of the five that are applying the same
14 numerical criteria.

15 MR. HILSMEIER: Right.

16 MEMBER STETKAR: One of the five is not.
17 I would like the staff to explain why that is okay.

18 MEMBER ARMIJO: John, isn't the absolute
19 value really the central issue if you are starting
20 with a very, very low risk to begin with?

21 MEMBER STETKAR: Sam, that --

22 MEMBER ARMIJO: The Deltas it seems
23 pretty reasonable to me --

24 MEMBER STETKAR: We're into the risk
25 metric discussion which I am not going to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: I'm not sure where I am
2 but I'm just trying --

3 MEMBER STETKAR: The fundamental issue of
4 the risk metrics, which is a separate issue.

5 CHAIR CORRADINI: But let me ask you a
6 different question, John. The question I proposed to
7 the staff, if I understood correctly in the
8 discussion with you before, they kind of bugged
9 with those two numbers so that they would come up
10 with a Delta CDF of one 10 to the minus 7. That's
11 what they told us.

12 MEMBER STETKAR: That's what they told
13 us. I don't know where that's documented but that's
14 what they told us.

15 CHAIR CORRADINI: So I guess a question
16 back is if that was an approach here and let's say
17 for the moment that approach is what they did and you
18 guys were aware of that -- you guys were aware of
19 that?

20 MR. HILSMEIER: Right.

21 CHAIR CORRADINI: Okay. How does one
22 rationalize that approach versus another approach?
23 Let's pick another passive plant that one might be
24 looking at. That's your question.

25 MEMBER STETKAR: Well, I'm not going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 differentiate between passive and active but --

2 CHAIR CORRADINI: There is another
3 passive plant design that applies the normal
4 numerical criteria and there are three -- well, I'm
5 sorry, there are two passive plant designs that apply
6 those criteria. ABWR is not considered a passive
7 plant. There is one passive plant design and three
8 nonpassive plant designs. All three of the
9 nonpassive plant designs without getting into
10 specific numbers show substantially lower core damage
11 frequencies than the current operating fleet. I'm
12 not going to split hairs about 10 to the minus five,
13 10 to the minus six down to 10 to the minus 30th
14 because for this discussion those absolute values are
15 not relevant.

16 MEMBER STETKAR: But your question is
17 more of a question of consistency.

18 CHAIR CORRADINI: My question is entirely
19 a question of consistency. If something for Plant X,
20 whether Plant X is a passive design or an active
21 design with 477 redundant trains of equipment, or two
22 redundant trains of equipment, if failure of a piece
23 of equipment increases the risk for that plant by a
24 factor of 2, the designers of that plant have judged
25 that increase in risk is large enough to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 considered risk significant, whatever those words
2 mean.

3 And on the ESBWR the designers of the
4 plant have concluded that if failure of a piece of
5 equipment increases the risk by a factor of 4.99999,
6 that piece of equipment is not risk significant.
7 That is a fundamental difference in terms of relative
8 risk increase across the design centers. We do have
9 a situation where four of them have accepted a
10 consistent notion of relative risk. And it's
11 relative risk, not absolute risk. It's relative
12 risk.

13 MEMBER ARMIJO: You keep saying it but I
14 can't understand it because it's where you are
15 starting from where the relative risk change is of
16 fundamental importance or not important.1

17 MEMBER STETKAR: It's the fundamental
18 notion of risk significance, of risk metrics and risk
19 significance.

20 MR. HILSMEIER: I can say one design
21 center that I'm reviewing, I shouldn't say what
22 design center it is but in reviewing the RAP list and
23 they use the RAW 2 Fussell-Vesely of .005 and they
24 have a very low CDF.

25 I would say the review of that list was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very simple because pretty much every SSC in the PRA
2 was considered risk significant. That provides
3 useful information if you include every SSC in the
4 PRA as risk significant. The RAP is a focus on those
5 SSC which are more risk significant in design and
6 assure those SSC are given quality assurance
7 controls.

8 MEMBER STETKAR: Todd, I'm not arguing
9 about absolute values. I'm questioning consistency
10 across --

11 MS. CUBBAGE: I think we'll have to take
12 this one back and look at what are the acceptance
13 criteria for this particular area. You implied that
14 the others were kind of arm-twisted into something.
15 Basically we have all these applicants. They have
16 proposed something. It's been found acceptable in
17 this regard. We can come back after lunch with
18 additional information.

19 MEMBER STETKAR: That might be the best
20 thing to do.

21 MEMBER SHACK: One of my analogies is
22 when you come to LRF where there is no real
23 definition of a large release, the different design
24 centers have proposed different large releases. The
25 staff has not judged anyone of them to be right but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they have judged all of them to be acceptable so
2 there is no consistency there but within the notion
3 of what is acceptable they have found it.

4 MS. CUBBAGE: Right. That would be an
5 analogy.

6 CHAIR CORRADINI: So are you saying we
7 are in a gray zone of degrees?

8 MEMBER SHACK: It's just that we are not
9 necessarily always consistent. The staff is looking
10 for what is acceptable under the regulations and the
11 Commission policy statements. It doesn't necessarily
12 have to be consistent from design center to design
13 center. LRF is the one where, in fact, the staff has
14 been directed to give up trying to be consistent.

15 MS. CUBBAGE: Right. That's an example
16 where this design center is conservative.

17 MR. HILSMEIER: I would like to present
18 my thought process if you don't mind for why I feel
19 this is --

20 CHAIR CORRADINI: Why don't that be the
21 last word. You get the last word for the first time
22 in history.

23 MEMBER ARMIJO: This is a key slide here.

24 MR. MISENHIMER: Do you want to finish
25 with this and then come back to your slide later?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: Yeah.

2 MR. HILSMEIER: May I present my thought
3 rationale on --

4 Common industry practice for operating
5 reactors which have the CDF range of 10 to the minus
6 4 to minus to the minus 6 uses a Fussell-Vesely of
7 .005 and a RAW threshold of 2. Reg Guide 1.174,
8 Appendix A, and SRP 19.2 Appendix C they state that
9 the thresholds for defining risk significance should
10 be a function of baseline CDF and LRF rather than
11 being fixed for all plants.

12 As such, ESBWR chose the Fussell-Vesely
13 .001 which is consistent with the approved certified
14 ABWR DCD design. They also chose a RAW threshold of
15 5 for single-failure events which, again, is
16 consistent with ABWR DCD design. The RAW threshold
17 of 50 common-cause failure events, the use of this
18 RAW threshold criteria common-cause failure events of
19 50 has a factor of 10 greater than single-failure
20 events which is actually consistent with Reg. Guide
21 1201 which endorses NEI 00-04 for a risk ranking of
22 SSCs under the 10 CFR 50.69 process.

23 Basically in the NEI 00-04 document the
24 RAW threshold for common-cause failure is increased
25 by a factor of 10. This document was heavily

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reviewed by the staff, by the ACRS and accepted.
2 ESBWR used this same increase for consistency. The
3 increase for common-cause failures, the RAW value was
4 increased by a factor of 10 and 5 at 50.

5 Also, the ESBWR threshold criteria
6 coordinates to a risk increase much less than the
7 risk increase associated with threshold criteria for
8 operating plants. Given all this information I
9 cannot say that GEH's methodology is unacceptable.
10 Given the absence of NRC's endorsement of a risk
11 metric I feel this is adequate. This methodology is
12 adequate.

13 There are many different avenues of
14 approaching the definition of risk significance.
15 Until NRC comes out with a risk metric I cannot say
16 this methodology is not acceptable. To me it seems
17 reasonable. If you use a RAW of 2 and Fussell-Vesely
18 .005 almost everybody, many, many points would be
19 unnecessary.

20 You had one comment about the TCCW being
21 modeled --

22 MEMBER STETKAR: Let's wait until after
23 lunch for that because that gets back into the --
24 it's a different topic. It's related but different.
25 It's the expert panel process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR CORRADINI: Let's finish off what
2 you've got here and then we can break for lunch.

3 MR. HILSMEIER: This slide presents the
4 staff's review of the list of risk significant SSCs
5 in NEDO-33411. We issued about 25 RAIs considering
6 the list of SSEs. These RAIs address such areas as
7 requesting certain SSEs be added to RAP and the bases
8 for not including other SSCs.

9 Risk-significant RAP SSCs is provided
10 NEDO-33411. Our review of this list included
11 examination of the risk important measures,
12 consideration of risk insights and assumptions that
13 are documented in the PRA, consideration of system
14 dependencies and SSC subsumed within risk significant
15 human error events, examination of the undeveloped
16 basic events, use of seismic margins analysis.

17 I also compared the list in NEDO-33411
18 with other risk significant lists of other design
19 centers to ensure that we are consistent. Also
20 feedback from the staff that reviewed -- I
21 incorporated feedback from the staff that reviewed
22 Chapter 19 because they are most familiar with the
23 PRA. The staff concludes that the list of RAP SCC is
24 adequate for design certification and meets the
25 guidance in SECY-95-132 SRP Section 1724.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Quickly, in summary the staff concludes
2 that the methodology used to identify the RAP SSCs
3 and the list of RAP SSCs is adequate and meets the
4 guidance of SECY-95-132 and SRP Section 1724. All
5 RAIs associated with NEDO-33411 are resolved.

6 CHAIR CORRADINI: Ask your question.

7 MEMBER STETKAR: Okay. I thought we were
8 going to continue after lunch.

9 CHAIR CORRADINI: I'll give you six
10 minutes.

11 MEMBER STETKAR: Okay. Thank you.

12 CHAIR CORRADINI: No problem.

13 MR. HILSMEIER: I'm really sleepy after
14 lunch.

15 CHAIR CORRADINI: What did you say

16 MR. HILSMEIER: I'm really sleepy after
17 lunch.

18 CHAIR CORRADINI: So you're ready now.

19 MR. HILSMEIER: I eat lunch at 5:00.

20 MEMBER STETKAR: You heard the
21 interchange earlier regarding the expert panel
22 process.

23 MR. HILSMEIER: Right.

24 MEMBER STETKAR: I don't know how to
25 praise this question because I read -- I don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all of the RAIs as you are aware. We don't get all
2 of the RAIs. The concern I have, and I use TTC view
3 and balance of plant chilled water as examples only
4 because they were simple systems that I could
5 understand what they did.

6 I don't know the scope of other systems
7 that are not in the PRA that were either evaluated or
8 not evaluated by the expert panel to make their
9 determination of why they are not on the RAP list.
10 I'm curious about how the staff's review examined
11 that part of the expert panel conclusion process.

12 In other words, that we have assurance
13 that, indeed, the expert panel examined systems that
14 are not explicitly modeled in the PRA and made an
15 active determination that they do not belong on the
16 RAP list for a variety of documented technical
17 reasons.

18 MR. HILSMEIER: That is my biggest
19 concern in reviewing the RAP list. I'm more
20 concerned about what is not on the list than what is
21 on the list. If it's on the list and doesn't belong
22 there, it's conservative.

23 MEMBER STETKAR: Indeed later refinements
24 of the process, different determinations of numerical
25 risk metrics, etc., etc., might find justification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for removing things from the list. You're right.

2 MR. HILSMEIER: Identify all those
3 systems first at the system level that are not on the
4 list and I investigated myself digging into the PRA
5 model and looking at the risk insights, assumptions,
6 and how it's modeled.

7 If I feel that it should belong on the
8 RAP list, I did ask RAI about the TCCW and the
9 balance of plant chill water system. Actually they
10 are modeled -- I believe they are modeled in the PRA
11 at a very high level like an undeveloped event or
12 maybe subsumed within another event. It's been a
13 year and a half or two years ago but I did ask -- I
14 forget the details but I did RAI on those systems.

15 GEH responded to my RAI justification why
16 they are not in RAP and satisfied with that. I
17 looked beyond risk thresholds and Raps to absolute
18 values. One issue is the assumptions within the PRA
19 can impact a RAW value for just train alignment.

20 I found some SSCs were not included
21 because of the assumption of the train alignment
22 being included there. This is a common issue for
23 other design centers, too. I'm very focused on making
24 sure to identify as many systems that I can to ensure
25 that those systems do not belong on the RAP list.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2 CHAIR CORRADINI: So can I just say back
3 what you just said to me? What you're saying is you
4 probably -- well, you used two examples. You did
5 write up RAIs when something based on your judgment
6 ought to have been there and wasn't there you checked
7 why wasn't it there and what was the reason. The
8 justification is buried somewhere in RAI response
9 from whenever you asked it.

10 MR. HILSMEIER: Yes.

11 CHAIR CORRADINI: Okay.

12 MR. HILSMEIER: I would have to go back
13 and look. It's something that I can probably address
14 through a letter, the reason being is because there
15 are various revisions. To talk about my final
16 decision and whether there are some things in RAP or
17 not gets confusing because there are various
18 revisions in the NEDO report, various revisions of
19 the PRA. Also the methodology for the NEDO report
20 changed over its life.

21 MEMBER STETKAR: Oh, it did?

22 MR. HILSMEIER: So what we had is a
23 handful of SSCs that went in RAP and stayed in RAP.
24 It's obvious they are risk significant. The gray
25 area of the SSCs sometimes they were put in and taken

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 out and put back in. My focus was on the end result
2 which is those SSCs are they in RAP or not and why.

3 MEMBER STETKAR: And the key is "and
4 why." At the point that the design is certified we
5 have one tool. It's called the PRA and, indeed, that
6 tool is auditable in the sense unambiguously given
7 enough time determine whether or not something is
8 modeled in the PRA.

9 In other words, is there a basic event
10 that somehow accounts for the failure of a piece of
11 equipment. That is documented. What's in the PRA
12 and the conclusions that derive from the PRA model is
13 something that is indeed documented at this stage of
14 the design certification process.

15 What seems not to be documented is the
16 expert panel's evaluation of everything else in
17 principle and their justification for why something
18 is not on the RAP based on their evaluation. I don't
19 see that.

20 MS. CUBBAGE: GE, could you explain? Do
21 you have the documentation on site for the expert
22 panel?

23 MR. MILLER: Like Todd said, this has all
24 transpired over the past several years. There is
25 nothing I can think of right now. I would have to go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 back and look.

2 MS. CUBBAGE: I mean, the question isn't
3 just what we have on the docket but if you're looking
4 at what supports the life of the plant and the future
5 operational phase, there is additional information
6 that GE would have that is nondocketed information.
7 I don't know if that's what you're getting at.

8 MEMBER STETKAR: I would have hoped when
9 I asked them about that they would have said,
10 "Certainly, we have our backup files and I got the
11 answer no."

12 MS. CUBBAGE: I would just also offer
13 talking about the number of RAIs isn't always that
14 relevant but there were 55 RAIs that Todd asked a
15 number of which were asking us about specific
16 components and the justification for why they were
17 not included in the RAP list.

18 MR. HILSMEIER: And we asked for an
19 expert panel.

20 MEMBER STETKAR: I think a little bit
21 what bothers me is you did ask a lot of questions and
22 as a result of your questions they added things which
23 troubles me a bit about the process. You understand
24 my concerns.

25 MR. HILSMEIER: I was concerned about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that also but it's common amongst the other design
2 centers.

3 MEMBER STETKAR: It's what? I'm sorry?

4 MR. HILSMEIER: Common with the other
5 design centers also.

6 MEMBER STETKAR: Okay.

7 MR. HILSMEIER: Part of the problem is
8 the SRP 17.4 guidance has a lot of parts that are
9 unclear. The SECY-95-132 document which is the basis
10 for RAP there are parts about D-RAP which is very
11 unclear and that led to the SRP 17.4 having unclear
12 parts. Add that to the applicants being confused so
13 as a result the list --

14 MEMBER STETKAR: We have all been.

15 MR. HILSMEIER: Yes, it was evolving. In
16 two RAIs that we were able to communicate to the
17 applicants what we expect of the list. That is why
18 initially the seismic margins analysis was not
19 considered and that's because the way SRP 70.4 is
20 written. Because of the RAIs we require them to
21 consider seismic margins analysis.

22 The ISG 18 that's coming out, hopefully
23 next month, they have one last public meeting on it,
24 all that is clarified. With that ISG we will no
25 longer need to issue RAIs to clarify to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicants what are expectations are.

2 CHAIR CORRADINI: Other questions to Todd
3 so he can go have his lunch or a nap, I'm not sure
4 which. I'm just joking with you.

5 Any questions for Todd? Okay. At this
6 point let's take a break for lunch. Back at 1:15.

7 (Whereupon, at 12:16 p.m. off the record
8 for lunch to reconvene at 1:15 p.m.)
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

6 1:15 p.m.

7 CHAIR CORRADINI: We now want to continue
8 in discussing regulatory treatment of nonsafety
9 systems. I'll turn it over to Gary or Rick or the
10 team and we'll start off.

11 MR. WACHOWIAK: Okay. For the record
12 again, I'm Rick Machowiak from GEH.

13 CHAIR CORRADINI: Can I stop you
14 actually? I'm going to lose a member, I just
15 realized, and I want to tell everybody now that we
16 have all the members sitting here, except for one
17 committee member, there has been a change in schedule
18 for July.

19 We were scheduled to have our next
20 subcommittee meeting on July 12th Monday because
21 there would be a fuels meeting on 5046(b) on Tuesday.

22 That meeting has been postponed so we are planning
23 now to move our subcommittee meeting to Tuesday the
24 13th, the day before the full committee.

25 That allows us not to have a gap so that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 can't go the baseball game and that sort of fun stuff
2 but we actually have to be here so we're going to
3 have it on the 13th, same thing. We are going to be
4 dealing with long-term cooling for the ESBWR since
5 that is a requirement, an SRM from the Commission.

6 Also that will kind of prepare us for the
7 final chapter 6 SERs with no open items later in our
8 subcommittee session. Please write it down. The
9 subcommittee meeting is going to be on the 13th on
10 Tuesday, not on the 12th.

11 MEMBER STETKAR: That's firm.

12 CHAIR CORRADINI: That's firm.

13 MEMBER STETKAR: So we can change travel
14 plans.

15 CHAIR CORRADINI: That's firm.

16 MEMBER ARMIJO: I just made my travel
17 arrangements.

18 CHAIR CORRADINI: I'm sorry.

19 MEMBER ARMIJO: It was mine that got
20 canceled but I didn't know that there was flexibility
21 to move this one up.

22 CHAIR CORRADINI: The meeting powers that
23 be informed me that over lunch so we will comply.

24 MEMBER ARMIJO: I will comply but I won't
25 like it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR CORRADINI: Sorry. I just wanted
2 to make sure before I lost Mike that everybody knew
3 about the change in schedule and then we'll pass it
4 on to Commissioner Brown who is not with us today.

5 Rick, go ahead.

6 MR. WACHOWIAK: All right. As I said,
7 I'm Rick Wachowiak from GEH. I'll do the play-by-
8 play and Gary will do color.

9 The topic for this afternoon is
10 Regulatory Treatment of Non-Safety Systems. In our
11 DCD that's in Chapter 19A and Chapter 22 in the SER
12 so there is a little bit of a disconnect there but
13 they are the same thing.

14 Prior to DCD Rev. 4 we had a meeting on
15 RTNSS. I believe it was in June of 2008. At least
16 that's what my slide said. We covered categorization
17 then and we covered the configuration changes that we
18 needed in the plant then.

19 Our focus since then has been on
20 addressing the correct treatment for RTNSS. The
21 focus in my presentation is on treatment but if you
22 have any questions on categorization just go ahead
23 and bring them up.

24 MEMBER ARMIJO: Just a top-level
25 question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: Okay.

2 MEMBER ARMIJO: Is all the RTNSS
3 equipment now identified?

4 MR. WACHOWIAK: Yes.

5 MEMBER ARMIJO: The staff and GEH are in
6 sync on that?

7 MR. WACHOWIAK: Yes.

8 MEMBER ARMIJO: Okay.

9 MR. WACHOWIAK: Okay. Long list of RAIs
10 here. I'll cover those in most of the presentation
11 pages. I won't read through them here. So the first
12 -- go ahead.

13 MEMBER STETKAR: I'm sorry. On the
14 categorization process there are five criteria that
15 you used: A, B, C, D, E.

16 MR. WACHOWIAK: There are five different
17 sets of requirements that bring things into RTNSS and
18 we call them five different categories.

19 MEMBER STETKAR: Categories. Are they
20 interpreted as mutually exclusive categories? In
21 particular I'll look at RTNSS B which is post-72 hour
22 response. RTNSS C is anything that comes in from the
23 risk-significance issue so it's PRA related.

24 Are they mutually exclusive in the sense
25 that something would be on the list for RTNSS B.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What I'm going for is the quality controls and all of
2 that stuff that would be enhanced, you know, seismic
3 qualification and that sort of stuff. Could there be
4 things that are on the list because of RTNSS C that
5 are also required for post-72 hour response that if
6 we didn't have a PRA, for example, would be on the
7 list for B.

8 MR. WACHOWIAK: Right. The list were
9 generated independently and I know at least at one
10 point in time we had things listed as some things
11 that were overlapped in B and C. I don't know if
12 there are any on the list now.

13 MEMBER STETKAR: I didn't see it. The
14 list seemed to be either A or B or C or D or E.

15 MR. WACHOWIAK: The other thing, though,
16 if you look at when we get into the slide on what the
17 treatment is, if it would be something that goes on
18 for B and C, then you would pick the treatment for B
19 because that is an all-encompassing for C treatment.

20 MEMBER STETKAR: Yeah, I understand but
21 that would only apply if, indeed, the classification
22 showed this was on the list for B and C.

23 MR. WACHOWIAK: It would show up. It
24 would be on the list for B if it met B and that would
25 be the higher category. Do you remember when we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 changed or if we changed them from B and C listed or
2 did it change because the categorization actually
3 changed?

4 MR. MILLER: I think it changed because
5 of the categorization. That's laid out
6 systematically in 19A as well so that we talk about
7 each one separately.

8 MEMBER STETKAR: Yeah, you do. I was
9 just curious because it's hard when you get down into
10 some of the subtle things whether there was overlap
11 or whether --

12 MR. WACHOWIAK: There can be overlap. I
13 don't think they are turned out to be any overlap in
14 the end. I don't remember seeing any on the final
15 -- you have the final list.

16 MEMBER STETKAR: Certainly in the
17 tabulation it simply list a single category for each.

18 MR. WACHOWIAK: I think that's the way it
19 came out. Okay. So one of the issues it was covered
20 by two RAIs and were listed as two open issues in the
21 SER dealt with the seismic criteria using
22 International Building Code version 2003. At the
23 time we had a RTNSS Class B1 and B2 where B1 were
24 those things that affected core cooling, long-term
25 core cooling and B2 was long-term post accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 monitoring and we had two sets of criteria for those
2 two categories.

3 It turns out that when we were done with
4 all the discussions on how we were going to provide
5 the long-term control room habitability cooling and
6 how we were going to deal with the long-term
7 containment cooling or long-term containment pressure
8 with the fans we ended up adding the ancillary diesel
9 generators as we spoke about this morning a little
10 bit in electric power.

11 When we added the ancillary diesel
12 generators we found that it was just more difficult
13 to keep track of the B1 and B2 for the core cooling
14 and the post-accident monitoring so we dropped that
15 idea and this went to a straight Category B where it
16 included everything in there.

17 That made the point about IBC-2003 moot
18 and it turns out that in the document we list
19 anything associated with RTNSS B to be seismic
20 Category I or seismic Category II and those meet the
21 requirements for that.

22 As I said, we had the two categories.
23 This list what they are, core cooling, containment
24 integrity, control room habitability with respect to
25 dose. And then B2 was post-accident monitoring which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 included the springs in the control room long-term
2 and it also included the long-term cooling of the
3 control room. We combined these into one and our new
4 Category B is the union of B1 and B2 from before so
5 there's no difference.

6 So what's the treatment that we have for
7 this? We are required to have redundant functions in
8 RTNSS B. In B those are those things that are
9 required after 72 hours to either perform safety
10 functions or to refill the inventory of safety-
11 related equipment. It acts just like safety-related
12 equipment. The main difference is that it's not
13 needed for 72 hours.

14 That allows for all sorts of different
15 recovery actions and things. It's allowed to be non-
16 safety related because it's not needed for 72 hours.

17 But it doesn't mean it doesn't need to be single
18 failure proof. We have redundant functions, flood
19 and fire protected. We keep these all in buildings
20 that are hurricane and missile protected. We
21 also have an EQ program associated with it so
22 everything in RTNSS B does go into the EQ program.
23 At least seismic Category II for the building and
24 anchorages on these. We do have to identify quality
25 suppliers. They don't necessarily need to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Appendix B suppliers but they do need to be quality
2 suppliers, ISO-9001, something along that line.
3 There needs to be a program.

4 Then the availability controls that we
5 have for these we put in the Availability Control
6 Manual. That's also in Chapter 19A. It looks like a
7 set of tech specs but it's not. It's availability
8 controls.

9 It's similar to what the plants today
10 have now in their Technical Requirements Manual.
11 It's an older control document that has additional
12 surveillance and other availability controls for
13 their equipment. Here we identify in there allotted
14 outage times for equipment and some specific testing
15 requirements for this equipment.

16 Okay. To get back to answering the
17 specific seismic question, we did add Table 19A-3 and
18 listed all of the buildings for the RTNSS B functions
19 and what their seismic category is. As you can see,
20 they are all in either Category I or Category II
21 structures.

22 Any questions about that open issue?

23 MEMBER STETKAR: Yes. Maybe you can help
24 me out.

25 MR. WACHOWIAK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: The fire protection, the
2 diesel driven fire pump is in for RTNSS B. The
3 piping from the pump out to the connections to the
4 fuel pool and the PCC pools are all seismic Category
5 I.

6 MR. WACHOWIAK: That's correct.

7 MEMBER STETKAR: That piping also
8 connects through normally open manual valves to the
9 main fire protection ring header.

10 MR. WACHOWIAK: I don't think that's the
11 case anymore. I think --

12 MEMBER STETKAR: Ah, I didn't have DCD
13 Rev. 7. On DCD Rev. 6 it shows normally open valves
14 into the main ring header from that, you know, the
15 main discharge line.

16 MR. WACHOWIAK: Okay. I see what you're
17 talking about. From the pipes into the main
18 headers --

19 MEMBER STETKAR: In other words --

20 MR. WACHOWIAK: From the pumps into the
21 main headers that's there. Then there's isolated
22 lines that go to the pool. Where it breaks off the
23 main header to go the pool that's isolated with the
24 manual valve. The fire pumps are still fire pumps
25 and need to act like fire pumps.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's what I mean.
2 That valve was normally open in case I have like a
3 fire. It's a good idea not to have somebody go out
4 and have to open that valve.

5 MR. WACHOWIAK: That's right. They are
6 required to be open.

7 MEMBER STETKAR: The question is for a
8 seismic event now your design basis, your .84g or
9 whatever your qualifying stuff is, is that connection
10 -- I'm assuming to make the diesel -- the motor pump,
11 I guess, and for that matter the diesel pump in
12 particular because that's the one that is inherently
13 qualified, available for the pools an operator would
14 need to go close that manual isolation valve because
15 I suspect the rest of the fire protection ring header
16 is not necessarily seismic Category I.

17 MR. WACHOWIAK: The reason that -- that's
18 a good point and I think we'll have to check on it.

19 MEMBER STETKAR: The question is
20 accessibility to that valve and survivability of that
21 interconnection point to ensure that I can establish
22 isolation for that long-term cooling function.

23 MR. WACHOWIAK: Right. So the reason
24 that the diesel fire pump is seismic Category I is an
25 NFPA requirement. It's not a RTNSS requirement for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that to be Category I. That's why those things are
2 Category I on that list so it's expected that diesel
3 fire pump and the tank and all the piping that's
4 associated with it would survive the seismic event.
5 That is the reason it's set up that way.

6 The particular valve that you're talking
7 about I'm not sure if that valve is located inside
8 the fire pump enclosure. If it is, it's in a seismic
9 Category I structure and it would be protected. The
10 only other place that it would be located is outside
11 in the yard and outside in the yard isn't necessary
12 subject to an issue with the seismic event or to
13 accessibility in this case. I would expect that
14 valve would be placed inside the fire pump enclosure,
15 though.

16 MEMBER STETKAR: I'm not sure. I can't
17 read the drawing that I've printed out here.

18 MR. WACHOWIAK: It's a simplified P&ID.

19 MEMBER STETKAR: It's a simplified P&ID
20 but it has little dotted lines on it and I can't read
21 what's inside the dotted lines at the moment.

22 CHAIR CORRADINI: Can I do that for you?

23 MEMBER STETKAR: No. But, indeed, the
24 valve is at the boundary on the dotted line so the
25 question -- I don't know. It may be in the yard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WACHOWIAK: So either one of those
2 two places I would consider accessible in a seismic
3 event. It's also a requirement and would need to be
4 accessible because under the EQ program the equipment
5 needs to be able to operate in the environment that
6 it's subject to so accessibility --

7 MEMBER STETKAR: My basic question was to
8 make sure that I understood where those lines were
9 and where that valve was and whether its
10 accessibility after the seismic event would be
11 considered.

12 MR. WACHOWIAK: Once again you get to a
13 point where when we make the decision of what goes
14 into RTNSS and what doesn't that is somewhat subject
15 to our choice because we have other things that could
16 have performed these same functions. We chose this
17 diesel power pump to do that function because it
18 already was seismic Category I and was designed to
19 the right standards for that treatment.

20 MEMBER STETKAR: I'm not arguing about
21 the selection. Given the fact that you have made
22 that determination, I wanted to make sure that it
23 indeed is available.

24 MR. WACHOWIAK: Right. All right. The
25 next issue that we had was that there was a confusion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about how we treated support systems in RTNSS area.
2 We had three designations at our table back in Rev.
3 whatever it was, Rev. 4 I believe, that were listed
4 as high regulatory oversight which implied technical
5 specifications for available controls, low regulatory
6 oversight which essentially pointed to the available
7 controls manual for available controls, and then we
8 had something listed as support systems.

9 There was no discussion about what do you
10 do with support. We have since clarified that
11 everything that was in support, or in support of LRO
12 equipment, and it all had LRO treatment. DCD Rev. 7
13 now explicitly states what the treatment is on all
14 the support systems so the ambiguity is gone.

15 Just to cover what the treatment is for
16 RTNSS C, in RTNSS C are the things that were brought
17 into RTNSS to address the probabilistic concerns, the
18 things needed to keep the CDF within the Commission's
19 goals.

20 We have redundant active components
21 similar to what was for the RTNSS B, flood and fire
22 protected, hurricane, Category V missile protection,
23 design for accident environment. We have quality
24 suppliers. Technical specifications.

25 If it's absolutely needed to meet the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 goals using the mean values like EPRI suggested in
2 their resolution to the RTNSS issue that created the
3 Category C category and for other things that we have
4 we put in availability controls for, those are the
5 ones that are in RTNSS to address uncertainty issues.

6 It says here Availability Control Manual
7 for front-line systems. For support systems we use
8 maintenance rule monitoring as the availability
9 controls for it. Two exceptions now to that, our
10 diesel engines. Those are treated like a front-line
11 system even though they are just a support system so
12 the diesels are treated with available control manual
13 explicit entries, treated like a front-line system.

14 I think I've got some examples here of
15 these. RTNSS A which are associated with at-risk
16 rule and Station Blackout rule. Those are all --
17 those particular functions are treated with
18 Availability Control Manual. They didn't turn out to
19 be risk significant or significant in the focus PRA.

20 Our RTNSS B, diesel-driven fire pump,
21 it's also a ACLCO, which stands for availability
22 control limiting condition for operation. We have
23 the diverse protection system. It's one of our
24 diverse control systems for GDCS injection. That
25 particular system was determined from the focus PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to be required to keep the core damage frequency or
2 the large release frequency below 10 to the minus
3 four for CDF, 10 to the minus six for LRF. It
4 requires technical specifications.

5 On the other hand, the DPS function for
6 performing the backup scram does not meet that same
7 threshold. It is not needed to keep the core damage
8 frequency below 10 to the minus 4 through large
9 release frequency below 10 to the minus six using
10 mean values. However, when we consider uncertainty
11 it just barely crossed the line so we would say for
12 things that are associated with uncertainty we treat
13 it with an Availability Control Manual.

14 FAPCS in the LPCI and SPC, that ended up
15 being in for uncertainty and we have availability
16 controls on that. The BiMAC comes in under Category
17 D which is like Category C except it's for the
18 containment performance. It's to essentially keep
19 the containment contribution to protection of a large
20 release at approximately .1 or less. Our BiMAC
21 device does that.

22 You'll notice that we don't have an ACLCO
23 on this one. We just have a description in the
24 Availability Control Manual. That's because it's not
25 something that can be tested while we are on line.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 It has an entry describing its importance and how it
2 is expected to perform. It's mostly like a bases
3 section essentially without any sort of surveillance.

4 CHAIR CORRADINI: There is no
5 surveillance, though, on piping or basemat material
6 or anything?

7 MR. MILLER: There is an ITAAC.

8 MR. WACHOWIAK: The ITACC confirms when
9 we build it and --

10 CHAIR CORRADINI: And that's it.

11 MR. WACHOWIAK: That's it. Okay. We do
12 have some things under E which is the search for
13 adverse system interactions. That is where the
14 failure of a non-safety system could adversely affect
15 a safety-related system. Here it's a little bit of a
16 different case because it's not really -- it's the
17 operation of this system that could be the adverse
18 system interaction.

19 If we turn on the reactor building HVAC
20 post-accident filters and the filter is cracked or
21 bypassed somehow, that is really the failure of that
22 filter. The failure of that filter could cause -- it
23 doesn't cause a failure of any safety-related system
24 but it could cause a release so we put in an
25 availability control on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It is essentially the same as testing
2 stand-by gas treatment charcoal filters. It's like
3 that except it's in the Availability Control Manual.

4 I added one structure there, fire protection water
5 tank. It's no different than other things that I
6 previously said.

7 The next three I have on there were
8 showing the difference between a support system and
9 the diesel generator as a front-line system. You can
10 see the standby diesel generators. They are in RTNSS
11 C because they are needed. Not necessarily needed.
12 They support continued AC power for the FAPCS
13 function. The FAPCS function is RTNSS C. That makes
14 the standby diesel generator RTNSS C as well but we
15 have availability controls, LCOs on those, just like
16 they were a front-line system.

17 Whereas the AC power buses for the
18 ancillary generator or the 6.9 kV PIP buses those are
19 support system and we monitor those under the
20 maintenance rule. Basically anything in RTNSS, as
21 Gary mentioned earlier today, is supposed to be put
22 into the maintenance rule as high-safety significant
23 systems. Therefore, they are monitored for both
24 availability and reliability under the maintenance
25 rule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I think we passed out the entire table
2 that goes along with this 19A-2 if you want to look
3 at more. This is just some loadable features.

4 MEMBER STETKAR: One -- I'll have
5 questions later on on the ACLCOs but you have more
6 presentation and discussion on that. On the list,
7 again, like my failed attempt on the TCCW system, I'm
8 trying to think about things that are not on the list
9 and why they might not be on the list. I think the
10 staff actually asked about one of these. It's kind
11 of a backwards questions, though.

12 The list includes the control room
13 ventilation system. It's not on our slides here but
14 the full list does because it's necessary for post-72
15 hour operation. I think that is the rationale. It
16 also includes -- yes, it's a RTNSS B. It also
17 includes, I believe -- let me just make sure. You
18 know this better than I do, the Q-DCIS. Right?

19 MR. WACHOWIAK: The Q-DCIS is safety
20 related so it wouldn't --

21 MEMBER STETKAR: I'm sorry. That's
22 right. For post-accident monitoring, arguments were
23 made that says beyond 72 hours you need power Q-DCIS.
24 Ancillary diesels are in there for that. It says Q-
25 DCIS has localized cooling from control room

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ventilation system.

2 When I look at the DCD most of the Q-DCIS
3 cabinets are out in other parts of the control
4 building that are not cooled by control room
5 ventilation. They are cooled by the control building
6 general area ventilation system. I was curious in
7 the sense of support systems for post-72 hours or
8 post-accident management functions why the control
9 building general area ventilation system wasn't
10 listed.

11 MR. WACHOWIAK: Okay. There are a couple
12 different things. You are all in the control
13 building, right?

14 MEMBER STETKAR: I'm in the control
15 building. The reactor building is different.

16 MR. WACHOWIAK: The reactor building is
17 different.

18 MEMBER STETKAR: The reactor building is
19 on the list. I don't know why it's on the list but
20 it's on the list.

21 MR. WACHOWIAK: The equipment that is out
22 in the reactor building doesn't really have the same
23 kind of heat generation capability. The Q-DCIS is
24 cooled essentially by the walls and the ground, as we
25 spoke about several weeks ago here, for the first 72

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hours. Then after 72 hours right now we don't know
2 whether or not cooling is going to be required for
3 that equipment. What we had in there was the
4 capability for whatever is providing the cooling to
5 the main control room to supply some duct down to
6 there to provide local cooling to those rooms if
7 needed.

8 MEMBER STETKAR: You remember the words
9 really well.

10 MR. WACHOWIAK: That was going to come
11 from the same chiller unit that is providing the
12 control room habitability area cooling post-72 hours.
13 We are not sure exactly what we need there yet but
14 the provisions are there if we need to put it in.

15 MEMBER STETKAR: I guess if the design
16 hasn't been finalized would it be prudent to add the
17 general area of ventilation at this point?

18 MR. WACHOWIAK: That's not part of the
19 general ventilation area. That is part of the
20 habitability ventilation area. The general
21 ventilation area are some very large blowers that are
22 set up for normal operation for cooling the whole
23 building.

24 MEMBER STETKAR: Now, I'm not a wind-
25 loading guy. The RTNSS B structures, and I guess you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are saying RTNSS C now, are designed for 195 mile an
2 hour five-second gust. The high wind loading
3 requirements for Category I structures are only hit
4 150 miles an hour five-second gust. Look up Table
5 2.0-1.

6 MR. WACHOWIAK: That doesn't sound right.

7 MEMBER STETKAR: I don't know Rev. 7. I
8 just got Rev. 7. Certainly in Rev. 6 I think it's
9 Table 2.0-1 where you have the requirements for
10 buildings. I can look it up quickly. I was curious
11 about whether in Rev. 7 it had changed.

12 MR. WACHOWIAK: Take a quick look there.

13 MEMBER SHACK: The design is the 195
14 three-second gust.

15 MEMBER STETKAR: What design?

16 MEMBER SHACK: For the building.

17 MEMBER STETKAR: No, I didn't go down to
18 3.

19 MS. CUBBAGE: So the siting is more
20 restrictive than the design. Is that what you're
21 saying?

22 MEMBER STETKAR: No, the siting is less
23 restrictive than the design which is okay.

24 MR. WACHOWIAK: The siting would be more
25 restrictive because you could not --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I'm sorry. You're
2 right.

3 MR. WACHOWIAK: We probably ought to take
4 a look at that in Chapter 2.

5 MEMBER STETKAR: You're right. The
6 siting is more restrictive because you couldn't site
7 it if you expected higher than 150-mile-an-hour
8 three-second gust even though the buildings,
9 according to the design, are 195.

10 MS. CUBBAGE: Chapter 2 will be coming
11 over to you shortly to support the August
12 Subcommittee meeting. That would be an appropriate
13 discussion.

14 MEMBER STETKAR: I just wanted to make
15 sure that I understood the differences between those
16 two tables. The 150 is pretty standard across all
17 the design centers and I thought I had remembered
18 that. Sorry. Thanks.

19 MR. WACHOWIAK: Another follow-on issue
20 that we had was that it wasn't clear what the
21 oversight was going to be for some of the equipment.
22 This gets back to the support system not being clear
23 as to what that was. I think originally we just had
24 the HRO LRO and then a discussion in the text as to
25 what was going to be the availability monitoring.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The table you have there, 19A-3, you can see it's
2 listed explicitly where it's covered in tech specs or
3 the Availability Control Manual, or if it's going to
4 be just covered in the maintenance rule. That closed
5 that issue.

6 The next issue it was associated with the
7 bases not being explicit as the level of protection
8 or the level of degradation that you could get to
9 before the system was determined to be not really
10 inoperable because it's the Availability Control
11 Manual but unavailable.

12 We addressed this by in some of the cases
13 we clarified the number of decisions required for the
14 ACLCO. Other ones were designated as it was treated
15 as a single train and we wouldn't necessarily do it
16 on a divisional basis. Essentially we went through
17 and we identified what number of divisions were
18 needed. The other thing that we put into the
19 response was that in any case whenever you have a
20 component failure in one of these systems you enter
21 action A of the ACLCO and you do an availability
22 determination. As we have more experience in the
23 digital control systems as to what is operable or
24 what makes it available versus not and with some of
25 the other systems that you would look at the actual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 capability of the system. Essentially what you are
2 going to do is each time you would have a component
3 failure you would do a capability assessment of the
4 equipment to determine is it available. It's
5 something like a maintenance rule A4 sort of
6 assessment. Here rather than being done prior to
7 entering a new maintenance condition, you would enter
8 it based on a component failure that you would
9 discover. It could determine that the system is
10 still capable of performing its function. Therefore,
11 it's available and you wouldn't be in the ACLCO, or
12 you would determine that it is unavailable and you
13 would be in it.

14 The next open issue was associated with
15 the surveillance requirements for FAPCS. The main
16 issue here was that in the PRA we have in the model
17 that there are two loops of FAPCS but the ACLCO power
18 operating modes only identify one as being required.

19 We go through and we would do the
20 evaluation kind of like an A4 maintenance rule
21 evaluation. If for some reason it looks like it's
22 going to be a risky condition, they would manage the
23 risk through ACLCO 3.0.3 but the cutsets just didn't
24 support adding the second diesel generator into the
25 number of divisions required for this ACLCO.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In the end with all that list there RTNSS
2 was one of the last things to get started on this
3 review of the ESBWR so we probably had the most open
4 items since the last time we spoke but I think we
5 were able to work our way through all of those open
6 items and come to an acceptable conclusion on each of
7 them.

8 MEMBER STETKAR: I'm trying to get my
9 hands around this notion of the PRA justification for
10 both the number of items that are specified in the
11 ACLCO and the -- I don't know what to call it -- what
12 would normally be called the allowed average time,
13 whatever you call it. There are a lot of statements
14 at least in the SER that they are justified based on
15 the PRA.

16 The PRA success criteria requires 6 but
17 it takes credit for all 12. None of them, zero of
18 them have any unavailability due to other than
19 hardware failures. In other words, there is no
20 likelihood that any of them are out of service for
21 maintenance or whatever.

22 MR. WACHOWIAK: I'll try to work
23 backwards through it.

24 MEMBER STETKAR: Tell me about the diesel
25 first. That's easier to kind of get my hands around.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WACHOWIAK: The way that we determine
2 whether or not these things in the C category of
3 RTNSS needed to be there was a little different than
4 if you look in the SECY on how you would determine
5 that something is RTNSS. If you pulled one of those
6 systems out with everything still at the mean value,
7 then it warranted a tech spec LCO. If you take any
8 one of the loops out you don't exceed the goals with
9 the mean values. If you take any one out, it's just
10 borderline if you don't meet it using the uncertainty
11 values. With the uncertainty values you are right up
12 near the limit. You pull the diesel out you're not
13 even close to that because most of the cutsets where
14 you require the FAPCS have some sort of other power
15 supply available. We think that's appropriate
16 because the risk isn't affected that much by taking
17 that one diesel out, at least as much as taking the
18 one FAPCS pump out.

19 MEMBER STETKAR: Okay. I sort of at
20 least understand how it should work.

21 CHAIR CORRADINI: Are you happier now?

22 MEMBER STETKAR: I'm happier. I'm still
23 a bit confused.

24 CHAIR CORRADINI: Should we let staff
25 come up?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Fine. Keep your meeting
2 going.

3 CHAIR CORRADINI: Staff is ready.

4 MR. MISENHIMER: Okay. I'm Dave
5 Misenhimer again. I'm the Chapter PM for Chapter 22
6 which we are going to go over next. Mark Caruso is
7 the lead technical reviewer. He's going to do the
8 presentation and go through the open items.

9 MR. CARUSO: Thank, Dave. I was lead for
10 coordinating this RTNSS review. There were a lot of
11 other people involved. Unfortunately, most of them
12 are not here today. We might get into some things
13 that I probably won't be able to answer questions.

14 This topic we were just discussing, I was
15 going to speak to this but at the end like these open
16 issues I had my structured to track along with Rick
17 but, if you want, we can skip right there and I can
18 make my little speech about this. It should go
19 pretty fast because of the information that was
20 provided was provided by Rick and I just want to
21 comment on why we thought what they told us was
22 incorrect.

23 Slide 3, the agenda is to give you one
24 slide on background, how we got to where we are,
25 where we stand now, and then really go into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discussing the open items that we were left with the
2 last time we talked to you. Rick has gone through
3 those and I'll just talk a little bit about our
4 review and our perspective on it.

5 In 225.16 this was about the oversight of
6 some of the RTNSS equipment. This, again, was a case
7 where we didn't really have a problem with the
8 oversight because they were telling us what it was in
9 the RAI responses. We wanted it in the DCD. They
10 finally committed to put it on the DCD and
11 incorporated Table 1983. The DCDC came in and
12 checked with us all there so we were fine with this.

13 In terms of the definition of available
14 the tech specs are very clear. It's very clear to
15 tell when it's applicable or not. Here there was
16 nothing. It was like it was unavailable. What does
17 that mean? Does that mean it's slight degraded? How
18 do you know when your degradation has made it
19 unavailable?

20 In probing that GE came up with an
21 approach that was satisfactory which was to say,
22 okay, if there is anything wrong with it, you lost
23 surveillance, and there were a number of things added
24 to the ACM to make sure the surveillance has covered
25 all the stuff that could affect availability, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there is anything wrong it, we are going to
2 immediately call it unavailable and go into the
3 action station and follow it and, at the same time,
4 investigate.

5 As Rick said, it may turn out that it
6 wasn't really unavailable or it is but at least for
7 the purpose of knowing what to do, what the LCL
8 really needs, when do I take action and when don't I
9 take action, that was written into the manual as the
10 way to do that so we were happy with that.

11 These things are not based on PRA
12 analysis and deriving them from cutsets and
13 calculations. The most relationship there is between
14 the action times and the PRA is that they have a
15 relationship to the assumptions in the PRA about
16 availability and they are for the most part bounded
17 by those assumptions. That's about it

18 MEMBER STETKAR: Yes, except for the fact
19 I brought up the diesel only because it's one of the
20 few areas that I could actually find some rationale.

21 For example, as I mentioned, both the standby diesel
22 and the ancillary diesel explicitly have maintenance
23 unavailabilities that are nominally equivalent to
24 about 15 days per year. They are in the PRA and they
25 are in a general sense consistent with those times

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and the ACLCO. The ancillary says both must be
2 available and if one is not available, it's a 14-day
3 time.

4 Stand-by diesel says only one has to be
5 available so one can be unavailable infinitely but
6 that's a previous discussion we had with GEH that
7 somehow, somewhere the maintenance rule eventually
8 kicks in and hopefully saves you there.

9 In a lot of other areas, in particular
10 the GDCS deluge valves and there was some discussion
11 about the number, for example, of channels, divisions
12 I think it's called, that must be available for
13 accuation of things like standby liquid control.
14 There are arguments saying only two divisions need to
15 be available. Only six deluge valves needs to be
16 available.

17 The PRA in those cases does not have any
18 quantitative unavailability other than it presumes
19 the equipment is always there. It has the ability to
20 fail to function when one required but it's always
21 there. Unlike the diesels that there is some
22 likelihood that it's not actually there the
23 equivalent of like 15 days out of the year.

24 In many cases for those functions, the
25 deluge valves, and I tried to find it in the I&C,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 there was nothing in the PRA that says it might not
2 be available when demanded. It can fail. I'm not
3 clear at all how the PRA provides any basis
4 whatsoever. It could be 300 days.

5 MR. CARUSO: Yeah, I agree.

6 MEMBER STETKAR: The PRA essentially
7 assumes zero days.

8 MR. CARUSO: In cases where there is an
9 unavailabilities factored into the basic events, I
10 think they try to use that as a guide. In some cases
11 there aren't and you are absolutely right. Here is
12 where, you know, you say we hope the maintenance rule
13 saves us. Well, the maintenance rule is it.

14 Remember, these availability controls all
15 it says is after seven days or after these days, you
16 know, do your best to get it back. It doesn't say if
17 you are unsuccessful. All it really says is if you
18 are not successful, use the maintenance rule.

19 I mean, that statement in there about managed
20 risk for practical purposes for this facility because
21 GE has placed all the RTNSS equipment into the
22 reliability assurance program it automatically is
23 covered by the maintenance rule so whether or not
24 that 303 is in there or not doesn't really matter
25 because they would have to apply A4 of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 maintenance rule and see whether or not it really
2 made a difference with the real PRA, the one that
3 really counts, the one that is there on site.

4 It better have the best information in it. You
5 know, I think what Craig and I feel like, you know,
6 you got to see to be logical to so much debt. You
7 ought to have something in there but they are not
8 that crucial. If the idea is to give the operations
9 people the sense that this stuff has some importance
10 to it and you can't just ignore it. You need to do
11 something.

12 Now, the diesel, you know, I think they
13 basically said, "I need support for this and I don't
14 want to be without support. But if, in fact, I were
15 to lose them both and not have it supported, I
16 already through the PRA found that wasn't a big risk
17 in terms of approaching the safety goals or
18 whatever."

19 My feeling was I didn't really understand
20 that either. I'm not sure I still like it but I'm
21 relying -- you know, it's like I think to myself
22 their PRA that they've done now, you know, what
23 really counts is when that thing really comes out of
24 service, at the time it does, what else is out of
25 service? What is the plant like and what PRA am I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 using then? I sort of said, you know, fine. We
2 accept it. Let's just move on.

3 MEMBER STETKAR: My concern, I hear all
4 of this and I understand it. I think I know how the
5 maintenance rule is going to kick in. I think I
6 understand how the ACM works. My concern as a PRA
7 person and having lived through all of this stuff for
8 years is under your third bullet, staff findings, the
9 sub-bullet says, "Repair times in ACM are reasonable
10 and bounded by assumptions in PRA."

11 MR. CARUSO: When there are assumptions
12 there.

13 MEMBER STETKAR: When, indeed -- well, if
14 there might be some assumptions. But, indeed, that
15 is not a truism. The implications of this is that
16 somehow we have a rational set of times in the ACM
17 that are somehow justified by the PRA which is,
18 indeed, a fabrication.

19 MR. CARUSO: There is another part to
20 rationality here. There's a part that says they've
21 got to do something. They got to fix it. They got
22 to get it back. What are reasonable times? When we
23 did tech specs you look at what is a reasonable time
24 to do it and what is my safety. If it was all
25 safety, you would say, Mark, shut down immediately."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: You're right. Forty
2 years ago, 50 years ago when people were making up
3 the concept of tech specs, people said, "Seven days
4 sounds like a reasonable time to be able to fix a
5 diesel. We'll put that in there. Yeah, you know,
6 three days sounds like a reasonable time." There was
7 no concept of deriving those times based on an
8 assessment of risk. It was reasonable risk. I view
9 the times in the ACM as reasonableness. To say that
10 they are reasonable and bounded by assumptions in the
11 PRA says that there is a risk. I won't call it based
12 and I won't call it informed because those are
13 specific legal terms. There is some risk support for
14 those times when, in fact, there is no.1

15 CHAIR CORRADINI: For some.

16 MEMBER STETKAR: There is none for any of
17 them. The only argument you might make is the
18 ancillary diesels.

19 CHAIR CORRADINI: I will look at the
20 applicant.

21 MEMBER STETKAR: Now, Rick might be able
22 to find other examples where there might be but, for
23 example, if there is no unavailability due to
24 maintenance whatsoever in the risk assessment, then
25 it's presumed that equipment is never unavailable so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 its unavailability due to maintenance is precisely
2 zero. You can't tell me that seven days is bounded
3 by zero.

4 MR. CARUSO: No, and --

5 MEMBER STETKAR: I'm bounded by an
6 assumption of no unavailability. A lot of my
7 problem is this sense that the Availability Control
8 Manual, the list of equipment in -- I'm not arguing
9 with the list of equipment. I'm arguing the bit
10 about the allowed outage times but they are not
11 allowed. The times that are in there are somehow
12 justified by the fact that the PRA provides technical
13 justification for those times. That's what I'm
14 arguing with. Let's just admit and be up front that
15 they're arbitrary and the maintenance rules provides
16 some protection for us that the risk of the plant is
17 going to be managed.

18 MR. CARUSO: If I were building the PRA
19 for the plant that's going to --

20 MEMBER STETKAR: Right.

21 MR. CARUSO: -- I'd be out of this. The
22 Availability Control Manual might be the way to say,
23 "Hey, you know, do I have an availability in for
24 this? I have nothing in there and then I got this
25 thing that is giving me an idea of what's reasonable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Maybe I should put that in. Maybe it could be
2 worked the other way around.

3 MEMBER STETKAR: But the fact of the
4 matter is what was done was done and --

5 MR. CARUSO: That was never done.

6 MEMBER STETKAR: Is does not violate
7 any --

8 MS. CUBBAGE: I would just like to take a
9 step back at why we are even talking about
10 availability controls. I mean, all the safety-
11 related systems are being handled in a manner
12 appropriate with safety regulations. Then we have
13 tech specs that are in accordance with the
14 requirements of 1536 and now we've taken the non-
15 safety systems and we have invented this RTNSS
16 process because there was anxiety about having these
17 non-safety systems that had some importance. The
18 RTNSS policy basically was to try to impose some
19 regulatory oversight to ensure that these systems
20 would be reliable and available when called upon.
21 The ACM is not a specific requirement. It's a
22 proposal that the applicant has put forth consistent
23 with previous passive plants to provide assurance of
24 availability. I think what you're hearing is the
25 logic process that the staff went through in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 determining what these ACMS should look like. Should
2 they look like a tech spec. We acknowledge your
3 comments and --

4 MEMBER STETKAR: I think that process --
5 I'm not arguing. I have no problem. I think it's a
6 wonderful process. The only thing that I'm arguing -
7 - I'm raising a concern about is the staff providing
8 written justification that essentially these times
9 are reasonable because they are bounded by something
10 in in the PRA when that thing is not even in the PRA.

11 MS. CUBBAGE: We acknowledge your
12 comment.

13 MEMBER STETKAR: So be careful about that
14 because you are raising the PRA essentially to a
15 level of technical support which indeed it cannot
16 actually meet.

17 MS. CUBBAGE: Right. We acknowledge your
18 comment.

19 MEMBER STETKAR: There is nothing wrong
20 with that but we can't meet that at this stage.

21 MS. CUBBAGE: Right. I also point out
22 that in the absence of the ACM you would just have
23 maintenance rule and the operating plants only have
24 maintenance rule.

25 MEMBER STETKAR: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: And the active plants only
2 have maintenance rule to provide availability
3 controls for non-safety systems that have importance,
4 perhaps more importance than some of these RTNSS
5 systems.

6 MR. CARUSO: I think in this case in our
7 time to make as much sense as we could out of it and
8 logic out of it was to say kind of like the expert
9 panel in the PRA. When you have some qualitative
10 information you use it to help you guide you in what
11 you should put here. When you don't, you know, you
12 don't and you do the best you can.

13 CHAIR CORRADINI: Did you want to say
14 something?

15 MR. WACHOWIAK: This is Rick Wachowiak.
16 I just wanted to make one comment. I don't know that
17 I would have used the word arbitrary. That seems
18 like --

19 MEMBER STETKAR: It's provocative.

20 MR. WACHOWIAK: -- either too strong or
21 too weak of a word.

22 MEMBER STETKAR: It's provocative.

23 MR. WACHOWIAK: It's a provocative word.
24 It's consistent with the reason why things got into
25 the ACM in the first place which is based on the way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the PRA is put together. For example, not having the
2 one diesel as we explained, why that works out, that
3 is consistent with what's in the PRA and consistent
4 with the way that the PRA was manipulated to give you
5 the list of RTNSS equipment, whether we put it in
6 versus keep it out. We wouldn't want to say that
7 something in the PRA told you that it should be 14
8 days or 13.5 days or something like that. That's
9 probably like knowing the wattage on a battery down
10 to the third, fourth, fifth decimal place.

11 MEMBER STETKAR: I understand that, Rick,
12 and I understand what you did. I know and I'm not
13 arguing at all about 14 days or seven days or three
14 days or whatever. I am concerned that people are
15 justifying and, in particular, the staff is
16 justifying that by making statements like, "It's okay
17 because it's bounded by what is in the PRA."

18 MEMBER ARMIJO: So if those words were
19 just taken out you would be happy?

20 MEMBER STETKAR: Yes.

21 CHAIR CORRADINI: That's what I sensed.

22 MEMBER ARMIJO: The other thing is I want
23 to make sure I understood John. You're not saying
24 that maybe in the ideal world they would be bounded
25 by the PRA in the ideal world.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's a different
2 world.

3 MEMBER ARMIJO: But it isn't our world.

4 MEMBER STETKAR: That's an ideal world
5 that may never occur.

6 MEMBER ARMIJO: It may never occur. I
7 don't think John is arguing that he should be. Just
8 don't make the claim.

9 MEMBER STETKAR: In risk-informed tech
10 spec space that ideal world is brought to fruition.
11 Whether there are ever any risk-informed ACLCOs who
12 know but the fact the matter is we are far from that
13 world right now.

14 CHAIR CORRADINI: Okay. On that note,
15 I'm going to move us along.

16 Mark, do you have anything else to say?

17 MR. CARUSO: Not on this chapter.

18 CHAIR CORRADINI: Okay. Do we have
19 anymore questions for the Committee?

20 MEMBER STETKAR: Yes.

21 CHAIR CORRADINI: You have another one?

22 MEMBER STETKAR: Yes, I do.

23 CHAIR CORRADINI: Okay.

24 MEMBER STETKAR: To get an idea about
25 some of this stuff, you did have questions about one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 part of the process that triggers something into the
2 RTNSS list that we really didn't talk about and that
3 is something could be important to an initiating even
4 frequency. There was some questioning from the staff
5 about loss of preferred power.

6 MR. CARUSO: Yes.

7 MEMBER STETKAR: And the conclusion for
8 that was -- I was going to ask GEH but I got moved
9 along there and I'm going to stop the process of
10 moving me along. The statement was made that grid-
11 related and weather related faults, the external grid
12 and faults that are caused by weather, are certainly
13 beyond the control of the plant operator and that
14 contributions to the loss of preferred power from
15 either switchyard related events or implant faults,
16 which are in principle under the control of the plant
17 operator, are insignificant, do not significantly
18 affect the initiating event frequency. That's a
19 statement. The SER just basically repeats that.

20 I dutifully went back and looked at data
21 and all the data that I can find says that switch-
22 yard related and plant-centered events are a heck of
23 a lot more important than weather-related events and
24 they may be more important than gird-related events,
25 certainly during shutdown modes so I was curious

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about that justification or maybe where the data came
2 from to show that grid-related and weather-related
3 events are by far the predominant cause for loss of
4 preferred power. By implication then nothing under
5 the COL applicant's control or the design would
6 contribute.

7 MR. CARUSO: I think that Marie Pohida
8 came to the same conclusion you did and found the
9 same indicator that you did about this. We went back
10 at the 11th hour and looked at what was the rationale
11 for this here. We went back through whether or not
12 this initiating event, you know, looked at those
13 three questions about whether or not it should
14 precipitate RTNSS equipment. We factored in the fact
15 that this stuff does initiate events. I think we
16 changed the write-up as to -- I can't tell you
17 exactly how it came out but it did come up and we did
18 resolve the issue. I don't know if you remember,
19 Rick. I should be in our SER.

20 MEMBER STETKAR: In the SER what it says
21 is, "In DCD Tier 2 Rev. 7 Section 19A4.3 the
22 applicant stated that the dominant risk contributions
23 in the loss of preferred power event category are
24 from the loss of incoming AC power from the utility
25 grid and weather related faults.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 These faults result from the failure of
2 components that are not controlled by the site
3 organization. Non-safety related SSCs controlled by
4 the site organization such as substations, breakers,
5 motor control centers and protective relays do not
6 significant affect the initiating event frequency.

7 In addition, the applicant noted that a
8 non-safety related emergency AC power system designed
9 to mitigate the effects of a loss of preferred power,
10 i.e., STGs and PIP busses, has RTNSS controls based
11 on other criteria."

12 It basically says that because the
13 diesels are in there you don't need to worry about --
14 if the loss of off-site power frequency was once per
15 year and it was all due to the switchyard failures
16 you wouldn't worry about it.

17 MR. WACHOWIAK: This is Rick again. When
18 we said that it doesn't significantly affect the
19 initiating frequency, I think what we were saying
20 there is it doesn't meet the definition for
21 significance for an initiating event frequency and
22 that is defining that section. Okay.

23 MEMBER STETKAR: It's a different
24 statement than what's in here.

25 MR. WACHOWIAK: The way we addressed the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particular RAI that you were talking about, Mark, was
2 it was unclear for shutdown whether that applied, the
3 at-power statement that we had that said something
4 similar to that. We determined that it did and
5 copied it into the shutdown section so we didn't
6 change that. We just put it every place that it
7 applied.

8 MEMBER STETKAR: The key is in the RAI
9 response is that it doesn't trigger the criteria for
10 RTNSS.

11 MR. WACHOWIAK: It doesn't trigger the
12 criteria for RTNSS. That's correct.

13 MEMBER STETKAR: That's fine. I didn't
14 know whether the staff's determination was based on
15 the statement that those particular causes were
16 insignificant to the overall initiating even
17 frequency which is what I got out of this.

18 MR. WACHOWIAK: No. It's a fraction of
19 the initiating event frequency but it's not a large
20 enough fraction so that piece in itself would meet
21 the RTNSS threshold.

22 MR. CARUSO: At shutdown the landscape
23 changes.

24 MEMBER STETKAR: It can be on the order
25 of about 80 percent event frequency so that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 essentially means the whole initiating event
2 frequency had better be below the RTNSS.

3 MR. WACHOWIAK: I would like to see the
4 report that you're talking about and we can compare
5 that to the one that is used for generating
6 initiating events as well. That whole topic has been
7 evolving.

8 MEMBER STETKAR: Look up just for
9 reference NUREG/CR-6890, Table 3-1. It gives you
10 data from 1997 through 2004. Table 3-5 picks up data
11 in 1986 through 1996.

12 CHAIR CORRADINI: So that's for the
13 record but you guys will converse after, right?

14 MR. WACHOWIAK: I thought that was what
15 we --

16 CHAIR CORRADINI: Other questions?

17 Okay. At this point we'll take a break
18 and we'll take a little bit longer break. We'll
19 convene right on time at 3:15 because we've got to
20 clear the room -- well, we'll come back at 3:15 and
21 bridgeline will be closed. All the members will
22 leave their various appliances in the back because
23 all cell phones will be confiscated.

24 (Whereupon, at 2:48 p.m. the open session
25 was adjourned.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

GE Hitachi Nuclear Energy


ESBWR Chapter 5: Reactor Coolant System and Connected Systems

Advisory Committee on
Reactor Safeguards

Tim Enfinger

Jerry Deaver

June 22, 2010



HITACHI


Introduction

- **Open items from the 2007 SER with Open Items**
 - 26 open items identified in the SER; all resolved
 - Most significant is Open Item 5.4-59
- **Open items of interest from 2007 ACRS chapter 5 meetings**
 - RAI 5.2-70 IASCC effects on reactor internals
 - RAI 5.2-71 & -71 S01; Welding & Grinding on RCPB components
- **Other item of interest**
 - ASME Code Case N-782; applicable ASME Code Edition

Open Issue 5.4-59

Summary from SER:

Provide additional information regarding operation of the reactor water cleanup/shutdown cooling (RWCU/SDC) system during Modes 5 (cold shutdown) and 6 (refueling).



HITACHI

RAI 5.4-59 Decay Heat Removal (DHR)

Response:

- a) Clarified vertical separation of feedwater (return flow) and mid-vessel (supply flow) nozzles and SDC flow path
- b) Clarified DCD discussion of vessel level for SDC function
 - Addresses ESBWR design relative to SIL-357 recommendations
 - Discusses transition between Modes, thermal stratification, and design to limit thermal cyclic fatigue.
- c) Results of RWCU/SDC DHR performance analysis provided
 - Described analytical model for Modes 4 & 5 DHR evaluation
 - Addressed sensitivity of mixing function value to SDC flow rate and cool down time
- d) Clarified information from the shutdown PRA



HITACHI

RAI 5.4-59 DHR (continued)

Conclusion

- Changes resulting from this RAI were incorporated in DCD Revision 6, no additional changes afterward
- Analytically shown to be tolerant of incomplete return flow mixing with respect to cool down time
- Design strategy mitigates cyclic thermal fatigue
- The design permits passive response to mitigate a loss of shutdown cooling



HITACHI

RAI 5.2-70

Summary of RAI:

1. Explain/expand DCD statement to include your plan of mitigating the IGSCC and IASCC of the core shroud
2. Revise the DCD and discuss other mitigating device(s) that you will be using in addressing the IGSCC and IASCC of the core shroud

Response:

DCD subsection 5.2.3.2.2 was modified to acknowledge that IASCC becomes a concern when fluence reaches 5×10^{20} n/cm², and that material hardening and segregation occur. Improvements in water chemistry are beneficial to limit susceptibility to both IGSCC and IASCC.

Prevention measures include material selection, fabrication and process controls, water chemistry controls, and locating welds away from high fluence regions. For the shroud, solution annealing following welding will reduce the effects of cold work and weld residual stresses.

Conclusion:

Effective prevention measures have been identified in the DCD that limit the susceptibility to IGSCC and IASCC to components exposed to Rx water



HITACHI

RAI 5.2-71 & -71 S01

Summary of RAI:

The staff requested that GEH make the following DCD modifications:

1. Describe controls placed on welding operations that minimize the potential for welding defects that would require grinding
2. For those situations where grinding is unavoidable, define methods to be taken to minimize the effects of cold work

Response:

DCD subsections 4.5.2.2 & 5.2.3.4.2 were revised to implement welding controls (thorough cleaning of weld preps, use of protective gas back purge, prohibiting SMAW on root pass, visual exam each weld pass)

DCD subsections 4.5.2.2 and 5.2.3.4.2 were revised to identify controls to limit cold work (limits on hardness, bend radii, and surface finish on ground surfaces); and identify methods to mitigate surface cold work (local or full re-solution annealing, flapping, controlled machining, mechanical polishing or electroplating)

Conclusion:

The DCD now provides controls that will minimize weld defects and contains processes to minimize the effects of grinding when it is necessary



HITACHI

ASME Code Case N-782

- Inquiry: What Code Editions, Addenda, and Cases may be used as an alternative to NCA-1140(a)(2)(a) and NCA-1140 (a)(2)(b)?

{NCA-1140(a)(2) In no case shall the code Edition and Addenda date be established in the Design Spec be earlier Than:

(a) 3 years prior to the date that the Nuclear Power Plant construction permit application is docketed; or

(b) the latest edition and addenda endorsed by the regulatory authority having jurisdiction at the plant site at the time the construction permit application is docketed}

- Reply: It is the opinion of the Committee that as an alternative to NCA-1140(a)(2)(a) and NCA-1140 (a)(2)(b), the following requirements may be used:

(a) The Edition and Addenda endorsed for a design certified or licensed by the regulatory authority

(b) This Case number shall be recorded on the documentation for the item



HITACHI

ASME Code Case N-782 (continued)

- This code case has been incorporated into the ESBWR DCD rev 7 (Table 5.2-1)
- The ASME Code Edition and Addenda will remain the same for all ESBWR plants licensed under the US NRC certification program
- Standardizes the equipment documentation and simplifies closure of ASME related ITAACs
- All ASME code requirements for all applicable equipment will be met

Summary

- All open Chapter 5 items have been resolved
 - Subsection 5.4.6 has been modified as a result of the chapter 6 hydrogen detonation issue
- The design of components exposed to reactor water are now more robust
- In response to operating plant experience, improved fabrication processes and methods are being implemented



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review

Chapter 5 - “Reactor Coolant System and Connected Systems”

Zahira Cruz – Project Manager

Marie Pohida – RAI 5.4-59 Resolution

John Wu – ASME Code Case

June 22, 2010

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 5

Open Item 5.4-59

- To support understanding of shutdown risk, staff requested information on:
 - Minimum vessel level to support RWCU/SDC operation (adequate vessel circulation).
 - Potential for RWCU/SDC flow to bypass the core due to inadequate mixing in the downcomer.

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 5

Open Item 5.4-59 (continued)

- In response to staff RAIs, GEH updated DCD to include:
 - Minimum vessel level to support shutdown cooling core circulation.
 - Discussion on prevention of thermal stratification by maintaining vessel level sufficiently above minimum level.
 - Discussion of mixing within the vessel.

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 5

Open Item 5.4-59 (continued)

- To confirm DCD updates and GEH's simplified calculation for core temperature response, RES performed 3D CFD calculations on RWCU/SDC flows
 - Geometry extracted from GEH supplied model.
 - Model includes:
 - downcomer region
 - space around separators
 - inlet feedwater spargers
 - lower plenum in detail
 - Downflow from separator spillover interacts with horizontal jets from feed water sparger.
 - spargers physically spread the incoming flow
 - flow interaction with separator geometry and spillover flows results in high turbulence generation and mixing
- RAI 5.4-59 is closed

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 5

Section 5.2.1 – Codes and Applicable Code Cases

Regulations and Regulatory Guidance

- General Design Criteria 1
- 10 CFR 50.55a
- Regulatory Guides 1.84, 1.147 and 1.192

Technical Review Summary

- GEH requested to add ASME Code Case N-782 to DCD Tier 2 Table 5.1-2, Applicable Code Cases, in order for ESBWR to be in compliance with requirements of ASME NCA-1140(a)(2).
- Code Case N-782 is not listed in RG 1.84 for NRC acceptance. The use of this Code Case requires the staff approval.
- The request is approved by the staff based on GEH's provided information in accordance with 10 CFR 50.55a(3)(i) and (3)(ii).

Open Items

- None

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 5

Discussion/Committee Questions

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 5

Backup Slide


ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 5

Open Item 5.4-59

- Mass flow from separator spillover (red) is over 10X the mass flow from the spargers (blue) at 8 hrs.
 - The spargers physically spread the incoming flow around the periphery of the vessel.
 - The incoming flow (blue) is swept away by the significantly larger natural circulation flows coming out of the separators (red).
 - Mixing is nearly 100% and bypass is not predicted.



GE Hitachi Nuclear Energy

ESBWR Chapter 8: Electric Power


Advisory Committee on
Reactor Safeguards

Rick Wachowiak

June 22, 2010



HITACHI



Introduction

Single open item from SER with Open Items

- Provide battery loading profile for safety-related 250 VDC batteries for 72-hour operation

Other configuration changes included in Advanced Final SER

- Battery type
- Uninterruptible Power Supply (UPS) configuration
- Ancillary Diesel Generators

Open Item 8.3-52 S03

Summary from the SER:

GEH did not provide the loading profile to demonstrate that the safety-related 250 VDC batteries are sized to meet the design requirement of their connected load for the corresponding time period of 72 hours without the charger's support. Therefore, the staff identified this issue as open for the safety-related 250 VDC system.

Response:

GEH generated a loading profile which was summarized in Table 8.3-3 of the DCD. This table documented the estimated nominal safety-related loads for the 250 VDC Safety-Related Batteries. In addition an ITAAC (Table 2.13.3-3 #3) was added to test the as-built batteries to simulate the analyzed battery design duty cycle.



HITACHI

Open Item 8.3-52 S03

Summary from RAI 8.3-52 S04:

The staff requested additional information related to the GEH response to S03 including battery capacity, charger and rectifier specifications, inverter specifications related to total harmonic distortion and regulating transformer and UPS requirements.

Response:

Table 8.3-4, *Safety-Related DC and UPS Nominal Component Data*, was added to DCD Rev 6 to address these concerns.

Conclusion:

The battery capacity, charger sizing, and inverter sizing are consistent with the DC load profile.

250 VDC Safety-Related Battery Nominal Load Requirements

	DC Power (Watts)							
	Normal	DBA 0-1 min	1-5 min	5-7 min	7-15 min	15-17 min	17-60 min	1-72 hours
Division 1	24697	26259	19618	22118	20501	20618	20501	20501
Division 2	24697	26259	19618	22118	20501	20618	20501	20501
Division 3	22040	23604	23993	26180	24563	24680	24563	24563
Division 4	22040	23604	23993	25805	24188	24305	24188	24188

Calculation Performed To IEEE 485 - 1997

ESBWR Safety Related Battery Type

Changed VRLA to VLA Batteries:

- In 2008, IEEE 535 committee had no plans to incorporate VRLA
- GEH conducted several month exploration of the two technologies
 - Examined four different suppliers with both offerings
 - Evaluation matrix created to aid in selection
 - VLA ranked highest
- Customers expressed concern with VRLA batteries
 - High comfort level with VLA and no experience with VRLA
 - Concerned about lack of regulatory guidance
- DCD rev 6 switched from VRLA to VLA batteries
- Battery qualification is described in NEDE-33516P



HITACHI

ESBWR Uninterruptible Power Supply (UPS)

Safety-related loads are supplied by the UPS

- Not directly from the battery

Each UPS consists of a rectifier and an inverter

- Two in each division
- Each UPS normally carries 50% of the load

Normal power to UPS is from Isolation Power Center bus


Standby power is 250 volt dc from batteries

No safety-related UPS bypass transformers to preclude the potential for disruptive voltages and frequencies to reach safety-related loads



HITACHI

250 VDC / UPS Configuration



HITACHI

Ancillary Diesel Generators (ADG)

Redundant ADGs provide 480 volt ac power post-72-hours


ADGs and support SSCs are seismic Category II and housed in a seismic Category II structure

Not credited in any design basis analysis for first 72 hours following the loss of all other ac power sources

Automatically start on low voltage or low room temperature



ADG Bus Configuration



* Required for RTNSS B



HITACHI

Summary

All open items related to the 250 VDC electrical system are closed and the system meets the regulatory requirements and associated acceptance criteria



HITACHI



United States Nuclear Regulatory Commission

Protecting People and the Environment

Presentation to the ACRS ESBWR Subcommittee

Advanced Final SER for Chapter 8 Electrical Power

Amar Pal – Technical Reviewer
Dennis Galvin – Project Manager

June 22, 2010

ESBWR-CHAPTER 8

- SER with Open Items briefed on October 3, 2007 based on DCD Revision 3
- Discussion
 - Open Item since last meeting with ACRS
 - Load Profile and Battery Sizing
 - Batteries
 - Uninterruptible Power Supply (UPS)
 - Ancillary Diesel Generators
 - Conclusion

ESBWR-CHAPTER 8

- One open item in the SER with Open items.
 - RAI 8.3-52 involved battery sizing
 - Battery Load Profile is provided in DCD
 - GEH provided a summary of the battery sizing calculation.
 - IEEE 485 is used to size the battery (aging factor, temperature correction factor based on lowest electrolyte temperature, margin, battery state of charge factor).
 - RAI 8.3-52 was resolved

ESBWR-CHAPTER 8

- Batteries
 - Batteries were changed from valve regulated lead acid (VRLA) to vented lead acid (VLA) in DCD Revision 6.
 - VLA batteries are used in existing nuclear power plants.
 - Batteries are adequately sized to mitigate accident without charger support for 72 hours.
 - Battery qualification will be demonstrated by type testing per licensing topical report NEDE-33516P.

ESBWR-CHAPTER 8

- Uninterruptible Power Supply (UPS)
 - In the ESBWR, all safety-related load are provided by the UPS
 - UPS consists of a rectifier and an inverter
 - Each division has two UPSs and each UPS normally carry 50% of the load
 - Normal power to UPS is 480 volt from isolation power center (IPC) bus and standby power is 250 volt dc from batteries.

ESBWR –Chapter 8

- Staff was concerned about the effect of voltage transients during islanding mode of operation (RAI 8.2-14).
 - The design includes trip coordination (magnitude and time delay) among input rectifiers, battery chargers, and inverters, so that rectifiers and battery chargers trip first on excessive high voltage so that inverters continue to supply safety-related loads using stored energy from batteries.
 - An ITAAC is provided to verify the trip coordination of safety-related battery chargers and UPS input rectifiers with inverters.
 - ESBWR design has been changed to eliminate the safety-related UPS bypass transformers because of potential for disruptive voltages and frequencies to reach safety-related loads.
 - RAI 8.2-14 was resolved.

ESBWR-CHAPTER 8

- Ancillary Diesel Generators (ADG)
 - ADGs added in DCD Revision 4
 - Two ADGs provide 480 volt ac power to meet post-72-hour power requirements.
 - ADGs and auxiliaries, controls, electrical distribution buses, and fuel tanks are seismic Category II and housed in a seismic Category II structure.
 - ADGs are not required to support safety-related loads for the first 72 hours following the loss of all other ac power sources.
 - An undervoltage condition on ancillary diesel buses or a low ancillary diesel room temperature will start ADG.

ESBWR –Chapter 8

- Ancillary Diesel Generators (Cont'd)
 - ADGs are part of RTNSS program.
 - The availability controls manual requires that two ADGs with fuel tanks, fuel oil transfer pumps and ancillary buses be available during all modes of plant operation.
 - ADGs are started and operated at rated load for one hour every 92 days.
 - ADGs are load tested at rated load for 24 hours every refueling outage.

ESBWR-CHAPTER 8

- Conclusion
 - The applicant has provided sufficient information to demonstrate that the offsite power supply system, onsite ac power supply systems, and onsite dc power supply systems are capable of providing power to support the plant's safe operation satisfying the requirements of GDC 17 and 18 . Additionally, the staff concludes that the ESBWR design is in compliance with 10 CFR 50.63 as they relate to the capability to achieve and maintain hot shutdown in the event of an SBO.

GE Hitachi Nuclear Energy


ESBWR Chapter 11: Radioactive Waste Management

Advisory Committee on
Reactor Safeguards

Tim Enfinger

James Cascone

June 22, 2010



HITACHI

Brief Timeline of DCD Chapter 11

- Revision 3 (Feb 2007) – No P&IDs and Systems Considered Mobile/Conceptual
- Revision 4 (Sept 2007) – P&IDs included, Systems still considered Mobile/Conceptual
- Revision 5 (May 2008) – P&IDs remain, Systems considered permanent and final



HITACHI

Open items from the 2007 SER

- Three open items identified in the 2007 SER with Open Items; all resolved.
- Most significant Open Items were RAIs 11.2-16 & 11.4-18. (Same issue for LWMS & SWMS respectively)
- Third Open Item was RAI 11.4-15. It required including ITAACs for the SWMS into Tier 1.


DCD Subsections and Figures Affected by RAIs 11.2-16 & 11.4-18

- As a result of RAI 11.2-16, DCD Subsections 11.2.2.2 and 11.2.2.3 and Figures 11.2-1a, 1b, 3 and 4 were revised accordingly.
- As a result of RAI 11.4-18, DCD Subsections 11.4.2.2 and 11.4.2.3 and Figures 11.4-2 and 11.4-3 were revised accordingly.




HITACHI

Typical P&ID (Figure 11.2-1a)




HITACHI

Figure 11.2-1a (Collection Tanks)




HITACHI

Figure 11.2-1a (Processing Train)



HITACHI

Figure 11.2-1a (Sample Tanks)



HITACHI

Summary

- Collection and Sample Tanks and Pumps are located on the lower elevation of the Radwaste Building (as these components will be required regardless of the type of processing)
- Processing equipment is modular and is located on the grade elevation of the Radwaste Building
 - Area is served with the Radwaste Building crane to allow for reconfiguration or replacement



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review

Chapter 11

“Radioactive Waste Management”

June 22, 2010

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 11

Purpose

- Brief the Subcommittee on the staff's review of open items for Chapter 11 of the ESBWR DCD application, resolved since last presentation
- Review and closure of open items based on applicant DCD Rev. 7 and RAI responses received from applicant.

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 11

Project and Technical Review Team

- Lead PM
 - David Misenheimer, Project Manager
- Lead Tech. Reviewers
 - George R Cicotte, Sr. Health Physicist
 - Jean-Claude Dehmel, Sr. Health Physicist
 - Chang Li, Sr. Reactor Systems Engineer
 - Hulbert Li, Electronics Engineer

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 11

SER Open Item in 11.2, Liquid Waste Management Systems

- Remaining RAI/Open Item 11.2-16 closed after confirming Rev 4 and 5 updates to DCD
 - Issue: augmentation of information on original design description and configuration - mobile systems
 - Resolution: revised DCD
 - Design relies on permanently installed systems
 - P&ID and description augmented
 - One COL Information Item, contamination minimization
 - No remaining open items in 11.2

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 11

SER Open Item in 11.4, Solid Waste Management Systems

- Open Items (2) closed after confirming Rev 4 and 5 updates to DCD on ITAAC
 - Issue 1: (Open Item 11.4-18) original design description and configuration relied on mobile systems, similar to Open Item 11.2-16
 - Resolution: DCD scope amended
 - Revised design relies on permanently installed systems, P&ID/system descriptions augmented

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 11

SER Open Item in 11.4, Solid Waste Management Systems (cont'd)

- Issue 2: (Open Item 11.4-15) ITAAC consistency with system description changes
- Resolution: DCD revised to amend ITAAC
 - Changes in ITAAC amended to address change from mobile to permanent systems
 - System descriptions/functions augmented to further develop functional description
 - COL Information Items amended/consolidated as 5 items versus previous 12, consistent with other DCD 11.4 revisions
- No remaining open items in 11.4

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 11**

Discussion/Committee Questions

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 11

Key Regulations and Review Guidance

- Part 50.34a, 50.36a, & 50.34(f)(2)
- Part 50, Appendix I Design Objectives
- Part 52.47(b)(1) and 52.80(a)
- Part 20.1301, 20.1302, 20.1406, & Appendix B to Part 20
- Part 50, Appendix A, GDC 3, 60, 61, 63, & 64
- Primary SRP Sections: 11.1, 11.2, 11.3, 11.4, & 11.5
- SRP Section Interface: 2.3, 2.4, 3.2 - 3.7, 3.8, 7.5, 9.2, 9.3, 9.4, 9.5, 10.4, 12.2.2, 13, 14, 16, & 17
- Regulatory Guides 1.11, 1.21, 1.33, 1.52, 1.97, 1.109, 1.110, 1.111, 1.112, 1.113, 1.140, 1.143, 4.15, 8.8, & 8.10
- Industry Standards: AISI, ANS, ANSI, API, ASME, ASTM, NFPA, & TEMA

GE Hitachi Nuclear Energy


ESBWR Section 17.4: Reliability Assurance Program During Design Phase

Advisory Committee on
Reactor Safeguards

Gary Miller

Lee Dougherty

June 22, 2010



HITACHI

Introduction

Open Item from the 2007 SER With Open Items:

17.4-1 List of SSCs within the scope of Design Reliability Assurance Program



HITACHI

Open Item 17.4-1

Summary from SER:

In response to RAI 17.4-1, GEH stated that it will identify a comprehensive list of SSCs within the scope of Design Reliability Assurance Program (D-RAP) at a later phase of development of the D-RAP.

GEH is requested to provide a comprehensive list of SSCs within the scope of D-RAP to the NRC staff so that the NRC staff can complete its review of the ESBWR D-RAP.



HITACHI

Response to Open Item 17.4-1

Response:

SSCs in the scope of D-RAP for ESBWR design certification:

- RTNSS SSCs, and
- Risk-Significant SSCs, as identified in NEDO-33411, “Risk Significance of Structures, Systems and Components For the Design Phase of the ESBWR.”
 - NEDO-33411, Revision 2 has been submitted to the NRC.

Response to Open Item 17.4-1, continued

RTNSS SSCs are addressed in DCD Appendix 19A (SER Chapter 22)

Risk-Significant SSC identification methodology

- PRA basic event Risk Ranking Criteria
 - Fussell-Vesely $\geq .01$
 - Risk Achievement Worth ≥ 5 for Individual Components
 ≥ 50 for Common Cause Failures
- Seismic Margins Assessment Components that require a High Confidence, Low Probability of Failure to withstand the Safe Shutdown Earthquake

Response to Open Item 17.4-1, continued

Additional Risk-Significant SSCs:

- RTNSS SSCs meeting Probabilistic Criteria
 - SSCs relied upon to meet NRC Safety Goals
 - SSCs relied upon to meet containment performance goals
- SSCs Identified in an Expert Review Process
 - Operating Experience Review
 - PRA and Severe Accident Insights
 - Integrated Perspective and Cumulative Effects

Conclusion:

GEH has provided a comprehensive list of SSCs in the scope of D-RAP.

Summary

Open Item 17.4-1 from the 2007 SER has been addressed.



Backup Slide



HITACHI



Presentation to the ACRS Subcommittee

ESBWR Design Certification Application Review

SER Chapter 17
“Quality Assurance”

June 22, 2010

ESBWR DCD Chapter 17

Staff Review Team

- **Project Managers**
 - Amy Cubbage, Lead PM, DNRL/NGE1
 - David Misenhimer, Chapter PM, DNRL/NGE1
- **Technical Staff Presenters**
 - Todd Hilsmeier, DSRA/SPRA

Summary of Technical Discussion for ESBWR DCD Chapter 17

DCD Section		Summary of Discussion
17.4	Reliability Assurance Program during Design Phase	Discussion of staff's review of the list of systems, structures, and components (SSCs) within the scope of the Reliability Assurance Program (RAP)

Section 17.4 – Reliability Assurance Program During Design Phase

Background

- In October 2007, the staff presented to ACRS Subcommittee its review of ESBWR DCD, Chapter 17 (“Quality Assurance”):
 - Staff identified an open item whereby the applicant will identify the SSCs within the scope of the RAP (RAP SSCs)
- By ACRS letter dated November 20, 2007, ACRS planned to review the staff’s resolution of this open item
- In May 2008, the applicant submitted the list of RAP SSCs

Section 17.4 – Reliability Assurance Program During Design Phase

SSCs Within the Scope of RAP

- The RAP SSCs (within the design certification envelop) include:
 - All RTNSS SSCs identified under ESBWR DCD, Tier 2, Section 19A (“Regulatory Treatment of Non-Safety Systems”), which was reviewed as part of ESBWR DCD Chapter 19
 - Additional SSCs identified under Licensing Topical Report NEDO-33411, Revision 2 (“Risk Significance of Structures, Systems and Components for the Design Phase of the ESBWR”)
- ESBWR DCD, Section 17.4 specifies COL Information Item 17.4-1-A:
 - The COL Applicant will identify the SSCs within the scope of the plant-specific RAP to include relevant COL site- and plant-specific information (e.g., the RAP SSCs identified in the DCD, updated using COL site- and plant-specific information)

Section 17.4 – Reliability Assurance Program During Design Phase

Staff's Review of NEDO-33411 – Methodology for Identifying Additional RAP SSCs

- Staff issued about 10 RAIs on the methodology for identifying additional RAP SSCs. These RAIs addressed such areas as:
 - Basis for risk importance thresholds that were used for identifying additional RAP SSCs
 - Use of PRA undeveloped basic events for identifying additional RAP SSCs
 - Use of seismic margins analysis (SMA) in identifying additional RAP SSCs

Section 17.4 – Reliability Assurance Program During Design Phase

Staff's Review of NEDO-33411 – Methodology (continued)

- The methodology for identifying additional RAP SSCs includes the use of probabilistic and deterministic analyses:
 - Use of at-power and shutdown PRAs for internal and external events resulting in core damage and large radiological releases
 - Consideration of risk insights and assumptions from the PRA and severe accident evaluations
 - Insights from the SMA
 - Consideration of operating experience from currently operating reactors
 - Use of an expert panel to review information associated with risk significance determinations
- Staff concludes that the methodology used to identify the RAP SSCs is adequate and meets the guidance in Item E of SECY-95-132 and SRP Section 17.4

Section 17.4 – Reliability Assurance Program During Design Phase

Staff's Review of NEDO-33411 – List of Additional RAP SSCs

- Staff issued about 25 RAIs on the list of additional RAP SSCs. These RAIs addressed such areas as:
 - Inclusion of additional SSCs based on the results, insights, and assumptions from the risk evaluations (e.g., specific SSCs associated with the SLCS, ICS, AC power, GDCS, remote shutdown panel)
 - Bases for not considering some SSCs in the scope of RAP (e.g., SSCs associated with the BOPCWS, CFWS, SLCS electrical heaters)
- The additional RAP SSCs (within the design certification envelop) are identified in Table 6 of NEDO-33411
- Staff concludes that the list of RAP SSCs is adequate and meets the guidance in Item E of SECY-95-132 and SRP Section 17.4

Section 17.4 – Reliability Assurance Program During Design Phase

Summary

- Staff concludes that the methodology used to identify the RAP SSCs is adequate and meets the guidance in Item E of SECY-95-132 and SRP Section 17.4
- Staff concludes that the list of RAP SSCs is adequate and meets the guidance in Item E of SECY-95-132 and SRP Section 17.4
- All RAIs associated with NEDO-33411 and SRP Section 17.4 are resolved

Section 17.4 – Reliability Assurance Program During Design Phase

Discussion/Committee Questions

Backup Slides

Reliability Assurance Program (RAP)

- Purpose of RAP is to ensure:
 - The reactor is designed, constructed, and operated consistent with the risk insights and key assumptions
 - The RAP SSCs do not degrade to an unacceptable level of reliability, availability, or condition during plant operations
 - The frequency of transients that challenge these SSCs is minimized
 - These SSCs will function reliably when challenged
- RAP is implemented in two stages:
 - Design-reliability assurance program (D-RAP) prior to fuel load
 - Use of operational programs to meet the objectives of RAP during operations phase

Backup Slides

Design Reliability Assurance Program

- D-RAP implementation includes:
 - Establishing and applying the essential elements of D-RAP.
These are controls/processes that ensure the risk insights and key assumptions are consistent with the designed and constructed plant, and that the list of RAP SSCs is appropriately developed, maintained, and communicated to the appropriate organizations
 - Subjecting the non-safety-related RAP SSCs to QA controls (Part V, "Nonsafety Related SSC Quality Controls," of SRP Section 17.5)

Backup Slides

Design Reliability Assurance Program

- **DC Applicant's Responsibilities:**
 - Describe the details of the D-RAP (e.g., scope, purpose, objectives, framework, and phases of D-RAP)
 - Establish and apply the essential elements of D-RAP during DC design activities
 - Determine the RAP SSCs (within the scope of the DC) using a combination of probabilistic, deterministic, and other methods of analysis
 - For the non-safety-related RAP SSCs, implement QA controls during DC design activities
 - Propose an D-RAP ITAAC
- **COL Applicant's Responsibilities:**
 - Establish and apply the essential elements of D-RAP during COL design activities
 - Determine the RAP SSCs in the COL's D-RAP by introducing plant-specific information
 - For the non-safety-related RAP SSCs, implement QA controls during COL design activities
 - Propose a process for integrating RAP into operational programs
- **COL Holder's Responsibilities:**
 - Apply the essential elements of D-RAP during COL design and construction activities (which includes updating the list of RAP SSCs as changes are made to the plant-specific design and PRA)
 - For the non-safety-related RAP SSCs, implement QA controls during design and construction activities
 - Complete the D-RAP ITAAC
 - Integrates RAP into operational programs (e.g., maintenance rule, quality assurance, surveillance testing, inservice inspection, inservice testing, and maintenance programs)

ITAAC

Table 3.6-1
ITAAC For The Design Reliability Assurance Program

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. Ensure that the design of systems, structures, and components within the scope of the reliability assurance program (RAP SSCs) is consistent with the risk insights and key assumptions (e.g., SSC design, reliability, and availability).	An analysis will confirm that the design of all RAP SSCs has been completed in accordance with applicable D-RAP activities.	All RAP SSCs have been designed in accordance with the applicable reliability assurance activities for the D-RAP.



GE Hitachi Nuclear Energy

ESBWR Chapter 19A: Regulatory Treatment of Non-Safety Systems

Advisory Committee on
Reactor Safeguards


Rick Wachowiak

Gary Miller

June 22, 2010



HITACHI



Introduction

Prior to DCD rev 4, issues focused on categorization

Presented configuration changes needed to resolve categorization in June 2008

Nine open items in the SER – Focus is on Treatment

- 22.5-6 Seismic category of some RTNSS support systems
- 22.5-7 Use of IBC-2003 criteria for some RTNSS equipment
- 22.5-21 Treatment for systems designated as “Support” in DCD 19A
- 22.5-9 External hazard protection for RTNSS equipment
- 22.5-5 Flood protection for RTNSS equipment
- 22.5-16 Treatment provisions for some RTNSS equipment
- 22.5-22 Instrumentation and bases for ACM entries not clear
- 22.5-23 Number of FAPCS trains required to be available
- 22.5-24 Number of SDG trains required to be available



HITACHI

Open Issues 22.5-6 and 22.5-7

Summary of open items:

- Post-accident monitoring equipment designed using IBC-2003 seismic criteria
- Not clear how these criteria provide adequate protection

Response:

- Reclassified post-accident monitoring equipment to be the same as long-term cooling
- Designed as seismic Category I & II



HITACHI

Changes for Long Term Safety and Seismic

Four functions with two sets of requirements for treatment

- B1 - Core cooling
- B1 - Containment Integrity
- B1 - Control room habitability with respect to dose
- B2 - Post-accident monitoring

Combined so that there is only one set of treatment requirements

- $B = B1 \sqcup B2$

Requirements for B1 now apply to all

RTNSS B Design Treatment

Redundant Functions

Fire and flood protected

Hurricane category 5 missile protection

Designed for accident environment

Seismic Category II

Quality suppliers (not Appendix B)

Availability Controls Manual



HITACHI

Structures Housing RTNSS B Functions

System	RTNSS Criterion	Location	Building Category
FPS Diesel Driven Pump	B	Fire Pump Enclosure	Seismic Cat. I
FPS Motor Driven Pump	B	Fire Pump Enclosure	Seismic Cat. I
FPS to FAPCS Connection	B	Reactor Building	Seismic Cat. I
PARs	B	Containment	Seismic Cat. I
PCCS Vent Fans	B	Containment	Seismic Cat. I
CRHAVS Air Handling Units	B	Control Building	Seismic Cat. I
Emergency Lighting	B	Control Building	Seismic Cat. I
FPS Water Tank	B	Fire Pump Enclosure	Seismic Cat. I
FPS Diesel Fuel Oil Tank	B	Fire Pump Enclosure	Seismic Cat. I
Ancillary Diesel Generators	B	Ancillary DG Building	Seismic Cat. II
Ancillary AC Power Buses	B	Ancillary DG Building	Seismic Cat. II
Ancillary DG Fuel Oil Tank	B	Ancillary DG Building	Seismic Cat. II
Ancillary DG Fuel Oil Transfer Pump	B	Ancillary DG Building	Seismic Cat. II
Ancillary Diesel Building HVAC	B	Ancillary DG Building	Seismic Cat. II
CRHAVS Air Handling Unit auxiliary heaters and coolers	B	Control Building	Seismic Cat. I

DCD Table 19A-3



HITACHI

Open Issue 22.5-21

Summary of open item:

- DCD was not clear concerning treatment of support systems
- Three designations
 - HRO – High Regulatory Oversight
 - LRO – Low Regulatory Oversight
 - Support
- Only HRO and LRO treatment was defined in the DCD

Response:

- Clarified that all “Support” systems received LRO treatment
- Explicitly added treatment for availability controls and external hazard protection for each system

RTNSS C Design Treatment

Redundant active components

Fire and flood protected

Hurricane category 5 missile protection

Designed for accident environment

Quality suppliers (not Appendix B)

Technical Specifications for SSCs Needed to Meet CDF and LRF Goals

Availability Controls Manual for Frontline Systems



HITACHI

RTNSS Functions and Availability Treatment

RTNSS Function	Description	Availability Controls
DPS – ARI Actuation	A - ATWS Rule	ACLCO 3.3.1
FPS Diesel Driven Pump	B - Long Term Core Cooling: RPV At-Power and Spent Fuel Pool; Long Term Containment Integrity	ACLCO 3.7.1
DPS – GDCS Injection	C - Focused PRA (CDF, LRF)High Regulatory Oversight	TS LCO 3.3.8.1
DPS – Scram	C - Focused PRA (CDF, LRF)	ACLCO 3.3.4
FAPCS (LPCI, SPC Modes)	C - Focused PRA (Uncertainty)	ACLCO 3.7.2 ACLCO 3.7.3
BiMAC Device	D - Containment Performance	AC 4.1
Reactor Building HVAC Accident Exhaust Filters	E – Adverse System Interactions	ACLCO 3.7.5
FPS Water Tank	B - Supports core cooling for refill of pools	ACLCO 3.7.1
Ancillary AC Power Buses	B - AC power distribution from Ancillary Diesel Generators to plant loads.	Maintenance Rule
Standby Diesel Generators	C - Supports FAPCS operation	ACLCO 3.8.1 ACLCO 3.8.2
6.9 kV PIP Buses	C - AC power distribution from Standby Diesel Generators to plant loads associated with FAPCS	Maintenance Rule



HITACHI

Excerpts from DCD Table 19A-2

Open Issues 22.5-5 and 22.5-9

Summary of open items:

- Missile protection for non-seismic structures housing RTNSS equipment not provided
- Flood protection for RTNSS equipment not provided


Response:

- Added table 19A-4 to describe external hazard protection applicable to buildings housing RTNSS equipment
- Added ITAAC to confirm hazard protection for RTNSS equipment



HITACHI

Capability of RTNSS Related Structures

System Location	Internal Flooding	External Flooding	Internal Missiles	Extreme Wind and Missiles
Reactor Building Control Building Fuel Building Fire Pump Enclosure Ancillary DG building	The design/ installation of RTNSS equipment includes protection from the effects of internal flooding.	<p>Seismic Category I structures are designed to withstand the flood level and groundwater level specified in Table 2.0-1 and described in Subsection 3.4.1.2. All exterior access openings are above flood level and exterior penetrations below design flood and groundwater levels are appropriately sealed as described in Subsection 3.4.1.1. On-site storage tanks are designed and constructed to minimize the risk of catastrophic failure and are located to allow drainage without damage to site facilities in the event of a tank rupture per Subsection 3.4.1.2.</p> <p>The Ancillary DG Building is designed to withstand external flooding with the same acceptance criteria as a Seismic Category I Structure.</p>	There are no credible sources of internal missiles per Section 3.5.	<p>Seismic Category I structures designed for tornado and extreme wind phenomena are described in Section 3.3 and Subsection 3.5.1.4.</p> <p>The Ancillary DG Building is designed for tornado and Category 5 hurricane wind loads . RTNSS systems in the Ancillary Diesel Building are protected from Category 5 hurricane wind and missiles .</p>
Electric Building Service Water Building Turbine Building	The design/ installation of RTNSS equipment includes protection from the effects of internal flooding.	All exterior access openings are above flood level and exterior penetrations below design flood and groundwater levels are appropriately sealed; basemat and walls are designed for hydrostatic loading, therefore protected from external flooding.	N/A	<p>The EB and SF are RTNSS Structures designed for Category 5 hurricane winds. RTNSS systems in the EB and SF are protected from Category 5 hurricane wind and missiles.</p> <p>The TB structure is designed for tornado and Category 5 hurricane wind loads . The design/installation of the RTNSS systems in the TB includes protection to comply with the requirement of Subsection 19A.8.3 to withstand winds and missiles generated from Category 5 hurricanes.</p>
PSW System located outdoors 	N/A	<p>The design/installation of the RTNSS system includes protection from the effects of flooding.</p> <p>DCD Table 19A-4</p>	N/A	<p>The design/installation of the RTNSS system complies with the requirement of Subsection 19A.8.3 to withstand winds and missiles generated from Category 5 hurricanes.</p>

Open Issue 22.5-16

Summary of open item:

- Details of the oversight for some RTNSS equipment were not apparent

Response:

- Provided revision to Table 19A-3 to specifically identify availability controls and monitoring



HITACHI

Open Issue 22.5-22

Summary of open item:

- Availability controls (AC) did not state the associated instrumentation functions and the number of required divisions in the ACLCOs for some functions
- AC bases do not explicitly state the minimum level of system degradation that corresponds to a function being unavailable, or the number of divisions used to determine the test interval for each required division (or component) for AC Surveillance Requirements (ACSR)

Response:

- Any associated component failure causes entry into action “A” and an availability determination must be made at that time
- Clarified the number of divisions required for each ACLCO



HITACHI

Open Issue 22.5-23

Summary of open item:

- No AC Surveillance Requirements (ACSR) for FAPCS
- PRA assumes two FAPCS loops available, but ACLCO only requires one for modes 1, 2, 3 & 4

Response:

- FAPCS is a normally operating system, so no ACSR is required
- Revised ACLCO to require two loops to be available
 - 14 day ACLCO completion time for one loop unavailable



HITACHI

Open Issue 22.5-24

Summary of open item:

- PRA assumes two standby diesel generators available, but ACLCO only requires one for modes 1, 2, 3 & 4
- Not consistent with FAPCS availability requirements

Response:

- The level of redundancy in the ACLCO is consistent with the risk significance of the standby diesel generators
- ACLCO 3.0.3 requires the licensee to “Assess and Manage the risk of the resulting unit configuration”



HITACHI

Summary

GEH has addressed all open items related to the regulatory treatment of non-safety systems.



Presentation to the ACRS Subcommittee

ESBWR Design Certification Review
Chapter 19A (SER Chapter 22)

Presented by
NRO/DNRL & NRO/DSRA & NRO/DCIP

June 22, 2010

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19A (FSER Chap. 22)

Purpose:

- Brief the Subcommittee on the resolution of open items leading to the FSER for the ESBWR DCD application, Chapter 19A - Regulatory Treatment of Non-Safety Systems (RTNSS)

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19A (FSER Chap. 22)

Outline of Presentation:

- Background
- RAI Status Summary
- Resolution of Significant Open Items

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19

Background

- Prior Subcommittee briefings June and August 2008 on SER with open items
- Full Committee briefed on October 3, 2008
- Interim ACRS letter on Chapters 19 & 22, October 29, 2008 – no specific comments on Chapter 22
 - Committee will review resolution of open items at a future meeting
- Staff response to ACRS letter in November 2008

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (FSER Chap. 22)**

RAI Status Summary:

- All RAIs have been addressed by GEH and responses have been reviewed by staff
- All previous open items have been closed
- FSER drafted for ACRS review

**ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (FSER Chap. 22)**

Key Issues Resolved Since Last Meeting

- Maintaining long-term safety (RTNSS criterion B)
 - Seismic design of RTNSS B SSCs
 - Flood related design
 - High winds related design
- Controlling the availability of RTNSS scope SSCs
 - Technical Specifications
 - Availability Controls Manual (ACM)
 - Assessing and managing risk via the Maintenance program

ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 19A (FSER Chap. 22)

Open Issues 22.5-6 and 22.5-7

- Summary of open items:
 - Post-accident monitoring equipment designed using IBC-2003 seismic criteria
 - Not clear how these criteria provide adequate protection
- GEH Response:
 - Re-classified post-accident monitoring equipment to be the same as long-term cooling
 - Designed as seismic Category I & II
- Staff Findings:
 - Seismic design for long-term safety SSCs now consistent with Commission 's objective for seismic protection of RTNSS SSCs
 - Response acceptable

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-21

- Summary of open items:
 - DCD was not clear concerning treatment category designated “support”
 - Only HRO and LRO treatment was defined in the DCD
- GEH Response:
 - Clarified that all “Support” systems received LRO treatment
- Staff Findings:
 - treatment of “support” SSCs well defined and acceptable
 - Availability of “support” SSCs covered adequately in ACM
 - Response acceptable

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issues 22.5-5 and 22.5-9

- Summary of open items:
 - Missile protection for non-seismic structures housing RTNSS equipment not provided
 - Flood protection for RTNSS equipment not provided
- Response:
 - Added table 19A-4 to describe external hazard protection applicable to buildings housing RTNSS equipment
 - Added ITAAC to confirm hazard protection for RTNSS equipment
- Staff Findings:
 - Design of RTNSS SSCs for protection against the effects for flooding and high winds and associated design criteria adequately described in DCD
 - Design criteria acceptable to staff

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-16

- Summary of open item:
 - Details of the oversight for some RTNSS equipment were not apparent
- Response:
 - Provided revision to Table 19A-3 to specifically identify availability controls and monitoring
- Staff Findings:
 - Treatment of RTNSS SSCs clarified adequately in DCD
 - Response acceptable

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-22

- Summary of open item:
 - Availability controls (AC) did not state the associated instrumentation functions and the number of required divisions in the ACLCOs for some functions
- Response:
 - Clarified the number of divisions required for each ACLCO
- Staff Findings:
 - ACs have been updated where necessary to specify what parts of an SSC and support functions need to be available to satisfy ACLCO
 - Relationship between support system availability and ACLCO now explicitly stated in ACM
 - Response acceptable

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-22

- Summary of open item:
 - AC bases do not explicitly state the minimum level of system degradation that corresponds to a function being unavailable, or the number of divisions used to determine the test interval for each required division (or component) for AC Surveillance Requirements (ACSR)
- Response:
 - Any associated component failure causes entry into action “A” and an availability determination must be made at that time
- Staff Findings:
 - Conditions for entering Action statement well defined in ACM
 - Response acceptable

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-23

- Summary of open item:
 - No AC Surveillance Requirements (ACSR) for FAPCS
 - PRA assumes two FAPCS loops available, but ACLCO only requires one for modes 1, 2, 3 & 4
- Response:
 - FAPCS is a normally operating system, so no ACSR is required
 - Revised ACLCO to require two loops to be available — 14 day ACLCO completion time for one loop unavailable
- Staff Findings:
 - Staff agrees ACSR not needed for SSCs that are normally operating
 - Bases for FAPCS AC clarified in ACM
 - Repair times in ACM are reasonable and bounded by assumptions in PRA

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 19A (FSER Chap. 22)

Open Issue 22.5-24

- Summary of open item:
 - PRA assumes two standby diesel generators available, but ACLCO only requires one for modes 1, 2, 3 & 4
 - Not consistent with FAPCS availability requirements
- Response:
 - The level of redundancy in the ACLCO is consistent with the risk significance of the standby diesel generators
 - ACLCO 3.0.3 requires the licensee to “Assess and Manage the risk of the resulting unit configuration”
- Staff Findings:
 - Response acceptable: ACLCO 3.0.3 in conjunction with the Maintenance Rule section (a)(4) assures the risk of only having one SDG will be assessed using best available PRA model and data

ACRS Subcommittee Presentation
ESBWR Design Certification Review
Chapter 19A (FSER Chap. 22)

- Discussion/Committee Questions