

From: WILLIAMSON, DANNY H [DWILL21@entergy.com]
Sent: Monday, July 12, 2010 8:52 AM
To: Wang, Alan
Subject: RBS Bases markups
Attachments: USAR markup.pdf

Alan

With regard to Mr. Sahay's question on our TS Bases markup, we will revise our Bases Section 3.8.1 to remove the RG 1.108 references from the discussions of SR frequencies being extended from 18 to 24 months.

Concerning RG 1.32 and 1.129, we will revise our Bases Section 3.8.4 to remove the RG 1.32 and 1.129 references from the discussions of SR frequencies being extended to 24 months. Additionally, we will revise the RBS Updated Safety Analysis Report to change our commitment to those RGs with regard to SR frequency. While this change remains to be developed and processed as part of implementation of 24-month operating cycles, attached are the pertinent markup pages from USAR Table 1.8-1 indicating the typical fashion by which this type of change is implemented.

Please let me know if you have any other questions on this matter.

Danny Williamson
Sr. Licensing Specialist

<<USAR markup.pdf>>

E-mail Properties

Mail Envelope Properties (A7C9762EBF7BD843B5B5977D3EE3B4EC083872C6)

Subject: RBS Bases markups
Sent Date: 7/12/2010 8:51:58 AM
Received Date: 7/12/2010 8:51:58 AM
From: WILLIAMSON, DANNY H

Created By: DWILL21@entergy.com

Recipients:
Alan.Wang@nrc.gov (Wang, Alan)
Tracking Status: None

Post Office:

CCTEXETSP006.etrsouth.corp.entergy.com

Files	Size	Date & Time
MESSAGE	41168	7/12/2010
USAR markup.pdf	38293	

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: True

Return Notification: False

Sensitivity: olNormal

Recipients received: