

NUREG/CP-0194  
Volume 3 of 3

EPRI 1020621  
Final Report

# **Methods for Applying Risk Analysis to Fire Scenarios **(MARIAFIRES)-2008****

NRC-RES/EPRI Fire Workshop

Volume 3

Module 3: Fire Analysis

Based on the Joint  
NRC-RES/EPRI Training Workshops  
Conducted in 2008

September 28 – October 2, 2008, and  
November 17-20, 2008, Bethesda, MD

David Stroup  
Felix Gonzalez  
Hugh Woods

U.S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research  
Washington, DC 20555-0001

Electric Power Research Institute  
3420 Hillview Avenue  
Palo Alto, CA 94303

## AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

### NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and *Title 10, Energy*, in the Code of *Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents  
U.S. Government Printing Office  
Mail Stop SSOP  
Washington, DC 20402-0001  
Internet: [bookstore.gpo.gov](http://bookstore.gpo.gov)  
Telephone: 202-512-1800  
Fax: 202-512-2250
2. The National Technical Information Service  
Springfield, VA 22161-0002  
[www.ntis.gov](http://www.ntis.gov)  
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission  
Office of Administration  
Mail, Distribution and Messenger Team  
Washington, DC 20555-0001

E-mail: [DISTRIBUTION@nrc.gov](mailto:DISTRIBUTION@nrc.gov)  
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

### Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, and transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute  
11 West 42<sup>nd</sup> Street  
New York, NY 10036-8002  
[www.ansi.org](http://www.ansi.org)  
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

**DISCLAIMER:** Where the papers in these proceedings have been authored by contractors of the U. S. Government, neither the U.S. Government nor any agency thereof, nor any U.S. employee makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use or the results of such use, of any information, apparatus, product, or process disclosed in these proceedings, or represents that its use by such third party would not infringe privately owned rights. The views expressed in these proceedings are not necessarily those of the U. S. Regulatory Commission.

# **Methods for Applying Risk Analysis to Fire Scenarios (MARIAFIRES)-2008**

NRC-RES/EPRI Fire PRA Workshop

Volume 3 - Module 3: Fire Analysis

**NUREG/CP-0194**

**EPRI 1020621**

## **Final Report**

July 2010

U.S. Nuclear Regulatory Commission  
Office of Nuclear Regulatory Research (RES)  
Washington, DC 20555-0001

U.S. NRC-RES Project Manager  
M. H. Salley

Electric Power Research Institute (EPRI)  
3420 Hillview Avenue  
Palo Alto, CA 94303

EPRI Project Manager  
R. P. Kassawara

## COURSE TRAINING INSTRUCTORS AND PROJECT MANAGERS

Sandia National Laboratories (SNL)  
1515 Eubank SE  
Albuquerque, NM 87185

Steven Nowlen

Mardy Kazarians (Kazarians & Associates)

Frank Wyant

Jeff LaChance

J.S. Hyslop/ Kendra Hill

U.S. NRC-RES Project Managers

Science Applications International Corp. (SAIC)  
1671 Dell Ave, Suite 100  
Campbell, CA 95008

Bijan Najafi

Francisco Joglar-Biloch

Dan Funk (EDAN Engineering)

Richard Anoba (Anoba Consulting Services)

R.P. Kassawara

EPRI Project Manager

## CITATIONS

This report was prepared by:

U.S. Nuclear Regulatory Commission,  
Office of Nuclear Regulatory Research (RES)  
Washington, DC 20555-0001

Principal Investigators:  
D. Stroup  
F. Gonzales

Electric Power Research Institute (EPRI)  
3420 Hillview Avenue  
Palo Alto, CA 94303

Principal Investigator:  
R. Kassawara

This report describes research sponsored jointly by the U.S. Nuclear Regulatory Commission, RES, and EPRI.

The report is a corporate document that should be cited in the literature in the following manner:

*Methods for Applying Risk Analysis to Fire Scenarios (MARIAFIRES), NRC-RES/EPRI Fire PRA Workshop, Volume 3 – Module 3: Fire Analysis*, U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research (RES), Washington, DC 20555-0001, and Electric Power Research Institute (EPRI), Palo Alto, CA, NUREG/CP-0194 and EPRI 1020621.

**NUREG/CP-0194 and EPRI 1020621, Volume 3,  
has been reproduced from the best available copy**

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI NOR ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, OR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

ORGANIZATION THAT PREPARED THIS DOCUMENT:

**U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research**

### **NOTE**

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail [askepri@epri.com](mailto:askepri@epri.com).

Electric Power Research Institute, EPRI, and TOGETHER...SHAPING THE FUTURE OF ELECTRICITY are registered service marks of the Electric Power Research Institute, Inc.



# ABSTRACT

The U.S. Nuclear Regulatory Commission (NRC) approved the risk-informed and performance-based alternative regulation 10 CFR 50.48(c) in July 2004, which allows licensees the option of using fire protection requirements contained in the National Fire Protection Association (NFPA) Standard 805, "Performance Based Standard for Fire Protection for Light-Water Reactor Electric Generating Plants, 2001 Edition," with certain exceptions. To support licensees's use of that option, NRC and the Electric Power Research Institute (EPRI) jointly issued NUREG/CR-6850 (EPRI 1011989) "Fire PRA Methodology for Nuclear Power Facilities," in September 2005. That report documents the state-of-the art methods, tools, and data for conducting a fire probabilistic risk assessment (PRA) in a commercial nuclear power plant (NPP) application. The report is intended to serve the needs of a fire risk analysis team by providing a general framework for conduct of the overall analysis as well as specific recommended practices to address each key aspect of the analysis. Participants from the U.S. nuclear power industry supported demonstration analyses and provided peer review of the program. Methodological issues raised in past fire risk analyses, including the Individual Plant Examination of External Events fire analyses, are addressed to the extent allowed by the current state-of-the-art and the overall project scope. Although the primary objective of the report is to consolidate existing state-of-the-art methods, in many areas, the newly documented methods represent a significant advance over previous methods.

NUREG/CR-6850 does not constitute regulatory requirements, and NRC participation in this study neither constitutes nor implies regulatory approval of applications based on the analysis contained in this document. The analyses/methods documented in this report represent the combined efforts of individuals from RES and EPRI. Both organizations provided specialists in the use of fire PRA to support this work. The results from this combined effort do not constitute either a regulatory position or regulatory guidance.

In addition, NUREG/CR-6850 can be used for risk-informed, performance-based approaches and insights to support fire protection regulatory decision-making in general.

On 14-16 June 2005, NRC's Office of Nuclear Regulatory Research (RES) and EPRI conducted a joint public workshop for about 80 attendees at the EPRI NDE Center in Charlotte, NC. A second workshop was held the following year, on 24-26 May 2006, in NRC's Two White Flint North Auditorium in Rockville, MD. About 130 people attended the second workshop. Based on the positive public response to these two workshops, a more detailed training class was developed by the authors of NUREG/CR-6850. Two detailed training workshops were conducted in 2007: on 23-27 July and again on 27-30 August, both at EPRI in Palo Alto, CA. About 100 people attended each of these workshops. In 2008, two more workshops were held from 29 September through 2 October, and again from 17-20 November in Bethesda, MD, near NRC Headquarters. The two workshops attracted about 170 participants including domestic representatives from NRC Headquarters and all four regional offices, U.S. Department of Energy, National Aeronautics and Space Administration, EPRI, NPP licensees/utilities, Nuclear Steam Supply System vendors, consulting engineering firms, and universities. Also in

attendance were international representatives from Belgium, Canada, France, Japan, South Korea, Spain, and Sweden.

The material in this NUREG/CP was recorded at the workshops in 2008 and adapted by RES Fire Research Branch members for use as an alternative training method for those who were unable to physically attend the training sessions. This report can also serve as a refresher for those who attended one or more training sessions and would be useful preparatory material for those planning to attend a session.

NRC Disclaimer: This document's text and video content are intended solely for use as training tools. No portions of their content are intended to represent NRC conclusions or Regulatory Positions, and they should not be interpreted as such.

# CONTENTS OF VOLUME 3

ABSTRACT.....	iii
ACKNOWLEDGEMENTS.....	vii
LIST OF ACRONYMS.....	ix
<b>1 INTRODUCTION - FIRE ANALYSIS OVERVIEW .....</b>	<b>1-1</b>
1.1 EPRI Perspective .....	1-1
<b>2 FIRE ANALYSIS SLIDES.....</b>	<b>2-1</b>
Session 1a: Plant Partitioning.....	2-1
Session 1b: Example Problems.....	2-14
Session 2a: Fire Ignition Frequency .....	2-19
Session 2b: Example Problems .....	2-48
Session 3: Scoping Fire Modeling .....	2-65
Session 4: Heat Release Rate .....	2-83
Session 5: Fire Severity .....	2-97
Session 6a: Damage Criteria.....	2-108
Session 6b: Example Problems .....	2-119
Session 7: Detailed Fire Modeling and Single Compartment Fire Scenarios .....	2-130
Session 8: Detection and Suppression .....	2-148
Session 9: Special Fire Models Part 1 .....	2-164
Session 10a: Special Fire Models Part 2.....	2-192
Session 10b: Example Problems.....	2-201
Session 11a: Main Control Room Fire Analysis.....	2-215
Session 11b: Example Problems.....	2-234
Session 12: Multi-Compartment Fire Analysis .....	2-249
Session 13: Seismic Fire Interaction .....	2-259
<b><u>CONCLUSION</u>.....</b>	<b>3-1</b>
Part 1: Integration.....	3-1
Part 2: Lessons Learned and Insights .....	3-6
Part 3: Perspective .....	3-20

## CONTENTS OF VOLUME 3 (CONTINUED)

<b>APPENDICES</b> .....	<b>A-1</b>
Appendix A: Questions Asked in Module 3 Sessions.....	A-1
Appendix B: Reference Tables and Figures .....	B-1
Appendix C: Exercise Set Solutions .....	C-1
Session 1b: Example Problems (Plant Partitioning).....	C-1
Session 2b: Example Problems (Fire Ignition Frequency) .....	C-6
Session 6b: Example Problems (Scoping Fire Modeling) .....	C-19
Session 10b: Example Problems (Detailed Fire Modeling).....	C-31
Session 11b: Example Problems (Main Control Room Fire Analysis).....	C-53

# Acknowledgements

The authors of this report greatly appreciate the efforts and contributions made by Carli Follett, David Yates, and Thomas DeBold, summer interns from the University of Maryland's Fire Protection Engineering Department, during development of this NUREG/Conference Proceedings report. As part of their summer internship, they were tasked to analyze, evaluate, organize, and edit information in the videos of this report and to develop its first draft under direct supervision of the authors. They compiled all the video files and presentation materials used during the training sessions and used their knowledge to create, organize, edit, and deliver a user-friendly report of the highest quality possible.

We also acknowledge the other Fire Research Branch members Kendra Hill, Aixa Belen-Ojeda, Jason Dreisbach, Jessica Kratchman, Gabriel Taylor, J.S. Hyslop, and Mark Henry Salley for their support and contributions during its development. Their input and encouragement facilitated its timely completion and greatly benefited the final product.

In addition, we want to extend our gratitude to Nathan White and Thomas Kardaras of the Information Technology and Infrastructure Branch for their quick responses addressing all our computer needs and issues during development of the report. We greatly appreciate the support of Linda Stevenson (the agency publication specialist) and Guy Beltz (the agency printing specialist) whose invaluable support and expertise were critical to ensuring the published report's quality.

Also, several other 2009 Office of Nuclear Regulatory Research summer interns, specifically Minh Dang, Daniel Breedlove, Ashley Carnes, and Anders Gilbertson, made valuable contributions to this project, both technical and editorial, that contributed to its overall quality.



# LIST OF ACRONYMS

ACB	Air-cooled Circuit Breaker
ACRS	Advisory Committee on Reactor Safeguards
AEP	Abnormal Event Procedure
AFW	Auxiliary Feedwater
AGS	Assistance General Supervisor
AOP	Abnormal Operating Procedure
AOV	Air Operated Valve
ATHEANA	A Technique for Human Event Analysis
ATS	Automatic Transfer Switch
ATWS	Anticipated Transient Without Scram
BAT	Boric Acid Tank
BNL	Brookhaven National Laboratory
BWR	Boiling-Water Reactor
CBDT	Causal Based Decision Tree
CCDP	Conditional Core Damage Probability
CF	Cable (Configuration) Factors
CCPS	Center for Chemical Process Safety
CCW	Component Cooling Water
CDF	Core Damage Frequency
CFD	Computational Fluid Dynamics
CFR	Code of Federal Regulations
CLERP	Conditional Large Early Release Probability
CM	Corrective Maintenance
CR	Control Room
CRS	Cable and Raceway (Database) System
CST	Condensate Storage Tank
CVCS	Chemical and Volume Control System
CWP	Circulating Water Pump
DC	Direct Current
EDG	Emergency Diesel Generator
EDS	Electrical Distribution System
EF	Error Factor
EI	Erroneous Status Indicator
EOP	Emergency Operating Procedure
EPR	Ethylene-Propylene Rubber
EPRI	Electric Power Research Institute

FEDB	Fire Events Database
FEP	Fire Emergency Procedure
FHA	Fire Hazards Analysis
FIVE	Fire-Induced Vulnerability Evaluation (EPRI TR 100370)
FMRC	Factory Mutual Research Corporation
FPRAIG	Fire PRA Implementation Guide (EPRI TR 105928)
FRSS	Fire Risk Scoping Study (NUREG/CR-5088)
FSAR	Final Safety Analysis Report
HEAF	High Energy Arcing Fault
HEP	Human Error Probability
HFE	Human Failure Event
HPI	High-Pressure Injection
HPCI	High-Pressure Coolant Injection
HRA	Human Reliability Analysis
HRR	Heat Release Rate
HTGR	High Temperature Gas-cooled Reactor
HVAC	Heating, Ventilation, and Air Conditioning
ICDP	Incremental Core Damage Probability
ILERP	Incremental Large Early Release Probability
INPO	Institute for Nuclear Power Operations
IPE	Individual Plant Examination
IPEEE	Individual Plant Examination of External Events
IS	Ignition Source
ISLOCA	Interfacing Systems Loss of Coolant Accident
KS	Key Switch
LCO	Limiting Condition of Operation
LERF	Large Early Release Frequency
LFL	Lower Flammability Limit
LOC	Loss of Control
LOCA	Loss-of-Coolant Accident
LPG	Liquefied Petroleum Gas
LWGR	Light-Water-cooled Graphite Reactors (Russian design)
MCB	Main Control Board
MCC	Motor Control Center
MCR	Main Control Room
MG	Motor-Generator
MFW	Main Feedwater
MOV	Motor-Operated Valve
MQH	McCaffrey, Quintiere and Harkleroad's Method
MS	Main Steam
MSIV	Main Steam Isolation Valve
NC	No Consequence
NEI	Nuclear Energy Institute
NEIL	Nuclear Electric Insurance Limited
NFPA	National Fire Protection Association
NPP	Nuclear Power Plant

NPSH	Net Positive Suction Head
NQ cable	Non-Qualified (IEEE-383) cable
NRC	U.S. Nuclear Regulatory Commission
P&ID	Piping and Instrumentation Diagram
PE	Polyethylene
PM	Preventive Maintenance
PMMA	Polymethyl Methacrylate
PORV	Power-Operated Relief Valve
PRA	Probabilistic Risk Assessment
PSF	Performance Shaping Factor
PTS	Pressurized Thermal Shock
PVC	Polyvinyl Chloride
PWR	Pressurized-Water Reactor
Q cable	Qualified (IEEE-383) cable
RBMK	Reactor Bolshoy Moshchnosty Kanalny (high-power channel reactor)
RCIC	Reactor Core Isolation Cooling
RCP	Reactor Coolant Pump
RCS	Reactor Coolant System
RDAT	Computer program for Bayesian analysis
RES	Office of Nuclear Regulatory Research (at NRC)
RHR	Residual Heat Removal
RI/PB	Risk-Informed / Performance-Based
RPS	Reactor Protection System
RWST	Refueling Water Storage Tank
SCBA	Self-Contained Breathing Apparatus
SDP	Significance Determination Process
SGTR	Steam Generator Tube Rupture
SI	Safety Injection
SMA	Seismic Margin Assessment
SNPP	Simplified Nuclear Power Plant
SO	Spurious Operation
SOV	Solenoid Operated Valve
SRV	Safety Relief Valve
SSD	Safe Shutdown
SSEL	Safe Shutdown Equipment List
SST	Station Service Transformer
SUT	Start-up Transformer
SW	Service Water
SWGR	Switchgear
T/G	Turbine/Generator
THERP	Technique for Human Error Rate Prediction
TGB	Turbine-Generator Building
TSP	Transfer Switch Panel
UAT	Unit Auxiliary Transformer
VCT	Volume Control Tank
VTT	Valtion Teknillinen Tutkimuskeskus (Technical Research Centre of Finland)

VVER	The Soviet (and now, Russian Federation) designation for light-water pressurized reactor
XLPE	Cross-Linked Polyethylene
ZOI	Zone of Influence

# 1 INTRODUCTION – FIRE ANALYSIS OVERVIEW

Within the context of a nuclear power plant (NPP), fires present a special hazard because fire can damage multiple equipment intended to mitigate core damage. This determination of fire damage is made through fire modeling using simple empirical approaches to complex computer codes such as CFAST or FDS. NUREG/CR-6850 provides the framework for including fire models in fire probabilistic risk assessment (PRA) and describes simple empirical models to assess fire damage. Extensive information on the more complex approaches such as CFAST and FDS is referred to NUREG-1824, the verification and validation of several fire models.

Cables are important fire damage targets in fire PRA models. Simple empirical models to evaluate cable damage, including damage to cables in different trays, are included in the methods presented. Thresholds for cable damage, primarily to thermoset and thermoplastic cables, are also discussed. Besides simple empirical models, more complex rule sets to evaluate high-energy arcing faults are also presented in this part of the training.

The treatment of heat-release rates has been expanded in NUREG/CR-6850, and distributions of heat-release rates for many types of fire sources have been provided. For example, heat-release rates for electrical cabinets depend on the configuration of cables in the cabinet and the cabinet itself. In addition, the severity factor concept, which refers to that portion of the heat-release rate above which damage occurs, has been improved.

Besides explicit fire modeling, the “Fire” portion of this training describes how fire-suppression activities are treated and evaluated. Fire suppression includes prompt suppression, such as for hot work, and automatic and manual fire suppression. Fire damage is generally evaluated in fire PRA under success and failure of fire suppression.

This module also describes how to divide the plant into regions to be used for analysis. A fire compartment is a common region applied in fire PRA. Fires producing damage across regions are also considered. Moreover, guidance on counting components and transferring those counts to fire frequency is provided. Guidance for a qualitative assessment of seismic-fire interactions is included.

## 1.1 EPRI Perspective

“Methods for Applying Risk Analysis to Fire Scenarios (MARIAFIRES)” is a collection of the materials that are presented at the fire PRA course provided by the Electric Power Research Institute (EPRI) and the U.S. Nuclear Regulatory Commission’s (NRC’s) Office of Nuclear Regulatory Research (RES). The training and resulting presentation material is detailed and represents in excess of 60 hours of classroom instruction. The training focuses on the fire PRA methods documented in the joint EPRI/RES publication 1011989 and NUREG/CR-6850 along with clarifications, enhancements, and additions provided via the Frequently Asked Question (FAQ) process for NFPA 805.

The intent of the publication is to provide to the public the training material used at the fire PRA training. This material is not intended to be a substitute for direct interaction that is provided in the periodically offered fire PRA courses; rather, it is meant to augment that training and to serve as a reference. Enthusiastic future students can use the material to become familiar with the general principles of fire PRA prior to arrival at the course. Students who have already taken the course can use the material for

reference. The material consists of a series of reports that document the presentations including some speakers' notes and text. In addition, an edited version of a recorded training session is also available via a separate product number. This video version can be used in a similar manner to the documentation (e.g., for reference or in preparation for the course) and includes the actual recorded and edited course.

This material is being provided with the hope that those who plan to attend the course can arrive more informed, those who have already attended can have a reference, and those who have been unable to attend can have a resource to gain a more complete understanding of the intent and goals of EPRI 1011989 and NUREG/CR-6850.

## **2 FIRE ANALYSIS SLIDES**

### **Session 1a: Plant Partitioning**













## Slide 13

Notes:

### Task 1: Plant Partitioning Plant Partitioning into Fire Compartments (2)

- This task is often subjective – judgment is required
- Ideally: Compartments = Rooms
  - Locations that are fully defined by physical partitioning features such as walls, floors, and ceilings
- But the ideal is not the only solution - other features and elements may be credited in partitioning
  - That's where judgment comes into play!
  - What will you credit as a Partitioning Feature?

Fire PRA Workshop, 2008, Washington DC  
Task 1: Plant Partitioning

Slide 13

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## Slide 14

Notes:

### Task 1: Plant Partitioning Plant Partitioning into Fire Compartments (3)

- A good starting point is your Fire Areas, but you are *by no means limited* to equating Fire Compartments to Fire Areas
  - A Fire Area may be partitioned to two or more Compartments
  - You may combine two or more Fire Areas into a single Compartment
- In the end: {  $\sum$  Compartments } = { Global Analysis Bnd. }
  - No omissions
  - No overlap!

Fire PRA Workshop, 2008, Washington DC  
Task 1: Plant Partitioning

Slide 14

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---











**Session 1b: Example Problems**

Workshop Problems for Task 1: Plant Boundary Definition and Partitioning

**Workshop Problem Set 01-01**

**Step 1 - Selection of Global Plant Analysis Boundary:** Using Drawing # 01 in the Sample Package and the information provided in other drawings, identify the Global Plant Analysis Boundaries in terms of plant areas. Make a complete list of plant areas shown on Drawing #01 in the matrix provided below. Specify whether or not the area shall be included within the Global Plant Analysis Boundaries and then provide the basis of your decision.

Plant Area	Included?	Basis

Plant Area	Included?	Basis

**Workshop Problem Set 01-02**

**Step 2: Plant Partitioning:** Using the drawings provided in the Sample Package, identify the set of fire compartments that you will consider for the fire PRA. In the following matrix (1) list selected compartments, (2) give each an identification number, (3) identify the associated plant area for each compartment from the Solution Statement for Problem Set 01-01. Provide comments where warranted.

Fire Comp. ID #	Fire Compartment Descriptor	Plant Area	Comments

<b>Fire Comp. ID #</b>	<b>Fire Compartment Descriptor</b>	<b>Plant Area</b>	<b>Comments</b>

## **Session 2a: Fire Ignition Frequency**

































## Slide 24

Notes:

### FIRE IGNITION FREQUENCIES

#### Step 6. Related FAQs (cont'd)

- FAQ 07-0035: High energy arc faults in bus ducts (Status: Open)
  - Issue:
    - Guidance document is silent on topic
  - General approach to resolution:
    - Acknowledge potential for such events (e.g., Diablo Canyon 5/2000)
    - Provide plant wide frequency and counting/partitioning guidance
    - Provide zone of influence and scenario development guidance
  - Status:
    - FAQ resolution has been drafted and reviewed
    - Final revisions in process

Fire PRA Workshop, 2008, Washington DC  
Task 6: Fire Ignition Frequency

Slide 24

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 25

Notes:

### FIRE IGNITION FREQUENCIES

#### Step 6. Related FAQs (cont'd)

- FAQ 08-0042: Cabinet Fire Propagation (Status: Open)
  - Issue:
    - Guidance provides conflicting language regarding propagation of fire from cabinets (Chapter 6 versus Appendix G) and definition of "well-sealed cabinets)
    - Implication for Step 6: you exclude well-sealed cabinets from cabinet count if contents are below 440V (see Vol. 2, Page 6-17)
  - General approach to resolution:
    - Clarify and expand definition of "well-sealed and robustly secured cabinets" (which will not propagate fires)
  - Status:
    - FAQ resolution has been drafted and reviewed by RES/EPRI team
    - Industry and NRC staff reviews pending

Fire PRA Workshop, 2008, Washington DC  
Task 6: Fire Ignition Frequency

Slide 25

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)























## Session 2b: Example Problems

## Workshop Problems for Task 6: Fire Ignition Frequency

### Workshop Problem Set 06-01

**Step 1: Mapping plant ignition sources to generic sources:** Using the information provided in this Sample Package, map the items listed in the following table to generic sources.

Equipment ID	Equipment Description	Equipment Type	Bin #	Bin Description / Comment\
HPI-B	High pressure safety injection pump B			
MOV-1	HPI valve			
MOV-5	RWST isolation valve			
BAT-B	Train B Battery			
RCP-1	Reactor coolant pump 1			
AOV-1 / (SOV-1)	Pilot operated relief valve			
PT-1	RCS pressure transmitter			
EDG-A	Train A Emergency Diesel Generator			
MCC-B1	Train B 480 V Motor Control Center			
ATS-1	Automatic Transfer Switch Panel			
VITAL-A	Train A 120 VAC Vital Bus			
SWGR-A	Train A 4160 V Bus			
LC-A	Train A 480 V Load Center			
SST-A	Train A Station Service Transformer			
BC-A	Train A Battery Charger			
DC BUS-A	Train A 125 VDC Bus			
PNL-A	Train A 125 VDC Panel			
INV-A	Train A Inverter			
AFW-A	Motor driven AFW pump A			
AFW-B	Steam driven AFW Pump B			
SUT-1	Startup Transformer			

Workshop Problem Set 06-02 (Example)

**Step 2: Plant Fire Event Data Collection and Review:** The following tables provide examples of fire events data collected for the sample nuclear power plant.

<b>Fire Event #</b>	1
<b>Event date:</b>	January 1, 2007
<b>Event Description:</b>	At approximately 16:49, a fire resulted from a short caused by the slabs on the MCC-A breakers not properly engaging the bus bars. As a result of a short, insulation on some wires ignited, resulting in a fire. The fire was discovered immediately by employees who extinguished the blaze with portable fire extinguishers. Damage was confined to the cabinet where the fire occurred, located inside the motor control center.
<b>Should this event be considered in fire frequency calculation?</b>	Yes
<b>Basis:</b>	The event occurred during power operation. Extent of damage was sufficient to render the ignition source inoperable and the flames and hot gases threatened the integrity of other items nearby.
<b>Associated Bin ID # per Table 6-1 of Ref.1:</b>	15
<b>Bin Location:</b>	Plant-wide components
<b>Bin Description:</b>	Electrical Cabinets
<b>Basis:</b>	The fire was initiated in an MCC. An MCC is considered an electrical cabinet.

<b>Fire Event #</b>	2
<b>Event date:</b>	February 1, 2007
<b>Event Description:</b>	A fire occurred in the 120VAC-A panel. The fire was extinguished when 4kV bus-A was de-energized from the control room. Fire resulted from arcing of supply lead to one of the fittings connecting to a controller to the bus. Problems have been previously experienced with this type of devices in other plants.
<b>Should this event be considered in fire frequency calculation?</b>	Yes
<b>Basis:</b>	The event occurred during power operation. Extent of damage was sufficient to render the ignition source (i.e., 120VAC bus) inoperable and threaten the integrity of other items nearby.
<b>Associated Bin ID # per Table 6-1 of Ref.1:</b>	15
<b>Bin Location:</b>	Plant-wide components
<b>Bin Description:</b>	Electrical Cabinets
<b>Basis:</b>	The fire was initiated in a 120VAC panel, which is considered as an electrical cabinet.

### **Workshop Problem Set 06-03 (Example)**

**Step 3: Plant Specific Updates of Generic Ignition Frequencies:** The following bullets provide a sample discussion of how the fire events presented in the previous sections were treated in the Fire PRA.

- The two events identified in the preceding step are certainly significant and should be included in a statistical analysis of fire frequency (e.g., Bayesian update of generic frequencies.)
- Plant has been in commercial operation for 10 years.
- Both events should be mapped to Bin # 15 “Electrical Cabinets”
- The resulting frequency can be approximated by  $2/10 = 0.2$  per electrical cabinet year.
- The estimated frequency is 4 times greater than 0.045, Bin #15 generic frequency
- Fire PRA analysts decided not to include this plant specific experience in the fire frequency analysis. The decision is based on the following: “The two events do not point out an unusual trend in electrical cabinet fires. The two panels where the fires had occurred were dissimilar items. Therefore, the plant experience is not deemed to be indicative of unusually high electrical cabinet fire tendency at this plant.”
- For all other bins, the experience is no events in 10 years (both power and shutdown) or 8 years (assuming 20% outages). If subjected to Bayesian update, the impact of this experience on bin frequencies is minimal.

**Workshop Problem Set 06-04**

**Step 4: Mapping Plant-Specific Locations to Generic Locations:** Using the information provided in this Sample Package, map the items listed in the following table to the applicable generic locations provided in NUREG/CR 6850. Note that some of the compartments may map to more than one Generic Location.

**Step 5: Location Weighting Factors:** Assign the location weighting factors of the Fire Compartments in the following table.

Fire Comp. #	Plant Fire Compartment	Plant Area	Generic Location	W <sub>L</sub>
1	Main Control Room	Auxiliary Building		
2	Aux Bldg El. 0 Ft	Auxiliary Building		
3	Cable Spreading Room	Auxiliary Building		
4A	RHR Pump Room	Auxiliary Building		
4B	AFW Pump Room	Auxiliary Building		
5	Battery Room A	Auxiliary Building		
6	Battery Room B	Auxiliary Building		
9	SWG Access Room	Auxiliary Building		
10	Switchgear Room A	Auxiliary Building		
11	Switchgear Room B	Auxiliary Building		
14	Stairway	Auxiliary Building		
7	Containment	Containment		
8A	DG-A Room	DG Bldg.		
8B	DG-B Room	DG Bldg.		
12	Turbine Bldg El. 0 Ft	Turbine Building		
15	Battery Room 1	Turbine Building		
13	Yard	Yard		
14	Intake Structure	Intake Structure		



**Workshop Problem Set 06-06**

**Step 6: Fixed Fire Ignition Source Counts:** Estimate the ignition source counts for only those items that are noted under each picture and are visible in the foreground of the picture:



Electrical Panels: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_

Transformers: \_\_\_\_\_



Transformers: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_

Transformers: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_




Electrical Panels: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_



Electrical Panels: \_\_\_\_\_

(These are sealed panels with low voltage circuits)

**Workshop Problem Set 06-07**

**Step 6: Fixed Fire Ignition Source Counts:** Estimate the ignition source counts for the components identified in Step 1 above.

			Bin # and Description (per Table 6-1)												
			1	2	8	4	9	10	14	15	16	21	23a	23b	29
			Batteries	Reactor Coolant Pump	Diesel Generators	Main Control Board	Air Compressors	Battery Chargers	Electric Motors	Electrical Cabinets	High Energy Arcing Faults	Pumps	Transformers (Dry)	Transformers (Oil filled)	Yard transformers (Others)
#	Compartment	Plant Area	BAT	RCP	DG	MCB	AC	BC	EM	EC	HEAF	PMP	XFMR-Dry	XFMR-Oil	XFMR-Yard
1	Main Control Room	Control/Aux/Reactor Building													
2	Aux Bldg El. 0 Ft	Control/Aux/Reactor Building													
3	Cable Spreading Room	Control/Aux/Reactor Building													
4A	RHR Pump Room	Control/Aux/Reactor Building													
4B	AFW Pump Room	Control/Aux/Reactor Building													
5	Battery Room A	Plant Wide Components													
6	Battery Room B	Plant Wide Components													
9	SWG Access Room	Plant Wide Components													
10	Switchgear Room A	Plant Wide Components													
11	Switchgear Room B	Plant Wide Components													
14	Stairway	Plant Wide Components													
7	Containment	Containment													
8A	DG-A Room	Plant Wide Components													
8B	DG-B Room	Plant Wide Components													
12	Turbine Bldg El. 0 Ft	Plant Wide Components													
15	Battery Room 1	Plant Wide Components													
13	Yard	Plant Wide Components													
14	Intake Structure	Plant Wide Components													
		<b>Total</b>													

**Workshop Problem Set 06-08**

**Step 7: Ignition Source Weighting Factors:** For an NPP, the fire PRA analysts have counted 23 pumps within the Plant Analysis Boundary.

- For RHR Pump RHRP-C located in RHR Pump room (FZ-03A), which in turn is located in the Auxiliary Building, establish the IS, J and L subscripts of:

$$W_{IS,J,L} =$$

- For the same RHR Pump, RHRP-C, calculate the Ignition Source Weighting Factor

$$W =$$

- RHR Pump room FZ-03A contains three pumps. Calculate the ignition source weighting factor for the pumps in this compartment.

$$W =$$

**Workshop Problem Set 06-09**

**Step 7: Ignition Source Weighting Factors:** For an NPP, the fire PRA analysts have counted 351 electrical cabinet vertical sections within the Plant Analysis Boundary.

- 480VAC MCC-A is composed of 32 breakers arranged in 8 vertical segments. Calculate the ignition source weighting factor for this MCC.

$$W_{\text{MCC-B}} =$$

- 4kV non-1E Switchgear 1 is composed of 8 breakers. Each breaker takes up one vertical segment of the switchgear. Calculate the ignition source weighting factor for this electrical panel.

$$W_{\text{SWG-1}} =$$

- The local control panel, CP-1, for the chemicals addition system located in the Reactor Building has the following dimensions: 2' Deep, 12' Long, 8' High. There are no partitions within the panel. Calculate the ignition source weighting factor for this electrical panel.

$$W_{\text{CP-1}} =$$

**Workshop Problem Set 06-10**

**Step 7: Ignition Source Weighting Factors:** Using the information provided in the solution for Problem Set 06-07, calculate the component weighting factors for the components listed below.

#	Compartment	Plant Area	Bin # and Description (per Table 6-1)												
			1	2	8	4	9	10	14	15	16	21	23a	23b	29
			BAT	RCP	DG	MCB	AC	BC	EM	EC	HEAF	PMP	XFMR-Dry	XFMR-Oil	XFMR-Yard
1	Main Control Room	Control/Aux/Reactor Building													
2	Aux Bldg El. 0 Ft	Control/Aux/Reactor Building													
3	Cable Spreading Room	Control/Aux/Reactor Building													
4A	RHR Pump Room	Control/Aux/Reactor Building													
4B	AFW Pump Room	Control/Aux/Reactor Building													
5	Battery Room A	Plant Wide Components													
6	Battery Room B	Plant Wide Components													
9	SWG Access Room	Plant Wide Components													
10	Switchgear Room A	Plant Wide Components													
11	Switchgear Room B	Plant Wide Components													
14	Stairway	Plant Wide Components													
7	Containment	Containment													
8A	DG-A Room	Plant Wide Components													
8B	DG-B Room	Plant Wide Components													
12	Turbine Bldg El. 0 Ft	Plant Wide Components													
15	Battery Room 1	Plant Wide Components													
13	Yard	Plant Wide Components													
14	Intake Structure	Plant Wide Components													

### **Workshop Problem Set 06-11**

**Transient Ignition Source Weighting Factors:** An NPP is composed of three compartments with the following characteristics:

#### Compartment 1:

- Houses the Steam Driven Auxiliary Feedwater Pump
- The pump has required major maintenance once per year
- The room is at a corner of the Auxiliary Building separated from other parts of the building with 3-hour rated walls and one access door
- The lubricating oils of this and other large safety related pumps are stored in this room.
- All cables are in open bottom and open top cable trays
- The total amount of cables in the room is 1,000 lbs.

#### Compartment 2:

- Houses the one of three High Pressure Injection Pumps
- The pump has required major maintenance once per three years
- The room is at a corner of the Auxiliary Building separated from other parts of the building with 3-hour rated walls and one access door
- There are no other items in this room except for the pump.
- All cables are inside conduits
- The total amount of cables in the room is 1,000 lbs.

#### Compartment 3:

- Houses 480VAC MCC
- The MCC has never required any major maintenance since installation 15 years ago
- The room is the passageway between the radiation control and other parts of the Auxiliary Building
- The room contains coveralls and other radiation protection related clothing items
- All cables are in open bottom and open top cable trays
- The total amount of cables in the room is 10,000 lbs.

A. Enter the influencing factors for each compartment and category:

Compartment	Influencing Factor			Cable Run (self-ignited cable fires)
	Maintenance	Occupancy	Storage	
Compartment 1				
Compartment 2				
Compartment 3				
Total				

B. Calculate the ignition source weighting factors for each compartment

Compartment	General Transients	Transients fires caused by welding and cutting	Cable fires caused by welding and cutting	Cable Run (self-ignited cable fires)
Compartment 1				
Compartment 2				
Compartment 3				
Total				

C. Calculate the ignition frequencies for each compartment

	General Transients	Transients fires caused by welding and cutting	Cable fires caused by welding and cutting	Cable Run (self-ignited cable fires)
<i>Total Location Frequency (/ry)</i>	<i>3.90E-03</i>	<i>9.70E-03</i>	<i>1.60E-03</i>	<i>4.40E-03</i>
Compartment 1				
Compartment 2				
Compartment 3				

**Transients and Cable Fire (Count, Ignition Source Weighting Factor and Frequency)**

	Count					Cable Quantity x Maintenance	Weighting Factors			Frequency		
	Cable Run (10 <sup>6</sup> BTU)	Maintenance	Storage	Occupancy	General Transients		Cable Fires Due to Hotwork	Transients due to Hotwork	General Transients	Cable Fires Due to Hotwork	Transients due to Hotwork	
Control / Aux. / Reactor Building												
1 Main Control Room	300	1	10	10	300	0.64	3.5E-01	0.2	2.5E-03	5.6E-04	1.9E-03	
2 Aux Bldg El. 0 Ft	6	1	1	1	6	0.09	7.0E-03	0.2	3.5E-04	1.1E-05	1.9E-03	
3 Cable Spreading Room	549	1	1	1	549	0.09	6.4E-01	0.2	3.5E-04	1.0E-03	1.9E-03	
4A RHR Pump Room	1	1	1	1	1	0.09	1.2E-03	0.2	3.5E-04	1.9E-06	1.9E-03	
4B AFW Pump Room	1	1	1	1	1	0.09	1.2E-03	0.2	3.5E-04	1.9E-06	1.9E-03	
<i>Total</i>		5	14	14	857				3.90E-03	1.60E-03	9.70E-03	
Plant Wide Components												
5 Battery Room A	1	1	1	1	1	0.05	4.2E-04	0.03	4.5E-04	8.3E-07	1.5E-04	
6 Battery Room B	0	1	1	1	0	0.05	--	0.03	4.5E-04	--	1.5E-04	
9 SWG Access Room	1.6	1	1	1	1.6	0.05	6.7E-04	0.03	4.5E-04	1.3E-06	1.5E-04	
10 Switchgear Room A	10	3	1	3	30	0.11	1.3E-02	0.09	1.1E-03	2.5E-05	4.6E-04	
11 Switchgear Room B	80	3	1	3	240	0.11	1.0E-01	0.09	1.1E-03	2.0E-04	4.6E-04	
14 Stairway	0	1	1	3	0	0.08	--	0.03	7.5E-04	--	1.5E-04	
7 Containment	0	1	1	1	0	0.05	--	0.03	4.5E-04	--	1.5E-04	
8A DG-A Room	218	3	1	1	654	0.08	2.7E-01	0.09	7.5E-04	5.5E-04	4.6E-04	
8B DG-B Room	218	3	1	1	654	0.08	2.7E-01	0.09	7.5E-04	5.5E-04	4.6E-04	
12 Turbine Bldg El. 0 Ft	80	10	1	3	800	0.21	3.3E-01	0.31	2.1E-03	6.7E-04	1.5E-03	
15 Battery Room 1	0	1	1	1	0	0.05	--	0.03	4.5E-04	--	1.5E-04	
13 Yard	0	1	1	1	0	0.05	--	0.03	4.5E-04	--	1.5E-04	
14 Intake Structure	6	3	1	1	18	0.08	7.5E-03	0.09	7.5E-04	1.5E-05	4.6E-04	
<i>Total</i>		32	13	21	2398.6				9.90E-03	2.00E-03	4.90E-03	

**Ignition Frequencies by Bin and Compartment (part 1 of 2)**

		Batteries	Reactor Coolant Pump	Diesel Generators	Air Compressors	Battery Chargers	Electric Motors	Electrical Cabinets	High Energy Arcing Faults	Pumps	Transformers (Dry)	Transformers (Oil filled)
Generic Frequency		7.5E-04	6.1E-03	2.1E-02	2.4E-03	1.8E-03	4.6E-03	4.5E-02	1.5E-03	2.1E-02	9.9E-03	9.9E-03
Compartment and Associated Freq.												
1	Main Control Room	1.1E-02						3.3E-04				
2	Aux Bldg El. 0 Ft	7.2E-03					2.0E-03			6.0E-03		
3	Cable Spreading Room	6.2E-03										
4A	RHR Pump Room	7.2E-03					2.0E-03			3.0E-03		
4B	AFW Pump Room	6.4E-03								6.0E-03		
5	Battery Room A	4.7E-04	2.5E-04									
6	Battery Room B	9.1E-04	2.5E-04									
9	SWG Access Room	1.1E-02						9.9E-03				
10	Switchgear Room A	1.5E-02				6.0E-04		7.9E-03	3.8E-04		5.0E-03	
11	Switchgear Room B	1.7E-02				6.0E-04		7.9E-03	3.8E-04		5.0E-03	
14	Stairway	6.6E-04										
7	Containment	3.2E-03					6.6E-04			3.0E-03		
8A	DG-A Room	1.8E-02		1.1E-02								
8B	DG-B Room	1.8E-02		1.1E-02								
12	Turbine Bldg El. 0 Ft	6.5E-02	2.5E-04		2.4E-03	6.0E-04		1.9E-02	7.5E-04	3.0E-03		9.9E-03
15	Battery Room 1	4.5E-04										
13	Yard	2.6E-03										
14	Intake Structure	1.1E-03										

**Ignition Frequencies by Bin and Compartment (part 2 of 2)**

	Yard transformers (Others)	Main Control Board	Cable Run	Junction Box	MG Sets	MFW Pumps	TG Oil	TG Exciter	TG Hydrogen
Generic Frequency	2.2E-03	2.5E-03	4.4E-03	1.9E-03	1.6E-03	1.3E-02	9.5E-03	3.9E-03	6.5E-03
Compartment									
1 Main Control Room		2.5E-03	9.0E-04						
2 Aux Bldg El. 0 Ft			1.8E-05	7.7E-06					
3 Cable Spreading Room			1.6E-03	7.1E-04					
4A RHR Pump Room			3.0E-06	1.3E-06					
4B AFW Pump Room			3.0E-06	1.3E-06					
5 Battery Room A			3.0E-06	1.3E-06					
6 Battery Room B									
9 SWG Access Room			4.8E-06	2.1E-06					
10 Switchgear Room A			3.0E-05	1.3E-05					
11 Switchgear Room B			2.4E-04	1.0E-04					
14 Stairway									
7 Containment									
8A DG-A Room			6.5E-04	2.8E-04					
8B DG-B Room			6.5E-04	2.8E-04					
12 Turbine Bldg El. 0 Ft			2.4E-04	1.0E-04			9.5E-03	3.9E-03	6.5E-03
15 Battery Room 1									
13 Yard	2.2E-03								
14 Intake Structure			1.8E-05	7.7E-06					

## **Session 3: Scoping Fire Modeling**



































## Session 4: Heat Release Rate







## Slide 6

Notes:

### HEAT RELEASE RATES HRR Profile – Related FAQs (continued)

- FAQ 08-0052 Transient Fires (Status: Open)
  - Issue:
    - No guidance on fire growth times for transient fires
    - Guidance not clear as to which non-suppression curve would apply to transient fires in the MCR (i.e., transient curve or MCR curve)
  - General approach to resolution:
    - Review existing test data and develop guidance for transient fire growth times
    - Clarify non-suppression curve application for this case
  - Status:
    - Initial team position drafted and undergoing review within the teams
    - Staff and industry reviews pending

Joint Fire PRA course, Sept. & Nov. 2008  
Module III: Heat Release Rates Appendix G

Slide 6

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

## Slide 7

Notes:

### HEAT RELEASE RATES HRR Profile – Related FAQs (continued)

- FAQ 08-0044 Pump Oil Fires (Status: Open)
  - Issue:
    - Guidance for large oil spill and fire is generating conservative results especially in the case of MFW pump fires (high frequency of large release compared to experience base)
  - General approach to resolution:
    - Provide an alternative approach and revised fire frequencies for leaks and spills from higher volume circulating oil/lubrication systems
  - Status:
    - General consensus that a revised treatment is appropriate and needed
    - RES/EPRI team discussion of the specific resolution approach continues, reviews ongoing
    - NRC 805 team and industry 805 task force reviews pending

Joint Fire PRA course, Sept. & Nov. 2008  
Module III: Heat Release Rates Appendix G

Slide 7

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)



















## Session 5: Fire Severity





















## **Session 6a: Damage Criteria**













## Slide 9

Notes:

### Damage Criteria Damage Time

- It is both appropriate and desirable to consider damage time during Task 11 – Detailed Fire Modeling
  - At the threshold exposure condition, damage times may be prolonged (e.g., 30 minutes or more)
  - As exposure conditions increase in severity, time to damage decreases (e.g., to as little as a few seconds)
  - Consideration of time to damage allows for a more realistic assessment of the non-suppression probability
    - How long do you have to put the fire out before damage occurs?

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Damage Criteria

Slide 9

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 10

Notes:

### Damage Criteria Damage Time

- Two general approaches to damage time analysis:
  - Direct modeling of target thermal response
    - Use a fire model to predict the temperature response of the target
    - When the predicted temperature of the target reaches the damage threshold, assume target failure
    - Catch: need fire model that does target response calculation
  - Empirical approach (e.g. SDP)
    - Predict the peak exposure condition (temperature or heat flux)
    - Use a look-up table to estimate time to damage
    - Catch: look-up tables currently only available for generic thermoset and thermoplastic cables

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Damage Criteria

Slide 10

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)





## Slide 14

Notes:

### Damage Criteria Smoke Damage

- Smoke damage is assessed on an empirical basis:
  - We don't set quantitative thresholds
  - We don't try to use fire models
  - You should consider the potential failure of vulnerable components due to smoke as a part of your damage target set

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Damage Criteria

Slide 14

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## Slide 15

Notes:

### Damage Criteria Smoke Damage

- Assume that vulnerable components adjacent to or connected to the fire source will be damaged by smoke:
  - Within the same electrical cabinet or housing as a fire source
    - e.g. given a panel fire, the whole panel is lost due to smoke and/or heat
  - In an adjacent cabinet if the cabinet-to-cabinet partitions is not well-sealed
  - In a common *stack* of electrical cubicles
  - In a nearby cabinet with a direct connection to the fire source
    - e.g., a shared or common bus-duct

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Damage Criteria

Slide 15

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## Session 6b: Example Problems

## Workshop Problems on Task 8: Scoping Fire Modeling

This handout includes workshop problems on the different steps of Task 8: Scoping Fire Modeling. Problems are grouped by steps.

### Step 1: Preparation for Walkdown

Step 1 has three sub-steps: 1) Estimate heat release rate for fixed ignition source screening, 2) Target and intervening combustibles damage or ignition criteria, and 3) Develop a zone of influence.

#### Workshop problem 08-01:

**Step 1.1: Estimate heat release rate for fixed ignition source screening:** Assign a heat release rate to the ignition sources depicted in the pictures of the following Table 08-01. For this exercise, assume that the plant has a mix of qualified and unqualified cables. The heat release rates are listed in Table E-1 of NUREG/CR-6850.

**Table 08-01: Inputs for Workshop problems 1**

Ignition Source	Table E-1 Case	98 <sup>th</sup> Percentile HRR	Justification
 <p data-bbox="331 1188 477 1211">Dry transformer</p>			
 <p data-bbox="315 1495 493 1518">Fire protection panel</p>			
 <p data-bbox="298 1801 509 1827">Ventilation sub-system</p>			

Ignition Source	Table E-1 Case	98 <sup>th</sup> Percentile HRR	Justification
 <p data-bbox="375 562 441 585">Pumps</p>			

**Workshop Problem Set 08-02:**

**Step 1.2: Target and intervening combustible damage and ignition criteria:** Assign damage criteria to the ignition sources depicted in Table 08-01. For this exercise, assume that the plant has a mix of thermoset and thermoplastic cable. Generic damage criteria are listed in Table H-1 of NUREG/CR-6850.

**Table 08-02: Inputs for workshop problem 2**

Target/Intervening Combustible	Damage Criteria	Justification
Cables in a ladder back tray		
Cables in a solid tray		
Theromset cable in a conduit		
Motor operated valve (MOV).		
Cabinet with a solid state device		

### Workshop Problem Set 08-03

**Step 1.3: Develop zone of influence:** Calculate the heat release rate required for generating target damage for the following ignition source/target combination and determine if the ignition source can be screened. Use the engineering calculations described in NUREG-1805 for determining the heat release rate value.

- Target in the hot gas layer:
  - A cable tray target is located near the ceiling in a room approximately 21' by 7' and has a normally closed door on each end. The room is approximately 20' high. The inside walls of the MCC room are reinforced concrete. There is one MCC cabinet in the room. The MCC cabinet has unqualified cable.

- Target subjected to flame impingement or fire plume temperatures:
  - A vertical cable tray is located 5' ft from a floor based ventilation subsystem.


- Target subjected to flame radiation:
  - A conduit is located 3 ft from a battery charger with qualified cable.

**Workshop Problem Set 08-04**

**Step 2: Plant Walkdown:** Inspect the ignition source and target combination in the pictures included in Table 08-03 and determine the appropriate zone of influence calculation necessary.

**Table 08-03: Inputs for Workshop problems 1**

Ignition Source	Ignition Source/Target	Zone of Influence	Distance
			
			
			

Ignition Source	Ignition Source/Target	Zone of Influence	Distance
			
			
			
			



## Workshop Problem Set 08-06

**Step 5: Calculation of Revised Compartment Fire Frequency:** Determine a revised compartment ignition frequency for switchgear room A assuming the walkdown results listed in Table 08-04.

**Table 08-04: Summary of Task 8 calculations**

Equipment Description	Count	Fire Condition	Measured Distance (ft)	Table E-1 Case	Critical HRR (Table E-1)	Room Area (ft <sup>2</sup> )	Room Height (ft)	Calculated HRR (kW)	Room Temp (F)	Screened	Severity Factor	Count Task 8
Train A 4160 V Bus	8	flame or plume	1.7	9	Do Not Screen	1350	20	7	N/A	No	1.00	8.00
Train A 480 V Load Center	6	flame radiation	4.9	9	Do Not Screen	1350	20	401	N/A	No	1.00	6.00
Train A Station Service Transformer	1	flame radiation	4.5	9	Do Not Screen	1350	20	336	N/A	No	1.00	1.00
Train A Battery Charger	1	flame or plume	2.9	4	464	1350	20	25	264	No	0.98	0.98
Train A 125 VDC Bus	8	flame or plume	0.7	4	464	1350	20	1	264	No	1.00	8.00
Train A 125 VDC Panel	1	flame radiation	2.8	4	464	1350	20	129	264	No	0.60	0.60
Train A Inverter	1	flame radiation	2.0	4	464	1350	20	64	264	No	0.88	0.88

**Table 08-05: Comparison of switchgear room A ignition frequency**

Task 6	Switchgear Room A	≈ 1.5E-02
Task 8	Switchgear Room A	≈ 1.5E-02

## **Session 7: Detailed Fire Modeling and Single Compartment Scenarios**





























## Slide 19

Notes:

### Module II-10: PROCESS Fire Detection/Suppression Analysis

- Assess fire detection timing
- Assess timing, reliability, and effectiveness of fixed-fire suppression systems
- Assess manual fire brigade response
- Estimate probability of fire suppression as a function of time
- Workshop problem 11a-09

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11a - Detailed Fire Modeling & Single  
Compartment Fire Scenarios

Slide 19

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

## Slide 20

Notes:

### Module II-10: PROCESS Calculate Severity Factor

- The time to target damage, and as a result the non-suppression probability is a function of the postulated heat release rate
- The severity factor should be calculated in combination with the non-suppression probability
- Workshop problem 11a-10, 11a-11

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11a - Detailed Fire Modeling & Single  
Compartment Fire Scenarios

Slide 20

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---





## Session 8: Detection and Suppression































**Session 9: Special Fire Models Part 1**























## Slide 17

Notes:

### FIRE PROPAGATION IN CABLE TRAY STACKS Related FAQ

- FAQ 08-0049 (Status: Open)
  - Issue:
    - The cable fire empirical spread model (tray-to-tray, stack-to-stack) has been misapplied in pilot applications
    - Reviewers concluded that misapplication resulted in very conservative fire growth and risk results
  - General approach to resolution:
    - Clarify the bounds of the empirical model to avoid misapplication
  - Status:
    - Proposed resolution has recently completed final review within the RES and EPRI teams
    - Staff and industry final review pending
    - Final revision, as needed, pending
  - Note: as a follow-on, team plans to generate a new FAQ to address broader needs relative to cable fire growth modeling

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 17

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 18

Notes:

### HIGH ENERGY ARCING FAULTS (1 of 16)

#### Definition

- Rapid release of electrical energy in the form of heat, vaporized copper, and mechanical force.
- An arc is a very intense discharge of electrons between two electrodes that are carrying an electric current. The arc is created by the flow of electrons through charged particles of gas ions that exist as a result of vaporization of the conductive material.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 18

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)











## Slide 28

Notes:

### HIGH ENERGY ARCING FAULTS (10 of 16)

High-Energy Phase: The zone of influence

- Any unprotected cables in the *first* overhead cable tray will be ignited concurrent with the initial arcing fault provided that this first tray is within 1.5 m (5') vertical distance of the top of the cabinet. The cable tray fire will propagate to additional trays consistent with the approach provided for the treatment of cable tray fires elsewhere in this document, assuming that the time to ignition of the first tray is zero rather than the normal 5 minutes.
  - This applies to any cable tray located directly above the panel.
  - This applies to any cable tray above the aisle way directly in front of, or behind, the faulting cabinet, provided some part of that tray is within 0.3 m (12") horizontally of the cabinet's front or rear face panel.
  - Cables in conduit or in a fire wrap are considered protected in this context.
  - Armored cables with an exposed plastic covering are considered unprotected in this context.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 28

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 29

Notes:

### HIGH ENERGY ARCING FAULTS (11 of 16)

High-Energy Phase: The zone of influence

- Any vulnerable component or movable/operable structural element located within 0.9 m (3') horizontally of either the front or rear panels/doors, and at or below the top of the faulting cabinet section, will suffer physical damage and functional failure.
  - This will *include* mobile/operable structural elements like fire dampers and fire doors.
  - This will *include* potentially vulnerable electrical or electromechanical components such as cables, transformers, ventilation fans, other cabinets, etc.
  - This will *exclude* fixed structural elements such as walls, floors, ceilings, and intact penetration seals.
  - This will *exclude* large components and purely mechanical components such as large pumps, valves, major piping, fire sprinkler piping, or other large piping (1" diameter or greater).
  - This may *include* small oil feed lines, instrument air piping, or other small piping (less than 1" diameter).

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 29

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)





## Slide 34

Notes:

### HIGH ENERGY ARCING FAULTS (16 of 16)

#### Example

- Consider a HEAF scenario consisting of a switchgear cabinet affecting two targets. A stack of three cable trays is above the cabinet. The first tray in the stack is 0.9 m (3') above the cabinet. It has been determined that one of the targets is in the first tray. The other target is in the third tray.
- According to the approach provided in Section M.3, the first target is assumed ignited at the time of the HEAF. The second target is damaged at time 7 minutes (4 minutes for fire propagation from the first to the second tray, and 3 minutes for fire propagation from the second to the third tray).
  - A scenario involving target in the first tray  $CDF_i = \lambda_e \cdot W_L \cdot W_U \cdot CCDF_i$
  - A scenario involving the two targets  $CDF_i = \lambda_e \cdot W_L \cdot W_U \cdot P_{23} \cdot CCDF_i$

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 34

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 35

Notes:

### FIRE PROPAGATION TO ADJACENT ELECTRICAL CABINETS (1 of 3)

Analytical fire models may be used in all types of fire propagation and damage scenarios.

- This appendix discusses empirical approaches for determining:
  - Fire propagation to adjacent cabinets
  - Fire induced damage in adjacent cabinets
- Empirical approach based on SNL and VTT experiments

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 35

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 36

Notes:

### FIRE PROPAGATION TO ADJACENT ELECTRICAL CABINETS (2 of 3)

The empirical model for fire propagation consists of the following rules:

- Assume no fire spread if either:
  - Cabinets are separated by a double wall with an air gap, or
  - Either the exposed or exposing cabinet has an open top, *and* there is an internal wall, possibly with some openings, *and* there is no diagonal cable run between the exposing and exposed cabinet.
- If fire spread cannot be ruled out, or cabinets are separated by a single metal wall, assume that no significant heat release occurs from the adjacent cabinet for 10 minutes if cables in the adjacent cabinet are in direct contact with the separating wall, and 15 minutes if cables are not in contact with the wall.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 36

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 37

Notes:

### FIRE PROPAGATION TO ADJACENT ELECTRICAL CABINETS (3 of 3)

The empirical model for fire damage consists of the following rules:

- Assume loss of function in an adjacent cabinet if there is not a double wall with an air gap.
- Assume no damage in the second adjacent cabinet occurs until after the fire propagates to the adjacent cabinet. Assume damage can occur earlier if there are large openings in a wall and plenum areas in which a hot gas layer is likely to form.
- Assume no damage to an adjacent cabinet if:
  - There is a double wall with an air gap, and
  - There are no sensitive electronics in the adjacent cabinet (or the sensitive electronics have been "qualified" above 82°C).
- Assume damage to sensitive electronics occurs at 10 minutes if there is a double wall with an air gap.
- Assume damage to sensitive electronics can be prevented before 10 minutes if the fire is extinguished and the cabinet is cooled, e.g., by CO<sub>2</sub> extinguishers.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 37

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)







## Slide 42

Notes:

### PASSIVE FIRE PROTECTION FEATURES (5 of 6)

The empirical approaches consist of replicating the thermal response of fire protection features observed in fire tests in the postulated fire scenarios.

- Cable tray barriers and fire stops: SNL tests (same configuration as coating tests)
- The following systems were tested:
  - Ceramic wool blanket wrap, solid tray bottom covers, solid tray top cover with no vents, solid tray bottom cover with vented top cover, one-inch insulating barrier between cable trays, and fire stops.
- Propagation of the fire to the second tray was prevented in each case.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 42

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

## Slide 43

Notes:

### PASSIVE FIRE PROTECTION FEATURES (5 of 6) (cont'd)

- Barriers seem to substantially delay cable damage for qualified cable. The barriers did not delay cable damage for nonqualified cable.
- Results considered most appropriate to exposure fires with smaller HRR and to cable trays in a stack threatened by fires in lower trays.
  - Each barrier prevents cable tray ignition until well after the fire brigade reaches the scene (i.e., greater than 20 minutes),
  - Each barrier prevents damage in *qualified* cable with solid tray bottom covers until well after the fire brigade reaches the scene.

Joint Fire PRA Course, Sept. & Nov. 2008  
Module III: Task 11, Special Fire Models Part 1

Slide 43

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)



## Session 10a: Special Fire Models Part 2









## Slide 7

Notes:

### Module II-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires

- Four types of fires can occur involving the turbine generator set, and each is treated differently:
  - Electrical fires in the exciter
  - Hydrogen fires:
  - General oil fires
  - Catastrophic failure (e.g., blade ejection)

Fire PRA Workshop, 2008, Washington DC  
Module II Pt. 2: Special Fire Models Part 2

Slide 7

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 8

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires: Exciter Fires

- Exciter fires do occur, but all evidence indicates fires remain small and non-threatening
  - No evidence of any exciter fire that led to damage to anything other than the exciter itself
  - No attempt was made to estimate likelihood of a severe exciter fire (one that challenges external targets)
- Recommended Practice:
  - Assume exciter fires remain confined to the exciter
  - Verify for your application, but should not represent a significant risk contributor

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 8

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 9

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires: Hydrogen Fires

- Database shows 13 TG set hydrogen fires, two categorized as severe, the rest were small leaks (generally associated with seals) with limited damage range
- For small fires:
  - Assume damage will be limited to within a few feet of the point of release
  - Secondary ignitions should be considered and treated if there are nearby combustibles
  - See more in Hydrogen Fires discussion (Appendix N)

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 9

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 10

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires: Hydrogen Fires

- For severe fires, widespread damage may occur due to an explosion or detonation of the hydrogen gas.
  - Assume fire may damage all Fire PRA cables and equipment within the line of site of the generator and its bearings (including above and below)
  - Hydrogen explosion could cause some structural damage as well
  - For further discussion – see Hydrogen Fires

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 10

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 11

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires: Catastrophic Failure

- International experience includes a few fires initiated by catastrophic turbine failure that resulted in widespread damage including structural damage
  - Examples: Vandellos (1989), Narora (1993), Chernobyl Unit 2 (1991)
  - Events involve a combination of turbine blade ejection, hydrogen release, and large oil fires.
- Domestically, only one event came close to involving all of these elements (Salem, 1991)
  - Event involved minor damage due to existence of an automatic suppression system and prompt fire brigade response
  - Indicates that both automatic fire suppression systems and fire brigade should be credited to prevent catastrophic consequences observed internationally

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 11

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

## Slide 12

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Turbine Generator Set Fires: Catastrophic Failure

- Screening approach: assume that the *conditional probability* that given a T/G set fire, the event will involve catastrophic failure (e.g., blade ejection), hydrogen, and oil fires:
  - 1 over 38 events or 0.025
  - With *successful* suppression, damage would be limited to the T/G system, as was the case at Salem
  - In case of failure of all suppression, automatic and manual, assume loss of all Fire PRA cables and equipment in the Turbine Building
    - Possible failure of exposed structural steel as well
  - Estimate screening CDF contribution, refine as appropriate

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 12

A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)

## Slide 13

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Hydrogen Fires

- This discussion (Appendix N) applies to general hydrogen fires
  - Including TG set fires
  - Also other source of hydrogen leaks and releases (e.g., recombiners, storage tanks, piping, etc.)
- The intent was to provide general discussion of hydrogen fires and their potential effects
- The discussion stops short of recommending modeling approaches, but does provide references to various information resources

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 13

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 14

Notes:

### Module III-11, Pt. 2: Special Models Part 2 Hydrogen Fires

- Two general types of fires:
  - Jet fires originating at point of a H2 leak
    - Critical question will be flame length
  - Explosions
    - If there is a mechanism for the release of large quantities of H2 (e.g., a large leak, a prolonged leak that might not be ignited early) then likelihood of a hydrogen explosion is high
    - References provide additional resources for assessing damage potential for an explosion scenario
    - Critical question will be the severity of the overpressure

Fire PRA Workshop, 2008, Washington DC  
Module III Pt. 2: Special Fire Models Part 2

Slide 14

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Session 10b: Example Problems

## **Workshop Problems on Task 11a: Detailed Fire Modeling**

This handout includes workshop problems on the different steps of Task 11: Detailed Fire Modeling. Problems are grouped according to the steps defined in NUREG/CR-6850. Detailed fire modeling will be conducted in the switchgear access room (Room 9) located in elevation 20 ft of the auxiliary building.

### ***Workshop Problem Set 11a-01***

**Step 1a: Identify and Characterize Compartments:** Review the following information necessary for fire modeling purposes.

- Room size: For the purpose of this exercise, assume the size of the room is 45' by 22' by 20' high.
- Wall boundaries: The surfaces, floor, ceiling, and walls are reinforced concrete. All the surfaces are 2' thick.
- Doors: The room has three doorways: 1) a double door connecting to switchgear room A, 2) a double door connecting to switchgear room B, and 3) a single door connecting to the stairwell. The size of a single door is 6.5' by 3'.
- Mechanical Ventilation: The switchgear access room has a mechanical ventilation system with a balance 5 air changes per hour.

**Workshop Problem Set 11a-02**

**Step 2a: Identify and Characterize fire Detection and Suppression Features and**

**Systems:** Review the following information necessary for fire modeling purposes.

- Prompt detection: Prompt detection is not credited since there is no incipient fire detection system in the room and no continuous fire watch.
- Prompt suppression: Prompt suppression is not credited since there is no continuous fire watch in the room.
- Fixed fire detection system/s (type, and sensor location): An automatic fire detection system is credited since the room is equipped with an automatic fire detection system. The location of the relevant detectors is specified in the corresponding scenario descriptions later in this document.
- Fixed fire suppression system/s (type and nozzle location): An automatic CO<sub>2</sub> system is credited since the room is equipped with an automatic CO<sub>2</sub> system. Upon smoke detection alarm, a timer starts providing 60 seconds delay for life safety purposes. The CO<sub>2</sub> is released after the delay time. The soak time is approximately 20 min.
- Fire brigade arrival time: The fire brigade arrival time is assumed to be 15 min.
- Delayed detection: Delayed detection is credited and assumed to be 15 minutes (consistent with the example in page P-14 of NUREG/CR-6850).

**Workshop Problem Set 11a-03**

**Step 3a: Characterize Fire Ignition Sources:** From the Task 6 (Fire Ignition Frequencies) calculation package, list the fixed ignition sources located in the switchgear access room (room 9) and assign a heat release rate probability distribution to each of them from Table G-1 of NUREG/CR-6850.

**Solution:** Table 1 lists the recommended answer to workshop problem 3.


**Table 1: Summary of ignition source characteristics in the switchgear access room.**

Equipment ID	Equipment Description	Case (Table E-1 of NUREG/CR-6850)	HRR Profile (Page G-6 in NUREG/CR-6850)
MCC-A1			
MCC-B1			
VITAL-A			
VITAL-B			
Transients			

**Step 4a: Identify Secondary Combustibles:** No workshop problem is associated with this step. The following discussion provides an example of how to identify and characterize secondary combustibles.

Sample Analysis for Step 4a:

For the purpose of this example, let's assume that there is one cable tray stack above each cabinet in the room. Each stack has two trays. The first tray is 1' above each cabinet. The second tray in the stack is 1.5' above the first tray. The trays are ladder-back. A pictorial representation of the secondary combustibles is provided in Figure 1.



**Figure 1: Pictorial representation of the secondary combustibles. Drawing not to scale.**

From Table 1, the cabinets in the switchgear access room will have a peak heat release rate of 211 kW. Heskestad's flame height correlation (Chapter 3 of NUREG 1805) suggests a flame height of approximately 4.6' above the ignition source. Therefore, the cable tray stack above the cabinet is expected to ignite and contributing to the fire intensity. Table 2 lists the Heskestad's flame height correlation analysis.

**Table 2: Heskestad's flame height correlation analysis.**

Heskestad's Flame Height Correlation	
<b>Inputs</b>	
Fire diameter [m]	0.6
HRR [kW]	211
<b>Results</b>	
Flame height [m]	1.4
Flame height [ft]	4.6

**Step 5a: Identify and Characterize Target Sets:** No workshop problem is associated with this step. The following discussion provides an example of how to identify and characterize target sets. In practice, this step requires highlighting of cable tray and conduit targets in room layout drawings based on cable routing analysis and plant walkdowns.

Sample Analysis for Step 5a:

For the purpose of this exercise, let's assume that there are two target sets in the room: 1) HCBT-35A and HCBT-35B, and 2) VCBT-20A, and VCBT-20B. These trays are identified in Figure 2. The trays have both thermo-set and thermo-plastic cables. Specifically, a fire damaging either the two horizontal trays or the two vertical trays will generate the postulated plant condition.




Figure 2: Cable tray locations in the switchgear access room

**Tray locations:**

- HCBT 35A: This horizontal tray comes into the switchgear access room from switchgear room A. The tray is the second tray in an elevated stack. The lowest tray in the stack is at elevation 33' (13' from the floor). The target tray, HCBT 35A, is at elevation 35' (15' ft from the floor and 2' above the lowest tray in the stack).
- HCBT 37B: This horizontal tray comes in the south direction into the switchgear access room from switchgear room B and turns west. The tray is the first tray in an elevated stack. It is located at elevation 37' (17' from the floor). At the point the cable tray crosses HCBT 35A, it is the third tray in the stack.
- VCBT 20A: This is a vertical cable tray in the south west corner of the room. The tray comes into the room through a floor penetration at elevation 20' and runs up to the ceiling.
- VCBT 20B: This is a vertical cable tray in the south west corner of the room. The tray comes into the room through a floor penetration at elevation 20' and runs up to the ceiling.

**Workshop Problem 11a-04**

**Step 6a: Define the Fire Scenarios to be Analyzed:** Define the fire scenarios to be analyzed in the switchgear access room using the information provided or collected in the first five steps.

- Fixed ignition source fire scenarios:

**Solution:**

- Transient ignition source fire scenarios:  
**Solution:**

**Step 7a: Conduct Fire Growth and Propagation Analysis:** For the purpose of this workshop, only two of the fire scenarios listed in the previous section are analyzed in detail: Scenario 1, and Scenario 4.

**Workshop Problem 11a-05:**

Determine if a fire in the ignition sources associate with scenarios 1 and 4 can produce room wide damage in the switchgear access room. If the ignition sources alone are not expected to generate room wide damage, determine the amount of secondary combustibles necessary to achieve it.

**Solution:**

**Workshop Problem 11a-06**

Determine the time to target damage, time to smoke detection, time to automatic suppression and the fire brigade arrival time for scenario 1.

**Solution:**

**Workshop Problem 11a-07**

Determine the time to target damage, time to smoke detection, time to automatic suppression and the fire brigade arrival time for scenario 4.

**Solution:**

**Workshop Problem 11a-08**

Let's assume that MCC-A1, which is the ignition source in scenario 1 it's a 4160V switchgear. In this case, a high energy arcing fault event should be also postulated and evaluated. Determine if the cable tray targets will be within the zone of influence of a high energy arcing fault.

**Solution:**

**Step 8a: Conduct Fire Detection and Suppression Analysis:** The detection and suppression is reflected in the risk analysis with the non-suppression probability, which is calculated using a Detection/Suppression event tree approach discussed in Appendix P of NUREG/CR-6850, Detection and Suppression Analysis. Recall that the switchgear access room is equipped with a smoke detection system, and an automatic CO<sub>2</sub> system. The CO<sub>2</sub> system has a 60 second warning alarm delay. In addition to these fixed systems, the fire brigade can also provide manual suppression activities.

Considering the above fire protection features, the suppression strategy in the switchgear access room can be summarized as:

1. Indication of smoke detection in control room
2. Control room sends an operator to the switchgear access room to confirm the fire
3. If fire is confirmed, the operator first if the automatic CO<sub>2</sub> system operated.
4. If further suppression activities are warranted after any of the automatic systems, manual suppression by the fire brigade may be used.

**Workshop Problem Set 11a-09**

Develop a detection suppression event tree for the fire protection strategy defined above.

**Solution:**

***Workshop Problem 11a-10***

**Step 9a: Calculate Conditional Non-Suppression Probability and Severity Factor:**

Determine the severity factor and the non-suppression probability for scenario 1.

**Solution:**

### **Workshop Problem 11a-11**

**Step 10a: Calculate Scenario Frequency:** Using the ignition frequency calculated in Task 6 for the ignition sources in the switchgear access room, and the severity factor and non-suppression probability calculated in the previous step for scenario 1, determine the frequency for fire scenario 1.

**Solution:**

## **Session 11a: Main Control Room Fire Analysis**



## Slide 3

Notes:

### Main Control Room Fire Analysis What is Different in the MCR?

- The control and instrumentation circuits of all redundant trains for almost all plant systems are present in the control room.
  - Redundant train controls may be installed within a short distance
  - Small fires within control panels may be risk-significant.
- The room is continuously occupied, which provides the capability of "prompt detection and suppression."
- Evaluating control room abandonment conditions is necessary.
  - Abandonment refers to situations in which control room operators are forced to leave due to untenable fire generated conditions (temperature, toxicity, and visibility).

Fire PRA Workshop, 2008, Washington DC  
Task 11b - Main Control Room Fire Analysis

Slide 3

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 4

Notes:

### Main Control Room Fire Analysis Recommended Steps

- Step 1: Identify and characterize main control room features
- **Step 2: Estimate control room fire frequency**
- Step 3: Identify and characterize fire detection and suppression features and systems
- **Step 4: Characterize alternate shutdown features**
- Step 5: Identify and characterize target sets
- Step 6: Identify and characterize ignition sources
- **Step 7: Define fire scenarios**
- **Step 8: Conduct fire growth and propagation analysis**
- **Step 9: Fire detection and suppression analysis and severity factor**
- **Step 10: Estimate failure probability of using alternate shutdown features**
- **Step 11: Estimate probability of control room abandonment**
- Step 12: Calculate scenario frequencies
- Step 13: Document analysis results

Fire PRA Workshop, 2008, Washington DC  
Task 11b - Main Control Room Fire Analysis

Slide 4

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

































## Session 11b: Example Problems

## **Workshop Problems for Task 11b: Detailed Fire Modeling in the Main Control Room**

### ***Workshop Problem Set 11b-01 (Example)***

***Step 1.b: Identify and Characterize Main Control Room Features:*** The following list summarizes the key features of the Main Control Room (MCR):

- The MCR is located at Elevation 55ft of the Auxiliary Building. See Drawings A-01 and A-07 for details.
- In this analysis, the kitchen and shift supervisor's office are included as part of Main Control Room proper.
- The dimensions of the MCR proper are as follows:
  - 15'ft high
  - 50 ft long
  - 30 ft wide
- Access to the kitchen and shift supervisor's office are solely from the control room
- The kitchen includes an electric water heater and a microwave oven, a refrigerator, a sink, kitchen cabinets and a small dining table and chairs.
- The shift supervisor's office includes a desk, a computer and printer, chairs and large quantity of reports, engineering documents and other paper documents.
- The Main Control Room includes the following:
  - A horse shoe shaped main control board (MCB) (see Drawing A-09 for details)
  - One free standing electrical panel where fire protection system display and controls are mounted
  - Two desks, assortment of chairs, book cases containing paper documents
  - Two printers with continuous feed paper roll.
- The main control board (MCB) is 22 feet long and 9 feet tall
- The fire protection panel has only one segment (there are no divisional walls within the panel). The panel is 8 feet tall, 3feet deep and 6 feet wide.
- The walls of the MCR are made of reinforced concrete with no penetrations in the ceiling and the walls except for a ventilation opening in the east wall. There are sealed control cable penetrations under the MCB and fire protection panel.
- Ventilation (heating, cooling and fresh air supply) is provided by a dedicated unit that provides fresh air from outside and can be shut closed by the MCR operators and put on a recirculation mode.
- There is a false ceiling 3 feet below the control ceiling of the MCR. The false ceiling is composed of light non-combustible boards held by an aluminum structure.

The following list summarizes the key features of the Main Control Board (MCB):

- The Main Control Board is composed of 7 segments (CB-1 through Cb-7). See Drawings A-01 and A-07 for details.
- Each Main Control Board segment is separated from the adjacent segments by a partial wall that extends halfway inside the panel.
- All cables enter the panel from below through sealed penetrations.
- The insulation of the cable and wires is a mixture of thermoset and thermoplastic insulation.
- The back and top of the control panel is closed. There are doors on the side walls that are normally closed.
- Instrumentation technicians enter the Main Control Board for various tasks no more than once per week.
- There are no power cables in the Main Control Board.

## Workshop Problem Set 11b-02

**Step 2.b: Estimate Control Room Fire Frequency:** For the overall MCR fire frequency the equation provided on pages 11-33 and 11-34 of NUREG/CR-6850 has been updated to read as follows:

$$\lambda_{MCR} = W_{L,MCR}(\lambda_{MCB} + W_{PWC,Elec.Cab,MCR}\lambda_{PWC,Elec.Cab.} + W_{transients,MCR}\lambda_{transient} + W_{welding,MCR}\lambda_{welding} + W_{Cable,MCR}\lambda_{cable})$$

where:

- $\lambda_{MCR}$  : Main Control Room fire frequency
- $W_{L,MCR}$  : Location weighting factor for the MCR
- $\lambda_{MCB}$  : Main Control Board fire frequency (Table 6-1, bin 4)
- $W_{PWC,Elec.Cab,MCR}$  : Ignition source weighting factor of Plant Wide Electrical Cabinets found in the Main Control Room.
- $\lambda_{PWC,Elec.Cab.}$  : Fire frequency of Plant Wide Electrical Cabinets (applies to all electrical cabinets in the plant including those panels in the MCR that were not labeled as MCB.) (Table 6-1, bin 15)
- $W_{transients,MCR}$  : Ignition source weighting factor of Control/Aux/Rx Bldg Transient Fire events that may occur in the MCR. This fraction should be computed using the same method as for transients for other parts of the location using the following influencing factors:
- Maintenance – Low
  - Occupancy – High
  - Storage – High (reflecting large quantity of paper materials)
- $\lambda_{transient}$  : Control/Aux/Rx Bldg Transient fire frequency (Table 6-1, bin 7).
- $W_{welding,MCR}$  : If welding is allowed in the MCR during power operation, this ignition source weighting factor should be evaluated in the same way as that for transient fire using the following influencing factors:
- Maintenance – Low
- $\lambda_{welding}$  : Control/Aux/Rx Bldg, transient fires caused by welding frequency (Table 6-1, bin 6).
- $W_{Cable,MCR}$  : Ignition source weighting factor of Control/Aux/Rx Bldg Cable Fires Caused by Welding and Cutting that may occur in the MCR. This fraction should be computed using the same method as for transients for other parts of the location using the following influencing factors:
- Maintenance – Low
- $\lambda_{cable}$  : Control/Aux/Rx Bldg, cable fires caused by welding frequency (Table 6-1, bin 5).

**Workshop Problem Set 11b-02 (continued)**

**Step 2.b: Estimate Control Room Fire Frequency:** Using the information provided in this Sample Package, and the above formula copied from NUREG/CR 6850, estimate the frequency of fire for the SNPP MCR.

$W_{L, MCR} =$  per \_\_\_\_\_

$\lambda_{MCB} =$  per \_\_\_\_\_

$W_{PWC, Elec. Cab, MCR} =$  per \_\_\_\_\_

$\lambda_{PWC, Elec. Cab.} =$  per \_\_\_\_\_

$W_{transients, MCR} =$  per \_\_\_\_\_

$\lambda_{transient} =$  per \_\_\_\_\_

$W_{welding, MCR} =$  per \_\_\_\_\_

$\lambda_{welding} =$  per \_\_\_\_\_

$W_{Cable, MCR} =$  per \_\_\_\_\_

$\lambda_{cable} =$  per \_\_\_\_\_

$\lambda_{MCR} =$

### **Workshop Problem Set 11b-03 (Example)**

#### **Step 3.B: Identify and Characterize Fire Detection and Suppression Features and Systems:**

The following list summarizes the key features of the fire detection and suppression systems of the Main Control Room (MCR):

- At least two qualified operators are present in the MCR at all times.
- There are smoke detectors under the false ceiling
- There are smoke detectors above the false ceiling
- There are portable fire extinguishers inside the kitchen and inside the Control Room area
- There is a wet hose reel in the Control Room Access area that can reach anywhere within the control room
- The ventilation system can be switched to smoke purge mode to exhaust the air from the control room to the outside.

## Workshop Problem Set 11b-04 (Example)

**Step 4.B: Characterize Alternate Shutdown Features:** The following list summarizes the key features of the Alternate Shutdown Panel:

- The Alternate Shutdown Panel is located at El. +20ft, in the SWG Access Room. The panel is located at the North wall between the two switchgear room doors.
- The following list of components can be controlled from the Alternate Shutdown Panel.

Equipment ID	Equipment Description	Power Supply	Control Room Panel
HPI-A	High pressure safety injection pump A	4.16kV Bus A	CB-5
HPI-B	High pressure safety injection pump B	4.16kV Bus B	CB-5
AFW-A	Motor driven AFW pump A	4.16kV Bus A	CB-3
AFW-C	Motor driven AFW pump C	4.16 kV Bus 2	CB-3
AOV-2 (SOV-2)	Letdown isolation valve	125 VDC Bus B	CB-5
MOV-1	HPI valve	480V MCC A1	CB-5
MOV-2	VCT isolation valve	480V MCC B1	CB-5
MOV-9	HPI valve	480V MCC B1	CB-5
MOV-10	AFW discharge valve	480V MCC A1	CB-3
MOV-11	AFW discharge valve	125 VDC Bus B	CB-3
MOV-14	AFW turbine steam line isolation valve	125 VDC Bus B	CB-3
MOV-15	AFW steam inlet throttle valve	125 VDC Bus B	CB-3
MOV-18	AFW C Pump Discharge	480 V MCC-2	CB-3
MOV-19	AFW test line isolation valve	480 V MCC-2	CB-3
LI-1	RWST level	120VAC Bus A	CB-5
LI-2	RWST level	120VAC Bus B	CB-5
A-1	AFW motor high temp	120VAC Bus A	CB-3
EDG-A	Train A Emergency Diesel Generator	PNL-A	CB-6
EDG-B	Train B Emergency Diesel Generator	PNL-B	CB-6

- To activate the alternate shutdown panel, the operators have to enter each switchgear room separately and transfer the controls of the desired components from the Main Control Board to the Alternate Shutdown Panel.
- A separate set of procedures exists for taking control at the Alternate Shutdown Panel.

**Workshop Problem Set 11b-05**

**Step 5.b: Identify and characterize target sets:** Identify at least five target sets for the Main Control Room by inspecting drawings DWG A-07 and A-09 and other information provided in this Sample Package.

Target Set ID	Items in the target set	Basis for selecting target set

Workshop Problem Set 11b-06

**Steps 6.b: Identify and Characterize Ignition Sources:**

**Steps 7.b: Define Fire Scenarios:** For the target sets provided in the solution of the preceding problem set, identify the corresponding ignition sources and fire scenarios.

Target Set ID	Ignition Sources	Fire Scenarios
MCR-01		
MCR-02		
MCR-03		
MCR-04		
MCR-05		

**Workshop Problem Set 11b-07**

***Step 8b: Conduct Fire Growth and Propagation Analysis***

***Step 9b: Detection and Suppression Analysis and Severity Factor:*** Using the information provided in the solution to Problem Set 11b-03 and Figure L-1, conduct fire propagation, detection and suppression analysis for the following fire scenarios and calculate scenario frequency:

MCR-03.1

$$\text{SFxPNS} =$$

$$\lambda_{\text{MCR-03.1}} =$$

MCR-04.1

$$\text{SFxPNS} =$$

$$\lambda_{\text{MCR-04.1}} =$$

## Workshop Problem Set 11b-08 (Example)

**Step 11.B: Estimate Probability of Control Room Abandonment:** The following is an example case presented here as an illustration on how the probability of abandonment can be estimated

The probability of abandonment represents the likelihood of a fire generating adverse environmental conditions meeting the criteria for control room evacuation described in Task 11 of NUREG/CR-6850. The abandonment criteria suggests that analysts must assume operators will leave the control room if:

- The room or hot gas layer temperature reaches 200 °F (93 °C).
- The heat flux to the control room floor is above 1 kW/m<sup>2</sup>,
- The hot gas layer is 6 ft or lower above the floor and has an optical density of 3.0 1/m. Such optical density will prevent operators to see through smoke.

Considering these criteria, the abandonment probability was calculated as follows:

1. From Task 6, the ignition sources in the main control room are:
  - the main control board,
  - vertical electrical cabinets and
  - transients.
2. The probability distribution for heat release rate Case 5 in Table E-1 of NUREG/CR-6850 has been assigned to the main control board and other electrical cabinets. This distribution applies to cabinets with un-qualified cables and fire spreading to more than one cable bundle.
3. The time to abandonment was calculated deterministically for the range of heat release rate values defined by the probability distributions listed in item 1 above. The zone model MAGIC was used for these calculations. Relevant inputs to MAGIC include the geometry of the main control room complex, and the mechanical ventilation system. The time to abandonment is the shortest time when one of the three defined above criteria is met.
4. Each MAGIC result (i.e., the time to abandonment resulting from a specific heat release rate input) is associated with a severity factor from the corresponding probability distribution for heat release rate. Similarly, there is a corresponding non-suppression probability for each MAGIC result. The non-suppression probability captures the likelihood that the fire will not be suppressed before the calculated abandonment time.
5. The resulting abandonment probability and average abandonment times are a weighted average of all the probabilities of fire sizes and corresponding non-suppression probabilities.

Table 3 summarizes the calculation of abandonment probabilities and average abandonment times for electrical cabinets. The first column in Table 3 refers to the heat release rate value used in MAGIC for determining the time to abandonment. The column labeled SF lists the severity factor associated with the heat release rate value (taken from Appendix E of NUREG/CR-6850). The Time column lists the resulting time to abandonment calculated with MAGIC. The column labeled  $P_{ns}$  lists the non-suppression probabilities. In general,  $P_{ns} = \exp(-\lambda t)$  where  $\lambda$  for the control room is 0.33 (see Appendix P of NUREG/CR-6850), and  $t$  is the time listed in the "Time" column.

The average abandonment time is calculated as

$$\hat{t}_{ab} = \frac{\sum t_i \cdot SF_i \cdot P_{ns-i}}{\sum SF_i \cdot P_{ns-i}}$$

which is the weighted average of the abandonment times calculated with MAGIC. The abandonment probability is calculated as

$$P_{ab} = \sum SF_i \cdot P_{ns-i}$$

which can also be interpreted as an average non-suppression probability since the  $SF_i$ 's for all possible heat release rates add to one. The following results are obtained using the two equations above:

- Electrical cabinets: Average abandonment time is approximately 8 minutes and the probability of abandonment is approximately 1.3E-2.
- Transient fires: For the purpose of this study, the time to abandonment and the abandonment probability calculated for electrical cabinet fires is assumed to be the same as for transient fires. This is a conservative assumption since the heat release rate profiles for the electrical cabinet fire suggests higher fire intensities with faster profiles that are expected to result in faster abandonment times.

**Table 3: Time to abandonment and abandonment probability analysis for electrical cabinet fires. Calculations assume no mechanical ventilation system in the room.**


HRR [kW]	SF	Time to Abb (min)	Pns	SF·Pns
1	0.0E+00	60	2.5E-09	0.0E+00
42	6.4E-01	60	2.5E-09	1.6E-09
197	1.6E-01	16	5.1E-03	7.9E-04
337	8.1E-02	11	3.1E-02	2.5E-03
475	4.7E-02	9	4.9E-02	2.3E-03
612	2.9E-02	8	6.4E-02	1.9E-03
749	1.8E-02	8	8.0E-02	1.4E-03
886	1.1E-02	7	9.4E-02	1.0E-03
1024	7.0E-03	7	1.1E-01	7.7E-04
1162	5.0E-03	6	1.2E-01	6.2E-04
1299	3.0E-03	6	1.4E-01	4.1E-04
1436	2.0E-03	6	1.5E-01	2.9E-04
1573	1.0E-03	6	1.5E-01	1.5E-04
1710	1.0E-03	6	1.6E-01	1.6E-04
1847	1.0E-03	5	1.7E-01	1.7E-04
2276	1.0E-03	5	2.0E-01	2.0E-04

## Simulations with MAGIC Software Package

As mentioned earlier, time to abandonment calculations were conducted using the zone model MAGIC. MAGIC is a fire two-zone model, which provides the capability of simulating the development of a hot gas layer in rooms with and without mechanical ventilation systems. Key

inputs to MAGIC includes: 1) room geometry, 2) wall thickness and construction, 3) specifications of the mechanical ventilation system, 4) fire size and 5) fuel properties.

The control room was modeled in MAGIC as a single room. The fire was located in the center of the common control room area. Figure 3 illustrates the geometry as modeled in MAGIC. Notice that the control room area was modeled as having a rectangular floor base with equivalent floor area. Simulation times were 20 minutes.



**Figure 3: Control room geometry as modeled in MAGIC**

The following were considered when running MAGIC:

- Room size and construction: The control room area was modeled with an effective floor area of 67' x 60' and a ceiling height of 23'.
- All wall materials were modeled as 2' thick concrete.
- Horizontal openings: As illustrated in Figure 3 above, the control room was modeled as having one 3' x 6' open door.
- Mechanical ventilation: The mechanical ventilation system is modeled as a balanced supply/exhaust system with a flow rate of 2.73 m<sup>3</sup>/s. The room also has a smoke extraction system with two vents, each extracting 3.7 m<sup>3</sup>/s. This system is manually activated by the fire brigade.
- For the purpose of the simulation, it is assumed that the smoke extraction system operates 10 minutes after the fire starts. At this point, the normal system is turned off.

- Heat release rate profiles: The heat release rate profiles follow the guidance provided in Appendices E & G of NUREG/CR-6850. That is, the peak heat release rates listed in Tables E-6 and E-9 in NUREG/CR-6850 for electrical cabinets and transients respectively were used. It was assumed that the growth profile is  $t^2$  growing to a peak in approximately 12 minutes.
- Fuel Properties: Fuel was assumed to have a soot yield of 0.18.

***Relevant outputs/Abandonment criteria***

MAGIC creates one output file for each simulation. The output files contain the information necessary for determining the time to abandonment. Specifically, the following outputs were evaluated:

- hot gas layer temperature in the MCR area,
- hot gas layer height in the MCR area,
- Total heat flux to Target 1, and
- optical density in the MCR area.

Specific MAGIC inputs are included in the MAGIC input files. Figure 4 illustrates a snapshot of a MAGIC simulation with and without mechanical ventilation. Notice that the simulation with no mechanical ventilation suggests the development of a hot gas layer and flows moving out through the open doors.




Figure 4: Pictorial representation of a MAGIC simulation of the control room fire

## **Session 12: Multi-Compartment Fire Analysis**



















**Session 13: Seismic Fire Interaction**















# Conclusion

## Part 1: Integration









## **Part 2: Lessons Learned and Insights**



## Slide 8

Notes:

### Lessons Learned and Insights *Demonstration /Pilot Studies*

- The procedures were individually tested during development
- All the procedures worked, and seemed to be of reasonable depth, scope, and clarity to make implementation practical
- First top-to-bottom testing as a full, consolidated, and complete set ongoing by 805 pilots and other early adopters

Fire PRA Workshop, 2006, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 8

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 9

Notes:

### Lessons Learned and Insights *Demonstration /Pilot Studies (continued)*

- Numerical results are being developed, but remain preliminary
- The potential for "hidden surprises" was acknowledged from the outset, and there have been some...
  - Others likely remain to be discovered, and **you** may find them
- *The NFPA-805 FAQ process is the primary mechanism currently available to address application issues*
  - As a user, you should monitor the FAQ process
  - FAQ resolutions may resolve your questions as well
- We continue to seek user feedback and experience – the procedures are intended to be "living documents" to at least some extent

Fire PRA Workshop, 2006, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 9

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)















## Slide 24

Notes:

### Lessons Learned and Insights In-process FAQs (continued)

- FAQ 08-0049
  - Issue:
    - The cable fire empirical spread model (tray-to-tray, stack-to-stack) has been misapplied in pilot applications
    - Reviewers concluded that misapplication resulted in very conservative fire growth and risk results
  - General approach to resolution:
    - Clarify the bounds of the empirical model to avoid misapplication
  - Status:
    - Proposed resolution has recently completed final review within the RES and EPRI teams
    - Staff and industry final review pending
    - Final revision, as needed, pending
  - Note: as a follow-on, team plans to generate a new FAQ to address broader needs relative to cable fire growth modeling

Fire PRA Workshop, 2008, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 24

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 25

Notes:

### Lessons Learned and Insights In-process FAQs (continued)

- FAQ 08-0050
  - Issue:
    - The fire non-suppression curves as cited as reflecting suppression performance *after* fire brigade response time but a significant fraction of the duration data used in curves includes brigade response time
    - Fire brigade may not be getting adequate credit for suppressing fires prior to damage
  - General approach to resolution:
    - EPRI team has reviewed data and proposed an alternative set of non-suppression curves that would include fire brigade response time
  - Status:
    - Work to date has largely been confined to EPRI team
    - NRC team is currently reviewing proposed resolution
    - Staff and industry reviews pending

Fire PRA Workshop, 2008, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 25

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 26

Notes:

### Lessons Learned and Insights *In-process FAQs (continued)*

- FAQ 08-0051
  - Issue:
    - The guidance does not provide a method for estimating the duration of a hot short once formed.
    - This could be a significant factor for certain types of plant equipment that will return to a "fail safe" position if the hot short is removed
  - General approach to resolution:
    - Analyze the existing cable failure modes and effects test data to determine if an adequate basis exists to establish hot short duration distributions
  - Status:
    - Initial data analysis has been completed and results are under team review
    - NRC staff and industry review pending

Fire PRA Workshop, 2008, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 26

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)

## Slide 27

Notes:

### Lessons Learned and Insights *In-process FAQs (continued)*

- FAQ 08-0052
  - Issue:
    - No guidance on fire growth times for transient fires
    - Guidance not clear as to which non-suppression curve would apply to transient fires in the MCR (i.e., transient curve or MCR curve)
  - General approach to resolution:
    - Review existing test data and develop guidance for transient fire growth times
    - Clarify non-suppression curve application for this case
  - Status:
    - Initial team position drafted and undergoing review within the teams
    - Staff and industry reviews pending

Fire PRA Workshop, 2008, Bethesda, MD  
Integration, Lessons Learned and Insights

Slide 27

A Collaboration of U.S. NRC Office of Nuclear Regulatory  
Research (RES) & Electric Power Research Institute (EPRI)





## Part 3: Perspective





# Appendices

## Appendix A: Questions Asked in Module 3 Sessions

**NRC Disclaimer:** Appendix A is intended solely for use as part of a training tool. No portion represents NRC conclusions or Regulatory Positions, and should not be interpreted as such.

### Session 1: Plant Partitioning

#### QUESTION

*Slide 21: Who conducts these plant walkdowns? Are they done in-house or by contractors, for example?*

#### RESPONSE

All of the people you mentioned are part of this effort. Contractors, utility people, co-ops, recent graduates, everyone. The level of experience and knowledge needed to do this must not be taken for granted.

### Session 2: Fire Ignition Frequency

#### QUESTION

*Presentation b, page 6: I still don't get how to consider  $W_L$ .*

#### RESPONSE

I basically try to start fresh and say how I'm going to count the equipment, and once you make that decision, this becomes simpler. For example, if it's very easy for you to assign equipment to one unit or another, which is not always the case, then you just count them by unit and forget about this stuff. It's all 1. The reason I'm saying that it's not all that easy is because if we're trying to count equipment by unit, where one panel is assigned to unit 1 and another to unit 2. Then, you go to a room and there is a panel with no label. You don't know what it is, so your ideal situation breaks down. So, this helps you count things. Then, you bring into the picture the question of whether or not the equipment is shared. At this point, you can do what Marty said, like counting half of a pump. Usually, in the control room, it can be discerned what corresponds to unit 1 or unit 2, and either you can split them in half or assign the board to one unit. If there is the case of a problem that is swinging, it may be better just to count it as half. If you are clear on how you are counting, then this does not pose a problem; either count it as half if it's shared, or count it as one.

If, on the other hand, you have a shared control room and you counted only one unit, without even considering the other unit, then the ignition sources for that room are twice what you have counted. So the contribution for the fire source is twice the ignition frequency. If you have a generic frequency for a single unit but have twice the units, then you have to double it. My advice, therefore, is to consider how and what you are counting in the interest of being systematic. If you're just doing a localized analysis for the control room, you can just count

something as one unit, but if you have a shared room, you need to add that multiplier because you are not counting the rest otherwise. (The answer to B is 2.)

The key to this is that the frequency in 6-1 applies to the cabinet in the unit that you are analyzing. That is the count on which Francisco is focusing. That frequency is the total frequency of fire ignition for a specific type of component. If you count that accurately as best you can, then in a room where the other unit is in there also, you can do what I suggested and you will be fine. The point is that this whole thing is unit based and that any new components must have units that match the existing components.

#### QUESTION

*Page 6: Would this be equivalent to saying that a fire that starts in unit 2's control board is guaranteed to spread to unit 1's board?*

#### RESPONSE

No. It is not necessarily guaranteed, but it is a possible contributor. You're establishing the frequency of fire within that room. Any fire. Actually, we're trying *not* to count it twice. That's what we need to be careful with, double-counting. This is equivalent to counting the two units, such that where you have 400 panels instead of 800, to simply double all the frequencies. When you do that, you will get the right weighting factors. Whatever you do, prevent that double counting, because the frequencies are per unit, and you have two units. Make sure you don't double-count.

#### QUESTION

*Page 6: I think you hit the nail on the head that if you're doing the per-component count for the entire space, that you wouldn't need the sign there, a WL of 2, if you count every source in there. If you know what's in unit 1 but are unsure of what's in unit 2, but you know that it has a similar configuration, then you could assume a WL of 2 for that space, that time in your analysis, right?*

#### RESPONSE

If you count everything, and you counted it well, you will get the weighting factors correctly.

#### QUESTION

*Presentation A, slide 22: Suppose they're done horizontally?*

#### RESPONSE

Again, you need to define your own reference cabinet and compare that against the reference cabinet. Define vertical segments of some kind and count it that way. You see, what it comes down to is that that specific cabinet vs. the rest of the cabinets in the plant that are within that group; all of the frequencies from 6-1 will be assigned to all of them. You must ask yourself how much of the frequency you will assign to this cabinet from another cabinet. If you come up with an internally consistent scheme, this will give you the best approach for use. All of your cabinets are horizontally divided, right? All of them are. Each horizontal division will be assigned one count. It comes down to pro-rating your total frequency to each item.

# Session 3: Scoping Fire Modeling

## A BRIEF REVIEW

*Reviewing the risk equation.*

*Points to lambda sub G; This is the generic frequency. Where does it come from? Inaudible answer. Points to W sub is-1. What is this? Where is it coming from? Walkdowns, and counts of ignition sources. This is a split fraction of ignition sources. What is this? Points to severity factor. Where is it coming from? Heat release rate. Somebody can tell me how we come up with the severity factor? Where does it come from? HRR that would damage your target. We assign a distribution to each ignition source, right? We found the HRR that would damage the target, found that value in the distribution, and the area under the curve to the right is, what Dean said, 2% or less, then you can screen it. We say that it is unlikely that the fire will get that big.*

## QUESTION

*Slide 13: So we screen ignition SOURCES if the critical value is higher than the 98<sup>th</sup> percentile?*

## RESPONSE

Yes. The only cautionary note is that the critical value should come only from the ignition source. If you have trays above the ignition source, the HRR may not come only from the ignition source. That may be one you have to further analyze to see what the cable trays would do. Only an isolated ignition source, incapable of propagating, would be able to be screened. This admittedly limits its applicability, given some of the complex geometries that we have, but that's the way to use it.

## QUESTION

*Slide 13: How do you determine whether or not an ignition source will screen?*

## RESPONSE

Let's do two cases. If, above your cabinet, you have a stack of cable trays, and you start a fire; if the only cable you care about is in a tray remote from the ignition source, then you can screen the source. If, however, you have the ability to propagate a fire up, you can not simply screen the fire, even if the actual target is remote from the fire.

## QUESTION

*Slide 7: How would you organize your list of design fires?*

## RESPONSE

I would strongly suggest a section, when you are dealing with either scoping fire modeling or detailed fire modeling, that clearly says "these are the types of fires I have, and I'm going to use this generic values, or I have these plant-specific values," and you just get it over with in a clear

section that you can reference, writing justifications for what your damage criteria are. Keep the HRRs in a centralized place where you know where your justifications are. That should work fine.

#### QUESTION

*Slide 7: What conduit do you use in this fire modeling?*

#### RESPONSE

The conduit is the same as the type of cable that you have inside. That was thermoset cable in a conduit, so we used 625.

#### QUESTION

*Slide 13: Do you treat transient fires in the same probabilistic manner as other ignition sources, by saying where they are most likely to be located?*

#### RESPONSE

What Walt is telling me is that this FAQ will need to be more detailed in addressing types of panels and transient fires. It is also silent on when to put a transient fire. People love to talk about trash bags. Where do you place a trash can fire? All of these are questions that are not addressed in 6850. Hopefully this FAQ will address it.

#### QUESTION

*Slide 13: What I'm hearing is that one thing being accounted for in the FAQ is that these correlations have not been developed for use in multi-dimensional cabinet fires. It seems that this is not an appropriate application for this model. A fire inside of an enclosure has an obstructed plume, resulting in a three-dimensional fire, rather than a two-dimensional fire. Now, there are ways to get around that. When I'm putting on my peer review pack, or I'm doing the analysis myself, what, when you're talking about justification, has been done in the way of discussion about whether these are really applicable to these cables and, if you recognize that they aren't, what documentation do you need to provide to be able to say "we handled this in a manner that deals conservatively with the answer to that question"?*

#### RESPONSE

You're right in all your points. For fires inside cabinets, you're right, these are not applicable, and I think our treatment has been "forget about the cabinet, we just put our fire there." Hopefully the effects of the cabinet walls will be to the benefit of those targets, so not having it adds that conservative approach.

#### QUESTION

*You could say that we measured the heat release rates and determined how much energy is being released there, and that the distribution of this release is unimportant because the plumes have different amounts of energy. You can postulate a single plume coming out. Like you said, I'm not saying that this is a show-stopper, but what I would do is go back to the FAQ and say "what's the bounding analysis where I can locate my fire?" The answer to your analysis may not*

*be favorable, and that's what I'm reading in this FAQ; that this answer is too conservative, and that we want something a little better, but we don't have the means to really do that. At this point, I don't think there are enough test data or analysis calculations.*

#### RESPONSE

In a way, that's why 6850 was silent, because this task is somewhat beyond the state of the art. That was the task of these documents, state of the art. I agree with that argument. I'm telling you that so far, once you assume this fire, the guidance is to use an unobstructed plume up to where you encounter this obstruction. In my example, I intentionally included intervening trays that are not targets and advised you to screen them if you have obstructions.

#### QUESTION

*Looking at some of these analyses, though, if you just plug and chug this, I will have to flag it and ask you to show me why this limitation is valid. There may be a valid reason, though, if you take that HRR and situate it atop the cabinet. You may not have a decent argument if it is situated on the floor. It is by no means a showstopper, but have there been discussions about this issue? When you get to the end of this, it could be a showstopper.*

#### RESPONSE

There is either limited guidance or questions being raised on the FAQ. The only point I want to make about the FAQ is that its focus is very narrow, and is not intended to expand into a research-wide paper. Another point to be made is that some of the arguments used in this may come on risk terms, rather than on fire modeling terms. They may choose to be very conservative, rather than using the best inputs, because they can accept the more conservative plant impacts.

#### QUESTION

*So then these equations are justified by guesses about conservatism?*

#### RESPONSE

I'm not saying that that's the justification. I am saying that the equations we have are what we have, not something new developed for the nuclear industry or something, and that there are documents and training describing its use and limitations. Analysts are using them within the limitations. I suggested that not all of the justifications will be on a fire modeling basis. There are other issues that provide these checks, not just because of the use of the model. In a risk analysis, the justification will not simply be the use of this model. By the time you know what the impact is, you must also know the cables involved, what the impact is, how the circuit behaves, and many other things involved in it.

Are you suggesting that the models we have are not conservative? Because the models can be quite conservative, we hope. Are you suggesting that we are guiding people in the wrong direction?

## QUESTION

*I don't think that there's sufficient guidance to tell people how to take correlations developed from two-dimensional pool fires and three-dimensional wood grids and apply them to an electrical cabinet. What you're saying with the lack of guidance here is that it's okay to do that. I don't see anything here that says "electrical cabinets: beware, because this is how these empirical correlations have been developed." They're outliers.*

## RESPONSE

I don't see that when we suggest "view the fire and forget about these cabinet walls" we are misapplying the correlation.

## QUESTION

*I don't think that you are. I think that one solution would be to do a bounding analysis where you find the HRR and find a reasonable representation of the area of the fire, and that will be all I've got. What I see in the FAQ is that this tends to be the most conservative approach, and we're asking for a less conservative approach. I don't think we're there yet, I don't think that we have the fundamentals to put forth this less conservative approach. That is guidance that could be provided to people, by saying "look, we understand this stuff doesn't work, but here's how you get around it."*

## RESPONSE

It's not that it doesn't work, it just yields a very conservative answer.

## QUESTION

*We don't know if it yields a conservative answer.*

## RESPONSE

That's the impression I'm getting, is that they're getting very short time periods, and that's giving them headaches.

## QUESTION

*We never validated the cabinet fires with the correlations. That's never been done. It's just been in applications.*

## RESPONSE

Then what you're suggesting is that what we have in the guidance is not conservative. That's the key here. What we have here is the important element that we have to fault on the side of the conservative.

## QUESTION

*The bounding analysis places the fire on the exterior of the cabinet, and thus far, I fail to see this addressed in the FAQ.*

## RESPONSE

Any reading that you're doing on this FAQ is not final yet. The FAQ is still in process, and these concerns that you raised are being considered. FAQ is a misleading term; it's actually only one question. This is currently under analysis. I am the first one to agree with you; from an experimental, analytical perspective, we may not have the tools to address it with math. That's not the only place in risk analysis where this is an issue.

## QUESTION

*But it has to be addressed, I think. There is a workaround, and it just needs to be put forth so that everybody knows exactly how we're getting around the limitation. All of these correlations were verified, right?*

## RESPONSE

Well, verified by experiment. That's how it's done.

## QUESTION

*But in the DMD study, if I remember correctly, you screened those out because they weren't the correct equipment. You can't use that in your correlation because it was essentially the junk data from another experiment. You did it for other well-known, well-characterized fires.*

## RESPONSE

We have to be careful here. I agree with you in that these correlations are applicable if you have a fire inside a panel and you want to consider this panel, walls, and the effect that the cabinet will have. Do we have a correlation for that? Do we have guidance on how to do that? No. People report a heat release rate and assume there is no cabinet. In this case, if there are no obstructions, we have said "yes, use this plume correlation". Would I want to see further research and a model to account for that? Probably yes. Do we have it? No, that's why it's not here.

## QUESTION

*But then specifically, how do you justify the use of the correlations this case?*

## RESPONSE

By assuming no cabinet. Is there an argument that yes, you actually have a cabinet and aren't accounting for it? Of course.

## QUESTION

*So that's an assumption and the engineering validates these assumptions, and so, to me, the best guidance would be to take the equipment fire and measure that heat release rate, and then place it at the top of the cabinet as the bounding analysis.*

## RESPONSE

That's fine. That's what Walt says that his inspectors are doing, and I know plants are doing that in some cases.

## RESPONSE

*I think that people who are doing these analyses need to understand that this is merely a workaround to do this.*

## QUESTION

*Why isn't fire modeling used every time? Wouldn't that help to evaluate each scenario in context?*

## RESPONSE

The general approach in PRA is that you start with several failures. Rather than postulating no damage, you start with fires that damage everything. From there, you make reductions. When you apply fire modeling, you do so with the goal of proving that the target is undamaged, because this disproves the initial assumption. You start assuming all these failures. If you have high-risk, sharpen your pencils and see what you can get. It is in this reduction that you start being less conservative because you're not killing everything, but within the application, your conservatism is built in, and hopefully, the way you use these models is on the conservative end, given that they are not the exact geometries present in each nuclear power plant scenario. When we were doing the validation work, this is a point we raised. To get validation for every single nuclear power plant scenario is probably impractical in the near future, due to all of the geometries that can be observed in different plants. This is part of the state of the audience.

# Session 6: Damage Criteria

## QUESTION

*Slide 3: How were the cables tested? Did they short and that caused the ignition?*

## RESPONSE

Well, it's just cables under a big flame. Those tests were trying to figure out the probabilities and how this circuit behaves. So, yes, the cable is exposed to either a plume or flames.

## QUESTION

*Was there a documented pilot, a point where the cable ignited each time?*

## RESPONSE

Once the experimenters observed a short, the cable shortly thereafter ignited and this was the pilot you were talking about.

# Session 7: Detailed Fire Modeling and Single Compartment Fire Scenarios

## QUESTION

*Slide 10: Can you set boundaries for ignition by saying "this is the closest ignition source, therefore since it doesn't catch, all of the others won't ignite also"?*

## RESPONSE

Why, yes. With the right tools like a well-organized database that can talk to the PRA, you can play games like failing all of the conduits and see if you can use that approach to screen the cable trays for something. That sounds easier than what it is if you don't have the right tools, because when it's not hooked up, this becomes a manual process. But once it is, and you understand your ID systems of how trays and conduits are labeled, then you can do cable database events on a larger scale in order to screen things. I have seen databases where the cable and raceways would have so-called "rooms" within compartments, based on column lines, because the cable and raceway database was based on these column lines. So we defined these rooms within the fire compartments. Since everything was so well-labeled, we could go and say "fail a room" in that compartment. That would be a portion of it defined by column lines where all the conduits and trays there could be set with trays associated to them. This would allow us to see where we really needed to go and sharpen our pencils. I stress that this sounds simpler than what it is, because it requires a well-structured database with good data. In plants that have that, it is straightforward by postulating fires once you have your ignition sources. But if it takes some building to do and some data cleanup, then so be it.

## QUESTION

*If you use CFAST, you don't have to verify and validate your model, do you?*

## RESPONSE

That's our intent. We want it to be such that if you use CFAST within reasonable bounds of what was V&Ved, then that's your V&V. But a V&V has its own limitations, a set of extrema that were set for it, so not every single feature in CFAST was V&Ved. The sprinkler feature, for example, lacks the verification process applied to the cable fire modeling within CFAST. The way it works is that we classify the results, and say "this kind of overestimates", or says that one part is right on target. Our intent, to the best extent possible, is that if you use CFAST, you don't have to write an appendix explaining your validation. I agree with you, that before the V&V, we would have to write an explanation of the model we were choosing, which is why we have this suggestion now: it is very convenient.

## QUESTION

*If you use CFAST, do you need to have it V&Ved on each computer? Is it workstation-specific, like in DOE?*

## RESPONSE

I will let higher pay grades answer that question. I don't know.

# Session 8: Detection and Suppression

## QUESTION

*Slide 15: Where is the data for the BWR containment? Four of them are not directed. Wouldn't we then use the PWR containment?*

## RESPONSE

I would say so. We didn't have data for the BWR containment to develop this. We knew that there were a few that were not. There are four in this country, but we only thought there was one. I guess we were off.

## QUESTION

*Does this assume a standpipe with a hose is available, or a fire extinguisher, or perhaps a mix?*

## RESPONSE

This is the deal with these curves. We have the data from the fire events database, and some of that data lists time (fire duration), or time to suppression, or both. So a subset of the data that we use for the frequency has that kind of information. In addition, we only use data after 1980, which is when appendix R kicked in. That's the data we use for these curves. Admittedly, not all of the data has this information. When available, we use the time to suppression, but if the duration was available and not suppression we will use the duration. This is part of the FAQ, saying "well, those duration times are longer than the actual time to suppression". By the way, the Browns Ferry fire was listed in order of minutes that they finally decided to use water after hours of trying to use extinguishers. You have to be careful with those numbers. The bottom line is that if the suppression was available, we picked that number. If not, then if the duration was available, we picked that number. That may be a limitation of this. I'm talking now about a subset of the data, post-1980, and data that had either suppression or duration available, and then we started excluding events that were suppressed by fixed systems, or self-extinguished. So all of this is basically someone with an extinguisher or the fire brigade coming. These are the events that made it to these curves, and with those events we developed this thing.

## QUESTION

*So for anything other than a brigade we don't use this time as a factor in the previous chart?*

## RESPONSE

Wrong. Like I was telling him, even for the activation of the sprinkler system, you need to calculate the time for that activation.

## QUESTION

*The suppression probability you gave on slide 9: this is the probability of non-suppression?*

## RESPONSE

No, this is the probability of failure of the system. If you go back to the event tree, the PNS is the sum of the non-suppression branches. When I'm crediting a smoke detection system, I would put here the probability of failure (the split fraction) for the smoke detection system. These are just probabilities of failure to put in these branches, but it is not the aggregate probability of non-suppression. Those numbers in slide 9 are inputs to the event tree.

## QUESTION

*The curve shown here is only manual?*

## RESPONSE

Yes, only for the suppression probability for the fire brigade. There are more curves, and one of the longest ones is the high-energy arcing faults. In this one, the quickest one to suppress was the cable fire, which took only about ten minutes. You see that you very quickly go to very low probabilities of the system.

## QUESTION

*Is there a curve for automatic suppression as well?*

## RESPONSE

No. The automatic suppression numbers will come out of the event tree when you do the same thing. This is the same in table format, and this is the curve, so if you have a  $\lambda$ , that would be this mean here, and you stick it in and get this probability as a function of time.

## QUESTION

*Slide 20: Is your fire brigade response time just the time it takes them to get there?*

## RESPONSE

Well, it should be the time to start suppression activities. We usually go through the real records of things within the plant, through all of your fire compartments in task 1, but places close to it, and average drill records, and come up with numbers.

## QUESTION

*So if I have a damage time of 15 minutes and a brigade response time of 15 minutes,...*

## RESPONSE

The brigade fails. I was doing work in one international plant, and asked for the brigade drill records, and they were all very good (~5 minutes), but then I tried to find out what was going on,

and the drill was always to the same place, and they knew where the fire was. They would say “oh, gosh. We have a fire in that room. Perhaps, you know, if you want, you can go and fight it or something.” If every week you go to the same place, they start becoming very, very good. They don’t have an addressable fire detection system, so when the alarm sounds they don’t know where it is, so for the drill they tell them where to go. This doesn’t really represent the real story. I have been in plants here, not to draw comparisons, but when I go through them, some of them are very detailed, with times for everything on reports for each drill, and we pick out of that the time to start the suppression activities. I put that as input data in my rooms tables, where I have time to brigade response, and this becomes the time input to the event tree.

#### QUESTION

*To take it a step further, if the damage time is longer than the response time, is there a suppression time you add on top of the response time?*

#### RESPONSE

No. If you can start suppression activities in 13 minutes and the damage time is 15, then you go to your curve for 2 minutes and see numbers very close to failure. That assumes, of course, that the fire brigade immediately begins doing the correct thing, rather than just wandering around.

## Session 9: Special Fire Models Part 1

#### QUESTION

*Slide 8: Why are the units for the bench scale HRR given as flux?*

#### RESPONSE

The bench scale is a small piece of material that you subject to heat flux and measure its HRR. They express that HRR per unit area, and then we multiply it by total area to get the total answer in kW. In this case, it is the area of the cable that is burning.

#### QUESTION

*I know you mentioned qualified and non-qualified, what makes a cable qualified?*

#### RESPONSE

It’s just that 383 flame spread rate, whether or not it can propagate. It’s not exactly the same, but there are two conditions: qualified and non-qualified, just like thermoset and thermoplastic materials. The best description of a thermoset cable vs a thermoplastic cable, as I heard from MARK SALLEY, is that a thermoplastic just melts and drips, and the insulation falls. The thermoset is like a hot dog that you leave on the grill on the 4<sup>th</sup> of July, in that it just chars around and the insulation doesn’t fall, it just remains there. Unqualified and qualified comes from the IEEE test, where we pass or fail that test. We kind of use thermoset / thermoplastic to mean qualified / unqualified, even though that’s not really what it means. But this PVC is clearly thermoplastic. Some of the others are thermoset. You would need to decide on a number, and

this is all we have. There is a NIST report on this, and the NIST report has the most guidance. The SFPE handbook has a condensed version, which is essentially the same thing as what is shown in the slides, and 1805 has somewhere in the middle a discussion of where this is coming from.

#### QUESTION

*Slide 14: How far apart were the trays when you saw the fires jump between them?*

#### RESPONSE

1 to 2 feet apart. Definitely not 10 feet.

#### QUESTION

*Slide 15: If a plant uses some computational fluid dynamics and fire models, do they match this model? If I built a model of that room and ran the calculations that you suggested here, would it realistically match the expected results and propagate?*

#### RESPONSE

Permit me to answer your inquiry in two parts.

Will it do some propagation? Absolutely.

The other part of your answer, a rather political topic, is that these models have not been experimentally verified, and we don't have input parameters for the model, to V&V it. Even if we take the experiments that were used for it and put it in a model, we would not have the properties of the cables and other inputs that a fire modeler would need to say "this is V&V". That's why we have it this way, and we say "go put it in a CFD code and see what it does", because we don't have properties.

#### QUESTION

*Why do you expect a disconnect between the model and the experiment?*

#### RESPONSE

Obviously, some of the variables are not valid for it. But I have seen simulations of fires like this, and there is no question that the fire jumps all over the place. My own opinion, by looking at those simulations and these experiments, is that definitely this happens, and until we have more data or better properties, we are not ready to go into those calculations, but at the same time, I am not ready to say that propagation will not happen. I mean, models show that, for whatever properties you put in, and experiments show it, for whatever experimental conditions you have. I am being careful in my answer, because that is the discussion we have been having.

#### QUESTION

*Is there a stated limitation in how far, when you get outside of the test parameters, that you can apply this model?*

## RESPONSE

The configuration of the test is described there.

## QUESTION

*Slide 19: When you say "segmented", you're talking about bus bars that are bolted together, rather than what we call bus ducts, which essentially consist of concrete holes with cables running through them.*

## RESPONSE

Actually, you can screen those, because it's only one piece of a cable that goes from one side to the other with no junction points, right? FAQ allows you to screen it.

## QUESTION

*Wouldn't it be much better if you abandon the control room and go to the backup where your probability of success is much higher?*

## RESPONSE

Yeah.

## QUESTION

*Why would you even try and stay in a place even if the temp of 85 degrees? Isn't the probability of making a mistake 50% or higher?*

## RESPONSE

I am finding the probability that at these temperatures the operator cannot even be there, risk analysis says that if there is a fire big enough, the operator should leave because this might be their only chance, it is going to raise the risk if you stay under these conditions that are slightly less than this limit, It is going to raise the risk than if you abandon the control room and shut the plan down from elsewhere. You are penalizing yourself.

## QUESTION

*Are they just giving you a limit where you can't stay in the control room from the fire analysis side? You got to take what they are doing and reintegrate it back into the model. One must establish the appropriate abandonment criteria on when you are going to leave versus when you going to stay. I am just saying that you start weighing how well are you're weighing your leave the room methodology versus staying in the control room.*

## RESPONSE

I believe that people will want to learn how to improve their smoke purge techniques among other things before they would want to worry about shutdown methodology. Fuel will burn fast, and the creation of smoke will be rapid. But to be completely honest, most of these control room

monitors have to act on instinct because there is nobody in the background that tells you exactly what to do in fires such as these.

#### QUESTION

*Should we expect any procedures that are below the levels than the ones that were included in this presentation, such as ones below the ultimate shutdown methodology? What we are learning as of now is the steps that we should take in these situations and what is the allowable time a operator should stay in the control room, From that information, it seems that we can determine the realistic criteria for abandoning a control room and we can also consider the shape factor and likelihood of making special actions.*

#### RESPONSE

Not usually based on specific fire conditions they are more specific on what Walter was talking about, I lose some of her ability and I usually take positions and waiting for judgments from the operators you went and that might mean that people can stay and some in the control and others do their own things. If you get to this stage, forget about the control, you are out of it.

## Session 10: Special Fire Models Part 2

#### QUESTION

*Slide 8: In the case of these fires, should you postulate a plant trip?*

#### RESPONSE

What else is failing besides the trip? An extreme example is an RHR pump room fire. If you're testing the RHR pump and the motor catches fire, will the plant trip? Most likely not. Of course, the shift super may panic and say "shut down the plant", but there's no reason for them to lower the power level and start a shutdown. You could argue that some of these events are a part of the internal event, something that other people have already modeled, because a plant trip can happen for many causes, including this one. You need to be careful how you do this, in order to ensure that anything else that could be affected is not. If you can convince yourself that nothing else is being affected by it, then you can say that it is a part of the failure probability that the internal events people already considered.

#### QUESTION

*Slide 8: When you look at the nature of these analyses, does it make sense that they would not be a non-threatening fire? The data tells you something, but when you actually look at the component, does it make sense that there's something about the way that the exciters are put together that your fires are always hot and bright, because there's nothing to burn around them?*

#### RESPONSE

That's exactly what I'm suggesting. Don't take this word and say "because evidence is confined every time, therefore there's no need to worry"; you should look into the exciter and see if there's anything nearby that is on the fire PRA component list. If it's on that list, you should look

at it carefully and see if it can be affected or not. This will come up again when we discuss the catastrophic failures.

#### QUESTION

*Slide 14: How do you resolve the fire size of the hydrogen formulas? I don't see a formula here.*

#### RESPONSE

We didn't provide you a formula there. We have references. If you need the flame length, there are formulas to find it, found in appendix N. I would suggest that you assume everything in that room is destroyed, and if you can't screen that, then you should use these formulas. If the room is huge, then use a smaller zone, but if it's a small room (which is typically where I find the hydrogen piping), then assume everything is gone. If you can't screen that, then use the appendix N formulas.

#### QUESTION

*Slide 14: For battery fires, did fires result in structural damage to the buildings?*

#### RESPONSE

The pictures I've seen have been in non-nuclear environments. In a nuclear plant, typical battery rooms are inside buildings and they're well-established. They're in isolated rooms with rated fire walls and ceilings. But the ones I'm familiar with were on the outside of another building with a regular frame-type construction.

#### QUESTION

*Slide 14: Have you ever encountered any catastrophic hydrogen deflagrations?*

#### RESPONSE

I think the majority of the events in nuclear plants have been deflagrations. I don't remember any detonations in the nuclear events, because the quantity generally is small. The large quantity releases have been outside, where the relief valve has vented and created a hydrogen fire on top of the hydrogen storage tank and created a large fire. In this case, the fire brigade has correctly said "okay, we're not going to put it out, just let it burn itself out". By the way, hydrogen flame (I think) is not visible.

## Session 11: Main Control Room Fire Analysis

#### QUESTION

*Why would analyze the fire impact on the farthest element from the postulated ignition source? Wouldn't it screen more efficiently if you addressed the closest element?*

## RESPONSE

I wouldn't pick the farthest one, I'd pick the closest. That's exactly what I'm saying. You need to be careful to see what set you're selecting. You will select the minimal selection that does your damage.

## QUESTION

*Are you trying to say that you want to find the scenarios that could take out all aux feedwater pumps? Or is there an exercise up front that will select those components you think you can seek, so if I was going in looking at aux feedwater pumps, will I look for those things that will take out all aux feed and measure those?*

## RESPONSE

In principle, you should look at every possible combination of these controls and instrumentation. Obviously, that's an impossible task, so minimal cutsets is one idea, albeit imperfect, because often times you don't have a perfect minimal cutset. You may have a partial minimal cutset, so you basically need to pass judgment to see which areas are the most important. Actually, it's a spatial exercise. You're basically going through the panel and imagining a glob of fire of different dimensions moving about and around and affecting things.

## QUESTION

*As per the chart, I will take auxiliary feedwater and measure the distance to main feedwater, with the assumption of no intervening barriers. Do we retroactively account for that?*

## RESPONSE

Not unless there is a very clear separation, a perfect wall. Cabinet walls can be considered perfect walls, so long as there is no air gap. Imagine two cabinets put next to one another: a perfect wall. Then, we give you a fifteen-minute credit in the methodology. Follow the associated guidelines where they are listed. The main control board is no exception, although it is generally open in the back. That opening has associated options with it, like half-walls, or channels coming in, where things are put through. Some of them are completely open, with spaghetti of wiring in the back well within sight.

## QUESTION

*If you postulate this type of fire, you discount the possibility that some of these elements with potentially massive ramifications (very large CCDP) will be affected by the postulated fires.*

## RESPONSE

In this case, you can not say "I don't care", because you need to be very specific which pump you will pick. You need to measure that distance. It may be difficult to establish the very fine resolution, saying that one will be affected and not another. I would not recommend it. If things are so close to one another, it is unrealistic to say that the fire will hit one element and not the one next to it. The best thing to do is to form your list of possible fire events and then examine all of those for which you think the CCDP will be significant. Significant CCDP in this world is probably anything above .01. Anything above this number probably has some contribution.

## QUESTION

*What about a fire in the back of the control board? Something that affects the wiring?*

## RESPONSE

This method includes damage to the wiring. I have seen cases where people have chosen to be so thorough as to walk it down and note where things cross from one part to another. That raises another important point. If you have two elements separated by a certain large distance, but whose wiring comes together in a small area of the control board, then a fire necessary to take out both elements is not the large fire that affects the distance of separation, but rather a fire only large enough to damage the control board at the point of contact, large enough only to affect the distance that the wires are separated. The presumption is that the fire happens in the back of the control board, or underneath.

## QUESTION

*What are some possible fire scenarios in this case? Where could the fire come from?*

## RESPONSE

Shorts, relays, smoking; there are some events inside panels that start with circuit guards. Some start in the wires. I think it has happened internally within wires, although usually this stems from a short somewhere else in the plant with a side effect of overheating within the panel.

Let me recap. By doing this exercise, you effectively are also analyzing everything in the immediate back of the panel that serves the front panel. Now if you have another back panel with its own instruments and devices back there, you treat it as an electrical cabinet. This does not change the exercise, though, in that you still walk the cabinet down and say "I care about this part because it has a high CCDP".

## QUESTION

*Is there an indication that they're relying on their damage temperature for MCR abandonment higher than 200 F?*

## RESPONSE

In the control room, usually some cables and sensitive electronics will be damaged below this temperature. That can happen even with a fire that requires abandonment. This does not assume that the entire room reaches a temperature of 200 F, just the gas layer at the top. If the board is at a lower temperature, the room can still be tenable. When I have done these analyses, I have seen that the HVAC in the MCR becomes a very significant factor that should be included in your fire model. You may not even develop a hot gas layer, because the rate of smoke removed from the room may be higher than the rate of smoke produced. Of course, the HVAC systems are also subject to failure, which can be represented in the same way as any other component, with a probability of failure. I have seen plants with detailed procedures for smoke purge. It is a mode, clearly defined, with operator guidance on usage. Push a button, and a certain fan starts the smoke purge. There are others that do not have such specific requirements; the only options are normal operation and emergency mode, which is designed to

contend with such things as radiation as well as fire. If smoke purge is not clearly defined, then it is more of a challenge. I have seen others that it is there, but for some reason, it is behind a plate that makes it completely inaccessible during emergency conditions. They knew the procedure, and there was certainly a way to make it automatic, but it was completely counterintuitive.

## Session 12: Multi-Compartment Fire Analysis

### QUESTION

*Slide 2: Spreading that you speak of here is just the gas and not the flame?*

### RESPONSE

Unless you have a direct line of sight for the radiation effects of the flame, you should take the gas into consideration, but generally what we have in mind is that a very hot gas forms under the ceiling, and it moves out. There are situations where there is a complete opening between rooms, and this task is to do a screening analysis in a stepwise way to arrive at specific scenarios that merit a more detailed analysis. You can appreciate that we could easily have a very large combination of compartments that are adjacent to one another, and would communicate with one another. Effectively, you must consider all combinations of rooms and screen them out.

### QUESTION

*Slide 10: In this case, will you include all of the fuel in the room, not just the burning cabinet?*

### RESPONSE

Yes. Add the intervening combustibles when considering your multi-compartment fire.

### QUESTION

*Slide 11: When calculating all of the combustibles in the room, how do you add the transient combustibles?*

### RESPONSE

We have a distribution for the transients, there is a 98 percentile HRR for the transients. We recommend you use the worst-case fire you have in the room, and see if you can do damage next door. In this step, something less than the worst case could do the damage, so this gives you a severity factor, and also in this step, you must consider the probability of failure of a certain fire barrier if it is required as a means of egress.

### QUESTION

*Slide 14: Do I need to subtract (1 – the barrier probability) from the other analysis that I did? In the other analysis, we examined the potential for damage to the walls of the compartment during a fire, so do I need to examine this scenario when assessing the probability that the flame will spread?*

## RESPONSE

In principle, yes. But I think the impact will probably be insignificant.

## QUESTION

*If you can not screen out a fire spreading to a second compartment, do you then use that second compartment as a source for the third compartment?*

## RESPONSE

Yes, you follow the same procedure that you followed for a single compartment analysis, but then in this case the new target set is based on the elements in the new room. At this point, do the same analysis that was done for a single analysis.

## QUESTION

*Could this lead to a domino effect, where rooms concatenate to form an extreme fire? In practice, how does the fire brigade play into all of this?*

## RESPONSE

The detailed analysis addresses this. In this task, the multi-compartment analysis is only screening-level analysis. This merely eliminates some scenarios and arrives at some others that can not be eliminated, and then applies the detailed analysis for only that subset.

## QUESTION

*In your experience, how readily do you see individual rooms that fail to screen?*

## RESPONSE

Very many of these rooms will screen, making multi-compartment fires rather unlikely. You need to consider barrier failure probabilities. The key is that the most important discriminator will be the things that are failing in the second room. In other words, the CCDP will play a very significant role in all of this. This is one area that requires a great deal of judgment. Over the years, some plants involve fire zones, and some have no walls. Some have 20 feet on the floor and say "this is my separation", with cable databases and documents all identifying this distinction. They find it very difficult to redefine everything and remap all the cables in the database. What I have commented on is that if you put fires in those boundaries and figure out very quickly what your targets there are, and in those areas, place fires and check the ramifications. One noteworthy exclusion is addressing what to do with oil. You could make such a big fire that it is difficult to screen. You then need to decide which oil fire size you will use, something that is not clearly defined in 6850. This is one thing that requires documentation.

# Session 13: Seismic Fire Interactions

## QUESTION

*Can you stay in a room that is on fire with temperatures rising to 90 degrees Celsius?*

## RESPONSE

If it gets to that temperature, that best course of action is just to abandon the room.

## QUESTION

*Would you be able to do anything within the control room once temperatures reaches these extreme conditions?*

## RESPONSE

Yeah, you will be able to do things at these temperatures. But it is known that smoke that is coming from the fire will affect your sight as well as your ability to breathe, so it will be assumed when the first signs of a fire are witnessed, you are geared up and you have your breathing equipment on.

## QUESTION

*A limitation of a 0.4 meter radius to see what is around you during an intense fire gives very low visibility to do anything. Usually, control room operators are about 6-8ft away from the actual control board. What should operators do in these situations?*

## RESPONSE

I mean, even with breathing equipment and everything I am not suggesting that you will have all the crew doing everything that they suppose to do. I am talking about a fire accident and we are just trying to find out where definitely they really have can't really do anything else in that room. Everyone who is in this vicinity should be equipped with equipment in order to protect themselves for the short time to evacuate the premises or do their specified duties.

## QUESTION

*At 95 degrees Celsius, aren't those temperatures where most people will gain 2<sup>nd</sup> degree burns in a matter of 10 min?*

## RESPONSE

Yes they are, but we expect our staff to be fully and properly geared up.

## QUESTION

*Do operator success probabilities change with room tenability? Obviously, they can not effect changes within the control room after it has been abandoned, but does performance change over time while the room is burning?*

## RESPONSE

One of the things that I think wasn't fully translated is if you assume that this operator stay in this control room at these conditions, there are significant changes on the performance shaping factor on the success of the operator. We are assuming that they are suited up as well as other things to keep them safe during a fire. Those operators are sweating and their success rates are low. I mean you got a high probability at play here for their actions within the main control room.

## QUESTION

*Do you know the location of the switches that transfer the controls are?*

## RESPONSE

The switches are always located outside of the control room.

# A Brief Review: by Mardy Kazarians

Here is my version of it. If you have an incident at all plants to the tune of about once every ten years, your CDF is to the tune of a serious incident at one plant about once every 500000 years. So to go from an incident every decade to a CDF of about 1 in 500,000 is a large step. I am not saying that the basis for a CDF is weak, but merely that it requires a very solid basis.

In order to achieve this, we had to develop a frequency for ignition sources. We multiplied this ignition frequency by a whole bunch of parameters, which became the fire scenario frequency. We then multiplied this by a CCDP, something that came from the PRA model.

There is something wedged in between, which is the circuit analysis. This is not a trivial part! The circuit analysis wedges between the fire scenario frequency and the CCDP because it may identify events that are probabilistic. If we ignore the probabilities on that one, it affects the CCDP, but sometimes we look at circuits and say "it probably won't happen, but here's the likelihood that it will." That is wedged in between the scenario frequency and the CCDP. The circuit analysis is a very important part of fire risk analysis for several reasons. The weakness of a NPP is really in the cables that run from one place to another, because they are bunched together. Common cause failure happens because they are bunched together and one fire can affect many elements. Cables are part of a circuit, so understanding how circuits work is important because the control circuit can cause failures that are not part of the risk model, like a spurious actuation. Not all circuit failures can do that, so an understanding of how it can happen is very important.

Our focus was completely on the fire frequency. We established the ignition frequency based on component type. We also said that fire is a localized phenomenon, so we will focus on compartments, a convenient way of looking at it. Ultimately, we will look at fire scenarios. Thus, the way we should think about this is by starting with a very specific item or device, and propagate that fire and its effects onto other items. This is the fire scenario, but it is too much work at the beginning. In order to have a complete analysis without doing an excessive amount of work, we use fire compartments and base our analysis on the compartments. We then take this component type as an identifier for our ignition frequency and say that it is the same for all components in the plant of that type.

We then need to multiply this by a factor that will correct it, to make it specific to either a certain device, or to all possible ignition sources within a compartment. This is the ignition source weighting factor. I don't want to talk about location factors, because this is the multi-unit factor, but that is something you may wish to consider if you want to do a multi-unit analysis. This establishes the initial fire. Now we must say that this fire must be strong enough, because not all fires are strong enough to damage each item. Smaller fires can damage these components, but they will take a very long time. A very strong fire is also possible from here, that can damage these components quickly, so the discrimination between fires that can damage these components quickly is the non-suppression probability. I can have a spectrum of severities of the fire, and if it is medium strength, there is more time to suppress the fire than if I have an extremely strong fire. It is an integral of all possible severities. We showed you how to do this, and that there is a range of HRRs based on a gamma distribution. Based on the gamma distribution, we showed you how to calculate the propagation rate to the targets, to establish the time to damage, and then we also talked about how to establish the probability of non-suppression based on location-specific features. If this event is a welding and cutting related event, then we have a prompt detection and probability of prompt suppression. If it is a component fire, then will the automatic systems come on? How long will it take the fire brigade to show up? With this, we have established a scenario frequency, and this entire thing will be multiplied with the CCDP and other things.

This is a summary of the parts we have discussed. Obviously, some of the parts are pretty complicated, and the methodology behind it is very, very complicated. Effectively, we will use relatively simplistic models to model what happens in nature. That basically gives you an overview of what we tried to cover in the past few days.



## Appendix B: Reference Tables and Figures

**Table 1**  
**Fire Frequency Bins and Generic Frequencies**

ID	Location	Ignition Source (Equipment Type)	Mode	Generic Freq (per rx yr)	Split Fractions for Fire Type					
					Electrical	Oil	Transient	Hotwork	Hydrogen	HEAF <sup>1</sup>
1	Battery Room	Batteries	All	7.5E-04	1.0	0	0	0	0	0
2	Containment (PWR)	Reactor Coolant Pump	Power	6.1E-03	0.14	0.86	0	0	0	0
3	Containment (PWR)	Transients and Hotwork	Power	2.0E-03	0	0	0.44	0.56	0	0
4	Control Room	Main Control Board	All	2.5E-03	1.0	0	0	0	0	0
5	Control/Aux/Reactor Building	Cable fires caused by welding and cutting	Power	1.6E-03	0	0	0	1.0	0	0
6	Control/Aux/Reactor Building	Transient fires caused by welding and cutting	Power	9.7E-03	0	0	0	1.0	0	0
7	Control/Aux/Reactor Building	Transients	Power	3.9E-03	0	0	1.0	0	0	0
8	Diesel Generator Room	Diesel Generators	All	2.1E-02	0.16	0.84	0	0	0	0
9	Plant-Wide Components	Air Compressors	All	2.4E-03	0.83	0.17	0	0	0	0
10	Plant-Wide Components	Battery Chargers	All	1.8E-03	1.0	0	0	0	0	0
11	Plant-Wide Components	Cable fires caused by welding and cutting	Power	2.0E-03	0	0	0	1.0	0	0
12	Plant-Wide Components	Cable Run (Self-ignited cable fires)	All	4.4E-03	1.0	0	0	0	0	0
13	Plant-Wide Components	Dryers	All	2.6E-03	0	0	1.0	0	0	0
14	Plant-Wide Components	Electric Motors	All	4.6E-03	1.0	0	0	0	0	0

**Table 6-1  
Fire Frequency Bins and Generic Frequencies (Continued)**

ID	Location	Ignition Source (Equipment Type)	Mode	Generic Freq (per rx yr)	Split Fractions for Fire Type					
					Electrical	Oil	Transient	Hotwork	Hydrogen	HEAF <sup>1</sup>
15	Plant-Wide Components	Electrical Cabinets	All	4.5E-02	1.0	0	0	0	0	0
16	Plant-Wide Components	High Energy Arcing Faults <sup>1</sup>	All	1.5E-03	0	0	0	0	0	1.0
17	Plant-Wide Components	Hydrogen Tanks	All	1.7E-03	0	0	0	0	1.0	0
18	Plant-Wide Components	Junction Boxes	All	1.9E-03	1.0	0	0	0	0	0
19	Plant-Wide Components	Misc. Hydrogen Fires	All	2.5E-03	0	0	0	0	1.0	0
20	Plant-Wide Components	Off-gas/H <sub>2</sub> Recombiner (BWR)	Power	4.4E-02	0	0	0	0	1.0	0
21	Plant-Wide Components	Pumps	All	2.1E-02	0.54	0.46	0	0	0	0
22	Plant-Wide Components	RPS MG Sets	Power	1.6E-03	1.0	0	0	0	0	0
23a	Plant-Wide Components	Transformers (Oil filled)	All	9.9E-03	0	1.0	0	0	0	0
23b	Plant-Wide Components	Transformers (Dry)			1.0	0	0	0	0	0
24	Plant-Wide Components	Transient fires caused by welding and cutting	Power	4.9E-03	0	0	0	1.0	0	0

**Table 6-1  
Fire Frequency Bins and Generic Frequencies (Continued)**

ID	Location	Ignition Source (Equipment Type)	Mode	Generic Freq (per rx yr)	Split Fractions for Fire Type					
					Electrical	Oil	Transient	Hotwork	Hydrogen	HEAF <sup>1</sup>
25	Plant-Wide Components	Transients	Power	9.9E-03	0	0	1.0	0	0	0
26	Plant-Wide Components	Ventilation Subsystems	All	7.4E-03	0.95	0.05	0	0	0	0
27	Transformer Yard	Transformer – Catastrophic <sup>2</sup>	Power	6.0E-03	1.0 <sup>2</sup>		0	0	0	0
28	Transformer Yard	Transformer - Non Catastrophic <sup>2</sup>	Power	1.2E-02	1.0 <sup>2</sup>		0	0	0	0
29	Transformer Yard	Yard transformers (Others)	Power	2.2E-03	1.0	0	0	0	0	0
30	Turbine Building	Boiler	All	1.1E-03	0	1.0	0	0	0	0
31	Turbine Building	Cable fires caused by welding and cutting	Power	1.6E-03	0	0	0	1.0	0	0
32	Turbine Building	Main Feedwater Pumps	Power	1.3E-02	0.11	0.89	0	0	0	0
33	Turbine Building	Turbine Generator Excitor	Power	3.9E-03	1.0	0	0	0	0	0
34	Turbine Building	Turbine Generator Hydrogen	Power	6.5E-03	0	0	0	0	1.0	0
35	Turbine Building	Turbine Generator Oil	Power	9.5E-03	0	1.0	0	0	0	0
36	Turbine Building	Transient fires caused by welding and cutting	Power	8.2E-03	0	0	0	1.0	0	0
37	Turbine Building	Transients	Power	8.5E-03	0	0	1.0	0	0	0

1. See Appendix M for a description of high-energy arcing fault (HEAF) fires.

2. See Section 6.5.6 below for a definition.

3. The event should be considered either as an electrical or oil fire, whichever yields the worst consequences.

**Table 2**  
**Description of Transient Fire Influencing Factors**

Influencing Factor	No (0)	Low (1)	Medium (3)	High (10)	Very High (50)
Maintenance	Maintenance activities during power operation are precluded by design.	Small number of PM/CM work orders compared to the average number of work orders for a typical compartment.	Average number of PM/CM work orders.	Large number of (PM)/(CM) work orders compared to the average number of work orders for a typical compartment.	Should be assigned to plant areas that may experience significantly more (PM)/(CM) work orders compared to the average number of work orders for a typical compartment.
Occupancy	Entrance to the compartment is not possible during plant operation.	Compartment with low foot traffic or out of general traffic path.	Compartments not continuously occupied, but with regular foot traffic.	Continuously occupied compartment.	Not applicable
Storage	Entrance to the compartment is not possible during plant operation.	Compartment where no combustible/flammable materials are stored.	Compartments where all combustible/flammable material is stored in closed containers placed in dedicated fire-safe cabinets.	Compartments where combustible/flammable materials may sometimes be brought in and left in either open containers for a short time or in a closed container, but outside a dedicated fire-safe cabinet for an extended time.	Not applicable

For *general transients* (i.e., Bins 3, 7, 25, and 37), the following equation should be used to establish the ignition source weighting factor:

$$W_{GT,J,L} = (n_{m,J,L} + n_{o,J,L} + n_{s,J,L})/N_{GT,L}$$

$$N_{GT,L} = \sum (n_{m,i,L} + n_{o,i,L} + n_{s,i,L})$$

(summed over i, all compartments of location L).

where:

$n_{m,J,L}$  = Maintenance influence factor rating of compartment J of location L,

$n_{o,J,L}$  = Occupancy influence factor rating of compartment J of location L, and

$n_{s,J,L}$  = Storage influence factor rating of compartment J of location L.

In the case of *transient fires caused by welding and cutting* (i.e., Bins 6, 24, and 36), the following equation should be used:

$$W_{WC,J,L} = n_{m,J}/N_{WC}$$

$$N_{WC} = \sum n_{m,i,L}$$

(summed over i, all the compartments of location L).

For *cable fires caused by welding and cutting* (i.e., Bins 5, 11, and 31), the following equation should be used:

$$W_{CF,J} = n_{m,J} W_{Cable,J} / N_{CF}$$

$$N_{CF} = \sum n_{m,i,L} W_{Cable,i}$$

(summed over i, all compartments of location L),

where:

$W_{Cable,i}$  = Cable load of compartment i, based on the ratio of quantity of cables in compartment i over the total quantity of cables in the location.

**Table 3  
List of Heat Release Rate Distributions**

Case	Ignition Source	HRR kW (Btu/s)		Gamma Distribution		Reference
		75th	98th	$\alpha$	$\beta$	
1	Vertical cabinets with qualified cable, fire limited to one cable bundle	69 (65)	211 (200)	0.84 (0.83)	59.3 (56.6)	Table G-1
2	Vertical cabinets with qualified cable, fire in more than one cable bundle	211 (200)	702 (665)	0.7 (0.7)	216 (204)	Table G-1
3	Vertical cabinets with unqualified cable, fire limited to one cable bundle	90 (85)	211 (200)	1.6 (1.6)	41.5 (39.5)	Table G-1
4	Vertical cabinets with unqualified cable, fire in more than one cable bundle closed doors	232 (220)	464 (440)	2.6 (2.6)	67.8 (64.3)	Table G-1
5	Vertical cabinets with unqualified cable, fire in more than one cable bundle open doors	232 (220)	1002 (950)	0.46 (0.45)	386 (366)	Table G-1
6	Pumps (electrical fires)	69 (65)	211 (200)	0.84 (0.83)	59.3 (56.6)	Table G-1
7	Motors	32 (30)	69 (65)	2.0 (2.0)	11.7 (11.1)	Table G-1
8	Transient Combustibles	142 (135)	317 (300)	1.8 (1.9)	57.4 (53.7)	Section G-4

**Table 4  
Discretized Distribution for Case 1 Heat Release Rate (Vertical Cabinets with Qualified Cable, Fire Limited to One Cable Bundle)**

Bin	Heat Release Rate – kW (Btu/s)			Severity Factor ( $P_i$ )
	Lower	Upper	Point Value	
1	0 (0)	26 (25)	11 (10.5)	0.446
2	26 (25)	53 (50)	38 (36)	0.219
3	53 (50)	79 (75)	64 (61)	0.129
4	79 (75)	106 (100)	92 (87)	0.078
5	106 (100)	132 (125)	118 (112)	0.048
6	132 (125)	158 (150)	145 (137)	0.030
7	158 (150)	185 (175)	171 (162)	0.019
8	185 (175)	211 (200)	197 (187)	0.012
9	211 (200)	237 (225)	224 (212)	0.007
10	237 (225)	264 (250)	250 (237)	0.005
11	264 (250)	290 (275)	276 (262)	0.003
12	290 (275)	317 (300)	303 (287)	0.002
13	317 (300)	343 (325)	329 (312)	0.001
14	343 (325)	369 (350)	356 (337)	0.001
15	369 (350)	Infinity	427 (405)	0.001

**Table 5**  
**Discretized Distribution for Case 2 Heat Release Rate (Vertical Cabinets with Qualified Cable, Fire in more than One Cable Bundle)**

Bin	Heat Release Rate – kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	90 (85)	34 (32.7)	0.506
2	90 (85)	179 (170)	130 (123)	0.202
3	179 (170)	269 (255)	221 (209)	0.113
4	269 (255)	359 (340)	310 (294)	0.067
5	359 (340)	448 (425)	400 (379)	0.041
6	448 (425)	538 (510)	490 (464)	0.026
7	538 (510)	628 (595)	579 (549)	0.016
8	628 (595)	717 (680)	669 (634)	0.010
9	717 (680)	807 (765)	759 (719)	0.006
10	807 (765)	897 (850)	848 (804)	0.004
11	897 (850)	986 (935)	938 (889)	0.003
12	986 (935)	1076 (1020)	1028 (974)	0.002
13	1076 (1020)	1166 (1105)	1118 (1060)	0.001
14	1166 (1105)	1255 (1190)	1208 (1145)	0.001
15	1255 (1190)	Infinity	1462 (1386)	0.001

**Table 6**  
**Discretized Distribution for Case 3 Heat Release Rate (Vertical Cabinets with Unqualified Cable, Fire Limited to One Cable Bundle)**

Bin	Heat Release Rate - kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	26 (25)	15 (14.2)	0.227
2	26 (25)	53 (50)	39 (37)	0.261
3	53 (50)	79 (75)	65 (62)	0.192
4	79 (75)	106 (100)	92 (87)	0.126
5	106 (100)	132 (125)	118 (112)	0.079
6	132 (125)	158 (150)	143 (136)	0.048
7	158 (150)	185 (175)	170 (161)	0.028
8	185 (175)	211 (200)	196 (186)	0.016
9	211 (200)	237 (225)	223 (211)	0.010
10	237 (225)	264 (250)	249 (236)	0.005
11	264 (250)	290 (275)	275 (261)	0.003
12	290 (275)	317 (300)	302 (286)	0.002
13	317 (300)	343 (325)	328 (311)	0.001
14	343 (325)	369 (350)	354 (336)	0.001
15	369 (350)	Infinity	414 (392)	0.001

**Table 7**  
**Discretized Distribution for Case 4 Heat Release Rate (Vertical Cabinets with Unqualified Cable, Fire in more than One Cable Bundle Closed Doors)**

Bin	Heat Release Rate - kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	53 (50)	36 (34)	0.082
2	53 (50)	106 (100)	80 (76)	0.213
3	106 (100)	158 (150)	131 (124)	0.224
4	158 (150)	211 (200)	184 (174)	0.177
5	211 (200)	264 (250)	235 (223)	0.122
6	264 (250)	317 (300)	288 (273)	0.077
7	317 (300)	369 (350)	341 (323)	0.046
8	369 (350)	422 (400)	394 (373)	0.027
9	422 (400)	475 (450)	446 (423)	0.015
10	475 (450)	528 (500)	499 (473)	0.008
11	528 (500)	580 (550)	552 (523)	0.004
12	580 (550)	633 (600)	603 (572)	0.002
13	633 (600)	686 (650)	656 (622)	0.001
14	686 (650)	739 (700)	709 (672)	0.001
15	739 (700)	Infinity	816 (773)	0.001

**Table 8**  
**Discretized Distribution for Case 5 Heat Release Rate (Vertical Cabinets with Unqualified Cable, Fire in more than One Cable Bundle Open Doors)**

Bin	Heat Release Rate - kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	137 (130)	42 (39.5)	0.638
2	137 (130)	274 (260)	197 (187)	0.155
3	274 (260)	411 (390)	337 (319)	0.081
4	411 (390)	549 (520)	475 (450)	0.047
5	549 (520)	686 (650)	612 (580)	0.029
6	686 (650)	823 (780)	749 (710)	0.018
7	823 (780)	960 (910)	886 (840)	0.011
8	960 (910)	1097 (1040)	1024 (971)	0.007
9	1097 (1040)	1234 (1170)	1162 (1101)	0.005
10	1234 (1170)	1372 (1300)	1299 (1231)	0.003
11	1372 (1300)	1509 (1430)	1436 (1361)	0.002
12	1509 (1430)	1646 (1560)	1573 (1491)	0.001
13	1646 (1560)	1783 (1690)	1710 (1621)	0.001
14	1783 (1690)	1920 (1820)	1847 (1751)	0.001
15	1920 (1820)	Infinity	2276 (2157)	0.001

**Table 9**  
**Discretized Distribution for Case 6 Heat Release Rate (Pumps – Electrical Fires)**

Bin	Heat Release Rate – kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	26 (25)	11 (10.5)	0.446
2	26 (25)	53 (50)	38 (36)	0.219
3	53 (50)	79 (75)	64 (61)	0.129
4	79 (75)	106 (100)	92 (87)	0.078
5	106 (100)	132 (125)	118 (112)	0.048
6	132 (125)	158 (150)	145 (137)	0.030
7	158 (150)	185 (175)	171 (162)	0.019
8	185 (175)	211 (200)	197 (187)	0.012
9	211 (200)	237 (225)	224 (212)	0.007
10	237 (225)	264 (250)	250 (237)	0.005
11	264 (250)	290 (275)	276 (262)	0.003
12	290 (275)	317 (300)	303 (287)	0.002
13	317 (300)	343 (325)	329 (312)	0.001
14	343 (325)	369 (350)	356 (337)	0.001
15	369 (350)	Infinity	427 (405)	0.001

**Table 10**  
**Discretized Distribution for Case 7 Heat Release Rate (Motors)**


Bin	Heat Release Rate – kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	7 (7)	5 (4.4)	0.132
2	7 (7)	15 (14)	12 (11)	0.227
3	15 (14)	22 (21)	18 (17)	0.205
4	22 (21)	30 (28)	25 (24)	0.153
5	30 (28)	37 (35)	33 (31)	0.105
6	37 (35)	44 (42)	40 (38)	0.069
7	44 (42)	52 (49)	47 (45)	0.043
8	52 (49)	59 (56)	55 (52)	0.027
9	59 (56)	66 (63)	62 (59)	0.016
10	66 (63)	74 (70)	70 (66)	0.010
11	74 (70)	81 (77)	77 (73)	0.006
12	81 (77)	89 (84)	84 (80)	0.003
13	89 (84)	96 (91)	92 (87)	0.002
14	96 (91)	103 (98)	99 (94)	0.001
15	103 (98)	Infinity	116 (110)	0.001

**Table 11**  
**Discretized Distribution for Case 8 Heat Release Rate (Transients<sup>1</sup>)**

Bin	Heat Release Rate – kW (Btu/s)			Severity Factor (P <sub>i</sub> )
	Lower	Upper	Point Value	
1	0 (0)	37 (35)	22 (21.2)	0.169
2	37 (35)	74 (70)	55 (52)	0.249
3	74 (70)	111 (105)	92 (87)	0.205
4	111 (105)	148 (140)	128 (121)	0.143
5	148 (140)	185 (175)	165 (156)	0.093
6	185 (175)	222 (210)	202 (191)	0.058
7	222 (210)	258 (245)	238 (226)	0.035
8	258 (245)	295 (280)	275 (261)	0.020
9	295 (280)	332 (315)	312 (296)	0.012
10	332 (315)	369 (350)	349 (331)	0.007
11	369 (350)	406 (385)	386 (366)	0.004
12	406 (385)	443 (420)	423 (401)	0.002
13	443 (420)	480 (455)	460 (436)	0.001
14	480 (455)	517 (490)	497 (471)	0.001
15	517 (490)	Infinity	578 (548)	0.001

**Table 12**  
**Damage Criteria for Electrical Cables – Generic Screening Criteria for the Assessment of the Ignition and Damage Potential of Electrical Cables [See Ref 8-1]**

<b>Cable Type</b>	<b>Radiant Heating Criteria</b>	<b>Temperature Criteria</b>
Thermoplastic	6 kW/m <sup>2</sup> (0.5 BTU/ft <sup>2</sup> s)	205°C (400°F)
Thermoset	11 kW/m <sup>2</sup> (1.0 BTU/ft <sup>2</sup> s)	330°C (625°F)



**Figure 1**  
**Likelihood of Target Damage Calculated as the Severity Factor Times the Probability of Non-suppression for MCB Fires**

**Table 13**  
**Probability Distribution for Rate of Fires Suppressed per Unit Time,  $\lambda$**

Suppression Curve	Number of Events in Curve	Total Duration	$\lambda$ Mean	5 <sup>th</sup> Per	50 <sup>th</sup> Per	95 <sup>th</sup> Per
T/G fires	21	749	0.03	0.02	0.03	0.04
Control room	6	18	0.33	0.15	0.32	0.58
PWR containment	3	23	0.13	0.04	0.12	0.27
Outdoor transformers	14	373	0.04	0.02	0.04	0.06
Flammable gas	5	195	0.03	0.01	0.02	0.05
Oil fires	36	404	0.09	0.07	0.09	0.11
Cable fires	4	11	0.24	0.12	0.33	0.70
Electrical fires	112	937	0.12	0.10	0.12	0.14
Welding fires	19	99	0.19	0.13	0.19	0.27
Transient fires	24	199	0.12	0.08	0.12	0.16
High energy arcing faults	5	118	0.01	0.02	0.04	0.08
All fires	250	3260	0.08	0.07	0.08	0.08

**Table 14**  
**Numerical Results for Suppression Curves**

Time (min)	T/G fires	High energy arcing faults	Outdoor transformers	Flammable gas	Oil fires	Electrical fires	Transient fires	PWR containment	Welding	Control room	Cable fires	All fires
0	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
5	0.87	0.94	0.83	0.88	0.64	0.55	0.55	0.52	0.38	0.19	0.30	0.68
10	0.76	0.88	0.69	0.77	0.41	0.30	0.30	0.27	0.15	0.04	0.09	0.46
15	0.66	0.83	0.57	0.68	0.26	0.16	0.16	0.14	0.06	0.01	0.03	0.32
20	0.57	0.78	0.47	0.60	0.17	0.09	0.09	0.07	0.02	0.00	0.01	0.22
25	0.50	0.73	0.39	0.53	0.11	0.05	0.05	0.04	0.01	*	0.00	0.15
30	0.43	0.69	0.32	0.46	0.07	0.03	0.03	0.02	0.00	*	*	0.10
35	0.37	0.64	0.27	0.41	0.04	0.01	0.01	0.01	0.00	*	*	0.07
40	0.33	0.61	0.22	0.36	0.03	0.01	0.01	0.01	*	*	*	0.05
45	0.28	0.57	0.18	0.32	0.02	0.00	0.00	0.00	*	*	*	0.03
50	0.25	0.53	0.15	0.28	0.01	0.00	0.00	0.00	*	*	*	0.02
55	0.21	0.50	0.13	0.24	0.01	0.00	0.00	*	*	*	*	0.01
60	0.19	0.47	0.11	0.21	0.00	*	*	*	*	*	*	0.01
65	0.16	0.44	0.09	0.19	0.00	*	*	*	*	*	*	0.01
70	0.14	0.42	0.07	0.17	0.00	*	*	*	*	*	*	0.00
75	0.12	0.39	0.06	0.15	0.00	*	*	*	*	*	*	0.00
80	0.11	0.37	0.05	0.13	*	*	*	*	*	*	*	0.00
85	0.09	0.34	0.04	0.11	*	*	*	*	*	*	*	0.00
90	0.08	0.32	0.03	0.10	*	*	*	*	*	*	*	0.00
95	0.07	0.30	0.03	0.09	*	*	*	*	*	*	*	*
100	0.06	0.29	0.02	0.08	*	*	*	*	*	*	*	*

\* A value of 1E-3 should be used

## **Appendix C: Exercise Set Solutions**

### **Session 1b: Example Problems (Plant Partitioning)**

## Workshop Problems for Task 1: Plant Boundary Definition and Partitioning

### Workshop Problem Set 01-01

**Step 1 - Selection of Global Plant Analysis Boundary:** Using Drawing # 01 in the Sample Package and the information provided in other drawings, identify the Global Plant Analysis Boundaries in terms of plant areas. Make a complete list of plant areas shown on Drawing #01 in the matrix provided below. Specify whether or not the area shall be included within the Global Plant Analysis Boundaries and then provide the basis of your decision.

Plant Area	Included?	Basis
Auxiliary Building	Yes	Contains equipment and cables that may be included in the fire PRA analysis
Containment	Yes	Contains equipment and cables that may be included in the fire PRA analysis
Diesel Generator Building	Yes	Contains equipment and cables that may be included in the fire PRA analysis
Turbine Building	Yes	Contains equipment and cables that may be included in the fire PRA analysis
Yard	Yes	Contains equipment and cables that may be included in the fire PRA analysis
Security Building	No	There are no equipment or cables in this building needed for safe shutdown
Switchyard	No	Offsite power is impacted from equipment or cable failure in the Switchyard. However, the impact of a fire event in the switchyard would be limited to loss of offsite power and no other safe shutdown related functions. Therefore, switchyard fires are considered a part of loss of offsite
Intake Structure	Yes	Contains equipment and cables that may be included in the fire PRA analysis

Workshop Problem Set 01-02

**Step 2: Plant Partitioning:** Using the drawings provided in the Sample Package, identify the set of fire compartments that you will consider for the fire PRA. In the following matrix (1) list selected compartments, (2) give each an identification number, (3) identify the associated plant area for each compartment from the Solution Statement for Problem Set 01-01. Provide comments where warranted.

Fire Comp. ID #	Fire Compartment Descriptor	Plant Area	Comments
1	Main Control Room	Auxiliary Building	Includes the kitchen and Shift Supervisor's Office
2	Aux Bldg El. 0 Ft	Auxiliary Building	
3	Cable Spreading Room	Auxiliary Building	
4A	Aux Bldg. El. -20 Ft, RHR Room	Auxiliary Building	
4B	Aux Bldg. El. -20 Ft, AFW Room	Auxiliary Building	
5	Battery Room A	Auxiliary Building	1 hour rated walls and 2 hour rated ceiling within the Switchgear rooms
6	Battery Room B	Auxiliary Building	1 hour rated walls and 2 hour rated ceiling within the Switchgear rooms
7	Containment	Containment	
8A	DG-A Room	Diesel Generator Building	

<b>Fire Comp. ID #</b>	<b>Fire Compartment Descriptor</b>	<b>Plant Area</b>	<b>Comments</b>
8B	DG-B Room	Diesel Generator Building	
9	SWG Access Room	Auxiliary Building	
10	Switchgear Room A	Auxiliary Building	
11	Switchgear Room B	Auxiliary Building	
12	Turbine Bldg El. 0 Ft	Turbine Building	
13	Yard	Yard	Includes the Transformers next to the Diesel Generator Building and the two safety related tanks.
14	Intake Structure	Intake Structure	A long building with some divisions with large openings among them with no doors isolating each compartment from other compartments.
15	Battery Room 1	Turbine Building	1 hour rated walls and 2 hour rated ceiling within the Switchgear rooms
16	Stairway	Auxiliary Building	All doors are 1 hour rated
17	Control Room Access	Auxiliary Building	

## Workshop Example

**Step 3: Compartment Information Gathering and Characterization:** The following tabulation provides an example of the information about fire compartments that may be used in a fire PRA project.

Item	Resolution
Fire Compartment ID #	9
Fire Compartment	Switchgear Access Room
Building	Auxiliary Building
Boundary Characteristics	The compartment is bounded by 3-hr rated fire walls, ceiling and floor.
Ventilation Features	The ventilation is provided by the Auxiliary Building HVAC system <sup>(1)</sup> . The equipment housed in this compartment can function properly and perform their safe shutdown duties in case of total loss of the HVAC system.
Fire Protection Features	The fire protection features of this compartment includes: 1. Handheld extinguishers inside the compartment (2 units) <sup>(1)</sup> 2. Wet hose reel outside the door inside the stairwell <sup>(1)</sup> 3. Smoke detectors attached to the ceiling (6 units) <sup>(1)</sup> 4. Automatic CO <sub>2</sub> system
Fire Sources	The following ignition sources were identified in this compartment. 1. MCC-A 2. MCC-B 3. 125VAC-A 4. 125VAC-B 5. ATS 6. Lighting Fixtures (10 units) <sup>(1)</sup>  Additionally the following combustibles are present: 1. Cable trays containing thermoset control cables 2. Wooden desk used by the electrical department <sup>(1)</sup>
Adjacent Compartments	The following compartments share a wall, ceiling or floor with this compartment: 1. Switchgear Room A 2. Switchgear Room B 3. Stairwell 4. Charging pump room 5. Cable spreading room
Access Routes	1. This room can be accessed from outside through the stairwell 2. Switchgear Rooms A and B are accessed through this room
Components /Systems / Cables Present	See the component and cable lists provided in Tasks 2 and 3.
SSD Human Actions Credited in this Compartment	To be completed after Task 12 is completed.

<sup>(1)</sup> Provided here to demonstrate how this part of the step may be addressed. These features are not intended to be included in the Fire PRA of this Sample Package.

## **Session 2b: Example Problems (Fire Ignition Frequency)**

## Workshop Problems for Task 6: Fire Ignition Frequency

### Workshop Problem Set 06-01

**Step 1: Mapping plant ignition sources to generic sources:** Using the information provided in this Sample Package, map the items listed in the following table to generic sources.

Equipment ID	Equipment Description	Equipment Type	Bin #	Bin Description / Comment\
HPI-B	High pressure safety injection pump B	Pump	21	Pumps
MOV-1	HPI valve	MOV	14	Electric Motors
MOV-5	RWST isolation valve	MOV	--	Less than 5hp motor
BAT-B	Train B Battery	Battery	1	Batteries
RCP-1	Reactor coolant pump 1	Pump	2	Reactor Coolant Pump
AOV-1 / (SOV-1)	Pressure operated relief valve	AOV	--	Assumed as insignificant ignition source.
PT-1	RCS pressure	Instrument	--	Assumed as insignificant ignition source.
EDG-A	Train A Emergency Diesel Generator	Diesel Generator	8	Diesel Generators
MCC-B1	Train B 480 V Motor Control Center	Motor Control Center	15	Electrical Cabinets
ATS-1	Automatic Transfer Switch	ATS	15	Electrical Cabinets
VITAL-A	Train A 120 VAC Vital Bus	120VAC Bus	15	Electrical Cabinets
SWGR-A	Train A 4160 V Bus	Switchgear	15/16	Electrical Cabinets/HEAF
LC-A	Train A 480 V Load Center	Load Center	15/16	Electrical Cabinets/HEAF
SST-A	Train A Station Service Transformer	Transformer	23a	Transformers (Dry)
BC-A	Train A Battery Charger	Battery Charger	10	Battery Chargers
DC BUS-A	Train A 125 VDC Bus	DC Bus	15	Electrical Cabinets
PNL-A	Train A 125 VDC Panel	Panelboard	15	Electrical Cabinets
INV-A	Train A Inverter	Inverter	15	Electrical Cabinets
AFW-A	Motor driven AFW pump A	Pump	21	Pumps
AFW-B	Steam driven AFW Pump B	Pump	21	Pumps
SUT-1	Startup Transformer	Transformer	29	Yard transformers (Others)

The following table provides the components specifically addressed in the Fire PRA of this Sample Package.

Equipment ID	Equipment Description	Equipment Type	Bin #	Bin Description / Comment\
TI-1	Letdown heat exchanger outlet temp	Instrument	--	Comment 1 (below)
HPI-A	High pressure safety injection pump A	Pump	21	Pumps
HPI-B	High pressure safety injection pump B	Pump	21	Pumps
AOV-2 / (SOV-2)	Letdown isolation valve	AOV	--	Comment 1
AOV-3 / (SOV-3)	Charging pump injection valve	AOV	--	Comment 1
MOV-1	HPI valve	MOV	14	Electric Motors
MOV-2	VCT isolation valve	MOV	14	Electric Motors
MOV-5	RWST isolation valve	MOV	--	Less than 5hp motor
MOV-6	RWST isolation valve	MOV	--	Less than 5hp motor
MOV-9	HPI valve	MOV	14	Electric Motors
RHR-B	RHR pump B	Pump	21	Pumps
MOV-3	Cont. sump recirc valve	MOV	14	Electric Motors
MOV-4	Cont. sump recirc valve	MOV	14	Electric Motors
MOV-8	RHR outboard suction valve	MOV	14	Electric Motors
BAT-A	Train A Battery	Battery	1	Batteries
BAT-B	Train B Battery	Battery	1	Batteries
RCP-1	Reactor coolant pump 1	Pump	2	Reactor Coolant Pump
AOV-1 / (SOV-1)	Pressure operated relief valve	AOV	--	Comment 1
MOV-7	RHR inboard suction valve	MOV	14	Electric Motors
MOV-13	PORV block valve	MOV	--	Comment 2
LI-3	Containment sump level	Instrument	--	Comment 1
LI-4	Containment sump level	Instrument	--	Comment 1
PT-1	RCS pressure	Instrument	--	Comment 1
EDG-A	Train A Emergency Diesel Generator	Diesel Generator	8	Diesel Generators
EDG-B	Train B Emergency Diesel Generator	Diesel Generator	8	Diesel Generators
ANN-1	AFW motor high temp	Annunciator	--	Comment 1
MCC-A1	Train A 480 V Motor Control Center	Motor Control Center	15	Electrical Cabinets
MCC-B1	Train B 480 V Motor Control Center	Motor Control Center	15	Electrical Cabinets
ATS-1	Automatic Transfer Switch	ATS	15	Electrical Cabinets
VITAL-A	Train A 120 VAC Vital Bus	120VAC Bus	15	Electrical Cabinets
VITAL-B	Train B 120 VAC Vital Bus	120VAC Bus	15	Electrical Cabinets
SWGR-A	Train A 4160 V Bus	Switchgear	15/16	Electrical Cabinets/HEAF
LC-A	Train A 480 V Load Center	Load Center	15/16	Electrical Cabinets/HEAF
SST-A	Train A Station Service Transformer	Transformer	23a	Transformers (Dry)
BC-A	Train A Battery Charger	Battery Charger	10	Battery Chargers
DC BUS-A	Train A 125 VDC Bus	DC Bus	15	Electrical Cabinets
PNL-A	Train A 125 VDC Panel	Panelboard	15	Electrical Cabinets
INV-A	Train A Inverter	Inverter	15	Electrical Cabinets
SWGR-B	Train B 4160 V Bus	Switchgear	15/16	Electrical Cabinets/HEAF
LC-B	Train B 480 V Load Center	Load Center	15/16	Electrical Cabinets/HEAF
SST-B	Train B Station Service Transformer	Transformer	23a	Transformers (Dry)

The following table provides the components specifically addressed in the Fire PRA of this Sample Package.

Equipment ID	Equipment Description	Equipment Type	Bin #	Bin Description / Comment\
BC-B	Train B Battery Charger	Battery Charger	10	Battery Chargers
DC BUS-B	Train B 125 VDC Bus	DC Bus	15	Electrical Cabinets
PNL-B	Train B 125 VDC Panel	Panelboard	15	Electrical Cabinets
INV-B	Train B Inverter	Inverter	15	Electrical Cabinets
LC-1	Non-Safety 480 V Load Center	Load Center	15/16	Electrical Cabinets/HEAF
LC-2	Non-Safety 480 V Load Center	Load Center	15/16	Electrical Cabinets/HEAF
SWGR-1	Non-Safety 4160 V Bus	Switchgear	15/16	Electrical Cabinets/HEAF
SWGR-2	Non-Safety 4160 V Bus	Switchgear	15/16	Electrical Cabinets/HEAF
COMP-1	Instrument air compressor	Compressor	9	Air Compressors
MOV-10	AFW discharge valve	MOV	--	Comment 2
MOV-11	AFW discharge valve	MOV	--	Comment 2
MOV-18	AFW C Pump Discharge	MOV	--	Comment 2
SST-1	Non-Safety Station Service Transformer	Transformer	23b	Transformers (Oil filled)
SST-2	Non-Safety Station Service Transformer	Transformer	23b	Transformers (Oil filled)
MCC-1	Non-Safety 480 V Motor Control Center	Motor Control Center	15	Electrical Cabinets
MCC-2	Non-Safety 480 V Motor Control Center	Motor Control Center	15	Electrical Cabinets
BC-1	Non-Safety Swing Battery Charger	Battery Charger	10	Battery Chargers
BAT-1	Non-Safety Battery	Battery	1	Batteries
DC BUS-1	Non-Safety 250 VDC Bus	DC Bus	15	Electrical Cabinets
AFW-A	Motor driven AFW pump A	Pump	21	Pumps
AFW-B	Steam driven AFW Pump B	Pump	21	Pumps
AFW-C	AFW pump C	Pump	21	Pumps
MOV-14	AFW turbine steam line isolation valve	MOV	--	Comment 2
MOV-15	AFW steam inlet throttle valve	MOV	--	Comment 2
MOV-16	AFW test line isolation valve	MOV	--	Comment 2
MOV-17	AFW test line isolation valve	MOV	--	Comment 2
MOV-19	AFW test line isolation valve	MOV	--	Comment 2
V-12	CST isolation valve	MOV	--	Comment 2
LI-1	RWST level	Instrument	--	Comment 1
LI-2	RWST level	Instrument	--	Comment 1
SUT-1	Startup Transformer	Transformer	27/28	Yard transformers (Others)

Comment 1: Assumed as insignificant ignition source.

Comment 2: Less than 5hp motor

**Workshop Problem Set 06-04**

**Step 4: Mapping Plant-Specific Locations to Generic Locations:** Using the information provided in this Sample Package, map the items listed in the following table to the applicable generic locations provided in NUREG/CR 6850. Note that some of the compartments may map to more than one Generic Location.

**Step 5: Location Weighting Factors:** Assign the location weighting factors of the Fire Compartments in the following table.

Fire Comp. #	Plant Fire Compartment	Plant Area	Generic Location	W <sub>L</sub>
1	Main Control Room	Auxiliary Building	See Note 1	1.0
2	Aux Bldg El. 0 Ft	Auxiliary Building	See Note 2	1.0
3	Cable Spreading Room	Auxiliary Building	See Note 2	1.0
4A	RHR Pump Room	Auxiliary Building	See Note 2	1.0
4B	AFW Pump Room	Auxiliary Building	See Note 2	1.0
5	Battery Room A	Auxiliary Building	See Note 3	1.0
6	Battery Room B	Auxiliary Building	See Note 3	1.0
9	SWG Access Room	Auxiliary Building	See Note 2	1.0
10	Switchgear Room A	Auxiliary Building	See Note 2	1.0
11	Switchgear Room B	Auxiliary Building	See Note 2	1.0
14	Stairway	Auxiliary Building	See Note 2	1.0
7	Containment	Containment	Containment	1.0
8A	DG-A Room	DG Bldg.	See Note 4	1.0
8B	DG-B Room	DG Bldg.	See Note 4	1.0
12	Turbine Bldg El. 0 Ft	Turbine Building	See Note 5	1.0
15	Battery Room 1	Turbine Building	See Note 6	1.0
13	Yard	Yard	See Note 7	1.0
14	Intake Structure	Intake Structure	Plant-Wide Components	1.0

Note 1: Control Room (for the Main Control Board) and Control/Aux/Reactor Building (for cable and transient fires)

Note 2: Control/Aux/Reactor Building (for cable and transient fires) and Plant-Wide Components for all other items

Note 3: Battery Room (for the batteries) and Control/Aux/Reactor Building (for cable and transient fires)

Note 4: Diesel Generator Room (for the Diesel Generators), Control/Aux/Reactor Building (for cable and transient fires), and Plant-Wide Components for all other items

Note 5: Turbine and Plant-Wide Components (for all items not specifically assigned to the Turbine Building)

Note 6: Battery Room (for the batteries) and Turbine Building (for cable and transient fires)

Note 7: Transformer Yard and Plant-Wide Components for all other items

Workshop Problem Set 06-05

**Step 5: Location Weighting Factors:** At a two-unit nuclear power plant, the Main Control Room is shared between the two units. The control room consists of two separate Main Control Boards that do not share any controls and are dedicated to one unit each. There are 5 electrical cabinets in the control room in addition to the Main Control Boards that are shared between the two units.

- a. For Unit 1, establish the Location Weighting Factor of the Main Control Board

$$W_{L, \text{MCR, Main Control Board}} = 2.0$$

- b. For Unit 1, establish the Location Weighting Factor of the electrical cabinets.


$$W_{L, \text{MCR, Electrical Cabinets}} = 2.0$$

- c. For Unit 1, establish the Location Weighting Factor of transient fires in the Main Control Room

$$W_{L, \text{MCR, Transients}} = 2.0$$

Workshop Problem Set 06-06

**Step 6: Fixed Fire Ignition Source Counts:** Estimate the ignition source counts for only those items that are noted under each picture and are visible in the foreground of the picture:



Electrical Panels: 8 vertical sections



Electrical Panels: 7 vertical sections

Transformers: 1



Transformers: 1



Electrical Panels: 5 vertical sections

Transformers: 2



Electrical Panels: 2 vertical sections



Electrical Panels: 3 vertical sections



*Electrical Panels: 2 vertical sections*



*Electrical Panels: 1 vertical sections*



*Electrical Panels: No count – Sealed with low voltage circuits*

**Workshop Problem Set 06-07**

**Step 6: Fixed Fire Ignition Source Counts:** Estimate the ignition source counts for the components identified in Step 1 above.

			Bin # and Description (per Table 6-1)												
			1	2	8	4	9	10	14	15	16	21	23a	23b	29
			Batteries	Reactor Coolant Pump	Diesel Generators	Main Control Board	Air Compressors	Battery Chargers	Electric Motors	Electrical Cabinets	High Energy Arcing Faults	Pumps	Transformers (Dry)	Transformers (Oil filled)	Yard transformers (Others)
#	Compartment	Plant Area	BAT	RCP	DG	MCB	AC	BC	EM	EC	HEAF	PMP	XFMR-Dry	XFMR-Oil	XFMR-Yard
1	Main Control Room	Control/Aux/Reactor Building	0	0	0	1	0	0	0	1	0	0	0	0	0
2	Aux Bldg El. 0 Ft	Control/Aux/Reactor Building	0	0	0	0	0	0	3	0	0	2	0	0	0
3	Cable Spreading Room	Control/Aux/Reactor Building	0	0	0	0	0	0	0	0	0	0	0	0	0
4A	RHR Pump Room	Control/Aux/Reactor Building	0	0	0	0	0	0	3	0	0	1	0	0	0
4B	AFW Pump Room	Control/Aux/Reactor Building	0	0	0	0	0	0	0	0	0	2	0	0	0
5	Battery Room A	Plant Wide Components	1	0	0	0	0	0	0	0	0	0	0	0	0
6	Battery Room B	Plant Wide Components	1	0	0	0	0	0	0	0	0	0	0	0	0
9	SWG Access Room	Plant Wide Components	0	0	0	0	0	0	0	31	0	0	0	0	0
10	Switchgear Room A	Plant Wide Components	0	0	0	0	0	1	0	25	14	0	1	0	0
11	Switchgear Room B	Plant Wide Components	0	0	0	0	0	1	0	24	14	0	1	0	0
14	Stairway	Plant Wide Components	0	0	0	0	0	0	0	0	0	0	0	0	0
7	Containment	Containment	0	1	0	0	0	0	1	0	0	0	0	0	0
8A	DG-A Room	Plant Wide Components	0	0	1	0	0	0	0	0	0	0	0	0	0
8B	DG-B Room	Plant Wide Components	0	0	1	0	0	0	0	0	0	0	0	0	0
12	Turbine Bldg El. 0 Ft	Plant Wide Components		0	0	0	2	1	0	57	28	1	0	2	0
15	Battery Room 1	Plant Wide Components	1	0	0	0	0	0	0	0	0	0	0	0	0
13	Yard	Plant Wide Components	0	0	0	0	0	0	0	0	0	0	0	0	3
14	Intake Structure	Plant Wide Components	0	0	0	0	0	0	0	0	0	0	0	0	0
		<b>Total</b>	<b>3</b>	<b>0</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>7</b>	<b>136</b>	<b>56</b>	<b>6</b>	<b>2</b>	<b>2</b>	<b>3</b>

Workshop Problem Set 06-08

**Step 7: Ignition Source Weighting Factors:** For an NPP, the fire PRA analysts have counted 23 pumps within the Plant Analysis Boundary.

- For RHR Pump RHRP-C located in RHR Pump room (FZ-03A), which in turn is located in the Reactor Building, establish the IS, J and L subscripts of:

$$W_{IS,J,L} = W_{RHRP-C,FZ-03A,AUX\ BLDG}$$

- For the same RHR Pump, RHRP-C, calculate the Ignition Source Weighting Factor

$$W = 1/23 = 0.043$$

- RHR Pump room FZ-03A contains three pumps. Calculate the ignition source weighting factor for the pumps in this compartment.

$$W = 3/23 = 0.13$$

### **Workshop Problem Set 06-09**

**Step 7: Ignition Source Weighting Factors:** For an NPP, the fire PRA analysts have counted 351 electrical cabinet vertical sections within the Plant Analysis Boundary.

- 480VAC MCC-A is composed of 32 breakers arranged in 8 vertical segments. Calculate the ignition source weighting factor for this MCC.

$$W_{\text{MCC-A}} = 8/351 = 0.023$$

- 4kV non-1E Switchgear 1 is composed of 8 breakers. Each breaker takes up one vertical segment of the switchgear. Calculate the ignition source weighting factor for this electrical panel.

$$W_{\text{SWG-1}} = 8/351 = 0.023$$

- The local control panel, CP-1, for the chemicals addition system located in the Reactor Building has the following dimensions: 2' Deep, 12' Long, 8' High. There are no partitions within the panel. Calculate the ignition source weighting factor for this electrical panel.

$$W_{\text{CP-1}} = 1/351 = 0.0028$$

Workshop Problem Set 06-10

**Step 7: Ignition Source Weighting Factors:** Using the information provided in the solution for Problem Set 06-07, calculate the component weighting factors for the components listed below.

#	Compartment	Plant Area	Bin # and Description (per Table 6-1)												
			1	2	8	4	9	10	14	15	16	21	23a	23b	29
			Batteries	Reactor Coolant Pump	Diesel Generators	Main Control Board	Air Compressors	Battery Chargers	Electric Motors	Electrical Cabinets	High Energy Arcing Faults	Pumps	Transformers (Dry)	Transformers (Oil filled)	Yard transformers (Others)
1	Main Control Room	Control/Aux/Reactor Building				1.0E+00					7.4E-03				
2	Aux Bldg El. 0 Ft	Control/Aux/Reactor Building								4.3E-01			3.3E-01		
3	Cable Spreading Room	Control/Aux/Reactor Building													
4A	RHR Pump Room	Control/Aux/Reactor Building								4.3E-01			1.7E-01		
4B	AFW Pump Room	Control/Aux/Reactor Building											3.3E-01		
5	Battery Room A	Plant Wide Components	3.3E-01												
6	Battery Room B	Plant Wide Components	3.3E-01												
9	SWG Access Room	Plant Wide Components									2.2E-01				
10	Switchgear Room A	Plant Wide Components							3.3E-01		1.8E-01	2.5E-01		5.0E-01	
11	Switchgear Room B	Plant Wide Components							3.3E-01		1.8E-01	2.5E-01		5.0E-01	
14	Stairway	Plant Wide Components													
7	Containment	Containment		1.0E+00						1.4E-01					
8A	DG-A Room	Plant Wide Components			5.0E-01										
8B	DG-B Room	Plant Wide Components			5.0E-01										
12	Turbine Bldg El. 0 Ft	Plant Wide Components	3.3E-01				1.0E+00	3.3E-01		4.2E-01	5.0E-01	1.7E-01		1.0E+00	
15	Battery Room 1	Plant Wide Components													
13	Yard	Plant Wide Components													1.0E+00
14	Intake Structure	Plant Wide Components													

Workshop Problem Set 06-11

**Transient Ignition Source Weighting Factors:** An NPP is composed of three compartments with the following characteristics:

A. Enter the influencing factors for each compartment and category:

Compartment	Influencing Factor			Cable Run (self-ignited cable fires)
	Maintenance	Occupancy	Storage	
Compartment 1	10	1	10	1,000
Compartment 2	3	1	3	--
Compartment 3	1	10	10	10,000
Total	14	12	23	11,000

B. Calculate the ignition source weighting factors for each compartment

Compartment	General Transients	Transients fires caused by welding and cutting	Cable fires caused by welding and cutting	Cable Run (self-ignited cable fires)
Compartment 1	43%	10/14	50%	9.1%
Compartment 2	14%	3/14	--	--
Compartment 3	43%	1/14	50%	90.9%
Total	100.0%	100.0%	100.0%	100.0%

C. Calculate the ignition frequencies for each compartment

	General Transients	Transients fires caused by welding and cutting	Cable fires caused by welding and cutting	Cable Run (self-ignited cable fires)
Total Location Frequency (/ry)	3.90E-03	9.70E-03	1.60E-03	4.40E-03
Compartment 1	1.67E-03	6.93E-03	8.0E-04	4.00E-04
Compartment 2	5.57E-04	2.08E-03	--	--
Compartment 3	1.67E-03	6.93E-04	8.0E-04	4.00E-03

## **Session 6b: Example Problems (Scoping Fire Modeling)**

**Workshop Problems on Task 8: Scoping Fire Modeling**

This handout includes workshop problems on the different steps of Task 8: Scoping Fire Modeling. Problems are grouped by steps.

**Step 1: Preparation for Walkdown**

Step 1 has three sub-steps: 1) Estimate heat release rate for fixed ignition source screening, 2) Target and intervening combustibles damage or ignition criteria, and 3) Develop a zone of influence.

**Workshop problem 08-01:**

**Step 1.1: Estimate heat release rate for fixed ignition source screening:** Assign a heat release rate to the ignition sources depicted in the pictures of the following Table 08-01. For this exercise, assume that the plant has a mix of qualified and unqualified cables. The heat release rates are listed in Table E-1 of NUREG/CR-6850.

**Table 08-01: Inputs for Workshop problems 1**

Ignition Source	Table E-1 Case	98 <sup>th</sup> Percentile HRR	Justification
 Dry transformer	7	69 kW	Table 8-1 in NUREG/CR-6850 suggests the use of the "Electric Motors" heat release rate probability distribution for dry transformers
 Fire protection panel	4	464 kW	Fire protection panels have usually moderate to high combustible loading (including relays circuit cards etc.). It is therefore assumed that the fire may be able to propagate to more than one cable bundle.
 Ventilation sub-system	7	69 kW	Table 8-1 in NUREG/CR-6850 suggests the use of the "Electric Motors" heat release rate probability distribution for ventilation sub-systems
fc	6	211 kW	Table 8-1 in NUREG/CR-6850

Ignition Source	Table E-1 Case	98 <sup>th</sup> Percentile HRR	Justification
 <p data-bbox="354 541 428 564">Pumps</p>			<p data-bbox="1092 275 1339 464"><i>suggests not to screen pumps due to the need of evaluating oil fires. Table E-1 suggests a heat release rate of 211 kW for electrical fires only.</i></p>

**Workshop Problem Set 08-02:**

**Step 1.2: Target and intervening combustible damage and ignition criteria:** Assign damage criteria to the ignition sources depicted in Table 08-01. For this exercise, assume that the plant has a mix of thermoset and thermoplastic cable. Generic damage criteria are listed in Table H-1 of NUREG/CR-6850.

**Table 08-02: Inputs for workshop problem 2**

Target/Intervening Combustible	Damage Criteria	Justification
Cables in a ladder back tray	6 kW/m <sup>2</sup> (0.5 BTU/ft <sup>2</sup> s) or 205°C (400°F)	<i>From Table H-1 in NUREG/CR-6850. Page H-2 of NUREG/CR-6850 suggests using the "weakest link" for determining damage criteria. Therefore the damage criteria for thermoplastic cable were selected.</i>
Cables in a solid tray	6 kW/m <sup>2</sup> (0.5 BTU/ft <sup>2</sup> s) or 205°C (400°F)	<i>Page H-2 of NUREG/CR-6850 suggests using the "weakest link" for determining damage criteria. Therefore the damage criteria for thermoplastic cable were selected. Solid trays are treated as conduits in this task. See second bullet in page H-1 of NUREG/CR-6850.</i>
Thermoset cable in a conduit	11 kW/m <sup>2</sup> (1.0 BTU/ft <sup>2</sup> s) or 330°C (625°F)	<i>From Table H-1 in NUREG/CR-6850. See second bullet in page H-1 of NUREG/CR-6850.</i>
Motor operated valve (MOV).	6 kW/m <sup>2</sup> (0.5 BTU/ft <sup>2</sup> s) or 205°C (400°F)	<i>See section H.2 in NUREG/CR-6850. Cables connecting the MOV are assumed thermoplastic in this example.</i>
Cabinet with a solid state device	3 kW/m <sup>2</sup> (0.25 BTU/ft <sup>2</sup> s) or 65°C (150°F)	<i>See section H.2 in NUREG/CR-6850.</i>

**Workshop Problem Set 08-03**

**Step 1.3: Develop zone of influence:** Calculate the heat release rate required for generating target damage for the following ignition source/target combination and determine if the ignition source can be screened. Use the engineering calculations described in NUREG-1805 for determining the heat release rate value.

- Target in the hot gas layer:
  - A cable tray target is located near the ceiling in a room approximately 21' by 7' and has a normally closed door on each end. The room is approximately 20' high. The inside walls of the MCC room are reinforced concrete. There is one MCC cabinet in the room. The MCC cabinet has unqualified cable.

The MQH room temperature correlation described in Section 2.6 of NUREG-1805 was selected for calculating the hot gas layer temperature in the room. Input values for the MQH model are listed in Table 08-03. Notice that a heat release rate of 600 kW generates room temperatures of approximately 205 °C. This calculation assumes a 20-min fire duration and one open door in the room.

**Table 08-03: MQH room temperature correlation analysis**

<b>MCC Room</b>	
Length [ft]:	21
Width [ft]:	7
Height [ft]:	20
<b>MQH Temperature Correlation</b>	
<b>Inputs</b>	
Ambient temperature [C]	20
Duration [sec]	1200
Opening area [m <sup>2</sup> ]	2
Height of opening [m]	2
Room length [m]	6
Room width [m]	2
Room height [m]	6
Thermal conductivity [kW/mK]	0.0014
Density [kg/m <sup>3</sup> ]	2000
Specific heat [kJ/kg]	0.88
Wall thickness [m]	0.6
HRR [kW]	600
<b>Results</b>	
Room Temp [C]	205

- Target subjected to flame impingement or fire plume temperatures:
  - A vertical cable tray is located 5' ft from a floor based ventilation subsystem.

The Heskestad' flame height and plume temperature correlations described in Chapter 3 and 9 of NUREG-1805 respectively were selected for calculating flame height and room temperature. Input values for the models are listed in Table 08-04 and Table 08-05. Notice that a heat release rate of 250 kW generates a flame height of 5'. In the case of the plume temperature correlation, a heat release rate of 165 kW generates damage temperatures of approximately 205 °C at the location of the target.

**Table 08-04: Heskestad flame height correlation**

<b>Heskestad's Flame Height Correlation</b>		
<b>Inputs</b>		
Fire diameter [m]	0.6	
HRR [kW]	250	
<b>Results</b>		
	[m]	[ft]
Flame height [m]	1.5	5.0

**Table 08-05: Heskestad plume temperature correlation**

<b>Heskestad Plume Temperature Correlation</b>	
<b>Inputs</b>	
Ambient temperature [C]	20
Fire location factor	1
HRR [kW]	165
Fire elevation [m]	0
Target Elevation [m]	1.5
Radiation Fraction	0.40
Fire Diameter [m]	1
<b>Results</b>	
Plume Temp [C]	202

- Target subjected to flame radiation:
  - A conduit is located 3 ft from a battery charger with qualified cable.

The point source flame radiation model described in section 5.3 of NUREG-1805 was selected for calculating the incident heat flux at the location of the target. Input values for the point source model are listed in

Table 08-06. Notice that a heat release rate of 160 kW generates incident heat fluxes of 5 kW/m<sup>2</sup>.


**Table 08-06: Point source flame radiation model**

<i>Point Source Flame Radiation Model</i>	
<b>Inputs</b>	
<i>Fire heat release rate [kW]</i>	160
<i>Radiation fraction</i>	0.40
<i>Distance from flames [m]</i>	1
<b>Results</b>	
<i>Heat flux [kW/m<sup>2</sup>]</i>	5.1

**Workshop Problem Set 08-04**

**Step 2: Plant Walkdown:** Inspect the ignition source and target combination in the pictures included in Table 08-07 and determine the appropriate zone of influence calculation necessary.

**Table 08-07: Inputs for Workshop problems 1**

Ignition Source	Ignition Source/Target	Zone of Influence	Distance
	<p><i>Fire protection panel/Conduits above</i></p>	<p><i>Targets in the conduits will be affected by flame or plume conditions. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</i></p>	<p><i>~4'</i></p>
	<p><i>Electrical cabinets/Conduit</i></p>	<p><i>Targets in the conduits will be affected by flame or plume conditions. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</i></p>	<p><i>~3'</i></p>
	<p><i>Ventilation Subsystem/Ventilation Subsystem</i></p>	<p><i>Adjacent ventilation subsystem will be affected by flame radiation. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</i></p>	<p><i>~2'</i></p>

Ignition Source	Ignition Source/Target	Zone of Influence	Distance
	<p>Ventilation Subsystem/MOV's</p>	<p>MOV's and associated cables will be affected by flame radiation from a fire in the ventilation subsystem. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</p>	<p>~3'</p>
	<p>Electrical cabinet/Cable tray</p>	<p>Targets in the cable tray will be affected by flame or plume conditions. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</p>	<p>~4'</p>
	<p>Transformer/Cable tray</p>	<p>Targets in the cable tray will be affected by flame or plume conditions. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</p>	<p>~5'</p>
	<p>Pump/Pump</p>	<p>Adjacent pump will be affected by flame radiation. Depending on the fire size and the characteristics of the room, the target may also be affected by hot gas layer temperatures.</p>	<p>~4'</p>

### **Step 3: Verification of Screened Ignition Sources**

No workshop problem for Step 3.

### **Workshop Problem Set 08-05**

**Step 4: Calculation of Severity Factors:** Calculate the severity factors for the ignition source and target combinations listed in Workshop Problem 08-03. Use the results of Workshop Problem Set 08-03 as inputs to this exercise.

- Target in the hot gas layer
  - Ignition source: MCC cabinet with unqualified cable
  - Heat release rate probability distribution: Case 4, Gamma distribution with  $\alpha = 2.6$  &  $\beta = 67.8$ .
  - Critical heat release rate: 600 kW
  - Severity factor: Using a Microsoft Excel function,  $SF = 1-GAMMADIST(600,2.6,67.8,TRUE) \approx 0.004$
  
- Target subjected to flame impingement or plume temperatures
  - Ignition source: Ventilation subsystem
  - Heat release rate probability distribution: Case 7, Gamma distribution with  $\alpha = 2.0$  &  $\beta = 11.7$ .
  - Critical heat release rate: 250 kW or 165 kW
  - Severity factor: Using a Microsoft Excel function,  $SF = 1-GAMMADIST(250,2,11.7,TRUE) \approx 1.2E-8$  or  $SF = 1-GAMMADIST(165,2,11.7,TRUE) \approx 1.1E-5$
  
- Target subjected to flame radiation
  - Ignition source: Battery charger with qualified cable
  - Heat release rate probability distribution: Case 2, Gamma distribution with  $\alpha = 0.7$  &  $\beta = 216$ .
  - Critical heat release rate: 160 kW
  - Severity factor: Using a Microsoft Excel function,  $SF = 1-GAMMADIST(160,0.7,216,TRUE) \approx 0.83$

*It should be noted that this problem can also be solved using the discretized Gamma distribution tables in Appendix E of NUREG/CR-6850. Consider the target subjected to flame radiation, which was assigned the following Case 2 gamma distribution for heat release rate:*

Bin	Heat Release Rate – kW (Btu/s)			Severity Factor (P)
	Lower	Upper	Point Value	
1	0 (0)	90 (85)	34 (32.7)	0.508
2	90 (85)	179 (170)	130 (123)	0.202
3	179 (170)	269 (255)	221 (209)	0.113
4	269 (255)	359 (340)	310 (294)	0.067
5	359 (340)	448 (425)	400 (379)	0.041
6	448 (425)	538 (510)	490 (464)	0.026
7	538 (510)	628 (595)	579 (549)	0.016
8	628 (595)	717 (680)	669 (634)	0.010
9	717 (680)	807 (765)	759 (719)	0.006
10	807 (765)	897 (850)	848 (804)	0.004
11	897 (850)	986 (935)	938 (889)	0.003
12	986 (935)	1076 (1020)	1028 (974)	0.002
13	1076 (1020)	1166 (1105)	1118 (1060)	0.001
14	1166 (1105)	1255 (1190)	1208 (1145)	0.001
15	1255 (1190)	Infinity	1462 (1386)	0.001

Figure 1: Table E-3 from NUREG/CR-6850

The severity factor is the sum of the severity factor column after the “Point Value” 160 kW (highlighted values in Figure 1).

**Workshop Problem Set 08-06**

**Step 5: Calculation of Revised Compartment Fire Frequency:** Determine a revised compartment ignition frequency for switchgear room A assuming the walkdown results listed in Table 08-08.

**Table 08-08: Summary of Task 8 calculations**

Equipment Description	Count	Fire Condition	Measured Distance (ft)	Table E-1 Case	Critical HRR (Table E-1)	Room Area (ft <sup>2</sup> )	Room Height (ft)	Calculated HRR (kW)	Room Temp (F)	Screened	Severity Factor	Count Task 8
Train A 4160 V Bus	8	flame or plume	1.7	9	Do Not Screen	1350	20	7	N/A	No	1.00	8.00
Train A 480 V Load Center	6	flame radiation	4.9	9	Do Not Screen	1350	20	401	N/A	No	1.00	6.00
Train A Station Service Transformer	1	flame radiation	4.5	9	Do Not Screen	1350	20	336	N/A	No	1.00	1.00
Train A Battery Charger	1	flame or plume	2.9	4	464	1350	20	25	264	No	0.98	0.98
Train A 125 VDC Bus	8	flame or plume	0.7	4	464	1350	20	1	264	No	1.00	8.00
Train A 125 VDC Panel	1	flame radiation	2.8	4	464	1350	20	129	264	No	0.60	0.60
Train A Inverter	1	flame radiation	2.0	4	464	1350	20	64	264	No	0.88	0.88

**Table 08-09: Comparison of switchgear room A ignition frequency**

Task 6	Switchgear Room A	≈ 1.5E-02
Task 8	Switchgear Room A	≈ 1.5E-02

## **Session 10b: Example Problems (Detailed Fire Modeling)**

# WORKSHOP PROBLEMS ON TASK 11A: DETAILED FIRE MODELING

---

This handout includes workshop problems on the different steps of Task 11: Detailed Fire Modeling. Problems are grouped according to the steps defined in NUREG/CR-6850. Detailed fire modeling will be conducted in the switchgear access room (Room 9) located in elevation 20 ft of the auxiliary building.

## ***Workshop Problem Set 11a-01***

***Step 1a: Identify and Characterize Compartments:*** Review the following information necessary for fire modeling purposes.

- Room size: For the purpose of this exercise, assume the size of the room is 45' by 22' by 20' high.
- Wall boundaries: The surfaces, floor, ceiling, and walls are reinforced concrete. All the surfaces are 2' thick.
- Doors: The room has three doorways: 1) a double door connecting to switchgear room A, 2) a double door connecting to switchgear room B, and 3) a single door connecting to the stairwell. The size of a single door is 6.5' by 3'.
- Mechanical Ventilation: The switchgear access room has a mechanical ventilation system with a balance 5 air changes per hour.

## **Workshop Problem Set 11a-02**

**Step 2a: Identify and Characterize fire Detection and Suppression Features and Systems:** Review the following information necessary for fire modeling purposes.

- Prompt detection: Prompt detection is not credited since there is no incipient fire detection system in the room and no continuous fire watch.
- Prompt suppression: Prompt suppression is not credited since there is no continuous fire watch in the room.
- Fixed fire detection system/s (type, and sensor location): An automatic fire detection system is credited since the room is equipped with an automatic fire detection system. The location of the relevant detectors is specified in the corresponding scenario descriptions later in this document.
- Fixed fire suppression system/s (type and nozzle location): An automatic CO<sub>2</sub> system is credited since the room is equipped with an automatic CO<sub>2</sub> system. Upon smoke detection alarm, a timer starts providing 60 seconds delay for life safety purposes. The CO<sub>2</sub> is released after the delay time. The soak time is approximately 20 min.
- Fire brigade arrival time: The fire brigade arrival time is assumed to be 15 min.
- Delayed detection: Delayed detection is credited and assumed to be 15 minutes (consistent with the example in page P-14 of NUREG/CR-6850).

**Workshop Problem Set 11a-03**

**Step 3a: Characterize Fire Ignition Sources:** From the Task 6 (Fire Ignition Frequencies) calculation package, list the fixed ignition sources located in the switchgear access room (room 9) and assign a heat release rate probability distribution to each of them from Table G-1 of NUREG/CR-6850.

**Solution:** Table 10 lists the recommended answer to workshop problem 3.


**Table 10: Summary of ignition source characteristics in the switchgear access room.**

Equipment ID	Equipment Description	Case (Table E-1 of NUREG/CR-6850)	HRR Profile (Page G-6 in NUREG/CR-6850)
MCC-A1	Train A 480 V Motor Control Center	Case 3	t <sup>2</sup> grow to a peak of 211 kW in 12 min followed by steady burning for 8 additional minutes
MCC-B1	Train B 480 V Motor Control Center	Case 3	t <sup>2</sup> grow to a peak of 211 kW in 12 min followed by steady burning for 8 additional minutes
VITAL-A	Train A 120 VAC Vital Bus	Case 3	t <sup>2</sup> grow to a peak of 211 kW in 12 min followed by steady burning for 8 additional minutes
VITAL-B	Train B 120 VAC Vital Bus	Case 3	t <sup>2</sup> grow to a peak of 211 kW in 12 min followed by steady burning for 8 additional minutes
Transients	Regular solid transient ignition sources.	Case 8	t <sup>2</sup> grow to a peak of 317 kW in 12 min followed by steady burning for 8 additional minutes

**Step 4a: Identify Secondary Combustibles:** No workshop problem is associated with this step. The following discussion provides an example of how to identify and characterize secondary combustibles.

Sample Analysis for Step 4a:

For the purpose of this example, let's assume that there is one cable tray stack above each cabinet in the room. Each stack has two trays. The first tray is 1' above each cabinet. The second tray in the stack is 1.5' above the first tray. The trays are ladder-back. A pictorial representation of the secondary combustibles is provided in Figure 2.



**Figure 2: Pictorial representation of the secondary combustibles. Drawing not to scale.**

From Table 10, the cabinets in the switchgear access room will have a peak heat release rate of 211 kW. Heskestad's flame height correlation (Chapter 3 of NUREG 1805) suggests a flame height of approximately 4.6' above the ignition source. Therefore, the cable tray stack above the cabinet is expected to ignite and contributing to the fire intensity. Table 11 lists the Heskestad's flame height correlation analysis.


**Table 11: Heskestad's flame height correlation analysis.**

Heskestad's Flame Height Correlation	
<b>Inputs</b>	
Fire diameter [m]	0.6
HRR [kW]	211
<b>Results</b>	
Flame height [m]	1.4
Flame height [ft]	4.6

**Step 5a: Identify and Characterize Target Sets:** No workshop problem is associated with this step. The following discussion provides an example of how to identify and characterize target sets. In practice, this step requires highlighting of cable tray and conduit targets in room layout drawings based on cable routing analysis and plant walkdowns.

Sample Analysis for Step 5a:

For the purpose of this exercise, let's assume that there are two target sets in the room: 1) HCBT-35A and HCBT-37B, and 2) VCBT-20A, and VCBT-20B. These trays are identified in Figure 3. The trays have both thermo-set and thermo-plastic cables. Specifically, a fire damaging either the two horizontal trays or the two vertical trays will generate the postulated plant condition.



**Figure 3: Cable tray locations in the switchgear access room**

**Tray locations:**

- HCBT 35A: This horizontal tray comes into the switchgear access room from switchgear room A. The tray is the second tray in an elevated stack. The lowest tray in the stack is at elevation 33' (13' from the floor). The target tray, HCBT 35A, is at elevation 35' (15' ft from the floor and 2' above the lowest tray in the stack).
- HCBT 37B: This horizontal tray comes in the south direction into the switchgear access room from switchgear room B and turns west. The tray is the first tray in an elevated stack. It is located at elevation 37' (17' from the floor). At the point the cable tray crosses HCBT 35A, it is the third tray in the stack.
- VCBT 20A: This is a vertical cable tray in the south west corner of the room. The tray comes into the room through a floor penetration at elevation 20' and runs up to the ceiling.
- VCBT 20B: This is a vertical cable tray in the south west corner of the room. The tray comes into the room through a floor penetration at elevation 20' and runs up to the ceiling.

### Workshop Problem 11a-04

**Step 6a: Define the Fire Scenarios to be Analyzed:** Define the fire scenarios to be analyzed in the switchgear access room using the information provided or collected in the first five steps.


**Solution:** The following tables and figures describe the fire scenarios defined for analysis. For the purpose of this exercise, only the scenarios that will be analyzed in detail in upcoming workshop problems have been defined in detail.

- Fixed ignition source fire scenarios: Fixed ignition source fire scenarios are postulated in the two closest cabinets to the target trays.

**Table 12: Summary of scenario 1.**

<b>Scenario 1:</b> A fire in the MCC-A cabinet affecting the two horizontal cable tray targets. The targets could be affected by hot gas layer temperatures, flame radiation or horizontal flame spread.	
Ignition Source	MCC-A cabinet. The fire is postulated 1' below the top of the cabinet. The cabinet is 7' high.
Secondary combustibles	Cable tray stack above the electrical cabinet.
Target	HCBT-35A, HCBT-37B. The pinch point is located 2' horizontally from the cabinet (closest distance from fire to pinch point).
Credited detection	Automatic fire detection system
Credited suppression	Automatic CO2 system and fire brigade

Figure 4 provides a pictorial representation of this scenario.



**Figure 4: Pictorial representation of fire scenario 1. Drawing not to scale.**


**Table 13: Summary of scenario 2.**

<b>Scenario 2:</b> A fire in the 120VAC-A cabinet affecting the two horizontal cable tray targets. The targets could be affected by hot gas layer temperatures, direct flame radiation, or horizontal flame spread.	
Ignition Source	120VAC-A cabinet
Secondary combustibles	Cable tray stack above the electrical cabinet.
Target	HCBT-35A, HCBT-37B
Credited detection	Automatic fire detection system
Credited suppression	Automatic CO2 system and fire brigade

**Table 14: Summary of scenario 3.**

<b>Scenario 3:</b> A fire in the 120VAC-A cabinet affecting the vertical cable tray targets. The targets could be affected by hot gas layer temperatures, direct flame radiation, or horizontal flame spread..	
Ignition Source	120VAC-A cabinet
Secondary combustibles	
Target	HCBT-35A, HCBT-37B
Credited detection	Automatic fire detection system
Credited suppression	Automatic CO2 system and fire brigade

Finally, Figure 4 illustrates the location of the postulated fires.



**Figure 5: Pictorial representation of the location of the postulated fire scenarios.**

- Transient ignition source fire scenarios: Only regular solid transient fire scenarios at floor level are postulated in this room. Since the room does not contain any mechanical equipment requiring lubrication or oil, fires resulting from combustible liquid spills are not postulated.

**Table 15: Summary of scenario 4.**

<b>Scenario 4:</b> A transient fire at floor level affecting the two horizontal cable tray targets. The targets could be affected by hot gas layer temperatures, flame impingement or fire plume temperatures.	
Ignition Source	Floor based transient fire
Secondary combustibles	
Target	VCBT-20A, VCBT-20B
Credited detection	Automatic fire detection system
Credited suppression	Automatic CO2 system and fire brigade

Figure 6 provides a pictorial representation of this scenario.




Figure 6: Pictorial representation of fire scenario 4. Drawing not to scale.

Table 16: Summary of scenario 5.

<b>Scenario 5:</b> A transient fire at floor level affecting the two vertical cable tray targets. The targets could be affected by hot gas layer temperatures, flame impingement or direct flame radiation.	
Ignition Source	Floor based transient fire
Secondary combustibles	
Target	VCBT-20A, VCBT-20B
Credited detection	Automatic fire detection system
Credited suppression	Automatic CO2 system and fire brigade

Figure 7 illustrate the location of the postulated transient fires.




Figure 7: Pictorial representation of the location of the postulated fire scenarios.

- Additional scenarios that should be considered include self-ignited cable fires and junction box fires since this room has unqualified cable.

**Step 7a: Conduct Fire Growth and Propagation Analysis:** For the purpose of this workshop, only two of the fire scenarios listed in the previous section are analyzed in detail: Scenario 1, and Scenario 4.

**Workshop Problem 11a-05:**

Determine if a fire in the ignition sources associate with scenarios 1 and 4 can produce room wide damage in the switchgear access room. If the ignition sources alone are not expected to generate room wide damage, determine the amount of secondary combustibles necessary to achieve it.

**Solution:**

A 1.1 MW fire is necessary for generating room wide damage in the aux switchgear access room. Using the MQH Room Temperature correlation (NUREG 1805), a 1.1 MW fire may generate a room temperature of 205 °C, which is the assumed damage temperature (Appendix H of NUREG/CR-6850) for thermoplastic cables in the aux control room. The aux control room has approximately 1000 ft<sup>2</sup> floor and 20 ft high ceiling. All room surfaces are concrete. The calculation assumes one single open door and a 20 min fire duration. Table 17 lists the inputs and output of the MQH room temperature analysis.

**Table 17: Summary of room temperature analyses using the MQH model.**

MQH Temperature Correlation		MQH Temperature Correlation		MQH Temperature Correlation	
Single cabinet cubicle fire		Transient fire		Limiting fire size	
<b>Inputs</b>		<b>Inputs</b>		<b>Inputs</b>	
Ambient temperature [C]	20	Ambient temperature [C]	20	Ambient temperature [C]	20
Duration [sec]	1200	Duration [sec]	1200	Duration [sec]	1200
Opening area [m <sup>2</sup> ]	2	Opening area [m <sup>2</sup> ]	2	Opening area [m <sup>2</sup> ]	2
Height of opening [m]	2	Height of opening [m]	2	Height of opening [m]	2
Room length [m]	14	Room length [m]	14	Room length [m]	14
Room width [m]	7	Room width [m]	7	Room width [m]	7
Room height [m]	6	Room height [m]	6	Room height [m]	6
Thermal cond [kW/mK]	0.0014	Thermal cond [kW/mK]	0.0014	Thermal cond [kW/mK]	0.0014
Density [kg/m <sup>3</sup> ]	2000	Density [kg/m <sup>3</sup> ]	2000	Density [kg/m <sup>3</sup> ]	2000
Specific heat [kJ/kg]	0.88	Specific heat [kJ/kg]	0.88	Specific heat [kJ/kg]	0.88
Wall thickness [m]	0.6	Wall thickness [m]	0.6	Wall thickness [m]	0.6
HRR [kW]	211	HRR [kW]	317	HRR [kW]	1100
<b>Results</b>		<b>Results</b>		<b>Results</b>	
Room Temp [C]	<b>82</b>	Room Temp [C]	<b>102</b>	Room Temp [C]	<b>205</b>

Both an electrical cabinet and a transient fire are postulated at floor level in the switchgear access room. Appendix G of NUREG/CR-6850 suggests that the 98<sup>th</sup> percentile heat release rates for these fires are 211 kW and 317 kW (see also Table 10). These fire intensities are lower than the critical value of 1.1 MW calculated earlier required for room wide damage. Consequently, fire propagation to nearby cable trays or secondary combustibles (if available) is necessary to reach the critical fire intensity.

The cable tray heat release rate model described in Chapter 7 of NUREG-1805 suggests a heat release rate of 265 kW for a 1 m<sup>2</sup> for a bench scale HRR of 589 kW/m<sup>2</sup> (PE/PVC material). With this approximation:

- If the fire starts in an electrical cabinet, approximately 5 trays will need to burn to produce a 1.9 MW fire assuming a 1 m<sup>2</sup> of tray on fire:  $(1100 - 211)/265 \approx 4$  (assuming a tray length of approximately 3').
- If the fire starts as a transient fire, approximately 6 trays will need to burn to produce a 1.9 MW fire assuming a 1 m<sup>2</sup> of tray on fire:  $(1100 - 317)/265 \approx 3$  (assuming a tray length of approximately 3').

In the case of self ignited or junction box fires, a total of  $1100/265 \approx 5$  trays will need to be on fire in order to generate room wide damage.

This analysis will serve as basis for decision making in selecting and analyzing fire scenarios in the aux control room. In this particular room, it appears that there are not enough trays above the cabinets or transients where the fire is postulated to generate room wide damage without significant horizontal flame spread and if suppression activities fail before fire propagates upward to at least five or six trays.

## Workshop Problem 11a-06

Determine the time to target damage, time to smoke detection, time to automatic suppression and the fire brigade arrival time for scenario 1.

### Solution:

- Time to target damage: Time to target damage is assumed to be: 1) the time required for the fire to heat up the cable trays to its damage temperature by direct flame radiation, or 2) the time to room heat up to cable damage temperature. In either case, the fire growth profile will be an important factor in this analysis.

*Heat release rate profile for the ignition source:* Table 10, the heat release rate profile for this ignition source is  $t^2$  grow to a peak of 211 kW in 12 min followed by steady burning for 8 additional minutes. This is the profile recommended in NUREG/CR-6850 for this electrical cabinet, page G-6.

*Heat release rate from secondary combustibles:* Recall that the secondary combustibles (cable tray stack above the panel) is expected to contribute to the fire intensity. Consequently, the heat release rate profile should include such contribution. Appendix R of NUREG/CR-6850 describes the following model for fire propagation in cable trays: the first tray above the ignition source will ignite at the calculated time using fire modeling tools. The second tray will ignite 4 minutes after the first one. Evaluating the flame height and plume temperature using the corresponding correlations from Heskestad (Chapters 3 & 9 in NUREG 1805), both models suggest ignition of the first tray in approximately 3 to 5 min. Therefore, ignition of the second tray is expected in approximately 9 min after ignition. Table 18 lists the solution of the correlations as a function of time. Notice that between times 4 and 5 min, the flame height reaches 1' (the location of the first tray above the cabinet). At this time however, the plume temperature has exceeded the cable damage temperature.

**Table 18: Summary of Heskestad's flame height and plume temperature analysis as a function of time.**

Time (min)	HRR (kW)	Flame height (ft)	Plume Temp (F)
0	0	0.0	68
1	1	0.0	123
2	6	0.0	226
3	13	0.2	380
4	23	0.7	596
5	37	1.2	895
6	53	1.8	1305
7	72	2.3	1871
8	94	2.7	2663
9	119	3.2	3794
10	147	3.7	5458
12	211	4.6	12138
14	211	4.6	12138
16	211	4.6	12138

Considering that the cables above the cabinet are expected to ignite, the contribution from the cable tray fire should be included in the analysis. The heat release rate profile listed in Table 19 is obtained using the cable tray heat release rate model described in Chapter 7 of NUREG-1805 with a bench scale HRR of 589 kW/m<sup>2</sup> (PE/PVC material). Notice that the total heat release rate profile includes the contribution from both, the cabinet fire and the cable tray fire.

**Table 19: Summary of heat release rate profile and room temperature analysis as a function of time.**

Tray width [m]:	0.6					
Tray sep [m]:	0.46					
Bench Scale HRR [kW/m <sup>2</sup> ]	589					
Ignition Source	Length [m]	Fire Duration [min]	HRR [kW] for cable trays	HRR for electrical cab [kW]	Total HRR [kW]	Room Temp [F]
Electrical cabinet		0		0	0	Ambient
Tray 1	0.6	5	95	37	132	134
Tray 2	1.03	9	164	119	283	187
		10		147	311	197
		12		211	375	219
		14		211	375	223
		16		211	375	226
		18		211	375	229
		20		211	375	232

In the case of room heat up, Table 19 suggests that the fire will not generate hot gas layer temperatures capable of producing room wide damage. These temperatures were calculated using the MQH model for room temperature. The results are also consistent with the analysis in workshop problem 5.

In the case of direct flame radiation, the pinch point is located approximately 2' from the fire. The point source flame radiation model (see Chapter 5 of NUREG 1805), suggest a damaging incident heat flux 2' from the ignition source from a fire intensity of 60 kW. This intensity is lower than the peak calculated earlier and listed in Table 19. A 60 kW fire is expected somewhere in between 5 and 9 min due to the fire quickly propagating to cable trays above. The point source flame radiation analysis is documented in Table 20. This heat flux result bounds the flame spread analysis since the fire at the ignition source location is capable of impacting the target.

**Table 20: Summary of point source flame radiation model analysis**

Point Source Flame Radiation Model	
<b>Inputs</b>	
Fire heat release rate [kW]	60
Radiation fraction	0.40
Distance from flames [m]	0.6

<b>Results</b>	
Heat flux [kW/m <sup>2</sup> ]	<b>5.3</b>

- Time to smoke detection:

The time to smoke detection is assumed to be 1 min. The technical basis for this assumption is as follows: The time to smoke detection listed in Table 21 below are calculated using the model described in Chapter 11 of NUREG 1805. Notice that for vertical and horizontal distances from the ignition source in the order of 6 meters, calculated times to detection are in the order of seconds, which suggests that the 1 min assumption is conservative. The time to detection calculations were conducted conservatively assuming a low heat release rate of 25 kW. It should be noted that these activation times are not considering any incipient stage of the fire development, e.g., smoldering.

**Table 21: Time to detector activation**

Seconds		Horizontal Radial Distance (m)					
		1	2	3	4	5	6
Vertical Height Above Fire (m)	1	0.5	1.3	2.4	3.9	5.7	7.9
	2	0.8	1.3	2.1	3.2	4.5	6.0
	3	1.2	1.6	2.2	3.1	4.2	5.4
	4	1.6	2.0	2.5	3.3	4.2	5.3
	5	2.1	2.4	2.9	3.6	4.4	5.4
	6	2.6	2.9	3.4	4.0	4.7	5.6

- Time to automatic suppression: Assuming a smoke detection signal in 1 min, and considering the delay time of 60 for the automatic CO<sub>2</sub> system, the time for automatic suppression is estimated as 2 min.
- Time to fire brigade arrival: The time to fire brigade arrival at the room is estimated as 15 min from brigade drill records.

### Workshop Problem 11a-07

Determine the time to target damage, time to smoke detection, time to automatic suppression and the fire brigade arrival time for scenario 4.

#### Solution:

- Time to target damage: Time to target damage is assumed to be: 1) the time required for the fire to heat up the cable trays to its damage temperature from fire plume exposure, or 2) the time to room heat up to cable damage temperature, whichever is less. In either case, the fire growth profile will be an important factor in this analysis.

*Heat release rate profile for the ignition source:* From Table 10, the heat release rate profile for this ignition source is  $t^2$  growth to a peak of 317 kW in 12 min followed by steady burning for 8 additional minutes. This is the profile recommended in page G-6 of NUREG/CR-6850 for this electrical cabinet. Similar to the flame height and plume temperature analysis in workshop problem 6, Table 22 lists the corresponding results for the transient fire. The results suggest that the fire will not affect cable trays located 13' above the floor since the plume temperature does not reach 405 °F.

**Table 22: Summary of Heskestad's flame height and plume temperature analysis as a function of time.**

Time (min)	HRR (kW)	Flame height (ft)	Plume Temp (F) (at 13' above the floor)
0	0	0.0	68
1	2	0.0	72
2	9	0.0	79
3	20	0.5	88
4	35	1.2	98
5	55	1.8	110
6	79	2.4	123
7	108	3.0	137
8	141	3.6	152
9	178	4.1	168
10	220	4.7	186
12	317	5.7	226
14	317	5.7	226
16	317	5.7	226

- Time to smoke detection: Time to smoke detection is assumed to be 1 min based on the results presented in Table 21.
- Time to automatic suppression: Assuming a smoke detection signal in 1 min, and considering the delay time of 60 for the automatic CO<sub>2</sub> system, the time for automatic suppression is estimated as 2 min.
- Time to fire brigade arrival: The time to fire brigade arrival at the room is estimated as 15 min from brigade drill records.

**Workshop Problem 11a-08**

Let's assume that MCC-A1, which is the ignition source in scenario 1 it's a 4160V switchgear. In this case, a high energy arcing fault event should be also postulated and evaluated. Determine if the cable tray targets will be within the zone of influence of a high energy arcing fault.

**Solution:** The two horizontal trays, HCBT-35A and HCBT-37B are located 6' vertically and 2' horizontally from the cabinet. According to the criteria listed in pages M-13 and M-14 or NUREG-CR/6850, the target trays will be outside the zone of influence. However, the stack of cable trays above the cabinet (the secondary combustibles) will be within the zone of influence, and therefore, will ignite at time zero. The time to target damage calculated in workshop problem 6 will be affected due to different ignition time of secondary combustibles.

**Step 8a: Conduct Fire Detection and Suppression Analysis:** The detection and suppression is reflected in the risk analysis with the non-suppression probability, which is calculated using a Detection/Suppression event tree approach discussed in Appendix P of NUREG/CR-6850, Detection and Suppression Analysis. Recall that the switchgear access room is equipped with a smoke detection system, and an automatic CO<sub>2</sub> system. The CO<sub>2</sub> system has a 60 second warning alarm delay. In addition to these fixed systems, the fire brigade can also provide manual suppression activities.

Considering the above fire protection features, the suppression strategy in the switchgear access room can be summarized as:

1. Indication of smoke detection in control room
2. Control room sends an operator to the switchgear access room to confirm the fire
3. If fire is confirmed, the operator first determines if the automatic CO<sub>2</sub> system operated.
4. If further suppression activities are warranted after any of the automatic systems, manual suppression by the fire brigade may be used.

**Workshop Problem Set 11a-09**

Develop a detection suppression event tree for the fire protection strategy defined above.

**Solution:**


The above strategy is reflected in the event tree depicted in Figure 8 (similar to the one described in Appendix P of NUREG/CR-6850). The event tree is then applied to each of the fire scenarios producing a non-suppression probability for each. The non-suppression probability results from the summation of the failure to suppress branches in the event tree. The event tree includes the events listed in Table 23:

**Table 23: Events included in the detection suppression event tree**

Sequence	Detection	Suppression
A	Prompt detection	Prompt suppression
B	Prompt detection	Automatic suppression
C	Prompt detection	Fire brigade
D	Prompt detection	Fire brigade failure
E	Prompt detection	Fire brigade
F	Prompt detection	Fire brigade failure
G	Automatic detection	Automatic suppression
H	Automatic detection	Fire brigade
I	Automatic detection	Fire brigade failure
J	Delayed detection	Fire brigade
K	Delayed detection	Fire brigade failure
L	Delayed detection failure	

Prompt detection and prompt suppression are not credited in the analysis since the switchgear access room has no continuous fire watch or is equipped with an incipient fire detection system. Automatic detection is credited since the room has a fire detection system. Fixed automatic suppression is also credited since the room has an automatic CO<sub>2</sub> system. Delayed detection is not credited since time to ignition of the first tray occurs in approximately 7 to 10 min, which is less than the recommended 15 min for delayed detection in NUREG/CR-6850. Finally, manual suppression by the fire brigade could be credited but will not have any impact since the CO<sub>2</sub> release is expected to occur first and the room must remain close during the CO<sub>2</sub> soak time.

**Figure 8: Detection/suppression event tree for the switchgear access room**



### **Workshop Problem 11a-10**

#### **Step 9a: Calculate Conditional Non-Suppression Probability and Severity Factor:**

Determine the severity factor and the non-suppression probability for scenario 1.

#### **Solution:**

This scenario consists of a fire propagating to cable trays above. From Table 9, a heat release rate of approximately 13 to 23 kW (based on plume results) is necessary for a fire to affect the cables above. For the purpose of this example, a value of 15 kW is selected. Per Table 1, the ignition source is assigned a Case 3 probability distribution for heat release rate from Table E-1 in NUREG/CR-6850. This is a Gamma distribution with  $\alpha = 1.6$  and  $\beta = 41.5$ . The severity factor values for heat release rates greater than 15 kW is (using the gamma distribution function in Microsoft Excel):

$$SF = 1 - \text{GAMMADIST}(15, 1.6, 41.5, \text{TRUE}) = 0.89$$

This is interpreted as the probability of a fire spreading to the cable trays above.

Solving the event tree depicted in Figure 8 for a damage time of 5 min, the non suppression probability is  $\approx 0.1$ . The solution of the event tree is presented in Figure 9. The general inputs to the event tree are listed in Table 24. Additional inputs to the event tree, developed from the fire modeling analysis described in the previous step are listed in

Table 25.

**Table 24: General inputs to detection/suppression event tree**

Prompt Detection:	FALSE
Auto Det:	TRUE
Prompt Suppression:	FALSE
Fixed Suppression:	TRUE
Fixed Supp Type:	Automatic
Supp Agent:	CO2
Delay time (Min):	1
Brigade Arrival (min):	15
Target Damage (min):	5
Det reliability:	0.95
Supp system reliability:	0.95
Traditional Sprinklers:	FALSE
HEP:	1
Supp Curve (Table P-3):	Electrical Fires

**Table 25: Fire modeling inputs to detection/suppression event tree**

Time to (Min)	
Ignition:	0
Prompt Det:	0
Prompt Supp:	0
Auto Det:	1
Fixed Supp:	2
Delayed Det:	15
Target Damage (min):	5

**Figure 9: Solution of the detection/suppression event tree**

Ignition	Prompt Detection	Prompt Suppression	Auto Detection	Fixed Suppression	Delayed Detection	Manual Suppression	Branch	Branch Probability		
0	0	0.00					A	--		
		1.00	0.95	0.95			B	--		
				0.05	0.00		C	0.0E+00		
						1.00		D	--	
			0.05			0.00		E	--	
						1.00		F	0.0E+00	
1	0	0.00	0.95	0.95			G	--		
				0.05	0.00		H	--		
						1.00		I	4.8E-02	
			0.05			0.00		J	--	
							1.00		K	0.0E+00
						0			L	5.0E-02
				1		P <sub>NS</sub>	0.098			

**Workshop Problem 11a-11**

**Step 10a: Calculate Scenario Frequency:** Using the ignition frequency calculated in Task 6 for the ignition sources in the switchgear access room, and the severity factor and non-suppression probability calculated in the previous step for scenario 1, determine the frequency for fire scenario 1.


**Solution:**

Recall that this scenario consists of a fire propagating to a cable tray stack above and generating target damage due to direct flame radiation. This sequence of events is captured in the event tree depicted in Figure 10.

- The first event is the ignition frequency calculated in Task 6 of the Fire PRA as documented in NUREG/CR-6850.
- The second event refers to the fire propagating to the cable tray stack above. The probability of propagating is given by the severity factor calculated in Step 9.
- The third event is defined by the probability of suppressing the fire before target damage, as calculated earlier in Step 9.

Only one outcome in the event tree refers to cable damage before suppression. The frequency of this outcome is 8.8E-5.

**Figure 10: Event tree depicting the sequence of events leading to target damage**



## **Session 11b: Example Problems (Main Control Room Fire Analysis)**

## Workshop Problems for Task 11b: Detailed Fire Modeling in the Main Control Room

### Workshop Problem Set 11b-02 (Solution)

**Step 2.b: Estimate Control Room Fire Frequency:** Using the information provided in this Sample Package, and the above formula copied from NUREG/CR 6850, estimate the frequency of fire for the SNPP MCR.

$W_{L, MCR} = 1$  per N/A  
There is only one unit and one MCR for the unit.

$\lambda_{MCB} = 2.5E-03$  per reactor year  
From Table 6-1 of NUREG/CR 6850, bin # 4

$W_{PWC, Elec. Cab, MCR.} = 7.4E-03$  per N/A  
From Results of Task 6 Problem Set 06-09

$\lambda_{PWC, Elec. Cab.} = 4.5E-02$  per reactor year  
From Table 6-1 of NUREG/CR 6850, bin # 15

$W_{transients, MCR} = 0.64$  per N/A  
From Task 6 Calculations

$\lambda_{transient} = 3.9E-03$  per reactor year  
From Table 6-1 of NUREG/CR 6850, bin # 7

$W_{welding, MCR} = 0.2$  per N/A  
From Task 6 Calculations

$\lambda_{welding} = 9.7E-03$  per reactor year  
From Table 6-1 of NUREG/CR 6850, bin # 6

$W_{Cable, MCR} = 0.35$  per N/A  
From Task 6 Calculations

$\lambda_{cable} = 1.6E-03$  per reactor year  
From Table 6-1 of NUREG/CR 6850, bin # 5

$$\begin{aligned}\lambda_{MCR} &= 1 \times (2.5E-03 + 7.4E-03 \times 4.5E-02 + 0.64 \times 3.9E-03 + 0.2 \times 9.7E-03 + 0.35 \times 1.6E-03) = \\ &= 2.5E-03 + 3.3E-04 + 2.5E-03 + 1.9E-03 + 5.6E-04 = 7.79E-03 \text{ per reactor year}\end{aligned}$$

**Workshop Problem Set 11b-05 (Solution)**

**Step 5.b: Identify and characterize target sets:** Identify at least five target sets for the Main Control Room by inspecting drawings DWG A-07 and A-09 and other information provided in this Sample Package.

Target Set ID	Items in the target set	Basis for selecting target set
MCR-01	Control room habitability	Of potential scenarios involving control room abandonment without any damage to the Main Control Board, a fire in the kitchen could be severe enough forcing the operators out.
MCR-02	Service water controls CCW Controls	Service water and CCW are controlled from a small part of the Main Control Board. A fire within CB-7 may fail both systems. Loss of Service Water alone, may have a significant CCDP.
MCR-03	HPI-A High pressure safety injection pump A HPI-B High pressure safety injection pump B RHR-B RHR pump AOV-2 (SOV-2) Letdown isolation valve AOV-3 (SOV-3) Charging pump injection valve MOV-1 HPI valve MOV-2 VCT isolation valve MOV-3 Cont. sump recirc valve MOV-4 Cont. sump recirc valve MOV-5 RWST isolation valve MOV-6 RWST isolation valve MOV-7 RHR inboard suction valve MOV-8 RHR outboard suction valve MOV-9 HPI valve LI-1 RWST level LI-2 RWST level LI-3 Cont. sump level LI-4 Cont. sump level TI-1 Letdown heat exchanger outlet temp	CB-5 contains a large number of safety related component controls. A fire limited to this part of the panel, affecting the equipment controlled from this panel may have a significant CCDP.

Target Set ID	Items in the target set	Basis for selecting target set
MCR-04	AFW-A Motor driven AFW pump A AFW-C Motor driven AFW pump C MOV-10 AFW discharge valve MOV-11 AFW discharge valve MOV-14 AFW turbine steam line isolation valve MOV-15 AFW steam inlet throttle valve MOV-16 AFW test line isolation valve MOV-17 AFW test line isolation valve MOV-18 AFW C Pump Discharge MOV-19 AFW test line isolation valve A-1 AFW motor high temp	CB-3 contains all post shutdown secondary cooling equipment controls. A fire limited to this part of the panel, affecting the equipment controlled from this panel may have a significant CCDP.
MCR-05	HPI-A High pressure safety injection pump A HPI-B High pressure safety injection pump B AOV-2 (SOV-2) Letdown isolation valve MOV-2 VCT isolation valve LI-3 Cont. sump level LI-4 Cont. sump level AFW-A Motor driven AFW pump A AFW-C Motor driven AFW pump C MOV-14 AFW turbine steam line isolation valve MOV-15 AFW steam inlet throttle valve	The shortest distance between the controls of the HPI and AFW systems that can render the pumps from both system inoperable is the distance from MOV-15 control switch to HPI-A control switch. Loss of both systems may have a significant CCDP.

## Workshop Problem Set 11b-06 (Solution)

### Steps 6.b: Identify and Characterize Ignition Sources:

**Steps 7.b: Define Fire Scenarios:** For the target sets provided in the solution of the preceding problem set, identify the corresponding ignition sources and fire scenarios.

Target Set ID	Ignition Sources	Fire Scenarios
MCR-01	1. Water heater in the kitchen	<u>MCR-01.1.</u> An electrical short in the water heater leads to a fire in the kitchen that becomes severe enough to lead to control room abandonment.
	2. Microwave oven in the kitchen	<u>MCR-01.2.</u> An electrical short in the microwave oven or a food item fire inside the oven leads to a fire in the kitchen that becomes severe enough to lead to control room abandonment.
MCR-02	1. Main Control Board – Fire in CB-7	<u>MCR-02.1.</u> A fire inside Main Control Board due to internal causes. The fire initiates inside CB-7. Operator response in putting the fire is not fast enough to prevent damage to CB-7 contents. But the fire is controlled before it propagates to other parts of the panel.
	2. Transient fire	<u>MCR-02.2.</u> A transient fire inside Main Control Room, but outside the Main Control Board, occurs near CB-7 such that only CB-7 is affected either because of the location of the fire or fire fighting efforts.
	3. Transient fire due welding and cutting	<u>MCR-02.3.</u> A transient fire due to welding and cutting inside Main Control Room, but outside the Main Control Board, occurs near CB-7 such that only CB-7 is affected either because of the location of the fire or fire fighting efforts.
	4. Cable fire due welding and cutting.	<u>MCR-02.4.</u> A cable fire occurs due to welding and cutting inside Main Control Board occurs near CB-7 such that only CB-7 is affected because fire fighting efforts limit the reach of the fire.
MCR-03	1. Main Control Board – Fire in CB-5	<u>MCR-03.1.</u> A fire inside Main Control Board due to internal causes. The fire initiates inside CB-5. Operator response in putting out the fire is not fast enough to prevent damage to CB-5 contents. But the fire is controlled before it propagates to other parts of the panel.
	2. Transient fire	<u>MCR-03.2.</u> A transient fire inside Main Control Room, but outside the Main Control Board, occurs near CB-5 such that only CB-5 is affected either because of the location of the fire or fire fighting efforts.
	3. Transient fire due welding and cutting	<u>MCR-03.3.</u> A transient fire due to welding and cutting inside Main Control Room, but outside the Main Control Board, occurs near CB-5 such that only CB-5 is affected either because of the location of the fire or fire fighting efforts.

Target Set ID	Ignition Sources	Fire Scenarios
	4. Cable fire due welding and cutting.	<u>MCR-03.4.</u> A cable fire occurs due to welding and cutting inside Main Control Board occurs in CB-5 such that only CB-5 is affected because fire fighting efforts limit the reach of the fire.
MCR-04	1. Main Control Board – Fire in CB-3	<u>MCR-04.1.</u> A fire inside Main Control Board due to internal causes. The fire initiates inside CB-3. Operator response in putting the fire is not fast enough to prevent damage to CB-3 contents. But the fire is controlled before it propagates to other parts of the panel.
	2. Transient fire	<u>MCR-04.2.</u> A transient fire inside Main Control Room, but outside the Main Control Board, occurs near CB-3 such that only CB-3 is affected either because of the location of the fire or fire fighting efforts.
	3. Transient fire due welding and cutting	<u>MCR-04.3.</u> A transient fire due to welding and cutting inside Main Control Room, but outside the Main Control Board, occurs near CB-3 such that only CB-3 is affected either because of the location of the fire or fire fighting efforts.
	4. Cable fire due welding and cutting.	<u>MCR-04.4.</u> A cable fire occurs due to welding and cutting inside Main Control Board occurs in CB-3 such that only CB-3 is affected because fire fighting efforts limit the reach of the fire.
MCR-05	1. Main Control Board – Fire starting either in CB-3 or in CB-5	<u>MCR-05.1.</u> A fire inside Main Control Board due to internal causes. The fire initiates inside CB-3 or CB-5. Operator response in putting the fire is not fast enough to prevent damage to the postulated target set. But the fire is controlled before it propagates to other parts of the panel.
	2. Transient fire	<u>MCR-05.2.</u> A transient fire inside Main Control Room, but outside the Main Control Board, occurs near CB-3 and CB-5 such that only the postulated target set is affected either because of the location of the fire or fire fighting efforts.
	3. Transient fire due welding and cutting	<u>MCR-05.3.</u> A transient fire due to welding and cutting inside Main Control Room, but outside the Main Control Board, occurs near CB-3 and CB-5 such that only the postulated target set is affected either because of the location of the fire or fire fighting efforts.
	4. Cable fire due welding and cutting.	<u>MCR-05.4.</u> A cable fire occurs due to welding and cutting inside Main Control Board occurs in CB-3 or CB-5 such that only the postulated target set is affected because fire fighting efforts limit the reach of the fire.

## Workshop Problem Set 11b-07 (Solution)

### *Step 8b: Conduct Fire Growth and Propagation Analysis*

**Step 9b: Detection and Suppression Analysis and Severity Factor:** Using the information provided in the solution to Problem Sets 11b-05 and 06 and Figure L-1, conduct fire propagation, detection and suppression analysis for the following fire scenarios and calculate scenario frequency:

#### MCR-03.1

The farthest distance between the postulated control devices on the board is 4 ft.

$$d = 4 \text{ ft} = 1.2 \text{ m}$$

Assumed non-qualified cables since a portion of the cables are non-qualified. From Figure L-1 it is concluded:

$$[\text{SFxP}_{\text{NS}}]_{\text{MCR-03.1}} = 3.0\text{E-03}$$

$$\lambda_{\text{MCR-03.1}} = 2.5\text{E-03} \times 3.0\text{E-03} = 7.5\text{E-06} \text{ per reactor year}$$

#### MCR-04.1

The farthest distance between the postulated control devices on the board is 2 ft.

$$d = 2 \text{ ft} = 0.6 \text{ m}$$

Assumed non-qualified cables since a portion of the cables are not qualified. From Figure L-1 it is concluded:

$$[\text{SFxP}_{\text{NS}}]_{\text{MCR-04.1}} = 5.0\text{E-03}$$

$$\lambda_{\text{MCR-04.1}} = 2.5\text{E-03} \times 5.0\text{E-03} = 1.25\text{E-05} \text{ per reactor year}$$



<b>NRC FORM 335</b> (9-2004) NRCMD 3.7  <p style="text-align: center;"><b>BIBLIOGRAPHIC DATA SHEET</b>  <i>(See instructions on the reverse)</i></p>	<b>U.S. NUCLEAR REGULATORY COMMISSION</b>  1. REPORT NUMBER <i>(Assigned by NRC, Add Vol., Supp., Rev., and Addendum Numbers, if any.)</i>  NUREG/CP-0194 Volume 3				
2. TITLE AND SUBTITLE  Methods for Applying Risk Analysis to Fire Scenarios (MARIAFIRES) - 2008, NRC-RES/EPRI Fire PRA Workshop, Volume 3 - Module 3: Fire Analysis	3. DATE REPORT PUBLISHED <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">MONTH</td> <td style="text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">July</td> <td style="text-align: center;">2010</td> </tr> </table>	MONTH	YEAR	July	2010
	MONTH	YEAR			
July	2010				
4. FIN OR GRANT NUMBER  					
5. AUTHOR(S)  Compiled and edited by D. Stroup, F. Gonzalez, and H. Woods (NRC)	6. TYPE OF REPORT Conference Proceedings				
	7. PERIOD COVERED <i>(Inclusive Dates)</i>  				
8. PERFORMING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, provide Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address; if contractor, provide name and mailing address.)</i> U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research (RES), Washington, DC 20555-0001 Electric Power Research Institute (EPRI), 3420 Hillview Avenue, Palo Alto, CA 94303					
9. SPONSORING ORGANIZATION - NAME AND ADDRESS <i>(If NRC, type "Same as above"; if contractor, provide NRC Division, Office or Region, U.S. Nuclear Regulatory Commission, and mailing address.)</i> U.S. Nuclear Regulatory Commission, Office of Nuclear Regulatory Research (RES), Washington, DC 20555-0001 Electric Power Research Institute (EPRI), 3420 Hillview Avenue, Palo Alto, CA 94303					
10. SUPPLEMENTARY NOTES NRC-RES/EPRI Fire PRA Workshops conducted Sept. 28 - Oct. 2, 2008 and Nov. 17-20, 2008 in Bethesda, MD					
11. ABSTRACT <i>(200 words or less)</i> <p>The U.S. Nuclear Regulatory Commission (NRC) approved the risk-informed and performance-based alternative regulation 10 CFR 50.48(c) in July 2004, which allows licensees the option of using fire protection requirements contained in the National Fire Protection Association (NFPA) Standard 805, "Performance Based Standard for Fire protection for Light-Water Reactor Electric Generating Plants, 2001 Edition," with certain exceptions. To support licensees' use of that option, the NRC and the Electric Power Research Institute (EPRI) jointly issued NUREG/CR-6850 (EPRI 1011989) "Fire PRA Methodology for Nuclear Power Facilities," in September 2005. That report documents the state-of-the-art methods, tools, and data for conducting a fire Probabilistic Risk Assessment (PRA) in a commercial nuclear power plant (NPP) application. Since the release of NUREG/CR-6850 in 2005, the NRC-RES and EPRI have conducted a number of joint public workshops to provide training in the use of the methodologies and tools contained in the document. The workshops have attracted both domestic and international. The material in this NUREG/CP was recorded during two workshops conducted in 2008. It was adapted by NRC-RES Fire Research Branch (FRB) members for use as an alternative training method for those who were unable to physically attend the training sessions. This report can also serve as a refresher for those who attended one or more training sessions, and would be useful preparatory material for those planning to attend a session.</p>					
12. KEY WORDS/DESCRIPTORS <i>(List words or phrases that will assist researchers in locating the report.)</i>  fire, performance-based, risk-Informed regulation, fire hazard analysis (FHA), fire safety, fire protection, nuclear power plant, probabilistic risk assessment (PRA), fire modeling, circuit analysis	13. AVAILABILITY STATEMENT unlimited				
	14. SECURITY CLASSIFICATION <i>(This Page)</i> unclassified  <i>(This Report)</i> unclassified				
	15. NUMBER OF PAGES				
	16. PRICE				



## Export Control Restrictions

Access to and use of this report is granted with the specific understanding and requirement that responsibility for ensuring full compliance with all applicable U.S. and foreign export laws and regulations is being undertaken by you and your company. This includes an obligation to ensure that any individual receiving access hereunder who is not a U.S. citizen or permanent U.S. resident is permitted access under applicable U.S. and foreign export laws and regulations. In the event you are uncertain whether you or your company may lawfully obtain access to this report, you acknowledge that it is your obligation to consult with your company's legal counsel to determine whether this access is lawful. Although EPRI may make available on a case-by-case basis an informal assessment of the applicable U.S. export classification for specific report, you and your company acknowledge that this assessment is solely for informational purposes and not for reliance purposes. You and your company acknowledge that it is still the obligation of you and your company to make your own assessment of the applicable U.S. export classification and ensure compliance accordingly. You and your company understand and acknowledge your obligations to make a prompt report to EPRI and the appropriate authorities regarding any access to or use of this report hereunder that may be in violation of applicable U.S. or foreign export laws or regulations.

Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc.

 Printed on recycled paper in the United States of America

EPRI 1020621

## The Electric Power Research Institute (EPRI)

The Electric Power Research Institute (EPRI), with major locations in Palo Alto, California, and Charlotte, North Carolina, was established in 1973 as an independent, nonprofit center for public interest energy and environmental research. EPRI brings together members, participants, the Institute's scientists and engineers, and other leading experts to work collaboratively on solutions to the challenges of electric power. These solutions span nearly every area of electricity generation, delivery, and use, including health, safety, and environment. EPRI's members represent over 90% of the electricity generated in the United States. International participation represents nearly 15% of EPRI's total research, development, and demonstration program.

Together...Shaping the Future of Electricity

United States Nuclear Regulatory Commission  
Washington, D.C.

NUREG/CP - 0194

---

### ELECTRIC POWER RESEARCH INSTITUTE

3420 Hillview Avenue, Palo Alto, California 94304-1395 • PO Box 10412, Palo Alto, California 94303-0813 USA  
800.313.3774 • 650.855.2121 • [askepri@epri.com](mailto:askepri@epri.com) • [www.epri.com](http://www.epri.com)

