

From: Hamm, Matthew
Sent: Friday, July 16, 2010 1:46 PM
To: Mann, Brian
Cc: Bucholtz, Kristy; Elliott, Robert; Miller, Barry
Subject: Mark up of STS page for Revision of TSTF-513 and TSTF-514
Attachments: TSTF 514 rev 2.docx; TS Mark-ups for TSTF-513 Rev 3.pdf

Brian,

As discussed during the TSTF/NRC meeting on 7/15/2010, the portions of TSTF-513 and TSTF-514 that would allow continued operation for up to 72 hours with no operable leakage detection methods should be changed. The Required Action for Proposed Condition D in NUREG-1430, Proposed Condition F in NUREGs 1431, 1432, 1433, and 1434 should be changed to "Enter LCO 3.0.3" with a Completion Time of "Immediately." The corresponding STS Bases sections should be changed accordingly.

I have attached marked up versions of the TS for each Traveler. Please call if you have any questions.

Thank You,

Matthew Hamm
Reactor Engineer, Technical Specifications Branch
U. S. Nuclear Regulatory Commission
301-415-1472
Matthew.Hamm@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: Mark up of STS page for Revision of TSTF-513 and TSTF-514
Sent Date: 7/16/2010 12:34:26 PM
Received Date: 7/16/2010 1:46:00 PM
From: Hamm, Matthew

Created By: Matthew.Hamm@nrc.gov

Recipients:

brianm@excelservices.com (Mann, Brian)
Tracking Status: None
Kristy.Bucholtz@nrc.gov (Bucholtz, Kristy)
Tracking Status: None
Robert.Elliott@nrc.gov (Elliott, Robert)
Tracking Status: None

Barry.Miller@nrc.gov (Miller, Barry)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	818749	7/16/2010
TSTF 514 rev 2.docx	61438	
TS Mark-ups for TSTF-513 Rev 3.pdf	745043	

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: