

**From:** Guzman, Richard  
**Sent:** Monday, February 01, 2010 11:55 AM  
**To:** Darling, Theresa H; Dosa, John J  
**Subject:** RE: Follow-up re: Piping & NDE Call

John, Theresa -

For D1, the staff would like to understand the NMP2 application of the GE BWROG TR relative to the associated 10 CFR requirements. In other words, how is the criteria being changed in reference to the TR, and still meeting all associated requirements (e.g., 10 CFR 50 App R).

For D3, the staff requests clarification to NMP2 core cooling assurance using RCIC or pseudo LPCI, and actions needed to get plant to cold S/D. Is licensee/NMP2 relying on RCIC until operator can get to remote S/D panel? Is licensee's approach consistent with the regulations?

Sorry for the delay in getting this additional info to you.

Rich Guzman  
301-415-1030

---

**From:** Darling, Theresa H [mailto:Theresa.Darling@cengllc.com]  
**Sent:** Monday, February 01, 2010 10:25 AM  
**To:** Guzman, Richard  
**Cc:** Dosa, John J  
**Subject:** RE: Follow-up re: Piping & NDE Call

Yes we have this action. Do you have the questions from the Fire Protection Branch on D1 or D3?

---

**From:** Guzman, Richard [mailto:Richard.Guzman@nrc.gov]  
**Sent:** Monday, February 01, 2010 10:24 AM  
**To:** Darling, Theresa H  
**Subject:** Follow-up re: Piping & NDE Call

Theresa,

I understand from Jay Wallace that the question we had on the MSIP weld was addressed - specifically, that the weld (2RPV-KC-32) does not have a weld overlay and it will be inspected every 6 years per BWRVIP-75. I understand that you can provide a supplement on the docket. I recommend that you reference the 1/27 phone call in the letter.

Please confirm you have this for action and advise when I should expect the letter.

Thanks,  
Rich

*Rich Guzman*  
*Sr. Project Manager*  
*NRR/DORL*  
*US NRC*  
*301-415-1030*  
[Richard.Guzman@nrc.gov](mailto:Richard.Guzman@nrc.gov)

>>> This e-mail and any attachments are confidential, may contain legal, professional or other privileged information, and are intended solely for the addressee. If you are not the intended recipient, do not use the information in this e-mail in any way, delete this e-mail and notify the sender. CEG-IP2

---

### E-mail Properties

Mail Envelope Properties (92E0E77F3622DA40B501E8D45083D5D9508499081F)

Subject: RE: Follow-up re: Piping & NDE Call  
Sent Date: 2/1/2010 10:40:34 AM  
Received Date: 2/1/2010 11:54:00 AM  
From: Guzman, Richard

Created By: Richard.Guzman@nrc.gov

Recipients:

Theresa.Darling@cengllc.com (Darling, Theresa H)  
Tracking Status: None  
John.Dosa@cengllc.com (Dosa, John J)  
Tracking Status: None

Post Office:  
HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	12518	2/1/2010

Options

Expiration Date:  
Priority: o!ImportanceNormal  
ReplyRequested: False  
Return Notification: False

Sensitivity: o!Normal  
Recipients received: