

PMSTPCOL PEmails

From: Govan, Tekia
Sent: Thursday, July 15, 2010 10:45 AM
To: 'Bense, Richard'
Cc: STPCOL
Subject: FW: Request For Additional Information Letter No. 351 Related To SRP Section 2.5.4 For The South Texas Project Combined License Application
Attachments: ML101950581.pdf

Tekia V. Govan, Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors
MS T-6-D48
Washington DC 20555-0001
301-415-6197
Tekia.Govan@nrc.gov

From: Keith, Felicia
Sent: Thursday, July 15, 2010 9:50 AM
To: Bill Mookhoek; Chappell, Coley; Scott Head
Cc: Govan, Tekia
Subject: Request For Additional Information Letter No. 351 Related To SRP Section 2.5.4 For The South Texas Project Combined License Application

To: Scott Head

From: Tekia Govan

Date: July 14, 2010

ADAMS: ML101950581
Felicia Keith, Administrative Assistant
U. S. Nuclear Regulatory Commission
MS T-638M
Washington, DC 20555-0001
Felicia.Keith@nrc.gov

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2277

Mail Envelope Properties (F5A4366DF596BF458646C9D433EA37D72F849734D4)

Subject: FW: Request For Additional Information Letter No. 351 Related To SRP Section 2.5.4 For The South Texas Project Combined License Application
Sent Date: 7/15/2010 10:45:25 AM
Received Date: 7/15/2010 10:45:26 AM
From: Govan, Tekia

Created By: Tekia.Govan@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Bense, Richard" <rhbense@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	775	7/15/2010 10:45:26 AM
ML101950581.pdf	82454	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

July 14, 2010

Mr. Scott Head, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 351 RELATED TO
SRP SECTION 2.5.4 FOR THE SOUTH TEXAS PROJECT COMBINED
LICENSE APPLICATION

Dear Mr. Head

By letter dated September 20, 2007, STP Nuclear Operating Company (STP) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **45** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-6197 or by e-mail at Tekia.Govan@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tekia V. Govan, Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013
eRAI Tracking No. 4824

Enclosure:
Request for Additional Information

cc: William Mookhoek
Richard Bense

S. Head

-2-

If you have any questions or comments concerning this matter, I can be reached at 301-415-6197 or by e-mail at Tekia.Govan@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tekia V. Govan, Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013
eRAI Tracking No. 4824

Enclosure:
Request for Additional Information

cc: William Mookhoek
Richard Bense

DISTRIBUTION:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BAbeywickrama, NRO
WBieganousky, NRO
FVega, NRO
RKaras, NRO
RidsNroDserRsac
RidsNroDnrlNge2

ADAMS Accession No. ML101950581

NRO-002

OFFICE	RGS1	RGS1	NGE2/PM	NGE2/L-PM
NAME	WBieganousky	RKaras	TGovan	GWunder
DATE	6/16/2010	6/16/2010	7/13/2010	7/14/2010

***Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information No. 4824 Revision 3

**South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013**

**SRP Section: 02.05.04 - Stability of Subsurface Materials and Foundations
Application Section: 2.5.4.5**

QUESTIONS for Geosciences and Geotechnical Engineering Branch 1 (RGS1)

02.05.04-37

In your response to RAI 2.5.4-36 you provided updated ITAACS for backfill, shear wave velocity and settlement in Table 3.0-11, "Backfill Under Seismic Category 1 Structures" and Table 3.0-13, "Settlement". With respect to the third ITAAC regarding the engineering properties of backfill, and in accordance with 10 CFR 100.23, please specify the tests to be performed, frequency of testing, and test standard employed (ASTM, USACE), in the "Inspections, Tests, and Analyses" column of the ITAAC.

Enclosure