

 Create another New Issue
  Create another Issue from '009f6938'

[Print](#)
[Close window](#)

****AS REQUIRED, PRINT ISSUE REPORT AND PROVIDE TO YOUR SUPERVISOR****
Note: This is your only notice. You will not have an opportunity to print this confirmation later.

Exelon Nuclear Issue - Statement of Confirmation

Issue #: 00916938 **Originator:** JAMES J VOUGLITOIS **Submit Date:** May 7, 2009

Basic Information

Affected Facility: Oyster Creek
Dscv Date: 05/07/2009 11:15
How Discovered Code: H02
Event Date: 05/07/2009 11:15
Affected Unit: NA
Affected Sys: --
Subject: NRC RECOMMENDS SAMPLING ADDITIONAL MONITORING WELL

Required Information

Condition Description: While interviewing Chemistry staff regarding the groundwater monitoring program associated with the condensate leaks from buried pipes during an inspection visit, an NRC inspector recommended that an additional off-site well in the Kirkwood Aquifer (W-4K) be included in the monitoring program. The inspector understands that there is no technical reason to believe that the Kirkwood Aquifer has been contaminated. However, from a public relations point of view, he feels that we should include this Kirkwood monitoring well in our sampling program in order to provide assurance to the public that the on-site groundwater contamination is not migrating to off-site wells.

Immediate actions taken: Discussed with Supervisor and wrote this IR.

Recommendation for action: Chemistry consider the NRC inspector's recommendation and determine if the additional well should be included in the monitoring program.

Supervisor Verbally Contacted: M. Nixon

Optional Additional Information

What activities, processes, or procedures were involved? Interview with NRC inspector.

Why did the condition happen? NA

What are the consequences? Additional costs associated with more sampling and analysis.

Any procedural requirements impacted? None

Identify any adverse physical conditions: NA

List of Knowledgeable individuals: J. Vouglitois, M. Nixon, J. Kandasamy

Is this a repeat or similar condition? No

Routing

A5332CAP

