

AP1000DCDFileNPEm Resource

From: Buckberg, Perry
Sent: Tuesday, July 20, 2010 11:39 AM
To: DeBlasio, John J.
Cc: Melton, Michael A; Ziesing, Rolf F.; Sisk, Robert B.; McKenna, Eileen
Subject: RE: Draft Rev 2 of RAI-SRP5 2 3-CIB1-03 (Quickloc)

John,

Regarding RAI-SRP 5.2.3-CIB1-02 (Quickloc)...the staff does not agree with the ISI COL Item Westinghouse proposed on 7/16/10. In order to facilitate the closure of this item, the wording of the COL item should read:

The Combined License holder will establish an in-service inspection program prior to fuel load. The in-service inspection program will include the performance of a 100 percent volumetric examination of the weld build-up on the reactor vessel head for the instrumentation penetrations (Quickloc) conducted once during each 120-month inspection interval in accordance with the ASME Code, Section XI. The weld build-up shall meet the acceptance standards of ASME Code, Section XI, IWB-3512. Personnel performing examinations and the ultrasonic examination systems shall be qualified in accordance with ASME Code, Section XI, Appendix VIII. Alternatively, the Combined License holder may develop an alternative inspection in conjunction with the voluntary consensus standards bodies (i.e., ASME) and submitted to the NRC for approval.

Thanks,

Perry Buckberg

Senior Project Manager
Nuclear Regulatory Commission
Office of New Reactors
phone: (301)415-1383
fax: (301)415-5397
perry.buckberg@nrc.gov

From: DeBlasio, John J. [mailto:deblasjj@westinghouse.com]
Sent: Friday, July 16, 2010 10:28 AM
To: Buckberg, Perry
Subject: Fw: Draft Rev 2 of RAI-SRP5 2 3-CIB1-03 (Quickloc)

For some reason this failed.

From: DeBlasio, John J.
To: Buckberg, Perry <Perry.Buckberg@nrc.gov>
Cc: Ziesing, Rolf F.; Sisk, Robert B.; Brehm, Jason A (Notes)
Sent: Thu Jul 15 15:48:42 2010
Subject: FW: Draft Rev 2 of RAI-SRP5 2 3-CIB1-03 (Quickloc)

Attached is the quickloc with the revisions . Please take a look and determine if acceptable.

From: Wiseman, Dale A.
Sent: Thursday, July 15, 2010 12:37 PM
To: DeBlasio, John J.
Cc: Wiseman, Dale A.
Subject: Draft Rev 2 of RAI-SRP5 2 3-CIB1-03 (Quickloc)

John,

Attached is the draft Revision 2 of RAI-SRP5 2 3-CIB1-03. This revision includes the responses to the NRC comments relative to 1)the in-service inspection of the weld buildup for the Quicklocs on the reactor vessel head and 2)Note 9 from the design drawing.

I have highlighted in yellow the Revision 2 NRC comments, the Westinghouse responses, and the DCD markup associated with the Revision 2 responses.

Dale

Hearing Identifier: AP1000_DCD_Review
Email Number: 494

Mail Envelope Properties (Perry.Buckberg@nrc.gov20100720113800)

Subject: RE: Draft Rev 2 of RAI-SRP5 2 3-CIB1-03 (Quickloc)
Sent Date: 7/20/2010 11:38:56 AM
Received Date: 7/20/2010 11:38:00 AM
From: Buckberg, Perry

Created By: Perry.Buckberg@nrc.gov

Recipients:

"Melton, Michael A" <melto1ma@westinghouse.com>
Tracking Status: None
"Ziesing, Rolf F." <ziesinrf@westinghouse.com>
Tracking Status: None
"Sisk, Robert B." <sisk1rb@westinghouse.com>
Tracking Status: None
"McKenna, Eileen" <Eileen.McKenna@nrc.gov>
Tracking Status: None
"DeBlasio, John J." <deblasjj@westinghouse.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2482	7/20/2010 11:38:00 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: