| ISOMETRIC OF SAFETY INJECTION LINE Nº 350 INSIDE CONTAINMENT | INDIAN POINT Nº2 | B 206901 |
|---|---|---|




## VALVE BONNET BOLTING

| VALVE NO. | VALVE TYPE | NO. OF BOLTS | BOLT DIA. | BOLT TYPE | VALVE MANUFACTURER | MANUFACTURER DWG. NO. |
|---|---|---|---|---|---|---|
| 894D | 10-VM58FM | 16 | 1 7/8" | STUD BOLTS | DARLING | 11663 |
| 895D | 10-C487 | 16 | | | DARLING | 11542 |
| 897D | 10-C487 | 16 | | | DARLING | 11542 |




KEY PLAN

## REVISIONS

0 — THIS ISSUE IS NON-CLASS "A" PER CI 240-1. RELEASE FOR RECORD. P.N. 7076 11-3-78

1 — THIS REVISION IS NON-CLASS "A" PER CI-240-1. UPDATED DWG. TO SHOW WORK ON DWG. 9321-F-2617, THRU REV. 22. ADDED REF. DRAWINGS. ADDED LATEST REV. Nº TO REF. DRAWINGS. RELEASE FOR RECORD. P.N. 7076 RT/AS EBASCO SERVICES, INC. 1-10-80

4 — THIS REVISION IS CLASS "A" PER 240-1, UPDATED DWG. PER INSERVICE INSPECTION. FIELD REVISION INFORMATION RELEASE FOR RECORD P.N. 69911-EI J.S.

2 — THIS REVISION IS NON CLASS "A" PER CI-240-1. ADDED LATEST REV. Nº TO REF. DWG'S. RELEASE FOR RECORD. P.N. 21368 TREADWELL CORP. 11-12-82.

3 — THIS REV. IS NON CLASS PER CI-240-1 CHANGED DISCIPLINE CODE FROM WJ TO ML. RELEASE FOR RECORD P.N. 69946E1 A.G.

NOT FOR FABRICATION OR INSTALLATION

NOT FOR FABRICATION OR INSTALLATION

## REFERENCE DRAWINGS

FLOW DIAGRAM-SAFETY INJECTION SYSTEM ——— A235296
CONTAINMENT BUILDING
SAFETY INJECTION SYSTEM-PLAN-SHEET Nº 2 ——— 9321-F-2617
CONTAINMENT BUILDING
SAFETY INJECTION SYSTEM-SECTIONS-SHEET Nº 2 ——— 9321-F-2626

## GENERAL NOTES

1. QUALITY GROUP B PORTION OF LINE Nº 350 FROM VALVE 895 D TO AND INCLUDING ACCUMULATOR Nº 24 EXEMPT FROM NDT REQUIREMENTS PER IWC-1221(c), STATICALLY PRESSURIZED, PASSIVE PWR S.I. SYSTEM.
2. WELDS LESS THAN 2 1/2" NOM. PIPE DIA - SOCKET-WELDED 2 1/2" AND LARGER - BUTT WELDED
3. WELDS IN QUALITY GROUP A PIPING, ONE INCH NOM. PIPE DIA OR LESS EXEMPT FROM NDT REQUIREMENTS PER IWB-1220(b).
4. (✱) INDICATES REMOVABLE INSULATION
5. WELDS IN QUALITY GROUP B PIPING 4" NOM. PIPE DIA. OR LESS ARE EXEMPT FROM NDT REQUIREMENTS PER IWC-1221(a)

## TYPICAL WELD DETAIL DRAWINGS

10" CLASS 2501, SCH 140S - D208025
10" CLASS 601, SCH 40S - D208024

## SYMBOL IDENTIFICATION

- SUPPORT NUMBER
- VALVE NUMBER
- WELD NUMBER
- QUALITY GROUP CLASSIFICATION
- INTEGRAL SUPPORT WELD NUMBER

ANSTEC APERTURE CARD

Docket # 50-247
Accession # 7403112 17
Date 2/28/74
Regulatory Docket File

THIS DRAWING CONTAINS ITEMS WHICH MUST BE CONTROLLED WITHIN CON EDISON AS:
**"CLASS A" ITEMS PER CI-240-1**

# B206901-4

**CONSOLIDATED EDISON CO. OF NEW YORK, INC.**

| | |
|---|---|
| STATION LOCATION | INDIAN POINT Nº 2 |
| | INSERVICE INSPECTION ISOMETRIC OF SAFETY INJECTION LINE Nº 350 INSIDE CONTAINMENT ACCUMULATOR Nº 24 DISCHARGE |
| SCALE | NONE |
| DRAWN BY | W. ANDRUSHKO |
| RECOMMENDED | 11/3/78 |
| P.N. | 7076 |
| CHECKED BY | M STEINAUER |
| SHEET | 29 |

APPROVALS: GENERAL ENGINEERING — CHIEF DESIGN ENGINEER; MECHANICAL ENGINEERING — MECH. PLANT ENGINEER; CIVIL ENGINEERING — PLANT STRUCT. ENGINEER; T & D STRUCT. ENGINEER; ELECTRICAL ENGINEERING — STATION ELECT. ENGINEER; T & D. ENGINEER; GAS & STEAM OPERATIONS — STRUCT. ENGINEER; PRODUCTION — CONVENTIONAL POWER; NUCLEAR POWER

ML

FORM 889051